

COMMONWEALTH OF KENTUCKY
BEFORE THE PUBLIC SERVICE COMMISSION

In the Matter of:

THE APPLICATION OF LEVEE ROAD WATER)	
ASSOCIATION FOR A DEVIATION FROM THE)	CASE NO.
REQUIREMENTS OF 807 KAR 5:066,)	2005-00491
SECTION 4(4), REGARDING WATER)	
STORAGE)	

O R D E R

On December 2, 2005, the Levee Road Water Association ("Levee Road") applied for permission to deviate from Commission regulation 807 KAR 5:066, Section 4(4), which requires that each utility maintain minimum water storage of one day's supply of its average daily usage. Levee Road states in its application that its average daily water usage, including unaccounted-for water, is approximately 130,000 gallons, and that its current water storage capacity is 75,000 gallons.

The Commission, having reviewed the application and being otherwise sufficiently advised, finds that:

1. Levee Road is not in compliance with Commission regulation 807 KAR 5:066, Section 4(4).
2. Because of the time needed to plan, finance, and construct water storage facilities, Levee Road should be given until December 2, 2008 to comply with 807 KAR 5:066, Section 4(4).

IT IS THEREFORE ORDERED that:


1. Levee Road is given until December 2, 2008 to comply with the provisions of 807 KAR 5:066, Section 4(4).

2. Levee Road shall take all necessary actions to bring its water storage facilities into compliance with Commission regulations prior to December 2, 2008.

Done at Frankfort, Kentucky, this 17th day of February, 2006.

By the Commission

ATTEST:



Executive Director