

TELECOPY COVER SHEET

If there is a problem with transmission, please call (606) 633-1315 for retransmission.

TO: 1-502-564-3460
FILINGS DIVISION,
Kentucky Public Service Commission
211 Sower Boulevard,
P.O. Box 615
Frankfort, KY 40602-0615

RECEIVED

MAR 26 2007

PUBLIC SERVICE
COMMISSION

FROM: Forrest Cook
PO Box 910
Whitesburg KY 41858-0910
Tel. (606) 633-1315
fcook@bellsouth.net

Re: CVE v. KU, Case No. 2006-00148

Number of pages including this cover page: 6

Comments:

This filing is made by facsimile transmittal March 26, 2007, with the original to be delivered by 5 p.m., March 27, 2007.

This message is intended only for the use of the individual or entity to which it is addressed, and may contain information that is PRIVILEGED, CONFIDENTIAL and exempt from disclosure under applicable law. If the reader of this message is not the intended recipient, or the employee or agent responsible for delivering the message to the intended recipient, you are hereby notified that any dissemination, distribution or copying of this communication is strictly prohibited. If you have received this communication in error, please notify us immediately by telephone, and return the original to us by mail without making a copy. Thank you.

COOK LAW OFFICE

178 Main Street - Suite 2
P.O. Box 910
Whitesburg, Kentucky 41858

(606) 633-1315
fcCook@bellsouth.net

RECEIVED

MAR 26 2007
PUBLIC SERVICE
COMMISSION

March 26, 2007

Ms. Elizabeth O'Donnell
Executive Director
Kentucky Public Service Commission
P.O. Box 615
Frankfort, Kentucky 40602-0615


Re: In the Matter of Cumberland Valley Electric, Inc. versus Kentucky Utilities Company, Case No. 2006-00148

Dear Ms. O'Donnell:

Enclosed please find and accept for filing the original and eight (8) copies of the **Corrected** Response of Black Mountain Resources LLC and Stillhouse Mining LLC to the Commission Staff's Post-Hearing Data Request in Case No. 2006-00148.

Should you have questions concerning the enclosed items, please advise.

Sincerely,



Forrest E. Cook

FEC/fc

Enclosures

cc: Parties of Record

**COMMONWEALTH OF KENTUCKY
BEFORE THE PUBLIC SERVICE COMMISSION**

RECEIVED

MAR 26 2007

**PUBLIC SERVICE
COMMISSION**

IN THE MATTER OF:

CUMBERLAND VALLEY ELECTRIC, INC.)

COMPLAINANT)

v.)

KENTUCKY UTILITIES COMPANY)

DEFENDANT)

CASE NO. 2006-00148

**CORRECTED RESPONSE OF
BLACK MOUNTAIN RESOURCES LLC AND
STILLHOUSE MINING LLC
TO THE COMMISSION STAFF'S
DATA REQUEST
DATED MARCH 14, 2007**

Filed: March 26, 2007

**BLACK MOUNTAIN RESOURCES LLC
AND STILLHOUSE MINING LLC
CASE NO. 2006-00148**

**Corrected Response to Commission Staff's
Data Request
Dated 3/14/07**

Question No. 1

Witness: Richard Matda

Q-1. Provide for the Stillhouse Mine No. 2

- a. the horsepower
- b. the load factor

A-1. a. The horsepower inventory for the Stillhouse No. 2 Mine is as follows:

| <u>Equipment</u> | <u>Horsepower</u> |
|---------------------|-------------------|
| Ventilation Fan | 200.0 |
| Belt Drives (7) | 1,250.0 |
| Belt Take-ups | 145.0 |
| Shuttle Cars | 870.0 |
| Mobile Roof Support | 200.0 |
| Roof Bolters | 200.0 |
| Pressure Pumps | 50.0 |
| Rock Duster | 10.0 |
| Rock Dust Bin | 10.0 |
| Cont. Miner | 790.0 |
| Feeders | 400.0 |
| Discharge Pumps | 165.5 |
| Total | 4,290.5 |

- b. Although there is a meter for the 69 Kv tap (at Lynch Substation) where retail power is delivered to the customer's distribution system, there are no other meters in use. The customer is, therefore, unable to provide the load factor for Stillhouse Mine No. 2. For purposes of accounting, the total charges for electricity purchased from KU are allocated / prorated between mining operations based upon horsepower of electric powered equipment in use at each operating unit.

**BLACK MOUNTAIN RESOURCES LLC
AND STILLHOUSE MINING LLC
CASE NO. 2006-00148**

**Corrected Response to Commission Staff's
Data Request
Dated 3/14/07**

Question No. 2

Witness: Richard Matda

Q-1. Provide for the Timbertree Mine

- a. the horsepower
- b. the load factor

A-1. a. The horsepower inventory for the Timbertree Mine is as follows:

A-1. a. The horsepower inventory for the Timbertree Mine is as follows:

| <u>Equipment</u> | <u>Horsepower</u> |
|------------------|-------------------|
| Ventilation Fan | 200.0 |
| Cont. Miner | 670.0 |
| Shuttle Cars | 290.0 |
| Roof Bolter | 100.0 |
| Pressure Pump | 25.0 |
| Total | 1,285.0 |

***Note: Timbertree is a new operation and not all equipment is in operation.**

- b. Although the Timbertree Mine is metered, the invoice from Cumberland Valley Electric, Inc. does not disclose a power or load factor and the customer is unable to provide this information.

CERTIFICATE OF SERVICE


I hereby certify that a copy of the foregoing Response was served by first-class mail, postage pre-paid, upon the following, March 26, 2007:

Hon. Anthony G. Martin
PO Box 1812
Lexington, KY 40588

Hon. W. Patrick Hauser
200 Knox St.
Box 1900
Barboursville, KY 40906

Hon. J. Gregory Cornett
Stoll Keenon Ogden PLLC
2000 PNC Plaza
500 West Jefferson Street
Louisville, KY 40202-2828

Hon. Allyson K. Sturgeon
Attorney for E.ON U.S. LLC
220 West Main Street
Louisville, KY 40202



Forrest E. Cook
Counsel for Black Mountain Resources LLC and
Stillhouse Mining LLC