

Grayson Rural Electric Cooperative Corporation

109 Bagby Park • Grayson, KY 41143-1292
Telephone 606-474-5136 • 1-800-562-3532 • Fax 606-474-5862

RECEIVED

OCT 18 2010

PUBLIC SERVICE
COMMISSION

October 14, 2010


Mr. Jeff Derouen
Executive Director
Kentucky Public Service Commission
211 Sower Blvd.
P O Box 615
Frankfort, KY 40602-0615

RE; Case No. 2010-00230

Dear Mr. Derouen:

Enclosed you will find Grayson RECC's original and 6 copies of its responses to the Commissions Third Data Request of October 7, 2010.

Sincerely,


Don M. Combs
Mgr. Finance & Accounting

C: Office of the Attorney General

GRAYSON RECC

CASE NO. 2010-00230

RESPONSE TO COMMISSION STAFF'S THIRD DATA REQUEST

1. Refer to Grayson's response to item 1 of the Commission Staff's Second Information Request. This response states that Grayson has mechanical, digital Centron, and digital Focus meters. In addition, it states that TS-1 and TS-2 modules refer to the method of data communication and that they are installed in the base meter.
 - a. Provide the cost of a mechanical base meter.
 - b. Provide the cost of a digital Centron base meter.
 - c. Provide the cost of a digital Focus base meter.
 - d. Provide a description of the difference between a digital Centron base meter and a digital Focus base meter.
 - e. Provide the cost of a TS-1 module.
 - f. Provide the cost of a TS-2 module.

Response:

a. \$29.00

b. \$30.74

c. \$31.78

d. The difference in function are minor, however the Focus meter software has a few more capabilities that meet our desires in measuring on peak and off peak usage. In addition, the focus meter and the Turtle 2 modules are manufactured by Landis Gyr, thus making the Focus meter more compatible.

e. \$27.73

f. 69.38

GRAYSON RECC

CASE NO. 2010-00230

RESPONSE TO COMMISSION STAFF'S THIRD DATA REQUEST

2. Refer to the response to Item 8.b.(2) of Staff's Second Request.
 - a. Grayson did not respond to the request to provide the basis for assuming a 10 percent failure rate. Provide a response.
 - b. Grayson did not respond to the request to provide the manufacturer's warranty on the disconnect module. Provide a response.

Response:

- a. It is an overall failure rate without regards to warranty or not. It means that 10 will be purchased over their life for 9 customers to have full use during it life.
- b. All modules have an (18) eighteen month warranty.