

Appendix B
E.ON Unit Specific Data

E.W. Brown

Black & Veatch AQCS Information Needs

Power Plant: _____
 Unit: _____

Owner: _____
 Project: _____

References:

- 1)
- 2)
- 3)
- 4)

Yellow highlight denotes Critical Focus Needs.

Fuel Data

Ultimate Coal Analysis (% by mass as received):	Typical	Minimum	Maximum	Notes
Carbon			%	
Hydrogen			%	
Sulfur			%	
Nitrogen			%	
Oxygen			%	
Chlorine			%	
Ash			%	
Moisture			%	
Total				
Higher Heating Value, Btu/lb (as received)			Btu/lb	
Ash Mineral Analysis (% by mass):				
Silica(SiO ₂)			%	
Alumina (Al ₂ O ₃)			%	
Titania (TiO ₂)			%	
Phosphorous Pentoxide (P ₂ O ₅)			%	
Calcium Oxide (CaO)			%	
Magnesium Oxide (MgO)			%	
Sodium Oxide (Na ₂ O)			%	
Iron Oxide (Fe ₂ O ₃)			%	
Sulfur Trioxide (SO ₃)			%	
Potassium Oxide (K ₂ O)			%	
Coal Trace Element Analysis (mercury and especially arsenic if fly ash is returned to boiler)				
Vanadium		%		
Arsenic		%		
Mercury		% or ppm		
Other <u>LOI</u>		%		
Natural gas firing capability (if any at all)				
Natural gas line (into the station) capacity (if applicable)				
Current Lost on Ignition (LOI)				
Start-up Fuel				
Ash Fusion Temperature				
Initial Deformation		°F		
Softening		°F		
Hemispherical		°F		
Hardgrove Grindability Index				

Black & Veatch AQCS Information Needs

Power Plant: _____
 Unit: _____

Owner: _____
 Project: _____

Plant Size and Operation Data: (provide for each unit)	Unit 1	Unit 2	Unit 3	Unit X		Notes
Maximum (Design) Fuel Burn Rate	4 * 14.91 Tons/hr	4 * 22.6 Tons/hr	5 * 46.75 Tons		MBtu/hr	# Pulv * Pulv rating
Boiler Type (e.g. wall-fired, tangential fired, cyclone)	Wall-Fired	Tangential Fired	Tangential Fired			
Boiler Manufacturer	B&W	CE	CE			
Net MW Rating (specify plant or turbine MW)	102	169	433		MW	Dispatch Generator Ratings
Gross MW Rating	110	180	457		MW	Dispatch Generator Ratings
Net Unit Heat Rate	9802	9855	9516		Btu/kWh	S&L Design Heat Balance
Net Turbine Heat Rate	8104	8149	8019		Btu/kWh	S&L Design Heat Balance
Boiler SO2 to SO3 Conversion Rate (if known)	na	na	na		%	
Fly Ash/Bottom Ash Split	80/20	80/20	80/20		%	Typical values used on other reports
Flue Gas Recirculation (FGR)						
Installed? (Y/N)	N	N	N			
In operation? (Y/N)						
Flue Gas Recirculation (if installed)					%	
Type of Air Heater	Ljungstrom	Ljungstrom	Ljungstrom			
Air Heater Configuration (horizontal or vertical flow or shaft)	Vertical	Vertical	Vertical			
Design Pressure/Vacuum Rating for Steam Generator	+/-				in wg.	
Design Pressure/Vacuum Rating for Particulate Control	+/-				in wg.	
Electrical / Control						
DCS Manufacturer (e.g. Westinghouse, Foxboro, Honeywell, etc.)						
Type of DCS (e.g. WDPF, Ovation, Net 90, Infi 90, Symphony, TDC 3000, etc.)						
Neural Network Installed? (Y/N)						
Neural Network Manufacturer (e.g. Pegasus, Westinghouse, etc.)						
Extra Capacity available in DCS?						
Historian Manufacturer						
Additional Controls from DCS or local PLC w/tie-in						
Transformer Rating for Intermediate Voltage Switchgear (SUS's) and Ratings of Equipment in These Cubicles						
Auxiliary Electric Limited (Y/N)						
Operating Conditions						
Economizer Outlet Temperature	650	730	730		°F	Typical data from PI historian
Economizer Outlet Pressure	-8	-3.7	-5		in wg.	Typical data from PI historian
Excess Air or Oxygen at Economizer Outlet (full load/min load)	5/8 O2	3/4 O2	2.8/3.3		%	Typical data from PI historian
Economizer Outlet Gas Flow	na	na	na		acfm	
					lb/hr	
Air Heater Outlet Temperature	350	330	340		°F	Typical data from PI historian
Air Heater Outlet Pressure	-14	-8	-18		in wg.	Typical data from PI historian; Unit 1 has back pass dampers
Particulate Control Equipment Outlet Temperature	340	320	330		°F	Typical data from PI historian
Particulate Control Equipment Outlet Pressure	-18	-12	-19		in wg.	Typical data from PI historian
FGD Outlet Temperature (if applicable)	na	na	na		°F	Typical data from PI historian
FGD Outlet Pressure (if applicable)	na	na	na		in wg.	

Black & Veatch AQCS Information Needs

Power Plant: _____
 Unit: _____

Owner: _____
 Project: _____

NOx Emissions	Unit X	Unit X	Unit X	Unit X	Notes
Emissions Limit	0.5	0.45	0.07	lb/MBtu	Units 1 & 2 on averaging plan for Nox so this is target rather
Type of NOx Control (if any) - LNB, OFA, etc.	Inb	Inb, ofa	Inb, ofa		
Current NOx Reduction with existing controls	na	na	na	%	
Type of Ammonia Reagent Used (Anhydrous or % H ₂ O or Urea)					
Reagent Cost				\$/ton	
Current Emissions				lb/hr	
				ton/yr	
				lb/MBtu	
Particulate Emissions					
Emissions Limit	0.254	0.162	0.03	lb/MBtu	Title V permit for 1 & 2, Consent Decree Unit 3
Type of Emission Control - Hot Side ESP, Cold Side ESP or FF	Cold Side ESP	Cold Side ESP	Cold Side ESP		
Oxygen Content of Flue Gas @ Air Heater Outlet	na	na	na	%	
Oxygen Content of Flue Gas @ ESP/FF Outlet	na	na	na	%	
Current Emissions	0.241	0.068	0.07	lb/MBtu	Latest compliance PM testing
Fly Ash Sold (Y/N) - See Economic Section	n	n	n		
ESP					
Specific Collection Area (SCA)				ft ² /1000 acfm	
Discharge Electrode Type					
Supplier					
Efficiency				%	
No. of Electrical Sections					
% of Fly Ash Sold				%	
Fabric Filter					
Air to Cloth Ratio (net)				ft/min	
Number of Compartments					
Number of Bags per Compartments					
Efficiency				%	
% of Fly Ash Sold				%	
SO₂ Emissions					
Emissions Limit	5.15	5.15	.1 or 97%	lb/MBtu	Title V permit for 1 & 2, Consent Decree Unit 3
Type of Emission Control - wet or semi-dry FGD (if any)					
Current Emissions	2.5	2.5	2.5	lb/hr	Typical Value from CEMS (typically varies from 1.5 to 3.5 wit
				ton/yr	
				lb/MBtu	
Byproduct Sold (Y/N) - See Economic Section					

Black & Veatch AQCS Information Needs

Power Plant: _____
 Unit: _____

Owner: _____
 Project: _____

Economic Evaluation Factors:

	<u>Unit X</u>	<u>Unit X</u>	<u>Unit X</u>	<u>Unit X</u>	<u>Notes</u>
Remaining Plant Life/Economic Life				years	
Annual Capacity Factor (over life of study/plant)				%	
Contingency Margin (can be determined by B&V)				%	
Owner Indirects Cost Margin				%	
Interest During Construction				%	
Levelized Fixed Charge Rate or Capital Recovery Factor				%	
Present Worth Discount Rate				%	
Capital Escalation Rate				%	
O&M Escalation Rate				%	
Energy Cost (energy to run in-house equipment)				\$/MWh	
Replacement Energy Cost (required to be purchased during unit outage)				\$/MWh	
Year-by-Year Fuel Prices (over life of study/plant)				\$/MWh	
				\$/ton	
Base Fuel Price				\$/MWh	
				\$/ton	
Fuel Price Escalation Rate				%	
Water Cost				\$/1,000 gal	
Limestone Cost				\$/ton	
Lime Cost				\$/ton	
Ammonia Cost				\$/ton	
Fully Loaded Labor Rate (per person)				\$/year	
Fly Ash Sales				\$/ton	
Bottom Ash Sales				\$/ton	
FGD Byproduct Sales				\$/ton	
Waste Disposal Cost					
Fly Ash				\$/ton	
Bottom Ash				\$/ton	
Scrubber Waste				\$/ton	

Ghent

Black & Veatch AQCS Information Needs

Power Plant: _____
 Unit: _____

Owner: _____
 Project: _____

References:

- 1)
- 2)
- 3)
- 4)

Yellow highlight denotes Critical Focus Needs.

Fuel Data

Ultimate Coal Analysis (% by mass as received):	Typical	Minimum	Maximum	Notes
Carbon			%	
Hydrogen			%	
Sulfur			%	
Nitrogen			%	
Oxygen			%	
Chlorine			%	
Ash			%	
Moisture			%	
Total				
Higher Heating Value, Btu/lb (as received)			Btu/lb	
Ash Mineral Analysis (% by mass):				
Silica(SiO ₂)			%	
Alumina (Al ₂ O ₃)			%	
Titania (TiO ₂)			%	
Phosphorous Pentoxide (P ₂ O ₅)			%	
Calcium Oxide (CaO)			%	
Magnesium Oxide (MgO)			%	
Sodium Oxide (Na ₂ O)			%	
Iron Oxide (Fe ₂ O ₃)			%	
Sulfur Trioxide (SO ₃)			%	
Potassium Oxide (K ₂ O)			%	
Coal Trace Element Analysis (mercury and especially arsenic if fly ash is returned to boiler)				
Vanadium			%	
Arsenic			%	
Mercury			% or ppm	
Other <u>LOI</u>			%	
Natural gas firing capability (if any at all)	No			
Natural gas line (into the station) capacity (if applicable)	No			
Current Lost on Ignition (LOI)				
Start-up Fuel	# 2 Fuel Oil			
Ash Fusion Temperature				
Initial Deformation			°F	
Softening			°F	
Hemispherical			°F	
Hardgrove Grindability Index				

Black & Veatch AQCS Information Needs

Power Plant: _____
 Unit: _____

Owner: _____
 Project: _____

NOx Emissions	Unit 1	Unit 2	Unit 3	Unit 4	Notes	
Emissions Limit	0.45	0.4	0.46	0.46	lb/MBtu	
Type of NOx Control (if any) - LNB, OFA, etc.	LNB	LNB/OFA	LNB/OFA	LNB/OFA		
Current NOx Reduction with existing controls	SCR	SCR	SCR	SCR	%	
Type of Ammonia Reagent Used (Anhydrous or % H ₂ O or Urea)	anhydrous	anhydrous	anhydrous	anhydrous		
Reagent Cost					\$/ton	
Current Emissions	330	1300	330	330	lb/hr	
	930	850	4800	850	ton/yr	
	0.04	0.35	0.04	0.04	lb/MBtu	
Particulate Emissions						
Emissions Limit					lb/MBtu	
Type of Emission Control - Hot Side ESP, Cold Side ESP or FF	Cold side ESP	Hot side ESP	Hot side ESP	Hot side ESP		
Oxygen Content of Flue Gas @ Air Heater Outlet					%	
Oxygen Content of Flue Gas @ ESP/FF Outlet					%	
Current Emissions	0.02 to 0.045 lbs/n				0.02 to 0.045 lbs/n	0.025 lbs/mmbtu
Fly Ash Sold (Y/N) - See Economic Section	No	No	No	No		
ESP						
Specific Collection Area (SCA)	153	223	328	328	ft ² /1000 acfm	
Discharge Electrode Type	rigid	wire	wire	wire		
Supplier	PECO	GE	GE	GE		
Efficiency	99.2	99			%	
No. of Electrical Sections	4 in series	4 in series	7 in series	7 in series		
% of Fly Ash Sold	0	0	0	0	%	
Fabric Filter						
Air to Cloth Ratio (net)	N/A				ft/min	
Number of Compartments						
Number of Bags per Compartments						
Efficiency					%	
% of Fly Ash Sold					%	
SO₂ Emissions						
Emissions Limit	5.67 lbs/mmbtu (24 Hr)	lbs/mmbtu (3 Hr)	lbs/mmbtu (3 Hr)	lbs/mmbtu (3 Hr)	lb/MBtu	
Type of Emission Control - wet or semi-dry FGD (if any)	wet FGD	wet FGD	wet FGD	wet FGD		
Current Emissions	600	600	1120	600	lb/hr	
	1400	2100	1400	1400	ton/yr	
	0.15	0.2	0.15	0.15	lb/MBtu	
Byproduct Sold (Y/N) - See Economic Section	yes	yes	yes	yes		

Black & Veatch AQCS Information Needs

Power Plant: _____
 Unit: _____

Owner: _____
 Project: _____

Economic Evaluation Factors:

	<u>Unit X</u>	<u>Unit X</u>	<u>Unit X</u>	<u>Unit X</u>	<u>Notes</u>
Remaining Plant Life/Economic Life				years	
Annual Capacity Factor (over life of study/plant)				%	
Contingency Margin (can be determined by B&V)				%	
Owner Indirects Cost Margin				%	
Interest During Construction				%	
Levelized Fixed Charge Rate or Capital Recovery Factor				%	
Present Worth Discount Rate				%	
Capital Escalation Rate				%	
O&M Escalation Rate				%	
Energy Cost (energy to run in-house equipment)				\$/MWh	
Replacement Energy Cost (required to be purchased during unit outage)				\$/MWh	
Year-by-Year Fuel Prices (over life of study/plant)				\$/Mbtu	
				\$/ton	
Base Fuel Price				\$/Mbtu	
				\$/ton	
Fuel Price Escalation Rate				%	
Water Cost				\$/1,000 gal	
Limestone Cost				\$/ton	
Lime Cost				\$/ton	
Ammonia Cost				\$/ton	
Fully Loaded Labor Rate (per person)				\$/year	
Fly Ash Sales				\$/ton	
Bottom Ash Sales				\$/ton	
FGD Byproduct Sales				\$/ton	
Waste Disposal Cost					
Fly Ash				\$/ton	
Bottom Ash				\$/ton	
Scrubber Waste				\$/ton	

Cane Run

Black & Veatch AQCS Information Needs

Power Plant: Cane Run
 Unit: _____

Owner: Louisville Gas & Electric
 Project: _____

References:

- 1)
- 2)
- 3)
- 4)

Yellow highlight denotes Critical Focus Needs.

Fuel Data

Ultimate Coal Analysis (% by mass as received):	Typical	Minimum	Maximum	Notes
Carbon	61.4	59.8	63.14	
Hydrogen	4.3	4.09	4.3	
Sulfur	3.2	2.23	3.2	
Nitrogen	1.3	1.26	1.5	
Oxygen	6.5	6.62	7.44	
Chlorine	0.1			
Ash	10.8	9.13	11.67	
Moisture	12.4	11.92	15.18	
Total	100	95.05	106.43	
Higher Heating Value, Btu/lb (as received)	10921.64	10391	11673	
Ash Mineral Analysis (% by mass):				
Silica(SiO ₂)	46.02	42.41	49.07	
Alumina (Al ₂ O ₃)	23.27	20.81	25.64	
Titania (TiO ₂)	1.09	0.99	1.21	
Phosphorous Pentoxide (P ₂ O ₅)	0.255	0.16	0.34	
Calcium Oxide (CaO)	1.211	0.88	1.89	
Magnesium Oxide (MgO)	0.98	0.87	1.14	
Sodium Oxide (Na ₂ O)	0.3	0.22	0.44	
Iron Oxide (Fe ₂ O ₃)	22.97	17.48	27.84	
Sulfur Trioxide (SO ₃)	0.95	0.52	1.7	
Potassium Oxide (K ₂ O)	2.6	2.24	2.93	
Coal Trace Element Analysis (mercury and especially arsenic if fly ash is returned to boiler)				
Vanadium	46.75	%		
Arsenic	15.47	%		
Mercury	0.09	% or ppm		
Other <u>LOI</u>		%		
Natural gas firing capability (if any at all)	Y			
Natural gas line (into the station) capacity (if applicable)				
Current Lost on Ignition (LOI)				
Start-up Fuel	Gas			
Ash Fusion Temperature				
Initial Deformation	2025.56	°F		
Softening	2211.44	°F		
Hemispherical	2332.11	°F		
Hardgrove Grindability Index		62		

Black & Veatch AQCS Information Needs

Power Plant: Cane Run
 Unit: _____

Owner: Louisville Gas & Electric
 Project: _____

Plant Size and Operation Data: (provide for each unit)	CR4	CR5	CR6		Notes
Maximum (Design) Fuel Burn Rate	1601.9	1753.4	2395.7	MBtu/hr	
Boiler Type (e.g. wall-fired, tangential fired, cyclone)	Wall	Wall	Wall		
Boiler Manufacturer	CE	Riley	CE		
Net MW Rating (specify plant or turbine MW)	155	168	240	MW	
Gross MW Rating	168	181	261	MW	
Net Unit Heat Rate	10340	10458	10789	Btu/kWh	
Net Turbine Heat Rate	8414	8429	8625	Btu/kWh	
Boiler SO2 to SO3 Conversion Rate (if known)	-	-	-	%	
Fly Ash/Bottom Ash Split	80/20	80/20	80/20	%	
Flue Gas Recirculation (FGR)					
Installed? (Y/N)	Y	N	N		
In operation? (Y/N)	Y	N	N		
Flue Gas Recirculation (if installed)				%	
Type of Air Heater	Ljungstrom	Ljungstrom	Ljungstrom		
Air Heater Configuration (horizontal or vertical flow or shaft)	Horizontal	Horizontal	Horizontal		
Design Pressure/Vacuum Rating for Steam Generator	+/- 1800/3.5	1800/1.5	2400/3.5	in wg.	
Design Pressure/Vacuum Rating for Particulate Control	+/- no data	20" H2O/-8.75	no data	in wg.	
Electrical / Control					
DCS Manufacturer (e.g. Westinghouse, Foxboro, Honeywell, etc.)	Honeywell	Honeywell	Honeywell		
Type of DCS (e.g. WDPF, Ovation, Net 90, Infi 90, Symphony, TDC 3000, etc.)	TDC3000/Experion	TDC3000/Experion	TDC3000/Experion		
Neural Network Installed? (Y/N)	Y	Y	Y		
Neural Network Manufacturer (e.g. Pegasus, Westinghouse, etc.)	Neuco	Neuco	Neuco		
Extra Capacity available in DCS?	Y	Y	Y		
Historian Manufacturer	Honeywell	Honeywell	Honeywell		
Additional Controls from DCS or local PLC w/tie-in					
Transformer Rating for Intermediate Voltage Switchgear (SUS's) and Ratings of Equipment in These Cubicles					
Auxiliary Electric Limited (Y/N)	N	N	N		
Operating Conditions					
Economizer Outlet Temperature	580.45	630.24	617.2	°F	
Economizer Outlet Pressure				in wg.	
Excess Air or Oxygen at Economizer Outlet (full load/min load)				%	
Economizer Outlet Gas Flow				acfm	
				lb/hr	
Air Heater Outlet Temperature	369.22	299.15	317.59	°F	
Air Heater Outlet Pressure				in wg.	
Particulate Control Equipment Outlet Temperature	132.6	128.4	132.8	°F	Summer design Temperature
Particulate Control Equipment Outlet Pressure				in wg.	ID Fan Suction Pressure
FGD Outlet Temperature (if applicable)	127			°F	
FGD Outlet Pressure (if applicable)				in wg.	

Black & Veatch AQCS Information Needs

Power Plant: Cane Run
 Unit: _____

Owner: Louisville Gas & Electric
 Project: _____

NOx Emissions	CR4	CR5	CR6		Notes
Emissions Limit	0.3372	0.3934	0.3276	lb/MBtu	
Type of NOx Control (if any) - LNB, OFA, etc.	LNB	LNB	OFA		
Current NOx Reduction with existing controls				%	
Type of Ammonia Reagent Used (Anhydrous or % H ₂ O or Urea)	N/A	N/A	N/A		
Reagent Cost				\$/ton	
Current Emissions	0.337	0.384	0.286	lb/hr	
				ton/yr	
				lb/MBtu	
Particulate Emissions					
Emissions Limit	0.11	0.11	0.11	lb/MBtu	
Type of Emission Control - Hot Side ESP, Cold Side ESP or FF					
Oxygen Content of Flue Gas @ Air Heater Outlet	5.78	5.82	4.53	%	
Oxygen Content of Flue Gas @ ESP/FF Outlet				%	
Current Emissions	0.041	0.034	0.024	lb/MBtu	
Fly Ash Sold (Y/N) - See Economic Section	N	N	N		
ESP					
Specific Collection Area (SCA)				ft ² /1000 acfm	
Discharge Electrode Type	0.109" Copper Bessemer	0.109" Copper Bessemer			
Supplier	Research-Cottrell	Research-Cottrell	Buell Engineering		Original supplier
Efficiency	99.1	96.1	99.2	%	
No. of Electrical Sections	48		49		
% of Fly Ash Sold	N/A	N/A	N/A	%	
Fabric Filter					
Air to Cloth Ratio (net)				ft/min	
Number of Compartments					
Number of Bags per Compartments					
Efficiency				%	
% of Fly Ash Sold	N/A	N/A	N/A	%	
SO₂ Emissions					
Emissions Limit	1.2	1.2	1.2	lb/MBtu	
Type of Emission Control - wet or semi-dry FGD (if any)	Wet	Wet	Wet		
Current Emissions	0.411	0.419	0.676	lb/hr	
				ton/yr	
				lb/MBtu	
Byproduct Sold (Y/N) - See Economic Section	N	N	N		

Black & Veatch AQCS Information Needs

Power Plant: Cane Run
 Unit: _____

Owner: Louisville Gas & Electric
 Project: _____

Economic Evaluation Factors:

	<u>Unit X</u>	<u>Unit X</u>	<u>Unit X</u>	<u>Notes</u>
Remaining Plant Life/Economic Life	20	20	20	years
Annual Capacity Factor (over life of study/plant)	65	65	65	%
Contingency Margin (can be determined by B&V)				%
Owner Indirects Cost Margin				%
Interest During Construction				%
Levelized Fixed Charge Rate or Capital Recovery Factor				%
Present Worth Discount Rate	6.4	6.4	6.4	%
Capital Escalation Rate	4%	4%	4%	%
O&M Escalation Rate	3%	3%	3%	%
Energy Cost (energy to run in-house equipment)				\$/MWh
Replacement Energy Cost (required to be purchased during unit outage)				\$/MWh
Year-by-Year Fuel Prices (over life of study/plant)				\$/MBtu
Base Fuel Price				\$/ton
Fuel Price Escalation Rate				\$/MBtu
Water Cost				\$/ton
Limestone Cost	N/A	N/A	N/A	\$/1,000 gal
Lime Cost	\$112.54	\$112.54	\$112.54	\$/ton
Ammonia Cost	N/A	N/A	N/A	\$/ton
Fully Loaded Labor Rate (per person)				\$/year
Fly Ash Sales	N/A	N/A	N/A	\$/ton
Bottom Ash Sales	N/A	N/A	N/A	\$/ton
FGD Byproduct Sales	N/A	N/A	N/A	\$/ton
Waste Disposal Cost				
Fly Ash	\$2.73			\$/ton
Bottom Ash	\$8.40			\$/ton
Scrubber Waste	\$3,469.00	\$4,989.00	\$8,734.00	000\$

Total cost \$773,013.3

Values represent total O&M cost for 2009. Plant Total

Values represent total O&M cost for 2009. Plant total

Values represent total O&M cost for 2009.

Mill Creek

Black & Veatch AQCS Information Needs

Power Plant: _____
 Unit: _____

Owner: _____
 Project: _____

References:

- 1)
- 2)
- 3)
- 4)

Yellow highlight denotes Critical Focus Needs.

Fuel Data				Notes
	Typical	Minimum	Maximum	
Ultimate Coal Analysis (% by mass as received):				
Carbon	64			%
Hydrogen	4.5			%
Sulfur	3.5			%
Nitrogen	1.3			%
Oxygen	4.62			%
Chlorine	0.08			%
Ash	12			%
Moisture	10			%
Total	100.00			
Higher Heating Value, Btu/lb (as received)	11471.82			Btu/lb
Ash Mineral Analysis (% by mass):				
Silica(SiO ₂)				%
Alumina (Al ₂ O ₃)				%
Titania (TiO ₂)				%
Phosphorous Pentoxide (P ₂ O ₅)				%
Calcium Oxide (CaO)				%
Magnesium Oxide (MgO)				%
Sodium Oxide (Na ₂ O)				%
Iron Oxide (Fe ₂ O ₃)				%
Sulfur Trioxide (SO ₃)				%
Potassium Oxide (K ₂ O)				%
Coal Trace Element Analysis (mercury and especially arsenic if fly ash is returned to boiler)				
Vanadium				%
Arsenic				%
Mercury				% or ppm
Other <u>LOI</u>				%
Natural gas firing capability (if any at all)				
Natural gas line (into the station) capacity (if applicable)				
Current Lost on Ignition (LOI)				
Start-up Fuel				
Ash Fusion Temperature				
Initial Deformation				°F
Softening				°F
Hemispherical				°F
Hardgrove Grindability Index				

Black & Veatch AQCS Information Needs

Power Plant: _____
 Unit: _____

Owner: _____
 Project: _____

Plant Size and Operation Data: (provide for each unit)	Unit 1	Unit 2	Unit 3	Unit 4	Notes	
Maximum (Design) Fuel Burn Rate	B&V can determine some values from previous VISTA				MBtu/hr	
Boiler Type (e.g. wall-fired, tangential fired, cyclone)	Tangential fired	Tangential fired	opposed wall	opposed wall		
Boiler Manufacturer	CE	CE	B&W	B&W		
Net MW Rating (specify plant or turbine MW) <i>Winter ratings</i>	303MW	303MW	397MW	492MW	MW	
Gross MW Rating <i>Winter ratings</i>	330MW	330MW	423MW	525MW	MW	
Net Unit Heat Rate	10639	10929	10602	10410	Btu/kWh	
Net Turbine Heat Rate					Btu/kWh	
Boiler SO2 to SO3 Conversion Rate (if known)					%	
Fly Ash/Bottom Ash Split	80/20	80/20	80/20	80/20	%	
Flue Gas Recirculation (FGR)						
Installed? (Y/N)	N	N	N	N		
In operation? (Y/N)						
Flue Gas Recirculation (if installed)					%	
Type of Air Heater	Air Preheater Co.	Air Preheater Co.	Ljungstrom	Ljungstrom		
Air Heater Configuration (horizontal or vertical flow or shaft)	Vertical Flow	Vertical Flow	Vertical Flow	Vertical Flow		
Design Pressure/Vacuum Rating for Steam Generator +/-					in wg.	
Design Pressure/Vacuum Rating for Particulate Control +/-					in wg.	
Electrical / Control						
DCS Manufacturer (e.g. Westinghouse, Foxboro, Honeywell, etc.)	Honeywell	Honeywell	Honeywel	Honeywell		
Type of DCS (e.g. WDPF, Ovation, Net 90, Infi 90, Symphony, TDC 3000, etc.)	TC3000			Experion		
Neural Network Installed? (Y/N)	Y	Y	N	N		
Neural Network Manufacturer (e.g. Pegasus, Westinghouse, etc.)	Neuco	Neuco				
Extra Capacity available in DCS?	minimal	minimal	minimal	minimal		
Historian Manufacturer	Honeywell	Honeywell	Honeywell	Honeywell		
Additional Controls from DCS or local PLC w/tie-in						
Transformer Rating for Intermediate Voltage Switchgear						
Capacity of Spare Electrical Cubicles in Existing MCC's and LCUS's (SUS's) and Ratings of Equipment in These Cubicles						
Auxiliary Electric Limited (Y/N)	N	N	N	N		
Operating Conditions						
Economizer Outlet Temperature	760	760	690	640	°F	
Economizer Outlet Pressure	-5	-5	-5	-5	in wg.	
Excess Air or Oxygen at Economizer Outlet (full load/min load)	5	5	5	5	%	
Economizer Outlet Gas Flow	1524804	1524804	1958726	2239453	acfm	
	2976508	2976508	4056287	4848440	lb/hr	
Air Heater Outlet Temperature	375	375	325	315	°F	
Air Heater Outlet Pressure	-10	-10	-18	-18	in wg.	
Particulate Control Equipment Outlet Temperature	375	375	325	315	°F	
Particulate Control Equipment Outlet Pressure	-14	-14	-23	-21	in wg.	
FGD Outlet Temperature (if applicable)	133	133	130	130	°F	
FGD Outlet Pressure (if applicable)	1	1	1	1	in wg.	

Black & Veatch AQCS Information Needs

Power Plant: _____
 Unit: _____

Owner: _____
 Project: _____

NOx Emissions	Unit 1	Unit 2	Unit 3	Unit 4		Notes
Emissions Limit			0.7	0.7	lb/MBtu	
Type of NOx Control (if any) - LNB, OFA, etc.	LNB/OFA	LNB/OFA	LNB/SCR	LNB/SCR		
Current NOx Reduction with existing controls			90%	90%	%	
Type of Ammonia Reagent Used (Anhydrous or % H ₂ O or Urea)			Anhydrous	Anhydrous		
Reagent Cost			500	500	\$/ton	
Current Emissions	0.32	0.32	0.05	0.05	lb/hr	
					ton/yr	
					lb/MBtu	
Particulate Emissions						
Emissions Limit	0.115	0.115	0.105	0.105	lb/MBtu	
Type of Emission Control - Hot Side ESP, Cold Side ESP or FF	Cold Side ESP	Cold Side ESP	Cold Side ESP	Cold Side ESP		
Oxygen Content of Flue Gas @ Air Heater Outlet	4	4	4	4	%	
Oxygen Content of Flue Gas @ ESP/FF Outlet	4	4	4	4	%	
Current Emissions	0.36	0.48	0.05	0.04	lb/MBtu	
Fly Ash Sold (Y/N) - See Economic Section	Y	Y	Y	Y		Very minimal at this point in time
ESP						
Specific Collection Area (SCA)					ft ² /1000 acfm	
Discharge Electrode Type						
Supplier						
Efficiency					%	
No. of Electrical Sections						
% of Fly Ash Sold					%	
Fabric Filter						
Air to Cloth Ratio (net)					ft/min	
Number of Compartments						
Number of Bags per Compartments						
Efficiency					%	
% of Fly Ash Sold					%	
SO₂ Emissions						
Emissions Limit	1.2	1.2	1.2	1.2	lb/MBtu	
Type of Emission Control - wet or semi-dry FGD (if any)	Wet FGD	Wet FGD	Wet FGD	Wet FGD		
Current Emissions	0.47	0.47	0.58	0.47	lb/hr	
					ton/yr	
					lb/MBtu	
Byproduct Sold (Y/N) - See Economic Section						

Black & Veatch AQCS Information Needs

Power Plant: _____
 Unit: _____

Owner: _____
 Project: _____

Economic Evaluation Factors:

	<u>Unit X</u>	<u>Unit X</u>	<u>Unit X</u>	<u>Unit X</u>	<u>Notes</u>
Remaining Plant Life/Economic Life				years	
Annual Capacity Factor (over life of study/plant)				%	
Contingency Margin (can be determined by B&V)				%	
Owner Indirects Cost Margin				%	
Interest During Construction				%	
Levelized Fixed Charge Rate or Capital Recovery Factor				%	
Present Worth Discount Rate				%	
Capital Escalation Rate				%	
O&M Escalation Rate				%	
Energy Cost (energy to run in-house equipment)				\$/MWh	
Replacement Energy Cost (required to be purchased during unit outage)				\$/MWh	
Year-by-Year Fuel Prices (over life of study/plant)				\$/MWh	
				\$/ton	
Base Fuel Price				\$/MWh	
				\$/ton	
Fuel Price Escalation Rate				%	
Water Cost				\$/1,000 gal	
Limestone Cost				\$/ton	
Lime Cost				\$/ton	
Ammonia Cost				\$/ton	
Fully Loaded Labor Rate (per person)				\$/year	
Fly Ash Sales				\$/ton	
Bottom Ash Sales				\$/ton	
FGD Byproduct Sales				\$/ton	
Waste Disposal Cost					
Fly Ash				\$/ton	
Bottom Ash				\$/ton	
Scrubber Waste				\$/ton	

Trimble County

Black & Veatch AQCS Information Needs

Power Plant: Trimble
 Unit: TC1 and TC2

Owner: _____
 Project: _____

References:

- 1)
- 2)
- 3)
- 4)

Yellow highlight denotes Critical Focus Needs.

Fuel Data

Ultimate Coal Analysis (% by mass as received):	Typical	Minimum	Maximum	Notes
Carbon			%	
Hydrogen			%	
Sulfur			%	
Nitrogen			%	
Oxygen			%	
Chlorine			%	
Ash			%	
Moisture			%	
Total				
Higher Heating Value, Btu/lb (as received)			Btu/lb	
Ash Mineral Analysis (% by mass):				
Silica(SiO ₂)			%	
Alumina (Al ₂ O ₃)			%	
Titania (TiO ₂)			%	
Phosphorous Pentoxide (P ₂ O ₅)			%	
Calcium Oxide (CaO)			%	
Magnesium Oxide (MgO)			%	
Sodium Oxide (Na ₂ O)			%	
Iron Oxide (Fe ₂ O ₃)			%	
Sulfur Trioxide (SO ₃)			%	
Potassium Oxide (K ₂ O)			%	
Coal Trace Element Analysis (mercury and especially arsenic if fly ash is returned to boiler)				
Vanadium			%	
Arsenic			%	
Mercury			% or ppm	
Other <u>LOI</u>			%	
Natural gas firing capability (if any at all)				
Natural gas line (into the station) capacity (if applicable)				
Current Lost on Ignition (LOI)				
Start-up Fuel				
Ash Fusion Temperature				
Initial Deformation			°F	
Softening			°F	
Hemispherical			°F	
Hardgrove Grindability Index				

Black & Veatch AQCS Information Needs

Power Plant: Trimble
 Unit: TC1 and TC2

Owner: _____
 Project: _____

Plant Size and Operation Data: (provide for each unit)	Unit 1	Unit 2	Unit X	Unit X	Notes
Maximum (Design) Fuel Burn Rate	B&V can determine some values from previous VISTA				MBtu/hr
Boiler Type (e.g. wall-fired, tangential fired, cyclone)	Tangential	Wallfired			
Boiler Manufacturer	Combustion Engineering		Doosan		
Net MW Rating (specify plant or turbine MW)	turbine 512	760			MW
Gross MW Rating	547	509			MW
Net Unit Heat Rate	10372	8662 quarenteed			Btu/kWh
Net Turbine Heat Rate	gross 8362.53	7066 turbine quarenteed			Btu/kWh
Boiler SO2 to SO3 Conversion Rate (if known)	NA	0.068 lb/MMBtu less than this at Econ outlet			%
Fly Ash/Bottom Ash Split	80/20	80/20			%
Flue Gas Recirculation (FGR)					
Installed? (Y/N)	N	N			
In operation? (Y/N)	N	NA			
Flue Gas Recirculation (if installed)	NA	NA			%
Type of Air Heater	Regenerative	Regenerative			
Air Heater Configuration (horizontal or vertical flow or shaft)	Vertical 2 layer	Vertical 2 layer			
Design Pressure/Vacuum Rating for Steam Generator	+/- 26.5	24/35 +/- 24 on continuous +/-35 on transient basis			in wg.
Design Pressure/Vacuum Rating for Particulate Control	+/- 42 at 100%	25/-6	+/-35 for DESP, PJFF	+25/-6	in wg.
Electrical / Control					
DCS Manufacturer (e.g. Westinghouse, Foxboro, Honeywell, etc.)	Emerson	Emerson			
Type of DCS (e.g. WDPF, Ovation, Net 90, Infi 90, Symphony, TDC 3000, etc.)	Ovation	Ovation			
Neural Network Installed? (Y/N)	N	N			
Neural Network Manufacturer (e.g. Pegasus, Westinghouse, etc.)	N/A	N/A			
Extra Capacity available in DCS?	Y	Y			
Historian Manufacturer	Emerson	Emerson			
Additional Controls from DCS or local PLC w/tie-in	Y	Y			
Transformer Rating for Intermediate Voltage Switchgear (SUS's) and Ratings of Equipment in These Cubicles	100.8 MVA? Need better definition				
Auxiliary Electric Limited (Y/N)	N				
Operating Conditions					
Economizer Outlet Temperature	700	586			°F
Economizer Outlet Pressure	-6				in wg.
Excess Air or Oxygen at Economizer Outlet (full load/min load)	3	3.2/8.15 25%			%
Economizer Outlet Gas Flow	N/A	3200333			acfm
	N/A				lb/hr
Air Heater Outlet Temperature	600	324			°F
Air Heater Outlet Pressure	diff 6.5				in wg.
Particulate Control Equipment Outlet Temperature	N/A	313			°F
Particulate Control Equipment Outlet Pressure	-0.3				in wg.
FGD Outlet Temperature (if applicable)	130	12.9 diff			°F
FGD Outlet Pressure (if applicable)					in wg. stack draft

Black & Veatch AQCS Information Needs

Power Plant: Trimble
 Unit: TC1 and TC2

Owner: _____
 Project: _____

NOx Emissions	Unit 1	Unit 2	Unit X	Unit X		Notes
Emissions Limit					lb/MBtu	
Type of NOx Control (if any) - LNB, OFA, etc.						
Current NOx Reduction with existing controls					%	
Type of Ammonia Reagent Used (Anhydrous or % H ₂ O or Urea)						
Reagent Cost					\$/ton	
Current Emissions					lb/hr	
					ton/yr	
					lb/MBtu	
Particulate Emissions						
Emissions Limit					lb/MBtu	
Type of Emission Control - Hot Side ESP, Cold Side ESP or FF						
Oxygen Content of Flue Gas @ Air Heater Outlet					%	
Oxygen Content of Flue Gas @ ESP/FF Outlet					%	
Current Emissions					lb/MBtu	
Fly Ash Sold (Y/N) - See Economic Section						
ESP						
Specific Collection Area (SCA)					ft ² /1000 acfm	
Discharge Electrode Type						
Supplier						
Efficiency					%	
No. of Electrical Sections						
% of Fly Ash Sold					%	
Fabric Filter						
Air to Cloth Ratio (net)					ft/min	
Number of Compartments						
Number of Bags per Compartments						
Efficiency					%	
% of Fly Ash Sold					%	
SO₂ Emissions						
Emissions Limit					lb/MBtu	
Type of Emission Control - wet or semi-dry FGD (if any)						
Current Emissions					lb/hr	
					ton/yr	
					lb/MBtu	
Byproduct Sold (Y/N) - See Economic Section						

Black & Veatch AQCS Information Needs

Power Plant: Trimble
 Unit: TC1 and TC2

Owner: _____
 Project: _____

Economic Evaluation Factors:

	<u>Unit X</u>	<u>Unit X</u>	<u>Unit X</u>	<u>Unit X</u>	<u>Notes</u>
Remaining Plant Life/Economic Life				years	
Annual Capacity Factor (over life of study/plant)				%	
Contingency Margin (can be determined by B&V)				%	
Owner Indirects Cost Margin				%	
Interest During Construction				%	
Levelized Fixed Charge Rate or Capital Recovery Factor				%	
Present Worth Discount Rate				%	
Capital Escalation Rate				%	
O&M Escalation Rate				%	
Energy Cost (energy to run in-house equipment)				\$/MWh	
Replacement Energy Cost (required to be purchased during unit outage)				\$/MWh	
Year-by-Year Fuel Prices (over life of study/plant)				\$/Mbtu	
				\$/ton	
Base Fuel Price				\$/Mbtu	
				\$/ton	
Fuel Price Escalation Rate				%	
Water Cost				\$/1,000 gal	
Limestone Cost				\$/ton	
Lime Cost				\$/ton	
Ammonia Cost				\$/ton	
Fully Loaded Labor Rate (per person)				\$/year	
Fly Ash Sales				\$/ton	
Bottom Ash Sales				\$/ton	
FGD Byproduct Sales				\$/ton	
Waste Disposal Cost					
Fly Ash				\$/ton	
Bottom Ash				\$/ton	
Scrubber Waste				\$/ton	

Green River

Black & Veatch AQCS Information Needs

Power Plant: Green River
 Unit: _____

Owner: _____
 Project: _____

References:

- 1)
- 2)
- 3)
- 4)

Yellow highlight denotes Critical Focus Needs.

Fuel Data

Ultimate Coal Analysis (% by mass as received):	Typical	Minimum	Maximum	Notes
Carbon			%	
Hydrogen			%	
Sulfur			%	
Nitrogen			%	
Oxygen			%	
Chlorine			%	
Ash			%	
Moisture			%	
Total				
Higher Heating Value, Btu/lb (as received)			Btu/lb	
Ash Mineral Analysis (% by mass):				
Silica(SiO ₂)			%	
Alumina (Al ₂ O ₃)			%	
Titania (TiO ₂)			%	
Phosphorous Pentoxide (P ₂ O ₅)			%	
Calcium Oxide (CaO)			%	
Magnesium Oxide (MgO)			%	
Sodium Oxide (Na ₂ O)			%	
Iron Oxide (Fe ₂ O ₃)			%	
Sulfur Trioxide (SO ₃)			%	
Potassium Oxide (K ₂ O)			%	
Coal Trace Element Analysis (mercury and especially arsenic if fly ash is returned to boiler)				
Vanadium		%		
Arsenic		%		
Mercury		% or ppm		
Other <u>LOI</u>		%		
Natural gas firing capability (if any at all)				
Natural gas line (into the station) capacity (if applicable)				
Current Lost on Ignition (LOI)				
Start-up Fuel				
Ash Fusion Temperature				
Initial Deformation		°F		
Softening		°F		
Hemispherical		°F		
Hardgrove Grindability Index				

Black & Veatch AQCS Information Needs

Power Plant: Green River
 Unit: _____

Owner: _____
 Project: _____

Plant Size and Operation Data: (provide for each unit)		Unit 3	Unit 4	Unit X	Unit X	Notes
Maximum (Design) Fuel Burn Rate		880	1.2			MBtu/hr
Boiler Type (e.g. wall-fired, tangential fired, cyclone)		Wall Fired	Wall Fired			Original Design
Boiler Manufacturer		B&W	B&W			
Net MW Rating (specify plant or turbine MW)		71	102			MW
Gross MW Rating		75	109			MW
Net Unit Heat Rate		11942	11278			Btu/kWh
Net Turbine Heat Rate						Btu/kWh
Boiler SO2 to SO3 Conversion Rate (if known)		Unknown	Unknown			%
Fly Ash/Bottom Ash Split		80/20	80/20			%
Flue Gas Recirculation (FGR)		NA	NA			
Installed? (Y/N)						
In operation? (Y/N)		NA	NA			
Flue Gas Recirculation (if installed)		NA	NA			%
Type of Air Heater		Tubular	Lungstrom			
Air Heater Configuration (horizontal or vertical flow or shaft)		Vertical	Vertical			
Design Pressure/Vacuum Rating for Steam Generator	+/-	-18	-13.3			in wg.
Design Pressure/Vacuum Rating for Particulate Control	+/-	-18	-13.3			in wg.
Electrical / Control						
DCS Manufacturer (e.g. Westinghouse, Foxboro, Honeywell, etc.)		Honeywell	Honeywell			
Type of DCS (e.g. WDPF, Ovation, Net 90, Infi 90, Symphony, TDC 3000, etc.)		Experion	Experion			
Neural Network Installed? (Y/N)		N	N			
Neural Network Manufacturer (e.g. Pegasus, Westinghouse, etc.)		NA	NA			
Extra Capacity available in DCS?		Y	Y			
Historian Manufacturer		Honeywell	Honeywell			
Additional Controls from DCS or local PLC w/tie-in		Y Rockwell	Y Rockwell			
Transformer Rating for Intermediate Voltage Switchgear (SUS's) and Ratings of Equipment in These Cubicles		7.5 MVA	9.375 MVA			
Auxiliary Electric Limited (Y/N)		N/A	N/A			
		N	N			
Operating Conditions						
Economizer Outlet Temperature		475	610			°F
Economizer Outlet Pressure		-5	-6			in wg.
Excess Air or Oxygen at Economizer Outlet (full load/min load)		25%	25%			%
Economizer Outlet Gas Flow						acfm
		510	687			Klb/hr
Air Heater Outlet Temperature		243	363			°F
Air Heater Outlet Pressure		-9	-135			in wg.
Particulate Control Equipment Outlet Temperature		230	600			°F
Particulate Control Equipment Outlet Pressure		-11	-8.1			in wg.
FGD Outlet Temperature (if applicable)		NA	NA			°F
FGD Outlet Pressure (if applicable)		NA	NA			in wg.

Black & Veatch AQCS Information Needs

Power Plant: Green River
 Unit _____

Owner: _____
 Project: _____

NOx Emissions	Unit 3	Unit 4	Unit X	Unit X	Notes
Emissions Limit	0.46	0.5			lb/MBtu
Type of NOx Control (if any) - LNB, OFA, etc.	LNB	LNB			
Current NOx Reduction with existing controls	NA	NA			%
Type of Ammonia Reagent Used (Anhydrous or % H ₂ O or Urea)	NA	NA			
Reagent Cost	NA	NA			\$/ton
Current Emissions					lb/hr
					ton/yr
	0.398	0.384			lb/MBtu
Particulate Emissions					
Emissions Limit	0.29	0.14			lb/MBtu
Type of Emission Control - Hot Side ESP, Cold Side ESP or FF	Cold side	Hot side			
Oxygen Content of Flue Gas @ Air Heater Outlet	-5%	-5%			%
Oxygen Content of Flue Gas @ ESP/FF Outlet	-5%	-5%			%
Current Emissions	Compliance	Compliance			lb/MBtu
Fly Ash Sold (Y/N) - See Economic Section	N	N			Indirectly measured by Opacity
ESP					
Specific Collection Area (SCA)					ft ² /1000 acfm
Discharge Electrode Type	Weighted Wire	Weighted Wire			
Supplier	Buell	Buell			
Efficiency	98.50%	99%			%
No. of Electrical Sections	6	7			
% of Fly Ash Sold	0	0			%
Fabric Filter					
Air to Cloth Ratio (net)	NA	NA			ft/min
Number of Compartments	NA	NA			
Number of Bags per Compartments	NA	NA			
Efficiency	NA	NA			%
% of Fly Ash Sold	NA	NA			%
SO₂ Emissions					
Emissions Limit	4.57	4.57			lb/MBtu
Type of Emission Control - wet or semi-dry FGD (if any)	NA	NA			
Current Emissions					lb/hr
	5448	9276			ton/yr
					lb/MBtu
Byproduct Sold (Y/N) - See Economic Section					2009 data

Black & Veatch AQCS Information Needs

Power Plant: Green River
 Unit _____

Owner: _____
 Project: _____

Economic Evaluation Factors:

	<u>Unit X</u>	<u>Unit X</u>	<u>Unit X</u>	<u>Unit X</u>	<u>Notes</u>
Remaining Plant Life/Economic Life				_____ years	_____
Annual Capacity Factor (over life of study/plant)				_____ %	_____
Contingency Margin (can be determined by B&V)				_____ %	_____
Owner Indirects Cost Margin				_____ %	_____
Interest During Construction				_____ %	_____
Levelized Fixed Charge Rate or Capital Recovery Factor				_____ %	_____
Present Worth Discount Rate				_____ %	_____
Capital Escalation Rate				_____ %	_____
O&M Escalation Rate				_____ %	_____
Energy Cost (energy to run in-house equipment)				_____ \$/MWh	_____
Replacement Energy Cost (required to be purchased during unit outage)				_____ \$/MWh	_____
Year-by-Year Fuel Prices (over life of study/plant)				_____ \$/MBtu	_____
				_____ \$/ton	_____
Base Fuel Price				_____ \$/MBtu	_____
				_____ \$/ton	_____
Fuel Price Escalation Rate				_____ %	_____
Water Cost				_____ \$/1,000 gal	_____
Limestone Cost				_____ \$/ton	_____
Lime Cost				_____ \$/ton	_____
Ammonia Cost				_____ \$/ton	_____
Fully Loaded Labor Rate (per person)				_____ \$/year	_____
Fly Ash Sales				_____ \$/ton	_____
Bottom Ash Sales				_____ \$/ton	_____
FGD Byproduct Sales				_____ \$/ton	_____
Waste Disposal Cost					_____
Fly Ash				_____ \$/ton	_____
Bottom Ash				_____ \$/ton	_____
Scrubber Waste				_____ \$/ton	_____