

Professional

Engineering


Services

Countywide  
Underserved  
Project  
Preliminary  
Engineering  
Report

Report.

Carrollton Utilities, KY

July 2012



STRAIN  
ASSOCIATES


EXHIBIT  
13

Bumgar No. 5208

# Report for Carrollton Utilities, Kentucky

---

## Countywide Underserved Project Preliminary Engineering Report (PER)



Prepared by:

STRAND ASSOCIATES, INC.®  
325 West Main St., Ste. 710  
Louisville, KY 40202  
[www.strand.com](http://www.strand.com)

July 2012



# TABLE OF CONTENTS

Page No.  
or Following

## PRELIMINARY ENGINEERING REPORT

Purpose and Scope .....	1
Existing WTP Operation.....	1
Water Quality and Operational Goals.....	11
Treatment Alternatives.....	11
Alternative Selection and Considerations.....	15
Permit Requirements .....	21
Opinion of Probable Cost.....	21
Distribution System Improvements.....	23
Conclusion and Recommendations.....	28

## TABLES

Table 1	Claricone Design Criteria .....	4
Table 2	Recarbonation Tank Design Criteria.....	5
Table 3	Filter Design Criteria .....	6
Table 4	Virus Removal Credit .....	6
Table 5	Groundwater Source Well Information.....	9
Table 6	Select Sampling Results vs. Secondary MCL Levels .....	10
Table 7	Select Finished Water Quality Data.....	10
Table 8	Ion Exchange Design Criteria.....	16
Table 9	Planning Level Opinion of Probable Construction Cost .....	22
Table 10	Summary of Water Main Additions .....	24

## FIGURES

Figure 1	Carrollton Utilities WTP Location and Service Area.....	1
Figure 2	Carrollton Utilities WTP Site .....	1
Figure 3	Existing Water Treatment Plant Schematic .....	1
Figure 4	Alternative 1 Treatment Schematic Existing Process Expansion with Sludge Dewatering.....	11
Figure 5	Alternative 2 Treatment Schematic Ion Exchange Plant.....	12
Figure 6	Alternative 2 Proposed WTP Site Plan .....	12
Figure 7	Alternative 2 Proposed Treatment Building Plan .....	12
Figure 8	Alternative 3 Treatment Schematic FBR Softening Addition with Filter Expansion .....	14
Figure 9	Distribution System Improvements.....	23

## APPENDICES

- APPENDIX A–WATER QUALITY DATA
- APPENDIX B–HYDRAULIC ANALYSIS OF LINE EXTENSIONS
- APPENDIX C–ANALYSIS OF TRANSMISSION MAIN TO SERVE GENERAL BUTLER TANK
- APPENDIX D–DISTRIBUTION SYSTEM IMPROVEMENTS COST OPINION

## PURPOSE AND SCOPE

The purpose of this preliminary engineering report (PER) is to discuss the necessary design elements for the proposed improvements at the Carrollton Utilities (CU) Water Treatment Plant (WTP) and throughout the West Carroll Water District (WCWD) distribution system. CU's primary objectives of the project are:

1. To reduce the operational requirements at the WTP to one manned shift a day so that these resources can be utilized elsewhere in the system.
2. To address the reduction in available sludge lagoon volume because of revised land use.
3. To extend potable water service to new customers and improve service to existing customers within the WCWD service area.
4. To increase treatment redundancy to accommodate equipment maintenance.

This report addresses the requirements, as described in the Kentucky Administrative Regulations Requirement Chapter 8:100, for the preliminary design approval before final design commences.

Using existing data, CU and WCWD input, and our water treatment and distribution experience, the PER identifies the issues and applicable technologies proposed to meet the goals of CU, WCWD, and the Safe Drinking Water Act (SDWA). This report encompasses the evaluated alternatives, considers the utilities' objectives, and presents the recommended solutions that were ultimately selected by CU and WCWD.

The PER will first address the WTP characteristics and improvements, followed by the distribution system portion of the project.

## EXISTING WTP OPERATION

### A. Location, Service Area, and Demands

The CU WTP is located within Carrollton, Kentucky, and has been drawing and treating water from local groundwater wells for more than 30 years. The CU WTP provides potable water for 2,037 service connections throughout the City of Carrollton (City) and wholesales to the WCWD, which has approximately 1,920 service connections and a population of approximately 7,300. CU has an emergency interconnect with Carroll County Water District No. 1 (CCWD1). Figure 1 shows the location of the CU WTP and its service area. Operators report a peak day demand of 1 million gallons per day (mgd) with demand in excess of 1.5 mgd under a rare firefighting event. Average demand is 0.75 mgd.

### B. Existing Plant Type and Capacity Evaluation

The existing WTP is a groundwater lime-softening plant with a design capacity of 1.5 mgd. Figure 2 shows an aerial view of the WTP site. Figure 3 shows a schematic of the existing WTP processes.

















Path: S:\L\OU\5100-5199\5104\0021\Data\GIS\Map\Figure 1-WTP Location.mxd


User: andrew

Date: 6/29/2012


Time: 7:59:12 AM

### Legend


-  Water Treatment Plant
-  Purchase Points
-  Ohio River
-  City Boundary
-  County Boundary
- Utility Service Boundaries**
-  WCWD Boundary
-  CU Boundary
-  CCWD#1 Boundary
-  Interstate
-  US HWY
-  KY HWY
-  Local Road
- Water Lines**
-  CCWD#1 Water Lines
-  CU Water Lines
-  WCWD Water Lines
-  Other Water Lines



CARROLL CO.



KENTUCKY COUNTY MAP



## CARROLLTON UTILITIES WTP LOCATION AND SERVICE AREA

WTP AND DISTRIBUTION SYSTEM IMPROVEMENTS PER  
 CARROLLTON UTILITIES  
 CARROLLTON, KENTUCKY



FIGURE 1  
 5104.002




### CARROLLTON UTILITIES WTP SITE

WTP AND DISTRIBUTION SYSTEM IMPROVEMENTS PER  
CARROLLTON UTILITIES  
CARROLLTON, KENTUCKY



FIGURE 2  
5104.002



**EXISTING WATER TREATMENT PLANT SCHEMATIC**

**WTP AND DISTRIBUTION SYSTEM IMPROVEMENTS PER  
CARROLLTON UTILITIES  
CARROLLTON, KENTUCKY**



**FIGURE 3**  
5104.002

The following is a summary of the unit processes at the existing WTP and evaluation of each unit's ability to provide reliable drinking water under current demands and potential for increasing flow rates through the unit processes. This section identifies issues with treatment capacity and performance to develop future improvement.

### 1. Raw Water Well Pumps

The raw water source consists of three wells and associated pumps. Operators report well pumping capacity of 1,100 gallons per minute (gpm) with one of the two large pumps and one smaller pump in operation. A new raw water main was installed several years ago. No major problems have been reported with these pumps.

### 2. Air Strippers

Air-stripping is a technology used to remove volatile organic compounds (VOCs) from water. The existing air strippers consist of two identical 5-foot by 5-foot by 25-foot towers partially filled with column-packing material. Raw groundwater enters the top of the towers through a set of spray nozzles that distribute flow down through the tower. Blowers located at the base of each tower force air up through the tower as the water descends across the packing material. This process strips the water of VOCs and transfers it to the air blowing up through the towers. The air strippers for the CU WTP were designed to liberate dissolved trichloroethylene (TCE) gases from the raw water supply. At a combined flow of 900 gpm (450 gpm per tower), the air strippers were designed to reduce TCE influent concentrations in the raw water of 200 micrograms per liter ( $\mu\text{g/L}$ ) by 99.9 percent, reducing the effluent concentration to 0.2  $\mu\text{g/L}$ . The United States Environmental Protection Agency (USEPA) maximum contaminant level (MCL) for TCE is 5  $\mu\text{g/L}$ . Decontaminated water collects at the bottom of the towers and flows by gravity to the low lift pump station.

No major problems have been reported with the air strippers. The air strippers are currently meeting the required TCE concentrations while operating the raw water well pumps at 1,100 gpm. Although the manufacturer has indicated that limits could be met at significantly higher flows, the operation and maintenance manual lists the design capacity at 900 gpm. The most cost-effective way to add additional capacity is to provide additional media or change the media size.

### 3. Low Lift Pump Station

Flow from the air strippers discharges into the low lift pump pit by gravity. The low lift pump station has one pump that discharges flow into the head tank. The low lift pump is designed to provide 1,500 gpm (2.1 mgd) to the head tank. The self-priming centrifugal pump replaced two submersible pumps approximately two years ago.



A summary of concerns related to the low lift pump station is that there is currently no redundancy in low lift pumping operation. A loss of this pump, even under current conditions, would result in the inability to discharge water into the head tank and require emergency repairs or acquisition of a replacement.

#### 4. Head Tank

The low lift pump station discharges into the head tank. Water from the head tank flows by gravity into the bottom of the claricone.

There are no specific design requirements associated with the head tank. Its purpose is to provide stable head conditions to the claricone. Additional flow through downstream treatment units could push the required head above that available but does not appear to be the case within the alternatives reviewed in this report.

#### 5. Claricone

The claricone is an inverted cone-shaped solids contact clarifier. Flow enters the claricone by gravity from the head tank through a 12-inch line and a 8-inch line at the base of the cone. The claricone is designed to accomplish the following:

- a. Mixing of treatment chemicals (lime) with the raw water to form floc in the mixing and reaction zone.
- b. Solids contact and agglomeration in the flocculation zone.
- c. Solids separation in the clarification zone.
- d. Slurry concentration and compaction in the slurry concentrator.

The influent lines are positioned to cause a rotational flow within the claricone. Lime is added to the influent lines before they enter the claricone. The shape and location of the influent lines cause an expanding helical flow path that provides a smooth transition from rapid mixing near the base of the claricone to gentle mixing near the top. The energy for this process is provided by flow from the head tank. Clarified water flows by gravity from the top of the claricone to the recarbonation tank. Sludge is discharged approximately twice a day through the 6-inch slurry blowdown line located at the base of the claricone. Sludge is discharged into a sewer that drains into four sludge drying beds located near 2nd Street.

Table 1 shows the design parameters for the existing WTP claricone for the treatment of groundwater.

Parameter	Units	Existing	Ten State Standards (2007)	Manufacturer Recommended Value
Claricone Units	No.	1	N/A	N/A
Design Flow/Unit	gpm	1,042	N/A	N/A
Claricone Diameter	ft	30	N/A	N/A
Surface Area	ft <sup>2</sup>	707	N/A	N/A
Volume/Unit	gallons	45,900	N/A	N/A
Detention Time	minutes	44	60 - 120	> 40
Overflow Rate	gpm/ft <sup>2</sup>	1.47	< 1.75	< 2

ft=feet, ft<sup>2</sup>=square feet

**Table 1 Claricone Design Criteria**

The following is a summary of concerns related to the claricone:

- a. With only one unit available, the existing WTP has no redundancy.
- b. Current flow conditions result in detention time approaching the minimum recommended by the manufacturer. Future flow conditions will reduce detention time below manufacturer recommended values.
- c. Detention time under current flow conditions does not meet Ten State Standards, though the quality of the treated water indicates current detention time is sufficient.
- d. Increased flow conditions will result in an overflow rate exceeding manufacturer recommended values.
- e. Sludge from the claricone is discharged to four sludge drying beds located near 2nd Street. CU desires to reduce or eliminate the drying beds, if possible. While CU reports that only two beds are required at current demands, increased production utilizing the lime softening process would require additional lagoon space or alternate residuals treatment such as a sludge dewatering unit.

## 6. Recarbonation Tank

The purpose of the recarbonation tank is to provide sufficient retention time for the adjustment of pH by introducing carbon dioxide bubbles into the water to lower the pH. This process converts carbonate ions to bicarbonate ions and stabilizes the solution against the precipitation of carbonate compounds. Effluent from the claricone flows by gravity into the recarbonation tank. Table 2 shows the design criteria for the recarbonation tank.

Parameter	Units	Existing	10 State Standards (2007)
Tank Units	No.	1	N/A
Design Flow/Unit	gpm	1,042	N/A
Tank Diameter	ft	8	N/A
Height	ft	18.83	N/A
Volume / Unit	gallons	7,080	N/A
Detention Time	minutes	6.8	20

**Table 2 Recarbonation Tank Design Criteria**

The recarbonation equipment inside the tank was replaced in 2012.

The following is a summary of concerns related to the recarbonation tank:

- a. With only one unit available, there is no redundancy with this process.
- b. Though the recarbonation tank is providing sufficient reduction in pH, current flow conditions result in detention time less than the minimum listed by Ten State Standards. Future flows will reduce detention time even further and a variance from the Kentucky Division of Water (KDOW) from the standard will likely be required if capacity is not increased with an increase in flow to the unit.

7. Filters

The CU WTP operates two-tapered bed mixed-media filters with areas that increase with depth. Stabilized water from the recarbonation tank flows by gravity to the two filters. Clarified water enters the filters through a trough in the center of each filter that distributes water evenly across the filter. Water then passes through the mixed media and is collected by a filter block underdrain system at the bottom of the filter. Filtered water is conveyed by gravity to the clearwell through a 12-inch effluent line.

The filters are backwashed periodically according to a schedule. The backwash pump is located next to the high service pumps on top of the clearwell. The backwash pump conveys water from the clearwell to the bottom of the filters and is distributed evenly across the filter by the underdrain system. An air scour system is also provided to break up compacted filter media to aid the backwash process.

Table 3 shows the design parameters for the existing WTP filters.

Parameter	Units	Existing	10 State Standards (2007)
Filter Units	No.	2	≥ 2
Design Flow/Unit (with 2 in service)	gpm	1,042	N/A
Dimensions (L x W)	ft	16 x 10	N/A
Filter Area, each	ft <sup>2</sup>	160	N/A
Filter Loading Rate (2 in service)	gpm/ft <sup>2</sup>	3.26	2 to 4
Filter Media, Depth-Type	ft	1.5 - Anthracite 1 - Sand	2 to 2.5
Support Media, Depth-Type	ft	1 - Gravel	N/A
Backwash Pumps	No.	1	N/A
Backwash Flow Rate	gpm	3,200	N/A
Backwash Loading Rate	gpm/ft <sup>2</sup>	20	> 15
Air Scour Rate	scfm/ft <sup>2</sup>	4.5	3 to 5
Influent Pipe Diameter	inch	12	N/A
Influent Pipe Velocity	fps	1.5	< 2

ft=feet, ft<sup>2</sup>=square feet, scfm=standard cubic feet per minute

**Table 3 Filter Design Criteria**

The following is a summary of concerns related to the filters:

- a. At current flows filter loading rate will exceed maximum rates recommended by Ten State Standards if only one filter is in operation.
- b. Increased flows cause the filter loading rate to exceed maximum rates established by Ten State Standards with both filters in operation.
- c. There is currently no redundancy in the backwash process.

8. Disinfection and Clearwell Storage

Chlorine gas is used for disinfection and is applied between the filters and the clearwell. Table 4 lists the existing design parameters and associated virus removal credit.

Parameter	Units	Existing Value
Clearwell Volume	gallons	239,000
Design Flow	gpm	1,042
Clearwell Volume (as % of WTP capacity)	%	16
Contact Time (CT)	minutes	229
Chlorine Residual	mg/L	1.2
Baffling Factor	unit less	0.5
Full Volume CT	mg-min/L	137
Water Temperature	°C	15
pH		7.5
Full Volume Log Inactivation - Viruses	log units	>4

mg/L=milligrams per liter, mg-min/L=milligrams per minute per liter

**Table 4 Virus Removal Credit**

The Groundwater Treatment Rule states that a ground water system is subject to triggered source water monitoring if it does not already provide treatment to reliably achieve at least 99.99 percent (4-log) inactivation or removal of viruses. Results, utilizing the USEPA's CT Calculator with the specified values listed above, indicate that adequate disinfection contact time can be maintained even with a large increase in WTP capacity.

The CU WTP clearwell is a baffled underground concrete tank with a total volume of approximately 239,000 gallons. The amount of storage is approximately 16 percent of the rated 1.5 mgd treatment capacity. KDOW requires facilities to have approximately 15 percent of rated capacity clearwell storage for adequate hydraulic storage for standby and emergency use. If treatment capacity is increased, additional storage will be required or a variance will need to be requested from KDOW.

A summary of concerns related to the disinfection and clearwell is that clearwell storage will need to increase if plant capacity is increased, or a variance from KDOW will be needed.

#### 9. Chemical Treatment

The following is a summary of the chemical feed systems used to treat water before distribution at the CU WTP:

- a. Lime feed system used for reducing hardness. Lime is fed into the base of the claricone.
- b. Polymer feed system is used as a coagulant aid. Polymer is fed into the base of the claricone.
- c. Chlorine feed system is used for disinfection. Chlorine is fed into the filter effluent. Operators report less than 50 percent capacity of the feed system is required at maximum plant flow.
- d. Hydrofluorosilicic Acid (fluoride) is used as a dentifrice to reduce tooth decay. Fluoride is fed into the filter effluent. Operators report less than 50 percent capacity of the feed system is required at maximum WTP flow.
- e. Caustic soda was previously used to reduce hardness. Though caustic soda storage is available on-site, it is no longer in use for the treatment process.

The existing chemical feed systems currently have enough capacity to accommodate the existing design flow rate with spare capacity; therefore, no changes are required for the chemical feed systems.

## 10. Residuals Handling

The existing filter backwash waste and claricone-generated sludge currently discharge to a sewer that flows to four lagoons located several blocks from the WTP. CU reports that only two of the lagoons are needed at any one time for current operations. Increased WTP production utilizing the lime softening process would require additional lagoon storage (beyond the two currently needed) or an alternate residuals handling method, such as sludge dewatering, would be necessary.

Discharging the current filter backwash water into the sanitary sewer system for treatment at the wastewater treatment plant (WWTP) would further enhance the ability of two lagoons to sufficiently accommodate the lime softening sludge. Based on information from CU, the WWTP has the capacity to receive the filter backwash water.

A summary of concerns related to the residual handling is that the lagoon facility is located in an area of the City that is experiencing new development and interest. Though total elimination of the ponds is desired, the existing residual handling facility can be reduced in size but not likely eliminated unless other means of disposing of the lime sludge is developed. Redundancy should be maintained.

### C. Existing WTP Operation and Staffing

The existing WTP operates approximately 12 hours a day to provide adequate water volume to keep distribution storage tanks filled within their set operating ranges. Staffing hours can exceed 16 hours under peak-day demand conditions. Though the WTP is meeting existing demands with current operating conditions, planning for system growth (specifically new industrial customers) is of particular concern to CU. In addition, the existing WTP has minimal redundancy; therefore when problems occur, the WTP may need to be taken completely out of service for repair.

WTP ratings are assigned based on two parameters: rated capacity (e.g., III or IV) and staffing requirements (e.g., A or B). The WTP is currently rated at 1.5 mgd, treating groundwater not under the direct influence of a surface water, using gravity filtration. Therefore, it is currently classified as a Class III A facility. If the improvements include additional gravity filtration capacity and the rated capacity of the WTP increases to 3 mgd or more, the WTP will be rerated as Class IV A facility, with associated revised operator requirements.

A summary of concerns related to WTP operations and staffing is that the primary concern is related to the rerating. As CU's goal is to reduce the operations staff man-hours at the WTP, an increase in rated capacity could actually cause an increase in staff requirements. The Treatment Alternatives and the Conclusion sections address WTP rating further.

#### D. Water Source

The CU WTP uses three local wells, two within the WTP site and a third on the CU administrative building property, as its source for groundwater. Figure 2 shows the location of the three wells. Table 5 summarizes the information on the wells as listed in the Assembled Kentucky Groundwater Database. CU will continue to use these three wells as its water source after the proposed WTP improvements have been completed.

Well Name	AKGWA ID <sup>1</sup>	Latitude	Longitude
Well A	00020667	38° 40' 46.38" N	85° 10' 45.84" W
Well B	00004033	38° 40' 51.82" N	85° 10' 36.96" W
Well C	00020670	38° 40' 47.84" N	85° 10' 48.39" W

<sup>1</sup>AKGWA ID=Assembled Kentucky Groundwater Database Identification Number.

**Table 5 Groundwater Source Well Information**

##### 1. Groundwater Yield

CU's current withdrawal permit, No. 0129, limits the total withdrawal from all three wells as follows:

- a. 0.85 mgd January through May
- b. 1.0 mgd June through August
- c. 0.85 mgd September through December

Although the design capacity of the existing CU WTP is 1.5 mgd, it is typically operated about 12 hours a day, as discussed above. Therefore, CU is currently withdrawing water within the limits of its current permit. A new permit will be required to increase the maximum withdrawal above this rate.

A summary of concerns related to the groundwater yield is that CU reports having a prior groundwater study indicating water availability in excess of the current limits; therefore, there does not appear to be any concerns with source water capacity.

#### E. Water Quality

##### 1. Groundwater Quality

Available groundwater data for the three wells from lab test results provided in May 2012 is shown in detail in Appendix A. Select Monthly Operating Report (MOR) data is also included for reference.

Lab results indicate that no primary drinking finished water standards were exceeded within the raw water. Table 6 displays a list of other water quality parameters of interest.

Parameter	Units	Well A (1)	Well B (2)	Well C (3)	Post Air Stripper*	Secondary USEPA MCL
Iron Related Bacteria	CFU/mL	25	<10	<10	NA	-
Iron	mg/L	0.19	0.18	0.60	0.14	0.3
Manganese	mg/L	0.12	0.11	0.13	0.11	0.05
Total Hardness (as CaCO3)	mg/L	432	434.1	398	406.9	-
TDS	mg/L	616.7	543.3	510.0	533.3	500
Sodium	mg/L	28.4	23.3	20.7	21.1	-

\* Results obtained with water from two wells combined.  
CaCO3=calcium carbonate, CFU=Colony forming units per milliliter

**Table 6 Select Sampling Results vs. Secondary MCL Levels**

The following is a summary of concerns related to the groundwater quality:

- a. Table 6 shows that Well C has an elevated level of iron. By utilizing the air stripper and mixing groundwater from one of the other two wells these impacts can be mitigated. Initial iron related bacteria levels in Well C were also elevated. A resampling of water from this source indicated the level as reported in Table 6. According to CU staff this level is more representative of actual water quality given the sampling methodology and conditions. Manganese levels are somewhat elevated and could be a source of customer aesthetic complaints, if not reduced.
- b. Finished water total dissolved solids (TDS) values have not exceeded the secondary limit and this does not appear to be a concern.

2. Treated Water Quality

The CU WTP consistently produces a high quality effluent that meets all primary drinking water MCL standards. Secondary MCL concerns as a groundwater treatment facility include reduction of iron, manganese, and hardness. Table 7 shows the average effluent iron, manganese, and hardness levels for the CU WTP. These results are based on select MOR data provided in Appendix A, which also show daily treated water quality for the CU WTP.

Parameter	Units	Average Treated Concentration	Secondary USEPA MCL
Iron	mg/L	0.03	0.3
Manganese	mg/L	0.04	0.05
Hardness	mg/L	183	-

**Table 7 Select Finished Water Quality Data**

There are currently no reported concerns related to the treated water quality.



## WATER QUALITY AND OPERATIONAL GOALS

CU has identified the following goals for the WTP improvements, which are to:

1. Limit the sludge production so that additional sludge drying beds are not required, and potentially reduce or eliminate the existing drying beds.
2. Reduce operator time requirements to one 8-hour shift a day.
3. Maintain or improve existing effluent water quality.
4. Maintain a treated water hardness below 200 mg/L.
5. Provide treatment redundancy so that equipment can be taken offline for maintenance.

These goals were taken into consideration when selecting the appropriate treatment alternative for the CU WTP expansion.

## TREATMENT ALTERNATIVES


A preliminary evaluation was conducted to consider whether the existing treatment site could be used or a new treatment site would be required to accommodate project demands and new equipment. Given the relatively good condition of the structures, equipment, WTP site, and availability of land, the existing plant facilities should be able to operate and accommodate the WTP expansion. Therefore, the alternatives presented below are based on utilizing the existing WTP site.

Three alternatives were considered to increase the design capacity of the CU WTP:

### A. Alternative 1: Increase Lime Softening and Filter Capacities

Alternative 1 essentially involves duplicating the existing treatment process to create two treatment trains each with a treatment capacity of 1.5 mgd. This will allow CU to produce up to 1 mgd during a single 8-hour period each day. Figure 4 shows a schematic of Alternative 1, which includes the following improvements:

1. Increase well pumping capacity.
2. Add media to the air strippers.
3. Add two low lift pumps to increase capacity and provide redundancy. New low lift pumps would be equipped with variable frequency drives (VFDs) to control flow through the WTP.
4. Install a second claricone identical to the existing claricone. Because of the size of the claricone, placing another in service would require a new building or building expansion.



**ALTERNATIVE 1 TREATMENT SCHEMATIC  
EXISTING PROCESS EXPANSION WITH SLUDGE DEWATERING**

**WTP AND DISTRIBUTION SYSTEM IMPROVEMENTS PER  
CARROLLTON UTILITIES  
CARROLLTON, KENTUCKY**



**FIGURE 4  
5104.002**

5. Install new sludge dewatering equipment to meet CU's goal of reducing sludge production.
6. Install a new recarbonation tank. The new recarbonation tank will need to be approximately three times larger than the existing tank to meet current detention time requirements in Ten State Standards. A smaller unit could provide redundancy with a variance given from KDOW.
7. Install two new filters identical in size to the existing filters. Because of the placement of the filters, new filters would require a building expansion.
8. Install a backup filter backwash pump or connection to distribution system.
9. Install a new 8- to 12-inch transmission main to the General Butler storage tank to accommodate the increased instantaneous flow rate.
10. Install new gravity main to existing wastewater pump station to divert filter backwash from the sludge holding ponds.


The advantage of this alternative is that operators are familiar with the process.

The disadvantages of this alternative include the following:

1. New equipment would require a new building or considerable building expansion. This translates to a higher cost than Alternative 2.
2. Additional sludge processing and dewatering equipment required to meet goal of reduced sludge production.
3. To avoid a reclassification of the plant to Class IV A, the plant would have to treat water at a rate just under 3 mgd.
4. To reduce staffing requirements at existing demand, transmission main improvements are required.

#### B. Alternative 2: Ion Exchange Softening

Alternative 2 includes adding a parallel ion exchange softening treatment plant to the existing treatment facilities. The ion exchange treatment process will be rated for 1.5 mgd and will be designed to run separately from the existing treatment process, increasing the total potential treatment capacity to 3 mgd, dependent upon well capacity. Total WTP capacity will be *rated* at less than 3 mgd since well capacity is currently only 1.6 mgd. Figures 5, 6, and 7 show a schematic, site plan, and treatment building plan of Alternative 2, respectively, which includes the following improvements:




**ALTERNATIVE 2 TREATMENT SCHEMATIC  
ION EXCHANGE PLANT**

**WTP AND DISTRIBUTION SYSTEM IMPROVEMENTS PER  
CARROLLTON UTILITIES  
CARROLLTON, KENTUCKY**



**FIGURE 5  
5104.002**



NO.	REVISIONS	DATE

ALTERNATIVE 2 PROPOSED WTP SITE PLAN

WTP AND DISTRIBUTION SYSTEM IMPROVEMENTS PER  
CARROLLTON UTILITIES  
CARROLL COUNTY, KENTUCKY



JOB NO.  
5104.002  
PROJECT MGR.



FIGURE 6



ALTERNATE EQUIPMENT LAYOUT



DATE:	NO.	REVISIONS

ALTERNATIVE 2 PROPOSED TREATMENT BUILDING PLAN

WTP AND DISTRIBUTION SYSTEM IMPROVEMENTS PER  
CARROLLTON UTILITIES  
CARROLL COUNTY, KENTUCKY

JOB NO.  
5104.002

PROJECT MGR.



FIGURE 7

1. Add one low lift pump to provide redundancy. The new low lift pump would be equipped with a VFD to control flow through the WTP. The required head at 1,040 gpm is anticipated to be between 27 and 40 feet depending on operating condition but could be sized to match the existing pump. Controls requirements will be reviewed during final design to confirm the existing pump can be utilized for this application.
2. Install three ion exchange units with a total design capacity for all three units of 1.5 mgd. The caustic soda tanks and containment walls would be removed to make room for the ion exchange units.
3. Provide a new brine system including brine storage and feed pumps.
4. Provide a new sewer line from the WTP to a nearby sanitary manhole to receive backwash from the ion exchange units.

The advantages of Alternative 2 include the following:

1. New equipment would not require a new building or building expansion.
2. Reduced sludge production.
3. Reduced operator time requirements because of a different treatment classification. Since there is not a filtration step, the ion exchange WTP should be considered a Class III B facility if it is rated separately from the lime softening process. Although KDOW staff are uncertain of the exact rating designation of the WTP, they have stated that the ion exchange process can be operated in a semiautomated condition with reduced operating requirements similar to a Class III B rating.
4. All existing equipment still available for use as second treatment train.
5. Delayed distribution system improvements. An ion-exchange WTP can be operated over a longer period of time while still reducing staffing requirements at the WTP because of the difference in classification mentioned previously. Treating water at the current production rate and number of production shifts or at a reduced rate for an additional shift postpones the need for transmission main improvements which would be required to accommodate higher instantaneous flow rates from the WTP described in Alternatives 1 and 3.

The disadvantages of Alternative 2 include the following:

1. Effluent concentrations of sodium and manganese will need to be balanced.
2. Operators are not currently treating water with the process.
3. Water quality aesthetics will be different than the existing finished water.

### C. Alternative 3: Fluidized Bed Reactors

Alternative 3 is similar to Alternative 1 except the additional claricone is replaced with two fluidized bed reactors (FBRs). Figure 8 shows a schematic of Alternative 3, which includes the following improvements:

1. Increase well pumping capacity.
2. Add media to the air strippers.
3. Add two low lift pumps to increase capacity and provide redundancy. New low lift pumps would be equipped with VFDs to control flow through the WTP.
4. Provide two new FBRs.
5. Install a new recarbonation tank. The new recarbonation tank would need to be approximately three times larger than the existing tank to meet current detention time requirements in Ten State Standards.
6. Install two new filters identical in size to the existing filters. Because of the placement of the filters, new filters would require a building expansion.
7. Provide a sand retention basin to receive FBR backwash for later removal and disposal.
8. Install a backup filter backwash pump or connection to distribution system.
9. Install new 8- to 12-inch transmission main to the General Butler storage tank to accommodate increased flows.
10. Install new gravity sewer main to existing wastewater pump station to divert filter backwash from the sludge holding ponds.


The advantages of Alternative 3 include the following:

1. Reuses most of existing equipment.
2. Does not increase sludge production.

The disadvantages of Alternative 3 include the following:

1. Filter expansion and FBR addition would require new building or building expansion.
2. Although sludge is reduced, FBR process would require sand removal.





**ALTERNATIVE 3 TREATMENT SCHEMATIC  
FBR SOFTENING ADDITION WITH FILTER EXPANSION**

**WTP AND DISTRIBUTION SYSTEM IMPROVEMENTS PER  
CARROLLTON UTILITIES  
CARROLLTON, KENTUCKY**



**FIGURE 8  
5104.002**

3. To avoid a reclassification of the plant to Class IV A, the WTP would have to treat water at a rate just under 3 mgd.
4. To reduce staffing requirements at existing demand, transmission main improvements are required.
5. Operators are not currently treating water with the process.
6. Water quality aesthetics will be different than the existing finished water.

## ALTERNATIVE SELECTION AND CONSIDERATIONS

The ion exchange alternative offers a combination of reduced operations, process stability, and cost-effectiveness. Any changes to water aesthetics can be mitigated by the ability to operate the existing lime softening process for portions of the day. After reviewing the alternatives, Alternative 2 was selected as the preferred alternative.

### A. Process Considerations

Table 8 provides a proposed list of design criteria for the ion exchange process. The design criteria, specifically the bypass rate, was chosen to reduce the treated water manganese levels below 0.05 mg/L and establish a maximum reduction in manganese and total hardness that may be required of the equipment. In operating the ion exchange units, operations staff will need to balance treatment of aesthetic water quality (nonprimary drinking water) constituents including hardness, sodium, and manganese. As additional flow above the design criteria shown is bypassed around the ion exchange units, the treated water hardness and manganese levels will increase while sodium levels will decrease.

TABLE 8—ION EXCHANGE DESIGN CRITERIA

Parameter	Value			Units
	Minimum	Maximum	Average	
<b>Raw Water Quality</b>				
Total Hardness	360	466	424	mg/L as CaCO <sub>3</sub>
Calcium Hardness	270	290	282	mg/L as CaCO <sub>3</sub>
Magnesium Hardness	90	176	142	mg/L as CaCO <sub>3</sub>
Alkalinity	320	350	336	mg/L as CaCO <sub>3</sub>
Sulfates	45	51	48	mg/L as SO <sub>4</sub>
Iron	0.14	0.6	0.32	mg/L as Fe
Manganese	0.11	0.18	0.12	mg/L as Mn
Sodium	21	28	24	mg/L
pH	6.7	8	7.44	none
<b>Treated Water Quality</b>				
	Minimum	Maximum	Average	
Total Hardness <sup>1</sup>	90	207	182	mg/L as CaCO <sub>3</sub>
Calcium Hardness	68	129	121	mg/L as Ca
Magnesium Hardness	23	78	61	mg/L as Mg
Sulfates	45	51	48	mg/L as SO <sub>4</sub>
Iron	0.04	0.27	0.14	mg/L as Fe
Manganese <sup>2</sup>	0.03	0.05	0.05	mg/L as Mn
Sodium <sup>3</sup>	91	189	135	mg/L
<b>Plant</b>				
	Min	Max	Avg	
Capacity	1,040	1,040	1,040	gpm
% Bypass <sup>4</sup>	25	45	43	%
Bypass Flow	260	463	447	gpm
Treated Flow	577	780	593	gpm
Demand		1	0.75	mgd

<sup>1</sup>Minimum calculated from bypass required for maximum required Mn removal needed at minimum raw hardness.

<sup>2</sup>Maximum calculated from bypass required for maximum Mn removal needed at maximum raw Mn.

<sup>3</sup>Maximum calculated from bypass required for maximum Mn removal needed at maximum raw hardness; minimum calculated from minimum raw hardness and maximum treated hardness.

<sup>4</sup>Minimum calculated from maximum required for Mn removal needed at maximum raw Mn.

TABLE 8—ION EXCHANGE DESIGN CRITERIA (CONTINUED)

Parameter	Value	Units
<b>Softeners</b>		
Type		Vertical Pressure
Number of units, n	3	Units
Operating Mode	2	in Service - 1 Standby
Total Softener Height	9.98	ft
Softener Side Shell Height	4.08	ft
Diameter	8.5	ft
Area (ea)	56.7	ft <sup>2</sup>
Loading Rate (n units in service)	4.6	gpm/ft <sup>2</sup> (maximum)
Loading Rate (n-1 units in service)	6.9	gpm/ft <sup>2</sup> (maximum)
Resin Depth	3	ft (minimum)
Treatment Capacity	20,000	g/cf (maximum)
Bed Capacity (ea)	3,402,975	grains
Resin Volume per Vessel	170	ft <sup>3</sup>
Backwash Rate	284	gpm
Backwash Rate	5.0	gpm/ft <sup>2</sup>
Backwash Duration	10	minutes
Backwash Volume	2,837	gallons
Regeneration	6.0	# salt /cf of resin
Brine Flow at 50% saturation	31	gpm
Brine Duration	25	minutes
Brine Volume at 50% saturation	775	gallons
Slow Rinse Flow	31	gpm
Slow Rinse Duration	25	minutes
Slow Rinse Volume	775	gallons
Fast Rinse flow	270.4	gpm
Fast Rinse Duration	10	minutes
Fast Rinse Volume	2,704	gallons
Total Waste per Regeneration	7,091	gallons
Average Total Hardness removed	25.4	grains/gallon
Volume treated between regenerations	133,817	gallons
Time between Regenerations	8.6	hours
<b>Salt Storage Tank</b>		
Number	2	
Salt Required per Regeneration	1,021	pounds
Salt Required per 1 MG treated	7,630	pounds
Salt Required per 1 MG blended finished water	5,722	pounds
30 Day Salt Supply @ Avg Day Demand	128,753	pounds
Salt Storage Tank Capacity	64	tons
Salt Storage Tank Capacity (ea)	32	tons

**TABLE 8—ION EXCHANGE DESIGN CRITERIA (CONTINUED)**

Parameter	Value	Units
<b>Brine Pumps</b>		
Number	2	
Type	By Equipment Manufacturer	
Capacity	15	gpm
Head	TBD	ft

As mentioned previously, the raw water from Well C has somewhat elevated levels of iron. Ten State Standards provide the following design considerations: iron, manganese, or a combination of the two, should not exceed 0.3 mg/L in the water as applied to the ion exchange resin. Pretreatment is required when the content of iron, manganese, or a combination of the two, is one milligram per liter or more. Therefore, the air strippers should continue to be utilized and effluent iron and manganese levels monitored. If water from Well C is utilized, it should be blended with water from one of the other two wells.

The equipment sizes and number were chosen to meet Ten State Standards and project requirements. The existing overhead door on the alley side of the WTP building will accommodate 8.5-foot-diameter softener units. Such units will also fit within the space available in the treatment building. Three units are required so that maximum loading rates are not exceeded with one unit out of service. For short periods of time, higher flow rates could be obtained with all three units in service. Brine storage in excess of 64 tons is required to meet 30-day storage requirements. Two 36-ton units are recommended to meet redundancy requirements. Multiple units facilitate one tank being taken offline for cleaning while the other remains in service.

CU may choose to utilize a coarse rock salt product, a solar salt or a granulated food grade salt.

Ion exchange equipment manufacturers indicate the food grade salt requires a gravel bed to be placed in the bottom of the brine maker. The coarse salt does not require the gravel subfill and is much more cost-effective. However, the coarse salt can contain traces of dirt which, over time, will require maintenance to remove sludge from the brine tanks. This manufacturer also offers a solar salt that is a cleaner product, similar in size to the rock salt. The cost for this product is between the rock salt and granulated salt products.

Budgetary costs for the three provided by a regional salt supply company are shown below. The prices include delivery of a minimum of 25 tons via a pneumatic truck.

Bulk Southern Coarse Rock Salt: \$115.00 per ton

Bulk Solar Salt: \$135.00 per ton

Bulk Granulated Special Purity Salt: \$156.00 per ton

At average raw water hardness and average water production, the amount of salt required could range from 48 to 64 tons per month depending on the amount of water bypassing the softeners. This would translate into an average of \$6,500 to \$8,600 a month in salt expenses. Current lime expenses have been between \$4,000 to \$5,000 per month.

The peak discharge rate from the backwash process is expected to be 284 gpm. An 8-inch sewer laid at minimum grade should be able to accommodate this flow. Given that it is expected that there will still be at least two lagoons available for use if the existing filtration process is utilized, the sewer will be designed to accept only the ion exchange backwash and not the filter backwash. The receiving point of this flow is expected to be a manhole at the intersection of the alley to the west of the WTP and Sycamore Street. CU staff indicated the sewer collection system is capable of handling this flow.

At the above-referenced salt usage a month, the daily average chloride waste level is expected to be approximately 2,600 pounds per day. At the WWTP design flow rate of 3.4 mgd, this equates to approximately 90 mg/L of chlorides being added to the effluent. At the average dry weather flow rate of 0.75 mgd, the concentration would be approximately 415 mg/L. The presence of chlorides in the waste stream will likely trigger KDOW to issue a chloride limit on the wastewater effluent, which will require sampling.

Typical water quality criteria levels for chlorides are 250 mg/L for human health, and 600 mg/L and 1,200 mg/L for chronic and acute warm water aquatic life protection, respectively. Meeting the human health and chronic aquatic related limits are further eased by the fact that the limits apply to the seven day 10 year low flow (7Q10) of the receiving stream, the Kentucky River, and not the effluent flow rate itself. At these limits, the chloride addition is not expected to have an impact on WWTP discharge compliance. Elevated chloride levels may result in higher rates of corrosion of equipment in the WWTP.

#### B. Structural Considerations

Based on our review of the record drawings, it appears that structural cast-in-place concrete equipment bases can be used to support the proposed ion exchange vessels. Therefore, we do not anticipate the need to cut the slab and provide isolated footings for the ion exchange vessels.

Additionally, we anticipate that an interior manhole or sump used to convey backwash to a new sewer in the adjacent alley can be constructed with cast-in-place concrete on the existing slab. This can be accomplished by constructing new walls and a slab or by constructing the walls directly on top of the existing slab. In either case, it is recommended the interior of the sump be treated with a flexible liner to reduce the potential for leaks.

The proposed ion exchange vessels and backwash manhole will likely conflict with an existing set of stairs to the lower level. To maintain this access into the lower level the existing stairs will need to be relocated or a new set of stairs will be needed. This will also require replacement or modification to the existing safety railing.

It is strongly recommended that a geotechnical investigation be performed on-site to properly design the brine storage facilities. The geotechnical investigation and report provide vital information during structural design and construction such as anticipated soil conditions, identification of poor soils, and recommended bearing pressures. This information is utilized during structural design to promote a cost-effective and safe design while reducing the risk of potential change orders during construction because of poor soil conditions. We can assist CU in obtaining cost proposals from geotechnical engineering firms as needed.

### C. Electrical Considerations

The WTP electrical service is 600 amp, 480 volt, three phase, 60 Hz. The electrical service disconnect is a 600 amp circuit breaker located in the motor control center. Power is distributed to motors and other utilization equipment from the motor control center. Power for lighting, receptacles and other general loads is provided at 208"Y"/120 volt, three phase, 60 Hz from a dry-type transformer and panel board.

In a past WTP renovation project, the two high service pump starters were abandoned and replaced with a separate high service pump control panel. This panel is fed from the existing motor control center.

The motor control center contains abandoned starters and spaces that can be reconfigured for other purposes such as additional circuit breakers or motor starters. If new VFDs are utilized in a plant renovation, they will likely require remote mounting.

Based on actual demand the 600 amp service is adequate with some additional capacity available. Based on current future load projections, the 600 amp service will be adequate for the two low lift pumps. However, if proposed electrical loads exceed the 600 amp service, additional capacity can be provided in the motor control center by placing the existing high service pump control panel on a separate circuit and increasing the service conductor size.

### **PERMIT REQUIREMENTS**

A KDOW drinking water permit to construct the proposed facilities will be required.

As previously mentioned, results of discussions with KDOW staff indicate that reduced staffing requirements will be allowed while utilizing the ion exchange units. As part of its response to this PER, it is expected that KDOW will address the rating of the facility, which may require an additional permit application, additional information included on MORs, or other documentation.

A building permit from the Kentucky Department of Housing, Buildings, and Construction (HBC) is not anticipated since no building additions are required for the preferred Alternative 2. Local building code requirements may require an approval of the proposed facilities.

If a withdrawal of groundwater greater than the current permitted quantity is desired, a revised permit application will be required.

### **OPINION OF PROBABLE COST**

Table 9 is the opinion of probable cost summarized by key components.



Item	Cost
New Intermediate Pumps and Controls	\$31,000
New Ion Exchange Sewer	15,000
Process and Yard Piping	50,000
Electrical	48,000
Site Work	20,000
Painting	25,000
Miscellaneous Structure Improvements	18,000
Installation of Ion Exchange Units and Appurtenances	89,000
<b>Subtotal</b>	<b>\$296,000</b>
Planning Level Cost Opinion Contingency	74,000
<b>Subtotal</b>	<b>\$370,000</b>
Contractor General Conditions and Profit	37,000
Ion Exchange Units and Appurtenances	444,000
<b>Total</b>	<b>\$851,000</b>

**Table 9 Planning Level Opinion of Probable Construction Cost**

To reduce construction costs, the following options were considered:

1. Three 7-foot-diameter units or two 8.5-foot-diameter units could be provided in lieu of the three 8.5-foot-diameter units. This would require all units to be in service to meet design criteria standards. This would also reduce the time between regenerations to approximately 6 hours. Additional media depth could be provided which would allow the units to run nine to ten hours before requiring regeneration but raise the price.
2. Provide two 12-foot-diameter units, which would provide similar performance to the three 8.5-foot-diameter units. Though the number of valves and fittings would be reduced, the manufacturer indicated the overall cost would be more and, at this size, the installation of the units would be more challenging and may not be possible through the existing 12-foot by 10-foot overhead door.

## DISTRIBUTION SYSTEM IMPROVEMENTS

### A. General

The objective of the water distribution system improvements is to extend potable water service to new customers and improve service to existing customers. The long term capital improvement plan for the WCWD system includes additional improvements adjacent to this project area. Consideration is given to these future improvements as pump stations and lines are sized for the project at hand.

Distribution system improvements, primarily within the WCWD service area, include approximately 49,600 linear feet of 3-inch polyvinyl chloride (PVC), 4-inch ductile iron (DI), 6-inch PVC, and 6-inch DI water mains with appurtenances to serve approximately 25 new customers in areas throughout Carroll, Henry, and Trimble Counties.

Additionally, the project includes a 40-gpm booster pump station on Kings Ridge Road, 60-gpm booster pump station on Gilgal Road, and appurtenances. The Kings Ridge Road booster pump station will fill the existing Bells Ridge Tank while the new Gilgal Road booster pump station will fill the existing Gilgal Tank.



The project goal is to provide potable water to currently unserved areas, as well as replacing some existing mains and possibly adding a new transmission main. The following new line extensions, transmission main and pump stations were analyzed for viability:

1. Painter's Ridge Road
2. Miller's Branch Road
3. Hardy Creek Road
4. R. D. Kendall Road
5. Nora (Smith) Lane
6. Mound Hill Road
7. Turkey Run Road
8. New transmission main to serve General Butler Storage Tank.
9. Line replacement on Gilgal Road.
10. Two new booster pump stations—Gilgal Road and Kings Ridge.
11. New supervisory control and data acquisition (SCADA) on the new booster stations and the tanks they fill to give the ability to turn on/off the booster pumps based on tank elevations.

Figure 9 shows a map of these improvements. Table 10 provides a summary of the water mains in the project. The columns labeled "Name" and "Main Size/Road" refer to the proposed mains. The column "Supply Main Size/Road" refers to the water main feeding the proposed main. The supply mains will either be another proposed main or an existing main. The "Supply Pump" column refers to the pump that is either on the suction or discharge side of the proposed main, which will affect pressures in the main.

# Legend

- Proposed PS
- Proposed Improvements
- Existing PS
- WTP Existing WTP
- Existing Tanks**
- WCWD Tank
- CU Tank
- CCWD#1 Tank
- Other Tanks
- Interstate
- US HWY
- KY HWY
- Local Road
- Water Lines
- Utility Service Boundaries**
- WCWD Boundary
- CU Boundary
- CCWD#1 Boundary



**DISTRIBUTION SYSTEM IMPROVEMENTS**

**WTP AND DISTRIBUTION SYSTEM IMPROVEMENTS PER  
CARROLLTON UTILITIES  
CARROLLTON, KENTUCKY**



**FIGURE 9  
5104.002**

“High Ground Elevation” is the highest elevation that will be served by the main either on the road or the area surrounding it. “Minimum Pressure” is the lowest expected pressure that will be provided in the vicinity of the proposed main.

TABLE 10

## SUMMARY OF WATER MAIN ADDITIONS

Name	Main Size/Road	Supply Main Size/Road	Supply Tank/Overflow Elevation	Supply Pump	High Ground Elevation (feet)	Minimum Pressure* (psi)
A	3-inch water main Painter's Ridge Road	3-inch water main Wrights Ridge Road	Bells Ridge Tank 1,075 feet	N/A	875	38
B	3-inch water main RD Kendall Road	3-inch water main RD Kendall Road	Bells Ridge Tank 1,075 feet	N/A	890	48
C	3-inch water main Miller's Branch	3-inch water main Miller's Branch	Bells Ridge Tank 1,075 feet	N/A	590	200
D	3-inch water main Hardy Creek	3-inch water main Hardy Creek	Bells Ridge Tank 1,075 feet	N/A	570	172
E	6-inch water main US 42/KY 36/Kings Ridge Road	6-inch water main US 42/KY 36	General Butler Tank 721 feet	Proposed Kings Ridge Pump Station	815	50
F	3-inch water main Mound Hill Road	6-inch water main Mound Hill Road	Mound Hill Tank 999 feet	N/A	880	43
G	4-inch water main Gilgal Road	3-inch water main Gilgal Road	Carroll Utilities MM-73 psi Minimum at Tie-in Location or 688 feet	Proposed Gilgal Road PS	850	60
H	3-inch water main Nora Lane	3-inch water main English Road	Gilgal Tank 976 feet	N/A	880	30

\* Minimum pressure calculations based on tank down 10 feet and peak demand headloss.

## B. WCWD Line Extensions and Mains

The hydraulic analysis on each proposed improvement is included in Appendix B. This analysis considered the existing tank serving each main, the characteristics of the existing mains, and the users. The hydraulic grade line (HGL) was based on the tank overflow elevation and the assumption that the water level is ten feet below the overflow. The HGL reflects the head loss generated throughout the existing and proposed mains because of the usage in the main.

Projected peak water usage was based on recent historical data concerning existing customers of the water supply system. Peak water usage was based on D.R. Taylor curve, or the square root of the total number of users times 10. This usage was included in the analysis.

According to Ten State Standards 8.1.6b, all dead-end mains shall provide 2.5 feet per second (fps) flushing velocity. The design of all mains should maintain the required 30 psi to all customers on this extension and 20 psi when flushing. Lines A, E, F, and G should maintain the required 20 psi when flushing at the low point on the main. Line H will need a mechanical form of cleaning since a 2.5 fps flushing velocity likely cannot be maintained.

During the completion of the hydraulic analysis, insufficient pressure and flushing velocity was identified on the Turkey Run Road line extension. The extension could not be served by the existing tank through the proposed main without the use of a new booster station. The anticipated shortfall in pressure and velocity is because of the existing elevation in portions of the proposed extension compared to the projected HGL in this area. Details of the analysis are provided in Appendix B.

Based on this information, the Turkey Run Road line extension was eliminated from the project. The area could be served in the future with the installation of a line extension supported by a booster pump station.

## C. Pump Stations

**Kings Ridge Road Pump Station**—This station will be an entirely new station where one does not currently exist. The overflow of the General Butler Tank, serving the proposed pump station, is 721 feet mean sea level (MSL), and the overflow of the Bells Ridge tank is 1,075 feet MSL. The ground elevation of the new pump station is approximately 590 feet MSL.

This new pump station should maintain the required 30 psi to all users on both the suction and discharge side based on the ground elevation of the land versus the HGL when the pump station is running (see the hydraulic analysis in Appendix B). The majority of the area should maintain 80 psi except for the locations of the existing tanks and the proposed pump station. This station was sized to maximize the flow rate while simultaneously maintaining line pressures that are within the acceptable range.

The pump station will be served with the existing single-phase power located in the area and converted to three-phase power through VFDs located within the proposed station. The pump station will be equipped with quick connects for a generator should emergency power be needed.

SCADA will be provided that will control the pump station on and off times based on the elevation of water in the Bells Ridge Tank.

The pumps for this station are rated for 40 gpm at 470 feet of total dynamic head (TDH) based on preliminary hydraulic calculations. The size of these pumps were limited because of the existing large amount of 3-inch mains located in the existing system that incurred a lot of head loss that required more TDH to overcome that increased the pressure on the discharge side of the booster station.

**Gilgal Road Pump Station**—This station is replacing an existing aged station at the same location. This pump station is being served by CU through a master meter. This existing pump station, as well as the new pump station, will fill the existing Gilgal Tank, which has an overflow of 976 feet MSL. The ground elevation of the new and existing pump station is approximately 520 feet MSL.

This new pump station should maintain the required 30 psi to all users on the discharge side based on the ground elevation of the land versus the HGL when the pump station is running (see the hydraulic analysis in Appendix B). The majority of the area should maintain over 100 psi except for the locations of the existing tank and the proposed pump station.

The pump station will be served with the existing single-phase power located in the area and converted to three-phase power through VFDs located within the proposed station. The pump station will be equipped with quick connects for a generator if emergency power is needed.

SCADA will be provided that will control the pump station On and Off times based on the elevation of water in the Gilgal Tank.

The pumps for this station are rated for 60 gpm at 310 feet of TDH based on preliminary hydraulic calculations. Piping on the discharge side of the proposed pump station is being upgraded to a 4-inch main to reduce headloss and pressure on the discharge sides of the pumps.

#### D. CU Transmission Main

The original proposed improvements included a new transmission main from 6th Street to Gillock Avenue to serve the side-by-side storage tanks located in General Butler State Park. The new main was initially proposed to increase the volume of water transmitted to the tanks, thereby reducing the amount of time required to fill the tanks. This objective supported the goal of reducing the operation time of the WTP. Subsequent treatment process changes at the WTP and the hydraulic analysis of the existing and proposed transmission mains revealed minimal benefits of a new transmission main.

Strand Associates, Inc.<sup>®</sup> (Strand) utilized an existing EPANET model provided by CU to analyze the proposed transmission line; the results of which are included in Appendix C. Under existing conditions, the maximum pressure using one high service pump is approximately 121 psi in the system and it takes approximately 13 hours to fill the General Butler tanks. Under existing conditions, the maximum pressure using two high service pumps for the existing system is approximately 137 psi and it takes about 5 hours to fill the General Butler tanks.

Strand evaluated three improvement scenarios, described below, to assess the time to fill the tanks without over pressurizing the existing system. The EPANET modeling results and scenarios are included in Appendix C.

1. Scenario 1 considers a new 8-inch main parallel with the existing 8-inch main on 6th Street to Gillock Avenue with both high service pumps running. The maximum pressure would be about 127 psi and it would take approximately 3.5 hours to fill the tank. The cost opinion for approximately 5,200 linear feet of 8-inch ductile iron pipe mainly in the roadway would be approximately \$208,000.
2. Scenario 2 indicates when a new 10-inch main is paralleled with the existing main 8-inch main on 6th Street to Gillock Avenue and both high service pumps are running. The maximum pressure is about 124 psi and it takes approximately 3 hours to fill the tank. The cost opinion for approximately 5,200 linear feet of 10-inch ductile iron pipe mainly in the roadway would be approximately \$260,000.
3. Scenario 3 accounts for a 12-inch main parallel with the existing 8-inch main on 6th Street to Gillock Avenue and both high service pumps running. The maximum pressure would be about 121 psi and would take approximately 3 hours to fill the tank. The cost opinion for approximately 5,200 linear feet of 12-inch ductile iron pipe mainly in the roadway would be approximately \$312,000.

Another alternative might include using one large pump instead of two smaller pumps. However, this alternative would increase pressure in the existing system.

Based on these results, it appears all three scenarios produce minimal benefit, especially when costs-to-benefit ratios are considered. Therefore, a new transmission main to serve the General Butler Storage Tanks is not warranted at this time and has been removed from the project.

#### E. Proposed Construction Cost Opinion

The proposed construction cost opinion of these improvements, without the Turkey Run Road extension and the General Butler Tank transmission main, is approximately \$762,760, not including contingencies.

Appendix D provides a detailed table showing the proposed construction cost opinion.



## CONCLUSIONS AND RECOMMENDATIONS

The following conclusions are based on the analysis and evaluation described in the previous sections of this report, discussions with utility staff and management, preliminary discussions with KDOW, the resulting recommendations from Strand, and the selection of those recommendations by CU and WCWD:

### A. WTP

1. Install a 1.5 mgd ion exchange softening treatment plant with the following features as indicated in Alternative 2.
  - a. Three ion exchange units each being a 8.5-foot-diameter tank. (Remove the existing caustic soda tanks and containment walls).
  - b. Two brine storage tanks with two brine feed pumps
  - c. Selection of the type of salt will be made during the final design phase based primarily on:
    - (1) Cost-benefit ratio of the cost versus additional manpower associated with each.
    - (2) CU's desire to potentially use the salt for future hypochlorite production.
2. Acquire the property immediately adjacent to the rear of the existing WTP building, if possible, to accommodate the brine storage tanks and to provide access to them. An alternative location for these tanks is immediately behind the WTP building near the air stripper towers.
3. Perform a geotechnical investigation on the brine storage tank site.
4. Install one additional low lift VFD driven pump. Leave the existing low lift pump in place (further detailed analysis will be completed in final design to confirm the existing pump can be utilized). Plumb both pumps such that either one can be used with either the ion exchange process or the lime softening process.
5. Utilize existing spaces in the motor control center for circuit breakers or motor starters. VFDs will likely require remote mounting, which will be determined during final design.
6. Install a new sewer line from the WTP to a nearby sanitary manhole to receive backwash from the ion exchange units.

7. Construct an interior manhole or sump to be used to convey backwash water to the new sewer.
8. Maintain the existing lime-softening treatment plant without any changes or improvements incorporated into this project (CU may benefit from extensive maintenance once the new ion exchange process is online.)
9. Maintain two of the existing lime sludge ponds near 2nd Street.
10. Request a 1.5 mgd rating for the ion exchange process (independent of the lime softening process) and a corresponding Class III B rating from KDOW.
11. Percent of water treated by the ion exchange process will need to be balanced based on raw water quality and desired finished water levels of iron, manganese, sodium and hardness.

B. Distribution System Improvements

1. Proceed with line extensions, as described in this report, except for the removal of the Turkey Run Road extension, which will be removed from this project.
2. Install two booster pump stations: at Kings Ridge Road and at Gilgal Road, as described.
3. Utilize single-phase electrical service at each pump station, which will be converted to three-phase electrical service through the VFDs.
4. Install quick-connects for generator connections.
5. Remove the transmission main from 6th Street to Gillock Avenue from this project.

The improvements discussed in this report will likely provide CU with cost-effective infrastructure for its existing customers and establish a plan to serve future community growth.

APPENDIX A  
WATER QUALITY DATA

---

# Report of Laboratory Analysis




635 Green Road, PO Box 968, Madison, IN 47250  
 Tel: 812.273.6699 Fax: 812.273.5788

**Report To:**  
 Corina Beach  
 CARROLLTON UTILITIES  
 P.O. BOX 269  
 CARROLLTON, KY 41008

Order No.: 2012050158  
 PO No.:  
 Date Received: 05/03/2012  
 Report Date: 05/24/2012

Lab Id	Matrix	Identification	Date Collected	Collected By	Description		
P05-152	Drinking Water	WPA	5/2/2012	FT			
Test Name	Results	Units	Analyst	Detection Limit	Test Method	Analysis Date	
Benzene	<0.5	ug/L	THB	0.5	EPA 524.2	5/3/2012	
Carbon Tetrachloride	<0.5	ug/L	THB	0.5	EPA 524.2	5/3/2012	
Chlorobenzene	<0.5	ug/L	THB	0.5	EPA 524.2	5/3/2012	
1,2-Dichlorobenzene	<0.5	ug/L	THB	0.5	EPA 524.2	5/3/2012	
1,4-Dichlorobenzene	<0.5	ug/L	THB	0.5	EPA 524.2	5/3/2012	
1,2-Dichloroethane	<0.5	ug/L	THB	0.5	EPA 524.2	5/3/2012	
1,1-Dichloroethylene	<0.5	ug/L	THB	0.5	EPA 524.2	5/3/2012	
1,2-Dichloroethylene,cis	<0.5	ug/L	THB	0.5	EPA 524.2	5/3/2012	
1,2-Dichloroethylene,trans	<0.5	ug/L	THB	0.5	EPA 524.2	5/3/2012	
Methylene Chloride (Dichloromethane)	<0.5	ug/L	THB	0.5	EPA 524.2	5/3/2012	
1,2-Dichloropropane	<0.5	ug/L	THB	0.5	EPA 524.2	5/3/2012	
Ethylbenzene	<0.5	ug/L	THB	0.5	EPA 524.2	5/3/2012	
Styrene	<0.5	ug/L	THB	0.5	EPA 524.2	5/3/2012	
Tetrachloroethylene	<0.5	ug/L	THB	0.5	EPA 524.2	5/3/2012	
Toluene	<0.5	ug/L	THB	0.5	EPA 524.2	5/3/2012	
1,2,4-Trichlorobenzene	<0.5	ug/L	THB	0.5	EPA 524.2	5/3/2012	
1,1,1-Trichloroethane	<0.5	ug/L	THB	0.5	EPA 524.2	5/3/2012	
1,1,2-Trichloroethane	<0.5	ug/L	THB	0.5	EPA 524.2	5/3/2012	
Trichloroethylene	<0.5	ug/L	THB	0.5	EPA 524.2	5/3/2012	
Vinyl Chloride	<0.5	ug/L	THB	0.5	EPA 524.2	5/3/2012	
Total Xylenes	<1.0	ug/L	THB	1.0	EPA 524.2	5/3/2012	
Bromobenzene	<0.5	ug/L	THB	0.5	EPA 524.2	5/3/2012	
Bromomethane	<0.5	ug/L	THB	0.5	EPA 524.2	5/3/2012	
Chloroethane	<0.5	ug/L	THB	0.5	EPA 524.2	5/3/2012	

# Report of Laboratory Analysis




635 Green Road, PO Box 968, Madison, IN 47250  
 Tel: 812.273.6699 Fax: 812.273.5788

**Report To:**  
 Corina Beach  
 CARROLLTON UTILITIES  
 P.O. BOX 269  
 CARROLLTON, KY 41008

Order No.: 2012050158  
 PO No.:  
 Date Received: 05/03/2012  
 Report Date: 05/24/2012

Lab Id	Matrix	Identification	Date Collected	Collected By	Description		
P05-152	Drinking Water	WPA	5/2/2012	FT			
Test Name	Results	Units	Analyst	Detection Limit	Test Method	Analysis Date	
Methyl Chloride (Chloromethane)	<0.5	ug/L	THB	0.5	EPA 524.2	5/3/2012	
2-Chlorotoluene	<0.5	ug/L	THB	0.5	EPA 524.2	5/3/2012	
4-Chlorotoluene	<0.5	ug/L	THB	0.5	EPA 524.2	5/3/2012	
1,3-Dichlorobenzene	<0.5	ug/L	THB	0.5	EPA 524.2	5/3/2012	
1,1-Dichloroethane	<0.5	ug/L	THB	0.5	EPA 524.2	5/3/2012	
1,3-Dichloropropane	<0.5	ug/L	THB	0.5	EPA 524.2	5/3/2012	
2,2-Dichloropropane	<0.5	ug/L	THB	0.5	EPA 524.2	5/3/2012	
1,1-Dichloropropylene	<0.5	ug/L	THB	0.5	EPA 524.2	5/3/2012	
Total 1,3-Dichloropropene	<0.5	ug/L	THB	0.5	EPA 524.2	5/3/2012	
1,1,1,2-Tetrachloroethane	<0.5	ug/L	THB	0.5	EPA 524.2	5/3/2012	
1,1,2,2-Tetrachloroethane	<0.5	ug/L	THB	0.5	EPA 524.2	5/3/2012	
1,2,3-Trichloropropane	<0.5	ug/L	THB	0.5	EPA 524.2	5/3/2012	
Dibromomethane	<0.5	ug/L	THB	0.5	EPA 524.2	5/3/2012	
Bromodichloromethane	<0.5	ug/L	THB	0.5	EPA 524.2	5/3/2012	
Bromoform	<0.5	ug/L	THB	0.5	EPA 524.2	5/3/2012	
Chlorodibromomethane	<0.5	ug/L	THB	0.5	EPA 524.2	5/3/2012	
Chloroform	<0.5	ug/L	THB	0.5	EPA 524.2	5/3/2012	
Methyl-Tert-Butyl Ether (MTBE)	<0.5	ug/L	THB	0.5	EPA 524.2	5/3/2012	
Comments:							

# Report of Laboratory Analysis




635 Green Road, PO Box 968, Madison, IN 47250  
 Tel: 812.273.6699 Fax: 812.273.5788

**Report To:**  
 Corina Beach  
 CARROLLTON UTILITIES  
 P.O. BOX 269  
 CARROLLTON, KY 41008

Order No.: 2012050158  
 PO No.:  
 Date Received: 05/03/2012  
 Report Date: 05/24/2012

Lab Id	Matrix	Identification	Date Collected	Collected By	Description		
P05-153	Drinking Water	WPA	5/2/2012	FT			
Test Name	Results	Units	Analyst	Detection Limit	Test Method	Analysis Date	
Arsenic, Total Rec.-(GFAA)	0.0006	mg/L	HW	0.0006	EPA 200.9	5/8/2012	
Antimony, Total Rec.-(GFAA)	<0.0004	mg/L	HW	0.0004	EPA 200.9	5/8/2012	
Cadmium, Total Rec.-(GFAA)	<0.0002	mg/L	HW	0.0002	EPA 200.9	5/9/2012	
Selenium, Total Rec.-(GFAA)	<0.0008	mg/L	HW	0.0008	EPA 200.9	5/9/2012	
Thallium, Total Rec.-(GFAA)	<0.0005	mg/L	HW	0.0005	EPA 200.9	5/9/2012	
Mercury, Total Rec.-(CVAA)	<0.0001	mg/L	LE	0.0001	SM-3112B	5/16/2012	
Barium, Total Rec.-(ICP)	0.171	mg/L	HW	0.08	EPA 200.7	5/4/2012	
Beryllium, Total Rec.-(ICP)	<0.0005	mg/L	HW	0.0005	EPA 200.7	5/4/2012	
Chromium, Total Rec.-(ICP)	<0.001	mg/L	HW	0.001	EPA 200.7	5/4/2012	
Nickel, Total Rec.-(ICP)	<0.001	mg/L	HW	0.001	EPA 200.7	5/4/2012	
Sodium, Total Rec.-(ICP)	28.37	mg/L	HW	0.2	EPA 200.7	5/4/2012	
Hardness, Total- as CaCO3	439.4	mg/L	HW	1.0	SM-2340B	5/4/2012	
Comments:							

# Report of Laboratory Analysis




635 Green Road, PO Box 968, Madison, IN 47250  
 Tel: 812.273.6699 Fax: 812.273.5788

**Report To:**  
 Corina Beach  
 CARROLLTON UTILITIES  
 P.O. BOX 269  
 CARROLLTON, KY 41008

Order No.: 2012050158  
 PO No.:  
 Date Received: 05/03/2012  
 Report Date: 05/24/2012

Lab Id	Matrix	Identification	Date Collected	Collected By	Description		
P05-154	Drinking Water	WPA	5/2/2012	FT			
Test Name	Results	Units	Analyst	Detection Limit	Test Method	Analysis Date	
Cyanide, Free (DW)	<0.005	mg/L	RH	0.005	SM-4500CN-G & E	5/11/2012	
Comments:							

# Report of Laboratory Analysis



635 Green Road, PO Box 968, Madison, IN 47250  
Tel: 812.273.6699 Fax: 812.273.5788


**Report To:**  
Corina Beach  
CARROLLTON UTILITIES  
P.O. BOX 269  
CARROLLTON, KY 41008

Order No.: 2012050158  
PO No.:  
Date Received: 05/03/2012  
Report Date: 05/24/2012

Lab Id	Matrix	Identification	Date Collected	Collected By	Description		
P05-155	Drinking Water	WPA	5/2/2012	FT			
Test Name		Results	Units	Analyst	Detection Limit	Test Method	Analysis Date
Fluoride, Adjusted		0.09	mg/L	PJ	0.02	EPA 300.1	5/4/2012
Nitrate (as N)		4.97	mg/L	PJ	0.05	EPA 300.1	5/4/2012
Comments:							



# Report of Laboratory Analysis




635 Green Road, PO Box 968, Madison, IN 47250  
 Tel: 812.273.6699 Fax: 812.273.5788

**Report To:**  
 Corina Beach  
 CARROLLTON UTILITIES  
 P.O. BOX 269  
 CARROLLTON, KY 41008

Order No.: 2012050158  
 PO No.:  
 Date Received: 05/03/2012  
 Report Date: 05/24/2012

Lab Id	Matrix	Identification	Date Collected	Collected By	Description		
P05-180	Drinking Water	WPA	5/3/2012	FT			
Test Name	Results	Units	Analyst	Detection Limit	Test Method	Analysis Date	
Iron Related Bacteria	25.000	CFU/mL	FO	10	BART	5/4/2012	
Comments:							

# Report of Laboratory Analysis




635 Green Road, PO Box 968, Madison, IN 47250  
 Tel: 812.273.6699 Fax: 812.273.5788

**Report To:**  
 Corina Beach  
 CARROLLTON UTILITIES  
 P.O. BOX 269  
 CARROLLTON, KY 41008

Order No.: 2012050158  
 PO No.:  
 Date Received: 05/03/2012  
 Report Date: 05/24/2012

Lab Id	Matrix	Identification	Date Collected	Collected By	Description		
P05-182	Drinking Water	WPA	5/3/2012	FT			
Test Name	Results	Units	Analyst	Detection Limit	Test Method	Analysis Date	
Aluminum, Total-(ICP)	<0.016	mg/L	HW	0.016	EPA 200.7	5/4/2012	
Copper, Total Rec.-(ICP)	<0.002	mg/L	HW	0.002	EPA 200.7	5/4/2012	
Iron, Total Rec.-(ICP)	0.193	mg/L	HW	0.005	EPA 200.7	5/4/2012	
Silver, Total Rec.-(ICP)	<0.003	mg/L	HW	0.003	EPA 200.7	5/4/2012	
Zinc, Total Rec.-(ICP)	0.0069	mg/L	HW	0.0005	EPA 200.7	5/4/2012	
Manganese, Total Rec.-(ICP)	0.119	mg/L	HW	0.003	EPA 200.7	5/4/2012	
Comments:							

# Report of Laboratory Analysis



635 Green Road, PO Box 968, Madison, IN 47250  
 Tel: 812.273.6699 Fax: 812.273.5788

**Report To:**  
 Corina Beach  
 CARROLLTON UTILITIES  
 P.O. BOX 269  
 CARROLLTON, KY 41008

Order No.: 2012050158  
 PO No.:  
 Date Received: 05/03/2012  
 Report Date: 05/24/2012

Lab Id	Matrix	Identification	Date Collected	Collected By	Description		
P05-183	Drinking Water	WPA	5/3/2012	FT			
Test Name	Results	Units	Analyst	Detection Limit	Test Method	Analysis Date	
Nitrate (as N)	4.95	mg/L	PJ	0.05	EPA 300.1	5/4/2012	
Nitrite (as N)	<0.05	mg/L	PJ	0.05	EPA 300.1	5/4/2012	
Sulfate	51.174	mg/L	PJ	1.0	EPA 300.1	5/4/2012	
Chloride	62.95	mg/L	PJ	2.0	EPA 300.1	5/4/2012	
Fluoride, Adjusted	0.09	mg/L	PJ	0.02	EPA 300.1	5/4/2012	
Comments:							

# Report of Laboratory Analysis




635 Green Road, PO Box 968, Madison, IN 47250  
 Tel: 812.273.6699 Fax: 812.273.5788

**Report To:**  
 Corina Beach  
 CARROLLTON UTILITIES  
 P.O. BOX 269  
 CARROLLTON, KY 41008

Order No.: 2012050158  
 PO No.:  
 Date Received: 05/03/2012  
 Report Date: 05/24/2012

Lab Id	Matrix	Identification	Date Collected	Collected By	Description		
P05-184	Drinking Water	WPA	5/3/2012	FT			
Test Name	Results	Units	Analyst	Detection Limit	Test Method	Analysis Date	
Color	<1	PC Units	THB	1	SM-2120B	5/3/2012	
Comments:							

# Report of Laboratory Analysis



635 Green Road, PO Box 968, Madison, IN 47250  
 Tel: 812.273.6699 Fax: 812.273.5788

**Report To:**  
 Corina Beach  
 CARROLLTON UTILITIES  
 P.O. BOX 269  
 CARROLLTON, KY 41008

Order No.: 2012050158  
 PO No.:  
 Date Received: 05/03/2012  
 Report Date: 05/24/2012

Lab Id	Matrix	Identification	Date Collected	Collected By	Description	
P05-185	Drinking Water	WPA	5/3/2012	FT		
Test Name	Results	Units	Analyst	Detection Limit	Test Method	Analysis Date
Odor Threshold	<1.0	T.O.N.	THB	1.0	SM-2150B	5/3/2012
Comments:						

# Report of Laboratory Analysis




635 Green Road, PO Box 968, Madison, IN 47250  
 Tel: 812.273.6699 Fax: 812.273.5788

**Report To:**  
 Corina Beach  
 CARROLLTON UTILITIES  
 P. O. BOX 269  
 CARROLLTON, KY 41008

Order No.: 2012050158  
 PO No.:  
 Date Received: 05/03/2012  
 Report Date: 05/24/2012

Lab Id	Matrix	Identification	Date Collected	Collected By	Description		
P05-186	Drinking Water	WPA	5/3/2012	FT			
Test Name	Results	Units	Analyst	Detection Limit	Test Method	Analysis Date	
Surfactants (Foaming Agents)	<0.02	mg MBAS/L	THB	0.02	SM-5540C	5/4/2012	
Comments:							

# Report of Laboratory Analysis




635 Green Road, PO Box 968, Madison, IN 47250  
 Tel: 812.273.6699 Fax: 812.273.5788

**Report To:**  
 Corina Beach  
 CARROLLTON UTILITIES  
 P.O. BOX 269  
 CARROLLTON, KY 41008

Order No.: 2012050158  
 PO No.:  
 Date Received: 05/03/2012  
 Report Date: 05/24/2012

Lab Id	Matrix	Identification	Date Collected	Collected By	Description		
P05-187	Drinking Water	WPA	5/3/2012	FT			
Test Name	Results	Units	Analyst	Detection Limit	Test Method	Analysis Date	
Hardness-(Ca)- as CaCO3	289.5	mg/L	HW	1.0	SM-2340B	5/10/2012	
Alkalinity, Total	351.0	mg CaCO3/L	RH	2.0	SM-2320B	5/7/2012	
pH	7.27	S.U.	PJ	0.10	SM-4500H+B	5/4/2012	
Solids, Dissolved Total	616.7	mg/L	LE	1.0	SM-2540C	5/8/2012	
Corrosivity, (Langelier Index)	0.41	Calculation	WW		SM-2330B	5/23/2012	
Carbonate	351.0	mg CaCO3/L	RH	2.0	SM-2320B	5/11/2012	
Hardness-(Mg)- as CaCO3	144.7	mg/L	HW	1.0	SM-2340B	5/10/2012	
Comments:	Temp@20C was used in the corrosivity calculation.						

# Report of Laboratory Analysis



635 Green Road, PO Box 968, Madison, IN 47250  
 Tel: 812.273.6699 Fax: 812.273.5788


**Report To:**  
 Corina Beach  
 CARROLLTON UTILITIES  
 P. O. BOX 269  
 CARROLLTON, KY 41008

Order No.: 2012050158  
 PO No.:  
 Date Received: 05/03/2012  
 Report Date: 05/24/2012

Lab Id	Matrix	Identification	Date Collected	Collected By	Description		
P05-151	Drinking Water	WPA	5/2/2012	FT			
Test Name	Results	Units	Analyst	Detection Limit	Test Method	Analysis Date	
Alachlor	<0.44	ug/L	WW	0.44	EPA 525.2	5/23/2012	
Atrazine	<0.22	ug/L	WW	0.22	EPA 525.2	5/23/2012	
Benzo(a)pyrene	<0.044	ug/L	WW	0.044	EPA 525.2	5/23/2012	
Di(2-ethylhexyl)adipate	<1.32	ug/L	WW	1.32	EPA 525.2	5/23/2012	
Di(2-ethylhexyl)phthalate	<1.32	ug/L	WW	1.32	EPA 525.2	5/23/2012	
Hexachloropentadiene	<0.22	ug/L	WW	0.22	EPA 525.2	5/23/2012	
Methoxychlor	<0.22	ug/L	WW	0.22	EPA 525.2	5/23/2012	
Simazine	<0.154	ug/L	WW	0.154	EPA 525.2	5/23/2012	
Sample Preparation-SPE Extraction	DONE		BD		EPA 525.2	5/3/2012	
Aldicarb	<1.1	ug/L	HW	1.1	EPA 531.1	5/8/2012	
Aldicarb Sulfone	<1.4	ug/L	HW	1.4	EPA 531.1	5/8/2012	
Aldicarb Sulfoxide	<1.0	ug/L	HW	1.0	EPA 531.1	5/8/2012	
Carbofuran	<1.98	ug/L	HW	1.98	EPA 531.1	5/8/2012	
Oxamyl (Vydate)	<4.4	ug/L	HW	4.4	EPA 531.1	5/8/2012	
Sample Preparation-Filtration	DONE		HW		EPA 531.1	5/8/2012	
Chlordane (total)	<0.44	ug/L	WW	0.44	EPA 508.1	5/17/2012	
Endrin	<0.022	ug/L	WW	0.022	EPA 508.1	5/17/2012	
Heptachlor	<0.088	ug/L	WW	0.088	EPA 508.1	5/17/2012	
Heptachlor Epoxide	<0.044	ug/L	WW	0.044	EPA 508.1	5/17/2012	
Hexachlorobenzene	<0.22	ug/L	WW	0.22	EPA 508.1	5/17/2012	
Lindane	<0.044	ug/L	WW	0.044	EPA 508.1	5/17/2012	
Toxaphene	<2.2	ug/L	WW	2.2	EPA 508.1	5/17/2012	
Sample Preparation-SPE Extraction	DONE		HW		EPA 508.1	5/4/2012	
Dalapon	<2.2	ug/L	HW	2.2	EPA 552.2	5/8/2012	



# Report of Laboratory Analysis



635 Green Road, PO Box 968, Madison, IN 47250  
 Tel: 812.273.6699 Fax: 812.273.5788

**Report To:**  
 Corina Beach  
 CARROLLTON UTILITIES  
 P.O. BOX 269  
 CARROLLTON, KY 41008

Order No.: 2012050158  
 PO No.:  
 Date Received: 05/03/2012  
 Report Date: 05/24/2012

Lab Id	Matrix	Identification	Date Collected	Collected By	Description	
P05-151	Drinking Water	WPA	5/2/2012	FT		
Test Name	Results	Units	Analyst	Detection Limit	Test Method	Analysis Date
Sample Preparation-LL Extraction	DONE		HW		EPA 552.2	5/4/2012
Sample Preparation-SPE Extraction	DONE		BD		EPA 515.2	5/9/2012
DBCP	<0.044	ug/L	WW	0.044	EPA 504.1	5/11/2012
EDB	<0.022	ug/L	WW	0.022	EPA 504.1	5/11/2012
Sample Preparation-LL Extraction	DONE		HW		EPA 504.1	5/11/2012
Diquat	<0.88	ug/L	WW	0.88	EPA 549.2	5/8/2012
Sample Preparation-SPE Extraction	DONE		BD		EPA 549.2	5/3/2012
Endothall	<19.8	ug/L	WW	19.8	EPA 548.1	5/10/2012
Sample Preparation-SPE Extraction	DONE		BD		EPA 548.1	5/8/2012
Comments:						

Approved by:

Whitney Wu, Lab Manager

# Report of Laboratory Analysis




635 Green Road, PO Box 968, Madison, IN 47250  
 Tel: 812.273.6699 Fax: 812.273.5788

**Report To:**  
 Corina Beach  
 CARROLLTON UTILITIES  
 P.O. BOX 269  
 CARROLLTON, KY 41008

Order No.: 2012050159  
 PO No.:  
 Date Received: 05/03/2012  
 Report Date: 05/24/2012

Lab Id	Matrix	Identification	Date Collected	Collected By	Description		
P05-194	Drinking Water	WPB	5/2/2012	FT			
Test Name		Results	Units	Analyst	Detection Limit	Test Method	Analysis Date
Benzene		<0.5	ug/L	THB	0.5	EPA 524.2	5/3/2012
Carbon Tetrachloride		<0.5	ug/L	THB	0.5	EPA 524.2	5/3/2012
Chlorobenzene		<0.5	ug/L	THB	0.5	EPA 524.2	5/3/2012
1,2-Dichlorobenzene		<0.5	ug/L	THB	0.5	EPA 524.2	5/3/2012
1,4-Dichlorobenzene		<0.5	ug/L	THB	0.5	EPA 524.2	5/3/2012
1,2-Dichloroethane		<0.5	ug/L	THB	0.5	EPA 524.2	5/3/2012
1,1-Dichloroethylene		<0.5	ug/L	THB	0.5	EPA 524.2	5/3/2012
1,2-Dichloroethylene,cis		<0.5	ug/L	THB	0.5	EPA 524.2	5/3/2012
1,2-Dichloroethylene,trans		<0.5	ug/L	THB	0.5	EPA 524.2	5/3/2012
Methylene Chloride (Dichloromethane)		<0.5	ug/L	THB	0.5	EPA 524.2	5/3/2012
1,2-Dichloropropane		<0.5	ug/L	THB	0.5	EPA 524.2	5/3/2012
Ethylbenzene		<0.5	ug/L	THB	0.5	EPA 524.2	5/3/2012
Styrene		<0.5	ug/L	THB	0.5	EPA 524.2	5/3/2012
Tetrachloroethylene		<0.5	ug/L	THB	0.5	EPA 524.2	5/3/2012
Toluene		<0.5	ug/L	THB	0.5	EPA 524.2	5/3/2012
1,2,4-Trichlorobenzene		<0.5	ug/L	THB	0.5	EPA 524.2	5/3/2012
1,1,1-Trichloroethane		<0.5	ug/L	THB	0.5	EPA 524.2	5/3/2012
1,1,2-Trichloroethane		<0.5	ug/L	THB	0.5	EPA 524.2	5/3/2012
Trichloroethylene		<0.5	ug/L	THB	0.5	EPA 524.2	5/3/2012
Vinyl Chloride		<0.5	ug/L	THB	0.5	EPA 524.2	5/3/2012
Total Xylenes		<1.0	ug/L	THB	1.0	EPA 524.2	5/3/2012
Bromobenzene		<0.5	ug/L	THB	0.5	EPA 524.2	5/3/2012
Bromomethane		<0.5	ug/L	THB	0.5	EPA 524.2	5/3/2012
Chloroethane		<0.5	ug/L	THB	0.5	EPA 524.2	5/3/2012

# Report of Laboratory Analysis



635 Green Road, PO Box 968, Madison, IN 47250  
 Tel: 812.273.6699 Fax: 812.273.5788

**Report To:**  
 Corina Beach  
 CARROLLTON UTILITIES  
 P.O. BOX 269  
 CARROLLTON, KY 41008

Order No : 2012050159  
 PO No.:  
 Date Received: 05/03/2012  
 Report Date: 05/24/2012

Lab Id	Matrix	Identification	Date Collected	Collected By	Description		
P05-194	Drinking Water	WPB	5/2/2012	FT			
Test Name	Results	Units	Analyst	Detection Limit	Test Method	Analysis Date	
Methyl Chloride (Chloromethane)	<0.5	ug/L	THB	0.5	EPA 524.2	5/3/2012	
2-Chlorotoluene	<0.5	ug/L	THB	0.5	EPA 524.2	5/3/2012	
4-Chlorotoluene	<0.5	ug/L	THB	0.5	EPA 524.2	5/3/2012	
1,3-Dichlorobenzene	<0.5	ug/L	THB	0.5	EPA 524.2	5/3/2012	
1,1-Dichloroethane	<0.5	ug/L	THB	0.5	EPA 524.2	5/3/2012	
1,3-Dichloropropane	<0.5	ug/L	THB	0.5	EPA 524.2	5/3/2012	
2,2-Dichloropropane	<0.5	ug/L	THB	0.5	EPA 524.2	5/3/2012	
1,1-Dichloropropylene	<0.5	ug/L	THB	0.5	EPA 524.2	5/3/2012	
Total 1,3-Dichloropropene	<0.5	ug/L	THB	0.5	EPA 524.2	5/3/2012	
1,1,1,2-Tetrachloroethane	<0.5	ug/L	THB	0.5	EPA 524.2	5/3/2012	
1,1,2,2-Tetrachloroethane	<0.5	ug/L	THB	0.5	EPA 524.2	5/3/2012	
1,2,3-Trichloropropane	<0.5	ug/L	THB	0.5	EPA 524.2	5/3/2012	
Dibromomethane	<0.5	ug/L	THB	0.5	EPA 524.2	5/3/2012	
Bromodichloromethane	<0.5	ug/L	THB	0.5	EPA 524.2	5/3/2012	
Bromoform	<0.5	ug/L	THB	0.5	EPA 524.2	5/3/2012	
Chlorodibromomethane	<0.5	ug/L	THB	0.5	EPA 524.2	5/3/2012	
Chloroform	<0.5	ug/L	THB	0.5	EPA 524.2	5/3/2012	
Methyl-Tert-Butyl Ether (MTBE)	<0.5	ug/L	THB	0.5	EPA 524.2	5/3/2012	

Comments:

# Report of Laboratory Analysis




635 Green Road, PO Box 968, Madison, IN 47250  
 Tel: 812.273.6699 Fax: 812.273.5788

**Report To:**  
 Corina Beach  
 CARROLLTON UTILITIES  
 P.O. BOX 269  
 CARROLLTON, KY 41008

Order No.: 2012050159  
 PO No.:  
 Date Received: 05/03/2012  
 Report Date: 05/24/2012

Lab Id	Matrix	Identification	Date Collected	Collected By	Description		
P05-162	Drinking Water	WPB	5/2/2012	FT			
Test Name	Results	Units	Analyst	Detection Limit	Test Method	Analysis Date	
Arsenic, Total Rec.-(GFAA)	<0.0006	mg/L	HW	0.0006	EPA 200.9	5/8/2012	
Antimony, Total Rec.-(GFAA)	<0.0004	mg/L	HW	0.0004	EPA 200.9	5/8/2012	
Cadmium, Total Rec.-(GFAA)	<0.0002	mg/L	HW	0.0002	EPA 200.9	5/9/2012	
Selenium, Total Rec.-(GFAA)	<0.0008	mg/L	HW	0.0008	EPA 200.9	5/9/2012	
Thallium, Total Rec.-(GFAA)	<0.0005	mg/L	HW	0.0005	EPA 200.9	5/9/2012	
Mercury, Total Rec.-(CVAA)	<0.0001	mg/L	LE	0.0001	SM-3112B	5/16/2012	
Barium, Total Rec.-(ICP)	0.084	mg/L	HW	0.08	EPA 200.7	5/4/2012	
Beryllium, Total Rec.-(ICP)	<0.0005	mg/L	HW	0.0005	EPA 200.7	5/4/2012	
Chromium, Total Rec.-(ICP)	<0.001	mg/L	HW	0.001	EPA 200.7	5/4/2012	
Nickel, Total Rec.-(ICP)	0.006	mg/L	HW	0.001	EPA 200.7	5/4/2012	
Sodium, Total Rec.-(ICP)	23.26	mg/L	HW	0.2	EPA 200.7	5/4/2012	
Hardness, Total- as CaCO3	434.1	mg/L	HW	1.0	SM-2340B	5/4/2012	
Comments:							

# Report of Laboratory Analysis




635 Green Road, PO Box 968, Madison, IN 47250  
 Tel: 812.273.6699 Fax: 812.273.5788

**Report To:**  
 Corina Beach  
 CARROLLTON UTILITIES  
 P.O. BOX 269  
 CARROLLTON, KY 41008

Order No.: 2012050159  
 PO No.:  
 Date Received: 05/03/2012  
 Report Date: 05/24/2012

Lab Id	Matrix	Identification	Date Collected	Collected By	Description		
P05-163	Drinking Water	WPB	5/2/2012	FT			
Test Name	Results	Units	Analyst	Detection Limit	Test Method	Analysis Date	
Cyanide, Free (DW)	<0.005	mg/L	RH	0.005	SM-4500CN-G & E	5/11/2012	
Comments:							

# Report of Laboratory Analysis




635 Green Road, PO Box 968, Madison, IN 47250  
 Tel: 812.273.6699 Fax: 812.273.5788

**Report To:**  
 Corina Beach  
 CARROLLTON UTILITIES  
 P.O. BOX 269  
 CARROLLTON, KY 41008

Order No.: 2012050159  
 PO No.:  
 Date Received: 05/03/2012  
 Report Date: 05/24/2012

Lab Id	Matrix	Identification	Date Collected	Collected By	Description		
P05-164	Drinking Water	WPB	5/2/2012	FT			
Test Name	Results	Units	Analyst	Detection Limit	Test Method	Analysis Date	
Fluoride, Adjusted	0.088	mg/L	PJ	0.02	EPA 300.1	5/4/2012	
Nitrate (as N)	4.668	mg/L	PJ	0.05	EPA 300.1	5/4/2012	
Comments:							

# Report of Laboratory Analysis



635 Green Road, PO Box 968, Madison, IN 47250  
 Tel: 812.273.6699 Fax: 812.273.5788

**Report To:**  
 Corina Beach  
 CARROLLTON UTILITIES  
 P.O. BOX 269  
 CARROLLTON, KY 41008

Order No.: 2012050159  
 PO No.:  
 Date Received: 05/03/2012  
 Report Date: 05/24/2012

Lab Id	Matrix	Identification	Date Collected	Collected By	Description	
P05-178	Drinking Water	WPB	5/3/2012	FT		
Test Name	Results	Units	Analyst	Detection Limit	Test Method	Analysis Date
Iron Related Bacteria	<10	CFU/mL	FO	10	BART	5/4/2012
Comments:						

# Report of Laboratory Analysis



635 Green Road, PO Box 968, Madison, IN 47250  
 Tel: 812.273.6699 Fax: 812.273.5788


**Report To:**  
 Corina Beach  
 CARROLLTON UTILITIES  
 P.O. BOX 269  
 CARROLLTON, KY 41008

Order No.: 2012050159  
 PO No.:  
 Date Received: 05/03/2012  
 Report Date: 05/24/2012

Lab Id	Matrix	Identification	Date Collected	Collected By	Description		
P05-156	Drinking Water	WPB	5/3/2012	FT			
Test Name	Results	Units	Analyst	Detection Limit	Test Method	Analysis Date	
Aluminum, Total-(ICP)	<0.016	mg/L	HW	0.016	EPA 200.7	5/4/2012	
Copper, Total Rec.-(ICP)	0.009	mg/L	HW	0.002	EPA 200.7	5/4/2012	
Iron, Total Rec.-(ICP)	0.184	mg/L	HW	0.005	EPA 200.7	5/4/2012	
Silver, Total Rec.-(ICP)	<0.003	mg/L	HW	0.003	EPA 200.7	5/4/2012	
Zinc, Total Rec.-(ICP)	0.0282	mg/L	HW	0.0005	EPA 200.7	5/4/2012	
Manganese, Total Rec.-(ICP)	0.113	mg/L	HW	0.003	EPA 200.7	5/4/2012	
Comments:							



# Report of Laboratory Analysis




635 Green Road, PO Box 968, Madison, IN 47250  
 Tel: 812.273.6699 Fax: 812.273.5788

**Report To:**  
 Corina Beach  
 CARROLLTON UTILITIES  
 P. O. BOX 269  
 CARROLLTON, KY 41008

Order No.: 2012050159  
 PO No.:  
 Date Received: 05/03/2012  
 Report Date: 05/24/2012

Lab Id	Matrix	Identification	Date Collected	Collected By	Description		
P05-157	Drinking Water	WPB	5/3/2012	FT			
Test Name	Results	Units	Analyst	Detection Limit	Test Method	Analysis Date	
Nitrate (as N)	4.52	mg/L	PJ	0.05	EPA 300.1	5/4/2012	
Nitrite (as N)	<0.05	mg/L	PJ	0.05	EPA 300.1	5/4/2012	
Sulfate	46.643	mg/L	PJ	1.0	EPA 300.1	5/4/2012	
Chloride	58.401	mg/L	PJ	2.0	EPA 300.1	5/4/2012	
Fluoride, Adjusted	0.095	mg/L	PJ	0.02	EPA 300.1	5/4/2012	
Comments:							

# Report of Laboratory Analysis




635 Green Road, PO Box 968, Madison, IN 47250  
 Tel: 812.273.6699 Fax: 812.273.5788

**Report To:**  
 Corina Beach  
 CARROLLTON UTILITIES  
 P.O. BOX 269  
 CARROLLTON, KY 41008

Order No.: 2012050159  
 PO No.:  
 Date Received: 05/03/2012  
 Report Date: 05/24/2012

Lab Id	Matrix	Identification	Date Collected	Collected By	Description	
P05-158	Drinking Water	WPB	5/3/2012	FT		
Test Name	Results	Units	Analyst	Detection Limit	Test Method	Analysis Date
Color	<1	PC Units	THB	1	SM-2120B	5/3/2012
Comments:						

# Report of Laboratory Analysis



635 Green Road, PO Box 968, Madison, IN 47250  
 Tel: 812.273.6699 Fax: 812.273.5788

**Report To:**  
 Corina Beach  
 CARROLLTON UTILITIES  
 P.O. BOX 269  
 CARROLLTON, KY 41008

Order No.: 2012050159  
 PO No.:  
 Date Received: 05/03/2012  
 Report Date: 05/24/2012

Lab Id	Matrix	Identification	Date Collected	Collected By	Description	
P05-159	Drinking Water	WPB	5/3/2012	FT		
Test Name	Results	Units	Analyst	Detection Limit	Test Method	Analysis Date
Odor Threshold	<1.0	T.O.N.	THB	1.0	SM-2150B	5/3/2012
Comments:						

# Report of Laboratory Analysis




635 Green Road, PO Box 968, Madison, IN 47250  
 Tel: 812.273.6699 Fax: 812.273.5788

**Report To:**  
 Corina Beach  
 CARROLLTON UTILITIES  
 P.O. BOX 269  
 CARROLLTON, KY 41008

Order No.: 2012050159  
 PO No.:  
 Date Received: 05/03/2012  
 Report Date: 05/24/2012

Lab Id	Matrix	Identification	Date Collected	Collected By	Description		
P05-160	Drinking Water	WPB	5/3/2012	FT			
Test Name	Results	Units	Analyst	Detection Limit	Test Method	Analysis Date	
Surfactants (Foaming Agents)	<0.02	mg MBAS/L	THB	0.02	SM-5540C	5/4/2012	
Comments:							

# Report of Laboratory Analysis



635 Green Road, PO Box 968, Madison, IN 47250  
 Tel: 812.273.6699 Fax: 812.273.5788

**Report To:**  
 Corina Beach  
 CARROLLTON UTILITIES  
 P.O. BOX 269  
 CARROLLTON, KY 41008

Order No.: 2012050159  
 PO No.:  
 Date Received: 05/03/2012  
 Report Date: 05/24/2012

Lab Id	Matrix	Identification	Date Collected	Collected By	Description		
P05-161	Drinking Water	WPB	5/3/2012	FT			
Test Name	Results	Units	Analyst	Detection Limit	Test Method	Analysis Date	
Hardness-(Ca)- as CaCO3	283.2	mg/L	HW	1.0	SM-2340B	5/10/2012	
Alkalinity, Total	338.0	mg CaCO3/L	RH	2.0	SM-2320B	5/7/2012	
pH	7.49	S.U.	PJ	0.10	SM-4500H+B	5/4/2012	
Solids, Dissolved Total	543.3	mg/L	LE	1.0	SM-2540C	5/8/2012	
Corrosivity, (Langelier Index)	0.61	Calculation	WW		SM-2330B	5/23/2012	
Carbonate	337.0	mg CaCO3/L	RH	2.0	SM-2320B	5/11/2012	
Comments: Temp@20C was used in the corrosivity calculation.							

# Report of Laboratory Analysis




635 Green Road, PO Box 968, Madison, IN 47250  
 Tel: 812.273.6699 Fax: 812.273.5788

**Report To:**  
 Corina Beach  
 CARROLLTON UTILITIES  
 P.O. BOX 269  
 CARROLLTON, KY 41008

Order No.: 2012050159  
 PO No.:  
 Date Received: 05/03/2012  
 Report Date: 05/24/2012

Lab Id	Matrix	Identification	Date Collected	Collected By	Description		
P05-149	Drinking Water	WPB	5/2/2012	FT			
Test Name	Results	Units	Analyst	Detection Limit	Test Method	Analysis Date	
Alachlor	<0.44	ug/L	WW	0.44	EPA 525.2	5/22/2012	
Atrazine	<0.22	ug/L	WW	0.22	EPA 525.2	5/22/2012	
Benzo(a)pyrene	<0.044	ug/L	WW	0.044	EPA 525.2	5/22/2012	
Di(2-ethylhexyl)adipate	<1.32	ug/L	WW	1.32	EPA 525.2	5/22/2012	
Di(2-ethylhexyl)phthalate	<1.32	ug/L	WW	1.32	EPA 525.2	5/22/2012	
Hexachloropentadiene	<0.22	ug/L	WW	0.22	EPA 525.2	5/22/2012	
Methoxychlor	<0.22	ug/L	WW	0.22	EPA 525.2	5/22/2012	
Simazine	<0.154	ug/L	WW	0.154	EPA 525.2	5/22/2012	
Sample Preparation-SPE Extraction	DONE		BD		EPA 525.2	5/3/2012	
Aldicarb	<1.1	ug/L	HW	1.1	EPA 531.1	5/8/2012	
Aldicarb Sulfone	<1.4	ug/L	HW	1.4	EPA 531.1	5/8/2012	
Aldicarb Sulfoxide	<1.0	ug/L	HW	1.0	EPA 531.1	5/8/2012	
Carbofuran	<1.98	ug/L	HW	1.98	EPA 531.1	5/8/2012	
Oxamyl (Vydate)	<4.4	ug/L	HW	4.4	EPA 531.1	5/8/2012	
Sample Preparation-Filtration	DONE		HW		EPA 531.1	5/8/2012	
Chlordane (total)	<0.44	ug/L	WW	0.44	EPA 508.1	5/17/2012	
Endrin	<0.022	ug/L	WW	0.022	EPA 508.1	5/17/2012	
Heptachlor	<0.088	ug/L	WW	0.088	EPA 508.1	5/17/2012	
Heptachlor Epoxide	<0.044	ug/L	WW	0.044	EPA 508.1	5/17/2012	
Hexachlorobenzene	<0.22	ug/L	WW	0.22	EPA 508.1	5/17/2012	
Lindane	<0.044	ug/L	WW	0.044	EPA 508.1	5/17/2012	
Toxaphene	<2.2	ug/L	WW	2.2	EPA 508.1	5/17/2012	
Sample Preparation-SPE Extraction	DONE		HW		EPA 508.1	5/4/2012	
Dalapon	<2.2	ug/L	HW	2.2	EPA 552.2	5/8/2012	

# Report of Laboratory Analysis



635 Green Road, PO Box 968, Madison, IN 47250  
 Tel: 812.273.6699 Fax: 812.273.5788

**Report To:**  
 Corina Beach  
 CARROLLTON UTILITIES  
 P.O. BOX 269  
 CARROLLTON, KY 41008

Order No.: 2012050159  
 PO No.:  
 Date Received: 05/03/2012  
 Report Date: 05/24/2012

Lab Id	Matrix	Identification	Date Collected	Collected By	Description		
P05-149	Drinking Water	WPB	5/2/2012	FT			
Test Name		Results	Units	Analyst	Detection Limit	Test Method	Analysis Date
Sample Preparation-LL Extraction		DONE		HW		EPA 552.2	5/4/2012
DBCP		<0.044	ug/L	WW	0.044	EPA 504.1	5/11/2012
EDB		<0.022	ug/L	WW	0.022	EPA 504.1	5/11/2012
Sample Preparation-LL Extraction		DONE		HW		EPA 504.1	5/11/2012
Diquat		<0.88	ug/L	WW	0.88	EPA 549.2	5/8/2012
Sample Preparation-SPE Extraction		DONE		BD		EPA 549.2	5/3/2012
Endothall		<19.8	ug/L	WW	19.8	EPA 548.1	5/10/2012
Sample Preparation-SPE Extraction		DONE		BD		EPA 548.1	5/8/2012
Comments:							

Approved by:

Whitney Wu, Lab Manager

# Report of Laboratory Analysis



635 Green Road, PO Box 968, Madison, IN 47250  
 Tel: 812.273.6699 Fax: 812.273.5788


**Report To:**  
 Corina Beach  
 CARROLLTON UTILITIES  
 P.O. BOX 269  
 CARROLLTON, KY 41008

Order No.: 2012050160  
 PO No.:  
 Date Received: 05/03/2012  
 Report Date: 05/24/2012

Lab Id	Matrix	Identification	Date Collected	Collected By	Description		
P05-195	Drinking Water	WPC	5/2/2012	FT			
Test Name	Results	Units	Analyst	Detection Limit	Test Method	Analysis Date	
Benzene	<0.5	ug/L	THB	0.5	EPA 524.2	5/3/2012	
Carbon Tetrachloride	<0.5	ug/L	THB	0.5	EPA 524.2	5/3/2012	
Chlorobenzene	<0.5	ug/L	THB	0.5	EPA 524.2	5/3/2012	
1,2-Dichlorobenzene	<0.5	ug/L	THB	0.5	EPA 524.2	5/3/2012	
1,4-Dichlorobenzene	<0.5	ug/L	THB	0.5	EPA 524.2	5/3/2012	
1,2-Dichloroethane	<0.5	ug/L	THB	0.5	EPA 524.2	5/3/2012	
1,1-Dichloroethylene	<0.5	ug/L	THB	0.5	EPA 524.2	5/3/2012	
1,2-Dichloroethylene,cis	<0.5	ug/L	THB	0.5	EPA 524.2	5/3/2012	
1,2-Dichloroethylene,trans	<0.5	ug/L	THB	0.5	EPA 524.2	5/3/2012	
Methylene Chloride (Dichloromethane)	<0.5	ug/L	THB	0.5	EPA 524.2	5/3/2012	
1,2-Dichloropropane	<0.5	ug/L	THB	0.5	EPA 524.2	5/3/2012	
Ethylbenzene	<0.5	ug/L	THB	0.5	EPA 524.2	5/3/2012	
Styrene	<0.5	ug/L	THB	0.5	EPA 524.2	5/3/2012	
Tetrachloroethylene	<0.5	ug/L	THB	0.5	EPA 524.2	5/3/2012	
Toluene	<0.5	ug/L	THB	0.5	EPA 524.2	5/3/2012	
1,2,4-Trichlorobenzene	<0.5	ug/L	THB	0.5	EPA 524.2	5/3/2012	
1,1,1-Trichloroethane	<0.5	ug/L	THB	0.5	EPA 524.2	5/3/2012	
1,1,2-Trichloroethane	<0.5	ug/L	THB	0.5	EPA 524.2	5/3/2012	
Trichloroethylene	3.03	ug/L	THB	0.5	EPA 524.2	5/3/2012	
Vinyl Chloride	<0.5	ug/L	THB	0.5	EPA 524.2	5/3/2012	
Total Xylenes	<1.0	ug/L	THB	1.0	EPA 524.2	5/3/2012	
Bromobenzene	<0.5	ug/L	THB	0.5	EPA 524.2	5/3/2012	
Bromomethane	<0.5	ug/L	THB	0.5	EPA 524.2	5/3/2012	
Chloroethane	<0.5	ug/L	THB	0.5	EPA 524.2	5/3/2012	



# Report of Laboratory Analysis



635 Green Road, PO Box 968, Madison, IN 47250  
 Tel: 812.273.6699 Fax: 812.273.5788


**Report To:**  
 Corina Beach  
 CARROLLTON UTILITIES  
 P.O. BOX 269  
 CARROLLTON, KY 41008

Order No.: 2012050160  
 PO No.:  
 Date Received: 05/03/2012  
 Report Date: 05/24/2012

Lab Id	Matrix	Identification	Date Collected	Collected By	Description		
P05-195	Drinking Water	WPC	5/2/2012	FT			
Test Name	Results	Units	Analyst	Detection Limit	Test Method	Analysis Date	
Methyl Chloride (Chloromethane)	<0.5	ug/L	THB	0.5	EPA 524.2	5/3/2012	
2-Chlorotoluene	<0.5	ug/L	THB	0.5	EPA 524.2	5/3/2012	
4-Chlorotoluene	<0.5	ug/L	THB	0.5	EPA 524.2	5/3/2012	
1,3-Dichlorobenzene	<0.5	ug/L	THB	0.5	EPA 524.2	5/3/2012	
1,1-Dichloroethane	<0.5	ug/L	THB	0.5	EPA 524.2	5/3/2012	
1,3-Dichloropropane	<0.5	ug/L	THB	0.5	EPA 524.2	5/3/2012	
2,2-Dichloropropane	<0.5	ug/L	THB	0.5	EPA 524.2	5/3/2012	
1,1-Dichloropropylene	<0.5	ug/L	THB	0.5	EPA 524.2	5/3/2012	
Total 1,3-Dichloropropene	<0.5	ug/L	THB	0.5	EPA 524.2	5/3/2012	
1,1,1,2-Tetrachloroethane	<0.5	ug/L	THB	0.5	EPA 524.2	5/3/2012	
1,1,2,2-Tetrachloroethane	<0.5	ug/L	THB	0.5	EPA 524.2	5/3/2012	
1,2,3-Trichloropropane	<0.5	ug/L	THB	0.5	EPA 524.2	5/3/2012	
Dibromomethane	<0.5	ug/L	THB	0.5	EPA 524.2	5/3/2012	
Bromodichloromethane	<0.5	ug/L	THB	0.5	EPA 524.2	5/3/2012	
Bromoform	<0.5	ug/L	THB	0.5	EPA 524.2	5/3/2012	
Chlorodibromomethane	<0.5	ug/L	THB	0.5	EPA 524.2	5/3/2012	
Chloroform	<0.5	ug/L	THB	0.5	EPA 524.2	5/3/2012	
Methyl-Tert-Butyl Ether (MTBE)	<0.5	ug/L	THB	0.5	EPA 524.2	5/3/2012	

Comments:

# Report of Laboratory Analysis




635 Green Road, PO Box 968, Madison, IN 47250  
 Tel: 812.273.6699 Fax: 812.273.5788

**Report To:**  
 Corina Beach  
 CARROLLTON UTILITIES  
 P.O. BOX 269  
 CARROLLTON, KY 41008

Order No.: 2012050160  
 PO No.:  
 Date Received: 05/03/2012  
 Report Date: 05/24/2012

Lab Id	Matrix	Identification	Date Collected	Collected By	Description		
P05-168	Drinking Water	WPC	5/2/2012	FT			
Test Name	Results	Units	Analyst	Detection Limit	Test Method	Analysis Date	
Arsenic, Total Rec.-(GFAA)	0.0008	mg/L	HW	0.0006	EPA 200.9	5/8/2012	
Antimony, Total Rec.-(GFAA)	<0.0004	mg/L	HW	0.0004	EPA 200.9	5/8/2012	
Cadmium, Total Rec.-(GFAA)	<0.0002	mg/L	HW	0.0002	EPA 200.9	5/9/2012	
Selenium, Total Rec.-(GFAA)	<0.0008	mg/L	HW	0.0008	EPA 200.9	5/9/2012	
Thallium, Total Rec.-(GFAA)	<0.0005	mg/L	HW	0.0005	EPA 200.9	5/9/2012	
Mercury, Total Rec.-(CVAA)	<0.0001	mg/L	LE	0.0001	SM-3112B	5/16/2012	
Barium, Total Rec.-(ICP)	0.117	mg/L	HW	0.08	EPA 200.7	5/4/2012	
Beryllium, Total Rec.-(ICP)	<0.0005	mg/L	HW	0.0005	EPA 200.7	5/4/2012	
Chromium, Total Rec.-(ICP)	<0.001	mg/L	HW	0.001	EPA 200.7	5/4/2012	
Nickel, Total Rec.-(ICP)	0.007	mg/L	HW	0.001	EPA 200.7	5/4/2012	
Sodium, Total Rec.-(ICP)	20.71	mg/L	HW	0.2	EPA 200.7	5/4/2012	
Hardness, Total- as CaCO3	398.0	mg/L	HW	1.0	SM-2340B	5/4/2012	
Comments:							

# Report of Laboratory Analysis




635 Green Road, PO Box 968, Madison, IN 47250  
 Tel: 812.273.6699 Fax: 812.273.5788

**Report To:**  
 Corina Beach  
 CARROLLTON UTILITIES  
 P.O. BOX 269  
 CARROLLTON, KY 41008

Order No.: 2012050160  
 PO No.:  
 Date Received: 05/03/2012  
 Report Date: 05/24/2012

Lab Id	Matrix	Identification	Date Collected	Collected By	Description	
P05-170	Drinking Water	WPC	5/2/2012	FT		
Test Name	Results	Units	Analyst	Detection Limit	Test Method	Analysis Date
Cyanide, Free (DW)	<0.005	mg/L	RH	0.005	SM-4500CN-G & E	5/11/2012
Comments:						

# Report of Laboratory Analysis




635 Green Road, PO Box 968, Madison, IN 47250  
 Tel: 812.273.6699 Fax: 812.273.5788

**Report To:**  
 Corina Beach  
 CARROLLTON UTILITIES  
 P.O. BOX 269  
 CARROLLTON, KY 41008

Order No.: 2012050160  
 PO No.:  
 Date Received: 05/03/2012  
 Report Date: 05/24/2012

Lab Id	Matrix	Identification	Date Collected	Collected By	Description		
P05-169	Drinking Water	WPC	5/2/2012	FT			
Test Name	Results	Units	Analyst	Detection Limit	Test Method	Analysis Date	
Fluoride, Adjusted	0.104	mg/L	PJ	0.02	EPA 300.1	5/4/2012	
Nitrate (as N)	2.73	mg/L	PJ	0.05	EPA 300.1	5/4/2012	
Comments:							

# Report of Laboratory Analysis



635 Green Road, PO Box 968, Madison, IN 47250  
 Tel: 812.273.6699 Fax: 812.273.5788

**Report To:**  
 Corina Beach  
 CARROLLTON UTILITIES  
 P.O. BOX 269  
 CARROLLTON, KY 41008

Order No.: 2012050160  
 PO No.:  
 Date Received: 05/03/2012  
 Report Date: 05/24/2012

Lab Id	Matrix	Identification	Date Collected	Collected By	Description	
P05-177	Drinking Water	WPC	5/3/2012	FT		
Test Name	Results	Units	Analyst	Detection Limit	Test Method	Analysis Date
Iron Related Bacteria	500.000	CFU/mL	FO	10	BART	5/4/2012
Comments:						

# Report of Laboratory Analysis




635 Green Road, PO Box 968, Madison, IN 47250  
 Tel: 812.273.6699 Fax: 812.273.5788

**Report To:**  
 Corina Beach  
 CARROLLTON UTILITIES  
 P. O. BOX 269  
 CARROLLTON, KY 41008

Order No.: 2012050160  
 PO No.:  
 Date Received: 05/03/2012  
 Report Date: 05/24/2012

Lab Id	Matrix	Identification	Date Collected	Collected By	Description		
P05-171	Drinking Water	WPC	5/3/2012	FT			
Test Name	Results	Units	Analyst	Detection Limit	Test Method	Analysis Date	
Aluminum, Total-(ICP)	<0.016	mg/L	HW	0.016	EPA 200.7	5/4/2012	
Copper, Total Rec.-(ICP)	0.039	mg/L	HW	0.002	EPA 200.7	5/4/2012	
Iron, Total Rec.-(ICP)	0.601	mg/L	HW	0.005	EPA 200.7	5/4/2012	
Silver, Total Rec.-(ICP)	<0.003	mg/L	HW	0.003	EPA 200.7	5/4/2012	
Zinc, Total Rec.-(ICP)	0.151	mg/L	HW	0.0005	EPA 200.7	5/4/2012	
Manganese, Total Rec.-(ICP)	0.134	mg/L	HW	0.003	EPA 200.7	5/4/2012	
Comments:							

# Report of Laboratory Analysis




635 Green Road, PO Box 968, Madison, IN 47250  
 Tel: 812.273.6699 Fax: 812.273.5788

**Report To:**  
 Corina Beach  
 CARROLLTON UTILITIES  
 P.O. BOX 269  
 CARROLLTON, KY 41008

Order No : 2012050160  
 PO No.:  
 Date Received: 05/03/2012  
 Report Date: 05/24/2012

Lab Id	Matrix	Identification	Date Collected	Collected By	Description		
P05-172	Drinking Water	WPC	5/3/2012	FT			
Test Name	Results	Units	Analyst	Detection Limit	Test Method	Analysis Date	
Nitrate (as N)	2.726	mg/L	PJ	0.05	EPA 300.1	5/4/2012	
Nitrite (as N)	<0.05	mg/L	PJ	0.05	EPA 300.1	5/4/2012	
Sulfate	45.546	mg/L	PJ	1.0	EPA 300.1	5/4/2012	
Chloride	45.574	mg/L	PJ	2.0	EPA 300.1	5/4/2012	
Fluoride, Adjusted	0.102	mg/L	PJ	0.02	EPA 300.1	5/4/2012	
Comments:							

# Report of Laboratory Analysis



635 Green Road, PO Box 968, Madison, IN 47250  
 Tel: 812.273.6699 Fax: 812.273.5788


**Report To:**  
 Corina Beach  
 CARROLLTON UTILITIES  
 P.O. BOX 269  
 CARROLLTON, KY 41008

Order No.: 2012050160  
 PO No.:  
 Date Received: 05/03/2012  
 Report Date: 05/24/2012

Lab Id	Matrix	Identification	Date Collected	Collected By	Description		
P05-173	Drinking Water	WPC	5/3/2012	FT			
Test Name	Results	Units	Analyst	Detection Limit	Test Method	Analysis Date	
Color	<1	PC Units	THB	1	SM-2120B	5/3/2012	
Comments:							



# Report of Laboratory Analysis




635 Green Road, PO Box 968, Madison, IN 47250  
 Tel: 812.273.6699 Fax: 812.273.5788

**Report To:**  
 Corina Beach  
 CARROLLTON UTILITIES  
 P.O. BOX 269  
 CARROLLTON, KY 41008

Order No.: 2012050160  
 PO No.:  
 Date Received: 05/03/2012  
 Report Date: 05/24/2012

Lab Id	Matrix	Identification	Date Collected	Collected By	Description	
P05-174	Drinking Water	WPC	5/3/2012	FT		
Test Name	Results	Units	Analyst	Detection Limit	Test Method	Analysis Date
Odor Threshold	<1.0	T.O.N.	THB	1.0	SM-2150B	5/3/2012
Comments:						

# Report of Laboratory Analysis




635 Green Road, PO Box 968, Madison, IN 47250  
 Tel: 812.273.6699 Fax: 812.273.5788

**Report To:**  
 Corina Beach  
 CARROLLTON UTILITIES  
 P.O. BOX 269  
 CARROLLTON, KY 41008

Order No.: 2012050160  
 PO No.:  
 Date Received: 05/03/2012  
 Report Date: 05/24/2012

Lab Id	Matrix	Identification	Date Collected	Collected By	Description		
P05-175	Drinking Water	WPC	5/3/2012	FT			
Test Name	Results	Units	Analyst	Detection Limit	Test Method	Analysis Date	
Surfactants (Foaming Agents)	<0.02	mg MBAS/L	THB	0.02	SM-5540C	5/4/2012	
Comments:							

# Report of Laboratory Analysis



635 Green Road, PO Box 968, Madison, IN 47250  
 Tel: 812.273.6699 Fax: 812.273.5788

**Report To:**  
 Corina Beach  
 CARROLLTON UTILITIES  
 P.O. BOX 269  
 CARROLLTON, KY 41008

Order No.: 2012050160  
 PO No.:  
 Date Received: 05/03/2012  
 Report Date: 05/24/2012

Lab Id	Matrix	Identification	Date Collected	Collected By	Description		
P05-176	Drinking Water	WPC	5/3/2012	FT			
Test Name	Results	Units	Analyst	Detection Limit	Test Method	Analysis Date	
Hardness-(Ca)- as CaCO3	271.8	mg/L	HW	1.0	SM-2340B	5/10/2012	
Alkalinity, Total	320.0	mg CaCO3/L	RH	2.0	SM-2320B	5/7/2012	
pH	7.56	S.U.	PJ	0.10	SM-4500H+B	5/4/2012	
Solids, Dissolved Total	510.0	mg/L	LE	1.0	SM-2540C	5/8/2012	
Corrosivity, (Langelier Index)	0.64	Calculation	WW		SM-2330B	5/23/2012	
Carbonate	320.0	mg CaCO3/L	RH	2.0	SM-2320B	5/11/2012	
Comments: Temp@20C was used in the corrosivity calculation.							

# Report of Laboratory Analysis




635 Green Road, PO Box 968, Madison, IN 47250  
 Tel: 812.273.6699 Fax: 812.273.5788

**Report To:**  
 Corina Beach  
 CARROLLTON UTILITIES  
 P.O. BOX 269  
 CARROLLTON, KY 41008

Order No.: 2012050160  
 PO No.:  
 Date Received: 05/03/2012  
 Report Date: 05/24/2012

Lab Id	Matrix	Identification	Date Collected	Collected By	Description		
P05-150	Drinking Water	WPC	5/2/2012	FT			
Test Name	Results	Units	Analyst	Detection Limit	Test Method	Analysis Date	
Alachlor	<0.44	ug/L	WW	0.44	EPA 525.2	5/23/2012	
Atrazine	<0.22	ug/L	WW	0.22	EPA 525.2	5/23/2012	
Benzo(a)pyrene	<0.044	ug/L	WW	0.044	EPA 525.2	5/23/2012	
Di(2-ethylhexyl)adipate	<1.32	ug/L	WW	1.32	EPA 525.2	5/23/2012	
Di(2-ethylhexyl)phthalate	<1.32	ug/L	WW	1.32	EPA 525.2	5/23/2012	
Hexachloropentadiene	<0.22	ug/L	WW	0.22	EPA 525.2	5/23/2012	
Methoxychlor	<0.22	ug/L	WW	0.22	EPA 525.2	5/23/2012	
Simazine	<0.154	ug/L	WW	0.154	EPA 525.2	5/23/2012	
Sample Preparation-SPE Extraction	DONE		BD		EPA 525.2	5/3/2012	
Aldicarb	<1.1	ug/L	HW	1.1	EPA 531.1	5/8/2012	
Aldicarb Sulfone	<1.4	ug/L	HW	1.4	EPA 531.1	5/8/2012	
Aldicarb Sulfoxide	<1.0	ug/L	HW	1.0	EPA 531.1	5/8/2012	
Carbofuran	<1.98	ug/L	HW	1.98	EPA 531.1	5/8/2012	
Oxamyl (Vydate)	<4.4	ug/L	HW	4.4	EPA 531.1	5/8/2012	
Sample Preparation-Filtration	DONE		HW		EPA 531.1	5/8/2012	
Chlordane (total)	<0.44	ug/L	WW	0.44	EPA 508.1	5/17/2012	
Endrin	<0.022	ug/L	WW	0.022	EPA 508.1	5/17/2012	
Heptachlor	<0.088	ug/L	WW	0.088	EPA 508.1	5/17/2012	
Heptachlor Epoxide	<0.044	ug/L	WW	0.044	EPA 508.1	5/17/2012	
Hexachlorobenzene	<0.22	ug/L	WW	0.22	EPA 508.1	5/17/2012	
Lindane	<0.044	ug/L	WW	0.044	EPA 508.1	5/17/2012	
Toxaphene	<2.2	ug/L	WW	2.2	EPA 508.1	5/17/2012	
Sample Preparation-SPE Extraction	DONE		HW		EPA 508.1	5/4/2012	
Dalapon	<2.2	ug/L	HW	2.2	EPA 552.2	5/8/2012	

# Report of Laboratory Analysis



635 Green Road, PO Box 968, Madison, IN 47250  
 Tel: 812.273.6699 Fax: 812.273.5788

**Report To:**  
 Corina Beach  
 CARROLLTON UTILITIES  
 P.O. BOX 269  
 CARROLLTON, KY 41008

Order No.: 2012050160  
 PO No.:  
 Date Received: 05/03/2012  
 Report Date 05/24/2012

Lab Id	Matrix	Identification	Date Collected	Collected By	Description		
P05-150	Drinking Water	WPC	5/2/2012	FT			
Test Name		Results	Units	Analyst	Detection Limit	Test Method	Analysis Date
Sample Preparation-LL Extraction		DONE		HW		EPA 552.2	5/4/2012
2,4,5-TP		<0.44	ug/L	WW	0.44	EPA 515.2	5/18/2012
2,4-D		<0.22	ug/L	WW	0.22	EPA 515.2	5/18/2012
Dinoseb		<0.44	ug/L	WW	0.44	EPA 515.2	5/18/2012
Pentachlorophenol		<0.088	ug/L	WW	0.088	EPA 515.2	5/18/2012
Picloram		<0.22	ug/L	WW	0.22	EPA 515.2	5/18/2012
Sample Preparation-SPE Extraction		DONE		BD		EPA 515.2	5/9/2012
DBCP		<0.044	ug/L	WW	0.044	EPA 504.1	5/11/2012
EDB		<0.022	ug/L	WW	0.022	EPA 504.1	5/11/2012
Sample Preparation-LL Extraction		DONE		HW		EPA 504.1	5/11/2012
Diquat		<0.88	ug/L	WW	0.88	EPA 549.2	5/8/2012
Sample Preparation-SPE Extraction		DONE		BD		EPA 549.2	5/3/2012
Endothall		<19.8	ug/L	WW	19.8	EPA 548.1	5/10/2012
Sample Preparation-SPE Extraction		DONE		BD		EPA 548.1	5/8/2012
Comments:							

Approved by:   
 Whitney Wu, Lab Manager

# Report of Laboratory Analysis




635 Green Road, PO Box 968, Madison, IN 47250  
 Tel: 812.273.6699 Fax: 812.273.5788

**Report To:**  
 Corina Beach  
 CARROLLTON UTILITIES  
 P.O. BOX 269  
 CARROLLTON, KY 41008

Order No.: 2012050161  
 PO No.:  
 Date Received: 05/03/2012  
 Report Date: 05/24/2012

Lab Id	Matrix	Identification	Date Collected	Collected By	Description		
P05-196	Drinking Water	AERATED WATER	5/2/2012	FT			
Test Name	Results	Units	Analyst	Detection Limit	Test Method	Analysis Date	
Benzene	<0.5	ug/L	THB	0.5	EPA 524.2	5/3/2012	
Carbon Tetrachloride	<0.5	ug/L	THB	0.5	EPA 524.2	5/3/2012	
Chlorobenzene	<0.5	ug/L	THB	0.5	EPA 524.2	5/3/2012	
1,2-Dichlorobenzene	<0.5	ug/L	THB	0.5	EPA 524.2	5/3/2012	
1,4-Dichlorobenzene	<0.5	ug/L	THB	0.5	EPA 524.2	5/3/2012	
1,2-Dichloroethane	<0.5	ug/L	THB	0.5	EPA 524.2	5/3/2012	
1,1-Dichloroethylene	<0.5	ug/L	THB	0.5	EPA 524.2	5/3/2012	
1,2-Dichloroethylene,cis	<0.5	ug/L	THB	0.5	EPA 524.2	5/3/2012	
1,2-Dichloroethylene,trans	<0.5	ug/L	THB	0.5	EPA 524.2	5/3/2012	
Methylene Chloride (Dichloromethane)	<0.5	ug/L	THB	0.5	EPA 524.2	5/3/2012	
1,2-Dichloropropane	<0.5	ug/L	THB	0.5	EPA 524.2	5/3/2012	
Ethylbenzene	<0.5	ug/L	THB	0.5	EPA 524.2	5/3/2012	
Styrene	<0.5	ug/L	THB	0.5	EPA 524.2	5/3/2012	
Tetrachloroethylene	<0.5	ug/L	THB	0.5	EPA 524.2	5/3/2012	
Toluene	<0.5	ug/L	THB	0.5	EPA 524.2	5/3/2012	
1,2,4-Trichlorobenzene	<0.5	ug/L	THB	0.5	EPA 524.2	5/3/2012	
1,1,1-Trichloroethane	<0.5	ug/L	THB	0.5	EPA 524.2	5/3/2012	
1,1,2-Trichloroethane	<0.5	ug/L	THB	0.5	EPA 524.2	5/3/2012	
Trichloroethylene	<0.5	ug/L	THB	0.5	EPA 524.2	5/3/2012	
Vinyl Chloride	<0.5	ug/L	THB	0.5	EPA 524.2	5/3/2012	
Total Xylenes	<1.0	ug/L	THB	1.0	EPA 524.2	5/3/2012	
Bromobenzene	<0.5	ug/L	THB	0.5	EPA 524.2	5/3/2012	
Bromomethane	<0.5	ug/L	THB	0.5	EPA 524.2	5/3/2012	
Chloroethane	<0.5	ug/L	THB	0.5	EPA 524.2	5/3/2012	

# Report of Laboratory Analysis



635 Green Road, PO Box 968, Madison, IN 47250  
 Tel: 812.273.6699 Fax: 812.273.5788

**Report To:**  
 Corina Beach  
 CARROLLTON UTILITIES  
 P.O. BOX 269  
 CARROLLTON, KY 41008

Order No.: 2012050161  
 PO No.:  
 Date Received: 05/03/2012  
 Report Date: 05/24/2012

Lab Id	Matrix	Identification	Date Collected	Collected By	Description		
P05-196	Drinking Water	AERATED WATER	5/2/2012	FT			
Test Name	Results	Units	Analyst	Detection Limit	Test Method	Analysis Date	
Methyl Chloride (Chloromethane)	<0.5	ug/L	THB	0.5	EPA 524.2	5/3/2012	
2-Chlorotoluene	<0.5	ug/L	THB	0.5	EPA 524.2	5/3/2012	
4-Chlorotoluene	<0.5	ug/L	THB	0.5	EPA 524.2	5/3/2012	
1,3-Dichlorobenzene	<0.5	ug/L	THB	0.5	EPA 524.2	5/3/2012	
1,1-Dichloroethane	<0.5	ug/L	THB	0.5	EPA 524.2	5/3/2012	
1,3-Dichloropropane	<0.5	ug/L	THB	0.5	EPA 524.2	5/3/2012	
2,2-Dichloropropane	<0.5	ug/L	THB	0.5	EPA 524.2	5/3/2012	
1,1-Dichloropropylene	<0.5	ug/L	THB	0.5	EPA 524.2	5/3/2012	
Total 1,3-Dichloropropene	<0.5	ug/L	THB	0.5	EPA 524.2	5/3/2012	
1,1,1,2-Tetrachloroethane	<0.5	ug/L	THB	0.5	EPA 524.2	5/3/2012	
1,1,2,2-Tetrachloroethane	<0.5	ug/L	THB	0.5	EPA 524.2	5/3/2012	
1,2,3-Trichloropropane	<0.5	ug/L	THB	0.5	EPA 524.2	5/3/2012	
Dibromomethane	<0.5	ug/L	THB	0.5	EPA 524.2	5/3/2012	
Bromodichloromethane	<0.5	ug/L	THB	0.5	EPA 524.2	5/3/2012	
Bromoform	<0.5	ug/L	THB	0.5	EPA 524.2	5/3/2012	
Chlorodibromomethane	<0.5	ug/L	THB	0.5	EPA 524.2	5/3/2012	
Chloroform	<0.5	ug/L	THB	0.5	EPA 524.2	5/3/2012	
Methyl-Tert-Butyl Ether (MTBE)	<0.5	ug/L	THB	0.5	EPA 524.2	5/3/2012	
Comments:							

# Report of Laboratory Analysis



635 Green Road, PO Box 968, Madison, IN 47250  
 Tel: 812.273.6699 Fax: 812.273.5788


**Report To:**  
 Corina Beach  
 CARROLLTON UTILITIES  
 P.O. BOX 269  
 CARROLLTON, KY 41008

Order No.: 2012050161  
 PO No.:  
 Date Received: 05/03/2012  
 Report Date: 05/24/2012

Lab Id	Matrix	Identification	Date Collected	Collected By	Description		
P05-165	Drinking Water	AERATED WATER	5/2/2012	FT			
Test Name		Results	Units	Analyst	Detection Limit	Test Method	Analysis Date
Arsenic, Total Rec.-(GFAA)		0.0006	mg/L	HW	0.0006	EPA 200.9	5/8/2012
Antimony, Total Rec.-(GFAA)		0.0004	mg/L	HW	0.0004	EPA 200.9	5/8/2012
Cadmium, Total Rec.-(GFAA)		<0.0002	mg/L	HW	0.0002	EPA 200.9	5/9/2012
Selenium, Total Rec.-(GFAA)		<0.0008	mg/L	HW	0.0008	EPA 200.9	5/9/2012
Thallium, Total Rec.-(GFAA)		<0.0005	mg/L	HW	0.0005	EPA 200.9	5/9/2012
Mercury, Total Rec.-(CVAA)		<0.0001	mg/L	LE	0.0001	SM-3112B	5/16/2012
Barium, Total Rec.-(ICP)		0.106	mg/L	HW	0.08	EPA 200.7	5/4/2012
Beryllium, Total Rec.-(ICP)		<0.0005	mg/L	HW	0.0005	EPA 200.7	5/4/2012
Chromium, Total Rec.-(ICP)		<0.001	mg/L	HW	0.001	EPA 200.7	5/4/2012
Nickel, Total Rec.-(ICP)		0.006	mg/L	HW	0.001	EPA 200.7	5/4/2012
Sodium, Total Rec.-(ICP)		21.13	mg/L	HW	0.2	EPA 200.7	5/4/2012
Hardness, Total- as CaCO3		406.9	mg/L	HW	1.0	SM-2340B	5/4/2012
Comments:							



# Report of Laboratory Analysis




635 Green Road, PO Box 968, Madison, IN 47250  
 Tel: 812.273.6699 Fax: 812.273.5788

**Report To:**  
 Corina Beach  
 CARROLLTON UTILITIES  
 P.O. BOX 269  
 CARROLLTON, KY 41008

Order No.: 2012050161  
 PO No.:  
 Date Received: 05/03/2012  
 Report Date: 05/24/2012

Lab Id	Matrix	Identification	Date Collected	Collected By	Description	
P05-166	Drinking Water	AERATED WATER	5/2/2012	FT		
Test Name	Results	Units	Analyst	Detection Limit	Test Method	Analysis Date
Cyanide, Free (DW)	<0.005	mg/L	RH	0.005	SM-4500CN-G & E	5/11/2012
Comments:						

# Report of Laboratory Analysis




635 Green Road, PO Box 968, Madison, IN 47250  
 Tel: 812.273.6699 Fax: 812.273.5788

**Report To:**  
 Corina Beach  
 CARROLLTON UTILITIES  
 P.O. BOX 269  
 CARROLLTON, KY 41008

Order No.: 2012050161  
 PO No.:  
 Date Received: 05/03/2012  
 Report Date: 05/24/2012

Lab Id	Matrix	Identification	Date Collected	Collected By	Description		
P05-167	Drinking Water	AERATED WATER	5/2/2012	FT			
Test Name	Results	Units	Analyst	Detection Limit	Test Method	Analysis Date	
Fluoride, Adjusted	0.104	mg/L	PJ	0.02	EPA 300.1	5/4/2012	
Nitrate (as N)	3.281	mg/L	PJ	0.05	EPA 300.1	5/4/2012	
Comments:							

# Report of Laboratory Analysis



635 Green Road, PO Box 968, Madison, IN 47250  
 Tel: 812.273.6699 Fax: 812.273.5788

**Report To:**  
 Corina Beach  
 CARROLLTON UTILITIES  
 P.O. BOX 269  
 CARROLLTON, KY 41008

Order No.: 2012050161  
 PO No.:  
 Date Received: 05/03/2012  
 Report Date: 05/24/2012

Lab Id	Matrix	Identification	Date Collected	Collected By	Description		
P05-188	Drinking Water	AERATED WATER	5/3/2012	FT			
Test Name	Results	Units	Analyst	Detection Limit	Test Method	Analysis Date	
Aluminum, Total-(ICP)	<0.016	mg/L	HW	0.016	EPA 200.7	5/4/2012	
Copper, Total Rec.-(ICP)	<0.002	mg/L	HW	0.002	EPA 200.7	5/4/2012	
Iron, Total Rec.-(ICP)	0.14	mg/L	HW	0.005	EPA 200.7	5/4/2012	
Silver, Total Rec.-(ICP)	<0.003	mg/L	HW	0.003	EPA 200.7	5/4/2012	
Zinc, Total Rec.-(ICP)	0.0038	mg/L	HW	0.0005	EPA 200.7	5/4/2012	
Manganese, Total Rec.-(ICP)	0.109	mg/L	HW	0.003	EPA 200.7	5/4/2012	
Comments:							

# Report of Laboratory Analysis




635 Green Road, PO Box 968, Madison, IN 47250  
 Tel: 812.273.6699 Fax: 812.273.5788

**Report To:**  
 Corina Beach  
 CARROLLTON UTILITIES  
 P.O. BOX 269  
 CARROLLTON, KY 41008

Order No.: 2012050161  
 PO No.:  
 Date Received: 05/03/2012  
 Report Date: 05/24/2012

Lab Id	Matrix	Identification	Date Collected	Collected By	Description		
P05-189	Drinking Water	AERATED WATER	5/3/2012	FT			
Test Name	Results	Units	Analyst	Detection Limit	Test Method	Analysis Date	
Nitrate (as N)	5.485	mg/L	PJ	0.05	EPA 300.1	5/4/2012	
Nitrite (as N)	<0.05	mg/L	PJ	0.05	EPA 300.1	5/4/2012	
Sulfate	50.000	mg/L	PJ	1.0	EPA 300.1	5/4/2012	
Chloride	61.334	mg/L	PJ	2.0	EPA 300.1	5/4/2012	
Fluoride, Adjusted	0.091	mg/L	PJ	0.02	EPA 300.1	5/4/2012	
Comments:							

# Report of Laboratory Analysis




635 Green Road, PO Box 968, Madison, IN 47250  
 Tel: 812.273.6699 Fax: 812.273.5788

**Report To:**  
 Corina Beach  
 CARROLLTON UTILITIES  
 P.O. BOX 269  
 CARROLLTON, KY 41008

Order No.: 2012050161  
 PO No.:  
 Date Received: 05/03/2012  
 Report Date: 05/24/2012

Lab Id	Matrix	Identification	Date Collected	Collected By	Description	
P05-190	Drinking Water	AERATED WATER	5/3/2012	FT		
Test Name	Results	Units	Analyst	Detection Limit	Test Method	Analysis Date
Color	<1	PC Units	THB	1	SM-2120B	5/3/2012
Comments:						

# Report of Laboratory Analysis




635 Green Road, PO Box 968, Madison, IN 47250  
 Tel: 812.273.6699 Fax: 812.273.5788

**Report To:**  
 Corina Beach  
 CARROLLTON UTILITIES  
 P.O. BOX 269  
 CARROLLTON, KY 41008

Order No.: 2012050161  
 PO No.:  
 Date Received: 05/03/2012  
 Report Date: 05/24/2012

Lab Id	Matrix	Identification	Date Collected	Collected By	Description		
P05-191	Drinking Water	AERATED WATER	5/3/2012	FT			
Test Name	Results	Units	Analyst	Detection Limit	Test Method	Analysis Date	
Odor Threshold	<1.0	T.O.N.	THB	1.0	SM-2150B	5/3/2012	
Comments:							

# Report of Laboratory Analysis



635 Green Road, PO Box 968, Madison, IN 47250  
 Tel: 812.273.6699 Fax: 812.273.5788

**Report To:**  
 Corina Beach  
 CARROLLTON UTILITIES  
 P.O. BOX 269  
 CARROLLTON, KY 41008

Order No.: 2012050161  
 PO No.:  
 Date Received: 05/03/2012  
 Report Date: 05/24/2012

Lab Id	Matrix	Identification	Date Collected	Collected By	Description	
P05-192	Drinking Water	AERATED WATER	5/3/2012	FT		
Test Name	Results	Units	Analyst	Detection Limit	Test Method	Analysis Date
Surfactants (Foaming Agents)	<0.02	mg MBAS/L	THB	0.02	SM-5540C	5/4/2012
Comments:						

# Report of Laboratory Analysis



635 Green Road, PO Box 968, Madison, IN 47250  
 Tel: 812.273.6699 Fax: 812.273.5788


**Report To:**  
 Corina Beach  
 CARROLLTON UTILITIES  
 P.O. BOX 269  
 CARROLLTON, KY 41008

Order No.: 2012050161  
 PO No.:  
 Date Received: 05/03/2012  
 Report Date: 05/24/2012

Lab Id	Matrix	Identification	Date Collected	Collected By	Description		
P05-193	Drinking Water	AERATED WATER	5/3/2012	FT			
Test Name	Results	Units	Analyst	Detection Limit	Test Method	Analysis Date	
Hardness-(Ca)- as CaCO3	286.5	mg/L	HW	1.0	SM-2340B	5/10/2012	
Alkalinity, Total	344.0	mg CaCO3/L	RH	2.0	SM-2320B	5/7/2012	
pH	8	S.U.	PJ	0.10	SM-4500H+B	5/4/2012	
Solids, Dissolved Total	533.3	mg/L	LE	1.0	SM-2540C	5/8/2012	
Corrosivity, (Langelier Index)	1.13	Calculation	WW		SM-2330B	5/23/2012	
Carbonate	344.0	mg CaCO3/L	RH	2.0	SM-2320B	5/11/2012	
Comments: Temp@20C was used in the corrosivity calculation.							



# Report of Laboratory Analysis




635 Green Road, PO Box 968, Madison, IN 47250  
 Tel: 812.273.6699 Fax: 812.273.5788

**Report To:**  
 Corina Beach  
 CARROLLTON UTILITIES  
 P.O. BOX 269  
 CARROLLTON, KY 41008

Order No.: 2012050161  
 PO No.:  
 Date Received: 05/03/2012  
 Report Date: 05/24/2012

Lab Id	Matrix	Identification	Date Collected	Collected By	Description		
P05-148	Drinking Water	AERATED WATER	5/2/2012	FT			
Test Name		Results	Units	Analyst	Detection Limit	Test Method	Analysis Date
Alachlor		<0.44	ug/L	WW	0.44	EPA 525.2	5/22/2012
Atrazine		<0.22	ug/L	WW	0.22	EPA 525.2	5/22/2012
Benzo(a)pyrene		<0.044	ug/L	WW	0.044	EPA 525.2	5/22/2012
Di(2-ethylhexyl)adipate		<1.32	ug/L	WW	1.32	EPA 525.2	5/22/2012
Di(2-ethylhexyl)phthalate		<1.32	ug/L	WW	1.32	EPA 525.2	5/22/2012
Hexachloropentadiene		<0.22	ug/L	WW	0.22	EPA 525.2	5/22/2012
Methoxychlor		<0.22	ug/L	WW	0.22	EPA 525.2	5/22/2012
Simazine		<0.154	ug/L	WW	0.154	EPA 525.2	5/22/2012
Sample Preparation-SPE Extraction		DONE		BD		EPA 525.2	5/3/2012
Aldicarb		<1.1	ug/L	HW	1.1	EPA 531.1	5/8/2012
Aldicarb Sulfone		<1.4	ug/L	HW	1.4	EPA 531.1	5/8/2012
Aldicarb Sulfoxide		<1.0	ug/L	HW	1.0	EPA 531.1	5/8/2012
Carbofuran		<1.98	ug/L	HW	1.98	EPA 531.1	5/8/2012
Oxamyl (Vydate)		<4.4	ug/L	HW	4.4	EPA 531.1	5/8/2012
Sample Preparation-Filtration		DONE		HW		EPA 531.1	5/8/2012
Chlordane (total)		<0.44	ug/L	WW	0.44	EPA 508.1	5/17/2012
Endrin		<0.022	ug/L	WW	0.022	EPA 508.1	5/17/2012
Heptachlor		<0.088	ug/L	WW	0.088	EPA 508.1	5/17/2012
Heptachlor Epoxide		<0.044	ug/L	WW	0.044	EPA 508.1	5/17/2012
Hexachlorobenzene		<0.22	ug/L	WW	0.22	EPA 508.1	5/17/2012
Lindane		<0.044	ug/L	WW	0.044	EPA 508.1	5/17/2012
Toxaphene		<2.2	ug/L	WW	2.2	EPA 508.1	5/17/2012
Sample Preparation-SPE Extraction		DONE		HW		EPA 508.1	5/4/2012
Dalapon		<2.2	ug/L	HW	2.2	EPA 552.2	5/8/2012

# Report of Laboratory Analysis



635 Green Road, PO Box 968, Madison, IN 47250  
 Tel: 812.273.6699 Fax: 812.273.5788

**Report To:**  
 Corina Beach  
 CARROLLTON UTILITIES  
 P. O. BOX 269  
 CARROLLTON, KY 41008


Order No.: 2012050161  
 PO No.:  
 Date Received: 05/03/2012  
 Report Date: 05/24/2012

Lab Id	Matrix	Identification	Date Collected	Collected By	Description		
P05-148	Drinking Water	AERATED WATER	5/2/2012	FT			
Test Name	Results	Units	Analyst	Detection Limit	Test Method	Analysis Date	
Sample Preparation-LL Extraction	DONE		HW		EPA 552.2	5/4/2012	
2,4,5-TP	<0.44	ug/L	WW	0.44	EPA 515.2	5/18/2012	
2,4-D	<0.22	ug/L	WW	0.22	EPA 515.2	5/18/2012	
Dinoseb	<0.44	ug/L	WW	0.44	EPA 515.2	5/18/2012	
Pentachlorophenol	<0.088	ug/L	WW	0.088	EPA 515.2	5/18/2012	
Picloram	<0.22	ug/L	WW	0.22	EPA 515.2	5/18/2012	
Sample Preparation-SPE Extraction	DONE		BD		EPA 515.2	5/9/2012	
DBCP	<0.044	ug/L	WW	0.044	EPA 504.1	5/11/2012	
EDB	<0.022	ug/L	WW	0.022	EPA 504.1	5/11/2012	
Sample Preparation-LL Extraction	DONE		HW		EPA 504.1	5/11/2012	
Diquat	<0.88	ug/L	WW	0.88	EPA 549.2	5/8/2012	
Sample Preparation-SPE Extraction	DONE		BD		EPA 549.2	5/3/2012	
Endothall	<19.8	ug/L	WW	19.8	EPA 548.1	5/10/2012	
Sample Preparation-SPE Extraction	DONE		BD		EPA 548.1	5/8/2012	
Comments:							

Approved by:

Whitney Wu, Lab Manager

# Report of Laboratory Analysis



635 Green Road, PO Box 968, Madison, IN 47250  
 Tel: 812.273.6699 Fax: 812.273.5788

**Report To:**  
 Frank Thieman  
 CARROLLTON UTILITIES  
 P.O. BOX 269  
 CARROLLTON, KY 41008

Order No.: 2012060345  
 PO No.:  
 Date Received: 06/11/2012  
 Report Date: 07/02/2012

Lab Id	Matrix	Identification	Date Collected	Collected By	Description	
P06-093	Drinking Water	WELL PUMP C	6/11/2012	FT		
Test Name	Results	Units	Analyst	Detection Limit	Test Method	Analysis Date
Iron Related Bacteria	<10	CFU/mL	FO	10	BART	6/12/2012

Comments:

Lab Id	Matrix	Identification	Date Collected	Collected By	Description	
P06-094	Drinking Water	WELL PUMP C	6/11/2012	FT		
Test Name	Results	Units	Analyst	Detection Limit	Test Method	Analysis Date
Sulfur Related Bacteria	<10 .0	CFU/mL	FO	10 .0	BART	6/12/2012

Comments:

Approved by:

Whitney Wu, Lab Manager

KENTUCKY DIVISION OF WATER  
DRINKING WATER BRANCH

2011 MAY -5 AM 11:10  
Revised 01/04/07  
DIVISION OF WATER

MONTHLY OPERATION REPORT (MOR)--ALL WATER SYSTEMS

MONTH & YEAR (mm/yyyy)

04/2011

Indicate one with "X"

- SURFACE WATER  
 GROUNDWATER  
 PURCHASE/DISTRIBUTE ONLY

DEP Form 4012--Revised 07/2006

PWS ID:	KY0210067	PLANT ID:	A	PLANT NAME:	Carrollton Water Treatment Plant
PWS NAME:	Carrollton Utilities	PLANT CLASS:	III	DIST. CLASS:	II
AGENCY INTEREST (AI):	696	DATE MAILED:	5/5/2011		
SOURCE NAME:	Ohio River Alluvial Aquifer	COUNTY:	Carroll		
OPERATOR(S) RESPONSIBLE / IN-CHARGE		CLASS	CERTIFICATION NUMBER		
WTP SHIFT 1:	Franklin W. Thieman II	IIIA	19184		
WTP SHIFT 2:	Chris Rose	IIIA	19857		
WTP SHIFT 3:					
DISTRIBUTION:	Larry Hayes	IID	9662		

THIS REPORT MUST BE RECEIVED BY THE DIVISION OF WATER AND APPLICABLE FIELD OFFICE  
NO LATER THAN 10 DAYS AFTER THE END OF THE MONTH.

TREATMENT PLANTS COMPLETE:

- DESIGN CAPACITY (gpm): 1040 gpm
- TYPE OF FILTRATION USED: Mixed Media
- DESIGN FILTRATION RATE (gpm/sq. ft.): Not to exceed 5gpm/sq.ft.
- PERCENT BACKWASH WATER USED: 3.6
- DATE FLOCCULATION BASIN(S) LAST CLEANED: April 20th 2011
- DATE SETTLING BASIN(S) LAST CLEANED: Claricone Unit

I certify under penalty of law that I have personally examined and am familiar with the information submitted herein. Based on my inquiry of those individuals immediately responsible for obtaining the information, I believe the submitted information is true, accurate and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment. See KRS 224.99-010 and 401 KAR 8:020. (Penalties under this statute and regulation may include fines up to \$25,000 per violation or by imprisonment for not more than one year, or both).

*Franklin Thieman II*

5/2/2011

SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT

DATE

KENTUCKY DIVISION OF WATER - DRINKING WATER BRANCH  
 WATER TREATMENT PLANT - MONTHLY OPERATING REPORT

PWS ID : KY0210067

PLANT ID : A

REPORT MONTH/YEAR : 04/2011

PAGE 1 OF 11

APPLICABLE TO ALL PLANTS

DAY	RAW WATER TREATED GALLONS	HOURS PLANT OPERATED	COAGULANT		COAGULANT Polymer		pH ADJUSTMENT CaO Lime		DISINFECTANT Cl2 Chlorine		DISINFECTANT	
			LBS	PPM	LBS	PPM	Pre		Pre		Post	
							LBS	PPM	LBS	PPM	LBS	PPM
1	797,000	12.4			191.0	26.7	1776.0	267.5	17.0	2.6		
2	712,000	11.8			178.0	30.0	1794.0	302.1	12.0	2.0		
3	699,000	11.6			175.0	30.0	1705.0	292.5	13.0	2.2		
4	728,000	12.1			182.0	30.0	1513.0	249.2	14.0	2.3		
5	773,000	12.5			188.0	29.2	1563.0	242.4	15.0	2.3		
6	679,000	11.1			167.0	29.5	1408.0	248.6	13.0	2.3		
7	716,000	12.5			188.0	31.5	1588.0	265.9	17.0	2.8		
8	711,000	12.1			182.0	30.7	1452.0	244.9	14.0	2.4		
9	861,000	14.0			211.0	29.4	1680.0	234.0	15.0	2.1		
10	827,000	13.6			205.0	29.7	1700.0	246.5	17.0	2.5		
11	729,000	12.3			185.0	30.4	1538.0	253.0	15.0	2.5		
12	743,000	11.8			178.0	28.7	1652.0	266.6	15.0	2.4		
13	767,000	12.6			190.0	29.7	1764.0	275.8	17.0	2.7		
14	736,000	12.0			181.0	29.4	1644.0	267.1	13.0	2.1		
15	793,000	12.8			192.0	29.0	1728.0	261.3	17.0	2.6		
16	711,000	11.3			170.0	28.7	1525.0	257.2	24.0	4.0		
17	773,000	12.7			191.0	29.6	1740.0	269.9	10.0	1.6		
18	802,000	12.8			193.0	28.9	1754.0	262.2	16.0	2.4		
19	759,000	12.1			182.0	28.8	1658.0	261.9	14.0	2.2		
20	779,000	14.5			219.0	33.7	1740.0	267.8	16.0	2.5		
21	861,000	14.0			211.0	29.4	1820.0	253.5	18.0	2.5		
22	788,000	12.7			191.0	29.1	1740.0	264.8	15.0	2.3		
23	769,000	12.1			182.0	28.4	1718.0	267.9	18.0	2.8		
24	777,000	11.5			173.0	26.7	1633.0	252.0	17.0	2.6		
25	761,000	12.2			184.0	29.0	1732.0	272.9	20.0	3.2		
26	806,000	13.1			197.0	29.3	2056.0	305.9	16.0	2.4		
27	774,000	12.6			190.0	29.4	2041.0	316.2	16.0	2.5		
28	726,000	11.5			173.0	28.6	1863.0	307.7	16.0	2.6		
29	804,000	13.1			197.0	29.4	2122.0	316.5	15.0	2.2		
30	806,000	12.0			180.0	26.7	1944.0	289.5	17.0	2.5		
31												
TOTAL	22,971,000		0.0		5626.0		51593.0		472.0		0.0	
AVERAGE	765,700		#DIV/0!	#DIV/0!	187.5	29.4	1719.8	269.4	15.7	2.5	#DIV/0!	#DIV/0!
MAX	861,000											



KENTUCKY DIVISION OF WATER - DRINKING WATER BRANCH  
 WATER TREATMENT PLANT - MONTHLY OPERATING REPORT

PWS ID : KY0210067  
 PLANT ID: A

APPLICABLE TO ALL PLANTS

REPORT MONTH/YEAR: 04/2011

PAGE 3 OF 11

ANALYTICAL RESULTS (mg/L OR PPM UNLESS OTHERWISE SPECIFIED)														
DAY	pH			TOTAL ALKALINITY		TOTAL HARDNESS		CHLORINE RESIDUAL				TURBIDITY (NTU)		
	RAW	TOP OF FILTER	TAP	RAW	TAP	RAW	TAP	TOP OF FILTER	PLANT TAP	TOTAL	FREE	RAW	SETTLED WATER	PLANT TAP
1	6.80	8.10	7.70				182				1.30	0.07		0.06
2	6.80	8.20	7.50				192				1.30	0.05		0.06
3	6.80	8.10	7.60				190				1.30	0.06		0.05
4	6.90	8.10	7.60		70	360	188				1.30	0.07		0.05
5	6.80	8.00	7.50				184				1.10	0.06		0.06
6	6.80	8.20	7.60				180				1.40	0.09		0.07
7	6.80	8.10	7.60				172				1.40	0.07		0.05
8	6.90	8.30	7.60				180				1.20	0.08		0.06
9	6.90	8.10	7.80				188				1.40	0.08		0.09
10	6.80	8.10	7.60				182				1.30	0.10		0.10
11	6.90	8.00	7.70		76	410	184				1.20	0.08		0.08
12	6.80	8.20	7.60				188				1.20	0.07		0.08
13	6.90	8.10	7.50				194				1.20	0.08		0.08
14	6.90	8.10	7.60				176				1.20	0.10		0.07
15	6.90	8.10	7.50				176				1.30	0.10		0.06
16	6.90	8.10	7.70				182				1.20	0.08		0.06
17	6.80	8.10	7.60				180				1.30	0.08		0.07
18	6.90	8.10	7.50		80	446	174				1.40	0.08		0.06
19	6.80	8.10	7.50				176				1.30	0.07		0.05
20	6.80	8.20	7.40				218				1.10	0.10		0.08
21	6.80	8.00	7.40				240				1.20	0.10		0.10
22	6.90	8.00	7.40				198				1.30	0.10		0.07
23	6.80	8.00	7.50				194				1.20	0.09		0.07
24	6.90	8.00	7.50				198				1.10	0.08		0.07
25	6.90	7.90	7.50		76	398	182				1.30	0.07		0.05
26	6.80	7.90	7.50				200				1.20	0.10		0.06
27	6.70	6.00	7.20				188				1.40	0.15		0.06
28	6.70	8.00	7.40				186				1.30	0.13		0.06
29	6.90	8.20	7.60				180				1.30	0.10		0.06
30	6.80	8.20	7.50				184				1.20	0.09		0.06
31														
AVERAGE	6.8	8.1	7.5	#DIV/0!	76	404	188	#DIV/0!	#DIV/0!	#DIV/0!	1.26	0.09	#DIV/0!	0.07





KENTUCKY DIVISION OF WATER - DRINKING WATER BRANCH  
 WATER TREATMENT PLANT - MONTHLY OPERATING REPORT

PWSID: KY0210067  
 PLANT ID: A

APPLICABLE TO ALL PLANTS

REPORT MONTH/YEAR: 04/2011

PAGE 5 OF 11

\*Please answer Y/N question below this chart.

ANALYTICAL RESULTS (mg/L OR PPM UNLESS OTHERWISE SPECIFIED)											
DAY	FLUORIDE		IRON		MANGANESE				Lowest Daily Chlorine Residual Plant Tap On-Line Chlorine Analyzer	RAINFALL	WATER TEMP.
	RAW	TAP	RAW	TAP	RAW	TAP	RAW	TAP	FREE / TOTAL	INCHES	DEGREES F°/C°
1		1.10							1.32	0.0	16.0
2		1.10							1.19	0.0	16.0
3		1.20							1.24	0.0	16.0
4	0.30	1.20	0.17	0.01		0.04			1.20	1.0	16.0
5		1.10							1.14	0.0	16.0
6		1.20							1.29	0.0	16.0
7		1.30							1.16	0.1	16.0
8		1.30							1.05	0.0	16.0
9		1.30							1.18	0.6	16.0
10		1.30							1.10	0.0	16.0
11	0.17	1.10	0.09	0.01		0.03			1.20	2.8	16.0
12		1.00							1.23	0.0	16.0
13		1.10							1.20	0.0	16.0
14		1.30							1.14	0.0	16.0
15		1.30							1.20	0.7	16.0
16		1.20							1.12	0.5	16.0
17		1.10							1.33	0.0	16.0
18	0.27	1.30	0.09	0.01		0.04			1.38	0.5	16.0
19		1.20							1.34	1.0	16.0
20		1.20							1.10	0.0	16.0
21		1.30							1.10	0.0	16.0
22		1.10							1.11	1.0	16.0
23		1.10							0.98	0.9	16.0
24		1.00							1.17	0.7	16.0
25	0.29	1.10	0.09	0.01		0.03			1.38	0.4	16.0
26		1.10							1.24	1.0	16.0
27		1.20							1.21	0.9	16.0
28		1.20							1.11	0.1	16.0
29		1.10							1.10	0.0	16.0
30		1.10							0.98	0.0	16.0
31											
AVERAGE	0.26	1.17	0.11	0.01	#DIV/0!	0.03	#DIV/0!	#DIV/0!	Monthly Minimum:	Total Rainfall	16.0
									0.98		
									Number of readings	30	12.19
									For Free Chlorine, # less than 0.2 mg/L	0	
									For Chloramines, # less than 0.5 mg/L		

Disinfectant Chloramines? (Y/N)

N

KENTUCKY DIVISION OF WATER - DRINKING WATER BRANCH  
 WATER TREATMENT PLANT - MONTHLY OPERATING REPORT

APPLICABLE TO ALL PLANTS WITH FILTRATION

PWS ID : KY0210067  
 PLANT ID : A  
 REPORT MONTH/YEAR: 04/2011  
 PAGE 6 OF 11

DAY	FILTER OPERATION										
	TOTAL WASH WATER	No: 1		No: 2		No:		No:		No:	
	GALLONS	AREA (square foot) WASHWATER GALLONS	FILT RUN HRS	AREA (square foot) WASHWATER GALLONS	FILT RUN HRS	AREA (square foot) WASHWATER GALLONS	FILT RUN HRS	AREA (square foot) WASHWATER GALLONS	FILT RUN HRS	AREA (square foot) WASHWATER GALLONS	FILT RUN HRS
1	48,000	48,000	11.90		12.40						
2	0		11.80		11.80						
3	0		11.60		11.60						
4	0		12.10		12.10						
5	52,800	52,800	12.00		12.50						
6	0		11.10		11.10						
7	0		12.50		12.50						
8	0		12.10		12.10						
9	132,000	60,000	13.50	72,000	13.50						
10	72,000	36,000	13.10	36,000	13.10						
11	0		12.30		12.30						
12	48,000		11.80	48,000	11.30						
13	48,000	48,000	12.10		12.60						
14	0		12.00		12.00						
15	52,800		12.80	52,800	12.30						
16	0		11.30		11.30						
17	0		12.70		12.70						
18	48,000		12.80	48,000	12.30						
19	50,400	50,400	11.60		12.10						
20	60,000	60,000	14.00		14.50						
21	96,000		14.00	96,000	13.50						
22	72,000	72,000	12.20		12.70						
23	0		12.10		12.10						
24	0		11.50		11.50						
25	0		12.20		12.20						
26	52,800		13.10	52,800	12.60						
27	0		12.60		12.60						
28	0		11.50		11.50						
29	48,000	48,000	12.60		13.10						
30	0		12.00		12.00						
31	0										
TOTAL	880,800	475,200	368.90	405,600	369.90	0	0.00	0	0.00	0	0.00
AVERAGE	28,413	52,800	12.297	57,943	12.330	#DIV/0!	#DIV/0!	#DIV/0!	#DIV/0!	#DIV/0!	#DIV/0!

COPY AS NEEDED

KENTUCKY DIVISION OF WATER - DRINKING WATER BRANCH  
 WATER TREATMENT PLANT - MONTHLY OPERATING REPORT

PWS ID: KY0210067  
 PLANT ID: A

ALL WATER SYSTEMS

REPORT MONTH/YEAR: 04/2011

PAGE 7 OF 11

DAY	CHEMICALS ADDED			DISTRIBUTION SYSTEM OPERATION							
	CHLORINE BOOSTER LBS	CHLORINE BOOSTER LBS		TEST RESULTS							
				TOTAL (T) AND FREE (F) CHLORINE RESIDUAL (ppm)							
				NORTH		SOUTH		EAST		WEST	
T	F	T	F	T	F	T	F				
1					1.20		1.00				
2								1.10			1.30
3					1.30		1.00				
4								0.70			1.20
5					1.10		0.70				
6								0.90			1.40
7					1.20		1.20				
8								1.00			1.20
9					1.30		1.00				
10								0.90			1.30
11					1.20		0.90				
12								0.90			1.00
13					1.20		0.90				
14								1.00			1.20
15					1.20		1.00				
16								0.90			1.00
17					1.10		0.80				
18								0.90			1.20
19					1.30		0.90				
20								0.50			1.20
21					1.21		1.00				
22								1.10			1.30
23					1.10		0.90				
24								0.80			0.90
25					1.20		0.90				
26								1.10			1.50
27					1.10		0.90				
28								1.20			1.30
29					1.20		0.90				
30								0.80			0.90
31											
AVERAGE	#DIV/0!	#DIV/0!	Average	#DIV/0!	1.19	#DIV/0!	0.93	#DIV/0!	0.92	#DIV/0!	1.19
TOTAL	0.0	0.0	Total Minimum Free Minimum		1.10		0.70		0.50		0.90

Total # Chlorine Samples	0	15	0	15	0	15	0	15
# Less than 0.2 mg/L/0.5 mg/L	0	0	0	0	0	0	0	0

Number of Free Residuals	00	Minimum Monthly Free Residual	0.50	Disinfectant Chloramines? (Y/N)	N
Number of Total Residuals	0	Minimum Monthly Total Residual	0.00	Number of days of operation?	30
Total # Less than 0.2 mg/L	0				
Total # Less than 0.5 mg/L					

KENTUCKY DIVISION OF WATER - DRINKING WATER BRANCH  
 WATER TREATMENT PLANT - MONTHLY OPERATING REPORT

PWS ID : KY0210067

PLANT ID: A

TURBIDITY REPORT

APPLICABLE TO ALL PLANTS WITH FILTRATION

Report Period (MM/YYYY): 04/2011

PAGE: 8 OF 11

PWS Name: Carrollton Utilities

DAY	Hours Plant Operated	# of Turbidity Samples Required	Mid - 4 am	4 am - 8 am	8 am - Noon	Noon - 4 pm	4 pm - 8 pm	8 pm - Mid	Daily Maximum	
1	12.4	4		0.06	0.06	0.06	0.06		0.060	
2	11.8	3			0.06	0.05	0.05		0.060	
3	11.6	3			0.05	0.05	0.05		0.050	
4	12.1	4		0.05	0.05	0.05	0.06		0.060	
5	12.5	4		0.06	0.06	0.06	0.06		0.060	
6	11.1	3			0.07	0.06	0.05		0.070	
7	12.5	4		0.05	0.05	0.08	0.09		0.090	
8	12.1	4		0.06	0.06	0.08	0.07		0.080	
9	14.0	4		0.08	0.08	0.07	0.08		0.080	
10	13.6	4		0.10	0.10	0.09	0.09		0.100	
11	12.3	4		0.08	0.08	0.08	0.09		0.090	
12	11.8	3			0.08	0.07	0.07		0.080	
13	12.6	4		0.08	0.08	0.08	0.09		0.090	
14	12.0	3			0.07	0.07	0.06		0.070	
15	12.8	4		0.06	0.06	0.06	0.06		0.060	
16	11.3	3			0.06	0.07	0.06		0.074	
17	12.7	4		0.07	0.07	0.06	0.07		0.070	
18	12.8	4		0.06	0.06	0.07	0.06		0.070	
19	12.1	4		0.05	0.05	0.05	0.05		0.050	
20	14.5	4		0.08	0.08	0.08	0.08		0.080	
21	14.0	4		0.10	0.10	0.10	0.10		0.100	
22	12.7	4		0.07	0.07	0.07	0.06		0.070	
23	12.1	4		0.07	0.07	0.07	0.06		0.070	
24	11.5	3			0.07	0.07	0.06		0.070	
25	12.2	4		0.05	0.05	0.05	0.06		0.060	
26	13.1	4		0.06	0.06	0.05	0.05		0.060	
27	12.6	4		0.06	0.06	0.06	0.05		0.060	
28	11.5	3			0.06	0.06	0.06		0.060	
29	13.1	4		0.06	0.06	0.05	0.06		0.060	
30	12.0	3			0.06	0.05	0.05		0.060	
31	0.0	0							0.000	
<b>Total</b>	<b>373.4</b>	<b>111</b>	TOTAL # OF TURBIDITY SAMPLES TAKEN -						<b>111</b>	<b>0.100</b>

ARE YOU USING EITHER CONVENTIONAL or DIRECT FILTRATION? (Y/N)  Y

(Any type of filtration besides slow sand)

Number of samples exceeding --> 0.1 NTU 0 0.3 NTU 0 1 NTU 0

For slow sand filtration, the number of samples exceeding --> 1 NTU          5 NTU         

\*NOTE: The "Number of Turbidity Samples Required" is the number of hours the plant operated divided by 4 rounded up to the next whole number.

I certify that the above turbidity readings were taken every 4 hours during plant operation and in the time frames noted above.

Franklin J. He  
 Signature of Principal Executive Officer or Authorized Agent

5/2/11  
 Date

**KENTUCKY DIVISION OF WATER - DRINKING WATER BRANCH  
WATER TREATMENT PLANT - MONTHLY OPERATING REPORT**

**APPLICABLE TO ALL SURFACE WATER PLANTS WITH FILTRATION**

**INDIVIDUAL FILTER TURBIDITY EXCEEDANCE REPORT**

PWS Name: Carrollton Utilities  
PWS ID: KY0210067  
PLANT ID: A  
Report Period (MM/YYYY): 04/2011

If any filter exceeded any one of the individual filter turbidity triggers below, (also listed on the Summary Sheet), complete the following and submit the appropriate report(s).

Date	Filter Number	Turbidity Reading (NTU)	Trigger Level (See below)	Reason for Exceedance (if known)	Date and Time State was Contacted

- Trigger Levels:**
- A. Any one filter has a measured turbidity level of greater than 1.0 NTU in 2 consecutive measurements taken 15 minutes apart.
  - B. Any one filter has a measured turbidity level of greater than 0.5 NTU in 2 consecutive measurements taken 15 minutes apart at the end of the first 4 hours of operation following a backwash or return to service.
  - C. Any one filter has a measured turbidity level of greater than 1.0 NTU in 2 consecutive measurements taken 15 minutes apart at any time in each of 3 consecutive months.
  - D. Any one filter has a measured turbidity level of greater than 2.0 NTU in 2 consecutive measurements taken 15 minutes apart at any time in each of 2 consecutive months.

**Report Required:**

**For Trigger A.:** Filter number, the turbidity measurement, the date of exceedance and filter profile within 7 days of the exceedance, if no obvious reason for the exceedance

**For Trigger B.:** Filter number, the turbidity measurement, the date of exceedance and filter profile within 7 days of the exceedance, if no obvious reason for the exceedance

**For Trigger C.:** Filter number, the turbidity measurement, the date of exceedance and a filter self-assessment within 14 days of the exceedance

**For Trigger D.:** Filter number, the turbidity measurement, the date of exceedance and arrange for a Comprehensive Performance Evaluation (CPE) with the Drinking Water Branch no later than 30 days following the exceedance

**MAKE COPIES AS NEEDED**



**KENTUCKY DIVISION OF WATER / DRINKING WATER BRANCH**  
**MONTHLY OPERATING REPORT (MOR) PLANT SUMMARY FORM**

PWS ID

KY0210067

MONITORING PERIOD (MMYYYY)

04/2011

**NOTE: COMPLETE ALL APPLICABLE FIELDS!!! NOT ALL OF THE FIELDS ARE PRE-POPULATED FOR YOU!!!**

PLANT INFORMATION APPLICABLE TO ALL PLANTS			
PLANT ID	<u>A</u>	TOTAL WATER TREATED (gallons)	<u>22,971,000</u>
PLANT NAME	<u>Carrollton Water Treatment Plant</u>	AVE. DAILY PRODUCTION (gallons)	<u>765,700</u>
AGENCY INTEREST	<u>696</u>	MAXIMUM PUMPAGE (gallons per day)	<u>861,000</u>

INDIVIDUAL FILTER EFFLUENT TURBIDITY APPLICABLE TO ALL PLANTS WITH FILTRATION	
ANALYTE CODE	<u>0100</u>
Was each filter monitored continuously? (Y/N)	<input checked="" type="checkbox"/> Y
Were measurements recorded every 15 minutes? (Y/N)	<input checked="" type="checkbox"/> Y
Was there a failure of the continuous monitoring equipment? (Y/N)	<input type="checkbox"/> N
If Yes, (1) were individual filter effluent turbidity grab samples collected every four hours of operation? (Y/N)	<input checked="" type="checkbox"/> Y
(2) was the continuously monitoring equipment repaired within 5 working days? (Y/N)	<input type="checkbox"/>
Was individual filter level greater than 1.0 NTU in two consecutive measurements? (Y/N)	<input type="checkbox"/> N
Was individual filter level greater than 0.5 NTU in two consecutive measurements after on line for more than four hours? (Y/N)	<input type="checkbox"/> N
Was individual filter level greater than 1.0 NTU in two consecutive measurements in three consecutive months? (Y/N)	<input type="checkbox"/> N
Was individual filter level greater than 2.0 NTU in two consecutive measurements in two consecutive months? (Y/N)	<input type="checkbox"/> N
<b>If any of the last 4 boxes are YES, fill out the Individual Filter Turbidity Sheet and submit with the MOR</b>	

COMBINED FILTER EFFLUENT TURBIDITY APPLICABLE TO ALL PLANTS WITH FILTRATION	ENTRY POINT RESIDUAL DISINFECTANT CONCENTRATION APPLICABLE TO ALL PLANTS
ANALYTE CODE	<u>0100</u>
Number of hours of plant operation	<u>373.4</u>
Were samples taken every 4 hours of plant operation? (Y/N)	<input checked="" type="checkbox"/> Y
Number of samples taken	<u>111</u>
Highest single turbidity reading	<u>0.10</u>
For all filtration except slow sand filtration:	
Number of samples exceeded 0.1 NTU	<u>0</u>
Number of samples exceeded 0.3 NTU	<u>0</u>
Number of samples exceeded 1 NTU	<u>0</u>
When filtration is slow sand filtration:	
Number of samples exceeded 1 NTU	
Number of samples exceeded 5 NTU	
	ANALYTE CODE
	<u>0999</u>
	Number of days of plant operation
	<u>30</u>
	Were samples taken each day of operation? (Y/N)
	<input checked="" type="checkbox"/> Y
	Number of lowest chlorine samples recorded
	<u>30</u>
	Lowest single chlorine reading
	<u>0.98</u>
	If less than required:
	Was residual restored within 4 hours of plant operation? (Y/N)
	<input type="checkbox"/>
	Free Chlorine (for all disinfectants except chloramine):
	Number of samples under 0.2 mg/L
	<u>0</u>
	Total Chlorine (when disinfectant is Chloramine):
	Number of samples under 0.5 mg/L

CHLORINE DIOXIDE ENTRY POINT MONITORING APPLICABLE TO PLANTS UTILIZING CHLORINE DIOXIDE	CHLORITE ENTRY POINT MONITORING APPLICABLE TO PLANTS UTILIZING CHLORINE DIOXIDE
ANALYTE CODE	<u>1008</u>
Number of days of plant operation	<u>30</u>
Were samples taken each day of operation? (Y/N)	<input type="checkbox"/>
Number of samples taken	<u>0</u>
Highest single chlorine dioxide reading	<u>0.00</u>
Number of chlorine dioxide samples exceeded 0.8 mg/L	<u>0</u>
	ANALYTE CODE
	<u>1009</u>
	Number of days of plant operation
	<u>30</u>
	Were samples taken each day of operation? (Y/N)
	<input type="checkbox"/>
	Number of samples taken
	<u>0</u>
	Highest single chlorite reading
	<u>0.00</u>
	Number of chlorite samples exceeded 1 mg/L
	<u>0</u>

I certify under penalty of law that I have personally examined and am familiar with the information submitted herein. Based on my inquiry of those individuals immediately responsible for obtaining the information, the submitted information is true, accurate and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment. Violations of 401 KAR Chapter 8 are subject to severe penalties prescribed in KRS 224.99-010, up to \$25,000 fine per day per violation and in some cases a violation may subject the violator to prison.

Franklin J. Hines  
 Signature of Principal Executive Officer or Authorized Agent

05/02/11

Date

KENTUCKY DIVISION OF WATER / DRINKING WATER BRANCH  
MONTHLY OPERATING REPORT (MOR) SUMMARY FORM

PWS ID       KY0210067        
AI       696      

MONITORING PERIOD (MMYYYY) **04/2011**

NOTE: COMPLETE ALL APPLICABLE FIELDS!!! NOT ALL OF THE FIELDS ARE PRE-POPULATED FOR YOU!!!

PURCHASED		SOLD	
APPLICABLE TO ALL WATER SYSTEMS			
FROM WHOM? (PWS ID)	HOW MUCH? (gallons)	TO WHOM? (PWS ID)	HOW MUCH? (gallons)
		KY0210008	4,933,015
		KY0210066	0

DISTRIBUTION RESIDUAL DISINFECTANT CONCENTRATION APPLICABLE TO ALL WATER SYSTEMS			
ANALYTE CODE <u>      0999      </u>			
Number of days of operation _____	<u>      30      </u>	<u>Free Chlorine</u> (for all disinfectants except chloramine)	
Were samples taken each day of operation? (Y/N) _____	<input checked="" type="checkbox"/>	Number of samples under 0.2 mg/L _____	<u>      0      </u>
Number of samples taken:		<u>Total Chlorine</u> (when disinfectant is chloramine)	
FREE _____	<u>      60      </u>	Number of samples under 0.5 mg/L _____	
TOTAL _____	<u>      0      </u>		
Lowest single FREE chlorine reading _____	<u>      0.50      </u>		
Lowest single TOTAL chlorine reading _____	<u>      0.00      </u>		

I certify under penalty of law that I have personally examined and am familiar with the information submitted herein. Based on my inquiry of those individuals immediately responsible for obtaining the information, the submitted information is true, accurate and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment. Violations of 401 KAR Chapter 8 are subject to severe penalties prescribed in KRS 224.99-010, up to \$25,000 fine per day per violation and in some cases a violation may subject the violator to prison.

                                Franklin Harmon III  05/02/11  
Signature of Principal Executive Officer or Authorized Agent                                Date



**KENTUCKY DIVISION OF WATER**  
**DRINKING WATER BRANCH**  
**MONTHLY OPERATION REPORT (MOR)--ALL WATER SYSTEMS**

Revised 01/04/07

MONTH & YEAR (mm/yyyy) 07/2011      Indicate one with "X"  SURFACE WATER  
 GROUNDWATER  
 PURCHASE/DISTRIBUTE ONLY

DEP Form 4012--Revised 07/2006

PWS ID :	KY0210067	PLANT ID: A	PLANT NAME:	Carrollton Water Treatment Plant
PWS NAME:	Carrollton Utilities	PLANT CLASS:	III	DIST. CLASS: II
AGENCY INTEREST (AI):	696	DATE MAILED:	8/5/2011	
SOURCE NAME:	Ohio River Alluvial Aquifer	COUNTY:	Carroll	
OPERATOR(S) RESPONSIBLE / IN-CHARGE		CLASS	CERTIFICATION NUMBER	
WTP SHIFT 1:	Franklin W. Thieman II	IIIA	19184	
WTP SHIFT 2:	Chris Rose	IIIA	19857	
WTP SHIFT 3:				
DISTRIBUTION:	Larry Hayes	IID	9662	

**THIS REPORT MUST BE RECEIVED BY THE DIVISION OF WATER AND APPLICABLE FIELD OFFICE  
NO LATER THAN 10 DAYS AFTER THE END OF THE MONTH.**

**TREATMENT PLANTS COMPLETE:**

1. DESIGN CAPACITY (gpm):	1040 gpm
2. TYPE OF FILTRATION USED:	Mixed Media
3. DESIGN FILTRATION RATE (gpm/sq. ft.):	Not to exceed 5gpm/sq.ft.
4. PERCENT BACKWASH WATER USED:	1.8
5. DATE FLOCCULATION BASIN(S) LAST CLEANED:	7/13/2011
6. DATE SETTLING BASIN(S) LAST CLEANED:	Claricone Unit

I certify under penalty of law that I have personally examined and am familiar with the information submitted herein. Based on my inquiry of those individuals immediately responsible for obtaining the information, I believe the submitted information is true, accurate and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment. See KRS 224.99-010 and 401 KAR 8:020. (Penalties under this statute and regulation may include fines up to \$25,000 per violation or by imprisonment for not more than one year, or both).

Franklin W. Thieman II  
SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT

8/3/2011  
DATE

KENTUCKY DIVISION OF WATER - DRINKING WATER BRANCH  
 WATER TREATMENT PLANT - MONTHLY OPERATING REPORT

PWS ID : KY0210057

PLANT ID: A

REPORT MONTH/YEAR: 07/2011

PAGE 1 OF 11

APPLICABLE TO ALL PLANTS

DAY	RAW WATER TREATED GALLONS	HOURS PLANT OPERATED	COAGULANT		COAGULANT Polymer		pH ADJUSTMENT CaO Lime		DISINFECTANT Cl2 Chlorine		DISINFECTANT	
			LBS	PPM	LBS	PPM	Pre		Pre		Post	
							LBS	PPM	LBS	PPM	LBS	PPM
1	839,000	13.1			221.0	31.6	1925.0	275.1	13.0	1.9		
2	906,000	14.1			238.0	31.5	2072.0	274.2	20.0	2.6		
3	734,000	12.7			215.0	35.1	1767.0	288.7	22.0	3.6		
4	786,000	12.7			215.0	32.8	1651.0	251.9	9.0	1.4		
5	856,000	13.5			228.0	31.9	1715.0	240.2	16.0	2.2		
6	820,000	13.0			219.0	32.0	1651.0	241.4	11.0	1.6		
7	825,000	13.1			222.0	32.3	1794.0	260.7	20.0	2.9		
8	833,000	13.3			225.0	32.4	1795.0	258.4	16.0	2.3		
9	735,000	11.9			201.0	32.8	1547.0	252.4	11.0	1.8		
10	839,000	13.5			228.0	32.6	1634.0	233.5	8.0	1.1		
11	908,000	14.9			252.0	33.3	1743.0	230.2	15.0	2.0		
12	887,000	14.1			238.0	32.2	1649.0	222.9	13.0	1.8		
13	795,000	12.7			214.0	32.3	1587.0	239.4	27.0	4.1		
14	894,000	14.2			240.0	32.2	2059.0	276.2	20.0	2.7		
15	878,000	14.2			240.0	32.8	1846.0	252.1	19.0	2.6		
16	937,000	15.0			254.0	32.5	1755.0	224.6	9.0	1.2		
17	853,000	13.7			232.0	32.6	1671.0	234.9	15.0	2.1		
18	854,000	13.3			225.0	31.6	1622.0	227.7	15.0	2.1		
19	960,000	15.3			258.0	32.2	2218.0	277.0	18.0	2.2		
20	853,000	13.3			225.0	31.6	1689.0	237.4	18.0	2.5		
21	890,000	14.3			242.0	32.6	1816.0	244.7	20.0	2.7		
22	905,000	14.5			245.0	32.5	1697.0	224.8	10.0	1.3		
23	963,000	15.5			262.0	32.6	1891.0	235.5	16.0	2.0		
24	901,000	14.3			241.0	32.1	1744.0	232.1	12.0	1.6		
25	928,000	14.2			240.0	31.0	1917.0	247.7	22.0	2.8		
26	965,000	15.2			257.0	31.9	2006.0	249.3	18.0	2.2		
27	859,000	13.9			235.0	32.8	1835.0	256.1	13.0	1.8		
28	955,000	15.4			261.0	32.8	1879.0	235.9	12.0	1.5		
29	975,000	15.8			267.0	32.8	1928.0	237.1	13.0	1.6		
30	884,000	14.0			236.0	32.0	1708.0	231.7	14.0	1.9		
31	886,000	14.1			238.0	32.2	1861.0	251.9	30.0	4.1		
TOTAL	27,103,000		0.0		7314.0		55672.0		495.0		0.0	
AVERAGE	874,290		#DIV/0!	#DIV/0!	235.9	32.4	1795.9	246.6	16.0	2.2	#DIV/0!	#DIV/0!
MAX	975,000											



KENTUCKY DIVISION OF WATER - DRINKING WATER BRANCH  
 WATER TREATMENT PLANT - MONTHLY OPERATING REPORT

PWS ID: KY0210067  
 PLANT ID: A

**APPLICABLE TO ALL PLANTS**

REPORT MONTH/YEAR: 07/2011

PAGE 3 OF 11

ANALYTICAL RESULTS (mg/L OR PPM UNLESS OTHERWISE SPECIFIED)														
DAY	pH			TOTAL ALKALINITY		TOTAL HARDNESS		CHLORINE RESIDUAL				TURBIDITY (NTU)		
	RAW	TOP OF FILTER	TAP	RAW	TAP	RAW	TAP	TOP OF FILTER		PLANT TAP		RAW	SETTLED WATER	PLANT TAP
								TOTAL	FREE	TOTAL	FREE			
1	7.00	8.30	7.80				166				0.90	0.03		0.03
2	6.90	8.40	7.80				170				1.20	0.02		0.02
3	6.90	8.50	7.90				174				1.30	0.03		0.02
4	7.00	8.50	8.00		70	440	180				1.50	0.03		0.02
5	7.00	8.40	8.00				170				1.10	0.02		0.02
6	7.00	8.40	8.00				170				1.00	0.02		0.02
7	7.00	8.50	8.00				164				1.00	0.02		0.03
8	6.90	8.50	8.10				180				1.20	0.02		0.04
9	6.90	8.40	7.90				184				1.00	0.02		0.02
10	7.00	8.70	8.40				178				1.30	0.02		0.10
11	7.00	8.70	8.10		62	430	184				1.20	0.02		0.02
12	7.00	8.50	8.10				170				1.20	0.02		0.02
13	6.90	8.70	7.90				176				1.10	0.03		0.02
14	6.80	7.80	7.90				188				0.90	0.03		0.02
15	7.00	8.20	7.60				186				1.10	0.04		0.02
16	7.00	8.30	8.00				184				1.20	0.02		0.02
17	7.00	8.70	7.90				178				1.20	0.02		0.02
18	7.00	8.60	8.00		68	420	170				1.10	0.02		0.02
19	6.90	8.50	7.90				174				1.00	0.03		0.02
20	6.80	8.60	8.00				170				1.30	0.03		0.02
21	7.00	8.10	8.00				174				1.00	0.03		0.02
22	7.00	8.10	7.90				186				1.20	0.05		0.02
23	7.00	8.60	7.80				190				1.00	0.02		0.02
24	7.00	8.40	7.90				170				1.10	0.02		0.02
25	6.80	8.20	7.80		74	466	182				1.10	0.02		0.02
26	6.90	8.60	8.00				184				1.00	0.02		0.02
27	6.90	8.50	7.90				174				0.70	0.02		0.03
28	7.00	8.30	8.00				180				1.00	0.02		0.02
29	7.00	8.60	8.00				168				1.20	0.02		0.02
30	7.10	8.60	8.10				170				1.10	0.02		0.02
31	6.90	8.40	7.90				174				1.00	0.03		0.02
AVERAGE	7.0	8.4	8.0	#DIV/0!	69	439	176	#DIV/0!	#DIV/0!	#DIV/0!	1.10	0.02	#DIV/0!	0.02



KENTUCKY DIVISION OF WATER - DRINKING WATER BRANCH  
 WATER TREATMENT PLANT - MONTHLY OPERATING REPORT

PWSID: KY0210067  
 PLANT ID: A

APPLICABLE TO ALL PLANTS

REPORT MONTH/YEAR: 07/2011

\*Please answer Y/N question below this chart.

PAGE 5 OF 11

ANALYTICAL RESULTS (mg/L OR PPM UNLESS OTHERWISE SPECIFIED)											RAINFALL INCHES	WATER TEMP. DEGREES F <sup>0</sup> /C <sup>0</sup>	
DAY	FLUORIDE		IRON		MANGANESE				Lowest Daily Chlorine Residual Plant Tap On-Line Chlorine Analyzer	FREE / TOTAL			
	RAW	TAP	RAW	TAP	RAW	TAP	RAW	TAP					
1		1.00								0.62	0.0	16.0	
2		1.10								1.27	0.0	16.0	
3		1.20								1.14	0.2	16.0	
4	0.02	1.30	0.08	0.02		0.08				1.21	0.2	16.0	
5		1.50								1.21	0.0	16.0	
6		1.30								1.18	0.0	16.0	
7		1.20								1.00	0.6	16.0	
8		1.20								1.23	0.0	16.0	
9		1.00								1.00	0.5	16.0	
10		1.10								0.91	0.0	16.0	
11	0.40	1.00	0.15	0.02		0.03				1.10	0.0	16.0	
12		1.10								1.15	0.0	16.0	
13		1.00								1.04	0.0	16.0	
14		1.00								0.90	0.0	16.0	
15		1.00								1.14	0.0	16.0	
16		1.20								1.09	0.0	16.0	
17		1.40								1.11	0.0	16.0	
18	0.30	1.10	0.13	0.02		0.02				1.14	0.0	16.0	
19		1.30								1.08	0.8	16.0	
20		1.20								1.30	0.0	16.0	
21		1.30								1.15	0.0	16.0	
22		1.30								1.15	0.0	16.0	
23		1.10								1.15	0.0	16.0	
24		1.20								1.09	0.0	16.0	
25	0.30	1.30	0.15	0.05		0.02				1.17	0.0	16.0	
26		1.20								1.00	0.0	16.0	
27		1.10								1.10	0.0	16.0	
28	0.40	1.20								1.22	0.0	16.0	
29	0.40	1.20								1.17	0.0	16.0	
30	0.40	1.20								1.20	0.0	16.0	
31	0.33	0.90								1.05	0.0	16.0	
AVERAGE	0.32	1.17	0.12	0.03	#DIV/0!	0.04	#DIV/0!	#DIV/0!	#DIV/0!	Monthly Minimum	0.62	2.23	16.0

Number of readings	31
For Free Chlorine. # less than 0.2 mg/L	0
For Chloramines. # less than 0.5 mg/L	

Disinfectant Chloramines? (Y/N) **N**

Ground Water Rule Minimum Chlorine Residual Report Form

PWSID: KY0210067

PLANT ID: A

REPORT MONTH/YEAR: 07/2011

**APPLICABLE TO ALL PLANTS**

\*Please answer questions below this chart.

PAGE 5 OF 11

ANALYTICAL RESULTS (mg/L OR PPM UNLESS OTHERWISE SPECIFIED)	
DAY	Lowest Daily Chlorine Residual Plant Tap On-Line Chlorine Analyzer FREE / TOTAL
1	0.62
2	1.27
3	1.14
4	1.21
5	1.21
6	1.18
7	1.00
8	1.23
9	1.00
10	0.91
11	1.10
12	1.15
13	1.04
14	0.90
15	1.14
16	1.09
17	1.11
18	1.14
19	1.08
20	1.30
21	1.15
22	1.15
23	1.15
24	1.09
25	1.17
26	1.00
27	1.10
28	1.22
29	1.17
30	1.20
31	1.05
AVERAGE	Monthly Minimum
	0.62

Number of Days of Plant Operation?

Required Ground Water Minimum Chlorine Residual?

Disinfectant Chloramines? (Y/N)

Number of readings	31
Ground Water Systems For Free Chlorine # less than minimum	

KENTUCKY DIVISION OF WATER - DRINKING WATER BRANCH  
 WATER TREATMENT PLANT - MONTHLY OPERATING REPORT

APPLICABLE TO ALL PLANTS WITH FILTRATION

PWS ID: KY0210067

PLANT ID: A

REPORT MONTH/YEAR: 07/2011

PAGE 6 OF 11

DAY	TOTAL WASH WATER GALLONS	FILTER OPERATION									
		No: 1		No: 2		No:		No:		No:	
		AREA (square feet)	FLT RUN HRS	AREA (square feet)	FLT RUN HRS	AREA (square feet)	FLT RUN HRS	AREA (square feet)	FLT RUN HRS	AREA (square feet)	FLT RUN HRS
1	48,000	48,000	12.60		13.10						
2	0		14.10		14.10						
3	0		12.70		12.70						
4	0		12.70		12.70						
5	55,200		13.50	55,200	13.00						
6	0		13.00		13.00						
7	0		13.10		13.10						
8	43,200	43,200	12.80		13.30						
9	0		11.90		11.90						
10	0		13.50		13.50						
11	48,000		14.90	48,000	14.40						
12	0		14.10		14.10						
13	0		12.70		12.70						
14	0		14.20		14.20						
15	52,800	52,800	13.70		14.20						
16	55,200		15.00	55,200	14.50						
17	0		13.70		13.70						
18	0		13.30		13.30						
19	0		15.30		15.30						
20	48,000	48,000	12.80		13.30						
21	0		14.30		14.30						
22	48,000	48,000	14.00		14.50						
23	0		15.50		15.50						
24	0		14.30		14.30						
25	0		14.20		14.20						
26	48,000		15.20	48,000	14.70						
27	0		13.90		13.90						
28	0		15.40		15.40						
29	48,000	48,000	15.30		15.80						
30	0		14.00		14.00						
31	0		14.10		14.10						
TOTAL	494,400	288,000	429.80	206,400	430.80	0	0.00	0	0.00	0	0.00
AVERAGE	15,948	48,000	13.865	51,600	13.897	#DIV/0!	#DIV/0!	#DIV/0!	#DIV/0!	#DIV/0!	#DIV/0!

COPY AS NEEDED



KENTUCKY DIVISION OF WATER - DRINKING WATER BRANCH  
 WATER TREATMENT PLANT - MONTHLY OPERATING REPORT

PWS ID : KY0210067

PLANT ID : A

REPORT MONTH/YEAR: 07/2011

ALL WATER SYSTEMS

PAGE 7 OF 11

DAY	DISTRIBUTION SYSTEM OPERATION											
	CHEMICALS ADDED			TEST RESULTS								
	CHLORINE BOOSTER	CHLORINE BOOSTER		TOTAL (T) AND FREE (F) CHLORINE RESIDUAL (ppm)								
				NORTH		SOUTH		EAST		WEST		
LBS	LBS		T	F	T	F	T	F	T	F		
1									0.60		0.60	
2					1.10		0.90					
3									0.80		0.90	
4					1.70		1.00					
5									1.30		1.30	
6					1.00		0.90		0.75		0.95	
7									0.80		0.90	
8					1.20		0.90					
9									0.90		1.00	
10					1.40		1.10					
11									1.00		1.20	
12					1.20		1.20					
13									0.70		0.60	
14					0.80		0.90					
15									0.80		0.90	
16					1.20		0.70					
17									1.20		1.00	
18					0.90		1.30					
19									1.00		0.80	
20					1.20		0.80		0.54		0.86	
21									0.70		0.90	
22					1.10		0.70					
23									1.00		1.00	
24					1.10		1.00					
25									0.80		0.90	
26					1.00		0.80					
27									0.90		1.00	
28					1.00		1.00					
29									1.00		1.00	
30					1.20		0.70					
31									1.00		0.90	
AVERAGE	#DIV/0!	#DIV/0!	Average	#DIV/0!	1.14	#DIV/0!	0.91	#DIV/0!	0.87	#DIV/0!	0.93	
TOTAL	0.0	0.0	Total Minimum Free Minimum		0.80		0.70		0.54		0.60	

Number of Free Residuals	66	Minimum Monthly Free Residual	0.54
Number of Total Residuals	0	Minimum Monthly Total Residual	0.00
Total # Less than 0.2 mg/L	0		
Total # Less than 0.5 mg/L			

Total # Chlorine Samples	0	15	0	15	0	18	0	16
# Less than 0.2 mg/L/0.5 mg/L	0	0	0	0	0	0	0	0

Disinfectant Chloramines? (Y/N) **N**  
 Number of days of operation? **31**

KENTUCKY DIVISION OF WATER - DRINKING WATER BRANCH  
 WATER TREATMENT PLANT - MONTHLY OPERATING REPORT

PWS ID : KY0210067

PLANT ID : A

**TURBIDITY REPORT**

**APPLICABLE TO ALL PLANTS WITH FILTRATION**

Report Period (MM/YYYY): 07/2011

PAGE: 8 OF 11

PWS Name: Carrollton Utilities

DAY	Hours Plant Operated	# of Turbidity Samples Required*	Mid - 4 am	4 am - 8 am	8 am - Noon	Noon - 4 pm	4 pm - 8 pm	8 pm - Mid	Daily Maximum
1	13.1	4		0.03	0.03	0.02	0.02		0.030
2	14.1	4		0.02	0.02	0.03	0.03		0.030
3	12.7	4		0.03	0.03	0.03	0.03		0.030
4	12.7	4		0.03	0.03	0.08	0.03		0.080
5	13.5	4		0.02	0.02	0.10	0.02		0.100
6	13.0	4		0.02	0.02	0.02	0.02		0.020
7	13.1	4		0.03	0.03	0.03	0.02		0.030
8	13.3	4		0.04	0.04	0.04	0.02		0.040
9	11.9	3			0.02	0.03	0.02		0.030
10	13.5	4		0.10	0.10	0.07	0.02		0.100
11	14.9	4		0.02	0.02	0.06	0.02		0.060
12	14.1	4		0.02	0.02	0.02	0.02		0.020
13	12.7	4		0.02	0.02	0.03	0.03		0.030
14	14.2	4		0.02	0.02	0.03	0.03		0.030
15	14.2	4		0.02	0.02	0.04	0.03		0.040
16	15.0	4		0.02	0.02	0.02	0.02		0.020
17	13.7	4		0.02	0.02	0.02	0.02		0.020
18	13.3	4		0.02	0.02	0.02	0.02		0.021
19	15.3	4		0.02	0.02	0.02	0.02		0.020
20	13.3	4		0.02	0.02	0.03	0.02		0.030
21	14.3	4		0.02	0.02	0.02	0.02		0.020
22	14.5	4		0.05	0.05	0.02	0.02		0.050
23	15.5	4		0.02	0.02	0.02	0.02		0.020
24	14.3	4		0.02	0.02	0.02	0.02		0.020
25	14.2	4		0.02	0.02	0.02	0.02		0.020
26	15.2	4		0.02	0.02	0.03	0.03		0.030
27	13.9	4		0.03	0.03	0.02	0.02		0.030
28	15.4	4		0.03	0.03	0.02	0.02		0.030
29	15.8	4		0.02	0.02	0.02	0.02		0.020
30	14.0	4		0.02	0.02	0.02	0.02		0.020
31	14.1	4		0.02	0.02	0.02	0.02		0.020
Total	432.8	123						TOTAL # OF TURBIDITY SAMPLES TAKEN - 123	0.100

ARE YOU USING EITHER CONVENTIONAL or DIRECT FILTRATION? (Y/N) Y

(Any type of filtration besides slow sand)

Number of samples exceeding --> 0.1 NTU 0 0.3 NTU 0 1 NTU 0

For slow sand filtration, the number of samples exceeding --> 1 NTU \_\_\_\_\_ 5 NTU \_\_\_\_\_

\*NOTE: The "Number of Turbidity Samples Required" is the number of hours the plant operated divided by 4 rounded up to the next whole number.

I certify that the above turbidity readings were taken every 4 hours during plant operation and in the time frames noted above.

Franklin W. Pherson II  
 Signature of Principal Executive Officer or Authorized Agent

8/3/11  
 Date

APPLICABLE TO ALL SURFACE WATER PLANTS WITH FILTRATION

INDIVIDUAL FILTER TURBIDITY EXCEEDANCE REPORT

PWS Name: Carrollton Utilities  
PWS ID: KY0210067  
PLANT ID: A  
Report Period (MM/YYYY): 07/2011

If any filter exceeded any one of the individual filter turbidity triggers below,  
(also listed on the Summary Sheet ), complete the following and submit  
the appropriate report(s).

Date	Filter Number	Turbidity Reading (NTU)	Trigger Level (see below)	Reason for Exceedance (if known)	Date and Time State was Contacted

Trigger Levels:

- A. Any one filter has a measured turbidity level of greater than 1.0 NTU in 2 consecutive measurements taken 15 minutes apart.
- B. Any one filter has a measured turbidity level of greater than 0.5 NTU in 2 consecutive measurements taken 15 minutes apart at the end of the first 4 hours of operation following a backwash or return to service.
- C. Any one filter has a measured turbidity level of greater than 1.0 NTU in 2 consecutive measurements taken 15 minutes apart at any time in each of 3 consecutive months.
- D. Any one filter has a measured turbidity level of greater than 2.0 NTU in 2 consecutive measurements taken 15 minutes apart at any time in each of 2 consecutive months.

Report Required:

- For Trigger A.: Filter number, the turbidity measurement, the date of exceedance and filter profile within 7 days of the exceedance, if no obvious reason for the exceedance
- For Trigger B.: Filter number, the turbidity measurement, the date of exceedance and filter profile within 7 days of the exceedance, if no obvious reason for the exceedance
- For Trigger C.: Filter number, the turbidity measurement, the date of exceedance and a filter self-assessment within 14 days of the exceedance
- For Trigger D.: Filter number, the turbidity measurement, the date of exceedance and arrange for a Comprehensive Performance Evaluation (CPE) with the Drinking Water Branch no later than 30 days following the exceedance

MAKE COPIES AS NEEDED





# Ground Water Rule Minimum Chlorine Residual Report Form

PWS ID KY0210067


MONITORING PERIOD (MMYYYY) 07/2011

PLANT ID A

NOTE: COMPLETE ALL APPLICABLE FIELDS!!! NOT ALL OF THE FIELDS ARE PRE-POPULATED FOR YOU!!!



ENTRY POINT RESIDUAL DISINFECTANT CONCENTRATION	
APPLICABLE TO ALL PLANTS	
ANALYTE CODE	<u>0999</u>
Number of days of plant operation	31
Were samples taken each day of operation? (Y/N)	<input checked="" type="checkbox"/> Y
Number of lowest chlorine samples recorded	31
Lowest single chlorine reading	0.62
If less than required:	
Was residual restored within 4 hours of plant operation? (Y/N)	<input type="checkbox"/> N
Free Chlorine (for all disinfectants except chloramine):	
Number of samples under minimum residual	0
Total Chlorine (when disinfectant is Chloramine):	
Number of samples under 0.5 mg/L	0



I certify under penalty of law that I have personally examined and am familiar with the information submitted herein. Based on my inquiry of those individuals immediately responsible for obtaining the information, the submitted information is true, accurate and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment. Violations of 401 KAR Chapter 8 are subject to severe penalties prescribed in KRS 224.99-010, up to \$25,000 fine per day per violation and in some cases a violation may subject the violator to prison.

Franklin Johnson II  
Signature of Principal Executive Officer or Authorized Agent

08/03/11  
Date

**KENTUCKY DIVISION OF WATER / DRINKING WATER BRANCH  
MONTHLY OPERATING REPORT (MOR) PLANT SUMMARY FORM**

PWS ID KY0210067

MONITORING PERIOD (MMYYYY) 07/2011

**NOTE: COMPLETE ALL APPLICABLE FIELDS!!! NOT ALL OF THE FIELDS ARE PRE-POPULATED FOR YOU!!!**

PLANT INFORMATION APPLICABLE TO ALL PLANTS			
PLANT ID <u>A</u>	TOTAL WATER TREATED (gallons)	<u>27,103,000</u>	
PLANT NAME <u>Carrollton Water Treatment Plant</u>	AVE DAILY PRODUCTION (gallons)	<u>874,290</u>	
AGENCY INTEREST <u>696</u>	MAXIMUM PUMPAGE (gallons per day)	<u>975,000</u>	

INDIVIDUAL FILTER EFFLUENT TURBIDITY APPLICABLE TO ALL PLANTS WITH FILTRATION	
ANALYTE CODE <u>0100</u>	
Was each filter monitored continuously? (Y/N)	<input checked="" type="checkbox"/> Y
Were measurements recorded every 15 minutes? (Y/N)	<input checked="" type="checkbox"/> Y
Was there a failure of the continuous monitoring equipment? (Y/N)	<input type="checkbox"/> N
If Yes, (1) were individual filter effluent turbidity grab samples collected every four hours of operation? (Y/N)	<input checked="" type="checkbox"/> Y
(2) was the continuously monitoring equipment repaired within 5 working days? (Y/N)	<input type="checkbox"/>
Was individual filter level greater than 1.0 NTU in two consecutive measurements? (Y/N)	<input type="checkbox"/> N
Was individual filter level greater than 0.5 NTU in two consecutive measurements after on line for more than four hours? (Y/N)	<input type="checkbox"/> N
Was individual filter level greater than 1.0 NTU in two consecutive measurements in three consecutive months? (Y/N)	<input type="checkbox"/> N
Was individual filter level greater than 2.0 NTU in two consecutive measurements in two consecutive months? (Y/N)	<input type="checkbox"/> N
<b>If any of the last 4 boxes are YES, fill out the Individual Filter Turbidity Sheet and submit with the MOR</b>	

COMBINED FILTER EFFLUENT TURBIDITY APPLICABLE TO ALL PLANTS WITH FILTRATION	
ANALYTE CODE <u>0100</u>	
Number of hours of plant operation	<u>432.8</u>
Were samples taken every 4 hours of plant operation? (Y/N)	<input checked="" type="checkbox"/> Y
Number of samples taken	<u>123</u>
Highest single turbidity reading	<u>0.10</u>
For all filtration except slow sand filtration:	
Number of samples exceeded 0.1 NTU	<u>0</u>
Number of samples exceeded 0.3 NTU	<u>0</u>
Number of samples exceeded 1 NTU	<u>0</u>
When filtration is slow sand filtration:	
Number of samples exceeded 1 NTU	<u>0</u>
Number of samples exceeded 5 NTU	<u>0</u>

ENTRY POINT RESIDUAL DISINFECTANT CONCENTRATION APPLICABLE TO ALL PLANTS	
ANALYTE CODE <u>0999</u>	
Number of days of plant operation	<u>31</u>
Were samples taken each day of operation? (Y/N)	<input checked="" type="checkbox"/> Y
Number of lowest chlorine samples recorded	<u>31</u>
Lowest single chlorine reading	<u>0.62</u>
If less than required:	
Was residual restored within 4 hours of plant operation? (Y/N)	<input type="checkbox"/>
Free Chlorine (for all disinfectants except chloramine):	
Number of samples under 0.2 mg/L	<u>0</u>
Total Chlorine (when disinfectant is Chloramine):	
Number of samples under 0.5 mg/L	<u>0</u>

CHLORINE DIOXIDE ENTRY POINT MONITORING APPLICABLE TO PLANTS UTILIZING CHLORINE DIOXIDE	
ANALYTE CODE <u>1008</u>	
Number of days of plant operation	<u>31</u>
Were samples taken each day of operation? (Y/N)	<input type="checkbox"/>
Number of samples taken	<u>0</u>
Highest single chlorine dioxide reading	<u>0.00</u>
Number of chlorine dioxide samples exceeded 0.8 mg/L	<u>0</u>

CHLORITE ENTRY POINT MONITORING APPLICABLE TO PLANTS UTILIZING CHLORINE DIOXIDE	
ANALYTE CODE <u>1009</u>	
Number of days of plant operation	<u>31</u>
Were samples taken each day of operation? (Y/N)	<input type="checkbox"/>
Number of samples taken	<u>0</u>
Highest single chlorite reading	<u>0.00</u>
Number of chlorite samples exceeded 1 mg/L	<u>0</u>

I certify under penalty of law that I have personally examined and am familiar with the information submitted herein. Based on my inquiry of those individuals immediately responsible for obtaining the information, the submitted information is true, accurate and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment. Violations of 401 KAR Chapter 8 are subject to severe penalties prescribed in KRS 224.59-010, up to \$25,000 fine per day per violation and in some cases a violation may subject the violator to prison.

Franklin W. Hume II  
Signature of Principal Executive Officer or Authorized Agent

08/03/11  
Date



KENTUCKY DIVISION OF WATER

2011 SEP -8 PM 3:20

Revised 01/10/07

DRINKING WATER BRANCH

DIVISION OF WATER

MONTHLY OPERATION REPORT (MOR)--ALL WATER SYSTEMS

MONTH & YEAR (mm/yyyy)

08/2011

Indicate one with "X"

<input type="checkbox"/>	SURFACE WATER
<input checked="" type="checkbox"/>	GROUNDWATER
<input type="checkbox"/>	PURCHASE/DISTRIBUTE ONLY

DEP Form 4012--Revised 07/2006

PWS ID:	KVG210087	PLANT ID:	A	PLANT NAME:	Carrollton Water Treatment Plant
FWS NAME:	Carrollton Utilities	PLANT CLASS:	III	DIST. CLASS:	B
AGENCY INTEREST (AI):	696	DATE MAILED:	6/6/2011		
SOURCE NAME:	Ohio River Alluvial Aquifer	COUNTY:	Carroll		
OPERATOR(S) RESPONSIBLE / IN-CHARGE		CLASS	CERTIFICATION NUMBER		
WTP SHIFT 1:	Franklin W. Thieman II	BA	19184		
WTP SHIFT 2:	Chris Rose	BA	19857		
WTP SHIFT 3:					
DISTRIBUTION:	Larry Hayes	BD	9662		

THIS REPORT MUST BE RECEIVED BY THE DIVISION OF WATER AND APPLICABLE FIELD OFFICE NO LATER THAN 10 DAYS AFTER THE END OF THE MONTH.

TREATMENT PLANTS COMPLETE:

1. DESIGN CAPACITY (gpm):	1040 gpm
2. TYPE OF FILTRATION USED:	Mixed Media
3. DESIGN FILTRATION RATE (gpm/sq. ft.):	Not to exceed 5gpm/sq. ft.
4. PERCENT BACKWASH WATER USED:	1.6
5. DATE FLOCCULATION BASIN(S) LAST CLEANED:	7/13/2011
6. DATE SETTLING BASIN(S) LAST CLEANED:	Claricone Unit

I certify under penalty of law that I have personally examined and am familiar with the information submitted herein. Based on my inquiry of those individuals immediately responsible for obtaining the information, I believe the submitted information is true, accurate and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment. See KRS 224.20-010 and 401 KAR 9-020. (Penalties under this statute and regulation may include fines up to \$25,000 per violation or by imprisonment for not more than one year, or both).

Franklin W. Thieman II  
SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT

8/4/2011  
DATE



KENTUCKY DIVISION OF WATER - DRINKING WATER BRANCH  
 WATER TREATMENT PLANT - MONTHLY OPERATING REPORT

PWS ID: KY0210637

PLANT ID: A

REPORT MONTH/YEAR: 08/2011

PAGE 1 OF 11

APPLICABLE TO ALL PLANTS

DAY	RAW WATER TREATED GALLONS	HOURS PLANT OPERATED	COAGULANT		COAGULANT Polymer		PH ADJUSTMENT CaO Lime		DISINFECTANT Cl2 Chlorine		DISINFECTANT	
			LBS	PPM	LBS	PPM	LBS	PPM	Pre		Post	
									LBS	PPM	LBS	PPM
1	945,000	15.1			255.0	32.4	1963.0	249.1	20.0	2.5		
2	938,000	15.0			254.0	32.5	1950.0	249.3	13.0	1.7		
3	883,000	14.5			245.0	33.3	1813.0	246.2	13.0	1.8		
4	901,000	14.8			250.0	33.3	1850.0	246.2	14.0	1.9		
5	938,000	15.3			275.0	35.2	2097.0	260.4	20.0	2.6		
6	898,000	15.0			253.0	33.8	1950.0	260.4	20.0	2.7		
7	905,000	15.0			253.0	33.5	1850.0	253.4	20.0	2.6		
8	1,075,000	16.7			283.0	31.6	2184.0	243.6	21.0	2.3		
9	958,000	15.3			259.0	32.4	1836.0	229.8	19.0	2.4		
10	980,000	15.7			268.0	32.5	1837.0	224.8	18.0	2.2		
11	919,000	14.3			241.0	31.4	1673.0	218.3	15.0	2.0		
12	942,000	15.0			253.0	32.2	1950.0	248.2	12.0	1.5		
13	949,000	15.1			255.0	32.2	1963.0	248.0	15.0	1.9		
14	959,000	15.4			261.0	32.6	1956.0	244.6	15.0	1.9		
15	847,000	14.1			239.0	33.8	1660.0	233.6	13.0	1.8		
16	989,000	15.9			269.0	32.6	1860.0	225.5	14.0	1.7		
17	980,000	15.6			264.0	33.0	1872.0	233.8	18.0	2.2		
18	937,000	15.0			254.0	32.5	1950.0	249.5	18.0	2.3		
19	988,000	13.7			231.0	28.6	1793.0	222.1	20.0	2.5		
20	786,000	14.1			239.0	36.5	1791.0	273.2	12.0	1.6		
21	914,000	15.0			254.0	33.3	1805.0	249.9	11.0	1.4		
22	1,138,000	18.2			308.0	32.5	2368.0	249.3	19.0	2.0		
23	1,032,000	16.2			274.0	31.8	2106.0	244.7	19.0	2.2		
24	916,000	14.5			245.0	32.1	1865.0	246.7	19.0	2.5		
25	922,000	14.6			247.0	32.1	1971.0	256.3	17.0	2.2		
26	888,000	14.2			240.0	32.4	1917.0	258.8	14.0	1.9		
27	879,000	15.2			257.0	35.1	1976.0	269.5	12.0	1.6		
28	866,000	14.0			237.0	32.8	1848.0	255.9	13.0	1.8		
29	915,000	14.7			249.0	32.6	1887.0	244.7	12.0	1.6		
30	916,000	15.0			254.0	33.2	1850.0	255.3	20.0	2.6		
31	842,000	13.5			228.0	32.5	1755.0	249.9	15.0	2.1		
TOTAL	28,905,000		0.0		7892.0		59374.0		501.0		0.0	
AVERAGE	932,419		#DIV/0!	#DIV/0!	254.6	32.8	1915.3	246.6	16.2	2.1	#DIV/0!	#DIV/0!
MAX	1,138,000											



KENTUCKY DIVISION OF WATER - DRINKING WATER BRANCH  
 WATER TREATMENT PLANT - MONTHLY OPERATING REPORT

PWS ID: KY0210597  
 PLANT ID: A

APPLICABLE TO ALL PLANTS

REPORT MONTH/YEAR: 08/2011

PAGE 3 OF 11

DAY	ANALYTICAL RESULTS (UG/L OR PPM UNLESS OTHERWISE SPECIFIED)														
	PH			TOTAL ALKALINITY		TOTAL HARDNESS		CHLORINE RESIDUAL				TURBIDITY (NTU)			
	RAW	TOP OF FILTER	TAP	RAW	TAP	RAW	TAP	TOTAL	FREE	TOTAL	FREE	RAW	SETTLED WATER	PLANT TAP	
1	6.90	8.40	8.00		78	442	182				1.40	0.03		0.02	
2	6.90	8.40	7.90				180				0.90	0.02		0.02	
3	7.00	8.20	8.00				190				1.10	0.02		0.02	
4	7.00	8.30	8.00				174				1.10	0.02		0.02	
5	7.00	8.70	8.00				184				1.10	0.02		0.02	
6	6.90	8.40	7.90				176				1.10	0.02		0.02	
7	6.80	8.50	8.00				174				1.10	0.03		0.02	
8	6.90	8.40	8.00	80	460		178				1.20	0.03		0.02	
9	7.00	8.00	8.00				188				1.20	0.02		0.03	
10	7.00	8.50	8.00				182				1.10	0.02		0.03	
11	7.00	8.20	8.10				182				1.20	0.03		0.02	
12	7.00	8.50	8.00				184				1.20	0.03		0.02	
13	6.90	8.30	7.90				176				1.20	0.03		0.02	
14	7.00	8.40	8.00				180				1.20	0.02		0.02	
15	7.00	8.10	7.90	78	432		184				1.10	0.05		0.03	
16	7.00	8.50	7.70				178				1.10	0.04		0.03	
17	7.00	8.30	7.90				182				1.20	0.04		0.05	
18	7.00	8.40	7.90				182				1.20	0.05		0.05	
19	6.80	8.40	7.80				190				1.10	0.04		0.03	
20	6.90	8.40	8.00				186				0.80	0.03		0.03	
21	7.00	8.30	8.00				186				1.20	0.03		0.04	
22	7.00	8.40	7.90	72	430		180				1.10	0.05		0.03	
23	7.00	8.60	7.90				210				1.20	0.04		0.03	
24	7.00	8.40	7.90				218				1.10	0.02		0.03	
25	7.00	8.60	8.00				200				1.10	0.03		0.04	
26	6.90	8.60	8.00				188				1.20	0.05		0.03	
27	7.00	8.10	8.00				204				0.90	0.04		0.03	
28	7.00	8.60	7.80				200				1.10	0.04		0.03	
29	7.00	8.40	8.10	96	460		200				1.00	0.03		0.03	
30	7.00	8.60	7.90				200				1.10	0.04		0.03	
31	7.00	8.50	8.00				180				1.10	0.02		0.03	
AVERAGE	7.0	8.4	8.0	#DIV/0!	81	445	187	#DIV/0!	#DIV/0!	#DIV/0!	1.12	0.03	#DIV/0!	0.03	



KENTUCKY DIVISION OF WATER - DRINKING WATER BRANCH  
 WATER TREATMENT PLANT - MONTHLY OPERATING REPORT

FWSID: KY0210067  
 PLANT ID: A

APPLICABLE TO ALL PLANTS

REPORT MONTH/YEAR: 08/2011

\*Please answer Y/N question below this chart.

PAGE 5 OF 11

DAY	ANALYTICAL RESULTS (mg/L OR PPM UNLESS OTHERWISE SPECIFIED)									RAINFALL INCHES	WATER TEMP. DEGREES F <sup>o</sup> /C <sup>o</sup>
	FLUORIDE		IRON		MANGANESE		Lowest Daily Chlorine Residual Plant Tap On-Line Chlorine Analyzer FREE / TOTAL	RAINFALL	WATER TEMP.		
	RAW	TAP	RAW	TAP	RAW	TAP					
1	0.30	0.90	0.09	0.06		0.18		1.44	0.0	16.0	
2	0.28	1.00						0.90	0.0	16.0	
3	0.30	1.10						1.09	0.2	16.0	
4	0.37	1.10						1.19	0.0	16.0	
5	0.12	1.00						1.04	0.0	16.0	
6	0.20	1.00						1.12	0.0	16.0	
7	0.20	1.00						1.14	0.5	16.0	
8	0.16	1.00	0.09	0.04		0.03		1.17	0.0	16.0	
9	0.40	1.00						1.10	0.3	16.0	
10	0.30	1.00						1.18	0.0	16.0	
11	0.30	1.20						1.22	0.0	16.0	
12	0.06	0.60						1.19	0.0	16.0	
13	0.10	0.90						1.20	0.4	16.0	
14	0.10	0.90						1.20	0.6	16.0	
15	0.10	1.00	0.16	0.02		0.03		1.18	0.0	16.0	
16	0.10	1.10						1.11	0.0	16.0	
17	0.20	1.00						1.09	0.0	16.0	
18	0.35	1.20						1.07	0.5	16.0	
19	0.34	1.10						1.16	0.0	16.0	
20	0.30	0.70						1.16	0.0	16.0	
21	0.10	1.00						1.00	0.1	16.0	
22	0.30	1.10	0.08	0.02		0.03		1.18	0.0	16.0	
23	0.40	1.20						1.08	0.0	16.0	
24	0.10	0.90						1.07	0.0	16.0	
25	0.29	1.10						1.15	0.0	16.0	
26	0.29	1.20						1.04	0.0	16.0	
27	0.16	1.10						1.00	0.0	16.0	
28	0.16	0.90						1.11	0.0	16.0	
29	0.27	1.10	0.16	0.16		0.02		0.96	0.0	16.0	
30	0.47	1.20						1.06	0.0	16.0	
31	0.30	1.10						1.06	0.0	16.0	
AVERAGE	0.24	1.02	0.12	0.06	#DIV/0!	0.06	#DIV/0!	#DIV/0!	Monthly Minimum	0.90	16.0

Number of readings	31	2.55
For Free Chlorine, # less than 0.2 mg/L	0	
For Chloramines, # less than 0.5 mg/L		

Disinfectant Chloramines? (Y/N)

N

KENTUCKY DIVISION OF WATER - DRINKING WATER BRANCH  
 WATER TREATMENT PLANT - MONTHLY OPERATING REPORT

APPLICABLE TO ALL PLANTS WITH FILTRATION

FWS ID: KY0210097

PLANT ID: A

REPORT MONTH/YEAR: 08/2011

PAGE 6 OF 11

DAY	FILTER OPERATION											
	TOTAL WASH WATER	No. 1		No. 2		No. 3		No. 4		No. 5		
	GALLONS	AREA (square feet) WASHWATER GALLONS	FLT RUN HRS	AREA (square feet) WASHWATER GALLONS	FLT RUN HRS	AREA (square feet) WASHWATER GALLONS	FLT RUN HRS	AREA (square feet) WASHWATER GALLONS	FLT RUN HRS	AREA (square feet) WASHWATER GALLONS	FLT RUN HRS	
1	0		15.10		15.10							
2	55,200		15.00	55,200	14.50							
3	0		14.50		14.50							
4	48,000	48,000	14.30		14.80							
5	0		15.30		15.30							
6	0		15.00		15.00							
7	0		15.00		15.00							
8	0		16.70		16.70							
9	48,000		15.30	48,000	14.80							
10	0		15.70		15.70							
11	0		14.30		14.30							
12	0		15.00		15.00							
13	52,800	52,800	14.60		15.10							
14	0		15.40		15.40							
15	0		14.10		14.10							
16	48,000		15.90	48,000	15.40							
17	0		15.80		15.80							
18	0		15.00		15.00							
19	52,800	52,800	13.20		13.70							
20	0		14.10		14.10							
21	0		15.00		15.00							
22	0		16.20		16.20							
23	0		16.20		16.20							
24	0		14.50		14.50							
25	50,400		14.60	50,400	14.10							
26	0		14.20		14.20							
27	48,000	48,000	14.70		15.20							
28	0		14.00		14.00							
29	0		14.70		14.70							
30	48,000		15.00	48,000	14.50							
31	0		13.50		13.50							
TOTAL	451,200	201,600	463.70	249,600	463.20	0	0.00	0	0.00	0	0.00	
AVERAGE	14,555	50,400	14.958	49,920	14.942	#DIV/0!	#DIV/0!	#DIV/0!	#DIV/0!	#DIV/0!	#DIV/0!	

COPY AS NEEDED

KENTUCKY DIVISION OF WATER - DRINKING WATER BRANCH  
 WATER TREATMENT PLANT - MONTHLY OPERATING REPORT

PWS ID : KY0216007  
 PLANT ID : A

ALL WATER SYSTEMS

REPORT MONTH/YEAR: 09/2011

PAGE 7 OF 11

DAY	CHEMICALS ADDED			DISTRIBUTION SYSTEM OPERATIONS							
	CHLORINE BOOSTER LBS	CHLORINE BOOSTER LBS		TEST RESULTS							
				NORTH				WEST			
				TOTAL (T) AND FREE (F) CHLORINE RESIDUAL (ppm)							
			T	F	T	F	T	F	T	F	
1					1.00		0.90				
2									0.80		1.00
3					0.50		0.70				
4									1.00		1.20
5					1.20		1.00				
6									0.80		0.90
7					1.10		0.90				
8									0.70		0.80
9					1.00		0.80				
10									1.10		1.10
11					1.30		1.00				
12									0.70		0.80
13					1.30		0.90				
14									0.80		0.90
15					1.10		1.10				
16									1.10		1.10
17					1.20		0.90				
18									1.00		1.00
19					0.60		0.60				
20									0.60		0.90
21					1.20		1.00				
22									0.90		0.90
23					1.20		0.90				
24									0.70		0.80
25					0.60		0.90				
26									1.00		1.10
27					1.10		1.00				
28									1.00		1.10
29					0.80		1.00				
30									0.60		1.00
31					1.10		0.90				
AVERAGE	#DIV/0!	#DIV/0!	Average	#DIV/0!	1.01	#DIV/0!	0.93	#DIV/0!	0.85	#DIV/0!	0.94
TOTAL	0.0	0.0	Total Chlorine		0.50		0.70		0.60		0.50

Total # Chlorine Samples	0	15	0	15	0	15	0	15
# Less than 0.2 mg/L	0	0	0	0	0	0	0	0

Number of Free Residuals	62	Minimum Monthly Free Residual	0.50
Number of Total Residuals	0	Minimum Monthly Total Residual	0.00
Total # Less than 0.2 mg/L	0		
Total # Less than 0.5 mg/L			

Disinfectant Chloramines? (Y/N)  N  
 Number of days of operation?  31

KENTUCKY DIVISION OF WATER - DRINKING WATER BRANCH  
 WATER TREATMENT PLANT - MONTHLY OPERATING REPORT

PWS ID: KY0210037  
 PLANT ID: A

TURBIDITY REPORT

APPLICABLE TO ALL PLANTS WITH FILTRATION

Report Period (MM/YYYY):

08/2011

PAGE: 8 OF 11

PWS Name: Carrollton Utilities

DAY	Hours Plant Operated	# of Turbidity Samples Required	Mid - 4 am	4 am - 8 am	8 am - Noon	Noon - 4 pm	4 pm - 8 pm	8 pm - Mid	Daily Maximum
1	15.1	4		0.02	0.02	0.03	0.02		0.030
2	15.0	4		0.02	0.02	0.02	0.02		0.020
3	14.5	4		0.02	0.02	0.02	0.02		0.020
4	14.8	4		0.02	0.02	0.02	0.02		0.020
5	15.3	4		0.02	0.02	0.02	0.02		0.020
6	15.0	4		0.02	0.02	0.02	0.02		0.020
7	15.0	4		0.02	0.02	0.02	0.02		0.020
8	16.7	5		0.02	0.02	0.03	0.02	0.02	0.030
9	15.3	4		0.03	0.03	0.03	0.03		0.030
10	15.7	4		0.03	0.03	0.04	0.03		0.040
11	14.3	4		0.02	0.02	0.04	0.04		0.040
12	15.0	4		0.02	0.02	0.02	0.02		0.020
13	15.1	4		0.02	0.02	0.02	0.02		0.020
14	15.4	4		0.02	0.02	0.02	0.02		0.020
15	14.1	4		0.05	0.05	0.03	0.03		0.050
16	15.9	4		0.03	0.03	0.03	0.03		0.030
17	15.6	4		0.05	0.05	0.04	0.04		0.050
18	15.0	4		0.05	0.05	0.05	0.04		0.050
19	13.7	4		0.03	0.03	0.04	0.03		0.040
20	14.1	4		0.03	0.03	0.03	0.03		0.030
21	15.0	4		0.04	0.04	0.02	0.02		0.040
22	18.2	5		0.02	0.02	0.03	0.03	0.03	0.030
23	16.2	5		0.04	0.04	0.03	0.03	0.03	0.040
24	14.5	4		0.03	0.03	0.02	0.03		0.030
25	14.6	4		0.04	0.04	0.03	0.03		0.040
26	14.2	4		0.03	0.03	0.04	0.02		0.040
27	15.2	4		0.04	0.04	0.03	0.04		0.040
28	14.0	4		0.04	0.04	0.04	0.04		0.040
29	14.7	4		0.03	0.03	0.03	0.03		0.030
30	15.0	4		0.03	0.03	0.03	0.03		0.030
31	13.5	4		0.03	0.03	0.03	0.03		0.030
<b>Total</b>	<b>465.7</b>	<b>127</b>						<b>127</b>	<b>0.050</b>

ARE YOU USING EITHER CONVENTIONAL or DIRECT FILTRATION? (Y/N) Y

(Any type of backwash besides clay sand)

Number of samples exceeding → 0.1 NTU 0 0.3 NTU 0 1 NTU 0

For slow sand filtration, the number of samples exceeding → 1 NTU 0 5 NTU 0

\*NOTE: The "Number of Turbidity Samples Required" is the number of hours the plant operated divided by 4 rounded up to the next whole number.

I certify that the above turbidity readings were taken every 4 hours during plant operation and in the time frames noted above.

Signature of Principal Executive Officer or Authorized Agent

Date 8/4/11



KENTUCKY DIVISION OF WATER - DRINKING WATER BRANCH  
 WATER TREATMENT PLANT - MONTHLY OPERATING REPORT

APPLICABLE TO ALL SURFACE WATER PLANTS WITH FILTRATION

INDIVIDUAL FILTER TURBIDITY EXCEEDANCE REPORT

PWS Name: Carrollton Utilities  
 PWS ID: KY0210067  
 PLANT ID: A  
 Report Period (MM/YYYY): 06/2011

If any filter exceeded any one of the individual filter turbidity triggers below, (also listed on the Summary Sheet), complete the following and submit the appropriate report(s).

PAGE 9 OF 11

Date	Filter Number	Turbidity Reading (NTU)	Trigger Level (see below)	Reason for Exceedance (if known)	Date and Time State was Contacted

Trigger Levels:

- A. Any one filter has a measured turbidity level of greater than 1.0 NTU in 2 consecutive measurements taken 15 minutes apart.
- B. Any one filter has a measured turbidity level of greater than 0.5 NTU in 2 consecutive measurements taken 15 minutes apart at the end of the first 4 hours of operation following a backwash or return to service.
- C. Any one filter has a measured turbidity level of greater than 1.0 NTU in 3 consecutive measurements taken 15 minutes apart at any time in each of 3 consecutive months.
- D. Any one filter has a measured turbidity level of greater than 2.0 NTU in 5 consecutive measurements taken 15 minutes apart at any time in each of 2 consecutive months.

Report Required:

- For Trigger A.: Filter number, the turbidity measurement, the date of exceedance and filter profile within 7 days of the exceedance, if no obvious reason for the exceedance
- For Trigger B.: Filter number, the turbidity measurement, the date of exceedance and filter profile within 7 days of the exceedance, if no obvious reason for the exceedance
- For Trigger C.: Filter number, the turbidity measurement, the date of exceedance and a filter self-assessment within 14 days of the exceedance
- For Trigger D.: Filter number, the turbidity measurement, the date of exceedance and arrange for a Comprehensive Performance Evaluation (CPE) with the Drinking Water Branch no later than 30 days following the exceedance

MAKE COPIES AS NEEDED



**KENTUCKY DIVISION OF WATER / DRINKING WATER BRANCH  
MONTHLY OPERATING REPORT (MOR) PLANT SUMMARY FORM**

PWS ID

KY0210007

MONITORING PERIOD (MMYYYY) 08/2011

**NOTE: COMPLETE ALL APPLICABLE FIELDS!!! NOT ALL OF THE FIELDS ARE PRE-POPULATED FOR YOU!!!**

PLANT INFORMATION APPLICABLE TO ALL PLANTS		
PLANT ID <u>A</u>	TOTAL WATER TREATED (gallons)	<u>28,905,000</u>
PLANT NAME <u>Carrollton Water Treatment Plant</u>	AVE. DAILY PRODUCTION (gallons)	<u>932,419</u>
AGENCY INTEREST <u>696</u>	MAXIMUM PUMPAGE (gallons per day)	<u>1,138,000</u>

INDIVIDUAL FILTER EFFLUENT TURBIDITY APPLICABLE TO ALL PLANTS WITH FILTRATION	
ANALYTE CODE <u>0100</u>	
Was each filter monitored continuously? (Y/N)	<input checked="" type="checkbox"/> Y
Were measurements recorded every 15 minutes? (Y/N)	<input checked="" type="checkbox"/> Y
Was there a failure of the continuous monitoring equipment? (Y/N)	<input type="checkbox"/> N
If Yes, (1) were individual filter effluent turbidity grab samples collected every four hours of operation? (Y/N)	<input checked="" type="checkbox"/> Y
(2) was the continuously monitoring equipment repaired within 5 working days? (Y/N)	<input type="checkbox"/> N
Was individual filter level greater than 1.0 NTU in two consecutive measurements? (Y/N)	<input type="checkbox"/> N
Was individual filter level greater than 0.5 NTU in two consecutive measurements after on line for more than four hours? (Y/N)	<input type="checkbox"/> N
Was individual filter level greater than 1.0 NTU in two consecutive measurements in three consecutive months? (Y/N)	<input type="checkbox"/> N
Was individual filter level greater than 2.0 NTU in two consecutive measurements in two consecutive months? (Y/N)	<input type="checkbox"/> N
If any of the last 4 boxes are YES, fill out the Individual Filter Turbidity Sheet and submit with the MOR	

COMBINED FILTER EFFLUENT TURBIDITY APPLICABLE TO ALL PLANTS WITH FILTRATION		ENTRY POINT RESIDUAL DISINFECTANT CONCENTRATION APPLICABLE TO ALL PLANTS	
ANALYTE CODE <u>0100</u>		ANALYTE CODE <u>0999</u>	
Number of hours of plant operation <u>455.7</u>		Number of days of plant operation <u>31</u>	
Were samples taken every 4 hours of plant operation? (Y/N)	<input checked="" type="checkbox"/> Y	Were samples taken each day of operation? (Y/N)	<input checked="" type="checkbox"/> Y
Number of samples taken <u>127</u>		Number of lowest chlorine samples recorded <u>31</u>	
Highest single turbidity reading <u>0.05</u>		Lowest single chlorine reading <u>0.90</u>	
For all filtration except slow sand filtration:		If less than required:	
Number of samples exceeded 0.1 NTU <u>0</u>		Was residual restored within 4 hours of plant operation? (Y/N)	<input type="checkbox"/> N
Number of samples exceeded 0.3 NTU <u>0</u>		Free Chlorine (for all disinfectants except chloramine):	
Number of samples exceeded 1 NTU <u>0</u>		Number of samples under 0.2 mg/L <u>0</u>	
When filtration is slow sand filtration:		Total Chlorine (when disinfectant is Chloramine):	
Number of samples exceeded 1 NTU <u>0</u>		Number of samples under 0.5 mg/L <u>0</u>	
Number of samples exceeded 5 NTU <u>0</u>			

CHLORINE DIOXIDE ENTRY POINT MONITORING APPLICABLE TO PLANTS UTILIZING CHLORINE DIOXIDE		CHLORITE ENTRY POINT MONITORING APPLICABLE TO PLANTS UTILIZING CHLORINE DIOXIDE	
ANALYTE CODE <u>1008</u>		ANALYTE CODE <u>1009</u>	
Number of days of plant operation <u>31</u>		Number of days of plant operation <u>31</u>	
Were samples taken each day of operation? (Y/N)	<input type="checkbox"/> N	Were samples taken each day of operation? (Y/N)	<input type="checkbox"/> N
Number of samples taken <u>0</u>		Number of samples taken <u>0</u>	
Highest single chlorine dioxide reading <u>0.00</u>		Highest single chlorite reading <u>0.00</u>	
Number of chlorine dioxide samples exceeded 0.8 mg/L <u>0</u>		Number of chlorite samples exceeded 1 mg/L <u>0</u>	

I certify under penalty of law that I have personally examined and am familiar with the information submitted herein. Based on my inquiry of those individuals immediately responsible for obtaining the information, the submitted information is true, accurate and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment. Violations of 401 KAR Chapter 3 are subject to severe penalties prescribed in KRS 224.99-010, up to \$25,000 fine per day per violation and in some cases a violation may subject the violator to prison.

Franklin W. Johnson, Jr.  
Signature of Principal Executive Officer or Authorized Agent


08/04/11  
Date



**APPENDIX B**  
**HYDRAULIC ANALYSIS OF LINE EXTENSIONS**

---

File: S:\LOU\5100--5199\5104\003\Acad\Hydraulics.dwg Time: Jul 05, 2012 - 9:06am



**LINE A**  
**PAINTER'S RIDGE WATERLINE EXTENSION**  
 USGS QUAD MAP MADISON EAST & CARROLLTON  
 DISTRIBUTION SYSTEM IMPROVEMENTS  
 CARROLLTON UTILITIES & WEST CARROLL WATER DISTRICT  
 CARROLL, TRIMBLE, & HENRY COUNTIES, KENTUCKY



**FIGURE 1**  
 5104.003

**MINIMUM PRESSURE CALCULATION FOR**

**New 3" Line**

Painter's Branch - Service from Palmyra Road										
								# of Customers	25	
								Flow (D.R. Taylor)	48 gpm	
								Supply Tank Overflow Elevation (ft)	1,065 ft	
								Peak Elevation (ft) for New 3" Line	875 ft	
Line	Length (ft)	Σ Length (ft)	Pipe Diameter (in)	Pipe Area (in <sup>2</sup> )	C	HL/1000'	HL (ft)	Σ HL (ft)	H.G.L. (ft)	V (ft/s)
Supply Line									1065.00	
Ex. 4" Line	4,245	4,245	4.0	12.6	140	1.70	7.20	7.20	1057.80	1.23
Ex. 6" Line	1,325	5,570	6.0	28.3	140	0.24	0.31	7.51	1057.49	0.54
Ex. 3" Line	2,855	8,425	3.0	7.1	140	6.87	19.63	27.14	1037.86	2.18
Ex. 4" Line	12,535	20,960	4.0	12.6	140	1.70	21.26	48.39	1016.61	1.23
New 3" Line	6,825	27,785	3.0	7.1	140	6.87	46.92	95.31	969.69	2.18
Cumulative		27,785								
Minimum Pressure (psi)	41									

= Enter data in shaded cells.

Painter's Branch - Flushing Velocity from Palmyra Road						
Water Main Relocation Flushing Velocity Spreadsheet	Pump Station & Flow Data					
Water Elevation (ft) with Bells Ridge Tank down 10 ft.	1065.0					
Headloss (ft) from tank through looped sections	0					
High Point (ft)	945.0	930.0	930.0	715.0	875.0	
<u>Supply Main Data</u>	Ex. 4" Line	Ex. 6" Line	Ex. 3" Line	Ex. 4" Line	New 3" Line	
Diameter (in)	4.0	6.0	3.0	4.0	3.0	
Length (ft)	4,245	1,325	2,855	12,535	6,825	
C Factor	140	140	140	140	140	
Flow (gpm)	60	60	60	60	60	
Headloss/1000'	2.6	0.4	10.4	2.6	10.4	
Headloss (ft)	10.8	0.5	29.6	32.0	70.7	
Σ Headloss (ft)	10.8	11.3	40.9	72.9	143.6	
HGL @ High Point (ft)	1054.2	1053.7	1024.1	992.1	921.4	
<u>Estimated Fireflow Data</u>						
Static (ft)	120.0	135.0	135.0	350.0	190.0	
Static (psi)	52.0	58.5	58.5	151.7	82.3	
Residual (psi)	<b>20.0</b>	<b>20.0</b>	<b>20.0</b>	<b>20.0</b>	<b>20.0</b>	
Residual (ft)	46.2	46.2	46.2	46.2	46.2	
Residual Elevation (ft)	991.2	976.2	976.2	761.2	921.2	
Head Differential (ft)	63.0	77.5	48.0	231.0	0.3	
Flow (gpm)	<b>877</b>	<b>973</b>	<b>765</b>	<b>1,679</b>	<b>60</b>	
Nozzle (in)	2.5	2.5	2.5	2.5	2.5	
Nozzle Discharge Coefficient	0.90	0.90	0.90	0.90	0.90	
Velocity (ft/sec)	<b>1.5</b>	<b>0.7</b>	<b>2.7</b>	<b>1.5</b>	<b>2.7</b>	




**MINIMUM PRESSURE CALCULATION FOR**

**New 3" Line**

Painter's Branch - Service from Wright's Ridge Road										
Line	Length (ft)	Σ Length (ft)	Pipe Diameter (in)	Pipe Area (in <sup>2</sup> )	C	HL/1000'	HL (ft)	Σ HL (ft)	H.G.L. (ft)	V (ft/s)
									# of Customers	25
									Flow (D.R. Taylor)	48 gpm
									Supply Tank Overflow Elevation (ft)	1,065 ft
									Peak Elevation (ft) for New 3" Line	875 ft
Supply Line									1065.00	
Ex. 4" Line	11,780	11,780	4.0	12.6	140	1.70	19.97	19.97	1045.03	1.23
Ex. 3" Line	5,265	17,045	3.0	7.1	140	6.87	36.19	56.17	1008.83	2.18
New 3" Line	6,825	23,870	3.0	7.1	140	6.87	46.92	103.08	961.92	2.18
Cumulative		23,870								
Minimum Pressure (psi)	<b>38</b>									
= Enter data in shaded cells.										

<b>Painter's Branch - Flushing Velocity from Wright's Ridge Road</b>				
<b>Water Main Relocation Flushing Velocity Speadsheet</b>		<b>Pump Station &amp; Flow Data</b>		
Water Elevation (ft) with Bells Ridge Tank down 10 ft.		1065.0		
Headloss (ft) from tank through looped sections		0		
High Point (ft)		945.0	922.0	875.0
<u>Supply Main Data</u>		Ex. 4" Line	Ex. 3" Line	New 3" Line
Diameter (in)		4.0	3.0	3.0
Length (ft)		11,780	5,265	6,825
C Factor		140	140	140
Flow (gpm)		57	57	57
Headloss/1000'		2.4	9.6	9.6
Headloss (ft)		27.8	50.4	65.3
∑ Headloss (ft)		27.8	78.2	143.6
HGL @ High Point (ft)		1037.2	986.8	921.4
<u>Estimated Fireflow Data</u>				
Static (ft)		120.0	143.0	190.0
Static (psi)		52.0	62.0	82.3
Residual (psi)		<b>20.0</b>	<b>20.0</b>	<b>20.0</b>
Residual (ft)		46.2	46.2	46.2
Residual Elevation (ft)		991.2	968.2	921.2
Head Differential (ft)		46.0	18.6	0.3
Flow (gpm)		<b>749</b>	<b>477</b>	<b>57</b>
Nozzle (in)		2.5	2.5	2.5
Nozzle Discharge Coefficient		0.90	0.90	0.90
Velocity (ft/sec)		<b>1.5</b>	<b>2.6</b>	<b>2.6</b>

File: S:\LOU\5100--5199\5104\003\Acad\Hydraulics.dwg Time: Jul 05, 2012 - 9:07am



**LINE B**  
**RD KENDALL WATERLINE EXTENSION**  
**USGS QUAD MAP MADISON EAST & CARROLLTON**  
**DISTRIBUTION SYSTEM IMPROVEMENTS**  
**CARROLLTON UTILITIES & WEST CARROLL WATER DISTRICT**  
**CARROLL, TRIMBLE, & HENRY COUNTIES, KENTUCKY**



**FIGURE 2**

5104.003


**MINIMUM PRESSURE CALCULATION FOR**

**New 3" Line**

RD Kendall										
									# of Customers	25
									Flow (D.R. Taylor)	48 gpm
									Supply Tank Overflow Elevation (ft)	1,065 ft
									Peak Elevation (ft) for New 3" Line	890 ft
Line	Length (ft)	Σ Length (ft)	Pipe Diameter (in)	Pipe Area (in <sup>2</sup> )	C	HL/1000'	HL (ft)	Σ HL (ft)	H.G.L. (ft)	V (ft/s)
Supply Line									1065.00	
Ex. 4" Line	7,305	7,305	4.0	12.6	140	1.70	12.39	12.39	1052.61	1.23
Ex. 3" Line	3,105	10,410	3.0	7.1	140	6.87	21.34	33.73	1031.27	2.18
New 3" Line	4,500	14,910	3.0	7.1	140	6.87	30.93	64.67	1000.33	2.18
Cumulative		14,910								
Minimum Pressure (psi)	48									
= Enter data in shaded cells.										

<b>RD Kendall</b>				
<b>Water Main Relocation Flushing Velocity Spreadsheet</b>		<b>Pump Station &amp; Flow Data</b>		
Water Elevation (ft) with Bells Ridge Tank down 10 ft.		1065.0		
Headloss (ft) from tank through looped sections		0		
High Point (ft)		945.0	925.0	890.0
<u>Supply Main Data</u>		<u>Ex. 4" Line</u>	<u>Ex. 3" Line</u>	<u>New 3" Line</u>
Diameter (in)		4.0	3.0	3.0
Length (ft)		7,305	3,105	4,500
C Factor		140	140	140
Flow (gpm)		70	70	70
Headloss/1000'		3.4	13.7	13.7
Headloss (ft)		24.6	42.4	61.4
Σ Headloss (ft)		24.6	67.0	128.4
HGL @ High Point (ft)		1040.4	998.0	936.6
<u>Estimated Fireflow Data</u>				
Static (ft)		120.0	140.0	175.0
Static (psi)		52.0	60.7	75.8
Residual (psi)		<b>20.0</b>	<b>20.0</b>	<b>20.0</b>
Residual (ft)		46.2	46.2	46.2
Residual Elevation (ft)		991.2	971.2	936.2
Head Differential (ft)		49.2	26.8	0.4
Flow (gpm)		<b>775</b>	<b>572</b>	<b>70</b>
Nozzle (in)		2.5	2.5	2.5
Nozzle Discharge Coefficient		0.90	0.90	0.90
Velocity (ft/sec)		<b>1.8</b>	<b>3.2</b>	<b>3.2</b>

File: S:\LOU\5100--5199\5104\003\Acad\Hydraulics.dwg Time: Jul 05, 2012 - 9:08am



**LINE C**  
**MILLER'S BRANCH WATERLINE EXTENSION**  
**USGS QUAD MAP MADISON EAST & BEDFORD**  
**DISTRIBUTION SYSTEM IMPROVEMENTS**  
**CARROLLTON UTILITIES & WEST CARROLL WATER DISTRICT**  
**CARROLL, TRIMBLE, & HENRY COUNTIES, KENTUCKY**



**FIGURE 3**

5104.003

**MINIMUM PRESSURE CALCULATION FOR**


**New 3" Line**

Miller's Branch										
								# of Customers	48	
								Flow (D.R. Taylor)	25 gpm	
								Supply Tank Overflow Elevation (ft)	1,065 ft	
								Peak Elevation (ft) for New 3" Line	590 ft	
Line	Length (ft)	Σ Length (ft)	Pipe Diameter (in)	Pipe Area (in <sup>2</sup> )	C	HL/1000'	HL (ft)	Σ HL (ft)	H.G.L. (ft)	V (ft/s)
Supply Line									1065.00	
Ex. 4" Line	14,375	14,375	4.0	12.6	140	0.51	7.29	7.29	1057.71	0.64
Ex. 3" Line	1,405	15,780	3.0	7.1	140	2.06	2.89	10.18	1054.82	1.13
New 3" Line	1,600	17,380	3.0	7.1	140	2.06	3.29	13.47	1051.53	1.13
Cumulative		17,380								
Minimum Pressure (psi)	<b>200</b>									
= Enter data in shaded cells.										

<b>Miller's Branch</b>				
<b>Water Main Relocation Flushing Velocity Speadsheet</b>		<b>Pump Station &amp; Flow Data</b>		
Water Elevation (ft) with Bells Ridge Tank down 10 ft.		1065.0		
Headloss (ft) from tank through looped sections		0		
High Point (ft)		922.0	505.0	590.0
<u>Supply Main Data</u>		<b>Ex. 4" Line</b>	<b>Ex. 3" Line</b>	<b>New 3" Line</b>
Diameter (in)		4.0	3.0	3.0
Length (ft)		14,375	1,405	1,600
C Factor		140	140	140
Flow (gpm)		162	162	162
Headloss/1000'		16.1	65.1	65.1
Headloss (ft)		231.0	91.5	104.2
∑ Headloss (ft)		231.0	322.5	426.7
HGL @ High Point (ft)		834.0	742.5	638.3
<u>Estimated Fireflow Data</u>				
Static (ft)		143.0	560.0	475.0
Static (psi)		62.0	242.7	205.8
Residual (psi)		<b>20.0</b>	<b>20.0</b>	<b>20.0</b>
Residual (ft)		46.2	46.2	46.2
Residual Elevation (ft)		968.2	551.2	636.2
Head Differential (ft)		-134.1	191.4	2.1
Flow (gpm)		<b>#NUM!</b>	<b>1,528</b>	<b>162</b>
Nozzle (in)		2.5	2.5	2.5
Nozzle Discharge Coefficient		0.90	0.90	0.90
Velocity (ft/sec)		<b>4.1</b>	<b>7.3</b>	<b>7.3</b>



File: S:\LOU\5100--5199\5104\003\Acad\Hydraulics.dwg Time: Jul 05, 2012 - 9:09am



**LINE D  
HARDY CREEK WATERMAIN**  
USGS QUAD MAP MADISON EAST & BEDFORD  
DISTRIBUTION SYSTEM IMPROVEMENTS  
CARROLLTON UTILITIES & WEST CARROLL WATER DISTRICT  
CARROLL, TRIMBLE, & HENRY COUNTIES, KENTUCKY

**SA**  
**STRAND**  
ASSOCIATES®

FIGURE 4  
5104.003

**MINIMUM PRESSURE CALCULATION FOR**

**New 3" Line**

**Hardy Creek**

# of Customers **25**

Flow (D.R. Taylor) **48 gpm**

Supply Tank Overflow Elevation (ft) **1,065 ft**


Peak Elevation (ft) for New 3" Line **570 ft**

Line	Length (ft)	Σ Length (ft)	Pipe Diameter (in)	Pipe Area (in <sup>2</sup> )	C	HL/1000'	HL (ft)	Σ HL (ft)	H.G.L. (ft)	V (ft/s)
									1065.00	
Supply Line										
Ex. 4" Line	13,620	13,620	4.0	12.6	140	1.70	23.09	23.09	1041.91	1.23
Ex. 3" Line	8,560	22,180	3.0	7.1	140	6.87	58.84	81.94	983.06	2.18
New 3" Line	2,380	24,560	3.0	7.1	140	6.87	16.36	98.30	966.70	2.18
Cumulative		24,560								
Minimum Pressure (psi)	<b>172</b>									

= Enter data in shaded cells.

<b>Hardy Creek</b>				
<b>Water Main Relocation Flushing Velocity Spreadsheet</b>		<b>Pump Station &amp; Flow Data</b>		
Water Elevation (ft) with Bells Ridge Tank down 10 ft.		1065.0		
Headloss (ft) from tank through looped sections		0		
High Point (ft)		922.0	540.0	570.0
<u>Supply Main Data</u>		<u>Ex. 4" Line</u>	<u>Ex. 3" Line</u>	<u>New 3" Line</u>
Diameter (in)		4.0	3.0	3.0
Length (ft)		13,620	8,560	2,380
C Factor		140	140	140
Flow (gpm)		109	109	109
Headloss/1000'		7.7	31.3	31.3
Headloss (ft)		105.2	268.1	74.5
∑ Headloss (ft)		105.2	373.3	447.9
HGL @ High Point (ft)		959.8	691.7	617.1
<u>Estimated Fireflow Data</u>				
Static (ft)		143.0	525.0	495.0
Static (psi)		62.0	227.5	214.5
Residual (psi)		<b>20.0</b>	<b>20.0</b>	<b>20.0</b>
Residual (ft)		46.2	46.2	46.2
Residual Elevation (ft)		968.2	586.2	616.2
Head Differential (ft)		-8.4	105.5	1.0
Flow (gpm)		<b>#NUM!</b>	<b>1,135</b>	<b>109</b>
Nozzle (in)		2.5	2.5	2.5
Nozzle Discharge Coefficient		0.90	0.90	0.90
Velocity (ft/sec)		2.8	4.9	4.9

File: S:\LOU\5100--5199\5104\003\Acad\Hydraulics.dwg Time: Jul 05, 2012 -- 9:11am



**LINE E**  
**US 36/KY 42 & KINGS RIDGE RD WATERMAIN EXTENSION**  
**USGS QUAD MAP CARROLLTON**  
**DISTRIBUTION SYSTEM IMPROVEMENTS**  
**CARROLLTON UTILITIES & WEST CARROLL WATER DISTRICT**  
**CARROLL, TRIMBLE, & HENRY COUNTIES, KENTUCKY**

**SA**  
**STRAND**  
ASSOCIATES®

**FIGURE 5**

5104.003

Kings Ridge Pump Station


**DISCHARGE SIDE**

Line	Length (ft)	CUMUL. Length (ft)	Pipe Size (in)	Area (sq in)	C	ELEV. BELLS RIDGE TANK		Flow		V (ft/s)
						HL /1000'	HL (ft)	CUMUL. HL (ft)	H.G.L. (ft)	
	0	24,445	0.0	0.0	140			4.56	706.44	
	0	24,445	0.0	0.0	140					
Prop. 6" Water Main	2,020	26,465	6.0	28.3	140	0.17	0.34	4.90	1070.10	0.45
Ex. 3" Water Main	16,265	42,730	3.0	7.1	140	4.91	79.80	84.70	990.30	1.82
Ex. 3" Water Main	3,435	46,165	3.0	7.1	140	4.91	16.85	101.55	973.45	1.82
									1171.99	
									1075.00	
								101.55		
								364.00		
								465.548		


**SUCTION SIDE**

Line	Length (ft)	CUMUL. Length (ft)	Pipe Size (in)	Area (sq in)	C	ELEV. GENERAL BUTLER TANK		Flow		V (ft/s)
						HL /1000'	HL (ft)	CUMUL. HL (ft)	H.G.L. (ft)	
Ex. 12" Water Main	670	670	12.0	113.1	140	0.01	0.00	0.00	711.00	0.11
Ex. 8" Water Main	1,720	2,390	8.0	50.3	140	0.04	0.07	0.08	710.92	0.26
Ex. 6" Water Main	1,290	3,680	6.0	28.3	140	0.17	0.22	0.29	710.71	0.45
Ex. 8" Water Main	1,900	5,580	8.0	50.3	140	0.04	0.08	0.37	710.63	0.26
Ex. 6" Water Main	2,485	8,065	6.0	28.3	140	0.17	0.42	0.79	710.21	0.45
Ex. 4" Water Main	970	9,035	4.0	12.6	140	1.21	1.17	1.96	709.04	1.02
Ex. 6" & Prop. 6" Water Main	15,410	24,445	6.0	28.3	140	0.17	2.59	4.56	706.44	0.45


## Kings Ridge



# King's Ridge HGL - 40 GPM PUMP



File: S:\LOU\5100--5199\5104\003\Acad\Hydraulics.dwg Time: Jul 05, 2012 - 9:15am



**LINE F**  
**MOUND HILL WATERLINE EXTENSION**  
**USGS QUAD MAP CARROLLTON**  
**DISTRIBUTION SYSTEM IMPROVEMENTS**  
**CARROLLTON UTILITIES & WEST CARROLL WATER DISTRICT**  
**CARROLL, TRIMBLE, & HENRY COUNTIES, KENTUCKY**



**FIGURE 6**

5104.003




**MINIMUM PRESSURE CALCULATION FOR**

Mound Hill										
								# of Customers	25	
								Flow (D.R. Taylor)	48 gpm	
								Supply Tank Overflow Elevation (ft)	989 ft	
								Peak Elevation (ft) for	880 ft	
Line	Length (ft)	Σ Length (ft)	Pipe Diameter (in)	Pipe Area (in <sup>2</sup> )	C	HL/1000'	HL (ft)	Σ HL (ft)	H.G.L. (ft)	V (ft/s)
Supply Line									989.00	
Ex. 6" Line	250	250	6.0	28.3	140	0.24	0.06	0.06	988.94	0.54
New 3" Line	1,500	1,750	3.0	7.1	140	6.87	10.31	10.37	978.63	2.18
Cumulative		1,751								
Minimum Pressure (psi)	<b>43</b>									
= Enter data in shaded cells.										

<b>Mound Hill</b>			
<b>Water Main Relocation Flushing Velocity Speadsheet</b>		<b>Pump Station &amp; Flow Data</b>	
Water Elevation (ft) with Mound Hill Tank down 10 ft.		989.0	
Headloss (ft) from tank through looped sections		0	
High Point (ft)		900.0	880.0
<u>Supply Main Data</u>		<b>Ex. 6" Line</b>	<b>Prop. 3" Line</b>
Diameter (in)		6.0	3.0
Length (ft)		250	1,500
C Factor		140	140
Flow (gpm)		126	126
Headloss/1000'		1.4	40.8
Headloss (ft)		0.3	61.2
∑ Headloss (ft)		0.3	61.5
HGL @ High Point (ft)		988.7	927.5
<u>Estimated Fireflow Data</u>			
Static (ft)		89.0	109.0
Static (psi)		38.6	47.2
Residual (psi)		<b>20.0</b>	<b>20.0</b>
Residual (ft)		46.2	46.2
Residual Elevation (ft)		946.2	926.2
Head Differential (ft)		42.5	1.3
Flow (gpm)		<b>720</b>	<b>126</b>
Nozzle (in)		2.5	2.5
Nozzle Discharge Coefficient		0.90	0.90
Velocity (ft/sec)		<b>1.4</b>	<b>5.7</b>

File: S:\LOU\5100--5199\5104\003\Acad\Hydraulics.dwg Time: Jul 05, 2012 - 9:15am



**LINE G**  
**GILGAL ROAD WATERLINE EXTENSION**  
**USGS QUAD MAP CAMPBELLSBURG & WORTHVILLE**  
**DISTRIBUTION SYSTEM IMPROVEMENTS**  
**CARROLLTON UTILITIES & WEST CARROLL WATER DISTRICT**  
**CARROLL, TRIMBLE, & HENRY COUNTIES, KENTUCKY**

**SA**  
**STRAND**  
ASSOCIATES®

**FIGURE 7**  
5104.003


Gilgal Pump Station - Based on Suction Side Minimum Pressure of 73 psi or 688 HGL

**DISCHARGE SIDE**

Line	Length (ft)	CUMUL. Length (ft)	Pipe Size (in)	Area (sq in)	C	ELEV. GILGAL TANK		Flow	H.G.L. (ft)	V (ft/s)	
						HL /1000'	HL (ft)	60 gpm 976 ft CUMUL. HL (ft)			
		42,800									
	7,000	49,800	0.0	0.0	140	10.39		0.00	688.00	#DIV/0!	
	0	49,800	0.0	0.0	140						
Pump to Tank Prop. 4" Water Main	7,000	56,800	4.0	12.6	140	2.56	17.94	17.94	670.06	1.53	
								17.94			
								288.00			
								305.94			

**SUCTION SIDE**

Line	Length (ft)	CUMUL. Length (ft)	Pipe Size (in)	Area (sq in)	C	ELEV. MOUND HILL TANK		Flow	H.G.L. (ft)	V (ft/s)
						HL /1000'	HL (ft)	60 gpm 989 ft CUMUL. HL (ft)		
Ex. 6" Water Main	6,300	6,300	6.0	28.3	140	0.36	2.24	2.24	986.76	0.68
Ex. 4" Water Main	36,500	42,800	4.0	12.6	140	2.56	93.52	95.77	893.23	1.53



Environmental Products

Excel Environmental Products

4548 Industrial Parkway


Cleveland, OH 44135

P: 216-941-1500 ♦ F: 216-941-9916


Toll Free: 800-892-2009

E-mail: sales@pescolc.com


91047452 HYDRO MULTI-E 3 CME 5-8 60 Hz



### Gilgal HGL - 60 GPM PUMP



File: S:\LOU\5100--5199\5104\003\Acad\Hydraulics.dwg Time: Jul 05, 2012 - 9:18am



**LINE H**  
**NORA LANE WATERLINE EXTENSION**  
USGS QUAD MAP CAMPBELLSBURG & WORTHVILLE  
DISTRIBUTION SYSTEM IMPROVEMENTS  
CARROLLTON UTILITIES & WEST CARROLL WATER DISTRICT  
CARROLL, TRIMBLE, & HENRY COUNTIES, KENTUCKY



FIGURE 8

5104.003

**MINIMUM PRESSURE CALCULATION FOR**

**New 3" Line**


Nora Lane								# of Customers	6	
								Flow (D.R. Taylor)	25 gpm	
								Supply Tank Overflow Elevation (ft)	966 ft	
								Peak Elevation (ft) for New 3" Line	880 ft	
Line	Length (ft)	Σ Length (ft)	Pipe Diameter (in)	Pipe Area (in <sup>2</sup> )	C	HL/1000'	HL (ft)	Σ HL (ft)	H.G.L. (ft)	V (ft/s)
Supply Line									966.00	
New 4" Line	915	915	4.0	12.6	140	0.51	0.46	0.46	965.54	0.64
Ex. 3" Line	3,575	4,490	3.0	7.1	140	2.06	7.35	7.82	958.18	1.13
New 3" Line	2,550	7,040	3.0	7.1	140	2.06	5.24	13.06	952.94	1.13
Cumulative		7,040								
Minimum Pressure (psi)		<b>32</b>								

**= Enter data in shaded cells.**



<b>Nora Lane</b>				
<b>Water Main Relocation Flushing Velocity Speadsheet</b>		<b>Pump Station &amp; Flow Data</b>		
Water Elevation (ft) with Gigal Tank down 10 ft.		966.0		
Headloss (ft) from tank through looped sections		0		
High Point (ft)		880.0	850.0	880.0
<u>Supply Main Data</u>		<b>New 4" Line</b>	<b>Ex. 3" Line</b>	<b>New 3" Line</b>
Diameter (in)		4.0	3.0	3.0
Length (ft)		915	3,575	2,550
C Factor		140	140	140
Flow (gpm)		46	46	46
Headloss/1000'		1.5	6.2	6.2
Headloss (ft)		1.4	22.3	15.9
∑ Headloss (ft)		1.4	23.7	39.7
HGL @ High Point (ft)		964.6	942.3	926.3
<u>Estimated Fireflow Data</u>				
Static (ft)		86.0	116.0	86.0
Static (psi)		37.3	50.3	37.3
Residual (psi)		<b>20.0</b>	<b>20.0</b>	<b>20.0</b>
Residual (ft)		46.2	46.2	46.2
Residual Elevation (ft)		926.2	896.2	926.2
Head Differential (ft)		38.4	46.1	0.2
Flow (gpm)		<b>685</b>	<b>750</b>	<b>46</b>
Nozzle (in)		2.5	2.5	2.5
Nozzle Discharge Coefficient		0.90	0.90	0.90
Velocity (ft/sec)		<b>1.2</b>	<b>2.1</b>	<b>2.1</b>

File: S:\LOU\5100--5199\5104\003\Acad\Hydraulics.dwg Time: Jul 05, 2012 - 9:18am



**LINE I**  
**TURKEY RUN RD WATERLINE EXTENSION**  
**USGS QUAD MAP CAMPBELLSBURG & WORTHVILLE**  
**DISTRIBUTION SYSTEM IMPROVEMENTS**  
**CARROLLTON UTILITIES & WEST CARROLL WATER DISTRICT**  
**CARROLL, TRIMBLE, & HENRY COUNTIES, KENTUCKY**



FIGURE 9

5104.003

**MINIMUM PRESSURE CALCULATION FOR**

**New 3" Line**

Line	Length (ft)	Σ Length (ft)	Pipe Diameter (in)	Pipe Area (in <sup>2</sup> )	C	HL/1000'	HL (ft)	Σ HL (ft)	H.G.L. (ft)	V (ft/s)											
<table border="0" style="width: 100%; border-collapse: collapse;"> <tr> <td style="width: 60%;"></td> <td style="text-align: right;"># of Customers</td> <td style="text-align: right;">15</td> </tr> <tr> <td></td> <td style="text-align: right;">Flow (D.R. Taylor)</td> <td style="text-align: right;">37 gpm</td> </tr> <tr> <td></td> <td style="text-align: right;">Gilgal Tank Assuming PRV Pit is Removed</td> <td style="text-align: right;">966 ft</td> </tr> <tr> <td></td> <td style="text-align: right;">Peak Elevation (ft) for New 3" Line</td> <td style="text-align: right;">850 ft</td> </tr> </table>											# of Customers	15		Flow (D.R. Taylor)	37 gpm		Gilgal Tank Assuming PRV Pit is Removed	966 ft		Peak Elevation (ft) for New 3" Line	850 ft
	# of Customers	15																			
	Flow (D.R. Taylor)	37 gpm																			
	Gilgal Tank Assuming PRV Pit is Removed	966 ft																			
	Peak Elevation (ft) for New 3" Line	850 ft																			
Supply Line									966.00												
New 4" Line	915	915	4.0	12.6	140	1.05	0.96	0.96	965.04	0.94											
Ex. 3" Line	12,500	13,415	3.0	7.1	140	4.25	53.09	54.05	911.95	1.68											
New 3" Line	10,950	24,365	3.0	7.1	140	4.25	46.51	100.56	865.44	1.68											
Cumulative		24,365																			
Minimum Pressure (psi)									7												
= Enter data in shaded cells.																					

<b>Turkey Run</b>				
<b>Water Main Relocation Flushing Velocity Spreadsheets</b>		<b>Pump Station &amp; Flow Data</b>		
Gilgal Tank - Assuming 10' low		966.0		
Headloss (ft) from tank through looped sections		0		
High Point (ft)		880.0	850.0	850.0
<u>Supply Main Data</u>		<u>New 4" Line</u>	<u>Ex. 3" Line</u>	<u>New 3" Line</u>
Diameter (in)		4.0	3.0	3.0
Length (ft)		915	12,500	10,950
C Factor		140	140	140
Flow (gpm)		30	30	30
Headloss/1000'		0.7	2.9	2.9
Headloss (ft)		0.7	36.8	32.3
∑ Headloss (ft)		0.7	37.5	69.8
HGL @ High Point (ft)		965.3	928.5	896.2
<u>Estimated Fireflow Data</u>				
Static (ft)		86.0	116.0	116.0
Static (psi)		37.3	50.3	50.3
Residual (psi)		<b>20.0</b>	<b>20.0</b>	<b>20.0</b>
Residual (ft)		46.2	46.2	46.2
Residual Elevation (ft)		926.2	896.2	896.2
Head Differential (ft)		39.2	32.3	0.1
Flow (gpm)		<b>691</b>	<b>628</b>	<b>30</b>
Nozzle (in)		2.5	2.5	2.5
Nozzle Discharge Coefficient		0.90	0.90	0.90
Velocity (ft/sec)		<b>0.8</b>	<b>1.4</b>	<b>1.4</b>

## MAXIMUM DOMESTIC DEMAND (gpm)


# of Customers	Class of Property				Square Root Curve
	1	2	3	4	
0					
1	10	12	14	19	10
2	12	15	18	24	14
3	14	17	20	27	17
4	16	19	22	30	20
6	18	21	25	34	24
8	20	23	28	37	28
10	21	25	30	40	32
15	25	30	37	50	39
20	28	35	43	58	45
25	30	39	48	66	50
30	31	42	53	73	55
40	36	48	62	85	63
50	40	54	70	96	71
60	43	59	76	105	77
70	45	62	82	115	84
80	48	68	88	125	89
90	50	71	94	132	95
100	52	75	100	140	100
125	57	83	110	157	112
150	61	90	120	175	122
175	64	97	132	190	132
200	68	105	140	205	141
300	80	125	175	250	173
400	90	145	200	295	200
500	100	160	225	335	224

*Note: Class of Property 3 & Square Root Curve Technique are approximately equal.*

### DESCRIPTION:


- Class 1 Sub-Standard houses with barest of minimum of plumbing where little or no lawn sprinkling is expected.
- Class 2 Small houses with one bath, on small lot. Small rental houses and small rental duplex houses. Very little lawn sprinkling. Either side of a duplex is considered as one house.
- Class 3 Average good subdivision with 80% two to three bedroom houses with one bath and 20% two to three bedroom huses with two baths. Houses owned by occupant, with average amount of lawn and shrubery requiring average amount of lawn sprinkling.
- Class 4 Houses with three to four bedrooms and two to three baths on large lots requiring considerable lawn sprinkling. Does not include estates with or without swimming pools.

### Maximum Domestic Demand - D.R. Taylor Curve



**APPENDIX C**  
**ANALYSIS OF TRANSMISSION MAIN TO SERVE GENERAL BUTLER TANK**


---



EPANET 2 - Carrollton Base - revised - JKD.net

File Edit View Project Report Window Help

NetworkMap



Day 1, 12:00 AM

Browser

Date	Map
Junctions	
561	
563	
565	
571	
573	
601	
603	
605	


**EXISTING SYSTEM PRESSURE WITH ONE  
HIGH SERVICE PUMP OPERATING  
CARROLLTON UTILITIES COUNTYWIDE  
UNDERSERVED PROJECT  
WEST CARROLL WATER DISTRICT  
CARROLL COUNTY, KENTUCKY**



**FIGURE 1**  
5104.002

Auto-Length On GPM 3579% X,Y: 21012.96, 21774.49






**TANK 1 AND TANK 2 HGL FOR EXISTING SYSTEM WITH  
 ONE HIGH SERVICE PUMP OPERATING  
 CARROLLTON UTILITIES COUNTYWIDE  
 UNDERSERVED PROJECT  
 WEST CARROLL WATER DISTRICT  
 CARROLL COUNTY, KENTUCKY**




**FIGURE 2**  
**5104.002**



**EXISTING SYSTEM PRESSURE WITH TWO  
 HIGH SERVICE PUMPS OPERATING  
 CARROLLTON UTILITIES COUNTYWIDE  
 UNDERSERVED PROJECT  
 WEST CARROLL WATER DISTRICT  
 CARROLL COUNTY, KENTUCKY**




**FIGURE 3**  
 5104.002



**TANK 1 AND TANK 2 HGL FOR EXISTING SYSTEM WITH  
TWO HIGH SERVICE PUMPS OPERATING  
CARROLLTON UTILITIES COUNTYWIDE  
UNDERSERVED PROJECT  
WEST CARROLL WATER DISTRICT  
CARROLL COUNTY, KENTUCKY**




**FIGURE 4  
5104.002**



**FUTURE SYSTEM PRESSURE WITH TWO HIGH SERVICE PUMPS  
OPERATING AND AN 8-IN. MAIN PARALLELING EXISTING 8-IN.  
CARROLLTON UTILITIES COUNTYWIDE  
UNDERSERVED PROJECT  
WEST CARROLL WATER DISTRICT  
CARROLL COUNTY, KENTUCKY**



**FIGURE 5**  
5104.002




**TANK 1 AND TANK 2 HGL WITH TWO HIGH SERVICE PUMPS OPERATING AND AN 8-INCH MAIN PARALLELING EXISTING 8-INCH**

**CARROLLTON UTILITIES COUNTYWIDE UNDERSERVED PROJECT  
WEST CARROLL WATER DISTRICT  
CARROLL COUNTY KENTUCKY**




**FIGURE 6  
5104.002**



**FUTURE SYSTEM PRESSURE WITH TWO HIGH SERVICE PUMPS  
 OPERATING AND A 10-INCH MAIN PARALLELING EXISTING 8-INCH  
 CARROLLTON UTILITIES COUNTYWIDE  
 UNDERSERVED PROJECT  
 WEST CARROLL WATER DISTRICT  
 CARROLL COUNTY, KENTUCKY**




**FIGURE 7**  
 5104.002



**TANK 1 AND TANK 2 HGL WITH TWO HIGH SERVICE PUMPS  
OPERATING AND A 10-INCH MAIN PARALLELING EXISTING 8-INCH  
CARROLLTON UTILITIES COUNTYWIDE  
UNDERSERVED PROJECT  
WEST CARROLL WATER DISTRICT  
CARROLL COUNTY, KENTUCKY**



**FIGURE 8  
5104.002**




**FUTURE SYSTEM PRESSURE WITH TWO HIGH SERVICE PUMPS OPERATING AND A12-INCH MAIN PARALLELING EXISTING 8-INCH**

**CARROLLTON UTILITIES COUNTYWIDE UNDERSERVED PROJECT  
WEST CARROLL WATER DISTRICT  
CARROLL COUNTY, KENTUCKY**



**FIGURE 9  
5104.002**





**TANK 1 AND TANK 2 HGL WITH TWO HIGH SERVICE PUMPS  
OPERATING AND A 12-INCH MAIN PARALLELING EXISTING 8-INCH  
CARROLLTON UTILITIES COUNTYWIDE  
UNDERSERVED PROJECT  
WEST CARROLL WATER DISTRICT  
CARROLL COUNTY, KENTUCKY**



**FIGURE 10  
5104.002**

**APPENDIX D**  
**DISTRIBUTION SYSTEM IMPROVEMENTS COST OPINION**

---

Countywide Underserved Project - Carrollton Utilities and West Carroll Water District  
Distribution System Improvements  
Project Construction Cost Opinion

CONTRACT 1-2012 Proposed Distribution System Improvements		OWNER: Carrollton Utilities/ WCWD		ENGINEER: Strand Associates, Inc. 325 West Main Street Louisville, KY 40202	
		BID / CHANGE ORDER			
NO.	ITEM	QTY	UNIT	UNIT COST	TOTAL
<b>LINE "A" PAINTERS RIDGE WATERLINE EXTENSION</b>					
1	3 IN PVC Pipe, furnishing, trenching, laying and backfilling. INCL all associated tees, reducers, and bends (unclassified excavation).	6,825	LF	\$6.00	\$40,950.00
2	Tie-in to existing water mains, INCL tapping saddle, tapping gate valve, etc. furnishing and installation, INCL unclassified excavation.	2	EA	\$1,500.00	\$3,000.00
3	3 IN C.I. AWWA N.R.S. gate valve and box, CIP.	2	EA	\$500.00	\$1,000.00
4	3 IN blowoff hydrant for all size water mains, INCL gate valve, box, and all appurtenances, CIP, as per detail.	1	EA	\$2,000.00	\$2,000.00
5	Stream crossing with 8 IN PVC SDR 35 cover pipe and concrete cap, INCL furnishing, material, and labor.	80	LF	\$50.00	\$4,000.00
6	Special creek crossing meter box per details, INCL valve, meter, meter box, etc. and furnishing, material, and labor.	1	EA	\$1,200.00	\$1,200.00
7	Stream crossing with crushed stone, INCL furnishing, material, and labor.	70	LF	\$40.00	\$2,800.00
8	Customer services opposite side of road as main with tandem meter setter and individual pressure reducing valve, CIP, as per detail.		EA	\$1,200.00	
9	Customer services same side of road as main with tandem meter setter and individual pressure reducing valve, CIP, as per detail.		EA	\$800.00	
10	Additional 3/4 IN service pipe, furnishing, trenching, laying and backfilling where required in addition to Items 5 & 6.		LF	\$10.00	
11	Cleanup and restoration, INCL furnishing, material, and labor.	6,825	LF	\$1.00	\$6,825.00
<b>TOTAL LINE "A" PAINTERS RIDGE WATERLINE EXTENSION</b>					<b>\$61,775.00</b>
<b>LINE "B" - KENDALL ROAD WATERLINE EXTENSION</b>					
1	3 IN PVC Pipe, furnishing, trenching, laying and backfilling. INCL all associated tees, reducers, and bends (unclassified excavation).	4,500	LF	\$6.00	\$27,000.00
2	Tie-in to existing water mains, INCL tapping saddle, tapping gate valve, etc. furnishing and installation, INCL unclassified excavation.	1	EA	\$1,500.00	\$1,500.00
3	3 IN C.I. AWWA N.R.S. gate valve and box, CIP.	2	EA	\$500.00	\$1,000.00
4	3 IN blowoff hydrant for all size water mains, INCL gate valve, box, and all appurtenances, CIP, as per detail.	1	EA	\$2,000.00	\$2,000.00

Countywide Underserved Project - Carrollton Utilities and West Carroll Water District  
Distribution System Improvements  
Project Construction Cost Opinion

NO.	ITEM	BID / CHANGE ORDER			
		QTY	UNIT	UNIT COST	TOTAL
5	Crushed rock on trench surface at roadway crossings, streets, and driveways.	30	LF	\$6.00	\$180.00
6	Customer services opposite side of road as main with tandem meter setter and individual pressure reducing valve, CIP, as per detail.		EA	\$1,200.00	
7	Customer services same side of road as main with tandem meter setter and individual pressure reducing valve, CIP, as per detail.		EA	\$800.00	
8	Additional 3/4 IN service pipe, furnishing, trenching, laying and backfilling where required in addition to Items 5 & 6.		LF	\$10.00	
9	Cleanup and restoration, INCL furnishing, material, and labor.	4,500	LF	\$1.00	\$4,500.00
<b>TOTAL LINE "B" - KENDALL ROAD WATERLINE EXTENSION</b>					<b>\$36,180.00</b>
<b>LINE "C" - MILLER'S BRANCH WATERLINE EXTENSION</b>					
1	3 IN PVC Pipe, furnishing, trenching, laying and backfilling. INCL all associated tees, reducers, and bends (unclassified excavation).	2,575	LF	\$6.00	\$15,450.00
2	Tie-in to existing water mains, INCL tapping saddle, tapping gate valve, etc. furnishing and installation, INCL unclassified excavation.	1	EA	\$1,500.00	\$1,500.00
3	3 IN C.I. AWWA N.R.S. gate valve and box, CIP.	2	EA	\$500.00	\$1,000.00
4	3 IN blowoff hydrant for all size water mains, INCL gate valve, box, and all appurtenances, CIP, as per detail.	1	EA	\$2,000.00	\$2,000.00
5	Stream crossing with 8 IN PVC SDR 35 cover pipe and concrete cap, INCL furnishing, material, and labor.	75	LF	\$50.00	\$3,750.00
6	Special creek crossing meter box per details, INCL valve, meter, meter box, etc. and furnishing, material, and labor.	2	EA	\$1,200.00	\$2,400.00
7	Stream crossing with crushed stone, INCL furnishing, material, and labor.	35	LF	\$40.00	\$1,400.00
8	Customer services opposite side of road as main with tandem meter setter and individual pressure reducing valve, CIP, as per detail.		EA	\$1,200.00	
9	Customer services same side of road as main with tandem meter setter and individual pressure reducing valve, CIP, as per detail.		EA	\$800.00	
10	Additional 3/4 IN service pipe, furnishing, trenching, laying and backfilling where required in addition to Items 5 & 6.		LF	\$10.00	
11	Cleanup and restoration, INCL furnishing, material, and labor.	2,575	LF	\$1.00	\$2,575.00

Countywide Underserved Project - Carrollton Utilities and West Carroll Water District  
Distribution System Improvements  
Project Construction Cost Opinion

NO.	ITEM	BID / CHANGE ORDER			TOTAL
		QTY	UNIT	UNIT COST	
<b>TOTAL LINE "C" - MILLER'S BRANCH WATERLINE EXTENSION</b>					<b>\$30,075.00</b>
<b>LINE "D" - HARDY CREEK WATERLINE EXTENSION</b>					
1	3 IN PVC Pipe, furnishing, trenching, laying and backfilling. INCL all associated tees, reducers, and bends (unclassified excavation).	2,800	LF	\$6.00	\$16,800.00
2	Tie-in to existing water mains, INCL tapping saddle, tapping gate valve, etc. furnishing and installation, INCL unclassified excavation.	1	EA	\$1,500.00	\$1,500.00
3	3 IN C.I. AWWA N.R.S. gate valve and box, CIP.	1	EA	\$500.00	\$500.00
4	3 IN blowoff hydrant for all size water mains, INCL gate valve, box, and all appurtenances, CIP, as per detail.	1	EA	\$2,000.00	\$2,000.00
5	Stream crossing with 8 IN PVC SDR 35 cover pipe and concrete cap, INCL furnishing, material, and labor.	130	LF	\$50.00	\$6,500.00
6	Special creek crossing meter box per details, INCL valve, meter, meter box, etc. and furnishing, material, and labor.	2	EA	\$1,200.00	\$2,400.00
7	8 IN steel cover pipe, furnishing and installing, trenching under state maintained roads, INCL unclassified boring and/or jacking (water pipe not included).	30	LF	\$90.00	\$2,700.00
8	Customer services opposite side of road as main with tandem meter setter and individual pressure reducing valve, CIP, as per detail.		EA	\$1,200.00	
9	Customer services same side of road as main with tandem meter setter and individual pressure reducing valve, CIP, as per detail.		EA	\$800.00	
10	Additional 3/4 IN service pipe, furnishing, trenching, laying and backfilling where required in addition to Items 5 & 6.		LF	\$10.00	
11	Cleanup and restoration, INCL furnishing, material, and labor.	2,800	LF	\$1.00	\$2,800.00
<b>TOTAL LINE "D" - HARDY CREEK WATERLINE EXTENSION</b>					<b>\$35,200.00</b>
<b>LINE "E" - US 42/KY 36 WATER MAIN EXTENSION</b>					
1	6 IN PVC Pipe furnishing, trenching, laying and backfilling. INCL all associated tees, reducers, and bends (unclassified excavation).	9,600	LF	\$10.00	\$96,000.00
2	6 DIP PVC Pipe furnishing, trenching, laying and backfilling. INCL all associated tees, reducers, and bends (unclassified excavation).	2,000	LF	\$20.00	\$40,000.00
3	Tie-in to existing water mains, INCL tapping saddle, tapping gate valve, etc. furnishing and installation, INCL unclassified excavation.	2	EA	\$2,000.00	\$4,000.00
4	6 IN C.I. AWWA N.R.S. gate valve and box, CIP.	6	EA	\$1,000.00	\$6,000.00

Countywide Underserved Project - Carrollton Utilities and West Carroll Water District  
Distribution System Improvements  
Project Construction Cost Opinion

NO.	ITEM	BID / CHANGE ORDER			TOTAL
		QTY	UNIT	UNIT COST	
5	Stream crossing with 12 IN PVC SDR 35 cover pipe and concrete cap, INCL furnishing, material, and labor.	90	LF	\$75.00	\$6,750.00
6	Special creek crossing meter box per details, INCL valve, meter, meter box, etc. and furnishing, material, and labor.	3	EA	\$1,300.00	\$3,900.00
7	12 IN steel cover pipe, furnishing and installing, trenching under state maintained roads, INCL unclassified boring and/or jacking (water pipe not included).	150	LF	\$150.00	\$22,500.00
8	Customer services opposite side of road as main with tandem meter setter and individual pressure reducing valve, CIP, as per detail.		EA	\$1,200.00	
9	Customer services same side of road as main with tandem meter setter and individual pressure reducing valve, CIP, as per detail.		EA	\$800.00	
10	Additional 3/4 IN service pipe, furnishing, trenching, laying and backfilling where required in addition to Items 5 & 6.		LF	\$10.00	
11	Cleanup and restoration, INCL furnishing, material, and labor.	9,600	LF	\$1.00	\$9,600.00
12	Stream crossing with 16" PE Directional Drill and 6" PE Water main, furnishing, trenching, laying and backfilling. INCL all associated tees, reducers, and bends (unclassified excavation).	300	LF	\$175.00	\$52,500.00
13	Automatic air release valve assembly and box, CIP, as per detail.	1	EA	\$1,200.00	\$1,200.00
<b>TOTAL LINE "E" - US 42/KY 36 WATER MAIN EXTENSION</b>					<b>\$242,450.00</b>
<b>LINE "F" - MOUND HILL WATERLINE EXTENSION</b>					
1	3 IN PVC Pipe furnishing, trenching, laying and backfilling. INCL all associated tees, reducers, and bends (unclassified excavation).	1,500	LF	\$6.00	\$9,000.00
2	Tie-in to existing water mains, INCL tapping saddle, tapping gate valve, etc. furnishing and installation, INCL unclassified excavation.	2	EA	\$1,500.00	\$3,000.00
3	Customer services opposite side of road as main with tandem meter setter and individual pressure reducing valve, CIP, as per detail.		EA	\$1,200.00	
4	Customer services same side of road as main with tandem meter setter and individual pressure reducing valve, CIP, as per detail.		EA	\$800.00	
5	Additional 3/4 IN service pipe, furnishing, trenching, laying and backfilling where required in addition to Items 5 & 6.		LF	\$10.00	
6	Crushed rock on trench surface at roadway crossings, streets, and driveways.	30	LF	\$6.00	\$180.00
7	Cleanup and restoration, INCL furnishing, material, and labor.	1,500	LF	\$1.00	\$1,500.00

Countywide Underserved Project - Carrollton Utilities and West Carroll Water District  
Distribution System Improvements  
Project Construction Cost Opinion

NO.	ITEM	BID / CHANGE ORDER			TOTAL
		QTY	UNIT	UNIT COST	
<b>TOTAL LINE "F" - MOUND HILL WATERLINE EXTENSION</b>					<b>\$13,680.00</b>
<b>LINE "G" - GILGAL ROAD WATER MAIN REPLACEMENT</b>					
1	4 IN DIP furnishing, trenching, laying and backfilling. INCL all associated tees, reducers, and bends (unclassified excavation).	6,000	LF	\$20.00	\$120,000.00
2	Tie-in to existing water mains, INCL tapping saddle, tapping gate valve, etc. furnishing and installation, INCL unclassified excavation.	1	EA	\$1,500.00	\$1,500.00
3	4 IN C.I. AWWA N.R.S. gate valve and box, CIP.	2	EA	\$550.00	\$1,100.00
4	10 IN steel cover pipe, furnishing and installing, trenching under state maintained roads, INCL unclassified boring and/or jacking (water pipe not included).	30	LF	\$95.00	\$2,850.00
5	Customer services opposite side of road as main with tandem meter setter and individual pressure reducing valve, CIP, as per detail.		EA	\$1,200.00	
6	Customer services same side of road as main with tandem meter setter and individual pressure reducing valve, CIP, as per detail.		LF	\$800.00	
7	Additional 3/4 IN service pipe, furnishing, trenching, laying and backfilling where required in addition to Items 5 & 6.	300	EA	\$10.00	\$3,000.00
8	Cleanup and restoration, INCL furnishing, material, and labor.	6,000	EA	\$1.00	\$6,000.00
9	Stream crossing with crushed stone, INCL furnishing, material, and labor.	65	LF	\$40.00	\$2,600.00
<b>TOTAL LINE "G" - GILGAL ROAD WATER MAIN REPLACEMENT</b>					<b>\$137,050.00</b>
<b>LINE "H" - NORA LANE WATERLINE EXTENSION</b>					
1	3 IN PVC, furnishing, trenching, laying and backfilling. INCL all associated tees, reducers, and bends (unclassified excavation).	2,550	LF	\$6.00	\$15,300.00
2	Tie-in to existing water mains, INCL tapping saddle, tapping gate valve, etc. furnishing and installation, INCL unclassified excavation.	1	EA	\$1,500.00	\$1,500.00
3	3 IN blowoff hydrant for all size water mains, INCL gate valve, box, and all appurtenances, CIP, as per detail.	1	EA	\$2,000.00	\$2,000.00
4	3 IN C.I. AWWA N.R.S. gate valve and box, CIP.	1	LF	\$500.00	\$500.00
5	8 IN steel cover pipe, furnishing and installing, trenching under state maintained roads, INCL unclassified boring and/or jacking (water pipe not included).	50	LF	\$90.00	\$4,500.00
6	Customer services opposite side of road as main with tandem meter setter and individual pressure reducing valve, CIP, as per detail.		LF	\$1,200.00	

Countywide Underserved Project - Carrollton Utilities and West Carroll Water District  
 Distribution System Improvements  
 Project Construction Cost Opinion

NO.	ITEM	BID / CHANGE ORDER			TOTAL
		QTY	UNIT	UNIT COST	
7	Customer services same side of road as main with tandem meter setter and individual pressure reducing valve, CIP, as per detail.		EA	\$800.00	
8	Additional 3/4 IN service pipe, furnishing, trenching, laying and backfilling where required in addition to Items 5 & 6.		EA	\$10.00	
9	Cleanup and restoration, INCL furnishing, material, and labor.	2,550	EA	\$1.00	\$2,550.00
<b>TOTAL LINE "H" - NORA LANE WATERLINE EXTENSION</b>					\$26,350.00
<b>TOTAL ALL LINES</b>					\$582,760.00
<b>Kings Ridge Road Booster Pump Station</b>					
1	Pump station includes furnishing, trenching, laying, building, foundation, telemetry system, electrical, all taps into existing mains, line work, and backfilling, including all associated tees, reducers, and bends. (Unclassified excavation)	1	EA	\$95,000.00	\$95,000.00
<b>TOTAL -Kings Ridge Road Booster Pump Station</b>					\$95,000.00
<b>Gilgal Road Booster Pump Station</b>					
1	Pump station includes furnishing, trenching, laying, building, foundation, telemetry system, electrical, all taps into existing mains, line work, and backfilling, including all associated tees, reducers, and bends. (Unclassified excavation)	1	EA	\$85,000.00	\$85,000.00
<b>TOTAL -Gilgal Road Booster Pump Station</b>					\$85,000.00
<b>TOTAL ALL BOOSTER PUMP STATIONS</b>					\$180,000.00
<b>PROJECT CONTINGENCIES</b>					\$76,276.00
<b>TOTAL PROJECT COST OPINION</b>					<b>\$839,036.00</b>