

SPRAGENS & HIGDON, P.S.C.

ATTORNEYS AT LAW

ROBERT SPRAGENS, JR.*
FREDERICK A. HIGDON

P. O. BOX 681 - 15 COURT SQUARE
LEBANON, KENTUCKY 40033-0681
TELEPHONE (270) 692-3141
FAX: (270) 692-6693

ROBERT SPRAGENS, SR.
(1920-1998)

*ALSO ADMITTED IN GEORGIA

GENERAL E-MAIL: sh@spragenshigdonlaw.com
WRITER'S E-MAIL: rspragens@spragenshigdonlaw.com

April 2, 2014

Mr. Jonathan Beyer, Esq.
Staff Attorney
Kentucky Public Service Commission
211 Sower Boulevard
P.O. Box 615
Frankfort, Kentucky 40602

RECEIVED

APR 17 2014

PUBLIC SERVICE
COMMISSION

Re: PSC Case No. 2013-00165
McAninch v. Taylor RECC

Dear Mr. Beyer:

This will acknowledge receipt of your email of yesterday which follows up on the February 27th informal conference conducted in this case.


Consistent with the understanding reached at the informal conference, Mike Skaggs, Taylor County's E & O Manager, made arrangements to meet with Mr. McAninch at the McAninch property in Casey County on March 6th. As a result of that on site meeting, and a March 7th follow-up phone discussion, Mr. McAninch and Mr. Skaggs apparently reached an understanding about McAninch's request for additional service, and that understanding is memorialized in March 10th correspondence from Skaggs to McAninch, a copy of which is attached hereto.

Mr. McAninch was to undertake some further study of the proposal which he and Mr. Skaggs had discussed, after which McAninch would notify Skaggs of his final decision so that the matter could go forward. I checked with Mr. Skaggs yesterday afternoon, and he is still awaiting final approval from Mr. McAninch. Accordingly, I would think it appropriate that this matter be diaried forward another 30 days in order to see if the parties have reached an accord.

With kind regards, I remain,

Very truly yours,

SPRAGENS & HIGDON, P.S.C.


Robert Spragens, Jr.

RS, JR :dlg

cc : Mr. Frank McAninch

Enclosures

Taylor County
Rural Electric Cooperative
Corporation

COPY
mailed 3/11/14

P. O. BOX 100
CAMPBELLSVILLE, KENTUCKY 42719

(270) 465-4101 • Fax (270) 789-3625
(800) 931-4551

3/10/14

Frank,

Following up on our on-site meeting March 6th, below are Taylor County RECC(TCRECC) requirements in order to provide service to your kiln via a 'non sawmill' tariff. Per discussions at our recent PSC visit, we do need to concentrate on the kiln specifically.

As discussed at our March 6th on-site meeting, TCRECC will build its facilities to match facilities installed by you. Therefore, if the existing single phase main remains in the kiln, and a single phase meter base is added, then a single phase line would be applicable. However, if a three phase main and meter base(per your request of a 400a 120/240v 3phase service) were installed at the kiln, then a three phase line would be applicable.

As discussed, regardless of which avenue you chose, your facilities would need to be in place and an inspection obtained and passed on to TCRECC – the inspectors do call in inspection information but it would be a good idea for you to give our Engineering Department a call as well to advise that the inspection has taken place. Upon receipt of the inspection and verification that installation is as agreed upon, then job would be released to our construction department.

Upon building of the job, TCRECC would place the meter and the transformer(s) would be energized. At this point, minimum billing would be in force if applicable - monthly charge is based on installed transformer capacity, in your case 45kva if 3phase option is chosen.

So, after making your decision, advise TCRECC as such and we'll finalize required job paperwork etcetera. Additionally, we'll have another conversation and/or on-site meeting to verify that we are on the same page and can indeed move forward.

Upon reviewing my notes related to our March 7th phone discussion, I think you'll find that the above requirements may provide a solution to this issue.

Please Advise.


Mike Skaggs
E&O Manager
Taylor County RECC