

JOHN N. HUGHES  
ATTORNEY AT LAW  
PROFESSIONAL SERVICE CORPORATION  
124 WEST TODD STREET  
FRANKFORT, KENTUCKY 40601

TELEPHONE: (502) 227-7270

[JNHUGHES@fewpb.net](mailto:JNHUGHES@fewpb.net)

RECEIVED

JUN 03 2015

PUBLIC SERVICE  
COMMISSION

June 4, 2015

Jeff Derouen  
Executive Director  
Public Service Commission  
211 Sower Blvd.  
Frankfort, KY 40601

Re: Green River Valley Water District  
Case No. 2015-00133


Dear Mr. Derouen:

Pursuant to the Staff's telephonic request yesterday, the following information is provided:

- (1) The reference to \$431,593 is paragraph 6 of the Application should be corrected to \$314,093.59.
- (2) Paragraph 5 of the Application is supplemented as follows: The proposed generator has adequate power to run the water treatment plant and the high service pumps at 100% of the plant's capacity. The high service pumps are divided into three separate pump stations. Under this contract the wiring will be installed to power the plant and one high service pump station. The wiring to the other high service pump stations will be installed in the near future when the plant is expanded. The Water District is currently preparing an application to Rural Development for the plant expansion project.

If you have any questions about this filing, please contact me.

Submitted By:



John N. Hughes  
124 West Todd St.  
Frankfort, KY 40601  
502 227 7270  
[jnhughes@fewpb.net](mailto:jnhughes@fewpb.net)

Attorney for Green River Valley Water District