

Matthew G. Bevin  
Governor

Charles G. Snively  
Secretary  
Energy and Environment Cabinet



Commonwealth of Kentucky  
**Public Service Commission**

211 Sower Blvd.  
P.O. Box 615  
Frankfort Kentucky 40602-0615  
Telephone: (502) 564-3940  
Fax: (502) 564-3460  
psc.ky.gov

Michael J. Schmitt  
Chairman

Robert Cicero  
Vice Chairman

Daniel E. Logsdon Jr.  
Commissioner

February 06, 2017

**PARTIES OF RECORD**

RE: Case No. **2016-00424**

Western Fleming County Water District  
(Deviation)  
807 KAR 5:066, Section 4(4)

The Commission Staff has reviewed the filing submitted February 03, 2017 and has determined that the application in the above case now meets the minimum filing requirements. Attached please find a stamped filed copy of the first page of your filing. This case has been docketed and will be processed as expeditiously as possible.

If you need further assistance, please contact my staff at 502-564-3940.

Sincerely,

A handwritten signature in black ink that reads "Talina R. Mathews".

Talina R. Mathews  
Executive Director

TM/rs

RECEIVED

KENTUCKY PUBLIC SERVICE COMMISSION

DEC 6 2016

Public Service Commission

Water Storage Requirement Deviation Request Application

807 KAR 5:066, Section 4(4): Storage. The minimum storage capacity for systems shall be equal to the average daily consumption.

FILED
FEB 03 2017
PUBLIC SERVICE COMMISSION

This form is intended to assist water utilities seeking a deviation from the requirements of 807 KAR 5:066, Section 4(4) and for permission to either maintain less water storage capacity than the average daily consumption or to obtain additional time to attain minimum storage capacity equal to the average daily consumption.

To request a deviation from the requirements of 807 KAR 5:066, Section 4(4), please complete the following application in full.

Utility: Western Fleming County Water District

Address: 1500 Ewing Road

City: Ewing State: Ky Zip Code: 41039

Telephone Number: (606) 267-2120 Number of Customers: 1487

County or Counties served: Fleming Robertson Nicholas

Are you requesting a deviation:

- (checked) To maintain less water storage capacity than the average daily consumption?
(checked) For additional time to attain minimum storage capacity equal to the average daily consumption?

\*Patrick E. Price  
Suit, Price, Price & Ruark, PLLC Attorneys at Law  
207 Court Square  
Flemingsburg, KENTUCKY 41041

\*Western Fleming County Water District  
1500 Ewing Road  
P. O. Box 16  
Ewing, KY 41039

\*Vernon Barton  
Chairman  
Western Fleming County Water District  
1500 Ewing Road  
P. O. Box 16  
Ewing, KY 41039