

Matthew G. Bevin
Governor

Charles G. Snaveley
Secretary
Energy and Environment Cabinet



Commonwealth of Kentucky
Public Service Commission
211 Sower Blvd.
P.O. Box 615
Frankfort, Kentucky 40602-0615
Telephone: (502) 564-3940
Fax: (502) 564-3460
psc.ky.gov

Michael J. Schmitt
Chairman

Robert Cicero
Vice Chairman

Talina R. Mathews
Commissioner

July 14, 2017

PARTIES OF RECORD

Re: Case No. 2016-00432

Attached is a copy of a memorandum which is being filed in the record of the above-referenced case. If you have any comments you would like to make regarding the contents of the memorandum please do so within five days of receipt of this letter.

If you have any questions, please contact Jennifer Fell, Commission Staff Attorney, at 502-782-2581.

Sincerely,

A handwritten signature in blue ink, appearing to read "John S. Lyons".

John S. Lyons
Acting Executive Director

JLF/ph

Attachments

INTRA-AGENCY MEMORANDUM ADDENDUM

KENTUCKY PUBLIC SERVICE COMMISSION

TO: Case File – Case No. 2016-00432
FROM: Jennifer Fell, Staff Attorney
DATE: July 13, 2017
RE: Informal Conference of July 13, 2017

Pursuant to Commission Staff's ("Staff") July 13, 2017 notice, an informal teleconference ("IC") was held in this matter on July 13, 2017. A list of attendees is attached.

A discussion was held regarding Hardin County Water District No. 2's ("Hardin No. 2") answer to Commission Staff's Second Request for Information, Item No. 5, which proposes that Hardin No. 2 use the ANSI Standard's Double Specification Limit ("DSL") for testing of maximum and intermediate flows on its meters, and the Single Specification Limit ("SSL") for testing low flows, due to an asymmetry in using DSL for low flow meter testing. Staff requested that within 14 days, Hardin No. 2 file into the record further information and support regarding the appropriateness of using both DSL and SSL under its proposed sample meter testing program.

Hardin No. 2 informed Staff that it has approved a pilot leak detection program and will be hiring an expert to inspect a targeted geographical area of its pipes for leaks, which were acquired along with the city of Elizabethtown's system, and hopes in the future to complete an inspection of all pipes that were acquired from the city of Elizabethtown. Staff requested that Hardin No. 2 supplement its responses to Staff's Requests for Information to reflect these measures to decrease line loss.

Finding that no party had any further questions, the conference was adjourned.

Attachment

COMMONWEALTH OF KENTUCKY
BEFORE THE PUBLIC SERVICE COMMISSION

In the Matter of:

ELECTRONIC APPLICATION OF)
HARDIN COUNTY WATER DISTRICT)
NO. 2 FOR A DECLARATORY ORDER)
THAT SAMPLE TESTING)
SATISFIES THE TESTING)
REQUIREMENTS OF 807 KAR)
5:066 SECTION 16(1) OR, IN THE)
ALTERNATIVE, FOR AN ORDER)
GRANTING A DEVIATION FROM)
807 KAR 5:066 SECTION 16(1))

CASE NO. 2016-00432

SIGN IN

July 13, 2017

PERSON

REPRESENTING

Jennifer Fell

PSC - Legal

Chris Pugh

PSC - DOI

Sam Kent

PSC

Ben L. Rice

PSC

Damon Talley

Stoll Keener Ogden PLLC for Hardin County

James Jeffries

Water District No. 2

Scott Clark

PSC

Forest Pollock

Hardin County Water Dist. No. 2

Nancy Ellen Wemberly

" "

" "

Stoll Keener Ogden PLLC for Hardin Co.

Water Dist. No. 2

*Honorable Damon R Talley
Attorney at Law
Stoll Keenon Ogden PLLC
P.O. Box 150
Hodgenville, KENTUCKY 42748

*Gerald E Wuetcher
Attorney at Law
STOLL KEENON OGDEN PLLC
300 West Vine Street
Suite 2100
Lexington, KENTUCKY 40507-1801

*Hardin County Water District #2
360 Ring Road
P. O. Box 970
Elizabethtown, KY 42702-0970

*James R Jeffries
Hardin County Water District #2
P. O. Box 970
Elizabethtown, KY 42702-0970

*Mary Ellen Wimberly
STOLL KEENON OGDEN PLLC
300 West Vine Street
Suite 2100
Lexington, KENTUCKY 40507-1801