## COMMONWEALTH OF KENTUCKY BEFORE THE PUBLIC SERVICE COMMISSION

In	the	1/1	ttor	of.
ın	me	IVI	amer	OT:

BRANDON AND TABITHA SWAFFORD	)
COMPLAINANT	)
V.  NORTH MANCHESTER WATER ASSOCIATION, INC.	) CASE NO. ) 2019-00457 )
DEFENDANT	)

## ORDER

On April 15, 2020, the Commission ordered both parties to file monthly status reports updating the progress of the construction project undertaken by North Manchester Water Association, Inc. (North Manchester Water) to remedy low water pressure provided to residential customers, Brandon and Tabitha Swafford (Swaffords). At the September 29, 2020 hearing in this matter, North Manchester Water and the Swaffords both reported that the project had been completed and that the water pressure was measured at 52–53 pounds per square inch (psi), which is higher than the regulatory minimum of 30 psi.

Because the construction project has been completed and the parties are satisfied with the result, the Commission finds there is no further purpose in filing monthly status reports, and therefore the parties should be relieved of the requirement to file said reports.

IT IS THEREFORE ORDERED that the parties are relieved of the requirement to file monthly status reports.

## By the Commission

ENTERED OCT 05 2020

KENTUCKY PUBLIC SERVICE COMMISSION

ATTEST:

Acting Executive Director

\*North Manchester Water Association, Inc. 7362 N Highway 421 Manchester, KY 40962

\*Steve Davis President North Manchester Water Association, Inc. 7362 N Highway 421 Manchester, KY 40962

\*Raleigh P. Shepherd Attorney at Law 305 Main Street Manchester, KENTUCKY 40962

\*Tabitha Swafford 2885 Upper Rader Road Manchester, KENTUCKY 40962

\*Brandon Swafford 2885 Upper Rader Road Manchester, KENTUCKY 40962