

SPECIFICATIONS AND CONTRACT DOCUMENTS
BIG SANDY WATER DISTRICT, BOYD COUNTY, KENTUCKY
WATER BOOSTER PUMP STATION – UPGRADES
CONTRACT G-1

BID OPENING: THURSDAY JUNE 13, 2019, 12:00 NOON LOCAL TIME

ADDENDUM NO. 2

June 11, 2019


DRAWINGS

Drawings – Sheet 2 of 5

Relative to both New Pump Stations, due to the isolation check valves, the electric check valve is redundant and **NOT** needed.

Bidders for this Contract must acknowledge this Addendum No. 2 on the bid documents.

Sisler – Maggard Engineering, PLLC



Joseph F. Sisler, P.E., P.L.S., President