

SPECIFICATIONS AND CONTRACT DOCUMENTS

BIG SANDY WATER DISTRICT, BOYD COUNTY, KENTUCKY

STREAM CROSSING REPLACEMENTS AND SERVICE LINE REPLACEMENTS

CONTRACT H-1

BID OPENING: THURSDAY JUNE 13, 2019, 12:00 NOON LOCAL TIME

ADDENDUM NO. 2

June 12, 2019

SPECIFICATIONS

Section 4 – Special Conditions

Paragraph 18 – Time of completion should be 210 calendar days. Time of completion is reflected correctly in **ALL** other places in specifications.

Section 5 – Technical Specifications

Section 01740 – Basis of Payment

Page 01740-5, Item 23 – Reconnect Meters


Payment for this item shall be made at the unit price bid each installed and shall include all work, excavation and materials necessary for the complete location and disconnection and reconnection to the existing water meter, including, locating the **existing** tapped connection and corporation stop **in the main water line**, and connecting new service lines **to existing corporation stop**, bedding, testing, backfill, clean-up and seeding all in accordance with the Technical Specifications and details. **No new tapped connection or corporation stop is required.**

The cost of all associated items not specifically listed for separate payment in the proposal shall be included as an incidental expense.

Rock excavation is **not** a separate pay item.

Bidders for this Contract must acknowledge this Addendum No. 2 on the bid documents.

Sisler – Maggard Engineering, PLLC



Joseph F. Sisler, P.E., P.L.S., President