

SPECIFICATIONS AND CONTRACT DOCUMENTS

BIG SANDY WATER DISTRICT, BOYD COUNTY, KENTUCKY

STREAM CROSSING REPLACEMENTS AND SERVICE LINE REPLACEMENTS

CONTRACT H-1

BID OPENING: THURSDAY JUNE 13, 2019, 12:00 NOON LOCAL TIME

ADDENDUM NO. 1

June 7, 2019

SPECIFICATIONS

Section 5 – Technical Specifications

1. Section 15080 – Standard Services and/or Service Line Replacements.

Page 15080-2, Paragraph 2.03 Service Pipe.

Service Pipe shall be PE 4710 High Density Polyethylene Pipe (3/4" or 1") with Pressure Rating of 250 psi. as produced by ENDOT Industries or approved equal.


2. Section 2702 – High Density Polyethylene (HDPE) Pipe and Fittings

Page 2702 – 14 Paragraph 3.09 Service Tapping Equipment

This project **DOES NOT** require furnishing tapping equipment.

Bidders for this Contract must acknowledge this Addendum No. 1 on the bid documents.

Sisler – Maggard Engineering, PLLC



Joseph F. Sisler, P.E., P.L.S., President