

COMMONWEALTH OF KENTUCKY  
BEFORE THE PUBLIC SERVICE COMMISSION

In the Matter of:


KENTUCKY FRONTIER GAS, LLC )  
 )  
 )  
 )

\_\_\_\_\_  
ALLEGED VIOLATION OF UNDERGROUND )  
FACILITY DAMAGE PREVENTION ACT )

CASE NO.  
2019-00318

NOTICE OF FILING

Notice is given to all parties that the Gas Excavation Damage Report for Incident 31332 has been filed into the record for this proceeding.



\_\_\_\_\_  
Gwen R. Pinson  
Executive Director  
Public Service Commission  
P.O. Box 615  
Frankfort, KY 40602

DATED OCT 31 2019

cc: Parties of Record

# Gas Excavation Damage Report

## Kentucky Frontier Gas, LLC

Submitted 2/18/2019 Incident ID: 31332

[Set back to Edit](#)

[Staff Edit](#)

[Print](#)

Reported By:

Name:

Heather Music

Phone:

606-886-2431 ext 100

Email:

hmusic@kyfrontiergas.com

Gas Line Incident Occured:

Date:

1/23/2019

Time:

9:30 AM

Details:

Reported Date: 2/18/2019 2:22 PM

Incident Location Address:

Location:

37.68307 -82.82172

Address:

Abbott Creek Road

City:

Prestonsburg

State:

KY

County:

Floyd

Zip:

41653

Confirm Code:

Address	City	State	
ZipCode	County	State	

Number of Customers out: 50

Locate Request Ticket No.: NA

**Excavator:** Contractor

Organization ID	Company	Status	Company Type
-----------------	---------	--------	--------------

Excavator Address:

First Name:

Louie

Last Name:

Messer

Organization ID:

Company:

Water Dawgs Construction

Phone:

304-928-8875

Email:

Address:

7435 S Ky Route 321

City:

Hagerhill

State:

KY

Zip:

41222

Confirm Code:

Y

Address	City	State
ZipCode	County	State

Excavation Damage: No notification made to the One Call Center

**Description of Incident** While doing a bore job, construction company hit a 4" main line.

Summary Information *2/18/2019*

**Full details such as the cause** While doing a bore job for Boca Engineering Company, the mole being used by the construction company came in contact with and damaged KFG's 4" main line. KFG technicians shut down a critical valve to make the situation safe and ready for repair, this caused loss of gas service to

around 50 customers. After repairing the line, technicians went to each affected customer and restored gas service. KFG was aware of a job being done in the area and had indicated to Boca Engineering that there were lines in the area.

**Extent of the damage**

Only one small section of line was damaged but due to size of pipe there was a moderate loss of gas.

**Cost of the damage**

\$900.00

**Steps taken to prevent re-occurrence**

KFG construction supervisor discussed 811 regulations and also stated that we would have someone come out to the work site if they were doing any more jobs in the area.

**Amount billed to excavator**

\$0.00

CT Corporation System Register Agent  
306 W Main Street, Suite 512  
Frankfort, KENTUCKY 40601

\*Honorable John N Hughes  
Attorney at Law  
124 West Todd Street  
Frankfort, KENTUCKY 40601

\*Kentucky Frontier Gas, LLC  
4891 Independence Street, Suite 200  
Wheat Ridge, CO 80033

\*Kentucky Frontier Gas, LLC  
Kentucky Frontier Gas, LLC  
4891 Independence Street, Suite 200  
Wheat Ridge, CO 80033