

COMMONWEALTH OF KENTUCKY
BEFORE THE PUBLIC SERVICE COMMISSION

In the Matter of:

JOEY HODGES


ALLEGED VIOLATION OF UNDERGROUND
FACILITY DAMAGE PREVENTION ACT

)
)
)
)
)
)

CASE NO.
2019-00336

NOTICE OF FILING

Notice is given to all parties that the Gas Excavation Damage Report for Incident 21169 has been filed into the record of this proceeding.



Gwen R. Pinson
Executive Director
Public Service Commission
P.O. Box 615
Frankfort, KY 40602

DATED NOV 01 2019

cc: Parties of Record

Gas Excavation Damage Report

City of Lewisport Natural Gas System

Submitted 11/26/2018 Incident ID: 21169

[Set back to Edit](#)

[Staff Edit](#)

[Print](#)

Reported By:

Name:

Jason Roberts

Phone:

Email:

Gas Line Incident Occured:

Date:

11/17/2018

Time:

12:19 PM

Details:

Reported Date: 11/26/2018 4:18 PM

Incident Location Address:

Location:

738 Sand Hill Road/Front of Property

Address:

738 Sand Hill Rd

City:

Lewisport

State:

KY

County:

Hancock

Zip:

42351

Confirm Code:

Y

Address	City	State	
ZipCode	County	State	

Number of Customers out: 0

Locate Request Ticket No.: N/A

Excavator: Home Owner

Organization ID	Company	Status	Company Type
-----------------	---------	--------	--------------

Excavator Address:

First Name:

Joey

Last Name:

Hodges

Organization ID:

Company:

Phone:

270-295-6625

Email:

Address:

738 Sand Hill Rd

City:

Lewisport

State:

KY

Zip:

42351

Confirm Code:

Y

Address	City	State
ZipCode	County	State

Excavation Damage: One Call notification practices not sufficient

Description of Incident

Gas Department was notified by Hancock County Dispatch and reported a gas leak on 738 Sand Hill Road. Arrived on scene to find a 2" PE Gas main damaged by a trencher. Customer was trenching water service to the house.

Summary Information 11/26/2018

Full details such as the cause Trencher was being used to trench in new water service at the above address. Customer did not call in a 811 Locate ticket.

Extent of the damage	2" PE Main was cut in a couple places. Main was squeezed off from both directions long enough to install new section of pipe.
Cost of the damage	\$300.00
Steps taken to prevent re-occurrence	Notified customer that it is the state law to contact 811 before and digging can take place
Amount billed to excavator	\$0.00

Joey Hodges
738 Sand Hill Road
, KENTUCKY 42351