



GERALD WUETCHER
DIRECT DIAL: (859) 231-3017
DIRECT FAX: (859) 259-3517
gerald.wuetcher@skofirm.com

300 WEST VINE STREET
SUITE 2100
LEXINGTON, KY 40507-1801
MAIN: (859) 231-3000
FAX: (859) 253-1093

January 18, 2022

Ms. Linda C. Bridwell, P.E.
Executive Director
Kentucky Public Service Commission
P.O. Box 615
Frankfort, KY 40602-0615

RECEIVED
JAN 18 2022
PUBLIC SERVICE
COMMISSION

Re: Case No. 2019-00375
Green River Valley Water District

Dear Ms. Bridwell:

Enclosed for filing in the above-referenced matter is Green River Valley Water District's Motion to Dismiss.

Sincerely,

Stoll Keenon Ogden PLLC

A handwritten signature in blue ink that reads "Gerald E. Wuetcher".

Gerald E. Wuetcher

GEW
Enclosure

COMMONWEALTH OF KENTUCKY
BEFORE THE PUBLIC SERVICE COMMISSION

In the Matter of:

TRACY KAY SANDERS)	
)	
COMPLAINANT)	
)	
v.)	CASE NO. 2019-00375
)	
GREEN RIVER VALLEY WATER DISTRICT)	
)	
DEFENDANT)	


MOTION TO DISMISS

Pursuant to 807 KAR 5:001, Section 20(5), Green River Valley Water District (“Green River District”) moves for dismissal of the Complaint in this matter. Based upon the information set forth in its responses to Commission Staff’s Requests for Information and its Status Reports to the Commission, Green River District has demonstrated that it has satisfied the Complaint, has installed the necessary infrastructure to provide water service to the Complainant at a pressure consistent with the requirements of 807 KAR 5:066, Section 5, and has been providing such service since December 15, 2021.

WHEREFORE, Green River District requests that the Commission dismiss the Complaint and remove this case from its docket.

Dated: January 18, 2022

Respectfully submitted,




Patrick A. Ross
hrh@scrtc.com
Hensley & Ross Attorneys
P.O. Box 350
Horse Cave, Kentucky 42749
Telephone: (270) 786-2155
Fax: (270) 786-2118

Gerald E. Wuetcher
gerald.wuetcher@skofirm.com
Stoll Keenon Ogden PLLC
300 West Vine St. Suite 2100
Lexington, Kentucky 40507-1801
Telephone: (859) 231-3017
Fax: (859) 259-3517

Counsel for Green River Valley Water District

CERTIFICATE OF SERVICE

In accordance with 807 KAR 5:001, Section 6, I certify that a true and accurate copy of this Motion was served by U.S. Mail, postage prepaid, on Tracy Kay Sanders, 1134 Bunnell Crossing Road, Munfordville, Kentucky 42765 on January 18, 2022. I further certify that an electronic copy of this Motion was transmitted to the Public Service Commission on January 18, 2022 by electronic mail to psced@ky.gov.



Counsel for Green River Valley Water District

COMMONWEALTH OF KENTUCKY
BEFORE THE PUBLIC SERVICE COMMISSION

In the Matter of:


TRACY KAY SANDERS)	
)	
COMPLAINANT)	
)	
v.)	CASE NO. 2019-00375
)	
GREEN RIVER VALLEY WATER DISTRICT)	
)	
DEFENDANT)	

**RESPONSE OF GREEN RIVER VALLEY WATER DISTRICT
TO COMMISSION STAFF'S SECOND REQUEST FOR INFORMATION**

Green River Valley Water District submits its Response to Commission Staff's Second Request for Information.

Dated: January 18, 2022

Respectfully submitted,




Patrick A. Ross
hrh@scrtc.com
Hensley & Ross Attorneys
P.O. Box 350
Horse Cave, Kentucky 42749
Telephone: (270) 786-2155
Fax: (270) 786-2118

Gerald E. Wuetcher
gerald.wuetcher@skofirm.com
Stoll Keenon Ogden PLLC
300 West Vine St. Suite 2100
Lexington, Kentucky 40507-1801
Telephone: (859) 231-3000
Fax: (859) 259-3517

Counsel for Green River Valley Water District

CERTIFICATE OF SERVICE

In accordance with 807 KAR 5:001, Section 6, I certify that a true and accurate copy of this Response was served by U.S. Mail, postage prepaid, on Tracy Kay Sanders, 1134 Bunnell Crossing Road, Munfordville, Kentucky 42765 on January 19, 2022. I further certify that an electronic copy of this Response was transmitted to the Public Service Commission on January 19, 2022 by electronic mail to psced@ky.gov.

A handwritten signature in blue ink, appearing to read "David E. Wetcher". The signature is written in a cursive style with a horizontal line underneath.

Counsel for Green River Valley Water District

COMMONWEALTH OF KENTUCKY
BEFORE THE PUBLIC SERVICE COMMISSION

In the Matter of:

TRACY KAY SANDERS)	
)	
COMPLAINANT)	
)	
v.)	CASE NO. 2019-00375
)	
GREEN RIVER VALLEY WATER DISTRICT)	
)	
DEFENDANT)	


RESPONSE OF
GREEN RIVER VALLEY WATER DISTRICT
TO
COMMISSION STAFF'S SECOND REQUEST FOR INFORMATION

FILED: January 18, 2022

VERIFICATION


COMMONWEALTH OF KENTUCKY)
) **SS:**
COUNTY OF HART)

The undersigned, David Paige, being duly sworn, deposes and states that he is the General Manager of Green River Valley Water District and that he has personal knowledge of the matters set forth in the responses for which he is identified as the witness, and the answers contained therein are true and correct to the best of his information, knowledge and belief.



David Paige
General Manager
Green River Valley Water District

Subscribed and sworn to before me, a Notary Public in and before said County and State, this 18 day of January 2022.



Notary Public

My Commission Expires: 12-9-2023

Notary ID: 636 733

GREEN RIVER VALLEY WATER DISTRICT

**Response to Commission Staff's Second Request for Information
Case No. 2019-00375**

Question No. 1

Responding Witness: David Paige

Q-1. Refer to Green River Valley District's Status Report filed on December 7, 2021.

- a. Provide the date the booster station went into service.**
- b. If the booster station has not gone into service, explain why and provide a date by which the booster station is expected to go into service.**
- c. Provide the pound per square inch of water pressure for 1134 Bunnell Crossing Road, Munfordville, Kentucky, since the booster station went into service.**

A-1. a. The booster station was placed into service on December 15, 2021.

b. Not applicable.

c. 55 pounds per square inch.

GREEN RIVER VALLEY WATER DISTRICT

**Response to Commission Staff's Second Request for Information
Case No. 2019-00375**

Question No. 2

Witness: David Paige

- Q-2. Provide a statement concerning the low-pressure condition at 1134 Bunnell Crossing Road, Munfordville, Kentucky. Include in the response any documentation of low pressure at 1134 Bunnell Crossing Road, Munfordville, Kentucky, since the completion of the booster station.**
- A-2. The low-pressure condition has been resolved. The water pressure at the metering point for 1134 Bunnell Crossing Road, Munfordville, Kentucky since the completion of the pumping station has been approximately 55 pounds per square inch.

GREEN RIVER VALLEY WATER DISTRICT

**Response to Commission Staff's Second Request for Information
Case No. 2019-00375**

Question No. 3

Witness: David Paige

- Q-3. Provide a list, by address, of all low-pressure conditions in the Bunnell Crossing Road area of Munfordville, Kentucky, that have been resolved following the startup of the booster station.**
- A-3. All low-pressure conditions that previously existed in the Bunnell Crossing Road area of Munfordville, Kentucky have been resolved. All addresses listed in the attachment to Commission Staff's Second Request for Information are now receiving water service at their metering points in excess of the minimum pressure requirements established in 807 KAR 5:066, Section 5.

GREEN RIVER VALLEY WATER DISTRICT

**Response to Commission Staff's Second Request for Information
Case No. 2019-00375**

Question No. 4

Witness: David Paige

- Q-4. Provide a list, by address, of any low-pressure conditions known by Green River Valley District to remain in the Bunnell Crossing Road area of Munfordville, Kentucky, following the startup of the booster station.**
- A-4. Green River Valley Water District has no knowledge of any low-pressure conditions in the Bunnell Crossing Road area of Munfordville, Kentucky since the booster station was placed into service on December 15, 2021.