

Lake Village Water Association, Inc.

801 Pleasant Hill Drive
P.O. Box 303
Burgin, Kentucky 40310
(859) 748-5642

January 13, 2020

Ms. Gwen R. Pinson
Executive Director
Kentucky Public Service Commission
211 Sower Blvd.
P.O. Box 615
Frankfort, Kentucky 40602

RECEIVED

JAN 14 2020

PUBLIC SERVICE
COMMISSION

Re: Lake Village Water Association, Inc.
Purchase Water Adjustment

Dear Ms. Pinson,

On January 6, 2020, Commission staff requested an explanation of the system flushing volume reported in the 2018 Annual Report by the third party CPA on behalf of the Association. The volume statistics were not reported accurately on the report, consequently reflecting all of the water used in operations as one category. The accurate breakdown of the usage for 2018 is attached for you.

PSC Case No. 2018-00394, specifically the response portion that was requested by the Commission concerning water loss reporting forced Association staff to modify and fine tune our record keeping regarding line breaks, flushing related to line breaks and water lost through meter malfunctions. The 2019 Annual Report will reflect the water usage breakdown using the form format recommended in the PSC Order issued in November 2019.

If further information is necessary please let me know and I will respond immediately.

Sincerely,



Mike D. Sanford, MPA
Executive Director
Lake Village Water Association, Inc.

PUBLIC SERVICE COMMISSION

Monthly Water Loss Report

Water Utility: Lake Village Water Association

For the Month of: Annual Year: 2018

LINE #	ITEM	GALLONS (Omit 000's)
1	WATER PRODUCED AND PURCHASED	
2	Water Produced	-
3	Water Purchased	214,289,681
4	TOTAL PRODUCED AND PURCHASED	214,289,681
5		
6	WATER SALES	
7	Residential	150,000,000
8	Commercial	7,625,800
9	Industrial	-
10	Bulk Loading Stations	-
11	Wholesale	-
12	Public Authorities	-
13	Other Sales (explain)	-
14	TOTAL WATER SALES	157,625,800
15		
16	OTHER WATER USED	
17	Utility and/or Water Treatment Plant	250,000
18	Wastewater Plant	-
19	System Flushing	11,460,900
20	Fire Department	-
21	Other Usage (explain) <u>Storage, Leak adjustments, meter malfunctions</u>	9,943,728
22	TOTAL OTHER WATER USED	21,654,628
23		
24	WATER LOSS	
25	Tank Overflows	12,500
26	Line Breaks	34,996,753
27	Line Leaks	-
28	Excavation Damages	-
29	Theft	-
30	Other Loss	-
31	TOTAL WATER LOSS	35,009,253
32		
33	Note: Line 14 + Line 22 + Line 31 MUST Equal Line 4	
34		
35	WATER LOSS PERCENTAGE	
36	(Line 31 divided by Line 4)	0.16