

COMMONWEALTH OF KENTUCKY
BEFORE THE PUBLIC SERVICE COMMISSION

In the Matter of:

PROPOSED FILING OF GREEN RIVER VALLEY) CASE NO.
WATER DISTRICT TO AMEND ITS TARIFF) 2020-00026

COMMISSION STAFF'S FIRST REQUEST FOR INFORMATION
TO GREEN RIVER VALLEY WATER DISTRICT

Green River Valley Water District (Green River Valley District), pursuant to 807 KAR 5:001, is to file with the Commission the original and five copies in paper medium of the following information, with a copy to all parties of record. The information requested herein is due on or before March 2, 2020. Responses to requests for information in paper medium shall be appropriately bound, tabbed, and indexed.

Each response shall include the name of the witness responsible for responding to the questions related to the information provided. Each response shall be answered under oath or, for representatives of a public or private corporation or a partnership or association or a governmental agency, be accompanied by a signed certification of the preparer or the person supervising the preparation of the response on behalf of the entity that the response is true and accurate to the best of that person's knowledge, information, and belief formed after a reasonable inquiry.

Green River Valley District shall make timely amendment to any prior response if Green River Valley District obtains information which indicates that the response was incorrect when made or, though correct when made, is now incorrect in any material respect. For any request to which Green River Valley District fails or refuses to furnish all or part of the requested information, Green River Valley District shall provide a written explanation of the specific grounds for its failure to completely and precisely respond.

Careful attention shall be given to copied material to ensure that it is legible. When the requested information has been previously provided in this proceeding in the requested format, reference may be made to the specific location of that information in responding to this request. When applicable, the requested information shall be separately provided for total company operations and jurisdictional operations. When filing a paper containing personal information, Green River Valley District shall, in accordance with 807 KAR 5:001, Section 4(10), encrypt or redact the paper so that personal information cannot be read.

1. Provide a copy of all written complaints received by Green River Valley District from 2016 to present. If an investigation was conducted by Green River Valley District in relation to a complaint, provide a copy of all documentation in relation to the investigation, including Green River Valley District's findings in the investigation.

2. Provide the name, address, date of installation, and any other pertinent information for all customers who currently have individual pumps.

3. Provide information concerning the ownership of the individual pumps, where power for each pump is obtained, who is responsible for paying for the power, and who performs maintenance and how each pump is controlled.

4. Provide a highway map at a scale of at least one inch equals two miles marked to show Green River Valley District's water distribution system in the areas where the customers have individual pumps. The map of the system shall show pipeline sizes, location and connections as well as pump stations, water storage tanks, and sea level elevations of key points. The location of each customer listed in the response to Item 1 should also be shown.

5. Provide a topographical map of all areas where the customers have individual pumps. The map shall show the location of each customer, pipeline sizes, location and connections as well as pump stations and water storage tanks.

6. Provide a pressure recording chart showing the actual 24-hour continuously measured pressure available at the locations in the vicinity of all water storage tanks where customers have individual pumps and any other locations necessary to provide a complete understanding of the existing system operation in the areas where customers have individual pumps in Green River Valley District's water system.

7. Identify the 24-hour period recorded, the exact location of the pressure recorder, and the sea level elevation of the recorder for those locations in the vicinity of all water storage tanks where customers have individual pumps and any other locations necessary to provide complete understanding of the existing system operation in the areas where customers have individual pumps in Green River Valley District's water system.

8. Explain how the installation of individual pumps complies with the requirements for booster pumps of the "Recommended Standards for Water Works" (Ten

State Standards) by the Great Lakes Upper Mississippi River Board of State Public Health and Environmental Managers.

9. Provide the name and address of all Green River Valley District customers whose water pressure does not meet the required 30 psig as established by 807 KAR 5:066, Section 5.



Kent A. Chandler
Executive Director
Public Service Commission
P.O. Box 615
Frankfort, KY 40602

DATED **FEB 20 2020**

cc: Parties of Record

*Gerald E Wuetcher
Attorney at Law
STOLL KEENON OGDEN PLLC
300 West Vine Street
Suite 2100
Lexington, KENTUCKY 40507-1801

*Green River Valley Water District
1180 E Main Street
P. O. Box 460
Horse Cave, KY 42749

*Katelyn L. Brown
Attorney
STOLL KEENON OGDEN PLLC
300 West Vine Street
Suite 2100
Lexington, KENTUCKY 40507-1801