Andy Beshear Governor

Rebecca W. Goodman Secretary Energy and Environment Cabinet



Commonwealth of Kentucky

Public Service Commission
211 Sower Blvd.
P.O. Box 615

Frankfort, Kentucky 40602-0615

Telephone: (502) 564-3940
Fax: (502) 564-3460
psc.ky.gov

Kent A. Chandler Chairman

Amy D. Cubbage Vice Chairman

Marianne Butler Commissioner

January 13, 2022

PARTIES OF RECORD

Re: Case No. 2021-00319

Notice is given to all parties that the attached document has been filed into the record of this proceeding.

If you have any comments you would like to make regarding the contents of the document, please do so within five days of receipt of this letter. If you have any questions, please contact Nancy Vinsel, General Counsel, at Nancy.Vinsel@ky.gov.

Sincerely,

Linda C. Bridwell, P.E. Executive Director

Attachment





Louisville Water Company

4801 Allmond Ave. Louisville, Ky 40214 502-569-3600

Meter Shop Test Report

Date Tested:	10 Dec. 21		
Tester:	Angela Thacker		

Customer:

PSC

As Found Read:	0042		
As Left Read:	0042		

% ACCURACY AS RECEIVED

Serial #	Size	Meter Mfg.	Model	Initial Test Read	Low	Med.	High
01328549	5/8 x 3/4"	Zenner		247.6	257.7	267.7	369.9
		Three Additional Tests for Billing Purposes			75%	50%	25%
					673.2	573.0	471.7

Donald Roberts 112 O'Bryan Circle Almo, KENTUCKY 42020

*Dexter-Almo Heights Water District 351 Almo Road Almo, KY 42020