

Andy Beshear
Governor

John Lyons
Secretary
Energy and Environment Cabinet

Angie Hatton
Chair



Commonwealth of Kentucky
Public Service Commission
211 Sower Blvd.
Frankfort, Kentucky 40601-8294
Telephone: (502) 564-3940
psc.ky.gov

Mary Pat Regan
Vice Chair

Andrew W. Wood
Commissioner

Barry L. Mayfield
Commissioner

August 28, 2026

PARTIES OF RECORD

Re: Case No. 2026-00120

Notice is given to all parties that the attached Ohio Valley Gas and Valley Gas Inc. Informal Conference Memorandum and attendance list has been filed into the record of this proceeding.

If you have any comments you would like to make regarding the contents of the document, please do so within five days of receipt of this letter. If you have any questions, please contact Moriah Tussey, Assistant General Counsel, at Moriah.Tussey@ky.gov.

Sincerely,

A handwritten signature in blue ink that reads "Justin McNeil".

Justin McNeil
Executive Director

Attachment

INTRA-AGENCY MEMORANDUM

KENTUCKY PUBLIC SERVICE COMMISSION

TO: Case No. 2026-00120

FROM: Moriah Tussey, Asst. General Counsel

DATE: August 27, 2026

RE: Informal Conference of August 5, 2026

Pursuant to Staff Notice issued on July 29, 2026, an informal conference was conducted on August 5, 2026. Attached is a copy of the attendance roster.

The purpose of the informal conference was to get clarification on several responses to requests for information and engage in a discussion on next steps. Ohio Valley Gas also mentioned upgrading the odorizer system. According to Ohio Valley Gas, no immediate projects would need to be undertaken to take over the system and meet the statutory requirements for adequate, reasonable and efficient service. Ohio Valley Gas does believe that it will undertake projects eventually including increasing overpressure protections. However, Ohio Valley Gas noted this project was not necessary to assume service.

The parties and Staff discussed metering infrastructure of the Valley Gas system. The parties also discussed the PHMSA operator ID. Ohio Valley Gas indicated they would look into how they were going to approach that issue.

During the Ohio Valley Gas inspection, a small piece of bare steel pipe was located and will eventually need to be addressed; however, no other parts of the system contained material of concern.

The parties agreed to do a follow-up IC.

There being no further discussion, the informal conference was then adjourned.

cc: Parties of Record

COMMONWEALTH OF KENTUCKY
BEFORE THE PUBLIC SERVICE COMMISSION

In the Matter of:

**ELECTRONIC JOINT APPLICATION OF OHIO
VALLEY GAS CORPORATION AND VALLEY
GAS INC. FOR APPROVAL OF OHIO VALLEY
GAS CORPORATION'S ACQUISITION OF
VALLEY GAS, INC.'S UTILITY ASSETS IN
BRECKINRIDGE COUNTY, KENTUCKY AND
APPROVAL TO RECOVER AN ASSOCIATED
ACQUISITION ADJUSTMENT**

CASE NO.
2026-00120

August 5, 2026

Please sign in:

NAME	REPRESENTING
Connor Haney_____	PSC_____
Mike Harris_____	PSC_____
Farhad Shahidi_____	PSC_____
Melissa Holbrook_____	PSC_____
Adam McCune_____	PSC_____
Bentley Jarboe_____	PSC_____
Valerie Herring_____	Taft_____
Moriah Tussey_____	PSC_____
Noah Abner _____	PSC_____
John Stenger_____	Ohio Valley Gas_____
Kerry Kasey_____	Valley Gas_____

Scott Williams_____

Steve James_____

Duncan Crosby_____

Greg Bailey_____

Brandon Bruner_____

Kay Pashos_____

Rajan Kapor_____

Jessica Norris Canfield_____

Ohio Valley Gas_____

Ohio Valley Gas_____

Stoll Keenon_____

Ohio Valley Gas_____

PSC_____

Taft_____

Taft_____

PSC_____

Service List for Case 2026-00120

* Honorable W. Duncan Crosby III
Attorney at Law
Stoll Keenon Ogden, PLLC
2000 PNC Plaza
500 W Jefferson Street
Louisville, KY 40202-2828

* Valley Gas, Inc.
401 S First Street
P. O. Box 366
Irvington, KY 40146

* Kay E. Pashos
Taft Stettinius & Hollister LLP
2200 IDS Center
80 South 8th Street
Minneapolis, MN 55402-215

* Rajan Kapoor
Taft Stettinius & Hollister LLP
2200 IDS Center
80 South 8th Street
Minneapolis, MN 55402-215

* Valerie T. Herring
Attorney
Taft Stettinius & Hollister LLP
2200 IDS Center
80 South 8th Street
Minneapolis, MN 55402-215