

RECEIVED

MAR 20 2015

PUBLIC SERVICE
COMMISSION

2011-00450

PSC Outage Tabulation, 2014

Taylor County RECC

System:			
<u>Year</u>	<u>SAIDI</u>	<u>SAIFI</u>	<u>CAIDI</u>
2009	1391.8	7	197.7
2010	307.16	3.91	78.65
2011	89.4	1.1	81.7
2012	74.0	1.3	57.4
2013	386.84	4.24	91.27
2014	119.18	1.58	75.29

Outage Subcategory Breakdown:	
<u>Subcategory:</u>	<u>Mins:</u>
Animal	178,183.2
Consumer	139,502.4
Equipment	300,976.2
Miscellaneous	266,980.8
Overload	5,405.4
Plan	40,981.8
Power Supplier	757,110.6
Tree	249,475.8
Weather	1,095,149.0

2014 - Major outage day defined per IEEE standard
5yr avg Tmed for 14
 88,456.4
 Major Outage Days - 2/20 Weather(88,574.4), 5/22 Weather(104,051.4),
 6/10 Weather(129,213.6), 7/23 Weather(231,575.4), 7/27 Weather(155,901.6).
 8/11 Weather(96,709.2) & 8/21 Power Supply(740,673.6)

2014 10 Worst Circuits per Category:						
<u>Substation</u>	<u>C</u>	<u>SAIDI</u>	<u>SAIFI</u>	<u>CAIDI</u>	<u>Maj. Out. Category</u>	
BASS	3	452.5			WEATHER	
MILE LANE	4	400.5			POWER SUPPLIER	
MILE LANE	3	398.4			POWER SUPPLIER	
MILE LANE	1	299.4			POWER SUPPLIER	
MILE LANE	5	276.2			POWER SUPPLIER	
MILE LANE	2	244.6			POWER SUPPLIER	
MILE LANE	6	219.6			POWER SUPPLIER	
PHIL	1	219.4			WEATHER	
MCKINNEY CORNER	1	192.4			WEATHER	
BASS	2	191.5			CONSUMER	
MILE LANE	3		4.4		POWER SUPPLIER	
BASS	3		3.6		WEATHER	
GARLIN	3		3.1		POWER SUPPLIER	

COBURG	4	2.6	WEATHER
COLUMBIA	2	2.6	ANIMAL
MILE LANE	2	2.5	POWER SUPPLIER
MILE LANE	5	2.4	POWER SUPPLIER
GARLIN	2	2.4	ANIMAL
PHIL	1	2.4	WEATHER
EAST CAMPBELLSVILLE	1	2.3	WEATHER
GREENSBURG	3	461.1	ANIMAL
MILE LANE	4	220.0	POWER SUPPLIER
PHIL	2	199.8	TREE
CRESTON	3	182.1	WEATHER
MILE LANE	1	159.5	POWER SUPPLIER
GREENSBURG	4	141.9	ANIMAL
BASS	1	129.4	WEATHER
MILE LANE	6	127.3	POWER SUPPLIER
BASS	3	125.7	WEATHER
PHIL	5	119.1	EQUIPMENT

Vegetation Management Plan:

Plan is progressing as expected/desired

Continue to face occasional issue with yard tree clearance

Taylor County RECC Outage Reporting - Circuit Level

Administrative Case No: 2011-00450

SECTION 1: CIRCUIT REPORTING

Utility Name: Taylor County RECC
Report Prepared By: Mike Skaggs
Preparer Email: mskaggs@tcrecc.com
Preparer Phone: 800-931-4551

SECTION 2: REPORTING YEAR

Calender Year of Report: 2014

SECTION 3: MAJOR EVENT DAYS (MED)

Tmed: 88456.4
First Date Used to Determine Tmed: 2/20/2014
Last Date Used to Determine Tmed: 8/21/2014
Number of MED in Report Year: 7

SECTION 4: SYSTEM RELIABILITY INFORMATION AND RESULTS

System-wide Information:

Total Customers: 26036
Total Circuits: 63

Excluding MED:

5 Year Average SAIDI: 164.46
5 Year Average SAIFI: 2.23
Reporting Year SAIDI: 57.1
Reporting Year SAIFI: 1.1

Including MED:

5 Year Average SAIDI: 180.52
5 Year Average SAIFI: 2.43
Reporting Year SAIDI: 119.18
Reporting Year SAIFI: 1.58

Taylor County RECC

SECTION 5: CIRCUIT REPORTING

**CIRCUITS with SAIDI AND/OR SAIFI EXCEEDING 5-year AVG
(excluding MED)**

1) Substation name and number	Bass
2) Substation location (County-road-town)	Hwy 70 at Taylor/Casey County Line
3) Circuit name and number	2
4) Circuit location (town-road-general area)	Feathersburg to Knifley
5) Total Circuit Length (miles)	66.47
6) Customer count for this circuit	502
7) Date of last circuit trim (VM)	2012
8) List outage causes for circuit along with percentage of total outage numbers represented by each cause	Animal 0.96% Consumer 47.14% Miscellaneous 34.23% Overload 0.21% Planned 8.40% Tree 6.80% Weather 2.20%
9) Circuit 5 year average SAIDI	130.81
10) Reporting year SAIDI	178.22
11) Circuit 5 year average SAIFI	2.67
12) Reporting year SAIFI	1.78
13) List of correction action, if any, taken or to be taken	

Taylor County RECC

SECTION 5: CIRCUIT REPORTING

**CIRCUITS with SAIDI AND/OR SAIFI EXCEEDING 5-year AVG
(excluding MED)**

1) Substation name and number	Campbellsville
2) Substation location (County-road-town)	Nr Hwy 3183/Hwy 55 intersection
3) Circuit name and number	4
4) Circuit location (town-road-general area)	Toward Campbellsville
5) Total Circuit Length (miles)	4.28
6) Customer count for this circuit	59
7) Date of last circuit trim (VM)	2014
8) List outage causes for circuit along with percentage of total outage numbers represented by each cause	Animal 13.0% Power Supply 84.4% Weather 2.6%
9) Circuit 5 year average SAIDI	16.16
10) Reporting year SAIDI	13.3
11) Circuit 5 year average SAIFI	0.28
12) Reporting year SAIFI	0.46
13) List of correction action, if any, taken or to be taken	

Taylor County RECC

SECTION 5: CIRCUIT REPORTING

CIRCUITS with SAIDI AND/OR SAIFI EXCEEDING 5-year AVG
(excluding MED)

1) Substation name and number	Campbellsville
2) Substation location (County-road-town)	Nr Hwy 3183/Hwy 55 intersection
3) Circuit name and number	5
4) Circuit location (town-road-general area)	Toward Greensburg RD
5) Total Circuit Length (miles)	40.46
6) Customer count for this circuit	608
7) Date of last circuit trim (VM)	2014
8) List outage causes for circuit along with percentage of total outage numbers represented by each cause	Miscellaneous 4.13% Overload 0.11% Power Supply 66.41% Trees 19.64% Weather 9.71%
9) Circuit 5 year average SAIDI	26.95
10) Reporting year SAIDI	28.65
11) Circuit 5 year average SAIFI	0.38
12) Reporting year SAIFI	0.46
13) List of correction action, if any, taken or to be taken	

Taylor County RECC

SECTION 5: CIRCUIT REPORTING

CIRCUITS with SAIDI AND/OR SAIFI EXCEEDING 5-year AVG
(excluding MED)

1) Substation name and number	East Campbellsville
2) Substation location (County-road-town)	Nr Hwy 3518/Hwy70 intersection
3) Circuit name and number	3
4) Circuit location (town-road-general area)	South Campbellsville
5) Total Circuit Length (miles)	21.4
6) Customer count for this circuit	464
7) Date of last circuit trim (VM)	2013
8) List outage causes for circuit along with percentage of total outage numbers represented by each cause	Animal 1.40% Miscellaneous 97.24% Weather 1.40%
9) Circuit 5 year average SAIDI	51.75
10) Reporting year SAIDI	90.1
11) Circuit 5 year average SAIFI	1.01
12) Reporting year SAIFI	1.15
13) List of correction action, if any, taken or to be taken	

Taylor County RECC

SECTION 5: CIRCUIT REPORTING

**CIRCUITS with SAIDI AND/OR SAIFI EXCEEDING 5-year AVG
(excluding MED)**

- | | | |
|--|--|----------------------------|
| 1) Substation name and number | Greensburg | |
| 2) Substation location (County-road-town) | Nr Hwy 661/West Hodgenville
Rd intersection | |
| 3) Circuit name and number | 3 | |
| 4) Circuit location (town-road-general area) | Toward Campbellsville | |
| 5) Total Circuit Length (miles) | 65.87 | |
| 6) Customer count for this circuit | 587 | |
| 7) Date of last circuit trim (VM) | 2010 | |
| 8) List outage causes for circuit along with percentage of
total outage numbers represented by each cause | Animal
Equipment
Weather | 46.66%
10.91%
42.44% |
| 9) Circuit 5 year average SAIDI | 40.67 | |
| 10) Reporting year SAIDI | 63.76 | |
| 11) Circuit 5 year average SAIFI | 0.305 | |
| 12) Reporting year SAIFI | 0.02 | |
| 13) List of correction action, if any, taken or to be taken | | |

Taylor County RECC

SECTION 5: CIRCUIT REPORTING

CIRCUITS with SAIDI AND/OR SAIFI EXCEEDING 5-year AVG
(excluding MED)

1) Substation name and number	Green River Plaza
2) Substation location (County-road-town)	Nr Hwy 55/Hwy 323 intersection
3) Circuit name and number	1
4) Circuit location (town-road-general area)	Greensburg Rd
5) Total Circuit Length (miles)	20.49
6) Customer count for this circuit	665
7) Date of last circuit trim (VM)	2011
8) List outage causes for circuit along with percentage of total outage numbers represented by each cause	Animal 0.44% Equipment 0.92% Overload 1.29% Power Supply 49.98% Tree 2.80% Weather 44.58%
9) Circuit 5 year average SAIDI	78.63
10) Reporting year SAIDI	71.7
11) Circuit 5 year average SAIFI	0.71
12) Reporting year SAIFI	1.16
13) List of correction action, if any, taken or to be taken	

Taylor County RECC

SECTION 5: CIRCUIT REPORTING

**CIRCUITS with SAIDI AND/OR SAIFI EXCEEDING 5-year AVG
(excluding MED)**

1) Substation name and number	McKinney Corner
2) Substation location (County-road-town)	Nr Hwy 218/Hwy 68 intersection
3) Circuit name and number	3
4) Circuit location (town-road-general area)	Toward Greensburg
5) Total Circuit Length (miles)	42.84
6) Customer count for this circuit	304
7) Date of last circuit trim (VM)	2012
8) List outage causes for circuit along with percentage of total outage numbers represented by each cause	Animal 5.39% Equipment 10.75% Miscellaneous 5.78% Overload 0.10% Weather 77.98%
9) Circuit 5 year average SAIDI	33.35
10) Reporting year SAIDI	43.32
11) Circuit 5 year average SAIFI	0.34
12) Reporting year SAIFI	0.52
13) List of correction action, if any, taken or to be taken	

Taylor County RECC

SECTION 5: CIRCUIT REPORTING

CIRCUITS with SAIDI AND/OR SAIFI EXCEEDING 5-year AVG
(excluding MED)

1) Substation name and number	Mile Lane	
2) Substation location (County-road-town)	Nr Hwy 3211/Hwy 527 intersection	
3) Circuit name and number	3	
4) Circuit location (town-road-general area)	Saloma	
5) Total Circuit Length (miles)	76.7	
6) Customer count for this circuit	523	
7) Date of last circuit trim (VM)	2011	
8) List outage causes for circuit along with percentage of total outage numbers represented by each cause	Animal	0.87%
	Consumer	1.98%
	Equipment	1.99%
	Miscellaneous	3.40%
	Planned	3.31%
	Power Supply	59.18%
	Weather	29.27%
9) Circuit 5 year average SAIDI	121.89	
10) Reporting year SAIDI	70.97	
11) Circuit 5 year average SAIFI	1.71	
12) Reporting year SAIFI	2.93	
13) List of correction action, if any, taken or to be taken		

Taylor County RECC

SECTION 5: CIRCUIT REPORTING

**CIRCUITS with SAIDI AND/OR SAIFI EXCEEDING 5-year AVG
(excluding MED)**

1) Substation name and number	Mile Lane
2) Substation location (County-road-town)	Nr Hwy 3211/Hwy 527 intersection
3) Circuit name and number	5
4) Circuit location (town-road-general area)	Toward Campbellsville
5) Total Circuit Length (miles)	12.53
6) Customer count for this circuit	411
7) Date of last circuit trim (VM)	2012
8) List outage causes for circuit along with percentage of total outage numbers represented by each cause	Animal 1.41% Equipment 0.08% Miscellaneous 3.09% Power Supply 61.13% Tree 32.71% Weather 1.58%
9) Circuit 5 year average SAIDI	44.59
10) Reporting year SAIDI	107.38
11) Circuit 5 year average SAIFI	0.64
12) Reporting year SAIFI	1.43
13) List of correction action, if any, taken or to be taken	

Taylor County RECC

SECTION 5: CIRCUIT REPORTING

**CIRCUITS with SAIDI AND/OR SAIFI EXCEEDING 5-year AVG
(excluding MED)**

1) Substation name and number	Mile Lane
2) Substation location (County-road-town)	Nr Hwy 3211/Hwy 527 intersection
3) Circuit name and number	6
4) Circuit location (town-road-general area)	Palestine Rd
5) Total Circuit Length (miles)	42.46
6) Customer count for this circuit	528
7) Date of last circuit trim (VM)	2012
8) List outage causes for circuit along with percentage of total outage numbers represented by each cause	Animal 4.79% Consumer 0.05% Equipment 1.08% Miscellaneous 0.17% Overload 0.21% Power Supply 89.34% Tree 0.21% Weather 4.15%
9) Circuit 5 year average SAIDI	46.33
10) Reporting year SAIDI	23.4
11) Circuit 5 year average SAIFI	0.34
12) Reporting year SAIFI	0.55
13) List of correction action, if any, taken or to be taken	

Taylor County RECC

SECTION 5: CIRCUIT REPORTING

CIRCUITS with SAIDI AND/OR SAIFI EXCEEDING 5-year AVG
(excluding MED)

- | | |
|---|--|
| 1) Substation name and number | Summersville |
| 2) Substation location (County-road-town) | Nr Hwy 323/Raymond Despain Rd intersection |
| 3) Circuit name and number | 3 |
| 4) Circuit location (town-road-general area) | Gabe |
| 5) Total Circuit Length (miles) | 51.69 |
| 6) Customer count for this circuit | 439 |
| 7) Date of last circuit trim (VM) | 2014 |
| 8) List outage causes for circuit along with percentage of total outage numbers represented by each cause | Animal 2.13%
Consumer 36.29%
Equipment 60.84%
Weather 0.74% |
| 9) Circuit 5 year average SAIDI | 148.41 |
| 10) Reporting year SAIDI | 162.33 |
| 11) Circuit 5 year average SAIFI | 3.59 |
| 12) Reporting year SAIFI | 2.17 |
| 13) List of correction action, if any, taken or to be taken | |

Outages - 2014
Taylor County RECC

<u>Date</u>	<u>Total Time (hrs)</u>	<u>Substation</u>	<u>Ckt</u>	<u># Membrs Effected</u>	<u>Consumers Hrs Off</u>	<u>Cause</u>
1/1/2014	0.5	SVILLE	4	42	21	MISCELLANEOUS
1/2/2014	1.58	COBURG	1	58	91.64	EQUIPMENT MATERIAL FAILURE
1/3/2014	1.42	CVILLE	5	90	127.8	TREE
1/3/2014	5	PHIL	5	1	5	EQUIPMENT MATERIAL FAILURE
1/4/2014	9	BASS	1	1	9	WEATHER
1/4/2014	6	CRESTON	1	1	6	WEATHER
1/4/2014	0.58	CVILLE	5	2	1.16	OVERLOAD
1/5/2014	1.5	ML	5	393	589.5	TREE
1/6/2014	1.67	BASS	1	1	1.67	OVERLOAD
1/6/2014	1.75	BASS	3	81	141.75	EQUIPMENT MATERIAL FAILURE
1/6/2014	2	COBURG	1	39	78	WEATHER
1/6/2014	1.08	CRESTON	1	47	50.76	EQUIPMENT MATERIAL FAILURE
1/6/2014	1	CVILLE	2	4	4	OVERLOAD
1/6/2014	1.33	EC	1	2	2.66	EQUIPMENT MATERIAL FAILURE
1/6/2014	1.83	MCK	1	1	1.83	EQUIPMENT MATERIAL FAILURE
1/6/2014	2.08	ML	3	65	135.2	WEATHER
1/6/2014	1.17	ML	4	1	1.17	OVERLOAD
1/6/2014	0.67	ML	6	29	19.43	EQUIPMENT MATERIAL FAILURE
1/6/2014	2.67	PHIL	1	3	8.01	EQUIPMENT MATERIAL FAILURE
1/6/2014	2	PHIL	1	3	6	EQUIPMENT MATERIAL FAILURE
1/6/2014	2.92	SVILLE	2	1	2.92	EQUIPMENT MATERIAL FAILURE
1/6/2014	2	SVILLE	4	18	36	WEATHER
1/7/2014	3	BASS	1	2	6	OVERLOAD
1/7/2014	1.33	BASS	3	1	1.33	OVERLOAD
1/7/2014	1	COBURG	1	3	3	OVERLOAD
1/7/2014	4.42	COBURG	2	2	8.84	OVERLOAD
1/7/2014	3	CRESTON	1	2	6	WEATHER
1/7/2014	3	CRESTON	2	2	6	WEATHER
1/7/2014	1.92	EC	1	4	7.68	OVERLOAD

1/7/2014	1.42	EC	5	4	5.68	OVERLOAD
1/7/2014	0.33	EC	5	32	10.56	EQUIPMENT MATERIAL FAILURE
1/7/2014	1.5	GARLIN	5	1	1.5	OVERLOAD
1/7/2014	1.67	GARLIN	5	2	3.34	OVERLOAD
1/7/2014	0.5	GBURG	3	2	1	EQUIPMENT MATERIAL FAILURE
1/7/2014	3.42	GRP	1	6	20.52	OVERLOAD
1/7/2014	3.17	PHIL	1	1	3.17	EQUIPMENT MATERIAL FAILURE
1/7/2014	3.5	PHIL	1	3	10.5	EQUIPMENT MATERIAL FAILURE
1/7/2014	2	PHIL	5	2	4	EQUIPMENT MATERIAL FAILURE
1/7/2014	0.07	WC	3	58	4.06	PLANNED
1/8/2014	1	GRP	3	2	2	PLANNED
1/9/2014	0.92	MCK	1	36	33.12	EQUIPMENT MATERIAL FAILURE
1/9/2014	6	PHIL	2	38	228	TREE
1/10/2014	8.33	EC	5	5	41.65	EQUIPMENT MATERIAL FAILURE
1/10/2014	0.02	ML	3	522	10.44	PLANNED
1/10/2014	0.2	ML	3	522	104.4	PLANNED
1/11/2014	2.33	COBURG	1	1	2.33	EQUIPMENT MATERIAL FAILURE
1/11/2014	0.83	COBURG	1	15	12.45	EQUIPMENT MATERIAL FAILURE
1/11/2014	0.83	ML	6	44	36.52	WEATHER
1/12/2014	3.08	COBURG	1	1	3.08	EQUIPMENT MATERIAL FAILURE
1/12/2014	3.75	ML	3	2	7.5	WEATHER
1/13/2014	0.05	COBURG	1	121	6.05	PLANNED
1/13/2014	1.42	PHIL	5	2	2.84	EQUIPMENT MATERIAL FAILURE
1/14/2014	6.42	CVILLE	3	1	6.42	EQUIPMENT MATERIAL FAILURE
1/14/2014	0.67	ML	6	44	29.48	WEATHER
1/16/2014	1.83	EC	1	1	1.83	OVERLOAD
1/17/2014	2.25	CVILLE	3	1	2.25	OVERLOAD
1/20/2014	4	COBURG	3	1	4	TREE
1/20/2014	0.5	GARLIN	3	2	1	ANIMAL
1/21/2014	0.04	MCK	1	69	2.76	EQUIPMENT MATERIAL FAILURE
1/21/2014	1.83	MCK	1	32	58.56	EQUIPMENT MATERIAL FAILURE
1/22/2014	0.02	EC	1	38	0.76	PLANNED
1/22/2014	0.67	MCK	1	3	2.01	OVERLOAD
1/22/2014	3	PHIL	5	2	6	EQUIPMENT MATERIAL FAILURE

1/23/2014	0.02	SVILLE	4	31	0.62	PLANNED
1/29/2014	1.08	COLUMBIA	2	3	3.24	OVERLOAD
1/29/2014	0.67	ML	6	2	1.34	OVERLOAD
1/29/2014	1.5	PHIL	2	1	1.5	EQUIPMENT MATERIAL FAILURE
1/29/2014	0.33	WC	2	1	0.33	OVERLOAD
1/30/2014	1	WC	3	2	2	EQUIPMENT MATERAIL FAILURE
2/1/2014	3.75	GARLIN	3	1	3.75	EQUIPMENT MATERIAL FAILURE
2/1/2014	1.17	SVILLE	4	86	100.62	EQUIPMENT MATERIAL FAILURE
2/2/2014	1.08	ML	2	313	338.04	ANIMAL
2/3/2014	1.43	ML	6	1	1.43	EQUIPMENT MATERIAL FAILURE
2/3/2014	1.25	ML	6	1	1.25	OVERLOAD
2/4/2014	1.08	GARLIN	4	54	58.32	MISCELLANEOUS
2/4/2014	1.25	ML	1	45	56.25	WEATHER
2/4/2014	2	PHIL	1	8	16	EQUIPMENT MATERIAL FAILURE
2/5/2014	2.5	PHIL	1	2	5	TREE
2/6/2014	1.25	COBURG	3	34	42.5	EQUIPMENT MATERIAL FAILURE
2/6/2014	0.67	COLUMBIA	2	1	0.67	EQUIPMENT MATERIAL FAILURE
2/6/2014	0.33	CRESTON	2	2	0.66	MISCELLANEOUS
2/7/2014	0.92	ML	3	87	80.04	WEATHER
2/7/2014	2.83	SVILLE	4	2	5.66	CONSUMER
2/8/2014	0.5	COLUMBIA	2	34	17	ANIMAL
2/8/2014	0.83	ML	3	87	72.21	MISCELLANEOUS
2/10/2014	0.67	SVILLE	4	17	11.39	MISCELLANEOUS
2/13/2014	8.33	BASS	2	15	124.95	PLANNED
2/13/2014	2	BASS	2	214	428	MISCELLANEOUS
2/13/2014	1.33	COLUMBIA	2	34	45.22	EQUIPMENT MATERIAL FAILURE
2/13/2014	0.92	CRESTON	3	31	28.52	MISCELLANEOUS
2/13/2014	22.42	ML	4	1	22.42	CONSUMER
2/14/2014	0.5	PHIL	1	12	6	MISCELLANEOUS
2/16/2014	0.42	GARLIN	3	2	0.84	ANIMAL
2/16/2014	3.92	SVILLE	1	20	78.4	EQUIPMENT MATERIAL FAILURE
2/17/2014	2	COLUMBIA	2	14	28	EQUIPMENT MATERIAL FAILURE
2/19/2014	1.17	SVILLE	4	16	18.72	WEATHER
2/20/2014	1	COBURG	1	60	60	WEATHER

2/20/2014	1.08	COBURG	2	3	3.24	WEATHER
2/20/2014	4.5	CRESTON	3	273	1228.5	WEATHER
2/20/2014	0.75	GBURG	3	86	64.5	WEATHER
2/20/2014	0.5	SVILLE	4	23	11.5	WEATHER
2/20/2014	1.75	SVILLE	4	62	108.5	WEATHER
2/21/2014	11.92	BASS	2	1	11.92	WEATHER
2/21/2014	2.17	CVILLE	4	1	2.17	WEATHER
2/22/2014	0.5	GARLIN	2	15	7.5	MISCELLANEOUS
2/22/2014	0.92	GARLIN	2	151	138.92	ANIMAL
2/23/2014	2.58	SVILLE	4	1	2.58	WEATHER
2/24/2014	0.58	CRESTON	1	5	2.9	ANIMAL
2/24/2014	1.33	ML	5	32	42.56	MISCELLANEOUS
2/25/2014	7.75	BASS	1	1	7.75	EQUIPMENT MATERIAL FAILURE
2/25/2014	3.33	SVILLE	4	7	23.31	CONSUMER
2/28/2014	0.05	GBURG	5	77	3.85	EQUIPMENT MATERIAL FAILURE
2/28/2014	1.52	GBURG	5	18	27.36	EQUIPMENT MATERIAL FAILURE
3/1/2014	0.35	CVILLE	3	54	18.9	MISCELLANEOUS
3/1/2014	1.17	GARLIN	2	15	17.55	ANIMAL
3/2/2014	2.5	BASS	1	42	105	WEATHER
3/2/2014	0.45	GARLIN	1	1	0.45	WEATHER
3/6/2014	1	MCK	1	6	6	MISCELLANEOUS
3/7/2014	0.5	EC	3	10	5	MISCELLANEOUS
3/10/2014	2.42	GARLIN	2	5	12.1	MISCELLANEOUS
3/11/2014	0.83	COLUMBIA	3	34	28.22	EQUIPMENT MATERIAL FAILURE
3/11/2014	0.83	MCK	2	49	40.67	MISCELLANEOUS
3/12/2014	1.5	BASS	1	38	57	WEATHER
3/12/2014	1.83	COBURG	2	1	1.83	EQUIPMENT MATERIAL FAILURE
3/12/2014	0.58	COLUMBIA	2	5	2.9	ANIMAL
3/12/2014	1	CRESTON	2	14	14	TREE
3/15/2014	3	CVILLE	3	10	30	MISCELLANEOUS
3/15/2014	2	PHIL	2	1	2	MISCELLANEOUS
3/16/2014	3.5	CRESTON	1	36	126	WEATHER
3/17/2014	1.17	CRESTON	2	17	19.89	EQUIPMENT MATERIAL FAILURE
3/17/2014	0.58	ML	1	8	4.64	ANIMAL

3/20/2014	0.58	CVILLE	3	16	9.28	ANIMAL
3/20/2014	0.5	CVILLE	3	76	38	CONSUMER
3/20/2014	1.67	GARLIN	3	3	5.01	EQUIPMENT MATERIAL FAILURE
3/22/2014	1.5	CRESTON	3	1	1.5	ANIMAL
3/23/2014	1	CRESTON	3	2	2	ANIMAL
3/26/2014	1.5	CRESTON	2	90	135	EQUIPMENT MATERIAL FAILURE
3/26/2014	28.8	CVILLE	5	1	28.8	WEATHER
3/26/2014	0.83	GBURG	3	583	483.89	ANIMAL
3/26/2014	0.83	MCK	2	18	14.94	CONSUMER
3/27/2014	0.08	CVILLE	3	47	3.76	PLANNED
3/28/2014	1.67	PHIL	1	36	60.12	ANIMAL
3/28/2014	0.5	WC	3	32	16	MISCELLANEOUS
3/29/2014	0.67	EC	1	66	44.22	EQUIPMENT MATERIAL FAILURE
3/29/2014	1.33	EC	1	66	87.78	WEATHER
3/30/2014	1	COLUMBIA	2	582	582	ANIMAL
3/30/2014	1.67	GRP	1	1	1.67	EQUIPMENT MATERIAL FAILURE
3/30/2014	0.92	WC	2	1	0.92	EQUIPMENT MATERIAL FAILURE
3/31/2014	0.5	CVILLE	3	25	12.5	TREE
4/1/2014	1	CRESTON	3	51	51	EQUIPMENT MATERIAL FAILURE
4/1/2014	1.67	WC	2	4	6.68	MISCELLANEOUS
4/2/2014	0.67	CVILLE	5	42	28.14	MISCELLANEOUS
4/2/2014	0.83	EC	2	1	0.83	MISCELLANEOUS
4/3/2014	0.75	CVILLE	5	51	38.25	WEATHER
4/3/2014	0.75	CVILLE	5	51	38.25	WEATHER
4/3/2014	0.25	EC	3	38	9.5	WEATHER
4/3/2014	2.17	ML	3	1	2.17	WEATHER
4/3/2014	3	SVILLE	1	1	3	WEATHER
4/3/2014	4	SVILLE	1	1	4	WEATHER
4/3/2014	1.83	WC	3	58	106.14	TREE
4/4/2014	6	CRESTON	3	1	6	EQUIPMENT MATERIAL FAILURE
4/4/2014	2	PHIL	1	1	2	WEATHER
4/4/2014	4.28	WC	2	1	4.28	WEATHER
4/7/2014	0.4	BASS	1	1	0.4	MISCELLANEOUS
4/7/2014	2	PHIL	3	1	2	EQUIPMENT MATERIAL FAILURE

4/8/2014	0.58	SVILLE	3	23	13.34	ANIMAL
4/9/2014	0.5	ML	5	32	16	MISCELLANEOUS
4/10/2014	4.5	COBURG	2	2	9	EQUIPMENT MATERIAL FAILURE
4/10/2014	6.5	COBURG	2	2	13	EQUIPMENT MATERIAL FAILURE
4/10/2014	6.5	COBURG	2	3	19.5	EQUIPMENT MATERIAL FAILURE
4/10/2014	1.25	WC	3	58	72.5	ANIMAL
4/11/2014	1.17	GBURG	3	97	113.49	EQUIPMENT MATERIAL FAILURE
4/13/2014	2	BASS	3	45	90	EQUIPMENT MATERIAL FAILURE
4/13/2014	0.83	BASS	3	829	688.07	EQUIPMENT MATERIAL FAILURE
4/13/2014	3	CRESTON	1	46	138	TREE
4/13/2014	1	GBURG	5	8	8	ANIMAL
4/14/2014	1	COBURG	1	1	1	MISCELLANEOUS
4/17/2014	2	CRESTON	3	1	2	MISCELLANEOUS
4/19/2014	0.83	SVILLE	1	7	5.81	EQUIPMENT MATERIAL FAILURE
4/21/2014	1	PHIL	1	1	1	ANIMAL
4/21/2014	6.25	SVILLE	4	1	6.25	WEATHER
4/21/2014	0.75	WC	4	1	0.75	CONSUMER
4/22/2014	0.83	BASS	3	98	81.34	CONSUMER
4/25/2014	0.83	ML	2	46	38.18	WEATHER
4/25/2014	1.17	ML	6	1	1.17	WEATHER
4/25/2014	0.83	SVILLE	4	2	1.66	WEATHER
4/25/2014	1.33	SVILLE	4	29	38.57	WEATHER
4/27/2014	1	EC	3	1	1	ANIMAL
4/27/2014	1.17	GBURG	5	29	33.93	EQUIPMENT MATERIAL FAILURE
4/28/2014	1	COBURG	2	1	1	WEATHER
4/28/2014	3.08	GBURG	6	1	3.08	TREE
4/28/2014	8.83	SVILLE	3	1	8.83	WEATHER
4/29/2014	3.33	CRESTON	3	53	176.49	TREE
4/29/2014	6.58	GBURG	4	1	6.58	WEATHER
4/29/2014	0.67	GBURG	4	38	25.46	WEATHER
4/29/2014	0.58	GRP	2	1	0.58	WEATHER
5/1/2014	3	BASS	3	78	234	EQUIPMENT MATERIAL FAILURE
5/1/2014	21	MCK	2	1	21	WEATHER
5/3/2014	1.5	ML	5	1	1.5	EQUIPMENT MATERIAL FAILURE

5/5/2014	1.42	CRESTON	3	25	35.5	MISCELLANEOUS
5/5/2014	1	SVILLE	3	431	431	CONSUMER
5/7/2014	2	BASS	3	1	2	EQUIPMENT MATERIAL FAILURE
5/8/2014	3.92	BASS	3	6	23.52	CONSUMER
5/8/2014	0.75	GRP	2	3	2.25	MISCELLANEOUS
5/10/2014	4.08	COBURG	1	1	4.08	WEATHER
5/10/2014	1.42	CVILLE	5	1	1.42	WEATHER
5/10/2014	3.5	ML	1	1	3.5	WEATHER
5/12/2014	1.67	COLUMBIA	5	1	1.67	EQUIPMENT MATERIAL FAILURE
5/13/2014	1	GARLIN	1	101	101	WEATHER
5/13/2014	0.67	PHIL	3	3	2.01	ANIMAL
5/14/2014	0.33	COLUMBIA	2	8	2.64	WEATHER
5/14/2014	1.5	CVILLE	3	1	1.5	ANIMAL
5/14/2014	2	MCK	1	2	4	WEATHER
5/14/2014	0.58	ML	1	25	14.5	WEATHER
5/15/2014	2.42	BASS	2	1	2.42	MISCELLANEOUS
5/15/2014	4	CRESTON	3	1	4	TREE
5/15/2014	0.33	EC	1	1	0.33	MISCELLANEOUS
5/20/2014	0.5	COLUMBIA	2	2	1	MISCELLANEOUS
5/21/2014	0.38	EC	5	1	0.38	ANIMAL
5/21/2014	1.17	WC	3	1	1.17	CONSUMER
5/22/2014	2	CRESTON	1	1	2	ANIMAL
5/22/2014	4.5	ML	3	1	4.5	WEATHER
5/22/2014	8.25	ML	3	1	8.25	WEATHER
5/22/2014	10.33	ML	3	1	10.33	CONSUMER
5/22/2014	0.67	ML	3	104	69.68	WEATHER
5/22/2014	6.78	ML	3	27	183.06	WEATHER
5/22/2014	7.13	ML	3	70	499.1	WEATHER
5/22/2014	9.5	ML	4	1	9.5	TREE
5/22/2014	12	ML	4	1	12	WEATHER
5/22/2014	5.17	ML	4	181	935.77	WEATHER
5/23/2014	0.05	COBURG	ALL	2134	106.7	POWER SUPPLY
5/23/2014	0.05	COLUMBIA	ALL	1478	73.9	POWER SUPPLY
5/23/2014	0.05	GARLIN	ALL	1808	90.4	POWER SUPPLY

5/23/2014	0.05	WC	ALL	2203	110.15	POWER SUPPLY
5/24/2014	1.47	GARLIN	5	11	16.17	EQUIPMENT MATERIAL FAILURE
5/25/2014	0.75	COBURG	4	13	9.75	MISCELLANEOUS
5/25/2014	1	CRESTON	3	7	7	MISCELLANEOUS
5/25/2014	0.58	GARLIN	3	13	7.54	MISCELLANEOUS
5/26/2014	1.17	CRESTON	2	1	1.17	ANIMAL
5/26/2014	2.17	GARLIN	2	13	28.21	ANIMAL
5/26/2014	0.5	ML	6	26	13	WEATHER
5/27/2014	1	BASS	2	102	102	TREE
5/27/2014	6.63	BASS	3	5	33.15	WEATHER
5/27/2014	1.92	BASS	3	75	144	WEATHER
5/27/2014	2.25	COBURG	4	1	2.25	WEATHER
5/27/2014	0.83	COBURG	4	13	10.79	PLANNED
5/27/2014	7	CRESTON	3	3	21	WEATHER
5/27/2014	1	CVILLE	3	21	21	WEATHER
5/27/2014	0.75	CVILLE	3	29	21.75	WEATHER
5/27/2014	2.58	GARLIN	3	6	15.48	WEATHER
5/27/2014	0.75	GBURG	3		10	WEATHER
5/27/2014	4	SVILLE	4	3	12	TREE
5/27/2014	1.5	SVILLE	4	66	99	TREE
5/28/2014	2	CRESTON	3	1	2	CONSUMER
5/28/2014	0.83	ML	2	10	8.3	TREE
5/28/2014	0.75	ML	3	4	3	WEATHER
5/28/2014	1.17	SVILLE	1	9	10.53	WEATHER
5/29/2014	1.08	BASS	3	75	81	MISCELLANEOUS
5/29/2014	3.67	CVILLE	3	2	7.34	ANIMAL
5/30/2014	2	GBURG	1	1	2	EQUIPMENT MATERIAL FAILURE
5/30/2014	0.08	WC	2	135	10.8	CONSUMER
5/31/2014	0.58	EC	5	1	0.58	TREE
5/31/2014	1	PHIL	5	4	4	MISCELLANEOUS
5/31/2014	0.67	SVILLE	4	62	41.54	MISCELLANEOUS
6/1/2014	0.92	CVILLE	3	12	11.04	WEATHER
6/1/2014	2.17	CVILLE	3	12	26.04	WEATHER
6/1/2014	0.42	ML	5	8	3.36	WEATHER

6/1/2014	0.5	SVILLE	1	2	1	MISCELLANEOUS
6/2/2014	0.67	COLUMBIA	5	8	5.36	MISCELLANEOUS
6/2/2014	0.92	SVILLE	4	18	16.56	MISCELLANEOUS
6/3/2014	0.5	CRESTON	1	36	18	MISCELLANEOUS
6/3/2014	0.5	CRESTON	2	17	8.5	MISCELLANEOUS
6/4/2014	2.08	COLUMBIA	5	1	2.08	WEATHER
6/4/2014	0.67	ML	3	3	2.01	ANIMAL
6/5/2014	3	BASS	1	1	3	ANIMAL
6/5/2014	1	BASS	2	9	9	ANIMAL
6/5/2014	0.75	WC	3	31	23.25	MISCELLANEOUS
6/6/2014	1.67	COBURG	4	2	3.34	ANIMAL
6/6/2014	1.33	CRESTON	1	37	49.21	MISCELLANEOUS
6/7/2014	2	EC	2	2	4	MISCELLANEOUS
6/8/2014	5.58	EC	1	1	5.58	EQUIPMENT MATERIAL FAILURE
6/8/2014	0.75	PHIL	3	1	0.75	MISCELLANEOUS
6/9/2014	0.42	BASS	3	102	42.84	MISCELLANEOUS
6/9/2014	0.42	CVILLE	4	26	10.92	ANIMAL
6/9/2014	1.33	GARLIN	3	1	1.33	EQUIPMENT MATERIAL FAILURE
6/10/2014	3.25	BASS	1	26	84.5	WEATHER
6/10/2014	5.58	COBURG	1	1	5.58	WEATHER
6/10/2014	1.25	COBURG	1	14	17.5	WEATHER
6/10/2014	2.5	COBURG	2	24	60	WEATHER
6/10/2014	3.75	COBURG	3	1	3.75	WEATHER
6/10/2014	4.83	COBURG	3	2	9.66	WEATHER
6/10/2014	2.08	COBURG	3	51	106.08	WEATHER
6/10/2014	3.25	COBURG	3	119	386.75	WEATHER
6/10/2014	4.67	COBURG	4	4	18.68	WEATHER
6/10/2014	8.33	COBURG	4	3	24.99	WEATHER
6/10/2014	5.17	COBURG	4	13	67.21	WEATHER
6/10/2014	3	COBURG	4	50	150	WEATHER
6/10/2014	4.25	COBURG	4	46	195.5	WEATHER
6/10/2014	6.83	COLUMBIA	2	8	54.64	WEATHER
6/10/2014	2.92	COLUMBIA	2	71	207.32	WEATHER
6/10/2014	3.08	CRESTON	3	77	237.16	WEATHER

6/10/2014	6.33	GARLIN	5	8	50.64	WEATHER
6/10/2014	4.83	GARLIN	5	40	193.2	WEATHER
6/10/2014	3.92	PHIL	2	2	7.84	WEATHER
6/10/2014	2	PHIL	2	20	40	WEATHER
6/10/2014	4.08	WC	3	57	232.56	WEATHER
6/11/2014	2	BASS	2	2	4	WEATHER
6/11/2014	0.45	EC	2	2	0.9	TREE
6/11/2014	16.25	WC	3	1	16.25	WEATHER
6/12/2014	0.67	CRESTON	3	3	2.01	MISCELLANEOUS
6/13/2014	0.75	COBURG	1	1	0.75	ANIMAL
6/13/2014	24	COBURG	2	1	24	EQUIPMENT MATERIAL FAILURE
6/15/2014	4.75	COBURG	4	5	23.75	ANIMAL
6/15/2014	1.25	COLUMBIA	2	8	10	MISCELLANEOUS
6/15/2014	1.67	GARLIN	5	15	25.05	ANIMAL
6/15/2014	2.17	PHIL	2	1	2.17	EQUIPMENT MATERIAL FAILURE
6/15/2014	2	WC	3	31	62	TREE
6/16/2014	1.17	COBURG	4	1	1.17	WEATHER
6/16/2014	0.75	CRESTON	1	3	2.25	MISCELLANEOUS
6/16/2014	1.5	WC	3	3	4.5	MISCELLANEOUS
6/17/2014	0.8	EC	3	5	4	MISCELLANEOUS
6/17/2014	0.33	GBURG	3	1	0.33	EQUIPMENT MATERIAL FAILURE
6/17/2014	3.5	WC	3	1	3.5	MISCELLANEOUS
6/17/2014	0.67	WC	3	124	83.08	MISCELLANEOUS
6/18/2014	0.2	COLUMBIA	2	21	4.2	PLANNED
6/18/2014	2	CRESTON	2	1	2	EQUIPMENT MATERIAL FAILURE
6/19/2014	1.17	MCK	2	67	78.39	WEATHER
6/19/2014	2.53	MCK	2	33	83.49	WEATHER
6/19/2014	1.33	ML	2	5	6.65	ANIMAL
6/19/2014	1.17	ML	2	16	18.72	TREE
6/19/2014	0.93	ML	3	63	58.59	CONSUMER
6/19/2014	0.62	WC	3	1	0.62	MISCELLANEOUS
6/20/2014	2.5	BASS	3	102	255	MISCELLANEOUS
6/20/2014	8.58	COLUMBIA	5	5	42.9	WEATHER
6/20/2014	2.83	COLUMBIA	5	16	45.28	WEATHER

6/20/2014	1.75	EC	3	5	8.75	ANIMAL
6/20/2014	0.78	MCK	2	234	182.52	PLANNED
6/20/2014	0.42	ML	5	1	0.42	ANIMAL
6/21/2014	0.63	COBURG	2	18	11.34	TREE
6/21/2014	4.25	GBURG	1	2	8.5	WEATHER
6/21/2014	1.75	GBURG	5	107	187.25	WEATHER
6/21/2014	1.83	MCK	1	17	31.11	ANIMAL
6/21/2014	1.75	SVILLE	2	302	528.5	WEATHER
6/21/2014	2.08	SVILLE	4	210	436.8	WEATHER
6/23/2014	2	BASS	2	40	80	MISCELLANEOUS
6/23/2014	5.17	ML	4	1	5.17	WEATHER
6/23/2014	1.67	ML	4	98	163.66	WEATHER
6/24/2014	1.5	CRESTON	1	1	1.5	EQUIPMENT MATERIAL FAILURE
6/24/2014	12	PHIL	2	4	48	WEATHER
6/26/2014	1.67	GARLIN	5	75	125.25	MISCELLANEOUS
6/26/2014	0.25	ML	2	1	0.25	EQUIPMENT MATERIAL FAILURE
6/27/2014	1.42	BASS	2	495	702.9	CONSUMER
6/27/2014	7.33	COBURG	4	1	7.33	ANIMAL
6/27/2014	1.75	COLUMBIA	2	1	1.75	OVERLOAD
6/27/2014	2.58	GARLIN	3	2	5.16	CONSUMER
6/27/2014	1.5	PHIL	1	1	1.5	MISCELLANEOUS
6/28/2014	1.08	GRP	1	656	708.48	WEATHER
6/28/2014	0.67	SVILLE	4	4	2.68	MISCELLANEOUS
6/29/2014	1	COBURG	2	1	1	CONSUMER
6/29/2014	0.75	CVILLE	2	1	0.75	CONSUMER
6/29/2014	2	PHIL	3	1	2	WEATHER
6/30/2014	2	CRESTON	3	1	2	CONSUMER
6/30/2014	0.75	GARLIN	5	11	8.25	MISCELLANEOUS
6/30/2014	0.83	GARLIN	5	75	62.25	ANIMAL
6/30/2014	0.58	ML	6	5	2.9	ANIMAL
7/1/2014	1.67	SVILLE	4	139	232.13	TREE
7/2/2014	2.83	SVILLE	4	1	2.83	TREE
7/3/2014	0.58	GRP	1	77	44.66	TREE
7/4/2014	1.75	BASS	2	3	5.25	ANIMAL

7/4/2014	1.33	BASS	3	102	135.66	ANIMAL
7/4/2014	1.25	ML	3	1	1.25	MISCELLANEOUS
7/7/2014	0.67	SVILLE	4	23	15.41	WEATHER
7/7/2014	1.75	WC	2	29	50.75	CONSUMER
7/7/2014	3.75	WC	2	61	228.75	CONSUMER
7/8/2014	0.75	CRESTON	3	46	34.5	MISCELLANEOUS
7/8/2014	0.58	MCK	2	67	38.86	WEATHER
7/8/2014	0.75	PHIL	1	125	93.75	MISCELLANEOUS
7/9/2014	0.62	BASS	3	102	63.24	MISCELLANEOUS
7/9/2014	0.93	COBURG	2	1	0.93	WEATHER
7/9/2014	1.75	CRESTON	2	3	5.25	WEATHER
7/9/2014	1.17	GARLIN	2	9	10.53	ANIMAL
7/10/2014	1	PHIL	1	338	338	CONSUMER
7/11/2014	2.25	COLUMBIA	2	26	58.5	EQUIPMENT MATERIAL FAILURE
7/11/2014	1.25	COLUMBIA	5	1	1.25	OVERLOAD
7/11/2014	9.5	CVILLE	3	2	19	EQUIPMENT MATERIAL FAILURE
7/12/2014	0.75	COBURG	2	29	21.75	TREE
7/12/2014	2.25	COBURG	3	1	2.25	OVERLOAD
7/13/2014	1.92	COLUMBIA	2	1	1.92	WEATHER
7/13/2014	0.5	ML	5	2	1	ANIMAL
7/14/2014	3.17	BASS	3	1	3.17	TREE
7/14/2014	1.33	SVILLE	3	46	61.18	EQUIPMENT MATERIAL FAILURE
7/14/2014	1.5	SVILLE	4	4	6	ANIMAL
7/14/2014	1	SVILLE	4	29	29	TREE
7/15/2014	0.58	PHIL	1	122	70.76	MISCELLANEOUS
7/15/2014	0.83	PHIL	3	4	3.32	MISCELLANEOUS
7/15/2014	1	SVILLE	4	61	61	WEATHER
7/18/2014	3.58	BASS	3	1	3.58	EQUIPMENT MATERIAL FAILURE
7/20/2014	1.5	PHIL	3	2	3	EQUIPMENT MATERIAL FAILURE
7/21/2014	0.42	CVILLE	3	12	5.04	ANIMAL
7/21/2014	0.75	GBURG	4	2	1.5	CONSUMER
7/21/2014	0.83	SVILLE	3	3	2.49	EQUIPMENT MATERIAL FAILURE
7/22/2014	0.42	CVILLE	3	12	5.04	ANIMAL
7/22/2014	0.75	MCK	2	1	0.75	CONSUMER

7/22/2014	17.33	WC	3	1	17.33	EQUIPMENT MATERIAL FAILURE
7/23/2014	1	BASS	1	1	1	TREE
7/23/2014	2.5	BASS	2	12	30	MISCELLANEOUS
7/23/2014	4	BASS	3	827	3308	WEATHER
7/23/2014	0.58	EC	1	5	2.9	WEATHER
7/23/2014	0.02	EC	2	335	6.7	PLANNED
7/23/2014	6.83	GBURG	6	1	6.83	WEATHER
7/23/2014	6	GBURG	6	2	12	WEATHER
7/23/2014	1.25	GBURG	6	51	63.75	WEATHER
7/23/2014	2.33	GBURG	6	58	135.14	WEATHER
7/23/2014	0.25	GRP	1	6	1.5	ANIMAL
7/23/2014	1	MCK	1	4	4	WEATHER
7/23/2014	5.83	MCK	1	1	5.83	WEATHER
7/23/2014	8	MCK	1	2	16	WEATHER
7/23/2014	3.5	MCK	3	36	126	WEATHER
7/23/2014	6.5	MCK	3	2	13	TREE
7/23/2014	1.08	ML	3	18	19.44	WEATHER
7/23/2014	0.5	ML	4	7	3.5	WEATHER
7/23/2014	0.67	SVILLE	1	20	13.4	WEATHER
7/23/2014	0.92	SVILLE	4	5	4.6	WEATHER
7/23/2014	1	WC	4	86	86	WEATHER
7/24/2014	6.25	COLUMBIA	4	1	6.25	WEATHER
7/24/2014	8.75	MCK	2	1	8.75	WEATHER
7/24/2014	8	MCK	2	6	48	WEATHER
7/25/2014	0.42	GRP	1	6	2.52	ANIMAL
7/25/2014	1	MCK	3	1	1	ANIMAL
7/26/2014	1.17	SVILLE	4	10	11.7	WEATHER
7/27/2014	0.58	BASS	2	2	1.16	WEATHER
7/27/2014	2	BASS	2	40	80	WEATHER
7/27/2014	0.5	BASS	3	66	33	WEATHER
7/27/2014	0.83	COLUMBIA	5	12	9.96	WEATHER
7/27/2014	4	CRESTON	1	2	8	TREE
7/27/2014	1.5	GARLIN	5	75	112.5	WEATHER
7/27/2014	3	GBURG	3	30	90	WEATHER

7/27/2014	2.83	GBURG	3	97	274.51	WEATHER
7/27/2014	0.75	GRP	1	1	0.75	WEATHER
7/27/2014	1.75	GRP	1	1	1.75	WEATHER
7/27/2014	6.67	MCK	1	1	6.67	WEATHER
7/27/2014	2	MCK	1	4	8	WEATHER
7/27/2014	1.5	ML	3	3	4.5	WEATHER
7/27/2014	2	PHIL	1	122	244	TREE
7/27/2014	2	PHIL	1	810	1620	WEATHER
7/27/2014	3	SVILLE	2	1	3	WEATHER
7/27/2014	3.5	SVILLE	4	1	3.5	WEATHER
7/27/2014	4	SVILLE	4	10	40	WEATHER
7/27/2014	1.83	SVILLE	4	29	53.07	WEATHER
7/27/2014	1.33	WC	2	1	1.33	WEATHER
7/27/2014	1.33	WC	2	2	2.66	WEATHER
7/29/2014	1	BASS	1	1	1	MISCELLANEOUS
7/29/2014	1.08	BASS	3	102	110.16	MISCELLANEOUS
7/29/2014	1.08	COLUMBIA	2	3	3.24	MISCELLANEOUS
7/30/2014	1	SVILLE	4	1	1	PLANNED
7/31/2014	0.58	ML	2	10	5.8	TREE
7/31/2014	1.25	WC	2	15	18.75	EQUIPMENT MATERIAL FAILURE
7/31/2014	1.08	WC	3	3	3.24	MISCELLANEOUS
7/31/2014	1.83	WC	3	1	1.83	CONSUMER
8/1/2014	0.33	WC	3	5	1.65	MISCELLANEOUS
8/4/2014	1	GRP	1	13	13	EQUIPMENT MATERIAL FAILURE
8/5/2014	0.75	BASS	1	63	47.25	MISCELLANEOUS
8/5/2014	1	SVILLE	1	62	62	MISCELLANEOUS
8/6/2014	0.25	GRP	1	12	3	ANIMAL
8/8/2014	1	PHIL	1	2	2	WEATHER
8/8/2014	2	PHIL	2	27	54	WEATHER
8/8/2014	0.42	SVILLE	1	1	0.42	MISCELLANEOUS
8/8/2014	0.53	WC	2	3	1.59	PLANNED
8/8/2014	0.07	WC	2	71	4.97	PLANNED
8/9/2014	1	GBURG	3	1	1	ANIMAL
8/9/2014	0.92	ML	5	32	29.44	TREE

8/9/2014	0.83	ML	6	5	4.15	TREE
8/10/2014	1	MCK	3	36	36	WEATHER
8/10/2014	1	PHIL	2	27	27	EQUIPMENT MATERIAL FAILURE
8/11/2014	1.17	COLUMBIA	1	3	3.51	WEATHER
8/11/2014	0.75	COLUMBIA	2	3	2.25	WEATHER
8/11/2014	0.92	COLUMBIA	5	3	2.76	WEATHER
8/11/2014	0.5	COLUMBIA	5	123	61.5	WEATHER
8/11/2014	1.58	CVILLE	5	2	3.16	TREE
8/11/2014	0.83	CVILLE	5	91	75.53	TREE
8/11/2014	0.75	EC	2	5	3.75	WEATHER
8/11/2014	0.27	GRP	3	1	0.27	WEATHER
8/11/2014	2.17	MCK	1	624	1354.08	WEATHER
8/11/2014	0.58	ML	1	19	11.02	WEATHER
8/11/2014	1.33	PHIL	3	3	3.99	EQUIPMENT MATERIAL FAILURE
8/11/2014	1	PHIL	3	90	90	TREE
8/14/2014	1	COLUMBIA	2	5	5	MISCELLANEOUS
8/14/2014	0.83	CVILLE	3	1	0.83	ANIMAL
8/15/2014	0.42	COBURG	2	4	1.68	MISCELLANEOUS
8/15/2014	5	COBURG	3	1	5	WEATHER
8/15/2014	0.83	EC	2	5	4.15	ANIMAL
8/15/2014	0.5	MCK	3	1	0.5	WEATHER
8/18/2014	1.17	COBURG	2	59	69.03	WEATHER
8/19/2014	1.5	COLUMBIA	3	12	18	CONSUMER
8/19/2014	0.92	ML	2	82	75.44	TREE
8/20/2014	1.67	GBURG	1	2	3.34	WEATHER
8/20/2014	1	GBURG	1	29	29	WEATHER
8/20/2014	2.5	MCK	1	2	5	EQUIPMENT MATERIAL FAILURE
8/21/2014	1.2	CVILLE	ALL	1571	1885.2	POWER SUPPLY
8/21/2014	0.03	EC	1	709	21.27	PLANNED
8/21/2014	0.07	EC	1	709	49.63	PLANNED
8/21/2014	0.1	GRP	3	363	36.3	PLANNED
8/21/2014	1.2	GRP	ALL	1099	1318.8	POWER SUPPLY
8/21/2014	4.22	ML	1	263	1109.86	POWER SUPPLY
8/21/2014	2.87	ML	5	403	1156.61	POWER SUPPLY

8/21/2014	4.22	ML	6	90	379.8	POWER SUPPLY
8/21/2014	2.55	ML	2,1,6	1036	2641.8	POWER SUPPLY
8/21/2014	3.93	ML	3,4	953	3745.29	POWER SUPPLY
8/22/2014	0.5	COBURG	2	35	17.5	TREE
8/22/2014	0.75	ML	1	26	19.5	ANIMAL
8/23/2014	6.67	BASS	3	1	6.67	WEATHER
8/23/2014	0.5	CVILLE	3	2	1	TREE
8/23/2014	1	GBURG	3	1	1	WEATHER
8/23/2014	2.25	GBURG	3	3	6.75	WEATHER
8/23/2014	1.83	GBURG	5	1	1.83	WEATHER
8/23/2014	1.58	MCK	2	51	80.58	WEATHER
8/23/2014	2.67	SVILLE	4	17	45.39	WEATHER
8/24/2014	2	PHIL	2	1	2	TREE
8/25/2014	1	CRESTON	1	1	1	EQUIPMENT MATERIAL FAILURE
8/25/2014	1.83	SVILLE	1	52	95.16	TREE
8/28/2014	0.75	WC	4	1	0.75	PLANNED
8/30/2014	1.33	SVILLE	4	139	184.87	EQUIPMENT MATERIAL FAILURE
8/31/2014	1	MCK	2	51	51	WEATHER
8/31/2014	3.25	WC	2	2	6.5	TREE
9/1/2014	4.33	BASS	1	37	160.21	TREE
9/1/2014	1.83	COBURG	2	1	1.83	EQUIPMENT MATERIAL FAILURE
9/1/2014	1	SVILLE	4	61	61	WEATHER
9/2/2014	4	BASS	1	6	24	WEATHER
9/2/2014	0.5	COLUMBIA	3	3	1.5	PLANNED
9/2/2014	0.48	CVILLE	3	4	1.92	WEATHER
9/2/2014	1.15	EC	1	2	2.3	EQUIPMENT MATERIAL FAILURE
9/2/2014	1.17	EC	1	6	7.02	WEATHER
9/2/2014	0.25	GRP	1	3	0.75	WEATHER
9/2/2014	0.67	ML	2	16	10.72	WEATHER
9/2/2014	0.83	ML	5	32	26.56	WEATHER
9/2/2014	1.5	SVILLE	3	431	646.5	EQUIPMENT MATERIAL FAILURE
9/2/2014	0.5	SVILLE	4	61	30.5	TREE
9/4/2014	1	CRESTON	3	1	1	MISCELLANEOUS
9/4/2014	0.67	ML	3	63	42.21	MISCELLANEOUS

9/4/2014	1.25	SVILLE	3	9	11.25	EQUIPMENT MATERIAL FAILURE
9/5/2014	2	CRESTON	1	47	94	MISCELLANEOUS
9/5/2014	0.67	GRP	3	5	3.35	EQUIPMENT MATERIAL FAILURE
9/7/2014	0.67	EC	2	1	0.67	CONSUMER
9/7/2014	0.83	MCK	2	1	0.83	EQUIPMENT MATERIAL FAILURE
9/8/2014	3	COBURG	3	1	3	EQUIPMENT MATERIAL FAILURE
9/9/2014	27.42	COBURG	3	1	27.42	WEATHER
9/10/2014	1.08	COBURG	2	8	8.64	MISCELLANEOUS
9/10/2014	0.5	COBURG	2	35	17.5	TREE
9/10/2014	1.25	MCK	2	51	63.75	MISCELLANEOUS
9/11/2014	1.37	GARLIN	5	35	47.95	EQUIPMENT MATERIAL FAILURE
9/14/2014	0.75	PHIL	2	1	0.75	MISCELLANEOUS
9/15/2014	0.58	COLUMBIA	2	5	2.9	MISCELLANEOUS
9/15/2014	4	SVILLE	2	3	12	EQUIPMENT MATERIAL FAILURE
9/19/2014	1.17	MCK	1	96	112.32	EQUIPMENT MATERIAL FAILURE
9/20/2014	0.5	ML	3	2	1	MISCELLANEOUS
9/23/2014	0.83	ML	6	5	4.15	ANIMAL
9/23/2014	0.5	ML	6	5	2.5	MISCELLANEOUS
9/24/2014	0.6	GRP	3	3	1.8	ANIMAL
9/24/2014	1.25	ML	6	5	6.25	ANIMAL
9/25/2014	1.25	ML	1	49	61.25	PLANNED
9/25/2014	0.83	ML	4	57	47.31	TREE
9/27/2014	0.67	ML	1	7	4.69	ANIMAL
9/27/2014	1.5	PHIL	1	340	510	MISCELLANEOUS
9/28/2014	1.83	COLUMBIA	5	1	1.83	EQUIPMENT MATERIAL FAILURE
9/28/2014	1.67	CRESTON	3	19	31.73	MISCELLANEOUS
9/28/2014	1	ML	1	6	6	ANIMAL
9/28/2014	1.42	SVILLE	4	60	85.2	MISCELLANEOUS
9/29/2014	1	BASS	1	26	26	CONSUMER
9/29/2014	0.67	WC	3	1	0.67	MISCELLANEOUS
10/1/2014	1.08	GARLIN	3	1	1.08	OVERLOAD
10/2/2014	0.08	COBURG	4	5	0.4	PLANNED
10/2/2014	2	COBURG	4	42	84	EQUIPMENT MATERIAL FAILURE
10/2/2014	1.58	GBURG	3	4	6.32	ANIMAL

10/3/2014	0.5	COBURG	2	17	8.5	ANIMAL
10/3/2014	2.25	COLUMBIA	3	221	497.25	TREE
10/3/2014	1.5	CRESTON	3	8	12	TREE
10/3/2014	0.67	SVILLE	4	139	93.13	WEATHER
10/4/2014	0.58	ML	6	26	15.08	ANIMAL
10/6/2014	0.33	SVILLE	4	4	1.32	WEATHER
10/7/2014	4	BASS	2	1	4	WEATHER
10/7/2014	1.5	BASS	2	9	13.5	WEATHER
10/7/2014	1.58	BASS	3	56	88.48	EQUIPMENT MATERIAL FAILURE
10/7/2014	3.5	COBURG	1	1	3.5	WEATHER
10/7/2014	1	COLUMBIA	6	5	5	ANIMAL
10/7/2014	0.67	CVILLE	2	35	23.45	ANIMAL
10/7/2014	1	MCK	3	4	4	WEATHER
10/7/2014	0.42	WC	3	38	15.96	PLANNED
10/8/2014	1.67	GBURG	1	2	3.34	MISCELLANEOUS
10/8/2014	0.75	GBURG	4	3	2.25	MISCELLANEOUS
10/8/2014	1.33	SVILLE	3	9	11.97	ANIMAL
10/8/2014	1.33	SVILLE	4	10	13.3	MISCELLANEOUS
10/9/2014	3.58	COLUMBIA	2	2	7.16	WEATHER
10/9/2014	0.67	COLUMBIA	2	68	45.56	WEATHER
10/9/2014	1.5	CRESTON	3	1	1.5	TREE
10/9/2014	1.83	MCK	1	90	164.7	WEATHER
10/9/2014	0.45	ML	5	56	25.2	ANIMAL
10/10/2014	0.83	CRESTON	3	1	0.83	MISCELLANEOUS
10/10/2014	1.75	GARLIN	4	3	5.25	WEATHER
10/10/2014	1	MCK	3	28	28	WEATHER
10/11/2014	1.5	GBURG	5	1	1.5	TREE
10/12/2014	3.5	CRESTON	1	1	3.5	TREE
10/12/2014	2	CRESTON	1	2	4	WEATHER
10/13/2014	0.42	SVILLE	4	149	62.58	ANIMAL
10/14/2014	0.67	MCK	2	158	105.86	WEATHER
10/16/2014	3.25	BASS	3	78	253.5	EQUIPMENT MATERIAL FAILURE
10/16/2014	5.42	GBURG	5	1	5.42	EQUIPMENT MATERIAL FAILURE
10/17/2014	2.67	BASS	3	1	2.67	CONSUMER

10/17/2014	0.83	COBURG	3	1	0.83	ANIMAL
10/20/2014	28.03	CRESTON	3	1	28.03	CONSUMER
10/20/2014	1.33	GARLIN	5	16	21.28	MISCELLANEOUS
10/20/2014	3.33	GARLIN	3	5	16.65	MISCELLANEOUS
10/20/2014	1.5	PHIL	2	2	3	MISCELLANEOUS
10/21/2014	1	ML	6	1	1	CONSUMER
10/22/2014	0.83	EC	3	10	8.3	MISCELLANEOUS
10/22/2014	0.33	ML	1	47	15.51	MISCELLANEOUS
10/22/2014	1.08	ML	2	33	35.64	ANIMAL
10/23/2014	0.5	EC	5	6	3	ANIMAL
10/23/2014	1.42	ML	6	1	1.42	OVERLOAD
10/24/2014	2.5	CRESTON	1	25	62.5	TREE
10/26/2014	0.75	MCK	2	21	15.75	MISCELLANEOUS
10/27/2014	0.52	ML	4	1	0.52	EQUIPMENT MATERIAL FAILURE
10/28/2014	0.67	ML	3	2	1.34	MISCELLANEOUS
11/1/2014	4.42	BASS	3	2	8.84	EQUIPMENT MATERIAL FAILURE
11/1/2014	3.33	BASS	3	79	263.07	EQUIPMENT MATERIAL FAILURE
11/1/2014	5.75	COBURG	3	2	11.5	EQUIPMENT MATERIAL FAILURE
11/1/2014	1.67	GARLIN	5	75	125.25	TREE
11/1/2014	3	MCK	2	78	234	TREE
11/2/2014	3.33	MCK	2	17	56.61	CONSUMER
11/2/2014	1	ML	6	5	5	ANIMAL
11/3/2014	4.5	MCK	2	2	9	CONSUMER
11/3/2014	1	MCK	2	83	83	CONSUMER
11/4/2014	1.45	COLUMBIA	5	2	2.9	ANIMAL
11/4/2014	0.78	COLUMBIA	5	123	95.94	ANIMAL
11/5/2014	1	CRESTON	1	41	41	CONSUMER
11/5/2014	0.33	MCK	1	120	39.6	MISCELLANEOUS
11/6/2014	0.58	CVILLE	5	16	9.28	TREE
11/11/2014	0.92	COBURG	2	1	0.92	MISCELLANEOUS
11/14/2014	0.02	GARLIN	3	679	13.58	PLANNED
11/14/2014	0.02	GARLIN	3	679	13.58	PLANNED
11/14/2014	1.07	WC	4	19	20.33	MISCELLANEOUS
11/16/2014	1.67	MCK	1	38	63.46	ANIMAL

11/17/2014	0.75	ML	2	8	6	MISCELLANEOUS
11/19/2014	0.8	BASS	2	4	3.2	OVERLOAD
11/20/2014	0.67	ML	3	42	28.14	ANIMAL
11/21/2014	1	MCK	2	1	1	OVERLOAD
11/21/2014	3	MCK	3	2	6	ANIMAL
11/21/2014	2	MCK	3	27	54	ANIMAL
11/22/2014	1	SVILLE	4	51	51	MISCELLANEOUS
11/23/2014	1.33	EC	5	11	14.63	EQUIPMENT MATERIAL FAILURE
11/24/2014	4.83	COLUMBIA	5	17	82.11	WEATHER
11/24/2014	2	CRESTON	3	10	20	TREE
11/24/2014	2	CRESTON	3	20	40	TREE
11/24/2014	1.33	CRESTON	3	46	61.18	TREE
11/24/2014	0.67	CVILLE	3	21	14.07	TREE
11/24/2014	0.93	CVILLE	3	21	19.53	TREE
11/24/2014	3.23	GARLIN	2	2	6.46	EQUIPMENT MATERIAL FAILURE
11/24/2014	76.75	ML	1	1	76.75	EQUIPMENT MATERIAL FAILURE
11/25/2014	1.83	COBURG	3	2	3.66	MISCELLANEOUS
11/26/2014	6	WC	2	1	6	EQUIPMENT MATERIAL FAILURE
11/27/2014	1.42	EC	3	465	660.3	MISCELLANEOUS
11/28/2014	2.08	BASS	3	2	4.16	TREE
11/28/2014	8.5	BASS	3	1	8.5	EQUIPMENT MATERIAL FAILURE
11/30/2014	1.5	EC	1	5	7.5	MISCELLANEOUS
11/30/2014	0.92	WC	2	1	0.92	CONSUMER
12/2/2014	0.67	MCK	1	20	13.4	ANIMAL
12/3/2014	26	COLUMBIA	2	1	26	EQUIPMENT MATERIAL FAILURE
12/3/2014	25.83	CRESTON	3	2	51.66	TREE
12/3/2014	1.92	WC	2	60	115.2	ANIMAL
12/4/2014	0.83	MCK	2	79	65.57	MISCELLANEOUS
12/7/2014	1.17	SVILLE	3	1	1.17	EQUIPMENT MATERIAL FAILURE
12/7/2014	1.33	WC	3	20	26.6	ANIMAL
12/8/2014	1.83	COBURG	1	63	115.29	EQUIPMENT MATERIAL FAILURE
12/10/2014	1	BASS	1	1	1	ANIMAL
12/12/2014	1.5	MCK	3	60	90	EQUIPMENT MATERIAL FAILURE
12/12/2014	0.33	SVILLE	2	5	1.65	MISCELLANEOUS

12/13/2014	2.17	BASS	3	86	186.62	MISCELLANEOUS
12/13/2014	0.67	CRESTON	1	26	17.42	MISCELLANEOUS
12/15/2014	0.43	COBURG	4	350	150.5	EQUIPMENT MATERIAL FAILURE
12/15/2014	0.5	ML	6	37	18.5	ANIMAL
12/15/2014	1	SVILLE	2	13	13	MISCELLANEOUS
12/16/2014	0.58	COBURG	1	1	0.58	MISCELLANEOUS
12/16/2014	0.92	COBURG	3	1	0.92	CONSUMER
12/16/2014	1.67	COBURG	3	12	20.04	EQUIPMENT MATERIAL FAILURE
12/23/2014	2	MCK	1	1	2	EQUIPMENT MATERIAL FAILURE
12/24/2014	2.08	CVILLE	2	1	2.08	EQUIPMENT MATERIAL FAILURE
12/24/2014	0.75	CVILLE	5	23	17.25	MISCELLANEOUS
12/25/2014	0.83	ML	6	49	40.67	ANIMAL
12/26/2014	1.08	ML	3	64	69.12	EQUIPMENT MATERIAL FAILURE
12/26/2014	0.75	ML	6	1	0.75	MISCELLANEOUS
12/28/2014	0.67	COBURG	4	4	2.68	MISCELLANEOUS
12/28/2014	1.5	CRESTON	3	5	7.5	ANIMAL
12/28/2014	0.58	ML	4	12	6.96	TREE
12/29/2014	70.67	GBURG	4	1	70.67	ANIMAL
12/29/2014	70.17	MCK	1	1	70.17	MISCELLANEOUS