

RECEIVED

MAR 21 2016

Public Service  
Commission

# Taylor County RECC 2015 Outage Data

*Case No. 2011-00450*

**PSC Outage Tabulation, 2015**

Taylor County RECC

<b>System:</b>			
<u>Year</u>	<u>SAIDI</u>	<u>SAIFI</u>	<u>CAIDI</u>
2010	307.16	3.91	78.65
2011	89.4	1.1	81.7
2012	74.0	1.3	57.4
2013	386.84	4.24	91.27
2014	119.18	1.58	75.29
<b>2015</b>	<b>198.6</b>	<b>1.3</b>	<b>150.7</b>

<b>Outage Subcategory Breakdown:</b>	
<u>Subcategory:</u>	<u>Mins:</u>
Animal	83,208.0
Consumer	204,397.8
Equipment	400,209.0
Miscellaneous	343,717.8
Overload	8,463.6
Plan	71,383.2
Power Supplier	136,572.0
Tree	262,632.6
Weather	3,682,659.0

**2015 - Major outage day defined per IEEE standard**

5yr avg Tmed for 15

87,987.8

Major Outage Days - 5/11 Weather(186,175.8), 6/19 Weather(92,374.8),  
7/9 Weather(215,399.4), 7/10 Weather(134,638.2), 7/13 Weather(2,279,998.8),  
7/14 Weather(205,445.4), 7/15 Weather(110,388), 10/24 Consumer(115,350)

**2015 10 Worst Circuits per Category:**

<u>Substation</u>	<u>C</u>	<u>SAIDI</u>	<u>SAIFI</u>	<u>CAIDI</u>	<u>Mai. Out. Category</u>
SUMMERSVILLE	1	889.7			WEATHER
SUMMERSVILLE	4	838.6			WEATHER
GREENSBURG	3	526.4			WEATHER
WEST COLUMBIA	2	473.6			WEATHER
EAST CAMPBELLSVILLE	3	455.4			WEATHER
GREENSBURG	5	426.7			WEATHER
GREENSBURG	1	423.5			WEATHER
MILE LANE	3	331.6			WEATHER
COLUMBIA	2	326.7			WEATHER
BASS	2	324.8			WEATHER
EAST CAMPBELLSVILLE	1		4.2		TREE
GREENSBURG	5		4.0		WEATHER
SUMMERSVILLE	4		3.6		WEATHER

SUMMERSVILLE	1	3.6		WEATHER
GREENSBURG	4	3.4		WEATHER
GREENSBURG	1	2.7		WEATHER
PHIL	5	2.6		WEATHER
MILE LANE	4	2.2		WEATHER
EAST CAMPBELLSVILLE	3	2.2		WEATHER
GARLIN	5	2.2		WEATHER
BASS	2		350.5	WEATHER
COLUMBIA	5		257.0	WEATHER
SUMMERSVILLE	1		246.5	WEATHER
GREENSBURG	3		241.7	WEATHER
GARLIN	3		240.2	WEATHER
MILE LANE	1		235.6	EQUIPMENT
COBURG	1		231.9	WEATHER
SUMMERSVILLE	4		231.2	WEATHER
WEST COLUMBIA	2		227.0	WEATHER
EAST CAMPBELLSVILLE	3		205.1	WEATHER

**Vegetation Management Plan:**

Plan is progressing as expected/desired

Continue to face occasional issue with yard tree clearance

Outages - 2015  
Taylor County RECC

<u>Date</u>	<u>Total Time (hrs)</u>	<u>Substation</u>	<u>Ckt(s)</u>	<u># Membrs Effected</u>	<u>Consumers Hrs Off</u>	<u>Cause</u>
1/3/2015	4.5	ML	1	174	783	EQUIPMENT/MATERIAL FAILURE
1/4/2015	1.83	GBURG	3	2	3.66	EQUIPMENT/MATERIAL FAILURE
1/6/2015	1.42	COBURG	1	37	52.54	MISCELLANEOUS
1/7/2015	0.67	SVILLE	1	1	0.67	EQUIPMENT/MATERIAL FAILURE
1/8/2015	1.25	BASS	2	1	1.25	EQUIPMENT/MATERIAL FAILURE
1/8/2015	2.25	BASS	2	19	42.75	EQUIPMENT/MATERIAL FAILURE
1/8/2015	1	PHIL	5	5	5	WEATHER
1/12/2015	1	SVILLE	4	10	10	MISCELLANEOUS
1/14/2015	2	MCK	2	1	2	CONSUMER
1/15/2015	1	GARLIN	4	3	3	MISCELLANEOUS
1/16/2015	0.83	ML	1	1	0.83	ANIMAL
1/16/2015	29.25	WC	3	1	29.25	EQUIPMENT/MATERIAL FAILURE
1/17/2015	3	SVILLE	4	1	3	CONSUMER
1/17/2015	47.08	MCK	2	1	47.08	OVERLOAD
1/20/2015	0.58	CVILLE	3	100	58	ANIMAL
1/24/2015	2.07	COLUMBIA	2	29	60.03	CONSUMER
1/24/2015	1.5	ML	1	1	1.5	EQUIPMENT/MATERIAL FAILURE
1/24/2015	2.4	COLUMBIA	2	2	4.8	EQUIPMENT/MATERIAL FAILURE
1/26/2015	1	SVILLE	4	4	4	MISCELLANEOUS
1/27/2015	1	MCK	2	52	52	CONSUMER
1/29/2015	2.67	MCK	1	3	8.01	CONSUMER
1/29/2015	1.32	SVILLE	2	2	2.64	EQUIPMENT/MATERIAL FAILURE
1/30/2015	1.17	BASS	1	1	1.17	CONSUMER
1/30/2015	0.5	SVILLE	1	11	5.5	MISCELLANEOUS
1/31/2015	1	WC	2	6	6	CONSUMER
1/31/2015	0.83	COBURG	3	6	4.98	MISCELLANEOUS
2/1/2015	1	CRESTON	3	7	7	WEATHER
2/6/2015	1.17	CRESTON	3	3	3.51	CONSUMER
2/10/2015	2	CRESTON	2	14	28	TREE
2/12/2015	2	CRESTON	1	1	2	MISCELLANEOUS
2/14/2015	2	CRESTON	1	76	152	CONSUMER
2/14/2015	1.5	COBURG	1	1	1.5	PLANNED
2/15/2015	1.92	COLUMBIA	2	180	345.6	EQUIPMENT/MATERIAL FAILURE

2/17/2015	4	PHIL	1	1	4	WEATHER
2/19/2015	1.5	EC	5	1	1.5	OVERLOAD
2/19/2015	1	GBURG	6	4	4	OVERLOAD
2/19/2015	3.67	WC	2	2	7.34	OVERLOAD
2/19/2015	5.08	COBURG	4	2	10.16	OVERLOAD
2/19/2015	1.58	GARLIN	5	41	64.78	WEATHER
2/19/2015	4	BASS	1	18	72	WEATHER
2/19/2015	3	BASS	3	54	162	WEATHER
2/19/2015	5.5	CRESTON	3	76	418	WEATHER
2/20/2015	6.25	EC	2	3	18.75	EQUIPMENT/MATERIAL FAILURE
2/20/2015	0.67	GARLIN	3	2	1.34	OVERLOAD
2/20/2015	2	COBURG	2	2	4	OVERLOAD
2/20/2015	0.58	GRP	1	12	6.96	OVERLOAD
2/20/2015	0.5	GRP	1	15	7.5	OVERLOAD
2/20/2015	2	GBURG	6	4	8	OVERLOAD
2/20/2015	3	GBURG	6	5	15	OVERLOAD
2/20/2015	1.42	PHIL	2	104	147.68	TREE
2/21/2015	1.5	SVILLE	4	10	15	MISCELLANEOUS
2/21/2015	1.5	SVILLE	1	584	876	POWER SUPPLY
2/22/2015	1.33	GARLIN	5	2	2.66	MISCELLANEOUS
2/22/2015	3	SVILLE	1	2	6	OVERLOAD
2/22/2015	4	MCK	2	51	204	WEATHER
2/23/2015	1.67	GARLIN	5	384	641.28	EQUIPMENT/MATERIAL FAILURE
2/23/2015	4	MCK	2	64	256	TREE
2/24/2015	1.08	EC	3	1	1.08	EQUIPMENT/MATERIAL FAILURE
2/25/2015	3	GARLIN	3	1	3	EQUIPMENT/MATERIAL FAILURE
2/25/2015	0.75	CRESTON	3	1	0.75	MISCELLANEOUS
2/26/2015	2.75	WC	2	1	2.75	MISCELLANEOUS
2/28/2015	0.67	COLUMBIA	2	8	5.36	WEATHER
3/2/2015	15.67	BASS	3	1	15.67	EQUIPMENT/MATERIAL FAILURE
3/3/2015	0.83	GBURG	4	5	4.15	ANIMAL
3/3/2015	1.83	GARLIN	1	2	3.66	EQUIPMENT/MATERIAL FAILURE
3/6/2015	2.92	CVILLE	3	1	2.92	OVERLOAD
3/7/2015	1	BASS	2	1	1	EQUIPMENT/MATERIAL FAILURE
3/7/2015	2.75	WC	4	2	5.5	EQUIPMENT/MATERIAL FAILURE
3/10/2015	1.5	CVILLE	2	7	10.5	ANIMAL
3/10/2015	1.75	BASS	2	34	59.5	ANIMAL

3/11/2015	0.5	CVILLE	5	91	45.5	ANIMAL
3/12/2015	1.08	SVILLE	2	2	2.16	MISCELLANEOUS
3/19/2015	1.17	WC	2	41	47.97	MISCELLANEOUS
3/21/2015	1	COLUMBIA	2	27	27	MISCELLANEOUS
3/22/2015	24	SVILLE	2	1	24	ANIMAL
3/23/2015	0.75	COBURG	3	1	0.75	EQUIPMENT/MATERIAL FAILURE
3/25/2015	1.67	COBURG	4	3	5.01	ANIMAL
3/25/2015	2	PHIL	1	2	4	EQUIPMENT/MATERIAL FAILURE
3/26/2015	1.83	ML	1	1	1.83	EQUIPMENT/MATERIAL FAILURE
3/27/2015	1	CRESTON	3	46	46	MISCELLANEOUS
3/28/2015	3.17	BASS	1	7	22.19	CONSUMER
3/30/2015	1.42	WC	3	37	52.54	MISCELLANEOUS
4/1/2015	0.83	COBURG	3	2	1.66	EQUIPMENT/MATERIAL FAILURE
4/2/2015	0.58	SVILLE	3	1	0.58	EQUIPMENT/MATERIAL FAILURE
4/2/2015	0.83	SVILLE	4	30	24.9	MISCELLANEOUS
4/2/2015	0.75	PHIL	3	4	3	TREE
4/2/2015	2	SVILLE	3	1	2	WEATHER
4/2/2015	1.83	GARLIN	3	8	14.64	WEATHER
4/2/2015	0.83	COBURG	3	22	18.26	WEATHER
4/2/2015	0.83	COBURG	3	22	18.26	WEATHER
4/2/2015	1.25	GARLIN	3	26	32.5	WEATHER
4/2/2015	0.5	WC	3	103	51.5	WEATHER
4/2/2015	3.92	COLUMBIA	2	45	176.4	WEATHER
4/3/2015	2.5	PHIL	5	1	2.5	TREE
4/3/2015	3	CRESTON	1	26	78	TREE
4/3/2015	0.5	COLUMBIA	3	1	0.5	WEATHER
4/3/2015	1.5	CRESTON	1	4	6	WEATHER
4/3/2015	2	CRESTON	1	5	10	WEATHER
4/3/2015	0.83	CVILLE	3	16	13.28	WEATHER
4/3/2015	0.83	WC	3	37	30.71	WEATHER
4/4/2015	3.5	CRESTON	1	1	3.5	EQUIPMENT/MATERIAL FAILURE
4/4/2015	0.67	CRESTON	1	4	2.68	MISCELLANEOUS
4/4/2015	9	COLUMBIA	5	1	9	MISCELLANEOUS
4/7/2015	1.58	MCK	1	46	72.68	MISCELLANEOUS
4/7/2015	2	PHIL	1	1	2	WEATHER
4/7/2015	0.92	GARLIN	4	3	2.76	WEATHER
4/7/2015	5	GBURG	1	1	5	WEATHER

4/7/2015	5	SVILLE	4	1	5	WEATHER
4/7/2015	1.5	MCK	1	4	6	WEATHER
4/7/2015	4.17	MCK	3	2	8.34	WEATHER
4/7/2015	5.33	GARLIN	5	2	10.66	WEATHER
4/7/2015	3	COBURG	3	5	15	WEATHER
4/7/2015	0.67	SVILLE	4	30	20.1	WEATHER
4/7/2015	3.58	BASS	2	8	28.64	WEATHER
4/7/2015	1	EC	3	34	34	WEATHER
4/7/2015	1.33	SVILLE	3	35	46.55	WEATHER
4/8/2015	384.17	GARLIN	3	1	384.17	MISCELLANEOUS
4/8/2015	0.75	ML	4	7	5.25	WEATHER
4/8/2015	0.75	ML	1	21	15.75	WEATHER
4/9/2015	0.58	ML	3	2	1.16	MISCELLANEOUS
4/9/2015	0.75	BASS	3	46	34.5	MISCELLANEOUS
4/9/2015	1.67	CRESTON	3	53	88.51	TREE
4/10/2015	0.6	COBURG	3	46	27.6	MISCELLANEOUS
4/10/2015	0.58	SVILLE	4	139	80.62	MISCELLANEOUS
4/10/2015	7.5	CRESTON	2	1	7.5	TREE
4/11/2015	0.75	EC	1	2	1.5	ANIMAL
4/12/2015	1.67	CRESTON	3	1	1.67	ANIMAL
4/12/2015	1	CVILLE	5	95	95	ANIMAL
4/14/2015	3	COBURG	2	1	3	WEATHER
4/14/2015	6	COBURG	1	2	12	WEATHER
4/16/2015	1.5	CRESTON	1	1	1.5	CONSUMER
4/16/2015	3	CRESTON	1	1	3	EQUIPMENT/MATERIAL FAILURE
4/19/2015	2.5	PHIL	2	1	2.5	TREE
4/19/2015	1	CVILLE	5	8	8	WEATHER
4/19/2015	1.33	CVILLE	5	8	10.64	WEATHER
4/20/2015	3.83	GBURG	3	1	3.83	EQUIPMENT/MATERIAL FAILURE
4/20/2015	0.5	CVILLE	3	42	21	EQUIPMENT/MATERIAL FAILURE
4/20/2015	2.5	ML	6	1	2.5	WEATHER
4/20/2015	4	CRESTON	1	1	4	WEATHER
4/20/2015	0.75	EC	2	32	24	WEATHER
4/20/2015	1.42	BASS	3	28	39.76	WEATHER
4/20/2015	4.5	CVILLE	5	21	94.5	WEATHER
4/21/2015	0.03	SVILLE	2	305	9.15	PLANNED
4/21/2015	1.83	SVILLE	4	10	18.3	PLANNED

4/21/2015	0.2	SVILLE	4	884	176.8	PLANNED
4/22/2015	1.33	EC	3	1	1.33	EQUIPMENT/MATERIAL FAILURE
4/22/2015	1.08	WC	2	2	2.16	MISCELLANEOUS
4/23/2015	2	CRESTON	3	19	38	EQUIPMENT/MATERIAL FAILURE
4/25/2015	22.67	COLUMBIA	2	1	22.67	WEATHER
4/25/2015	23.17	COLUMBIA	2	1	23.17	WEATHER
4/25/2015	5.5	COLUMBIA	2	36	198	WEATHER
4/25/2015	11.17	COLUMBIA	2	26	290.42	WEATHER
4/26/2015	1	COLUMBIA	2	110	110	ANIMAL
4/27/2015	0.42	SVILLE	1	21	8.82	ANIMAL
4/27/2015	1.17	MCK	1	3	3.51	MISCELLANEOUS
4/28/2015	0.92	ML	5	40	36.8	ANIMAL
4/29/2015	0.7	GBURG	4	1	0.7	MISCELLANEOUS
4/29/2015	1.25	GBURG	4	1	1.25	MISCELLANEOUS
4/29/2015	0.5	GBURG	4	38	19	MISCELLANEOUS
4/30/2015	1.38	SVILLE	4	10	13.8	MISCELLANEOUS
5/1/2015	1	SVILLE	2	7	7	CONSUMER
5/1/2015	2.5	SVILLE	2	3	7.5	CONSUMER
5/1/2015	1.5	BASS	1	83	124.5	TREE
5/2/2015	0.83	CVILLE	3	8	6.64	ANIMAL
5/2/2015	2.17	MCK	1	47	101.99	EQUIPMENT/MATERIAL FAILURE
5/3/2015	1.33	COLUMBIA	5	44	58.52	EQUIPMENT/MATERIAL FAILURE
5/3/2015	1.33	COLUMBIA	5	44	58.52	EQUIPMENT/MATERIAL FAILURE
5/4/2015	0.83	EC	3	5	4.15	ANIMAL
5/4/2015	0.83	CVILLE	3	1	0.83	EQUIPMENT/MATERIAL FAILURE
5/4/2015	1.08	GARLIN	5	20	21.6	EQUIPMENT/MATERIAL FAILURE
5/5/2015	0.83	ML	4	58	48.14	TREE
5/6/2015	1	CRESTON	1	1	1	ANIMAL
5/6/2015	0.67	GBURG	3	97	64.99	CONSUMER
5/7/2015	0.75	WC	3	135	101.25	CONSUMER
5/8/2015	3	BASS	3	30	90	PLANNED
5/9/2015	0.67	CRESTON	1	4	2.68	MISCELLANEOUS
5/10/2015	1.33	ML	2	64	85.12	MISCELLANEOUS
5/11/2015	0.92	ML	1	1	0.92	WEATHER
5/11/2015	2.75	GBURG	3	1	2.75	WEATHER
5/11/2015	1	GBURG	1	3	3	WEATHER
5/11/2015	2	GRP	3	2	4	WEATHER



5/11/2015	0.25	ML	2	16	4	WEATHER
5/11/2015	5.42	EC	1	1	5.42	WEATHER
5/11/2015	2.75	SVILLE	1	2	5.5	WEATHER
5/11/2015	1.33	SVILLE	4	10	13.3	WEATHER
5/11/2015	6.8	COLUMBIA	2	2	13.6	WEATHER
5/11/2015	20.25	BASS	3	1	20.25	WEATHER
5/11/2015	9.5	COLUMBIA	2	3	28.5	WEATHER
5/11/2015	2.5	ML	6	14	35	WEATHER
5/11/2015	3.58	ML	6	10	35.8	WEATHER
5/11/2015	2	GBURG	3	20	40	WEATHER
5/11/2015	2.15	EC	1	27	58.05	WEATHER
5/11/2015	2.58	ML	6	26	67.08	WEATHER
5/11/2015	1	GBURG	3	81	81	WEATHER
5/11/2015	5	GBURG	3	20	100	WEATHER
5/11/2015	1.42	COLUMBIA	2	71	100.82	WEATHER
5/11/2015	2	SVILLE	1	61	122	WEATHER
5/11/2015	2.5	SVILLE	1	61	152.5	WEATHER
5/11/2015	5.53	COLUMBIA	2	33	182.49	WEATHER
5/11/2015	3.83	MCK	2	52	199.16	WEATHER
5/11/2015	6.53	GARLIN	5	39	254.67	WEATHER
5/11/2015	4.67	COLUMBIA	2	71	331.57	WEATHER
5/11/2015	4.8	WC	2	72	345.6	WEATHER
5/11/2015	4.33	COLUMBIA	2	90	389.7	WEATHER
5/11/2015	6.25	ML	2	81	506.25	WEATHER
5/12/2015	1.58	WC	2	2	3.16	ANIMAL
5/12/2015	1.08	SVILLE	1	17	18.36	CONSUMER
5/12/2015	0.83	SVILLE	1	4	3.32	EQUIPMENT/MATERIAL FAILURE
5/12/2015	1.92	SVILLE	1	2	3.84	EQUIPMENT/MATERIAL FAILURE
5/12/2015	2.92	SVILLE	1	2	5.84	EQUIPMENT/MATERIAL FAILURE
5/12/2015	1.42	GARLIN	3	51	72.42	PLANNED
5/12/2015	214.17	ML	2	1	214.17	WEATHER
5/13/2015	0.67	MCK	3	2	1.34	MISCELLANEOUS
5/14/2015	1	PHIL	1	2	2	ANIMAL
5/14/2015	2.67	GARLIN	5	1	2.67	EQUIPMENT/MATERIAL FAILURE
5/14/2015	2	COLUMBIA	2	70	140	TREE
5/15/2015	1.3	COBURG	4	1	1.3	ANIMAL
5/15/2015	1.42	CRESTON	3	1	1.42	EQUIPMENT/MATERIAL FAILURE

5/15/2015	2	SVILLE	4	10	20	EQUIPMENT/MATERIAL FAILURE
5/15/2015	0.75	BASS	2	1	0.75	MISCELLANEOUS
5/15/2015	3.67	CRESTON	3	26	95.42	TREE
5/16/2015	1	PHIL	1	42	42	TREE
5/18/2015	2	PHIL	3	1	2	EQUIPMENT/MATERIAL FAILURE
5/19/2015	1	EC	3	7	7	MISCELLANEOUS
5/20/2015	0.5	COBURG	1	25	12.5	CONSUMER
5/20/2015	0.55	COBURG	1	25	13.75	CONSUMER
5/20/2015	1.17	EC	1	719	841.23	MISCELLANEOUS
5/22/2015	0.38	CRESTON	1	6	2.28	MISCELLANEOUS
5/23/2015	2	MCK	1	52	104	TREE
5/24/2015	1.33	ML	1	11	14.63	MISCELLANEOUS
5/24/2015	1	GBURG	1	27	27	MISCELLANEOUS
5/25/2015	1	MCK	3	2	2	MISCELLANEOUS
5/25/2015	1.33	CVILLE	3	3	3.99	MISCELLANEOUS
5/25/2015	1.67	ML	1	11	18.37	MISCELLANEOUS
5/26/2015	5.42	COBURG	2	2	10.84	EQUIPMENT/MATERIAL FAILURE
5/26/2015	3.17	GARLIN	3	27	85.59	MISCELLANEOUS
5/26/2015	3.83	GARLIN	4	1	3.83	TREE
5/26/2015	2.35	GARLIN	5	34	79.9	TREE
5/26/2015	0.75	ML	4	10	7.5	WEATHER
5/27/2015	1.67	WC	2	73	121.91	MISCELLANEOUS
5/27/2015	0.42	COBURG	3	230	96.6	PLANNED
5/27/2015	0.58	CVILLE	3	18	10.44	TREE
5/27/2015	2	PHIL	3	11	22	TREE
5/27/2015	1	MCK	1	7	7	WEATHER
5/27/2015	15.17	WC	3	1	15.17	WEATHER
5/27/2015	0.33	CVILLE	5	62	20.46	WEATHER
5/27/2015	1.08	COBURG	3	122	131.76	WEATHER
5/28/2015	0.67	ML	1	8	5.36	ANIMAL
5/28/2015	0.58	COLUMBIA	2	8	4.64	MISCELLANEOUS
5/28/2015	0.25	CVILLE	3	1	0.25	WEATHER
5/29/2015	0.67	COLUMBIA	2	8	5.36	ANIMAL
5/29/2015	1.17	MCK	3	59	69.03	EQUIPMENT/MATERIAL FAILURE
5/30/2015	0.5	GRP	1	40	20	ANIMAL
5/31/2015	3	BASS	1	42	126	EQUIPMENT/MATERIAL FAILURE
5/31/2015	1	CRESTON	2	2	2	MISCELLANEOUS

6/1/2015	0.33	GBURG	4	38	12.54	ANIMAL
6/1/2015	0.67	COBURG	1	25	16.75	CONSUMER
6/2/2015	0.67	GRP	1	4	2.68	MISCELLANEOUS
6/2/2015	0.92	WC	2	40	36.8	MISCELLANEOUS
6/2/2015	0.58	ML	1	4	2.32	TREE
6/3/2015	0.5	PHIL	3	1	0.5	ANIMAL
6/3/2015	0.92	ML	4	4	3.68	ANIMAL
6/3/2015	0.42	GBURG	4	38	15.96	ANIMAL
6/3/2015	0.75	WC	3	19	14.25	MISCELLANEOUS
6/3/2015	1	CRESTON	2	19	19	MISCELLANEOUS
6/4/2015	0.33	ML	3	42	13.86	ANIMAL
6/4/2015	0.83	PHIL	2	8	6.64	MISCELLANEOUS
6/5/2015	0.75	GARLIN	2	6	4.5	MISCELLANEOUS
6/5/2015	0.67	CRESTON	3	7	4.69	MISCELLANEOUS
6/5/2015	0.83	COBURG	2	17	14.11	MISCELLANEOUS
6/5/2015	0.67	COLUMBIA	2	18	12.06	PLANNED
6/6/2015	0.58	WC	3	35	20.3	ANIMAL
6/8/2015	5.5	CRESTON	3	1	5.5	EQUIPMENT/MATERIAL FAILURE
6/8/2015	0.83	COLUMBIA	2	8	6.64	WEATHER
6/8/2015	1	MCK	1	46	46	WEATHER
6/8/2015	0.92	MCK	2	114	104.88	WEATHER
6/9/2015	1	MCK	3	36	36	MISCELLANEOUS
6/10/2015	0.58	ML	5	32	18.56	ANIMAL
6/10/2015	3.75	EC	2	2	7.5	TREE
6/11/2015	0.58	GARLIN	3	3	1.74	MISCELLANEOUS
6/11/2015	0.25	GARLIN	3	60	15	PLANNED
6/11/2015	0.83	ML	2	2	1.66	TREE
6/12/2015	0.5	EC	3	10	5	ANIMAL
6/12/2015	2.5	BASS	1	1	2.5	WEATHER
6/12/2015	0.42	CVILLE	5	16	6.72	WEATHER
6/12/2015	0.58	SVILLE	2	12	6.96	WEATHER
6/12/2015	0.92	GBURG	4	38	34.96	WEATHER
6/13/2015	0.83	PHIL	3	2	1.66	CONSUMER
6/13/2015	1.33	COLUMBIA	5	1	1.33	EQUIPMENT/MATERIAL FAILURE
6/13/2015	1.83	PHIL	3	1	1.83	EQUIPMENT/MATERIAL FAILURE
6/13/2015	4.25	COLUMBIA	2	42	178.5	MISCELLANEOUS
6/14/2015	1	CRESTON	3	3	3	MISCELLANEOUS

6/14/2015	0.75	ML	6	37	27.75	MISCELLANEOUS
6/14/2015	0.83	ML	4	12	9.96	TREE
6/15/2015	0.13	EC	2	1	0.13	EQUIPMENT/MATERIAL FAILURE
6/15/2015	0.5	EC	1	1	0.5	MISCELLANEOUS
6/15/2015	1.45	GRP	3	1	1.45	MISCELLANEOUS
6/16/2015	0.92	ML	2	1	0.92	MISCELLANEOUS
6/16/2015	2.5	GBURG	6	1	2.5	TREE
6/17/2015	1	COLUMBIA	5	1	1	EQUIPMENT/MATERIAL FAILURE
6/17/2015	1.58	COBURG	3	1	1.58	MISCELLANEOUS
6/17/2015	20.42	CVILLE	4	4	81.68	MISCELLANEOUS
6/17/2015	3.83	ML	4	35	134.05	WEATHER
6/17/2015	2.08	ML	4	77	160.16	WEATHER
6/18/2015	1	ML	2	2	2	ANIMAL
6/18/2015	1	SVILLE	2	7	7	WEATHER
6/18/2015	1.17	SVILLE	4	16	18.72	WEATHER
6/19/2015	0.42	WC	3	1	0.42	ANIMAL
6/19/2015	2	CRESTON	1	1	2	EQUIPMENT/MATERIAL FAILURE
6/19/2015	1	CRESTON	3	2	2	MISCELLANEOUS
6/19/2015	6.58	ML	4	1	6.58	MISCELLANEOUS
6/19/2015	3.5	MCK	3	5	17.5	WEATHER
6/19/2015	2.92	GBURG	3	7	20.44	WEATHER
6/19/2015	1.17	SVILLE	4	27	31.59	WEATHER
6/19/2015	4	CVILLE	3	12	48	WEATHER
6/19/2015	2.17	CVILLE	5	83	180.11	WEATHER
6/19/2015	3.42	ML	1	80	273.6	WEATHER
6/19/2015	3.17	SVILLE	1	302	957.34	WEATHER
6/20/2015	3	BASS	3	31	93	EQUIPMENT/MATERIAL FAILURE
6/20/2015	1	PHIL	1	1	1	MISCELLANEOUS
6/20/2015	1.75	PHIL	2	420	735	WEATHER
6/21/2015	1	GBURG	5	2	2	WEATHER
6/21/2015	0.83	GBURG	4	38	31.54	WEATHER
6/22/2015	1	COLUMBIA	2	28	28	CONSUMER
6/22/2015	1	GBURG	5	2	2	WEATHER
6/22/2015	4.5	COLUMBIA	2	1	4.5	WEATHER
6/22/2015	1.5	SVILLE	4	13	19.5	WEATHER
6/22/2015	2	MCK	3	36	72	WEATHER
6/23/2015	17.25	CVILLE	4	1	17.25	EQUIPMENT/MATERIAL FAILURE

6/23/2015	1.42	CVILLE	4	55	78.1	EQUIPMENT/MATERIAL FAILURE
6/23/2015	0.75	CRESTON	2	3	2.25	MISCELLANEOUS
6/23/2015	3	BASS	2	2	6	MISCELLANEOUS
6/24/2015	2.67	EC	1	8	21.36	ANIMAL
6/24/2015	2.67	CVILLE	4	1	2.67	MISCELLANEOUS
6/24/2015	0.75	SVILLE	1	63	47.25	WEATHER
6/25/2015	2.58	EC	1	1	2.58	TREE
6/25/2015	0.5	MCK	2	83	41.5	WEATHER
6/26/2015	1.5	PHIL	3	1	1.5	EQUIPMENT/MATERIAL FAILURE
6/26/2015	1.67	BASS	3	16	26.72	MISCELLANEOUS
6/26/2015	0.17	GARLIN	4	194	32.98	PLANNED
6/26/2015	1.92	WC	4	1	1.92	WEATHER
6/26/2015	2.75	EC	2	1	2.75	WEATHER
6/26/2015	4.17	EC	1	1	4.17	WEATHER
6/26/2015	12.67	BASS	3	1	12.67	WEATHER
6/26/2015	14.67	CVILLE	3	1	14.67	WEATHER
6/26/2015	1.67	GARLIN	4	12	20.04	WEATHER
6/26/2015	1	CVILLE	3	21	21	WEATHER
6/26/2015	1.33	COBURG	2	17	22.61	WEATHER
6/26/2015	1.83	GARLIN	2	13	23.79	WEATHER
6/26/2015	0.92	ML	3	30	27.6	WEATHER
6/26/2015	3	MCK	3	36	108	WEATHER
6/26/2015	2.15	MCK	3	63	135.45	WEATHER
6/27/2015	5.67	GBURG	5	1	5.67	WEATHER
6/28/2015	0.92	SVILLE	3	2	1.84	MISCELLANEOUS
6/28/2015	1	MCK	1	2	2	WEATHER
6/29/2015	1.15	GBURG	3	1	1.15	MISCELLANEOUS
6/29/2015	0.17	GARLIN	5	384	65.28	PLANNED
6/29/2015	1.58	ML	3	2	3.16	WEATHER
6/29/2015	3.5	GARLIN	4	1	3.5	WEATHER
6/29/2015	18.5	GBURG	6	1	18.5	WEATHER
6/29/2015	1.25	ML	4	35	43.75	WEATHER
6/29/2015	0.83	ML	3	65	53.95	WEATHER
6/29/2015	0.83	GBURG	3	71	58.93	WEATHER
6/29/2015	2.08	GARLIN	5	156	324.48	WEATHER
6/30/2015	1.08	BASS	3	81	87.48	EQUIPMENT/MATERIAL FAILURE
6/30/2015	1.5	CRESTON	1	37	55.5	MISCELLANEOUS

6/30/2015	0.83	COLUMBIA	2	1	0.83	WEATHER
6/30/2015	0.5	GARLIN	5	7	3.5	WEATHER
6/30/2015	0.5	WC	2	111	55.5	WEATHER
7/1/2015	0.58	ML	6	9	5.22	WEATHER
7/2/2015	1	CRESTON	2	11	11	ANIMAL
7/2/2015	0.92	ML	1	1	0.92	EQUIPMENT/MATERIAL FAILURE
7/2/2015	2	BASS	1	30	60	MISCELLANEOUS
7/4/2015	3.5	PHIL	1	4	14	EQUIPMENT/MATERIAL FAILURE
7/6/2015	1.75	GARLIN	5	2	3.5	MISCELLANEOUS
7/6/2015	0.75	WC	2	58	43.5	MISCELLANEOUS
7/6/2015	0.92	GARLIN	5	76	69.92	TREE
7/7/2015	2.33	SVILLE	1	16	37.28	TREE
7/7/2015	1	GBURG	4	38	38	WEATHER
7/8/2015	6	GBURG	5	1	6	TREE
7/8/2015	1	GBURG	5	121	121	TREE
7/8/2015	3	BASS	1	6	18	WEATHER
7/9/2015	2.52	CRESTON	3	1	2.52	TREE
7/9/2015	9.5	CRESTON	1	1	9.5	TREE
7/9/2015	7	BASS	2	2	14	TREE
7/9/2015	1.83	CRESTON	2	29	53.07	TREE
7/9/2015	0.55	BASS	2	101	55.55	TREE
7/9/2015	1.15	CRESTON	3	59	67.85	TREE
7/9/2015	1.63	CRESTON	2	81	132.03	TREE
7/9/2015	1.33	GRP	3	1	1.33	WEATHER
7/9/2015	0.92	GARLIN	5	2	1.84	WEATHER
7/9/2015	2.5	EC	2	1	2.5	WEATHER
7/9/2015	1.58	WC	2	2	3.16	WEATHER
7/9/2015	4.5	CVILLE	2	1	4.5	WEATHER
7/9/2015	6	GRP	1	1	6	WEATHER
7/9/2015	7.92	SVILLE	2	1	7.92	WEATHER
7/9/2015	8.5	GBURG	5	1	8.5	WEATHER
7/9/2015	8.83	GRP	1	1	8.83	WEATHER
7/9/2015	2.33	WC	3	4	9.32	WEATHER
7/9/2015	10.33	SVILLE	3	1	10.33	WEATHER
7/9/2015	10.5	EC	2	1	10.5	WEATHER
7/9/2015	1.5	GBURG	6	10	15	WEATHER
7/9/2015	6	ML	5	3	18	WEATHER

7/9/2015	0.58	BASS	1	37	21.46	WEATHER
7/9/2015	11.08	WC	2	2	22.16	WEATHER
7/9/2015	9.17	COBURG	1	3	27.51	WEATHER
7/9/2015	7	SVILLE	4	4	28	WEATHER
7/9/2015	4.08	SVILLE	1	7	28.56	WEATHER
7/9/2015	6	COBURG	3	5	30	WEATHER
7/9/2015	10.83	BASS	3	3	32.49	WEATHER
7/9/2015	4.17	SVILLE	4	10	41.7	WEATHER
7/9/2015	1.5	CVILLE	5	28	42	WEATHER
7/9/2015	1.17	GBURG	4	38	44.46	WEATHER
7/9/2015	6.5	COLUMBIA	2	8	52	WEATHER
7/9/2015	14.33	COLUMBIA	5	4	57.32	WEATHER
7/9/2015	1	BASS	3	66	66	WEATHER
7/9/2015	2.75	SVILLE	3	35	96.25	WEATHER
7/9/2015	1.58	WC	3	62	97.96	WEATHER
7/9/2015	11	EC	3	10	110	WEATHER
7/9/2015	3	GRP	1	45	135	WEATHER
7/9/2015	9.67	EC	1	16	154.72	WEATHER
7/9/2015	5.17	BASS	2	34	175.78	WEATHER
7/9/2015	0.92	GBURG	5	210	193.2	WEATHER
7/9/2015	2	GBURG	3	97	194	WEATHER
7/9/2015	7.5	BASS	2	28	210	WEATHER
7/9/2015	5	BASS	2	70	350	WEATHER
7/9/2015	2.67	COBURG	3	351	937.17	WEATHER
7/10/2015	1.58	PHIL	1	3	4.74	TREE
7/10/2015	1.62	BASS	1	30	48.6	TREE
7/10/2015	2.42	BASS	1	30	72.6	TREE
7/10/2015	1	SVILLE	1	2	2	WEATHER
7/10/2015	3.83	ML	6	1	3.83	WEATHER
7/10/2015	1	GBURG	3	4	4	WEATHER
7/10/2015	0.58	GRP	1	40	23.2	WEATHER
7/10/2015	7	BASS	2	4	28	WEATHER
7/10/2015	5	BASS	2	26	130	WEATHER
7/10/2015	2.5	CVILLE	5	62	155	WEATHER
7/10/2015	3.5	ML	3	112	392	WEATHER
7/10/2015	3	EC	3	460	1380	WEATHER
7/11/2015	1	COBURG	4	8	8	ANIMAL

7/11/2015	0.17	CVILLE	5	62	10.54	TREE
7/11/2015	0.83	GRP	2	1	0.83	WEATHER
7/12/2015	0.62	COLUMBIA	1	4	2.48	WEATHER
7/12/2015	4.5	EC	1	1	4.5	WEATHER
7/12/2015	5.92	COLUMBIA	2	1	5.92	WEATHER
7/12/2015	7.83	COLUMBIA	5	1	7.83	WEATHER
7/12/2015	1.25	ML	6	14	17.5	WEATHER
7/12/2015	1	COLUMBIA	5	37	37	WEATHER
7/12/2015	2.08	COLUMBIA	2	27	56.16	WEATHER
7/13/2015	0.75	WC	3	35	26.25	ANIMAL
7/13/2015	28.33	SVILLE	1	61	1728.13	EQUIPMENT/MATERIAL FAILURE
7/13/2015	0.42	GARLIN	5	6	2.52	MISCELLANEOUS
7/13/2015	1	EC	3	1	1	WEATHER
7/13/2015	0.02	GBURG	4	213	4.26	WEATHER
7/13/2015	17.27	WC	3	1	17.27	WEATHER
7/13/2015	25.5	COBURG	1	1	25.5	WEATHER
7/13/2015	4.25	SVILLE	2	6	25.5	WEATHER
7/13/2015	0.67	COBURG	2	60	40.2	WEATHER
7/13/2015	41.58	GBURG	5	1	41.58	WEATHER
7/13/2015	42.08	SVILLE	1	1	42.08	WEATHER
7/13/2015	42.75	SVILLE	1	1	42.75	WEATHER
7/13/2015	45	SVILLE	4	1	45	WEATHER
7/13/2015	45.42	COBURG	1	1	45.42	WEATHER
7/13/2015	45.5	CVILLE	3	1	45.5	WEATHER
7/13/2015	2.25	SVILLE	1	21	47.25	WEATHER
7/13/2015	48	CVILLE	3	1	48	WEATHER
7/13/2015	49	COBURG	1	1	49	WEATHER
7/13/2015	50	ML	6	1	50	WEATHER
7/13/2015	50.67	GBURG	3	1	50.67	WEATHER
7/13/2015	58	WC	3	1	58	WEATHER
7/13/2015	15.67	WC	2	4	62.68	WEATHER
7/13/2015	72.25	WC	3	1	72.25	WEATHER
7/13/2015	76.08	COLUMBIA	5	1	76.08	WEATHER
7/13/2015	45.83	SVILLE	4	2	91.66	WEATHER
7/13/2015	1.5	SVILLE	1	63	94.5	WEATHER
7/13/2015	8.83	GBURG	4	11	97.13	WEATHER
7/13/2015	5.08	CVILLE	3	21	106.68	WEATHER



7/13/2015	47.92	SVILLE	1	3	143.76	WEATHER
7/13/2015	40.67	GBURG	3	4	162.68	WEATHER
7/13/2015	163	SVILLE	1	1	163	WEATHER
7/13/2015	28.67	SVILLE	2	6	172.02	WEATHER
7/13/2015	192.67	SVILLE	3	1	192.67	WEATHER
7/13/2015	5.92	SVILLE	1	36	213.12	WEATHER
7/13/2015	1	GBURG	4	229	229	WEATHER
7/13/2015	3	GBURG	5	81	243	WEATHER
7/13/2015	6.93	GBURG	6	42	291.06	WEATHER
7/13/2015	323	MCK	1	1	323	WEATHER
7/13/2015	7.92	COBURG	1	41	324.72	WEATHER
7/13/2015	6.92	ML	3	70	484.4	WEATHER
7/13/2015	6.92	ML	3	70	484.4	WEATHER
7/13/2015	13.83	WC	2	40	553.2	WEATHER
7/13/2015	13	SVILLE	1	43	559	WEATHER
7/13/2015	31.08	MCK	2	18	559.44	WEATHER
7/13/2015	18	GBURG	4	33	594	WEATHER
7/13/2015	38	CRESTON	3	16	608	WEATHER
7/13/2015	10.08	COBURG	1	61	614.88	WEATHER
7/13/2015	15.75	GBURG	5	40	630	WEATHER
7/13/2015	12.67	SVILLE	4	52	658.84	WEATHER
7/13/2015	19	WC	3	36	684	WEATHER
7/13/2015	5.97	COBURG	1	121	722.37	WEATHER
7/13/2015	28	SVILLE	4	27	756	WEATHER
7/13/2015	23.87	SVILLE	4	32	763.84	WEATHER
7/13/2015	6.15	GBURG	1	134	824.1	WEATHER
7/13/2015	10.67	COLUMBIA	5	79	842.93	WEATHER
7/13/2015	8	SVILLE	1	106	848	WEATHER
7/13/2015	30.92	SVILLE	4	29	896.68	WEATHER
7/13/2015	13.67	ML	4	70	956.9	WEATHER
7/13/2015	13.58	WC	2	72	977.76	WEATHER
7/13/2015	14.67	WC	2	68	997.56	WEATHER
7/13/2015	2.5	GBURG	5	407	1017.5	WEATHER
7/13/2015	4.33	CVILLE	3	274	1186.42	WEATHER
7/13/2015	40.17	BASS	2	34	1365.78	WEATHER
7/13/2015	39.67	GBURG	3	43	1705.81	WEATHER
7/13/2015	7	SVILLE	1	302	2114	WEATHER

7/13/2015	3.67	GBURG	3	584	2143.28	WEATHER
7/13/2015	9	SVILLE	4	884	7956	WEATHER
7/14/2015	0.25	EC	1	3	0.75	WEATHER
7/14/2015	0.17	WC	2	7	1.19	WEATHER
7/14/2015	0.17	CVILLE	5	13	2.21	WEATHER
7/14/2015	6.58	GARLIN	3	1	6.58	WEATHER
7/14/2015	12.75	GARLIN	3	1	12.75	WEATHER
7/14/2015	6.83	GARLIN	3	3	20.49	WEATHER
7/14/2015	24	GBURG	3	1	24	WEATHER
7/14/2015	2.58	MCK	1	52	134.16	WEATHER
7/14/2015	3.25	CVILLE	5	70	227.5	WEATHER
7/14/2015	12	GARLIN	3	34	408	WEATHER
7/14/2015	8.17	ML	4	100	817	WEATHER
7/14/2015	3.83	EC	3	462	1769.46	WEATHER
7/15/2015	2	EC	1	1	2	ANIMAL
7/15/2015	3.5	CVILLE	3	2	7	TREE
7/15/2015	0.08	ML	3	8	0.64	WEATHER
7/15/2015	0.33	ML	4	21	6.93	WEATHER
7/15/2015	0.5	ML	5	80	40	WEATHER
7/15/2015	4.67	GBURG	5	29	135.43	WEATHER
7/15/2015	8	ML	2	41	328	WEATHER
7/15/2015	2	ML	1	291	582	WEATHER
7/15/2015	2.17	PHIL	1	340	737.8	WEATHER
7/16/2015	1.58	EC	1	1	1.58	EQUIPMENT/MATERIAL FAILURE
7/16/2015	5	CVILLE	3	1	5	EQUIPMENT/MATERIAL FAILURE
7/16/2015	3.75	WC	2	1	3.75	OVERLOAD
7/16/2015	13.67	CRESTON	2	6	82.02	TREE
7/16/2015	0.25	WC	2	1	0.25	WEATHER
7/16/2015	2.75	EC	1	1	2.75	WEATHER
7/16/2015	6.42	EC	1	1	6.42	WEATHER
7/16/2015	9.58	GARLIN	3	2	19.16	WEATHER
7/16/2015	27.17	COBURG	1	1	27.17	WEATHER
7/16/2015	7.5	WC	2	68	510	WEATHER
7/17/2015	1.08	EC	1	1	1.08	EQUIPMENT/MATERIAL FAILURE
7/17/2015	1.5	CRESTON	2	2	3	EQUIPMENT/MATERIAL FAILURE
7/17/2015	3.17	BASS	3	1	3.17	TREE
7/17/2015	2.83	EC	5	1	2.83	WEATHER

7/18/2015	1.42	CVILLE	3	124	176.08	EQUIPMENT/MATERIAL FAILURE
7/18/2015	3	EC	1	83	249	MISCELLANEOUS
7/18/2015	0.83	ML	6	14	11.62	TREE
7/19/2015	2	EC	3	10	20	WEATHER
7/19/2015	0.75	ML	5	32	24	WEATHER
7/21/2015	22.33	ML	6	1	22.33	MISCELLANEOUS
7/21/2015	6	PHIL	1	1	6	TREE
7/21/2015	2.5	CRESTON	3	19	47.5	TREE
7/21/2015	3.15	ML	3	1	3.15	WEATHER
7/21/2015	5.67	COBURG	2	5	28.35	WEATHER
7/21/2015	1.25	SVILLE	1	32	40	WEATHER
7/21/2015	1.83	GBURG	5	61	111.63	WEATHER
7/22/2015	3	SVILLE	2	1	3	CONSUMER
7/23/2015	1.33	SVILLE	1	32	42.56	EQUIPMENT/MATERIAL FAILURE
7/23/2015	3.5	PHIL	2	2	7	MISCELLANEOUS
7/24/2015	1.5	PHIL	1	1	1.5	EQUIPMENT/MATERIAL FAILURE
7/24/2015	0.58	CRESTON	3	1	0.58	TREE
7/24/2015	72	CVILLE	3	1	72	WEATHER
7/25/2015	0.83	GBURG	3	1	0.83	ANIMAL
7/25/2015	1.5	CVILLE	3	47	70.5	EQUIPMENT/MATERIAL FAILURE
7/25/2015	1.67	CRESTON	3	40	66.8	TREE
7/26/2015	1	GARLIN	2	76	76	MISCELLANEOUS
7/27/2015	9	PHIL	1	1	9	EQUIPMENT/MATERIAL FAILURE
7/27/2015	1.92	GBURG	3	30	57.6	EQUIPMENT/MATERIAL FAILURE
7/28/2015	1.25	BASS	3	1	1.25	EQUIPMENT/MATERIAL FAILURE
7/28/2015	1.92	CVILLE	3	28	53.76	EQUIPMENT/MATERIAL FAILURE
7/28/2015	0.83	BASS	1	1	0.83	WEATHER
7/28/2015	0.58	MCK	1	12	6.96	WEATHER
7/28/2015	1.5	SVILLE	1	32	48	WEATHER
7/28/2015	3	PHIL	5	268	804	WEATHER
7/29/2015	1.67	COLUMBIA	5	1	1.67	WEATHER
7/29/2015	19.75	COLUMBIA	5	1	19.75	WEATHER
7/29/2015	2.67	COLUMBIA	5	46	122.82	WEATHER
7/29/2015	16.75	COLUMBIA	5	9	150.75	WEATHER
7/29/2015	0.67	ML	4	440	294.8	WEATHER
7/30/2015	1	CVILLE	5	7	7	ANIMAL
7/30/2015	0.5	GBURG	1,5,6	860	430	POWER SUPPLY

7/31/2015	3.5	PHIL	3	3	10.5	EQUIPMENT/MATERIAL FAILURE
8/2/2015	1	MCK	2	1	1	MISCELLANEOUS
8/3/2015	2	BASS	1	1	2	EQUIPMENT/MATERIAL FAILURE
8/3/2015	0.5	GARLIN	5	57	28.5	PLANNED
8/4/2015	1.25	GBURG	3	1	1.25	ANIMAL
8/4/2015	0.33	EC	4	1	0.33	WEATHER
8/4/2015	1.17	CVILLE	3	2	2.34	WEATHER
8/4/2015	2.83	CRESTON	1	1	2.83	WEATHER
8/4/2015	0.75	ML	3	18	13.5	WEATHER
8/5/2015	0.17	WC	2	36	6.12	PLANNED
8/5/2015	0.42	CRESTON	2	3	1.26	WEATHER
8/5/2015	0.83	MCK	1	4	3.32	WEATHER
8/5/2015	2.17	GARLIN	3	9	19.53	WEATHER
8/5/2015	0.67	COBURG	3	725	485.75	WEATHER
8/5/2015	0.75	SVILLE	4	887	665.25	WEATHER
8/6/2015	1	GBURG	5	2	2	CONSUMER
8/6/2015	2.33	COBURG	4	1	2.33	MISCELLANEOUS
8/6/2015	1.75	EC	4	1	1.75	WEATHER
8/7/2015	0.5	GBURG	1	30	15	MISCELLANEOUS
8/9/2015	3.08	ML	6	8	24.64	ANIMAL
8/10/2015	0.75	SVILLE	1	1	0.75	EQUIPMENT/MATERIAL FAILURE
8/10/2015	1.67	WC	2	3	5.01	WEATHER
8/13/2015	0.58	GBURG	3	1	0.58	MISCELLANEOUS
8/15/2015	2.25	COBURG	1	1	2.25	EQUIPMENT/MATERIAL FAILURE
8/15/2015	2.25	CVILLE	5	1	2.25	EQUIPMENT/MATERIAL FAILURE
8/16/2015	1.67	COLUMBIA	5	1	1.67	ANIMAL
8/16/2015	0.5	SVILLE	2	19	9.5	MISCELLANEOUS
8/17/2015	8	ML	4	4	32	EQUIPMENT/MATERIAL FAILURE
8/18/2015	0.5	COBURG	3	4	2	ANIMAL
8/18/2015	4	BASS	2	1	4	CONSUMER
8/18/2015	2.58	BASS	2	101	260.58	CONSUMER
8/19/2015	0.83	GARLIN	5	76	63.08	WEATHER
8/21/2015	2	ML	1	1	2	EQUIPMENT/MATERIAL FAILURE
8/21/2015	70	MCK	3	1	70	MISCELLANEOUS
8/22/2015	2.5	PHIL	3	1	2.5	EQUIPMENT/MATERIAL FAILURE
8/22/2015	2	CRESTON	3	1	2	MISCELLANEOUS
8/26/2015	1.83	CVILLE	5	2	3.66	TREE

8/26/2015	0.75	CVILLE	5	83	62.25	TREE
8/27/2015	0.83	GARLIN	5	1	0.83	EQUIPMENT/MATERIAL FAILURE
8/27/2015	0.58	MCK	1	1	0.58	MISCELLANEOUS
8/28/2015	1	GBURG	1	30	30	MISCELLANEOUS
8/29/2015	1.92	GARLIN	5	1	1.92	TREE
8/29/2015	0.5	CVILLE	2	8	4	WEATHER
8/30/2015	7.17	COBURG	3	1	7.17	CONSUMER
8/30/2015	4.17	COBURG	3	4	16.68	CONSUMER
8/30/2015	1	GBURG	4	3	3	MISCELLANEOUS
8/31/2015	1	MCK	3	36	36	MISCELLANEOUS
9/3/2015	0.5	ML	3	2	1	CONSUMER
9/5/2015	1.25	PHIL	1	13	16.25	ANIMAL
9/5/2015	1.17	COBURG	3	1	1.17	OVERLOAD
9/5/2015	1.83	BASS	3	1	1.83	WEATHER
9/5/2015	2.75	BASS	3	1	2.75	WEATHER
9/6/2015	4.33	CRESTON	1	14	60.62	WEATHER
9/6/2015	1.5	CRESTON	1	47	70.5	WEATHER
9/8/2015	0.92	ML	1	21	19.32	CONSUMER
9/8/2015	2.17	COLUMBIA	5	43	93.31	EQUIPMENT/MATERIAL FAILURE
9/8/2015	3	SVILLE	4	2	6	OVERLOAD
9/9/2015	3.5	MCK	1	1	3.5	MISCELLANEOUS
9/10/2015	1.92	SVILLE	3	85	163.2	EQUIPMENT/MATERIAL FAILURE
9/11/2015	3.17	PHIL	5	91	288.47	EQUIPMENT/MATERIAL FAILURE
9/11/2015	0.67	PHIL	5	261	174.87	PLANNED
9/12/2015	1.17	SVILLE	4	24	28.08	EQUIPMENT/MATERIAL FAILURE
9/14/2015	1.3	CRESTON	3	43	55.9	ANIMAL
9/17/2015	1	SVILLE	1	2	2	ANIMAL
9/17/2015	1	GBURG	1	5	5	ANIMAL
9/21/2015	0.83	SVILLE	1	11	9.13	ANIMAL
9/22/2015	0.42	GARLIN	5	76	31.92	TREE
9/24/2015	0.83	EC	3	4	3.32	ANIMAL
9/24/2015	1.33	CVILLE	3	21	27.93	MISCELLANEOUS
9/25/2015	0.67	GBURG	4	12	8.04	ANIMAL
9/26/2015	1.42	ML	1	1	1.42	CONSUMER
9/28/2015	1.17	EC	1	74	86.58	ANIMAL
9/29/2015	0.75	GARLIN	2	1	0.75	ANIMAL
9/29/2015	1	GBURG	3	24	24	ANIMAL

9/29/2015	2	MCK	2	53	106	ANIMAL
9/29/2015	4	EC	1	1	4	EQUIPMENT/MATERIAL FAILURE
9/29/2015	1.33	COBURG	2	18	23.94	EQUIPMENT/MATERIAL FAILURE
9/29/2015	48	CRESTON	1	1	48	MISCELLANEOUS
9/29/2015	3.5	COLUMBIA	2	73	255.5	PLANNED
9/29/2015	0.75	CVILLE	3	21	15.75	TREE
9/29/2015	2.08	ML	4	21	43.68	TREE
9/29/2015	1.08	COBURG	3	18	19.44	WEATHER
9/30/2015	1.5	CRESTON	3	1	1.5	EQUIPMENT/MATERIAL FAILURE
9/30/2015	1.42	BASS	3	104	147.68	EQUIPMENT/MATERIAL FAILURE
10/1/2015	0.92	GARLIN	3	4	3.68	MISCELLANEOUS
10/1/2015	1	GBURG	3	99	99	MISCELLANEOUS
10/1/2015	2.42	COLUMBIA	5	49	118.58	TREE
10/2/2015	4	GBURG	3	1	4	TREE
10/2/2015	1.75	GARLIN	3	58	101.5	TREE
10/4/2015	0.67	COLUMBIA	1	1	0.67	ANIMAL
10/4/2015	3.5	ML	1	2	7	MISCELLANEOUS
10/5/2015	145	COLUMBIA	5	1	145	EQUIPMENT/MATERIAL FAILURE
10/5/2015	1.75	COLUMBIA	2	7	12.25	TREE
10/7/2015	3	BASS	3	1	3	CONSUMER
10/7/2015	1	CVILLE	5	8	8	TREE
10/8/2015	1.92	CVILLE	5	23	44.16	MISCELLANEOUS
10/8/2015	1.17	ML	2	1	1.17	TREE
10/9/2015	0.42	MCK	1	622	261.24	WEATHER
10/10/2015	2.5	GBURG	5	1	2.5	CONSUMER
10/12/2015	0.5	SVILLE	1	21	10.5	MISCELLANEOUS
10/13/2015	0.42	GARLIN	4	1	0.42	ANIMAL
10/13/2015	1.17	COBURG	1	61	71.37	MISCELLANEOUS
10/14/2015	0.83	WC	3	1	0.83	ANIMAL
10/15/2015	0.75	EC	3	8	6	ANIMAL
10/15/2015	9.5	COLUMBIA	2	1	9.5	CONSUMER
10/16/2015	0.5	EC	5	11	5.5	ANIMAL
10/16/2015	1.33	COLUMBIA	2	73	97.09	ANIMAL
10/17/2015	0.92	CVILLE	2	1	0.92	CONSUMER
10/17/2015	0.42	ML	2	64	26.88	MISCELLANEOUS
10/18/2015	0.5	BASS	2	1	0.5	ANIMAL
10/18/2015	1.33	COBURG	1	1	1.33	ANIMAL

10/19/2015	24.58	ML	6	1	24.58	MISCELLANEOUS
10/19/2015	1.17	SVILLE	3	55	64.35	MISCELLANEOUS
10/21/2015	1	CRESTON	3	3	3	MISCELLANEOUS
10/23/2015	1.42	GARLIN	5	2	2.84	EQUIPMENT/MATERIAL FAILURE
10/24/2015	2.5	WC	2	769	1922.5	CONSUMER
10/25/2015	2.33	GARLIN	5	56	130.48	ANIMAL
10/25/2015	0.5	GARLIN	4	3	1.5	EQUIPMENT/MATERIAL FAILURE
10/26/2015	1.08	CVILLE	3	17	18.36	ANIMAL
10/26/2015	2	EC	5	2	4	EQUIPMENT/MATERIAL FAILURE
10/26/2015	0.25	GARLIN	3	6	1.5	PLANNED
10/27/2015	0.58	COLUMBIA	2	8	4.64	MISCELLANEOUS
10/27/2015	0.75	ML	6	40	30	WEATHER
10/28/2015	2.25	PHIL	1	32	72	MISCELLANEOUS
10/28/2015	0.67	BASS	3	93	62.31	TREE
10/29/2015	1.25	GBURG	5	402	502.5	CONSUMER
10/30/2015	0.5	GRP	1	4	2	ANIMAL
10/30/2015	2.08	ML	3	1	2.08	CONSUMER
11/1/2015	2.5	ML	6	9	22.5	TREE
11/1/2015	1.5	SVILLE	2	21	31.5	TREE
11/2/2015	23.08	MCK	3	1	23.08	MISCELLANEOUS
11/3/2015	0.08	SVILLE	2	2	0.16	ANIMAL
11/3/2015	1.25	GRP	2	1	1.25	ANIMAL
11/4/2015	0.33	SVILLE	1	9	2.97	ANIMAL
11/4/2015	0.42	GRP	1	83	34.86	ANIMAL
11/5/2015	2	PHIL	5	53	106	MISCELLANEOUS
11/6/2015	1.75	COLUMBIA	5	21	36.75	EQUIPMENT/MATERIAL FAILURE
11/6/2015	1.75	COBURG	1	27	47.25	MISCELLANEOUS
11/6/2015	2.42	ML	6	5	12.1	WEATHER
11/10/2015	4.75	COLUMBIA	5	39	185.25	EQUIPMENT/MATERIAL FAILURE
11/10/2015	2.33	PHIL	1	30	69.9	TREE
11/11/2015	0.75	BASS	3	1	0.75	ANIMAL
11/11/2015	1.17	GARLIN	4	2	2.34	MISCELLANEOUS
11/12/2015	1.33	CRESTON	3	1	1.33	EQUIPMENT/MATERIAL FAILURE
11/12/2015	0.83	GBURG	5	2	1.66	TREE
11/14/2015	48	GBURG	3	1	48	EQUIPMENT/MATERIAL FAILURE
11/14/2015	0.62	EC	1	735	455.7	POWER SUPPLY
11/14/2015	0.7	EC	1	735	514.5	POWER SUPPLY

11/15/2015	0.67	ML	4	45	30.15	MISCELLANEOUS
11/15/2015	1.33	CRESTON	3	985	1310.05	MISCELLANEOUS
11/16/2015	1	SVILLE	1	1	1	MISCELLANEOUS
11/16/2015	0.75	CVILLE	4	30	22.5	TREE
11/18/2015	1.33	COLUMBIA	5	50	66.5	MISCELLANEOUS
11/18/2015	5.67	WC	2	3	17.01	WEATHER
11/18/2015	1.17	MCK	2	19	22.23	WEATHER
11/18/2015	0.67	SVILLE	1	61	40.87	WEATHER
11/18/2015	4.17	WC	2	39	162.63	WEATHER
11/19/2015	0.58	WC	3	2	1.16	ANIMAL
11/21/2015	43.83	SVILLE	1	3	131.49	PLANNED
11/21/2015	0.67	SVILLE	1	61	40.87	TREE
11/23/2015	1.25	SVILLE	4	82	102.5	EQUIPMENT/MATERIAL FAILURE
11/23/2015	1.67	WC	2	72	120.24	EQUIPMENT/MATERIAL FAILURE
11/24/2015	4.33	MCK	1	4	17.32	MISCELLANEOUS
11/25/2015	1.07	COBURG	4	1	1.07	CONSUMER
11/25/2015	0.33	MCK	2	5	1.65	PLANNED
11/26/2015	1.83	BASS	3	1	1.83	EQUIPMENT/MATERIAL FAILURE
11/26/2015	0.42	COBURG	3	7	2.94	MISCELLANEOUS
11/26/2015	0.75	GARLIN	2	13	9.75	MISCELLANEOUS
11/27/2015	0.75	CVILLE	5	16	12	TREE
11/28/2015	3.08	COLUMBIA	5	50	154	EQUIPMENT/MATERIAL FAILURE
11/28/2015	0.67	GARLIN	3	1	0.67	TREE
11/29/2015	0.75	ML	1	8	6	MISCELLANEOUS
11/29/2015	12	COBURG	4	1	12	MISCELLANEOUS
11/29/2015	0.75	COBURG	1	120	90	MISCELLANEOUS
11/29/2015	1.08	COBURG	1	2	2.16	TREE
11/29/2015	0.75	SVILLE	1	61	45.75	TREE
12/1/2015	3.33	ML	3	18	59.94	CONSUMER
12/1/2015	8.5	COBURG	3	1	8.5	EQUIPMENT/MATERIAL FAILURE
12/2/2015	0.67	ML	2	8	5.36	MISCELLANEOUS
12/3/2015	1	CRESTON	1	1	1	ANIMAL
12/3/2015	4.28	WC	3	1	4.28	CONSUMER
12/3/2015	1	WC	2	1	1	OVERLOAD
12/7/2015	4.33	SVILLE	1	1	4.33	EQUIPMENT/MATERIAL FAILURE
12/7/2015	0.75	EC	3	4	3	TREE
12/12/2015	1.5	WC	3	11	16.5	EQUIPMENT/MATERIAL FAILURE



12/12/2015	1	CRESTON	3	29	29	EQUIPMENT/MATERIAL FAILURE
12/12/2015	0.92	WC	3	84	77.28	EQUIPMENT/MATERIAL FAILURE
12/12/2015	0.67	SVILLE	3	35	23.45	MISCELLANEOUS
12/14/2015	2.33	PHIL	3	1	2.33	TREE
12/14/2015	2.33	ML	3	96	223.68	WEATHER
12/16/2015	1.45	GBURG	1	1	1.45	MISCELLANEOUS
12/16/2015	0.83	GBURG	3	2	1.66	MISCELLANEOUS
12/16/2015	0.42	ML	3	110	46.2	MISCELLANEOUS
12/19/2015	1.75	CVILLE	5	29	50.75	MISCELLANEOUS
12/20/2015	3.67	COLUMBIA	5	2	7.34	OVERLOAD
12/22/2015	0.42	CRESTON	1	27	11.34	MISCELLANEOUS
12/22/2015	2	CRESTON	2	35	70	TREE
12/22/2015	0.67	COBURG	2	2	1.34	WEATHER
12/23/2015	0.58	CVILLE	2	1	0.58	WEATHER
12/24/2015	1.17	COLUMBIA	2	29	33.93	ANIMAL
12/25/2015	1	GBURG	1	1	1	MISCELLANEOUS
12/27/2015	1.83	EC	1	735	1345.05	TREE
12/28/2015	72	CVILLE	3	1	72	WEATHER
12/30/2015	0.5	EC	5	43	21.5	ANIMAL

**Taylor County RECC**

**SECTION 5: CIRCUIT REPORTING**

**CIRCUITS with SAIDI AND/OR SAIFI EXCEEDING 5-year AVG  
(excluding MED)**

1) Substation name and number	Creston
2) Substation location (County-road-town)	Casey-nr Hwy 70/206 Intersection
3) Circuit name and number	3
4) Circuit location (town-road-general area)	Knifley/Clements ville
5) Total Circuit Length (miles)	122.84
6) Customer count for this circuit	978
7) Date of last circuit trim (VM)	2008
8) List outage causes for circuit along with percentage of total outage numbers represented by each cause	Animal 2.58% Consumer 0.02% Equipment 3.44% Miscellaneous 61.38% Tree 13.39% Weather 19.05%
9) Circuit 5 year average SAIDI	90.8
10) Reporting year SAIDI	136.9
11) Circuit 5 year average SAIFI	1.15
12) Reporting year SAIFI	1.4
13) List of correction action, if any, taken or to be taken	

**Taylor County RECC**

**SECTION 5: CIRCUIT REPORTING**

**CIRCUITS with SAIDI AND/OR SAIFI EXCEEDING 5-year AVG  
(excluding MED)**

1) Substation name and number	Campbellsville
2) Substation location (County-road-town)	Taylor-nr Hwy 55/Hwy 3183 Intersection
3) Circuit name and number	3
4) Circuit location (town-road-general area)	Hwy 55S
5) Total Circuit Length (miles)	50.44
6) Customer count for this circuit	557
7) Date of last circuit trim (VM)	2011
8) List outage causes for circuit along with percentage of total outage numbers represented by each cause	Animal 12.45% Equipment 49.07% Miscellaneous 4.79% Overload 0.44% Tree 3.93% Weather 29.33%
9) Circuit 5 year average SAIDI	57.2
10) Reporting year SAIDI	71.8
11) Circuit 5 year average SAIFI	0.72
12) Reporting year SAIFI	0.85
13) List of correction action, if any, taken or to be taken	

**Taylor County RECC**

**SECTION 5: CIRCUIT REPORTING**

**CIRCUITS with SAIDI AND/OR SAIFI EXCEEDING 5-year AVG  
(excluding MED)**

1) Substation name and number	Campbellsville
2) Substation location (County-road-town)	Taylor-nr Hwy 55/Hwy 3183 Intersection
3) Circuit name and number	4
4) Circuit location (town-road-general area)	Toward Campbellsville
5) Total Circuit Length (miles)	4.45
6) Customer count for this circuit	58
7) Date of last circuit trim (VM)	2015
8) List outage causes for circuit along with percentage of total outage numbers represented by each cause	Equipment 47.16% Miscellaneous 41.72% Tree 11.13%
9) Circuit 5 year average SAIDI	54.76
10) Reporting year SAIDI	209.17
11) Circuit 5 year average SAIFI	0.536
12) Reporting year SAIFI	1.57
13) List of correction action, if any, taken or to be taken	

## Taylor County RECC

### SECTION 5: CIRCUIT REPORTING

CIRCUITS with SAIDI AND/OR SAIFI EXCEEDING 5-year AVG  
(excluding MED)

1) Substation name and number	Campbellsville
2) Substation location (County-road-town)	Taylor-nr Hwy 55/Hwy 3183 Intersection
3) Circuit name and number	5
4) Circuit location (town-road-general area)	To Greensburg Rd
5) Total Circuit Length (miles)	40.49
6) Customer count for this circuit	609
7) Date of last circuit trim (VM)	2015
8) List outage causes for circuit along with percentage of total outage numbers represented by each cause	Animal 29.61% Equipment 0.47% Miscellaneous 20.01% Tree 20.33% Weather 29.58%
9) Circuit 5 year average SAIDI	30.91
10) Reporting year SAIDI	46.74
11) Circuit 5 year average SAIFI	0.48
12) Reporting year SAIFI	0.86
13) List of correction action, if any, taken or to be taken	

**Taylor County RECC**

**SECTION 5: CIRCUIT REPORTING**

**CIRCUITS with SAIDI AND/OR SAIFI EXCEEDING 5-year AVG  
(excluding MED)**

1) Substation name and number	East Campbellsville
2) Substation location (County-road-town)	Taylor-nr Hwy 70/Hwy 3518 Intersection
3) Circuit name and number	1
4) Circuit location (town-road-general area)	Hwy55N
5) Total Circuit Length (miles)	71.73
6) Customer count for this circuit	738
7) Date of last circuit trim (VM)	2013
8) List outage causes for circuit along with percentage of total outage numbers represented by each cause	Animal 3.01% Equipment 0.19% Miscellaneous 30.87% Power Supply 27.46% Tree 38.14% Weather 0.25%
9) Circuit 5 year average SAIDI	88.81
10) Reporting year SAIDI	287.3
11) Circuit 5 year average SAIFI	1.13
12) Reporting year SAIFI	4.2
13) List of correction action, if any, taken or to be taken	

**Taylor County RECC**

**SECTION 5: CIRCUIT REPORTING**

**CIRCUITS with SAIDI AND/OR SAIFI EXCEEDING 5-year AVG  
(excluding MED)**

1) Substation name and number	Greensburg
2) Substation location (County-road-town)	Green-nr Hwy61/West Hodgenville Rd Intersection
3) Circuit name and number	3
4) Circuit location (town-road-general area)	Toward Campbellsville
5) Total Circuit Length (miles)	66.42
6) Customer count for this circuit	586
7) Date of last circuit trim (VM)	2009
8) List outage causes for circuit along with percentage of total outage numbers represented by each cause	Animal 7.06% Consumer 17.59% Equipment 30.61% Miscellaneous 27.71% Tree 1.08% Weather 16.0%
9) Circuit 5 year average SAIDI	40.1
10) Reporting year SAIDI	37.83
11) Circuit 5 year average SAIFI	0.36
12) Reporting year SAIFI	0.57
13) List of correction action, if any, taken or to be taken	

**Taylor County RECC**

**SECTION 5: CIRCUIT REPORTING**

**CIRCUITS with SAIDI AND/OR SAIFI EXCEEDING 5-year AVG  
(excluding MED)**

1) Substation name and number	Greensburg
2) Substation location (County-road-town)	Green-nr Hwy61/West Hodgenville Rd Intersection
3) Circuit name and number	4
4) Circuit location (town-road-general area)	Hospital Hill area
5) Total Circuit Length (miles)	8.67
6) Customer count for this circuit	229
7) Date of last circuit trim (VM)	2010
8) List outage causes for circuit along with percentage of total outage numbers represented by each cause	Animal 24.06% Miscellaneous 14.16% Weather 61.78%
9) Circuit 5 year average SAIDI	58.1
10) Reporting year SAIDI	44.3
11) Circuit 5 year average SAIFI	1.03
12) Reporting year SAIFI	1.09
13) List of correction action, if any, taken or to be taken	



**Taylor County RECC**

**SECTION 5: CIRCUIT REPORTING**

**CIRCUITS with SAIDI AND/OR SAIFI EXCEEDING 5-year AVG  
(excluding MED)**

1) Substation name and number	Greensburg
2) Substation location (County-road-town)	Green-nr Hwy61/West Hodgenville Rd Intersection
3) Circuit name and number	5
4) Circuit location (town-road-general area)	Gresham
5) Total Circuit Length (miles)	61.64
6) Customer count for this circuit	421
7) Date of last circuit trim (VM)	2010
8) List outage causes for circuit along with percentage of total outage numbers represented by each cause	Consumer 52.40% Power Supply 21.76% Tree 13.29% Weather 12.54%
9) Circuit 5 year average SAIDI	64.6
10) Reporting year SAIDI	137.9
11) Circuit 5 year average SAIFI	0.98
12) Reporting year SAIFI	2.41
13) List of correction action, if any, taken or to be taken	

**Taylor County RECC**

**SECTION 5: CIRCUIT REPORTING**

**CIRCUITS with SAIDI AND/OR SAIFI EXCEEDING 5-year AVG  
(excluding MED)**

1) Substation name and number	Greensburg
2) Substation location (County-road-town)	Green-nr Hwy61/West Hodgenville Rd Intersection
3) Circuit name and number	6
4) Circuit location (town-road-general area)	Hwy 88
5) Total Circuit Length (miles)	46.39
6) Customer count for this circuit	317
7) Date of last circuit trim (VM)	2011
8) List outage causes for circuit along with percentage of total outage numbers represented by each cause	Overload 13.08% Power Supply 76.76% Tree 1.21% Weather 8.96%
9) Circuit 5 year average SAIDI	54.6
10) Reporting year SAIDI	39.1
11) Circuit 5 year average SAIFI	0.71
12) Reporting year SAIFI	1.05
13) List of correction action, if any, taken or to be taken	

**Taylor County RECC**

**SECTION 5: CIRCUIT REPORTING**

**CIRCUITS with SAIDI AND/OR SAIFI EXCEEDING 5-year AVG  
(excluding MED)**

1) Substation name and number	McKinney Corner
2) Substation location (County-road-town)	Green-nr Hwy68/Hwy218 Intersection
3) Circuit name and number	1
4) Circuit location (town-road-general area)	To Pierce
5) Total Circuit Length (miles)	75.34
6) Customer count for this circuit	633
7) Date of last circuit trim (VM)	2008
8) List outage causes for circuit along with percentage of total outage numbers represented by each cause	Consumer 1.48% Equipment 18.88% Miscellaneous 18.07% Weather 61.57%
9) Circuit 5 year average SAIDI	76.02
10) Reporting year SAIDI	51.2
11) Circuit 5 year average SAIFI	1
12) Reporting year SAIFI	1.27
13) List of correction action, if any, taken or to be taken	

**Taylor County RECC**

**SECTION 5: CIRCUIT REPORTING**

CIRCUITS with SAIDI AND/OR SAIFI EXCEEDING 5-year AVG  
(excluding MED)

1) Substation name and number	McKinney Corner
2) Substation location (County-road-town)	Green-nr Hwy68/Hwy218 Intersection
3) Circuit name and number	3
4) Circuit location (town-road-general area)	Toward Greensburg
5) Total Circuit Length (miles)	42.97
6) Customer count for this circuit	307
7) Date of last circuit trim (VM)	2008
8) List outage causes for circuit along with percentage of total outage numbers represented by each cause	Equipment 12.30% Miscellaneous 30.00% Weather 57.69%
9) Circuit 5 year average SAIDI	48.6
10) Reporting year SAIDI	109.7
11) Circuit 5 year average SAIFI	0.45
12) Reporting year SAIFI	0.89
13) List of correction action, if any, taken or to be taken	

**Taylor County RECC**

**SECTION 5: CIRCUIT REPORTING**

**CIRCUITS with SAIDI AND/OR SAIFI EXCEEDING 5-year AVG  
(excluding MED)**

1) Substation name and number	Mile Lane
2) Substation location (County-road-town)	Taylor-nr Hwy527/Hwy3211 Intersection
3) Circuit name and number	1
4) Circuit location (town-road-general area)	Toward Finley
5) Total Circuit Length (miles)	45.04
6) Customer count for this circuit	575
7) Date of last circuit trim (VM)	2010
8) List outage causes for circuit along with percentage of total outage numbers represented by each cause	Animal 0.70% Consumer 2.36% Equipment 89.66% Miscellaneous 5.23% Tree 0.26% Weather 1.79%
9) Circuit 5 year average SAIDI	53.2
10) Reporting year SAIDI	91.85
11) Circuit 5 year average SAIFI	0.624
12) Reporting year SAIFI	0.46
13) List of correction action, if any, taken or to be taken	

## Taylor County RECC

### SECTION 5: CIRCUIT REPORTING

CIRCUITS with SAIDI AND/OR SAIFI EXCEEDING 5-year AVG  
(excluding MED)

1)	Substation name and number	Mile Lane	
2)	Substation location (County-road-town)	Taylor-nr Hwy527/Hwy3211 Intersection	
3)	Circuit name and number	4	
4)	Circuit location (town-road-general area)	Toward Saloma	
5)	Total Circuit Length (miles)	49.88	
6)	Customer count for this circuit	442	
7)	Date of last circuit trim (VM)	2011	
8)	List outage causes for circuit along with percentage of total outage numbers represented by each cause	Animal	0.45%
		Equipment	3.94%
		Miscellaneous	3.71%
		Tree	12.52%
		Weather	79.39%
9)	Circuit 5 year average SAIDI	73.17	
10)	Reporting year SAIDI	110.4	
11)	Circuit 5 year average SAIFI	1.01	
12)	Reporting year SAIFI	1.7	
13)	List of correction action, if any, taken or to be taken		

**Taylor County RECC**

**SECTION 5: CIRCUIT REPORTING**

**CIRCUITS with SAIDI AND/OR SAIFI EXCEEDING 5-year AVG  
(excluding MED)**

1) Substation name and number	Phil	
2) Substation location (County-road-town)	Casey-nr Hwy127/Haggard Drive Intersection	
3) Circuit name and number	2	
4) Circuit location (town-road-general area)	Hwy 501	
5) Total Circuit Length (miles)	58.12	
6) Customer count for this circuit	443	
7) Date of last circuit trim (VM)	2009	
8) List outage causes for circuit along with percentage of total outage numbers represented by each cause	Miscellaneous	1.52%
	Tree	16.71%
	Weather	81.77%
9) Circuit 5 year average SAIDI	101.6	
10) Reporting year SAIDI	121.7	
11) Circuit 5 year average SAIFI	1.468	
12) Reporting year SAIFI	1.21	
13) List of correction action, if any, taken or to be taken		6

## Taylor County RECC

### SECTION 5: CIRCUIT REPORTING

CIRCUITS with SAIDI AND/OR SAIFI EXCEEDING 5-year AVG  
(excluding MED)

1)	Substation name and number	Phil	
2)	Substation location (County-road-town)	Casey-nr Hwy127/Haggard Drive Intersection	
3)	Circuit name and number	5	
4)	Circuit location (town-road-general area)	Hwy 910	
5)	Total Circuit Length (miles)	35.75	
6)	Customer count for this circuit	257	
7)	Date of last circuit trim (VM)	2010	
8)	List outage causes for circuit along with percentage of total outage numbers represented by each cause	Equipment	20.89%
		Miscellaneous	7.68%
		Planned	12.66%
		Tree	0.18%
		Weather	58.59%
9)	Circuit 5 year average SAIDI	208	
10)	Reporting year SAIDI	322.4	
11)	Circuit 5 year average SAIFI	2.57	
12)	Reporting year SAIFI	2.64	
13)	List of correction action, if any, taken or to be taken		



**Taylor County RECC**

**SECTION 5: CIRCUIT REPORTING**

**CIRCUITS with SAIDI AND/OR SAIFI EXCEEDING 5-year AVG  
(excluding MED)**

1) Substation name and number	Summersville
2) Substation location (County-road-town)	Green-nr Hwy323/Raymond Despain Road Intersection
3) Circuit name and number	1
4) Circuit location (town-road-general area)	Mac-Pitman
5) Total Circuit Length (miles)	87.61
6) Customer count for this circuit	584
7) Date of last circuit trim (VM)	2015
8) List outage causes for circuit along with percentage of total outage numbers represented by each cause	Animal 0.26% Consumer 0.21% Equipment 20.66% Miscellaneous 0.20% Overload 0.07% Planned 1.52% Power Supply 10.12% Tree 1.00% Weather 65.96%
9) Circuit 5 year average SAIDI	122.76
10) Reporting year SAIDI	143.4
11) Circuit 5 year average SAIFI	2.03
12) Reporting year SAIFI	1.77
13) List of correction action, if any, taken or to be taken	