

RECEIVED

MAR 17 2020

PUBLIC SERVICE
COMMISSION

CY2019 Outage Data

Taylor County RECC

Taylor County RECC Outage Reporting - Circuit Level

Administrative Case No: 2011-00450

SECTION 1: CIRCUIT REPORTING

Utility Name: Taylor County RECC
Report Prepared By: Mike Skaggs
Preparer Email: mskaggs@tcrecc.com
Preparer Phone: 800-931-4551

SECTION 2: REPORTING YEAR

Calendar Year of Report: 2019

SECTION 3: MAJOR EVENT DAYS (MED)

Tmed: 119,308.8
First Date Used to Determine Tmed: 6/23/2019
Last Date Used to Determine Tmed: 6/23/2019
Number of MED in Report Year: 1

SECTION 4: SYSTEM RELIABILITY INFORMATION AND RESULTS

System-wide Information:

Total Customers: 26696
Total Circuits: 65

Excluding MED:

5 Year Average SAIDI: 76.2
5 Year Average SAIFI: 0.97
Reporting Year SAIDI: 86.1
Reporting Year SAIFI: 1.0

Including MED:

5 Year Average SAIDI: 142.5
5 Year Average SAIFI: 1.3
Reporting Year SAIDI: 111.0
Reporting Year SAIFI: 1.1

PSC Outage Tabulation, 2019

Taylor County RECC

System:			
<u>Year</u>	<u>SAIDI</u>	<u>SAIFI</u>	<u>CAIDI</u>
2014	119.18	1.58	75.29
2015	198.6	1.3	150.7
2016	153.3	1.3	119.6
2017	126.25	1.25	100.96
2018	123.15	1.63	75.42
2019	111.02	1.14	97.06

Outage Subcategory Breakdown:	
<u>Subcategory:</u>	<u>Mins:</u>
Animal	183,106.8
Consumer	110,619.6
Equipment	484,788.0
Miscellaneous	282,554.4
Overload	5,442.0
Plan	25,140.0
Power Supplier	0.0
Tree	241,990.2
Weather	1,630,287.6

2019 - Major outage day defined per IEEE standard	
<u>5yr avg Tmed for 19</u>	
	119,308.8
Major Outage Days -	6/23 Weather(665,478)

2019 10 Worst Circuits per Category:					
<u>Substation</u>	<u>C</u>	<u>SAIDI</u>	<u>SAIFI</u>	<u>CAIDI</u>	<u>Maj. Out. Category</u>
PHIL	1	751.6			WEATHER
COLUMBIA	2	720.2			WEATHER
CAMPBELLSVILLE	1	720.0			CONSUMER
EAST CAMPBELLSVILLE	3	436.7			WEATHER
PHIL	5	282.7			WEATHER
PHIL	3	235.2			WEATHER
CRESTON	3	227.6			EQUIPMENT
BASS	3	203.0			ANIMAL
BASS	1	194.2			WEATHER
COBURG	2	163.3			WEATHER
CAMPBELLSVILLE	1		8.0		CONSUMER
COLUMBIA	2		4.7		WEATHER
EAST CAMPBELLSVILLE	3		4.2		WEATHER
PHIL	1		3.8		WEATHER
GARLIN	5		3.2		EQUIPMENT

GARLIN	4	2.5	WEATHER
BASS	3	2.3	ANIMAL
PHIL	3	2.1	WEATHER
SUMMERSVILLE	1	2.1	WEATHER
CRESTON	3	2.1	EQUIPMENT
SUMMERSVILLE	2	334.2	TREE
GREEN RIVER PLAZA	2	234.8	EQUIPMENT
PHIL	1	200.2	WEATHER
PHIL	5	197.7	WEATHER
COLUMBIA	5	170.6	WEATHER
EAST CAMPBELLSVILLE	5	164.3	WEATHER
COBURG	1	158.6	WEATHER
COLUMBIA	2	154.5	WEATHER
MCKINNEY CORNER	2	144.5	WEATHER
BASS	1	137.1	WEATHER

Vegetation Management Plan:

Plan is progressing as expected/desired

Continue to face occasional issue with yard tree clearance

Outages 2019

<u>Date</u>	<u>Total Time (hrs)</u>	<u>Substation</u>	<u>Ckt</u>	<u># Membrs Effected</u>	<u>Consumers Hrs Off</u>	<u>Cause</u>
1/1/2019	2.25	BASS	2	1	2.25	TREE
1/1/2019	2.50	COBURG	2	1	2.5	TREE
1/2/2019	0.92	MCK	2	1	0.92	OVERLOAD
1/2/2019	2.50	BASS	1	1	2.5	EQUIPMENT/MATERIAL FAILURE
1/2/2019	1.50	BASS	1	25	37.5	EQUIPMENT/MATERIAL FAILURE
1/5/2019	0.92	EC	1	1	0.92	ANIMAL
1/5/2019	1.58	MCK	1	76	120.08	CONSUMER
1/6/2019	1.00	MCK	1	1	1	MISCELLANEOUS
1/6/2019	6.17	SVILLE	4	2	12.34	EQUIPMENT/MATERIAL FAILURE
1/7/2019	3.50	EC	1	1	3.5	EQUIPMENT/MATERIAL FAILURE
1/7/2019	0.50	EC	1	70	35	MISCELLANEOUS
1/8/2019	0.42	CVILLE	2	2	0.84	EQUIPMENT/MATERIAL FAILURE
1/9/2019	0.25	CRESTON	2	213	53.25	CONSUMER
1/11/2019	2.75	PHIL	1	1	2.75	MISCELLANEOUS
1/11/2019	1.00	GARLIN	2	3	3	CONSUMER
1/13/2019	0.75	GARLIN	3	3	2.25	ANIMAL
1/13/2019	0.83	GARLIN	3	3	2.49	ANIMAL
1/13/2019	3.08	BASS	2	1	3.08	EQUIPMENT/MATERIAL FAILURE
1/14/2019	0.83	COBURG	4	5	4.15	MISCELLANEOUS
1/15/2019	9.00	GARLIN	3	1	9	EQUIPMENT/MATERIAL FAILURE
1/18/2019	0.50	COBURG	3	3	1.5	ANIMAL
1/18/2019	1.33	MCK	3	27	35.91	TREE
1/19/2019	2.00	PHIL	1	37	74	WEATHER
1/21/2019	0.42	MCK	1	1	0.42	OVERLOAD
1/23/2019	4.83	ML	4	2	9.66	EQUIPMENT/MATERIAL FAILURE
1/23/2019	1.67	CRESTON	1	26	43.42	WEATHER
1/23/2019	0.53	COLUMBIA	2	600	318	WEATHER
1/25/2019	0.83	CVILLE	3	15	12.45	EQUIPMENT/MATERIAL FAILURE
1/26/2019	1.17	GARLIN	2	1	1.17	EQUIPMENT/MATERIAL FAILURE
1/28/2019	2.00	PHIL	2	1	2	EQUIPMENT/MATERIAL FAILURE
1/29/2019	1.00	COBURG	1	1	1	WEATHER
1/30/2019	1.50	EC	1	2	3	EQUIPMENT/MATERIAL FAILURE

1/30/2019	1.42	SVILLE	4	31	44.02	EQUIPMENT/MATERIAL FAILURE
2/1/2019	1.03	COBURG	3	74	76.22	CONSUMER
2/1/2019	1.50	PHIL	3	58	87	TREE
2/4/2019	2.08	EC	1	78	162.24	CONSUMER
2/4/2019	0.50	EC	1	750	375	CONSUMER
2/6/2019	1.17	CVILLE	5	5	5.85	EQUIPMENT/MATERIAL FAILURE
2/6/2019	5.00	CRESTON	3	2	10	EQUIPMENT/MATERIAL FAILURE
2/10/2019	1.00	WC	3	10	10	ANIMAL
2/10/2019	1.17	BASS	3	46	53.82	TREE
2/12/2019	1.50	CRESTON	1	1	1.5	EQUIPMENT/MATERIAL FAILURE
2/12/2019	1.33	BASS	2	7	9.31	MISCELLANEOUS
2/12/2019	3.17	MCK	2	52	164.84	WEATHER
2/12/2019	0.33	SVILLE	4	893	294.69	PLANNED
2/12/2019	2.00	SVILLE	4	289	578	WEATHER
2/13/2019	0.92	ML	3	67	61.64	MISCELLANEOUS
2/15/2019	0.58	COBURG	2	61	35.38	ANIMAL
2/17/2019	0.92	EC	1	4	3.68	EQUIPMENT/MATERIAL FAILURE
2/19/2019	0.17	PHIL	1	185	31.45	MISCELLANEOUS
2/21/2019	2.50	SVILLE	4	1	2.5	EQUIPMENT/MATERIAL FAILURE
2/22/2019	1.75	COLUMBIA	2	33	57.75	WEATHER
2/23/2019	1.50	GARLIN	2	34	51	WEATHER
2/24/2019	1.00	ML	6	1	1	WEATHER
2/24/2019	1.33	CRESTON	3	19	25.27	WEATHER
2/24/2019	5.00	CRESTON	1	6	30	WEATHER
2/24/2019	0.67	WC	2	57	38.19	WEATHER
2/24/2019	2.50	CRESTON	3	20	50	WEATHER
2/24/2019	1.50	CRESTON	1	46	69	WEATHER
2/24/2019	2.42	ML	4	58	140.36	WEATHER
2/24/2019	3.50	PHIL	3	50	175	WEATHER
2/24/2019	1.17	SVILLE	4	193	225.81	WEATHER
2/24/2019	1.50	PHIL	3	287	430.5	WEATHER
2/25/2019	1.00	EC	1	1	1	EQUIPMENT/MATERIAL FAILURE
2/25/2019	0.92	COLUMBIA	2	557	512.44	EQUIPMENT/MATERIAL FAILURE
2/26/2019	1.67	BASS	3	30	50.1	EQUIPMENT/MATERIAL FAILURE
2/27/2019	1.00	EC	6	1	1	EQUIPMENT/MATERIAL FAILURE

3/1/2019	1.00	COLUMBIA	2	1	1	EQUIPMENT/MATERIAL FAILURE
3/2/2019	0.67	ML	5	48	32.16	ANIMAL
3/6/2019	0.50	GBURG	4	229	114.5	PLANNED
3/9/2019	0.50	GBURG	6	7	3.5	WEATHER
3/9/2019	0.67	COBURG	2	10	6.7	WEATHER
3/9/2019	0.97	BASS	3	18	17.46	WEATHER
3/9/2019	2.67	WC	3	36	96.12	WEATHER
3/11/2019	1.00	WC	2	1	1	EQUIPMENT/MATERIAL FAILURE
3/13/2019	0.75	BASS	1	1	0.75	MISCELLANEOUS
3/13/2019	0.67	ML	6	5	3.35	ANIMAL
3/14/2019	0.83	MCK	1	1	0.83	WEATHER
3/14/2019	1.00	MCK	3	1	1	WEATHER
3/14/2019	1.00	GARLIN	5	1	1	TREE
3/14/2019	0.67	BASS	1	23	15.41	WEATHER
3/14/2019	2.83	BASS	2	6	16.98	WEATHER
3/14/2019	0.67	BASS	3	48	32.16	WEATHER
3/14/2019	1.17	SVILLE	3	32	37.44	WEATHER
3/14/2019	1.08	BASS	2	37	39.96	WEATHER
3/14/2019	2.08	GARLIN	5	32	66.56	WEATHER
3/14/2019	1.50	GBURG	3	67	100.5	WEATHER
3/17/2019	3.00	PHIL	5	54	162	TREE
3/18/2019	0.50	ML	2	81	40.5	TREE
3/20/2019	1.00	GRP	1	1	1	MISCELLANEOUS
3/20/2019	1.42	BASS	2	3	4.26	EQUIPMENT/MATERIAL FAILURE
3/20/2019	0.75	COLUMBIA	2	7	5.25	MISCELLANEOUS
3/20/2019	0.75	BASS	2	37	27.75	EQUIPMENT/MATERIAL FAILURE
3/22/2019	0.75	WC	3	17	12.75	CONSUMER
3/24/2019	5.33	CVILLE	3	1	5.33	EQUIPMENT/MATERIAL FAILURE
3/24/2019	1.50	CRESTON	3	6	9	MISCELLANEOUS
3/24/2019	3.00	CVILLE	3	26	78	EQUIPMENT/MATERIAL FAILURE
3/25/2019	1.08	MCK	2	2	2.16	EQUIPMENT/MATERIAL FAILURE
3/29/2019	1.00	COBURG	3	1	1	EQUIPMENT/MATERIAL FAILURE
3/30/2019	2.75	ML	2	2	5.5	TREE
3/30/2019	0.67	BASS	2	105	70.35	MISCELLANEOUS
3/30/2019	1.67	ML	2	64	106.88	WEATHER

3/30/2019	1.50	BASS	2	105	157.5	TREE
4/1/2019	5.57	SVILLE	2	2	11.14	TREE
4/2/2019	3.00	PHIL	2	36	108	TREE
4/4/2019	1.08	CVILLE	5	1	1.08	EQUIPMENT/MATERIAL FAILURE
4/4/2019	1.00	PHIL	2	36	36	MISCELLANEOUS
4/6/2019	1.33	SVILLE	3	9	11.97	MISCELLANEOUS
4/7/2019	2.00	MCK	2	1	2	ANIMAL
4/7/2019	2.83	ML	4	1	2.83	WEATHER
4/7/2019	0.58	ML	4	12	6.96	WEATHER
4/7/2019	1.08	GBURG	6	306	330.48	TREE
4/10/2019	1.00	CRESTON	1	1	1	EQUIPMENT/MATERIAL FAILURE
4/10/2019	0.67	SVILLE	3	9	6.03	MISCELLANEOUS
4/11/2019	1.00	CRESTON	2	1	1	WEATHER
4/11/2019	2.00	CRESTON	2	1	2	WEATHER
4/11/2019	0.87	GBURG	6	5	4.35	MISCELLANEOUS
4/11/2019	1.00	PHIL	1	37	37	EQUIPMENT/MATERIAL FAILURE
4/11/2019	1.25	PHIL	2	36	45	MISCELLANEOUS
4/12/2019	1.83	GBURG	1	1	1.83	MISCELLANEOUS
4/14/2019	1.00	EC	2	1	1	WEATHER
4/14/2019	3.33	CRESTON	3	1	3.33	WEATHER
4/14/2019	3.50	COBURG	3	1	3.5	WEATHER
4/14/2019	3.92	ML	3	1	3.92	WEATHER
4/14/2019	0.67	SVILLE	4	42	28.14	WEATHER
4/14/2019	1.45	SVILLE	4	20	29	TREE
4/14/2019	2.00	PHIL	1	36	72	MISCELLANEOUS
4/14/2019	0.67	SVILLE	4	154	103.18	WEATHER
4/14/2019	3.58	BASS	2	37	132.46	WEATHER
4/14/2019	2.92	ML	4	58	169.36	WEATHER
4/14/2019	3.75	COBURG	3	49	183.75	WEATHER
4/14/2019	3.67	ML	4	58	212.86	WEATHER
4/14/2019	2.83	BASS	3	80	226.4	WEATHER
4/14/2019	4.75	COBURG	2	102	484.5	WEATHER
4/16/2019	1.00	SVILLE	3	2	2	MISCELLANEOUS
4/17/2019	1.33	PHIL	1	36	47.88	MISCELLANEOUS
4/18/2019	1.17	MCK	2	7	8.19	MISCELLANEOUS

4/18/2019	1.08	MCK	3	59	63.72	TREE
4/19/2019	1.33	PHIL	1	42	55.86	MISCELLANEOUS
4/19/2019	2.00	ML	6	135	270	WEATHER
4/20/2019	1.00	GBURG	6	2	2	OVERLOAD
4/21/2019	2.08	GBURG	6	1	2.08	OVERLOAD
4/21/2019	1.08	GBURG	3	4	4.32	MISCELLANEOUS
4/21/2019	2.00	BASS	1	28	56	TREE
4/21/2019	1.67	BASS	3	53	88.51	EQUIPMENT/MATERIAL FAILURE
4/21/2019	1.17	BASS	3	850	994.5	ANIMAL
4/23/2019	1.17	GBURG	6	7	8.19	EQUIPMENT/MATERIAL FAILURE
4/24/2019	0.87	COBURG	2	61	53.07	ANIMAL
4/25/2019	0.58	CVILLE	2	3	1.74	EQUIPMENT/MATERIAL FAILURE
4/26/2019	0.75	ML	1	3	2.25	MISCELLANEOUS
4/26/2019	0.58	MCK	1	23	13.34	TREE
4/26/2019	1.08	WC	2	36	38.88	MISCELLANEOUS
4/28/2019	1.00	BASS	3	1	1	MISCELLANEOUS
4/28/2019	0.50	SVILLE	3	9	4.5	ANIMAL
4/28/2019	2.67	GRP	1	113	301.71	EQUIPMENT/MATERIAL FAILURE
4/29/2019	1.00	BASS	3	1	1	MISCELLANEOUS
4/30/2019	1.92	ML	1	1	1.92	EQUIPMENT/MATERIAL FAILURE
4/30/2019	0.58	GRP	1	15	8.7	MISCELLANEOUS
4/30/2019	9.08	GRP	2	3	27.24	EQUIPMENT/MATERIAL FAILURE
4/30/2019	1.33	COLUMBIA	2	29	38.57	MISCELLANEOUS
5/1/2019	1.50	SVILLE	4	2	3	TREE
5/1/2019	3.67	GBURG	4	2	7.34	OVERLOAD
5/1/2019	0.50	SVILLE	4	53	26.5	TREE
5/1/2019	0.75	BASS	2	41	30.75	TREE
5/2/2019	0.75	ML	4	7	5.25	ANIMAL
5/3/2019	0.42	SVILLE	4	53	22.26	MISCELLANEOUS
5/4/2019	0.92	EC	1	4	3.68	EQUIPMENT/MATERIAL FAILURE
5/4/2019	1.17	ML	4	11	12.87	ANIMAL
5/5/2019	2.00	COBURG	4	13	26	MISCELLANEOUS
5/5/2019	2.83	CRESTON	3	21	59.43	MISCELLANEOUS
5/5/2019	2.25	COLUMBIA	2	29	65.25	TREE
5/6/2019	1.00	GRP	2	1	1	EQUIPMENT/MATERIAL FAILURE

5/7/2019	0.42	EC	2	19	7.98	MISCELLANEOUS
5/7/2019	1.00	COBURG	4	13	13	ANIMAL
5/7/2019	1.00	MCK	3	31	31	MISCELLANEOUS
5/8/2019	0.67	MCK	3	2	1.34	ANIMAL
5/8/2019	1.42	ML	1	9	12.78	ANIMAL
5/10/2019	1.00	CRESTON	3	1	1	ANIMAL
5/10/2019	0.58	EC	3	11	6.38	ANIMAL
5/11/2019	2.00	BASS	3	80	160	CONSUMER
5/13/2019	24.00	BASS	1	1	24	EQUIPMENT/MATERIAL FAILURE
5/14/2019	1.33	PHIL	3	32	42.56	MISCELLANEOUS
5/15/2019	1.00	WC	3	1	1	MISCELLANEOUS
5/15/2019	0.67	ML	6	9	6.03	CONSUMER
5/15/2019	1.42	PHIL	3	32	45.44	MISCELLANEOUS
5/16/2019	0.58	BASS	3	4	2.32	TREE
5/16/2019	0.50	BASS	3	45	22.5	MISCELLANEOUS
5/16/2019	5.00	PHIL	3	32	160	EQUIPMENT/MATERIAL FAILURE
5/17/2019	1.00	EC	3	18	18	EQUIPMENT/MATERIAL FAILURE
5/17/2019	2.67	GBURG	1	7	18.69	OVERLOAD
5/17/2019	1.00	CRESTON	3	57	57	MISCELLANEOUS
5/18/2019	1.00	CRESTON	3	3	3	MISCELLANEOUS
5/18/2019	1.00	CRESTON	3	748	748	EQUIPMENT/MATERIAL FAILURE
5/18/2019	3.00	CRESTON	3	250	750	EQUIPMENT/MATERIAL FAILURE
5/19/2019	0.83	EC	3	34	28.22	WEATHER
5/19/2019	0.58	BASS	3	55	31.9	TREE
5/19/2019	1.00	SVILLE	1	36	36	MISCELLANEOUS
5/20/2019	0.77	EC	1	1	0.77	TREE
5/20/2019	1.00	COBURG	2	63	63	WEATHER
5/20/2019	1.42	COBURG	3	215	305.3	TREE
5/21/2019	0.83	PHIL	3	7	5.81	PLANNED
5/21/2019	0.67	SVILLE	3	9	6.03	ANIMAL
5/22/2019	0.67	GBURG	3	1	0.67	ANIMAL
5/22/2019	1.00	SVILLE	4	3	3	MISCELLANEOUS
5/22/2019	0.77	MCK	3	31	23.87	TREE
5/23/2019	1.17	MCK	2	1	1.17	MISCELLANEOUS
5/23/2019	1.25	COBURG	3	1	1.25	OVERLOAD

5/23/2019	0.75	GARLIN	5	6	4.5	MISCELLANEOUS
5/24/2019	0.50	EC	1	6	3	ANIMAL
5/24/2019	0.58	CRESTON	1	6	3.48	MISCELLANEOUS
5/25/2019	1.92	EC	1	1	1.92	TREE
5/25/2019	0.58	EC	1	6	3.48	ANIMAL
5/25/2019	1.25	COBURG	3	3	3.75	OVERLOAD
5/25/2019	1.00	WC	4	21	21	MISCELLANEOUS
5/25/2019	0.67	BASS	3	55	36.85	TREE
5/25/2019	1.43	BASS	3	55	78.65	TREE
5/26/2019	0.75	ML	3	2	1.5	EQUIPMENT/MATERIAL FAILURE
5/26/2019	1.67	EC	1	1	1.67	EQUIPMENT/MATERIAL FAILURE
5/26/2019	1.33	GARLIN	5	3	3.99	MISCELLANEOUS
5/26/2019	0.93	COBURG	2	19	17.67	WEATHER
5/26/2019	1.33	MCK	3	31	41.23	WEATHER
5/27/2019	13.67	COBURG	3	1	13.67	TREE
5/27/2019	1.00	EC	1	73	73	MISCELLANEOUS
5/28/2019	1.00	MCK	1	2	2	MISCELLANEOUS
5/28/2019	1.33	ML	2	3	3.99	EQUIPMENT/MATERIAL FAILURE
5/28/2019	0.92	BASS	3	55	50.6	TREE
5/29/2019	1.08	EC	3	5	5.4	WEATHER
5/30/2019	1.93	COBURG	4	1	1.93	EQUIPMENT/MATERIAL FAILURE
5/30/2019	1.72	COLUMBIA	5	2	3.44	MISCELLANEOUS
5/30/2019	1.08	WC	3	4	4.32	MISCELLANEOUS
5/30/2019	1.00	GBURG	4	39	39	MISCELLANEOUS
6/2/2019	1.50	CRESTON	3	6	9	MISCELLANEOUS
6/2/2019	1.00	SVILLE	3	9	9	MISCELLANEOUS
6/2/2019	0.33	CVILLE	2	39	12.87	WEATHER
6/3/2019	0.42	EC	2	1	0.42	EQUIPMENT/MATERIAL FAILURE
6/3/2019	1.00	CRESTON	1	2	2	MISCELLANEOUS
6/3/2019	1.00	GBURG	1	2	2	EQUIPMENT/MATERIAL FAILURE
6/4/2019	0.33	GARLIN	2	11	3.63	MISCELLANEOUS
6/4/2019	0.75	CRESTON	3	21	15.75	MISCELLANEOUS
6/4/2019	0.92	WC	3	68	62.56	MISCELLANEOUS
6/5/2019	0.33	CRESTON	1	2	0.66	MISCELLANEOUS
6/5/2019	0.83	GARLIN	2	11	9.13	MISCELLANEOUS

6/5/2019	0.50	CVILLE	5	63	31.5	WEATHER
6/5/2019	1.17	GARLIN	5	81	94.77	MISCELLANEOUS
6/6/2019	1.00	SVILLE	1	1	1	WEATHER
6/6/2019	0.67	CRESTON	1	13	8.71	MISCELLANEOUS
6/6/2019	2.33	CRESTON	3	95	221.35	TREE
6/7/2019	0.83	CRESTON	2	16	13.28	MISCELLANEOUS
6/7/2019	1.50	CRESTON	2	16	24	TREE
6/7/2019	0.83	SVILLE	1	53	43.99	TREE
6/8/2019	1.42	ML	5	2	2.84	MISCELLANEOUS
6/8/2019	0.67	GARLIN	2	11	7.37	MISCELLANEOUS
6/8/2019	2.00	COBURG	2	5	10	EQUIPMENT/MATERIAL FAILURE
6/8/2019	2.50	WC	2	73	182.5	MISCELLANEOUS
6/9/2019	1.00	WC	3	1	1	EQUIPMENT/MATERIAL FAILURE
6/9/2019	1.92	WC	2	45	86.4	EQUIPMENT/MATERIAL FAILURE
6/10/2019	0.83	COBURG	2	4	3.32	ANIMAL
6/10/2019	1.00	COBURG	2	63	63	MISCELLANEOUS
6/11/2019	1.00	BASS	3	1	1	TREE
6/11/2019	0.83	ML	3	11	9.13	ANIMAL
6/12/2019	0.50	ML	6	54	27	TREE
6/13/2019	0.83	CRESTON	2	11	9.13	MISCELLANEOUS
6/13/2019	16.00	SVILLE	1	1	16	MISCELLANEOUS
6/13/2019	0.67	GBURG	4	39	26.13	ANIMAL
6/14/2019	1.00	CRESTON	3	3	3	MISCELLANEOUS
6/15/2019	1.00	ML	3	1	1	ANIMAL
6/15/2019	1.17	GARLIN	3	9	10.53	WEATHER
6/15/2019	0.92	GBURG	1	12	11.04	MISCELLANEOUS
6/16/2019	1.75	GARLIN	5	1	1.75	ANIMAL
6/16/2019	0.83	GARLIN	5	405	336.15	ANIMAL
6/18/2019	1.00	MCK	1	1	1	WEATHER
6/18/2019	1.50	COLUMBIA	5	44	66	TREE
6/19/2019	0.67	GBURG	6	5	3.35	MISCELLANEOUS
6/19/2019	4.25	BASS	1	2	8.5	MISCELLANEOUS
6/19/2019	8.67	BASS	3	1	8.67	WEATHER
6/19/2019	2.08	BASS	3	81	168.48	WEATHER
6/20/2019	1.00	CRESTON	1	1	1	EQUIPMENT/MATERIAL FAILURE

6/20/2019	1.00	GARLIN	4	3	3	WEATHER
6/20/2019	3.92	WC	3	1	3.92	WEATHER
6/20/2019	2.00	COBURG	1	2	4	PLANNED
6/20/2019	0.08	CVILLE	5	67	5.36	WEATHER
6/20/2019	0.58	CRESTON	1	26	15.08	MISCELLANEOUS
6/20/2019	1.00	ML	1	40	40	WEATHER
6/20/2019	1.00	COBURG	2	62	62	WEATHER
6/20/2019	2.75	PHIL	3	32	88	TREE
6/20/2019	1.72	COLUMBIA	2	565	971.8	EQUIPMENT/MATERIAL FAILURE
6/21/2019	1.00	SVILLE	1	2	2	MISCELLANEOUS
6/21/2019	6.33	WC	2	1	6.33	WEATHER
6/21/2019	13.73	COLUMBIA	5	1	13.73	WEATHER
6/21/2019	8.58	WC	3	3	25.74	WEATHER
6/21/2019	0.83	SVILLE	3	35	29.05	WEATHER
6/21/2019	1.00	GARLIN	5	81	81	TREE
6/21/2019	11.92	COLUMBIA	5	12	143.04	WEATHER
6/21/2019	7.92	COLUMBIA	5	27	213.84	WEATHER
6/21/2019	5.50	COLUMBIA	2	76	418	WEATHER
6/22/2019	1.00	CVILLE	5	1	1	WEATHER
6/22/2019	1.00	GBURG	4	1	1	WEATHER
6/22/2019	1.00	CVILLE	5	3	3	WEATHER
6/22/2019	11.83	COLUMBIA	2	38	449.54	WEATHER
6/23/2019	3.83	SVILLE	4	1	3.83	WEATHER
6/23/2019	2.00	CRESTON	3	2	4	WEATHER
6/23/2019	0.50	SVILLE	1	21	10.5	WEATHER
6/23/2019	1.33	COLUMBIA	5	16	21.28	WEATHER
6/23/2019	24.00	PHIL	1	1	24	WEATHER
6/23/2019	3.83	EC	5	10	38.3	WEATHER
6/23/2019	2.00	COLUMBIA	5	44	88	WEATHER
6/23/2019	1.00	SVILLE	4	114	114	WEATHER
6/23/2019	5.75	WC	3	20	115	WEATHER
6/23/2019	0.83	SVILLE	4	209	173.47	WEATHER
6/23/2019	2.58	SVILLE	4	69	178.02	WEATHER
6/23/2019	3.83	BASS	3	115	440.45	WEATHER
6/23/2019	2.42	ML	5	469	1134.98	WEATHER

6/23/2019	2.17	MCK	1	641	1390.97	WEATHER
6/23/2019	6.00	COLUMBIA	2	601	3606	WEATHER
6/23/2019	4.50	PHIL	1	833	3748.5	WEATHER
6/24/2019	0.83	GBURG	1	2	1.66	MISCELLANEOUS
6/24/2019	0.83	WC	3	3	2.49	TREE
6/24/2019	4.50	BASS	3	2	9	WEATHER
6/24/2019	0.25	SVILLE	1	70	17.5	WEATHER
6/24/2019	1.42	GARLIN	5	42	59.64	WEATHER
6/24/2019	4.00	PHIL	5	281	1124	WEATHER
6/25/2019	2.33	MCK	2	2	4.66	WEATHER
6/26/2019	1.00	ML	6	1	1	EQUIPMENT/MATERIAL FAILURE
6/26/2019	2.00	CRESTON	3	1	2	EQUIPMENT/MATERIAL FAILURE
6/26/2019	2.33	EC	1	2	4.66	CONSUMER
6/26/2019	1.75	EC	1	6	10.5	CONSUMER
6/26/2019	1.83	PHIL	3	32	58.56	TREE
6/26/2019	1.00	WC	3	141	141	EQUIPMENT/MATERIAL FAILURE
6/26/2019	2.83	WC	3	68	192.44	CONSUMER
6/27/2019	1.33	COLUMBIA	5	2	2.66	MISCELLANEOUS
6/27/2019	4.37	COLUMBIA	5	44	192.28	WEATHER
6/27/2019	5.75	COLUMBIA	2	94	540.5	WEATHER
6/29/2019	1.42	GARLIN	4	2	2.84	ANIMAL
6/29/2019	7.00	COBURG	1	1	7	EQUIPMENT/MATERIAL FAILURE
6/29/2019	1.75	SVILLE	3	15	26.25	MISCELLANEOUS
6/29/2019	1.50	GARLIN	5	42	63	WEATHER
6/29/2019	3.72	SVILLE	1	86	319.92	ANIMAL
7/1/2019	0.58	GBURG	5	116	67.28	MISCELLANEOUS
7/1/2019	2.50	PHIL	1	37	92.5	TREE
7/2/2019	1.50	PHIL	4	1	1.5	MISCELLANEOUS
7/2/2019	1.17	CRESTON	3	49	57.33	MISCELLANEOUS
7/2/2019	1.50	CRESTON	3	49	73.5	TREE
7/3/2019	1.33	ML	3	5	6.65	MISCELLANEOUS
7/3/2019	2.83	MCK	1	3	8.49	WEATHER
7/3/2019	1.17	MCK	1	34	39.78	WEATHER
7/4/2019	2.67	GARLIN	5	6	16.02	MISCELLANEOUS
7/4/2019	3.25	COLUMBIA	2	15	48.75	WEATHER

7/4/2019	1.67	ML	6	54	90.18	MISCELLANEOUS
7/4/2019	3.00	BASS	2	50	150	TREE
7/4/2019	4.50	EC	3	472	2124	WEATHER
7/5/2019	1.00	GRP	3	1	1	WEATHER
7/5/2019	1.00	EC	4	1	1	EQUIPMENT/MATERIAL FAILURE
7/5/2019	0.83	GARLIN	5	15	12.45	MISCELLANEOUS
7/5/2019	1.00	WC	2	50	50	MISCELLANEOUS
7/6/2019	2.00	ML	3	5	10	MISCELLANEOUS
7/7/2019	1.00	COLUMBIA	2	1	1	EQUIPMENT/MATERIAL FAILURE
7/7/2019	1.00	PHIL	1	2	2	MISCELLANEOUS
7/7/2019	3.50	PHIL	1	4	14	EQUIPMENT/MATERIAL FAILURE
7/7/2019	3.00	WC	4	14	42	WEATHER
7/8/2019	1.50	CRESTON	1	1	1.5	EQUIPMENT/MATERIAL FAILURE
7/9/2019	1.00	GBURG	6	1	1	MISCELLANEOUS
7/9/2019	0.83	SVILLE	4	12	9.96	TREE
7/11/2019	1.50	MCK	2	1	1.5	MISCELLANEOUS
7/11/2019	1.50	COBURG	3	16	24	WEATHER
7/12/2019	0.50	EC	1	9	4.5	EQUIPMENT/MATERIAL FAILURE
7/12/2019	1.50	GARLIN	5	4	6	MISCELLANEOUS
7/12/2019	1.33	EC	1	28	37.24	TREE
7/13/2019	0.83	ML	3	5	4.15	EQUIPMENT/MATERIAL FAILURE
7/14/2019	1.00	BASS	3	2	2	MISCELLANEOUS
7/14/2019	2.83	SVILLE	3	4	11.32	EQUIPMENT/MATERIAL FAILURE
7/14/2019	2.83	GBURG	5	8	22.64	EQUIPMENT/MATERIAL FAILURE
7/14/2019	1.83	GBURG	5	116	212.28	EQUIPMENT/MATERIAL FAILURE
7/15/2019	0.75	ML	3	2	1.5	WEATHER
7/15/2019	2.00	PHIL	3	1	2	CONSUMER
7/15/2019	1.58	ML	6	50	79	WEATHER
7/16/2019	1.00	GBURG	3	1	1	WEATHER
7/16/2019	1.33	CRESTON	3	18	23.94	MISCELLANEOUS
7/16/2019	0.50	WC	3	48	24	MISCELLANEOUS
7/16/2019	1.00	WC	3	48	48	MISCELLANEOUS
7/16/2019	1.50	COLUMBIA	2	77	115.5	MISCELLANEOUS
7/17/2019	0.50	GBURG	1	1	0.5	MISCELLANEOUS
7/17/2019	1.00	COLUMBIA	2	1	1	MISCELLANEOUS

7/17/2019	1.00	COLUMBIA	5	1	1	WEATHER
7/17/2019	0.42	ML	2	12	5.04	ANIMAL
7/17/2019	1.50	CRESTON	1	7	10.5	EQUIPMENT/MATERIAL FAILURE
7/17/2019	1.00	WC	3	47	47	MISCELLANEOUS
7/17/2019	1.50	BASS	1	40	60	TREE
7/17/2019	1.08	CRESTON	1	111	119.88	MISCELLANEOUS
7/18/2019	1.00	GARLIN	5	1	1	WEATHER
7/18/2019	1.92	EC	1	1	1.92	TREE
7/18/2019	5.00	CVILLE	3	1	5	EQUIPMENT/MATERIAL FAILURE
7/18/2019	0.73	GARLIN	3	7	5.11	TREE
7/20/2019	0.33	GARLIN	5	647	213.51	EQUIPMENT/MATERIAL FAILURE
7/20/2019	1.00	GARLIN	5	403	403	EQUIPMENT/MATERIAL FAILURE
7/21/2019	1.00	COBURG	3	1	1	WEATHER
7/21/2019	3.00	PHIL	1	4	12	MISCELLANEOUS
7/21/2019	16.50	ML	3	1	16.5	EQUIPMENT/MATERIAL FAILURE
7/21/2019	3.00	PHIL	1	60	180	MISCELLANEOUS
7/22/2019	0.58	GARLIN	5	2	1.16	ANIMAL
7/22/2019	7.42	ML	3	1	7.42	WEATHER
7/22/2019	0.83	GRP	1	14	11.62	WEATHER
7/22/2019	1.17	WC	3	68	79.56	MISCELLANEOUS
7/22/2019	2.42	BASS	1	40	96.8	ANIMAL
7/22/2019	2.08	PHIL	3	85	176.8	TREE
7/23/2019	0.67	GRP	1	84	56.28	ANIMAL
7/23/2019	1.00	PHIL	3	68	68	MISCELLANEOUS
7/24/2019	1.25	CVILLE	3	1	1.25	EQUIPMENT/MATERIAL FAILURE
7/24/2019	0.42	SVILLE	4	6	2.52	CONSUMER
7/24/2019	2.33	CVILLE	5	24	55.92	EQUIPMENT/MATERIAL FAILURE
7/25/2019	1.00	COBURG	1	1	1	WEATHER
7/25/2019	3.92	GARLIN	5	1	3.92	EQUIPMENT/MATERIAL FAILURE
7/25/2019	0.67	GARLIN	5	43	28.81	EQUIPMENT/MATERIAL FAILURE
7/26/2019	0.83	GARLIN	5	80	66.4	MISCELLANEOUS
7/27/2019	3.33	COBURG	2	44	146.52	ANIMAL
7/28/2019	1.50	PHIL	3	4	6	EQUIPMENT/MATERIAL FAILURE
7/29/2019	1.00	GBURG	5	89	89	EQUIPMENT/MATERIAL FAILURE
7/30/2019	5.00	COLUMBIA	2	1	5	TREE

7/30/2019	0.67	GARLIN	2	11	7.37	MISCELLANEOUS
7/30/2019	1.08	COLUMBIA	2	38	41.04	TREE
7/31/2019	1.00	MCK	3	3	3	ANIMAL
7/31/2019	0.08	ML	2	370	29.6	MISCELLANEOUS
8/1/2019	1.17	PHIL	5	4	4.68	MISCELLANEOUS
8/1/2019	0.50	COBURG	1	36	18	WEATHER
8/1/2019	1.83	GARLIN	5	15	27.45	ANIMAL
8/2/2019	1.00	COLUMBIA	3	1	1	WEATHER
8/2/2019	1.28	GBURG	4	1	1.28	MISCELLANEOUS
8/2/2019	3.00	CRESTON	2	3	9	MISCELLANEOUS
8/3/2019	0.92	MCK	2	4	3.68	ANIMAL
8/3/2019	2.00	GARLIN	4	3	6	ANIMAL
8/3/2019	0.92	GARLIN	5	15	13.8	MISCELLANEOUS
8/3/2019	1.50	COLUMBIA	2	47	70.5	MISCELLANEOUS
8/3/2019	0.80	GBURG	5	90	72	EQUIPMENT/MATERIAL FAILURE
8/4/2019	0.67	GARLIN	5	2	1.34	ANIMAL
8/4/2019	1.00	ML	3	11	11	WEATHER
8/6/2019	0.75	GBURG	1	34	25.5	MISCELLANEOUS
8/7/2019	1.17	PHIL	3	32	37.44	MISCELLANEOUS
8/10/2019	3.00	GRP	1	1	3	CONSUMER
8/10/2019	0.58	GRP	1	26	15.08	TREE
8/11/2019	2.00	GBURG	3	1	2	ANIMAL
8/11/2019	1.17	ML	2	4	4.68	EQUIPMENT/MATERIAL FAILURE
8/13/2019	1.00	SVILLE	4	22	22	WEATHER
8/13/2019	2.17	GARLIN	5	11	23.87	EQUIPMENT/MATERIAL FAILURE
8/16/2019	10.00	PHIL	2	3	30	CONSUMER
8/18/2019	2.75	WC	2	1	2.75	OVERLOAD
8/19/2019	1.00	WC	2	1	1	MISCELLANEOUS
8/20/2019	1.00	CRESTON	1	1	1	WEATHER
8/20/2019	1.02	GRP	1	1	1.02	EQUIPMENT/MATERIAL FAILURE
8/20/2019	0.75	GBURG	3	10	7.5	MISCELLANEOUS
8/20/2019	15.50	COBURG	1	1	15.5	WEATHER
8/20/2019	1.42	COLUMBIA	5	17	24.14	WEATHER
8/20/2019	1.00	COBURG	4	27	27	WEATHER
8/20/2019	3.17	ML	3	19	60.23	WEATHER

8/20/2019	1.00	CRESTON	1	78	78	WEATHER
8/20/2019	1.00	SVILLE	1	110	110	WEATHER
8/20/2019	2.50	BASS	5	51	127.5	WEATHER
8/21/2019	1.00	GBURG	5	9	9	EQUIPMENT/MATERIAL FAILURE
8/21/2019	11.25	COBURG	4	1	11.25	EQUIPMENT/MATERIAL FAILURE
8/22/2019	1.00	COLUMBIA	2	3	3	WEATHER
8/22/2019	0.75	GARLIN	5	42	31.5	WEATHER
8/22/2019	0.83	GARLIN	5	80	66.4	WEATHER
8/23/2019	1.00	COBURG	2	1	1	ANIMAL
8/23/2019	1.67	EC	3	3	5.01	ANIMAL
8/24/2019	1.58	CRESTON	2	23	36.34	MISCELLANEOUS
8/25/2019	0.17	EC	3	2	0.34	WEATHER
8/25/2019	0.92	EC	5	6	5.52	ANIMAL
8/25/2019	2.42	ML	4	18	43.56	WEATHER
8/25/2019	0.50	EC	3	473	236.5	WEATHER
8/26/2019	2.75	GARLIN	5	2	5.5	EQUIPMENT/MATERIAL FAILURE
8/26/2019	2.40	SVILLE	4	11	26.4	WEATHER
8/26/2019	2.17	CRESTON	3	49	106.33	TREE
8/27/2019	1.17	GBURG	3	3	3.51	WEATHER
8/27/2019	1.00	GBURG	1	34	34	MISCELLANEOUS
8/28/2019	1.50	GARLIN	5	1	1.5	EQUIPMENT/MATERIAL FAILURE
8/28/2019	1.00	EC	3	2	2	MISCELLANEOUS
8/28/2019	0.50	CRESTON	2	23	11.5	TREE
8/29/2019	0.88	MCK	3	5	4.4	MISCELLANEOUS
8/31/2019	1.00	EC	2	1	1	MISCELLANEOUS
8/31/2019	1.00	CRESTON	3	1	1	EQUIPMENT/MATERIAL FAILURE
9/1/2019	1.33	GARLIN	3	2	2.66	MISCELLANEOUS
9/2/2019	1.83	BASS	3	1	1.83	ANIMAL
9/3/2019	1.00	SVILLE	1	1	1	CONSUMER
9/5/2019	4.00	CRESTON	3	1	4	MISCELLANEOUS
9/5/2019	3.17	MCK	2	15	47.55	ANIMAL
9/6/2019	0.67	GRP	1	1	0.67	ANIMAL
9/6/2019	1.17	GBURG	3	7	8.19	MISCELLANEOUS
9/9/2019	0.83	MCK	1	1	0.83	MISCELLANEOUS
9/9/2019	1.33	WC	3	91	121.03	ANIMAL

9/10/2019	2.50	CRESTON	3	559	1397.5	WEATHER
9/11/2019	1.25	CVILLE	3	77	96.25	CONSUMER
9/13/2019	0.83	GBURG	3	1	0.83	EQUIPMENT/MATERIAL FAILURE
9/13/2019	1.00	COBURG	4	1	1	MISCELLANEOUS
9/13/2019	0.83	GRP	1	7	5.81	EQUIPMENT/MATERIAL FAILURE
9/14/2019	1.50	CVILLE	1	8	12	CONSUMER
9/15/2019	0.98	GBURG	1	34	33.32	ANIMAL
9/15/2019	2.33	PHIL	3	17	39.61	MISCELLANEOUS
9/17/2019	0.58	ML	3	43	24.94	ANIMAL
9/19/2019	0.67	GBURG	3	4	2.68	MISCELLANEOUS
9/19/2019	0.67	ML	4	11	7.37	TREE
9/22/2019	0.72	GBURG	1	34	24.48	MISCELLANEOUS
9/22/2019	1.92	ML	3	67	128.64	EQUIPMENT/MATERIAL FAILURE
9/23/2019	1.00	ML	3	2	2	ANIMAL
9/24/2019	0.92	CRESTON	1	40	36.8	MISCELLANEOUS
9/25/2019	1.25	COBURG	1	26	32.5	EQUIPMENT/MATERIAL FAILURE
9/26/2019	1.25	ML	4	1	1.25	CONSUMER
9/26/2019	0.37	GBURG	4	40	14.8	MISCELLANEOUS
9/26/2019	0.42	CVILLE	2	78	32.76	ANIMAL
9/27/2019	2.67	SVILLE	4	1	2.67	EQUIPMENT/MATERIAL FAILURE
9/28/2019	1.00	ML	3	1	1	EQUIPMENT/MATERIAL FAILURE
9/28/2019	2.17	GARLIN	4	2	4.34	EQUIPMENT/MATERIAL FAILURE
9/29/2019	2.67	SVILLE	4	42	112.14	TREE
9/30/2019	0.67	COLUMBIA	2	3	2.01	MISCELLANEOUS
10/1/2019	4.50	GRP	1	1	4.5	ANIMAL
10/1/2019	1.83	GARLIN	4	36	65.88	CONSUMER
10/3/2019	0.50	ML	3	27	13.5	MISCELLANEOUS
10/4/2019	0.50	COLUMBIA	2	3	1.5	MISCELLANEOUS
10/4/2019	0.83	COBURG	4	24	19.92	ANIMAL
10/5/2019	4.50	CRESTON	2	1	4.5	CONSUMER
10/6/2019	1.00	COBURG	1	2	2	WEATHER
10/6/2019	1.50	COLUMBIA	2	7	10.5	MISCELLANEOUS
10/6/2019	0.87	GBURG	1	34	29.58	EQUIPMENT/MATERIAL FAILURE
10/6/2019	1.00	BASS	1	36	36	MISCELLANEOUS
10/6/2019	1.75	COBURG	3	25	43.75	TREE

10/6/2019	0.92	EC	3	470	432.4	WEATHER
10/7/2019	1.50	COBURG	2	1	1.5	EQUIPMENT/MATERIAL FAILURE
10/7/2019	1.00	EC	3	470	470	EQUIPMENT/MATERIAL FAILURE
10/7/2019	3.00	BASS	1	248	744	WEATHER
10/8/2019	2.00	ML	2	3	6	TREE
10/8/2019	1.12	EC	1	55	61.6	TREE
10/9/2019	0.50	COLUMBIA	5	45	22.5	MISCELLANEOUS
10/9/2019	0.75	BASS	2	104	78	MISCELLANEOUS
10/10/2019	1.00	GARLIN	3	1	1	OVERLOAD
10/10/2019	0.83	GBURG	3	31	25.73	MISCELLANEOUS
10/12/2019	0.92	CRESTON	2	5	4.6	MISCELLANEOUS
10/12/2019	0.83	CRESTON	3	21	17.43	MISCELLANEOUS
10/13/2019	3.00	CRESTON	2	1	3	EQUIPMENT/MATERIAL FAILURE
10/14/2019	1.00	GBURG	1	1	1	MISCELLANEOUS
10/14/2019	2.33	WC	3	22	51.26	MISCELLANEOUS
10/15/2019	0.92	PHIL	2	10	9.2	MISCELLANEOUS
10/15/2019	1.00	COBURG	3	40	40	EQUIPMENT/MATERIAL FAILURE
10/16/2019	7.33	GBURG	6	1	7.33	EQUIPMENT/MATERIAL FAILURE
10/16/2019	0.92	ML	1	26	23.92	WEATHER
10/17/2019	2.83	ML	1	8	22.64	EQUIPMENT/MATERIAL FAILURE
10/17/2019	0.83	GARLIN	5	39	32.37	MISCELLANEOUS
10/18/2019	0.50	COLUMBIA	2	2	1	ANIMAL
10/21/2019	1.00	COBURG	3	1	1	WEATHER
10/21/2019	3.50	COBURG	1	18	63	WEATHER
10/21/2019	0.67	SVILLE	1	311	208.37	WEATHER
10/22/2019	0.83	GRP	2	3	2.49	ANIMAL
10/22/2019	1.00	GARLIN	3	32	32	MISCELLANEOUS
10/24/2019	0.50	CRESTON	1	2	1	MISCELLANEOUS
10/25/2019	1.00	COBURG	3	2	2	MISCELLANEOUS
10/27/2019	0.67	ML	3	1	0.67	ANIMAL
10/27/2019	0.90	GBURG	3	4	3.6	MISCELLANEOUS
10/27/2019	2.33	CVILLE	5	2	4.66	EQUIPMENT/MATERIAL FAILURE
10/27/2019	1.00	CRESTON	3	21	21	MISCELLANEOUS
10/31/2019	2.17	ML	6	4	8.68	WEATHER
10/31/2019	0.83	COLUMBIA	5	19	15.77	WEATHER

10/31/2019	1.00	BASS	3	68	68	WEATHER
10/31/2019	4.00	COLUMBIA	5	19	76	WEATHER
10/31/2019	1.25	ML	6	570	712.5	WEATHER
11/1/2019	1.00	SVILLE	4	1	1	TREE
11/1/2019	0.63	PHIL	5	35	22.05	EQUIPMENT/MATERIAL FAILURE
11/3/2019	0.75	GARLIN	3	1	0.75	OVERLOAD
11/4/2019	0.67	CRESTON	1	8	5.36	EQUIPMENT/MATERIAL FAILURE
11/6/2019	1.50	MCK	3	50	75	MISCELLANEOUS
11/6/2019	0.42	MCK	3	311	130.62	MISCELLANEOUS
11/8/2019	0.58	GRP	2	1	0.58	EQUIPMENT/MATERIAL FAILURE
11/8/2019	1.00	ML	1	1	1	WEATHER
11/9/2019	3.00	GARLIN	3	1	3	MISCELLANEOUS
11/9/2019	1.00	GARLIN	3	8	8	TREE
11/10/2019	7.83	GBURG	3	2	15.66	MISCELLANEOUS
11/11/2019	0.25	CVILLE	3	4	1	MISCELLANEOUS
11/12/2019	1.00	MCK	2	21	21	TREE
11/13/2019	0.75	SVILLE	4	1	0.75	OVERLOAD
11/13/2019	1.33	CVILLE	3	1	1.33	EQUIPMENT/MATERIAL FAILURE
11/13/2019	2.00	CRESTON	3	2	4	EQUIPMENT/MATERIAL FAILURE
11/16/2019	1.00	SVILLE	1	2	2	CONSUMER
11/16/2019	2.00	BASS	2	5	10	EQUIPMENT/MATERIAL FAILURE
11/16/2019	1.00	SVILLE	1	311	311	CONSUMER
11/17/2019	1.50	COBURG	2	36	54	TREE
11/20/2019	0.83	MCK	3	2	1.66	ANIMAL
11/20/2019	0.85	GBURG	5	3	2.55	MISCELLANEOUS
11/21/2019	1.00	BASS	1	1	1	CONSUMER
11/22/2019	2.83	EC	3	43	121.69	EQUIPMENT/MATERIAL FAILURE
11/23/2019	1.17	WC	3	2	2.34	ANIMAL
11/23/2019	1.00	PHIL	5	35	35	EQUIPMENT/MATERIAL FAILURE
11/24/2019	0.50	PHIL	2	1	0.5	MISCELLANEOUS
11/24/2019	1.17	WC	3	25	29.25	MISCELLANEOUS
11/26/2019	1.00	CVILLE	5	1	1	EQUIPMENT/MATERIAL FAILURE
11/27/2019	2.25	CRESTON	1	1	2.25	WEATHER
11/27/2019	1.00	CVILLE	3	8	8	TREE
11/27/2019	1.50	GRP	1	8	12	TREE

11/27/2019	3.55	ML	2	4	14.2	TREE
11/27/2019	1.83	SVILLE	1	42	76.86	TREE
11/27/2019	1.08	GARLIN	2	82	88.56	WEATHER
11/27/2019	0.83	ML	4	116	96.28	TREE
11/28/2019	1.17	COBURG	1	28	32.76	EQUIPMENT/MATERIAL FAILURE
11/28/2019	132.50	COBURG	1	1	132.5	WEATHER
11/29/2019	6.00	BASS	1	1	6	MISCELLANEOUS
11/29/2019	1.33	WC	2	73	97.09	MISCELLANEOUS
11/30/2019	1.00	BASS	1	36	36	MISCELLANEOUS
11/30/2019	1.00	BASS	1	36	36	MISCELLANEOUS
11/30/2019	3.00	BASS	1	36	108	EQUIPMENT/MATERIAL FAILURE
12/1/2019	1.83	COLUMBIA	5	50	91.5	ANIMAL
12/2/2019	3.50	WC	2	36	126	TREE
12/2/2019	1.67	COBURG	3	217	362.39	ANIMAL
12/3/2019	1.50	CVILLE	2	4	6	EQUIPMENT/MATERIAL FAILURE
12/5/2019	0.58	ML	5	26	15.08	TREE
12/7/2019	1.58	COBURG	2	1	1.58	TREE
12/8/2019	1.58	CVILLE	3	10	15.8	MISCELLANEOUS
12/8/2019	2.17	COBURG	2	63	136.71	EQUIPMENT/MATERIAL FAILURE
12/8/2019	5.58	COBURG	2	63	351.54	MISCELLANEOUS
12/10/2019	0.42	ML	6	6	2.52	MISCELLANEOUS
12/10/2019	0.75	CVILLE	5	8	6	ANIMAL
12/10/2019	0.67	BASS	3	46	30.82	EQUIPMENT/MATERIAL FAILURE
12/11/2019	3.17	GBURG	3	1	3.17	EQUIPMENT/MATERIAL FAILURE
12/14/2019	2.75	MCK	3	2	5.5	MISCELLANEOUS
12/14/2019	0.75	GBURG	3	10	7.5	MISCELLANEOUS
12/15/2019	2.50	COBURG	3	2	5	OVERLOAD
12/16/2019	1.00	CRESTON	3	2	2	MISCELLANEOUS
12/16/2019	0.50	MCK	3	36	18	WEATHER
12/18/2019	1.00	WC	3	1	1	EQUIPMENT/MATERIAL FAILURE
12/19/2019	1.00	PHIL	1	3	3	MISCELLANEOUS
12/20/2019	4.00	ML	1	11	44	OVERLOAD
12/22/2019	2.83	GARLIN	3	1	2.83	EQUIPMENT/MATERIAL FAILURE
12/22/2019	2.98	MCK	1	6	17.88	EQUIPMENT/MATERIAL FAILURE
12/23/2019	2.00	CRESTON	3	4	8	CONSUMER

12/23/2019	0.50	GBURG	4	41	20.5	MISCELLANEOUS
12/26/2019	1.17	GBURG	3	34	39.78	MISCELLANEOUS
12/26/2019	1.15	SVILLE	1	88	101.2	MISCELLANEOUS
12/26/2019	1.33	SVILLE	1	88	117.04	WEATHER
12/27/2019	1.75	PHIL	2	15	26.25	ANIMAL
12/27/2019	3.25	CVILLE	5	47	152.75	EQUIPMENT/MATERIAL FAILURE
12/27/2019	1.83	CVILLE	5	623	1140.09	EQUIPMENT/MATERIAL FAILURE
12/28/2019	2.00	CONTOWN	4	2	4	MISCELLANEOUS
12/28/2019	1.67	BASS	3	80	133.6	TREE
12/29/2019	3.33	CVILLE	3	1	3.33	TREE
12/30/2019	1.00	GARLIN	5	1	1	TREE
12/30/2019	1.25	COLUMBIA	2	1	1.25	EQUIPMENT/MATERIAL FAILURE
12/30/2019	1.83	CRESTON	3	62	113.46	MISCELLANEOUS
12/31/2019	1.00	CONTOWN	3	1	1	MISCELLANEOUS
12/31/2019	8.33	BASS	3	5	41.65	CONSUMER
12/31/2019	2.67	BASS	3	32	85.44	CONSUMER

Taylor County RECC

SECTION 5: CIRCUIT REPORTING

**CIRCUITS with SAIDI AND/OR SAIFI EXCEEDING 5-year AVG
(excluding MED)**

1) Substation name and number	Bass
2) Substation location (County-road-town)	Hwy 70 at Taylor/Casey County Lir
3) Circuit name and number	1
4) Circuit location (town-road-general area)	Toward Liberty
5) Total Circuit Length (miles)	61.63
6) Customer count for this circuit	392
7) Date of last circuit trim (VM)	2006
8) List outage causes for circuit along with percentage of total outage numbers represented by each cause	Animal 8.27% Consumer 0.09% Equipment 14.69% Miscellaneous 10.53% Tree 9.91% Weather 64.87%
9)	
10)	
11) Circuit 5 year average SAIDI	114.63
12) Reporting year SAIDI	194.2
13) Circuit 5 year average SAIFI	0.89
14) Reporting year SAIFI	1.4

List of correction action, if any, taken or to be taken

Taylor County RECC

SECTION 5: CIRCUIT REPORTING

**CIRCUITS with SAIDI AND/OR SAIFI EXCEEDING 5-year AVG
(excluding MED)**

1) Substation name and number	Bass	
2) Substation location (County-road-town)	Hwy 70 at Taylor/Casey County Lir	
3) Circuit name and number	2	
4) Circuit location (town-road-general area)	Feathersburg/Knifley	
5) Total Circuit Length (miles)	67.42	
6) Customer count for this circuit	524	
7) Date of last circuit trim (VM)	2009	
8) List outage causes for circuit along with percentage of total outage numbers represented by each cause	Equipment	5.24%
	Miscellaneous	18.33%
	Tree	39.59%
	Weather	36.84%
9) Circuit 5 year average SAIDI	79.01	
10) Reporting year SAIDI	98.5	
11) Circuit 5 year average SAIFI	0.72	
12) Reporting year SAIFI	1.1	
13) List of correction action, if any, taken or to be taken		

Taylor County RECC

SECTION 5: CIRCUIT REPORTING

**CIRCUITS with SAIDI AND/OR SAIFI EXCEEDING 5-year AVG
(excluding MED)**

1) Substation name and number	Bass
2) Substation location (County-road-town)	Hwy 70 at Taylor/Casey County Lir
3) Circuit name and number	3
4) Circuit location (town-road-general area)	Toward Mannsville
5) Total Circuit Length (miles)	108.17
6) Customer count for this circuit	839
7) Date of last circuit trim (VM)	2012
8) List outage causes for circuit along with percentage of total outage numbers represented by each cause	Animal 35.01% Consumer 10.11% Equipment 5.97% Miscellaneous 9.34% Tree 13.69% Weather 34.19%
9) Circuit 5 year average SAIDI	117.4
10) Reporting year SAIDI	170.9
11) Circuit 5 year average SAIFI	1.38
12) Reporting year SAIFI	2.1
13) List of correction action, if any, taken or to be taken	

Taylor County RECC

SECTION 5: CIRCUIT REPORTING

**CIRCUITS with SAIDI AND/OR SAIFI EXCEEDING 5-year AVG
(excluding MED)**

1) Substation name and number	Coburg
2) Substation location (County-road-town)	Hwy 682 and Cane Valley Road intersection
3) Circuit name and number	2
4) Circuit location (town-road-general area)	Toward Campbellsville
5) Total Circuit Length (miles)	52.16
6) Customer count for this circuit	549
7) Date of last circuit trim (VM)	2010
8) List outage causes for circuit along with percentage of total outage numbers represented by each cause	Animal 16.02% Equipment 9.92% Miscellaneous 27.75% Tree 3.89% Weather 42.43%
9) Circuit 5 year average SAIDI	117.82
10) Reporting year SAIDI	163.3
11) Circuit 5 year average SAIFI	1.03
12) Reporting year SAIFI	1.2
13) List of correction action, if any, taken or to be taken	

Taylor County RECC

SECTION 5: CIRCUIT REPORTING

**CIRCUITS with SAIDI AND/OR SAIFI EXCEEDING 5-year AVG
(excluding MED)**

1)	Substation name and number	Columbia	
2)	Substation location (County-road-town)	Hwy 55 and Hwy 6177 intersection	
3)	Circuit name and number	2	
4)	Circuit location (town-road-general area)	Toward Columbia	
5)	Total Circuit Length (miles)	92.8	
P	Customer count for this circuit	607	
7)	Date of last circuit trim (VM)	2014	
8)	List outage causes for circuit along with percentage of total outage numbers represented by each cause	Animal Equipment Miscellaneous Tree Weather	0.01% 20.42% 3.36% 1.53% 74.68%
9)	Circuit 5 year average SAIDI	208.24	
10)	Reporting year SAIDI	363.8	
11)	Circuit 5 year average SAIFI	2.24	
12)	Reporting year SAIFI	3.7	
13)	List of correction action, if any, taken or to be taken		

Taylor County RECC

SECTION 5: CIRCUIT REPORTING

CIRCUITS with SAIDI AND/OR SAIFI EXCEEDING 5-year AVG (excluding MED)

1)	Substation name and number	Creston	
2)	Substation location (County-road-town)	Hwy 70 nr Hwy 206 Intersection	
3)	Circuit name and number	1	
4)	Circuit location (town-road-general area)	Toward Liberty	
5)	Total Circuit Length (miles)	63.9	
6)	Customer count for this circuit	722	
7)	Date of last circuit trim (VM)	2009	
8)	List outage causes for circuit along with percentage of total outage numbers represented by each cause	Equipment Miscellaneous Weather	4.83% 43.41% 51.76%
9)	Circuit 5 year average SAIDI	39.82	
10)	Reporting year SAIDI	35.9	
11)	Circuit 5 year average SAIFI	0.47	
12)	Reporting year SAIFI	0.5	
13)	List of correction action, if any, taken or to be taken		

Taylor County RECC

SECTION 5: CIRCUIT REPORTING

**CIRCUITS with SAIDI AND/OR SAIFI EXCEEDING 5-year AVG
(excluding MED)**

1)	Substation name and number	Creston	
2)	Substation location (County-road-town)	Hwy 70 nr Hwy 206 Intersection	
3)	Circuit name and number	3	
4)	Circuit location (town-road-general area)	Dunbar Hill / Knifley	
5)	Total Circuit Length (miles)	124.63	
6)	Customer count for this circuit	1002	
7)	Date of last circuit trim (VM)	2008	
8)	List outage causes for circuit along with percentage of total outage numbers represented by each cause	Animal Consumer Equipment Miscellaneous Tree Weather	0.03% 0.21% 39.86% 10.40% 10.56% 38.94%
9)	Circuit 5 year average SAIDI	107.81	
10)	Reporting year SAIDI	227.3	
11)	Circuit 5 year average SAIFI	0.91	
12)	Reporting year SAIFI	2.1	
13)	List of correction action, if any, taken or to be taken		

Taylor County RECC

SECTION 5: CIRCUIT REPORTING

**CIRCUITS with SAIDI AND/OR SAIFI EXCEEDING 5-year AVG
(excluding MED)**

1) Substation name and number	Campbellsville
2) Substation location (County-road-town)	Taylor-nr Hwy 55/Hwy 3183 Intersection
3) Circuit name and number	2
4) Circuit location (town-road-general area)	Blue Hole Road
5) Total Circuit Length (miles)	18.83
6) Customer count for this circuit	427
7) Date of last circuit trim (VM)	2014
8) List outage causes for circuit along with percentage of total outage numbers represented by each cause	Animal 60.43% Equipment 15.83% Weather 23.74%
9) Circuit 5 year average SAIDI	8.22
10) Reporting year SAIDI	7.6
11) Circuit 5 year average SAIFI	0.17
12) Reporting year SAIFI	0.3
13) List of correction action, if any, taken or to be taken	

Taylor County RECC

SECTION 5: CIRCUIT REPORTING

**CIRCUITS with SAIDI AND/OR SAIFI EXCEEDING 5-year AVG
(excluding MED)**

1) Substation name and number	Campbellsville
2) Substation location (County-road-town)	Taylor-nr Hwy 55/Hwy 3183 Intersection
3) Circuit name and number	5
4) Circuit location (town-road-general area)	Greensburg Rd
5) Total Circuit Length (miles)	40.78
6) Customer count for this circuit	626
7) Date of last circuit trim (VM)	2014
8) List outage causes for circuit along with percentage of total outage numbers represented by each cause	Animal 0.44% Equipment 99.60% Weather 2.99%
9) Circuit 5 year average SAIDI	53.44
10) Reporting year SAIDI	135
11) Circuit 5 year average SAIFI	0.7
12) Reporting year SAIFI	1.3
13) List of correction action, if any, taken or to be taken	

Taylor County RECC

SECTION 5: CIRCUIT REPORTING

**CIRCUITS with SAIDI AND/OR SAIFI EXCEEDING 5-year AVG
(excluding MED)**

1) Substation name and number	East Campbellville
2) Substation location (County-road-town)	Taylor-nr Hwy 70/Hwy 3518 Int
3) Circuit name and number	3
4) Circuit location (town-road-general area)	Smith Ridge
5) Total Circuit Length (miles)	21.99
6) Customer count for this circuit	474
7) Date of last circuit trim (VM)	2013
8) List outage causes for circuit along with percentage of total outage numbers represented by each cause	Animal 0.33% Equipment 0.05% Miscellaneous 17.70% Weather 82.00%
9) Circuit 5 year average SAIDI	81.5
10) Reporting year SAIDI	197.2
11) Circuit 5 year average SAIFI	1.3
12) Reporting year SAIFI	3.3
13) List of correction action, if any, taken or to be taken	

Taylor County RECC

SECTION 5: CIRCUIT REPORTING

**CIRCUITS with SAIDI AND/OR SAIFI EXCEEDING 5-year AVG
(excluding MED)**

1) Substation name and number	Garlin	
2) Substation location (County-road-town)	Hwy 206 nr Charles Cole Rd	
3) Circuit name and number	2	
4) Circuit location (town-road-general area)	Hwy 80	
5) Total Circuit Length (miles)	6.55	
6) Customer count for this circuit	156	
7) Date of last circuit trim (VM)	2013	
8) List outage causes for circuit along with percentage of total outage numbers represented by each cause	Consumer	1.80%
	Equipment	0.70%
	Miscellaneous	16.10%
	Weather	81.50%
9) Circuit 5 year average SAIDI	28.34	
10) Reporting year SAIDI	65.9	
11) Circuit 5 year average SAIFI	0.67	
12) Reporting year SAIFI	1.1	
13) List of correction action, if any, taken or to be taken		

Taylor County RECC

SECTION 5: CIRCUIT REPORTING

**CIRCUITS with SAIDI AND/OR SAIFI EXCEEDING 5-year AVG
(excluding MED)**

1) Substation name and number	Garlin	
2) Substation location (County-road-town)	Adair-Hwy 206 nr Charles Cole Rd	
3) Circuit name and number	5	
4) Circuit location (town-road-general area)	Hwy 206	
5) Total Circuit Length (miles)	65.89	
6) Customer count for this circuit	651	
7) Date of last circuit trim (VM)	2013	
8) List outage causes for circuit along with percentage of total outage numbers represented by each cause	Animal	22.03%
	Equipment	40.70%
	Miscellaneous	15.00%
	Tree	5.00%
	Weather	17.30%
9) Circuit 5 year average SAIDI	118.03	
10) Reporting year SAIDI	153.9	
11) Circuit 5 year average SAIFI	1.69	
12) Reporting year SAIFI	3.2	
13) List of correction action, if any, taken or to be taken		

Taylor County RECC

SECTION 5: CIRCUIT REPORTING

**CIRCUITS with SAIDI AND/OR SAIFI EXCEEDING 5-year AVG
(excluding MED)**

1) Substation name and number	Greensburg
2) Substation location (County-road-town)	Green-nr Hwy61/West Hodgenville Rd Inters
3) Circuit name and number	4
4) Circuit location (town-road-general area)	Hospital
5) Total Circuit Length (miles)	8.72
6) Customer count for this circuit	230
7) Date of last circuit trim (VM)	2009
8) List outage causes for circuit along with percentage of total outage numbers represented by each cause	Animal 11.64% Miscellaneous 33.66% Overload 3.27% Planned 50.99% Weather 0.45%
9) Circuit 5 year average SAIDI	43.5
10) Reporting year SAIDI	58.6
11) Circuit 5 year average SAIFI	0.85
12) Reporting year SAIFI	1.7
13) List of correction action, if any, taken or to be taken	

Taylor County RECC

SECTION 5: CIRCUIT REPORTING

**CIRCUITS with SAIDI AND/OR SAIFI EXCEEDING 5-year AVG
(excluding MED)**

1) Substation name and number	Greensburg
2) Substation location (County-road-town)	Green-nr Hwy61/West Hodgenville Rd Inters
3) Circuit name and number	6
4) Circuit location (town-road-general area)	Hwy 88
5) Total Circuit Length (miles)	46.54
6) Customer count for this circuit	309
7) Date of last circuit trim (VM)	2011
8) List outage causes for circuit along with percentage of total outage numbers represented by each cause	Equipment 4.28% Miscellaneous 2.40% Overload 1.13% Tree 91.22% Weather 0.97%
9) Circuit 5 year average SAIDI	47.02
10) Reporting year SAIDI	70.3
11) Circuit 5 year average SAIFI	0.65
12) Reporting year SAIFI	1.1
13) List of correction action, if any, taken or to be taken	

Taylor County RECC

SECTION 5: CIRCUIT REPORTING

**CIRCUITS with SAIDI AND/OR SAIFI EXCEEDING 5-year AVG
(excluding MED)**

1) Substation name and number	Green River Plaza	
2) Substation location (County-road-town)	Behind TCRECC Offc	
3) Circuit name and number	1	
4) Circuit location (town-road-general area)	Radio Station	
5) Total Circuit Length (miles)	20.78	
6) Customer count for this circuit	649	
7) Date of last circuit trim (VM)	2006	
8) List outage causes for circuit along with percentage of total outage numbers represented by each cause	Animal	14.58%
	Consumer	0.71%
	Equipment	73.22%
	Miscellaneous	2.31%
	Tree	6.43%
	Weather	2.76%
9) Circuit 5 year average SAIDI	24.2	
10) Reporting year SAIDI	39	
11) Circuit 5 year average SAIFI	0.29	
12) Reporting year SAIFI	0.4	
13) List of correction action, if any, taken or to be taken		

Taylor County RECC

SECTION 5: CIRCUIT REPORTING

**CIRCUITS with SAIDI AND/OR SAIFI EXCEEDING 5-year AVG
(excluding MED)**

1) Substation name and number	McKinney Corner
2) Substation location (County-road-town)	Green-Hwy 68 nr Hwy 218 Intersection
3) Circuit name and number	3
4) Circuit location (town-road-general area)	To Greensburg
5) Total Circuit Length (miles)	42.71
6) Customer count for this circuit	317
7) Date of last circuit trim (VM)	2008
8) List outage causes for circuit along with percentage of total outage numbers represented by each cause	Animal 1.38% Miscellaneous 56.51% Tree 28.31% Weather 13.81%
9) Circuit 5 year average SAIDI	136.42
10) Reporting year SAIDI	82.6
11) Circuit 5 year average SAIFI	1.16
12) Reporting year SAIFI	1.9
13) List of correction action, if any, taken or to be taken	

Taylor County RECC

SECTION 5: CIRCUIT REPORTING

**CIRCUITS with SAIDI AND/OR SAIFI EXCEEDING 5-year AVG
(excluding MED)**

1) Substation name and number	Mile Lane
2) Substation location (County-road-town)	Taylor-nr Hwy527/Hwy3211 Intersection
3) Circuit name and number	2
4) Circuit location (town-road-general area)	Bluegrass Estates
5) Total Circuit Length (miles)	12.97
6) Customer count for this circuit	367
7) Date of last circuit trim (VM)	2012
8) List outage causes for circuit along with percentage of total outage numbers represented by each cause	Animal 2.33% Equipment 4.01% Miscellaneous 13.68% Tree 30.59% Weather 49.39%
9) Circuit 5 year average SAIDI	43.2
10) Reporting year SAIDI	35.4
11) Circuit 5 year average SAIFI	1.16
12) Reporting year SAIFI	1.5
13) List of correction action, if any, taken or to be taken	

Taylor County RECC

SECTION 5: CIRCUIT REPORTING

**CIRCUITS with SAIDI AND/OR SAIFI EXCEEDING 5-year AVG
(excluding MED)**

1) Substation name and number	Mile Lane	
2) Substation location (County-road-town)	Taylor-nr Hwy527/Hwy3211 Intersection	
3) Circuit name and number	4	
4) Circuit location (town-road-general area)	Hwy 210	
5) Total Circuit Length (miles)	50.92	
6) Customer count for this circuit	457	
7) Date of last circuit trim (VM)	2011	
8) List outage causes for circuit along with percentage of total outage numbers represented by each cause	Animal	2.56%
	Consumer	0.18%
	Equipment	1.36%
	Tree	14.63%
	Weather	81.28%
9) Circuit 5 year average SAIDI	78.66	
10) Reporting year SAIDI	93	
11) Circuit 5 year average SAIFI	1.11	
12) Reporting year SAIFI	0.8	
13) List of correction action, if any, taken or to be taken		

Taylor County RECC

SECTION 5: CIRCUIT REPORTING

**CIRCUITS with SAIDI AND/OR SAIFI EXCEEDING 5-year AVG
(excluding MED)**

1) Substation name and number	Mile Lane
2) Substation location (County-road-town)	Taylor-nr Hwy527/Hwy3211 Intersection
3) Circuit name and number	6
4) Circuit location (town-road-general area)	Palestine
5) Total Circuit Length (miles)	44.11
6) Customer count for this circuit	573
7) Date of last circuit trim (VM)	2012
8) List outage causes for circuit along with percentage of total outage numbers represented by each cause	Animal 0.28% Consumer 0.50% Equipment 0.08% Miscellaneous 7.72% Tree 2.25% Weather 89.17%
9) Circuit 5 year average SAIDI	52.17
10) Reporting year SAIDI	125.8
11) Circuit 5 year average SAIFI	0.99
12) Reporting year SAIFI	1.6
13) List of correction action, if any, taken or to be taken	

Taylor County RECC

SECTION 5: CIRCUIT REPORTING

**CIRCUITS with SAIDI AND/OR SAIFI EXCEEDING 5-year AVG
(excluding MED)**

1) Substation name and number	Phil
2) Substation location (County-road-town)	Casey-nr Hwy127/Haggard Drive Intersection
3) Circuit name and number	1
4) Circuit location (town-road-general area)	Toward Liberty
5) Total Circuit Length (miles)	26.67
6) Customer count for this circuit	351
7) Date of last circuit trim (VM)	2014
8) List outage causes for circuit along with percentage of total outage numbers represented by each cause	Equipment 1.16% Miscellaneous 9.26% Tree 2.10% Weather 87.48%
9) Circuit 5 year average SAIDI	73.82
10) Reporting year SAIDI	106.7
11) Circuit 5 year average SAIFI	0.74
12) Reporting year SAIFI	1.4
13) List of correction action, if any, taken or to be taken	

Taylor County RECC

SECTION 5: CIRCUIT REPORTING

**CIRCUITS with SAIDI AND/OR SAIFI EXCEEDING 5-year AVG
(excluding MED)**

1) Substation name and number	Phil
2) Substation location (County-road-town)	Casey-nr Hwy127/Haggard Drive Intersection
3) Circuit name and number	3
4) Circuit location (town-road-general area)	Dunnville
5) Total Circuit Length (miles)	44.95
6) Customer count for this circuit	363
7) Date of last circuit trim (VM)	2008
8) List outage causes for circuit along with percentage of total outage numbers represented by each cause	Consumer 0.14% Equipment 11.67% Micellaneous 16.38% Planned 0.41% Tree 28.84% Weather 42.56%
9) Circuit 5 year average SAIDI	162.95
10) Reporting year SAIDI	235.2
11) Circuit 5 year average SAIFI	2.12
12) Reporting year SAIFI	2.1
13) List of correction action, if any, taken or to be taken	

Taylor County RECC

SECTION 5: CIRCUIT REPORTING

**CIRCUITS with SAIDI AND/OR SAIFI EXCEEDING 5-year AVG
(excluding MED)**

1) Substation name and number	Phil	
2) Substation location (County-road-town)	Casey-nr Hwy127/Haggard Drive Intersection	
3) Circuit name and number	5	
4) Circuit location (town-road-general area)	Hwy 910	
5) Total Circuit Length (miles)	38.12	
6) Customer count for this circuit	286	
7) Date of last circuit trim (VM)	2010	
8) List outage causes for circuit along with percentage of total outage numbers represented by each cause	Equipment	4.23%
	Miscellaneous	0.35%
	Tree	12.02%
	Weather	83.40%
9) Circuit 5 year average SAIDI	159.25	
10) Reporting year SAIDI	282.7	
11) Circuit 5 year average SAIFI	1.71	
12) Reporting year SAIFI	1.4	
13) List of correction action, if any, taken or to be taken		

Taylor County RECC

SECTION 5: CIRCUIT REPORTING

**CIRCUITS with SAIDI AND/OR SAIFI EXCEEDING 5-year AVG
(excluding MED)**

1) Substation name and number	Summersville
2) Substation location (County-road-town)	Green-nr Hwy323/Raymond Despain Road Intersection
3) Circuit name and number	1
4) Circuit location (town-road-general area)	Bengal/Hwy 210
5) Total Circuit Length (miles)	138.9
6) Customer count for this circuit	890
7) Date of last circuit trim (VM)	2015
8) List outage causes for circuit along with percentage of total outage numbers represented by each cause	Animal 23.28% Consumer 22.85% Miscellaneous 11.29% Tree 8.79% Weather 33.79%
9) Circuit 5 year average SAIDI	82.96
10) Reporting year SAIDI	141.1
11) Circuit 5 year average SAIFI	1.41
12) Reporting year SAIFI	2.1
13) List of correction action, if any, taken or to be taken	

Taylor County RECC

SECTION 5: CIRCUIT REPORTING

**CIRCUITS with SAIDI AND/OR SAIFI EXCEEDING 5-year AVG
(excluding MED)**

1) Substation name and number	Summersville
2) Substation location (County-road-town)	Green-nr Hwy323/Raymond Despain Road Intersection
3) Circuit name and number	4
4) Circuit location (town-road-general area)	Bloyds Crossing
5) Total Circuit Length (miles)	138.9
6) Customer count for this circuit	890
7) Date of last circuit trim (VM)	2015
8) List outage causes for circuit along with percentage of total outage numbers represented by each cause	Consumer 0.12% Equipment 3.05% Miscellaneous 1.25% Overload 0.04% Planned 14.59% Tree 8.99% Weather 71.95%
9) Circuit 5 year average SAIDI	91.43
10) Reporting year SAIDI	104.5
11) Circuit 5 year average SAIFI	1.7
12) Reporting year SAIFI	2.1
13) List of correction action, if any, taken or to be taken	

Taylor County RECC

SECTION 5: CIRCUIT REPORTING

**CIRCUITS with SAIDI AND/OR SAIFI EXCEEDING 5-year AVG
(excluding MED)**

1) Substation name and number	West Columbia
2) Substation location (County-road-town)	Adair - Hwy 61S, S of Cumberland Pkway
3) Circuit name and number	3
4) Circuit location (town-road-general area)	Gradyville
5) Total Circuit Length (miles)	104.95
6) Customer count for this circuit	875
7) Date of last circuit trim (VM)	2014
8) List outage causes for circuit along with percentage of total outage numbers represented by each cause	Animal 12.44% Consumer 19.14% Equipment 13.34% Miscellaneous 32.37% Tree 0.23% Weather 22.47%
9) Circuit 5 year average SAIDI	69.02
10) Reporting year SAIDI	65.6
11) Circuit 5 year average SAIFI	0.75
12) Reporting year SAIFI	0.8
13) List of correction action, if any, taken or to be taken	

Taylor County RECC

SECTION 5: CIRCUIT REPORTING

**CIRCUITS with SAIDI AND/OR SAIFI EXCEEDING 5-year AVG
(excluding MED)**

1) Substation name and number	West Columbia	
2) Substation location (County-road-town)	Adair - Hwy 61S, S of Cumberland Pkway	
3) Circuit name and number	4	
4) Circuit location (town-road-general area)	Walmart	
5) Total Circuit Length (miles)	10.24	
6) Customer count for this circuit	126	
7) Date of last circuit trim (VM)	2018	
8) List outage causes for circuit along with percentage of total outage numbers represented by each cause	Miscellaneous Weather	33.30% 66.70%
9) Circuit 5 year average SAIDI	15.49	
10) Reporting year SAIDI	30	
11) Circuit 5 year average SAIFI	0.23	
12) Reporting year SAIFI	0.3	
13) List of correction action, if any, taken or to be taken		

Taylor County RECC Substation Coordinates		
rev 3/17/17		
<u>Substation</u>	<u>Lat</u>	<u>Long</u>
Bass	37°19'49.26"N	85° 9'3.97"W
Campbellsville	37°18'58.23"N	85°21'48.25"W
Coburg	37°11'51.17"N	85°19'31.25"W
Columbia	37° 5'3.02"N	85°17'57.08"W
Contown	37° 15'28.15"N	84°54'24.80"W
Creston	37°16'4.72"N	85° 2'45.94"W
East Campbellsville	37°20'7.78"N	85°19'4.30"W
Garlin	37° 6'27.49"N	85°16'35.83"W
Green River Plaza	37°20'13.17"N	85°21'34.37"W
Greensburg	37°16'14.12"N	85°30'33.99"W
McKinney Corner	37°11'8.42"N	85°31'44.90"W
Mile Lane	37°22'31.44"N	85°21'38.84"W
Phil	37°13'8.16"N	84°57'51.03"W
Summersville	37°19'50.85"N	85°32'12.79"W
West Columbia	37° 3'51.56"N	85°20'20.26"