

**PSC Outage Tabulation, 2012**

Taylor County RECC

*Case 2006-00494*

RECEIVED

MAR 28 2013

PUBLIC SERVICE  
COMMISSION

<b>System:</b>	<u>Year</u>	<u>SAIDI</u>	<u>SAIFI</u>	<u>CAIDI</u>
	2007	113.28	1.35	83.72
	2008	279.64	2.3	121.76
	2009	1391.8	7	197.7
	2010	307.16	3.91	78.65
	2011	89.4	1.1	81.7
	<b>2012</b>	<b>74.0</b>	<b>1.3</b>	<b>57.4</b>

**Outage Subcategory Breakdown:**

<u>Subcategory:</u>	<u>Mins:</u>
Animal	199,377.6
Consumer	88,543.2
Equipment	237,092.6
Miscellaneous	239,117.2
Overload	1,186.8
Plan	22,639.2
Power Supplier	367,106.4
Tree	148,410.6
Weather	594,631.2

**2012 - Major outage day defined per IEEE standard**

5yr avg Tmed for 12

457,820.4

Major Outage Days - None

**2012 10 Worst Circuits per Category:**

<u>Substation</u>	<u>C</u>	<u>SAIDI</u>	<u>SAIFI</u>	<u>CAIDI</u>	<u>Maj. Out. Category</u>
BASS	1	276.3			Power Supplier
BASS	3	265.7			Power Supplier
COLUMBIA	1	245.7			Equipment
MILE LANE	2	221.4			Animal
WEST COLUMBIA	2	201.3			Equipment
COLUMBIA	2	193.0			Weather
BASS	2	185.3			Power Supplier
WEST COLUMBIA	3	174.2			Weather
EAST CAMPBELLSVILLE	2	133.6			Weather
GARLIN	2	113.6			Equipment
BASS	3		4.8		Power Supplier
WEST COLUMBIA	3		4.2		Weather
BASS	1		4.0		Power Supplier
COLUMBIA	2		3.6		Weather
BASS	2		3.4		Power Supplier

COBURG	1	3.3	Power Supplier
EAST CAMPBELLSVILLE	2	2.9	Weather
WEST COLUMBIA	2	2.7	Equipment
COLUMBIA	5	2.7	Weather
COLUMBIA	3	2.6	Miscellaneous
COLUMBIA	1	860.1	Equipment
GREEN RIVER PLAZA	2	810.0	Weather
MILE LANE	6	313.4	Animal
GARLIN	2	188.2	Equipment
MILE LANE	4	181.3	Weather
MILE LANE	2	179.0	Animal
MCKINNEY CORNER	2	158.5	Weather
SUMMERSVILLE	3	137.6	Equipment
PHIL	1	125.6	Weather
GREENSBURG	3	115.8	Weather

**Vegetation Management Plan:**

Plan is progressing as expected/desired

Continue to face occasional issue with yard tree clearance

**Outages - 2012**

Taylor County RECC

<u>Date</u>	<u>Total Time (hrs)</u>	<u>Substation</u>	<u>Ckt</u>	<u># Membrs Effected</u>	<u>Consumers Hrs Off</u>	<u>Cause</u>
1/1/2012	1.25	MCK	3	28	35.0	TREES
1/1/2012	0.42	EC	3	440	184.8	TREES
1/1/2012	0.58	EC	3	22	12.8	WEATHER
1/1/2012	2.00	CRESTON	1	24	48.0	WEATHER
1/1/2012	1.67	BASS	1	1	1.7	TREES
1/1/2012	1.00	CRESTON	1	35	35.0	MISCELLANEOUS
1/2/2012	0.67	COL	5	1	0.7	EqUIPMENT MATERIAL FAILURE
1/3/2012	0.67	ML	3	50	33.5	MISCELLANEOUS
1/3/2012	0.92	WC	3	1	0.9	OVERLOAD
1/3/2012	0.50	CVILLE	5	13	6.5	ANIMAL
1/5/2012	1.75	ML	3	60	105.0	EQUIPMENT MATERIAL FAILURE
1/8/2012	0.63	COBURG	3	7	4.4	MISCELLANEOUS
1/9/2012	1.50	PHIL	2	3	4.5	ANIMAL
1/10/2012	1.00	GARLIN	5	14	14.0	ANIMAL
1/10/2012	3.25	ML	3	3	9.8	EQUIPMENT MATERIAL FAILURE
1/10/2012	0.33	EC	2	5	1.7	ANIMAL
1/11/2012	0.50	GBURG	1	1	0.5	ANIMAL
1/11/2012	0.75	GBURG	6	314	235.5	MISCELLANEOUS
1/11/2012	0.33	GBURG	1	3	1.0	ANIMAL
1/11/2012	48.58	WC	4	1	48.6	MISCELLANEOUS
1/11/2012	1.42	WC	2	793	1126.1	EQUIPMENT MATERIAL FAILURE
1/12/2012	1.25	ML	6	1	1.3	EQUIPMENT MATERIAL FAILURE
1/12/2012	20.50	WC	2	3	20.5	EqUIPMENT MATERIAL FAILURE
1/13/2012	1.17	WC	2	61	71.4	EQUIPMENT MATERIAL FAILURE
1/15/2012	1.83	BASS	2	3	5.5	EqUIPMENT MATERIAL FAILURE
1/16/2012	2.00	CVILLE	5	8	16.0	EQUIPMENT MATERIAL FAILURE
1/17/2012	1.08	PHIL	2	73	78.8	WEATHER
1/18/2012	0.75	GARLIN	2	10	7.5	MISCELLANEOUS
1/19/2012	0.50	GARLIN	3	544	272.0	ANIMAL
1/21/2012	1.30	GARLIN	1	6	7.8	WEATHER
1/21/2012	4.00	COL	2	2	8.0	WEATHER
1/21/2012	0.58	ML	4	4	2.3	WEATHER
1/21/2012	1.75	BASS	3	37	64.8	WEATHER
1/21/2012	4.42	GARLIN	3	9	39.8	WEATHER CONDITIONS
1/21/2012	0.92	GARLIN	5	7	6.4	MISCELLANEOUS

RECEIVED

MAR 28 2013  
PUBLIC SERVICE  
COMMISSION

1/21/2012	0.42	GARLIN	5	31	13.0
1/21/2012	7.08	GARLIN	3	1	7.1
1/21/2012	1.25	COBURG	2	15	18.8
1/21/2012	2.25	COBURG	2	15	33.8
1/21/2012	0.67	COBURG	2	2	1.3
1/22/2012	2.00	WC	3	141	282.0
1/22/2012	0.30	WC	3	411	123.3
1/23/2012	1.92	PHIL	1	333	639.4
1/23/2012	2.50	COBURG	2	15	37.5
1/23/2012	1.50	COBURG	2	15	22.5
1/23/2012	0.58	GARLIN	2	10	5.8
1/24/2012	0.58	GARLIN	5	2	1.2
1/24/2012	0.75	SVILLE	1	9	6.8
1/25/2012	0.08	GARLIN	4	187	15.0
1/25/2012	2.00	GARLIN	3	8	16.0
1/26/2012	1.33	CRESTON	3	1	1.3
1/29/2012	1.75	COBURG	1	26	45.5
1/29/2012	2.33	COLUMBIA	2	8	18.6
1/31/2012	1.92	COLUMBIA	5	4	7.7
2/1/2012	2.50	MCK	1	1	2.5
2/6/2012	1.17	COBURG	4	4	4.7
2/7/2012	0.25	PHIL	2	1	0.3
2/7/2012	1.50	EC	3	31	46.5
2/9/2012	1.50	CRESTON	3	1	1.5
2/11/2012	2.25	WC	3	2	4.5
2/12/2012	0.50	GBURG	6	7	3.5
2/13/2012	1.33	COBURG	1	1	1.3
2/14/2012	0.42	SVILLE	1	2	0.8
2/15/2012	2.33	GARLIN	2	10	23.3
2/15/2012	9.50	CRESTON	3	1	9.5
2/16/2012	0.42	CVILLE	5	15	6.3
2/17/2012	2.75	SVILLE	4	1	2.8
2/18/2012	7.92	WC	3	2	15.8
2/18/2012	1.75	GARLIN	3	1	1.8
2/20/2012	0.50	COL	2	8	4.0
2/21/2012	1.17	COLUMBIA	2	4	4.7
2/21/2012	0.37	WC	3	409	151.3
2/23/2012	0.42	GRP	3	1	0.4
2/24/2012	1.58	CVILLE	1	2	3.2

WEATHER CONDITIONS  
 WEATHER CONDITIONS  
 WEATHER CONDITIONS  
 WEATHER CONDITIONS  
 WEATHER CONDITIONS  
 WEATHER CONDITIONS  
 WEATHER  
 WEATHER CONDITIONS  
 WEATHER CONDITIONS  
 TREES  
 ANIMAL  
 MISCELLANEOUS  
 PLANNED  
 ANIMAL  
 EQUIPMENT MATERIAL FAILURE  
 EQUIPMENT MATERIAL FAILURE  
 MISCELLANEOUS  
 EQUIPMENT MATERIAL FAILURE  
 EQUIPMENT MATERIAL FAILURE  
 MISCELLANEOUS  
 MISCELLANEOUS  
 EQUIPMENT MATERIAL FAILURE  
 EQUIPMENT MATERIAL FAILURE  
 EQUIPMENT MATERIAL FAILURE  
 MISCELLANEOUS  
 EQUIPMENT MATERIAL FAILURE  
 MISCELLANEOUS  
 TREES  
 EQUIPMENT MATERIAL FAILURE  
 TREES  
 EQUIPMENT MATERIAL FAILURE  
 EQUIPMENT MATERIAL FAILURE  
 CONSUMER  
 MISCELLANEOUS  
 PLANNED  
 PLANNED  
 MISCELLANEOUS  
 PLANNED

2/24/2012	1.28	BASS	1	52	66.6
2/24/2012	1.25	SVILLE	1	2	2.5
2/26/2012	0.50	SVILLE	1	9	4.5
2/27/2012	4.33	BASS	1	1	4.3
2/29/2012	1.50	SVILLE	4	15	22.5
2/29/2012	0.67	ML	3	40	26.8
2/29/2012	3.75	ML	4	4	15.0
2/29/2012	1.50	CVILLE	3	4	6.0
2/29/2012	2.00	CVILLE	3	1	2.0
2/29/2012	1.33	ML	1	9	12.0
2/29/2012	2.00	GBURG	3	96	192.0
3/1/2012	0.58	EC	5	7	4.1
3/1/2012	1.00	CRESTON	3	3	3.0
3/2/2012	0.78	CRESTON	3	2	1.6
3/2/2012	0.42	WC	3	26	10.9
3/2/2012	0.33	WC	3	16	5.3
3/2/2012	2.42	WC	3	10	24.2
3/2/2012	1.92	GARLIN	5	15	28.8
3/2/2012	0.08	GARLIN	5	18	1.4
3/2/2012	2.35	WC	3	2	4.7
3/2/2012	2.17	COBURG	2	57	123.7
3/2/2012	2.00	EC	1	59	118.0
3/6/2012	29.75	GARLIN	5	1	29.8
3/7/2012	0.92	ML	1	35	32.2
3/8/2012	1.12	WC	2	64	71.7
3/11/2012	2.00	EC	3	2	4.0
3/12/2012	0.75	GBURG	6	5	3.8
3/14/2012	2.75	BASS	2	1	2.8
3/14/2012	1.50	BASS	1	2	3.0
3/15/2012	0.62	BASS	2	1	0.6
3/17/2012	1.33	BASS	3	15	20.0
3/19/2012	1.17	COBURG	2	3	3.5
3/21/2012	0.87	BASS	1,2, 3	1633	1420.7
3/21/2012	0.67	BASS	3	26	17.4
3/22/2012	0.13	EC	1	1	0.1
3/22/2012	2.42	EC	1	1	2.4
3/23/2012	1.25	ML	3	66	82.5
3/23/2012	4.50	GBURG	6	2	9.0
3/24/2012	1.50	ML	3	66	99.0

TREES  
 PLANNED  
 MISCELLANEOUS  
 CONSUMER  
 WEATHER CONDITIONS  
 WEATHER CONDITIONS  
 WEATHER CONDITIONS  
 WEATHER CONDITIONS  
 WEATHER CONDITIONS  
 WEATHER CONDITIONS  
 WEATHER CONDITIONS  
 ANIMAL  
 MISCELLANEOUS  
 WEATHER CONDITIONS  
 WEATHER CONDITIONS  
 WEATHER CONDITIONS  
 WEATHER CONDITIONS  
 WEATHER CONDITIONS  
 PLANNED  
 WEATHER CONDITIONS  
 WEATHER CONDITIONS  
 WEATHER CONDITIONS  
 WEATHER CONDITIONS  
 CONSUMER  
 TREES  
 ANIMAL  
 ANIMAL  
 EQUIPMENT MATERIAL FAILURE  
 EQUIPMENT MATERIAL FAILURE  
 MISCELLANEOUS  
 CONSUMER  
 CONSUMER  
 POWER SUPPLY  
 TREES  
 EQUIPMENT MATERIAL FAILURE  
 WEATHER  
 WEATHER CONDITIONS  
 CONSUMER  
 WEATHER

3/24/2012	0.92	COBURG	3	1	0.9	ANIMAL
3/24/2012	1.50	CVILLE	2	14	21.0	TREES
3/27/2012	23.50	BASS	1	1	23.5	WEATHER
3/27/2012	2.00	SVILLE	3	80	160.0	EQUIPMENT MATERIAL FAILURE
3/27/2012	5.15	WC	2	2	10.3	CONSUMER
3/27/2012	4.00	COBURG	2	2	8.0	OVERLOAD
3/27/2012	0.08	GARLIN	1	1	0.1	BAD CONNECTOR
3/28/2012	0.37	WC	3	409	151.3	WEATHER
3/29/2012	5.50	ML	6	1	5.5	EQUIPMENT MATERIAL FAILURE
3/29/2012	0.50	ML	5	6	3.0	CONSUMER
3/30/2012	1.17	COBURG	1	18	21.1	EQUIPMENT MATERIAL FAILURE
4/2/2012	0.67	WC	2	73	48.9	CONSUMER
4/2/2012	0.80	GBURG	1	2	1.6	ANIMAL
4/3/2012	0.13	WC	3	409	53.2	MISCELLANEOUS
4/4/2012	0.58	EC	1	7	4.1	CONSUMER
4/6/2012	1.17	MCK	2	164	191.9	CONSUMER
4/9/2012	0.50	BASS	3	1	0.5	MISCELLANEOUS
4/9/2012	2.00	PHIL	1	1	2.0	EQUIPMENT MATERIAL FAILURE
4/10/2012	0.70	BASS	1,2,3	1633	1143.1	POWER SUPPLY
4/12/2012	0.75	EC	5	3	2.3	MISCELLANEOUS
4/12/2012	2.00	ML	1	2	4.0	CONSUMER
4/12/2012	2.00	COBURG	4	1	2.0	EQUIPMENT MATERIAL FAILURE
4/16/2012	0.08	COL	3	224	17.9	PLANNED
4/16/2012	0.38	COL	3	229	87.0	EQUIPMENT MATERIAL FAILURE
4/18/2012	2.00	BASS	3	6	12.0	MISCELLANEOUS
4/20/2012	2.00	SVILLE	3	1	2.0	EQUIPMENT MATERIAL FAILURE
4/20/2012	23.92	PHIL	1	1	23.9	MISCELLANEOUS
4/21/2012	0.70	BASS	1,2,3	1654	1157.8	POWER SUPPLY
4/21/2012	3.08	MCK	3	1	3.1	TREES
4/23/2012	1.67	MCK	1	94	157.0	EQUIPMENT MATERIAL FAILURE
4/24/2012	5.83	WC	2	1	5.8	CONSUMER
4/25/2012	0.75	COL	2	1	0.8	MISCELLANEOUS
4/26/2012	5.35	MCK	2	1	5.4	TREES
4/26/2012	5.35	MCK	2	36	192.6	TREES
4/26/2012	5.42	MCK	2	83	449.9	WEATHER
4/26/2012	11.17	MCK	2	2	22.3	TREES
4/26/2012	2.00	WC	2	1	2.0	WEATHER
4/26/2012	1.47	GARLIN	4	189	277.8	WEATHER
4/26/2012	10.58	WC	3	1	10.6	WEATHER

4/26/2012	6.75	GARLIN	3	3	20.3	WEATHER
4/26/2012	9.08	WC	2	1	9.1	WEATHER
4/27/2012	0.83	WC	3	37	30.7	TREES
4/28/2012	1.75	COL	2	1	1.8	TREES
4/29/2012	5.00	GARLIN	5	1	5.0	ANIMAL
4/29/2012	1.75	CRESTON	3	3	5.3	MISCELLANEOUS
4/30/2012	0.67	COBURG	3	7	4.7	WEATHER CONDITIONS
4/30/2012	1.08	GRP	1	2	2.2	WEATHER CONDITIONS
4/30/2012	0.67	GBURG	1	2	1.3	WEATHER CONDITIONS
4/30/2012	3.50	MCK	1	4	14.0	CONSUMER
4/30/2012	0.58	GBURG	6	31	18.0	MISCELLANEOUS
5/1/2012	4.50	WC	2	30	135.0	TREE
5/1/2012	0.67	CRESTON	2	14	9.4	WEATHER CONDITIONS
5/1/2012	1.75	CRESTON	3	28	49.0	WEATHER CONDITIONS
5/1/2012	0.67	MCK	2	3	2.0	TREES
5/1/2012	1.00	SVILLE	3	2	2.0	CONSUMER
5/1/2012	3.17	BASS	2	1	3.2	WEATHER
5/1/2012	1.00	CVILLE	5	15	15.0	WEATHER
5/1/2012	0.42	ML	5	31	13.0	WEATHER
5/1/2012	1.25	COLUMBIA	2	1	1.3	WEATHER
5/1/2012	4.55	GARLIN	3	1	4.6	WEATHER
5/1/2012	3.50	BASS	3	83	290.5	CONSUMER
5/2/2012	0.92	COL	4	12	11.0	MISCELLANEOUS
5/2/2012	1.75	BASS	1	8	14.0	TREES
5/3/2012	23.87	ML	3	1	23.9	EQUIPMENT MATERIAL FAILURE
5/4/2012	1.42	EC	1	2	2.8	EQUIPMENT MATERIAL FAILURE
5/5/2012	0.92	ML	3	40	36.8	WEATHER
5/5/2012	2.67	WC	3	108	288.4	WEATHER
5/5/2012	3.75	WC	3	13	48.8	WEATHER
5/5/2012	1.50	CRESTON	1	35	52.5	WEATHER CONDITIONS
5/5/2012	0.50	SVILLE	1	1	0.5	Weather
5/5/2012	4.50	ML	4	42	189.0	WEATHER
5/7/2012	0.53	COL	3	2	1.1	WEATHER CONDITIONS
5/7/2012	0.17	WC	2	73	12.4	EQUIPMENT MATERIAL FAILURE
5/7/2012	0.67	WC	2	73	48.9	CONSUMER
5/7/2012	4.25	WC	2	12	51.0	CONSUMER
5/8/2012	0.33	GARLIN	2	10	3.3	ANIMAL
5/9/2012	1.08	SVILLE	1	570	615.6	MISCELLANEOUS
5/9/2012	1.92	GRP	1	1	1.9	MISCELLANEOUS

5/10/2012	0.45	ML	2	16	7.2	ANIMAL
5/10/2012	4.17	SVILLE	1	1	4.2	ANIMAL
5/11/2012	1.50	CVILLE	3	60	90.0	TREES
5/11/2012	0.67	ML	5	41	27.5	ANIMAL
5/11/2012	0.50	ML	5	1	0.5	EQUIPMENT MATERIAL FAILURE
5/11/2012	0.17	EC	1	9	1.5	MISCELLANEOUS
5/12/2012	1.00	GBURG	6	31	31.0	ANIMAL
5/12/2012	1.00	COL	5	67	67.0	TREES
5/12/2012	0.25	COBURG	3	53	13.3	CONSUMER
5/12/2012	0.75	EC	3	1	0.8	MISCELLANEOUS
5/12/2012	2.42	ML	4	42	101.6	EQUIPMENT MATERIAL FAILURE
5/12/2012	1.33	EC	1	1	1.3	EQUIPMENT MATERIAL FAILURE
5/13/2012	0.50	GBURG	4	1	0.5	TREES
5/13/2012	2.83	BASS	2	20	56.6	EQUIPMENT MATERIAL FAILURE
5/13/2012	2.42	BASS	3	29	70.2	MISCELLANEOUS
5/13/2012	2.33	GBURG	4	1	2.3	TREES
5/14/2012	0.42	WC	3	20	8.4	MISCELLANEOUS
5/14/2012	0.58	ML	3	11	6.4	CONSUMER
5/14/2012	3.00	CRESTON	2	4	12.0	CONSUMER
5/15/2012	0.58	BASS	3	29	16.8	MISCELLANEOUS
5/15/2012	0.28	ML	4	4	1.1	MISCELLANEOUS
5/15/2012	25.30	EC	1	1	25.3	TREES
5/15/2012	1.78	ML	6	1	1.8	TREES
5/15/2012	1.00	ML	1	9	9.0	TREES
5/15/2012	0.33	ML	5	1	0.3	TREES
5/15/2012	1.33	SVILLE	4	2	2.7	CONSUMER
5/16/2012	2.00	CVILLE	4	1	2.0	EQUIPMENT MATERIAL FAILURE
5/16/2012	2.58	WC	3	1	2.6	ANIMAL
5/17/2012	1.50	EC	1	65	97.5	ANIMAL
5/17/2012	0.87	COL	3	1	0.9	ANIMAL
5/18/2012	0.83	ML	5	31	25.7	ANIMAL
5/18/2012	0.75	CVILLE	3	28	21.0	ANIMAL
5/18/2012	0.67	WC	4	19	12.7	MISCELLANEOUS
5/18/2012	0.92	GARLIN	3	9	8.3	ANIMAL
5/18/2012	2.00	PHIL	1	6	12.0	EQUIPMENT MATERIAL FAILURE
5/19/2012	1.33	COBURG	2	17	22.6	EQUIPMENT MATERIAL FAILURE
5/20/2012	1.00	COL	2	8	8.0	EQUIPMENT MATERIAL FAILURE
5/20/2012	1.00	SVILLE	4	2	2.0	ANIMAL
5/20/2012	1.25	CRESTON	3	28	35.0	MISCELLANEOUS



5/21/2012	0.42	ML	3	11	4.6	MISCELLANEOUS
5/21/2012	1.50	COL	5	1	1.5	EQUIPMENT MATERIAL FAILURE
5/21/2012	71.67	BASS	1	1	71.7	MISCELLANEOUS
5/22/2012	1.00	GARLIN	3	4	4.0	CONSUMER
5/23/2012	0.33	CRESTON	1	29	9.6	MISCELLANEOUS
5/23/2012	1.50	CRESTON	1	13	19.5	ANIMAL
5/23/2012	120.00	ML	6	3	360.0	ANIMAL
5/24/2012	0.30	CVILLE	3	12	3.6	ANIMAL
5/25/2012	2.08	COBURG	1	1	2.1	ANIMAL
5/25/2012	0.67	ML	6	2	1.3	ANIMAL
5/25/2012	0.67	EC	1	5	3.4	ANIMAL
5/26/2012	1.58	WC	3	174	274.9	CONSUMER
5/26/2012	3.00	CVILLE	5	1	3.0	EQUIPMENT MATERIAL FAILURE
5/26/2012	2.50	MCK	3	2	5.0	ANIMAL
5/27/2012	11.58	SVILLE	3	2	23.2	ANIMAL
5/27/2012	0.75	ML	2	1	0.8	ANIMAL
5/28/2012	2.33	SVILLE	4	1	2.3	EQUIPMENT MATERIAL FAILURE
5/29/2012	0.83	COBURG	1	557	462.3	POWER SUPPLY
5/29/2012	0.08	COBURG	1	557	44.6	POWER SUPPLY
5/29/2012	3.00	CRESTON	3	1	3.0	WEATHER CONDITIONS
5/31/2012	0.67	EC	1	7	4.7	ANIMAL
5/31/2012	0.50	GARLIN	1	6	3.0	WEATHER CONDITIONS
6/1/2012	0.33	CVILLE	5	24	7.9	ANIMAL
6/1/2012	0.83	EC	3	4	3.3	ANIMAL
6/1/2012	0.50	WC	3	1	0.5	PLANNED
6/2/2012	2.00	GRP	1	11	22.0	EQUIPMENT MATERIAL FAILURE
6/2/2012	1.00	BASS	2	10	10.0	MISCELLANEOUS
6/3/2012	1.25	CVILLE	5	3	3.8	ANIMAL
6/3/2012	0.50	GBURG	4	1	0.5	ANIMAL
6/4/2012	2.33	ML	6	1	2.3	TREE
6/4/2012	1.17	PHIL	1	1	1.2	MISCELLANEOUS
6/5/2012	1.00	COBURG	3	187	187.0	EQUIPMENT MATERIAL FAILURE
6/5/2012	160.00	GARLIN	2	1	160.0	EQUIPMENT MATERIAL FAILURE
6/6/2012	1.00	GBURG	6	1	1.0	MISCELLANEOUS
6/8/2012	0.30	EC	3	4	1.2	ANIMAL
6/9/2012	1.00	BASS	2	1	1.0	EQUIPMENT MATERIAL FAILURE
6/10/2012	11.83	ML	2	82	970.1	ANIMAL
6/10/2012	1.50	EC	3	7	10.5	MISCELLANEOUS
6/10/2012	2.08	COBURG	4	2	4.2	MISCELLANEOUS

6/11/2012	1.75	COBURG	1	14	24.5	EQUIPMENT MATERIAL FAILURE
6/12/2012	23.83	COLUMBIA	2	1	23.8	MISCELLANEOUS
6/13/2012	2.92	ML	4	1	2.9	ANIMAL
6/14/2012	0.67	EC	3	3	2.0	ANIMAL
6/14/2012	0.50	EC	3	7	3.5	ANIMAL
6/14/2012	1.12	PHIL	3	2	2.2	CONSUMER
6/15/2012	0.58	MCK	2	3	1.7	EQUIPMENT MATERIAL FAILURE
6/15/2012	1.50	PHIL	3	2	3.0	ANIMAL
6/16/2012	1.50	GBURG	3	1	1.5	OVERLOAD
6/16/2012	0.42	SVILLE	4	2	0.8	MISCELLANEOUS
6/17/2012	0.83	COBURG	4	10	8.3	ANIMAL
6/17/2012	0.67	CVILLE	2	3	2.0	ANIMAL
6/17/2012	0.33	EC	3	10	3.3	MISCELLANEOUS
6/17/2012	2.67	ML	3	66	176.2	TREES
6/17/2012	0.92	GARLIN	3	219	201.5	EQUIPMENT MATERIAL FAILURE
6/18/2012	1.08	ML	1	6	6.5	ANIMAL
6/19/2012	1.00	COL	4	69	69.0	MISCELLANEOUS
6/19/2012	0.75	ML	2	21	15.8	ANIMAL
6/19/2012	1.50	EC	3	4	6.0	EQUIPMENT MATERIAL FAILURE
6/20/2012	0.50	EC	1	5	2.5	CONSUMER
6/20/2012	0.58	EC	5	270	156.6	EQUIPMENT MATERIAL FAILURE
6/20/2012	0.50	EC	5	270	135.0	ANIMAL
6/21/2012	0.58	GARLIN	3	3	1.7	ANIMAL
6/21/2012	1.00	GRP	3	84	84.0	ANIMAL
6/21/2012	0.33	ML	2	83	27.4	ANIMAL
6/21/2012	1.37	CRESTON	3	1	1.4	OVERLOAD
6/22/2012	2.17	GBURG	3	1	2.2	EQUIPMENT MATERIAL FAILURE
6/23/2012	0.50	CVILLE	3	1	0.5	EQUIPMENT MATERIAL FAILURE
6/24/2012	0.50	SVILLE	1	4	2.0	MISCELLANEOUS
6/24/2012	1.50	ML	4	12	18.0	ANIMAL
6/24/2012	1.00	ML	2	1	1.0	ANIMAL
6/24/2012	1.50	ML	3	2	3.0	TREE
6/24/2012	1.08	GARLIN	3	3	3.2	ANIMAL
6/25/2012	0.22	ML	4	4	0.9	ANIMAL
6/25/2012	1.00	CVILLE	3	15	15.0	ANIMAL
6/25/2012	0.92	ML	6	9	8.3	TREES
6/25/2012	0.33	COL	3	42	13.9	MISCELLANEOUS
6/25/2012	1.75	ML	1	1	1.8	MISCELLANEOUS
6/26/2012	0.30	ML	6	10	3.0	ANIMAL

6/27/2012	0.83	ML	2	82	68.1	ANIMAL
6/27/2012	1.17	ML	6	26	30.4	ANIMAL
6/27/2012	0.50	CVILLE	3	1	0.5	ANIMAL
6/27/2012	4.00	GARLIN	3	1	4.0	Equipment Material Failure
6/28/2012	5.00	MCK	2	1	5.0	MISCELLANEOUS
6/28/2012	5.00	MCK	2	1	5.0	MISCELLANEOUS
6/28/2012	3.83	COLUMBIA	2	44	168.5	TREES
6/29/2012	1.42	COBURG	1	59	83.8	ANIMAL
6/29/2012	3.92	COBURG	3	2	7.8	ANIMAL
6/29/2012	28.17	COLUMBIA	1	1	28.2	EQUIPMENT MATERIAL FAILURE
6/30/2012	1.50	COBURG	1	1	1.5	EQUIPMENT MATERIAL FAILURE
6/30/2012	0.58	CVILLE	3	16	9.3	ANIMAL
6/30/2012	0.75	CVILLE	3	4	3.0	ANIMAL
7/1/2012	0.92	GARLIN	2	12	11.0	WEATHER CONDITIONS
7/1/2012	1.08	GARLIN	5	9	9.7	Weather
7/1/2012	0.67	EC	2	331	221.8	WEATHER CONDITIONS
7/1/2012	1.50	EC	2	1	1.5	TREE
7/1/2012	0.92	GBURG	3	10	9.2	WEATHER CONDITIONS
7/2/2012	0.33	PHIL	3	1	0.3	MISCELLANEOUS
7/2/2012	3.33	EC	2	6	20.0	ANIMAL
7/2/2012	0.47	COBURG	3	1	0.5	MISCELLANEOUS
7/3/2012	0.58	COBURG	3	14	8.1	ANIMAL
7/3/2012	0.97	WC	2	1	1.0	CONSUMER
7/3/2012	2.00	MCK	2	1	2.0	TREES
7/3/2012	0.83	EC	5	1	0.8	EQUIPMENT MATERIAL FAILURE
7/4/2012	1.00	ML	6	9	9.0	TREE
7/4/2012	1.33	EC	3	2	2.7	ANIMAL
7/4/2012	0.67	GARLIN	5	8	5.4	ANIMAL
7/5/2012	8.58	CRESTON	3	3	25.7	WEATHER CONDITIONS
7/5/2012	0.67	PHIL	3	182	121.9	TREES
7/5/2012	0.50	EC	5	54	27.0	TREES
7/5/2012	0.25	ML	2	1	0.3	ANIMAL
7/5/2012	1.00	GARLIN	5	127	127.0	WEATHER
7/5/2012	3.33	GARLIN	5	95	316.4	WEATHER
7/6/2012	0.75	EC	1	1	0.8	ANIMAL
7/6/2012	1.67	CRESTON	1	3	5.0	EQUIPMENT MATERIAL FAILURE/OVERLOAD
7/6/2012	1.83	PHIL	2	31	56.7	MISCELLANEOUS
7/7/2012	1.00	MCK	3	1	1.0	CONSUMER
7/8/2012	0.92	EC	2	15	13.8	WEATHER CONDITIONS

7/8/2012	0.04	COBURG	4	1	0.0	ANIMAL
7/8/2012	1.00	WC	2	2	2.0	MISCELLANEOUS
7/8/2012	3.33	GARLIN	5	77	256.4	MISCELLANEOUS
7/8/2012	1.25	COBURG	3	14	17.5	WEATHER CONDITIONS
7/8/2012	2.15	COBURG	3	1	2.2	WEATHER CONDITIONS
7/8/2012	1.58	GARLIN	5	2	3.2	WEATHER CONDITIONS
7/8/2012	0.77	GARLIN	3	48	37.0	WEATHER
7/8/2012	3.17	GARLIN	3	5	15.9	WEATHER
7/9/2012	0.75	ML	2	62	46.5	TREE
7/9/2012	1.00	COLUMBIA	2	3	3.0	MISCELLANEOUS
7/9/2012	0.67	PHIL	3	1	0.7	WEATHER CONDITIONS
7/9/2012	2.00	MCK	1	1	2.0	EQUIPMENT MATERIAL FAILURE
7/9/2012	0.30	WC	3	53	15.9	WEATHER
7/9/2012	6.00	WC	3	18	108.0	WEATHER
7/10/2012	21.00	PHIL	2	1	21.0	TREES
7/10/2012	0.33	CRESTON	1	35	11.6	MISCELLANEOUS
7/10/2012	3.00	GBURG	3	1	3.0	WEATHER CONDITIONS
7/12/2012	3.67	SVILLE	4	1	3.7	EQUIPMENT MATERIAL FAILURE
7/12/2012	1.83	GBURG	6	1	1.8	WEATHER
7/13/2012	2.00	ML	4	1	2.0	TREE
7/13/2012	0.75	EC	2	556	417.0	WEATHER
7/13/2012	2.75	CRESTON	3	1	2.8	ANIMAL
7/13/2012	3.17	SVILLE	4	17	53.9	TREES
7/13/2012	2.83	PHIL	1	38	107.5	MISCELLANEOUS
7/14/2012	1.17	BASS	1	12	14.0	EQUIPMENT MATERIAL FAILURE
7/14/2012	0.83	SVILLE	4	1	0.8	ANIMAL
7/14/2012	1.17	SVILLE	4	1	1.2	TREES
7/15/2012	0.08	COBURG	ALL	2137	171.0	POWER SUPPLY
7/15/2012	2.17	SVILLE	1	11	23.9	MISCELLANEOUS
7/15/2012	1.00	MCK	3	1	1.0	MISCELLANEOUS
7/15/2012	1.08	ML	6	5	5.4	MISCELLANEOUS
7/15/2012	1.42	GARLIN	5	34	48.3	WEATHER CONDITIONS
7/16/2012	1.83	CVILLE	5	3	5.5	TREE
7/16/2012	0.25	COLUMBIA	5	326	81.5	PLANNED
7/16/2012	2.03	COLUMBIA	5	1	2.0	CONSUMER
7/17/2012	1.00	WC	3	2	2.0	MISCELLANEOUS
7/17/2012	1.50	BASS	2	42	63.0	TREES
7/17/2012	25.00	CRESTON	3	1	25.0	MISCELLANEOUS
7/18/2012	1.67	GARLIN	5	9	15.0	WEATHER CONDITIONS

7/18/2012	1.25	PHIL	1	13	16.3	WEATHER CONDITIONS
7/18/2012	0.83	GBURG	4	2	1.7	MISCELLANEOUS
7/19/2012	0.08	COLUMBIA	2	583	46.6	PLANNED
7/19/2012	1.58	COLUMBIA	2	540	853.2	WEATHR CONDITIONS
7/19/2012	1.33	CRESTON	3	28	37.2	WEATHER CONDITIONS
7/19/2012	10.67	GBURG	4	2	21.3	WEATHER CONDITIONS
7/19/2012	2.50	GRP	1	4	10.0	WEATHER
7/19/2012	5.75	ML	1	1	5.8	TREE
7/19/2012	0.58	SVILLE	1	11	6.4	WEATHER CONDITIONS
7/19/2012	0.75	SVILLE	4	29	21.8	WEATHER CONDITIONS
7/19/2012	0.67	GBURG	4	33	22.1	WEATHER CONDITIONS
7/19/2012	1.83	MCK	3	58	106.1	WEATHER CONDITIONS
7/19/2012	2.00	MCK	2	3	6.0	WEATHER CONDITIONS
7/19/2012	1.83	GBURG	6	1	1.8	WEATHER
7/19/2012	6.83	SVILLE	4	1	6.8	WEATHER
7/20/2012	0.08	COLUMBIA	2	583	46.6	PLANNED
7/20/2012	3.18	GARLIN	5	3	9.5	WEATHER CONDITIONS
7/20/2012	2.50	COLUMBIA	2	176	440.0	WEATHER CONDITIONS
7/20/2012	1.00	CRESTON	2	1	1.0	MISCELLANEOUS
7/20/2012	14.08	GBURG	6	3	42.2	WEATHER
7/20/2012	0.50	MCK	1	43	21.5	CONSUMER
7/20/2012	2.42	MCK	1	1	2.4	CONSUMER
7/20/2012	5.75	ML	6	2	11.5	WEATHER
7/20/2012	5.42	GARLIN	3	1	5.4	WEATHER
7/20/2012	3.75	BASS	3	84	315.0	WEATHER
7/20/2012	5.25	CVILLE	5	15	78.8	WEATHER
7/20/2012	4.00	BASS	3	1	4.0	WEATHER
7/20/2012	5.50	COBURG	2	15	82.5	WEATHER
7/20/2012	0.83	BASS	3	1	0.8	WEATHER
7/20/2012	3.75	CVILLE	3	7	26.3	WEATHER
7/20/2012	5.00	COBURG	2	8	40.0	WEATHER
7/20/2012	2.25	COBURG	2	3	6.8	WEATHER
7/20/2012	1.08	GARLIN	3	5	5.4	WEATHER
7/20/2012	1.67	CVILLE	2	8	13.4	WEATHER
7/20/2012	2.33	BASS	3	1	2.3	WEATHER
7/20/2012	1.00	EC	3	10	10.0	WEATHER
7/20/2012	3.42	BASS	3	36	123.1	WEATHER
7/20/2012	4.58	GBURG	6	7	32.1	WEATHER
7/20/2012	0.67	COBURG	3	2	1.3	MISCELLANEOUS

7/21/2012	2.00	BASS	3	80	160.0	MISCELLANEOUS
7/22/2012	0.75	EC	3	10	7.5	ANIMAL
7/22/2012	1.00	PHIL	3	1	1.0	WEATHER
7/23/2012	1.00	COBURG	2	13	13.0	MISCELLANEOUS
7/23/2012	0.42	COBURG	4	39	16.4	CONSUMER
7/23/2012	4.00	COBURG	4	2	8.0	CONSUMER
7/24/2012	0.40	GRP	3	1	0.4	CONSUMER
7/24/2012	2.50	SVILLE	4	1	2.5	WEATHER CONDITIONS
7/24/2012	1.15	SVILLE	1	31	35.7	WEATHER
7/24/2012	6.00	SVILLE	3	5	30.0	WEATHER
7/25/2012	0.50	MCK	2	3	1.5	ANIMAL
7/25/2012	3.33	MCK	2	2	6.7	TREES
7/25/2012	0.50	COBURG	2	17	8.5	MISCELLANEOUS
7/25/2012	0.45	GBURG	4	1	0.5	EQUIPMENT MATERIAL FAILURE
7/26/2012	1.33	GARLIN	3	26	34.6	TREES
7/27/2012	3.00	ML	3	1	3.0	WEATHER
7/27/2012	1.08	COLUMBIA	3	95	102.6	MISCELLANEOUS
7/27/2012	1.58	EC	1	1	1.6	EQUIPMENT MATERIAL FAILURE
7/27/2012	10.50	BASS	1	1	10.5	EQUIPMENT MATERIAL FAILURE
7/27/2012	1.17	CRESTON	1	35	41.0	MISCELLANEOUS
7/27/2012	0.50	EC	3	10	5.0	ANIMAL
7/28/2012	0.67	COBURG	3	81	54.3	WEATHER CONDITIONS
7/28/2012	1.17	CRESTON	1	5	5.9	MISCELLANEOUS
7/28/2012	2.33	PHIL	1	38	88.5	WEATHER CONDITIONS
7/28/2012	13.50	GRP	2	1	13.5	WEATHER
7/28/2012	4.67	BASS	3	47	48.0	WEATHER
7/28/2012	4.00	CVILLE	5	14	56.0	WEATHER
7/28/2012	11.00	ML	6	1	11.0	WEATHER
7/28/2012	1.00	GBURG	6	32	32.0	EQUIPMENT MATERIAL FAILURE
7/28/2012	4.00	ML	6	31	124.0	WEATHER
7/28/2012	12.25	EC	2	1	12.3	WEATHER
7/29/2012	3.50	CRESTON	3	21	73.5	TREES
7/29/2012	1.25	ML	1	1	1.3	ANIMAL
7/30/2012	0.50	CVILLE	4	1	0.5	WEATHER
7/30/2012	0.42	ML	1	50	21.0	ANIMAL
7/30/2012	0.33	ML	2	33	10.9	ANIMAL
7/30/2012	0.83	COBURG	4	39	32.4	TREES
7/31/2012	1.33	WC	2	2	2.7	OVERLOAD
8/1/2012	1.50	GBURG	6	7	10.5	EQUIPMENT MATERIAL FAILURE

8/1/2012	5.80	GARLIN	5	15	87.0	CONSUMER
8/3/2012	0.75	GBURG	5	1	0.8	WEATHER CONDITIONS
8/3/2012	1.08	ML	3	3	3.2	TREES
8/3/2012	1.00	COLUMBIA	5	95	95.0	ANIMAL
8/3/2012	1.50	MCK	1	3	4.5	CONSUMER
8/4/2012	2.17	CRESTON	3	17	36.9	TREES
8/4/2012	1.42	ML	6	10	14.2	WEATHER
8/4/2012	0.75	EC	1	5	3.8	WEATHER
8/4/2012	8.25	GBURG	6	1	8.3	WEATHER
8/4/2012	1.17	SVILLE	4	85	99.5	WEATHER CONDITIONS
8/4/2012	3.00	ML	1	1	3.0	EQUIPMENT MATERIAL FAILURE
8/5/2012	2.83	GARLIN	5	18	50.9	WEATHER
8/5/2012	2.17	GARLIN	2	31	67.3	WEATHER CONDITIONS
8/5/2012	0.58	COLUMBIA	2	8	4.6	WEATHER CONDITIONS
8/5/2012	1.33	GARLIN	5	2	2.7	WEATHER CONDITIONS
8/5/2012	1.17	GARLIN	5	1	1.2	WEATHER CONDITIONS
8/5/2012	1.50	COLUMBIA	4	2	3.0	EQUIPMENT MATERIAL FAILURE
8/5/2012	1.33	GBURG	6	11	14.6	WEATHER CONDITIONS
8/5/2012	4.42	GBURG	3	1	4.4	WEATHER
8/5/2012	2.42	GBURG	6	1	2.4	WEATHER CONDITIONS
8/5/2012	2.42	BASS	1	107	258.9	EQUIPMENT MATERIAL FAILURE
8/6/2012	2.00	COBURG	2	1	2.0	MISCELLANEOUS
8/6/2012	0.75	ML	3	2	1.5	MISCELLANEOUS
8/6/2012	2.33	COLUMBIA	4	1	2.3	WEATHER CONDITIONS
8/6/2012	3.75	COBURG	3	1	3.8	WEATHER CONDITIONS
8/6/2012	0.75	COBURG	2	3	2.3	MISCELLANEOUS
8/6/2012	0.67	GARLIN	2	6	4.0	MISCELLANEOUS
8/7/2012	0.50	SVILLE	2	1	0.5	MISCELLANEOUS
8/8/2012	0.42	GRP	1	1	0.4	MISCELLANEOUS
8/8/2012	0.92	BASS	3	80	73.6	CONSUMER
8/8/2012	2.25	BASS	3	2	4.5	CONSUMER
8/9/2012	0.42	EC	3	10	4.2	MISCELLANEOUS
8/10/2012	1.00	PHIL	3	1	1.0	EQUIPMENT MATERIAL FAILURE
8/10/2012	1.25	SVILLE	1	1	1.3	EQUIPMENT MATERIAL FAILURE
8/11/2012	0.75	COBURG	2	1	0.8	MISCELLANEOUS
8/12/2012	0.75	CVILLE	3	1	0.8	ANIMAL
8/13/2012	3.42	GARLIN	3	1	3.4	TREES
8/14/2012	0.67	BASS	3	1	0.7	CONSUMER
8/14/2012	3.25	EC	2	1	3.3	EQUIPMENT MATERIAL FAILURE

8/15/2012	1.00	CRESTON	1	34	34.0	ANIMAL
8/16/2012	1.00	EC	1	1	1.0	EQUIPMENT MATERIAL FAILURE
8/17/2012	1.25	GRP	1	1	1.3	EQUIPMENT MATERIAL FAILURE
8/18/2012	1.00	WC	ALL	1719	1719.0	POWER SUPPLY
8/18/2012	0.50	SVILLE	3	5	2.5	ANIMAL
8/19/2012	0.75	ML	5	30	22.5	ANIMAL
8/19/2012	1.00	EC	3	10	10.0	ANIMAL
8/20/2012	1.42	CVILLE	5	14	19.9	EQUIPMENT MATERIAL FAILURE
8/20/2012	0.83	CRESTON	1	34	28.2	MISCELLANEOUS
8/22/2012	0.87	GRP	3	1	0.9	MISCELLANEOUS
8/25/2012	1.00	SVILLE	1	7	7.0	MISCELLANEOUS
8/25/2012	0.58	COBURG	2	13	7.5	MISCELLANEOUS
8/25/2012	0.75	ML	2	1	0.8	EQUIPMENT MATERIAL FAILURE
8/26/2012	0.58	ML	3	2	1.2	ANIMAL
8/27/2012	0.92	BASS	3	1	0.9	ANIMAL
8/27/2012	2.33	EC	1	45	104.9	EQUIPMENT MATERIAL FAILURE
8/28/2012	0.83	EC	2	55	45.7	WEATHER
8/29/2012	0.42	PHIL	3	1	0.4	EQUIPMENT MATERIAL FAILURE
8/30/2012	1.00	ML	2	1	1.0	EQUIPMENT MATERIAL FAILURE
8/30/2012	3.33	GBURG	6	1	3.3	CONSUMER
8/31/2012	3.00	COLUMBIA	6	1	3.0	PLANNED
9/1/2012	2.33	GRP	1	1	2.3	EQUIPMENT MATERIAL FAILURE
9/1/2012	0.50	EC	3	2	1.0	OVERLOAD
9/1/2012	0.25	SVILLE	1	1	0.3	MISCELLANEOUS
9/2/2012	0.58	CVILLE	3	3	1.7	EQUIPMENT MATERIAL FAILURE
9/2/2012	2.00	PHIL	1	38	76.0	MISCELLANEOUS
9/2/2012	0.75	MCK	2	21	15.8	MISCELLANEOUS
9/3/2012	1.10	SVILLE	2	1	1.1	WEATHER
9/3/2012	2.17	BASS	3	83	180.1	TREE
9/3/2012	0.33	SVILLE	1	1	0.3	ANIMAL
9/4/2012	0.50	COLUMBIA	6	1	0.5	EQUIPMENT MATERIAL FAILURE
9/5/2012	0.50	ML	3	6	3.0	EQUIPMENT MATERIAL FAILURE
9/5/2012	24.00	MCK	2	1	24.0	CONSUMER
9/5/2012	0.05	COLUMBIA	6	1	0.1	PLANNED
9/5/2012	0.92	COLUMBIA	5	120	110.4	WEATHER CONDITIONS
9/7/2012	0.67	CRESTON	3	3	2.0	ANIMAL
9/8/2012	3.33	SVILLE	4	1	3.3	EQUIPMENT MATERIAL FAILURE
9/8/2012	4.00	COLUMBIA	5	1	4.0	TREE
9/8/2012	1.00	COLUMBIA	5	45	45.0	WEATHER



9/8/2012	4.33	COLUMBIA	5	2	8.7	WEATHER CONDITIONS
9/8/2012	3.00	COLUMBIA	6	1	3.0	PLANNED
9/8/2012	1.08	COBURG	2	16	17.3	MISCELLANEOUS
9/8/2012	2.50	PHIL	1	38	95.0	EQUIPMENT MATERIAL FAILURE
9/9/2012	1.83	PHIL	3	1	1.8	EQUIPMENT MATERIAL FAILURE
9/9/2012	0.42	COLUMBIA	4	2	0.8	MISCELLANEOUS
9/10/2012	4.00	GARLIN	3	8	32.0	MISCELLANEOUS
9/11/2012	1.58	COBURG	2	10	15.8	ANIMAL
9/11/2012	1.58	CRESTON	3	3	4.7	ANIMAL
9/11/2012	2.00	GBURG	4	11	22.0	ANIMAL
9/12/2012	0.50	SVILLE	4	2	1.0	MISCELLANEOUS
9/16/2012	1.42	CRESTON	1	34	48.3	ANIMAL
9/18/2012	3.08	GARLIN	4	22	67.8	EQUIPMENT MATERIAL FAILURE
9/21/2012	1.50	ML	3	5	7.5	ANIMAL
9/21/2012	0.50	EC	3	6	3.0	ANIMAL
9/23/2012	1.00	COBURG	1	24	24.0	MISCELLANEOUS
9/23/2012	3.00	COBURG	1	1	3.0	EQUIPMENT MATERIAL FAILURE
9/23/2012	1.17	COBURG	1	24	28.1	EQUIPMENT MATERIAL FAILURE
9/23/2012	24.67	SVILLE	4	2	49.3	CONSUMER
9/23/2012	1.00	BASS	3	1	1.0	MISCELLANEOUS
9/23/2012	2.50	PHIL	1	1	2.5	EQUIPMENT MATERIAL FAILURE
9/24/2012	0.75	CVILLE	3	1	0.8	CONSUMER
9/25/2012	2.58	ML	4	1	2.6	WEATHER CONDITIONS
9/25/2012	1.00	CRESTON	3	38	38.0	WEATHER CONDITIONS
9/25/2012	1.00	BASS	1	107	107.0	WEATHER CONDITIONS
9/25/2012	0.58	CRESTON	3	4	2.3	WEATHER CONITIONS
9/25/2012	1.00	GRP	3	84	84.0	WEATHER
9/25/2012	2.00	PHIL	2	1	2.0	WEATHER
9/26/2012	0.62	GRP	1	27	16.7	WEATHER
9/26/2012	1.00	COLUMBIA	3	2	2.0	MISCELLANEOUS
9/27/2012	2.33	ML	1	1	2.3	EQUIPMENT MATERIAL FAILURE
9/27/2012	0.33	COLUMBIA	2	13	4.3	MISCELLANEOUS
9/28/2012	0.42	EC	1	7	2.9	ANIMAL
9/29/2012	2.00	PHIL	2	47	94.0	TREES
9/29/2012	1.00	BASS	2	1	1.0	EQUIPMENT MATERIAL FAILURE
9/29/2012	13.33	ML	5	3		EQUIPMENT MATERIAL FAILURE
10/1/2012	0.50	CVILLE	3	23	11.5	TREE
10/5/2012	1.08	ML	3	2	2.2	ANIMAL
10/6/2012	24.00	WC	2	1	24.0	CONSUMER

10/7/2012	0.03	WC	3	464	13.9	EQUIPMENT
10/7/2012	0.17	GARLIN	3	10	1.7	ANIMAL
10/8/2012	1.58	MCK	1	1	1.6	EQUIPMENT MATERIAL FAILURE
10/10/2012	0.50	COLUMBIA	1	1	0.5	MISCELLANEOUS
10/11/2012	0.50	SVILLE	2	1	2.0	ANIMAL
10/11/2012	1.42	WC	2	2	2.8	MISCELLANEOUS
10/11/2012	0.83	ML	2	2	1.7	ANIMAL
10/11/2012	3.00	WC	3	1	3.0	EQUIPMENT MATERIAL FAILURE
10/12/2012	0.50	EC	3	17	8.5	MISCELLANEOUS
10/14/2012	0.67	EC	5	55	36.9	WEATHER
10/14/2012	1.33	CVILLE	3	74	98.4	MISCELLANEOUS
10/15/2012	0.42	COBURG	2	59	24.8	TREE
10/15/2012	0.83	SVILLE	4	27	22.4	EQUIPMENT MATERIAL FAILURE
10/15/2012	0.42	ML	5	18	7.6	TREE
10/16/2012	0.42	CVILLE	3	7	2.9	MISCELLANEOUS
10/16/2012	1.00	GARLIN	3	8	8.0	MISCELLANEOUS
10/17/2012	0.50	ML	5	18	9.0	ANIMAL
10/18/2012	0.83	MCK	3	1	0.8	WEATHER
10/19/2012	1.25	GBURG	6	43	53.8	CONSUMER
10/19/2012	4.25	GBURG	6	6	25.5	CONSUMER
10/20/2012	0.75	SVILLE	2	2	1.5	ANIMAL
10/21/2012	1.00	GBURG	4	38	38.0	MISCELLANEOUS
10/23/2012	0.83	SVILLE	2	2	1.7	ANIMAL
10/26/2012	2.50	BASS	2	104	260.0	ANIMALS
10/29/2012	0.63	MCK	1	28	17.6	MISCELLANEOUS
10/29/2012	1.58	GARLIN	5	12	19.0	MISCELLANEOUS
10/29/2012	0.83	GARLIN	5	77	63.9	MISCELLANEOUS
10/29/2012	0.83	GBURG	4	11	9.1	MISCELLANEOUS
10/30/2012	0.50	CRESTON	1	113	56.5	TREES
10/31/2012	1.50	CRESTON	3	43	64.5	MISCELLANEOUS
11/3/2012	1.33	CRESTON	3	1	1.3	ANIMAL
11/6/2012	0.03	MCK	2	16	0.4	MISCELLANEOUS
11/6/2012	0.50	SVILLE	3	1	0.5	ANIMAL
11/6/2012	1.62	MCK	2	30	48.6	MISCELLANEOUS
11/8/2012	0.92	BASS	2	9	8.3	ANIMAL
11/10/2012	1.50	CRESTON	3	2	3.0	CONSUMER
11/11/2012	2.00	GARLIN	3	1	2.0	TREES
11/12/2012	1.50	GRP	1	1	1.5	ANIMAL
11/13/2012	0.17	GBURG	4	1	0.2	ANIMAL

11/13/2012	0.83	GRP	1	1	0.8	EQUIPMENT/MATERIAL FAILURE
11/14/2012	0.37	CRESTON	1	1	0.4	EQUIPMENT MATERIAL FAILURE
11/15/2012	0.50	EC	5	2	1.0	ANIMAL
11/18/2012	0.58	COLUMBIA	2	13	7.5	MISCELLANEOUS
11/18/2012	0.92	COBURG	1	1	0.9	EQUIPMENT MATERIAL FAILURE
11/18/2012	0.92	COBURG	1	1	0.9	MISCELLANEOUS
11/20/2012	0.50	GBURG	6	1	0.5	ANIMAL
11/20/2012	0.83	COLUMBIA	2	13	10.8	ANIMAL
11/20/2012	1.92	WC	2	65	124.8	ANIMAL
11/21/2012	0.33	GBURG	4	38	12.5	ANIMAL
11/22/2012	3.50	COLUMBIA	2	36	126.0	EQUIPMENT MATERIAL FAILURE
11/26/2012	1.03	EC	1	1	1.0	EQUIPMENT MATERIAL FAILURE
12/1/2012	2.08	EC	3	2	4.2	EQUIPMENT MATERIAL FAILURE
12/4/2012	0.83	GARLIN	3	1	0.8	TREES
12/5/2012	0.67	SVILLE	1	3	2.0	ANIMAL
12/10/2012	3.00	BASS	1	108	324.0	WEATHER
12/10/2012	2.00	MCK	2	1	2.0	TREES
12/12/2012	2.33	MCK	1	1	2.3	EQUIPMENT MATERIAL FAILURE
12/12/2012	0.42	CRESTON	3	1	0.4	EQUIPMENT MATERIAL FAILURE
12/13/2012	0.19	GRP	3	344	65.4	EQUIPMENT MATERIAL FAILURE
12/13/2012	3.45	GRP	3	1	3.5	EQUIPMENT MATERIAL FAILURE
12/14/2012	1.17	SVILLE	4	17	19.9	MISCELLANEOUS
12/14/2012	2.00	COBURG	1	1	2.0	EQUIPMENT MATERIAL FAILURE
12/15/2012	0.42	BASS	3	842	353.6	MISCELLANEOUS
12/17/2012	1.50	EC	3	1	1.5	MISCELLANEOUS
12/17/2012	2.00	EC	3	1	2.0	WEATHER
12/17/2012	1.00	PHIL	1	1	1.0	WEATHER CONDITIONS
12/18/2012	2.00	BASS	3	2	4.0	EQUIPMENT MATERIAL FAILURE
12/18/2012	2.00	CRESTON	3	1	2.0	EQUIPMENT MATERIAL FAILURE
12/19/2012	0.50	GBURG	5	1	0.5	CONSUMER
12/20/2012	2.33	COLUMBIA	2	40	93.2	TREES
12/20/2012	0.92	GBURG	4	11	10.1	WEATHER
12/20/2012	1.15	GRP	1	1	1.2	WEATHER
12/20/2012	0.58	SVILLE	1	2	1.2	MISCELLANEOUS
12/20/2012	1.50	PHIL	5	1	1.5	EQUIPMENT MATERIAL FAILURE
12/20/2012	2.00	CRESTON	3	64	128.0	WEATHER CONDITIONS
12/20/2012	1.00	ML	1	5	5.0	WEATHER
12/20/2012	2.42	MCK	3	1	2.4	TREES
12/20/2012	0.58	COLUMBIA	5	510	295.8	WEATHER

12/20/2012	<b>1.25</b>	COLUMBIA	5	<b>37</b>	46.3
12/20/2012	<b>1.08</b>	CRESTON	3	<b>47</b>	50.8
12/20/2012	<b>1.15</b>	EC	2	<b>15</b>	17.3
12/20/2012	<b>1.75</b>	COLUMBIA	5	<b>66</b>	115.5
12/20/2012	<b>0.33</b>	SVILLE	4	<b>882</b>	291.1
12/20/2012	<b>1.33</b>	SVILLE	4	<b>168</b>	223.4
12/20/2012	<b>0.75</b>	SVILLE	2	<b>1</b>	0.8
12/21/2012	<b>2.33</b>	EC	5	<b>1</b>	2.3
12/21/2012	<b>1.00</b>	CVILLE	3	<b>1</b>	1.0
12/21/2012	<b>0.50</b>	EC	2	<b>2</b>	1.0
12/26/2012	<b>0.57</b>	GRP	1	<b>29</b>	16.5
12/26/2012	<b>1.00</b>	CRESTON	3	<b>4</b>	4.0
12/26/2012	<b>1.50</b>	CVILLE	2	<b>1</b>	1.5
12/26/2012	<b>0.42</b>	COLUMBIA	4	<b>69</b>	29.0
12/29/2012	<b>2.67</b>	WC	2	<b>1</b>	2.7
12/29/2012	<b>0.83</b>	COBURG	4	<b>2</b>	1.7

TREES  
WEATHER CONDITIONS  
WEATHER  
WEATHER  
MISCELLANEOUS  
MISCELLANEOUS  
MISCELLANEOUS  
EQUIPMENT MATERIAL FAILURE  
TREE  
WEATHER  
EQUIPMENT MATERIAL FAILURE  
MISCELLANEOUS  
TREE  
MISCELLANEOUS  
OVERLOAD  
OVERLOAD