

February 4, 2015

RECEIVED

FEB 6 2015

PUBLIC SERVICE COMMISSION

Mr. Jeff Derouen
Executive Director
Kentucky Public Service Commission
211 Sower Boulevard
P.O. Box 615
Frankfort, Kentucky 40602-0615

RE: Post-Case Correspondence – In the Matter of the Application of East Kentucky Power Cooperative, Inc. for an Order Declaring the Maysville-Mason County Landfill Gas to Energy Project to be an Ordinary Extension of Existing Systems in the Usual Course of Business, Case No. 2007-00509 (Ky. P.S.C., Mar. 28, 2008)

Dear. Mr. DeRouen:

Since May 2009, East Kentucky Power Cooperative, Inc. ("EKPC") has operated the Maysville-Mason County Renewable Energy Plant, a landfill gas-to-energy ("LFGTE") plant at the Maysville-Mason County Landfill (the "Mason County LFGTE Plant"). The plant is one of 6 LFGTE plants in the EKPC fleet that are currently capable of producing a total of 14.4 Megawatts ("MW") of electric power. The Mason County LFGTE Plant was designed to have a capacity of 1.6 MW, however, despite EKPC's best efforts, including a swap-out of the generator in 2010, the output of the plant was consistently less than 200 kilowatts ("kW") due to an unsustainable flow of landfill gas from the Maysville-Mason County Landfill. Subsequently, the unit was taken offline in early 2012.

On February 2, 2015, EKPC gave notice to the Mason County Fiscal Court and the City of Maysville that it was terminating the agreements associated with the Mason County LFGTE Plant. It is currently anticipated that all of the generating equipment at the Mason County LFGTE Plant will be transported to, and reused at, either EKPC's Bavarian LFGTE site or at the Glasgow LFGTE site that is being developed. Thus, EKPC expects the equipment to remain in service within the EKPC system. The structure that housed the generator and other equipment at the landfill will remain in place and become the property of the Mason County Fiscal Court, thereby saving EKPC the expenses associated with demolishing the structure.

If you have any further questions, please do not hesitate to contact me.

Sincerely,

Patrick C. Wood

PCW/gw