

SHEEHAN, BARNETT, DEAN,
PENNINGTON, LITTLE & DEXTER, P.S.C.

d/b/a THE DANVILLE LAW GROUP
ATTORNEYS AT LAW
111 SOUTH FOURTH STREET
P.O. BOX 1517
DANVILLE, KENTUCKY 40423-1517

Telephone (859) 236-2641
Fax Number (859) 236-0081

JAMES WILLIAM BARNETT
JAMES HADDEN DEAN
HENRY VINCENT PENNINGTON, III
RAMONA CASTELLVI LITTLE
STEPHEN ABELL DEXTER

OF COUNSEL
ELIZABETH NICKELS LENN

RETIRED
JAMES G. SHEEHAN, JR

February 1, 2012

RECEIVED

FEB 02 2012

PUBLIC SERVICE
COMMISSION

Mr. Jeff Derouen
Executive Director
Public Service Commission
211 Sower Boulevard
Frankfort, KY 40602


RE: Public Contact Case No. 2011-00280

Dear Mr. Derouen:

Pursuant to the order entered on November 7, 2011, I am enclosing an original and one copy of the required documents in keeping with compliance with that order.

If you have any questions, please contact me.

Very truly yours,



HON. J. HADDEN DEAN

JHD/ebs
Enclosures
CC: L. Allyson Honaker
Jim Jacobus



A Touchstone Energy Cooperative 

RECEIVED

FEB 02 2012

PUBLIC SERVICE
COMMISSION

PSC Case No. 2011-00280

**In The Matter Of
Inter-County Energy Cooperative Corporation
Alleged Failure to Comply With KRS 278.042**

February 1, 2012

P. O. Box 87 • Danville, KY 40423-0087 • (859) 236-4561

INTER-COUNTY ENERGY COOPERATIVE

P. O. Box 87 • Danville, KY 40423-0087

Case No. 2011-00280

CONTENT

EXHIBIT 1

Pursuant to the November 7, 2011 Order, page 4, paragraph 6, within 30 days of the Order, Inter-County shall provide a summary report to the Commission of the system-wide inspection performed as a result of this incident. The report shall contain all potential violations found including this type of violation, the curative action taken and the timeframe in which they were corrected.

Inter-County Energy Potential Clearance Findings and Corrections

Updated Response – February 1, 2012

EXHIBIT 2

Pursuant to the November 7, 2011 Order, page 4, paragraph 8, beginning with the December 2011 issue, Inter-County shall provide information in each issue of its monthly magazine distributed to all customers regarding safety. At least once per year, Inter-County will provide specific information in the magazine on clearance issues. Inter-County shall file a copy of each monthly magazine with the Commission beginning with the December 2011 issue.

Kentucky Living – February 2012

- Page 30C
- Page 30F
- Page 52

Inter-County Energy - Clearance Findings and Corrections 2/1/2012

WO #	STAKED DATE	MEMBER NAME	CLEARANCE ISSUE	DESCRIPTION	COUNT	COMPLETION
110383	5/2/2011	James Coffey	Neutral 8' over grain bin	Changed OH to UG primary	Lincoln	5/27/2011
110505	5/24/2011	James Beeler	Primary 10' from grain bin	Install 50' Pole and shorten Primary Tap	Casey	6/2/2011
110475	5/13/2011	Lyndal Mattingly	Phase 2' inside clearance window	Moved Phase to new cross arm	Nelson	6/13/2011
110499	5/23/2011	Floyd Rowe	Neutral 3' over grain bin	Rerouted 500' Primary away from Grain bins	Lincoln	6/24/2011
110500	5/23/2011	Old Railroad Bed Rd	Primary line 10' inside vertical window at 28' away	Insall 55' Pole and shorten Primary Tap	Garrard	6/24/2011
110476	5/13/2011	William Peterson	Primary line over fuel storage tanks	Relocated 307' of primary	Marion	7/12/2011
110372	4/27/2011	Kay Hale	Line over swimming pool / Pool removed after line move	Relocated 118' of primary line	Lincoln	7/21/2011
110657	7/7/2011	Thomas Martin Mattingly	Over head service to close/ changed to underground	Replaced OH service with UG service	Marion	8/1/2011
110474	5/13/2011	Cloyd Brady	Line at 15' of grain bin	Install new pole and relocate primary	Marion	9/28/2011
110611	6/22/2011	Bill & Susan Mattingly	Line at 8' of grain bin	Relocate 312' of OH primary	Marion	9/28/2011
110655	7/7/2011	Joseph Buckman	Primary line close to grain bins	Change out pole and move away from Grain bin	Marion	9/28/2011
110349	4/19/2011	George Burdine	Primary 12' over barn	Change Pole and add pole in line	Lincoln	5/4/2011
110889	9/6/2011	Peterson Grain Bin	Removed OH prim Installed URD prim for clearance	URD Primary to Padmount Xfmer for grain bins	Marion	9/19/2011
110968	9/29/2011	Danny Gentry	Primary line close to grain bins	add pole and reroute line away from grain bin	Laurue	10/4/2011
110655	7/7/2011	Joseph Buckman	Primary line close to grain bins	Change out pole and move away from Grain bin	Marion	9/27/2011
110977	9/30/2011	Katherine Peake	Primary line close to grain bins	Reroute primary line away from grain bins	Marion	10/5/2011
110349	4/19/2011	George Burdine	Clearance issue	Relocate primary close to grain bin	Lincoln	5/2/2011
111068	10/25/2011	Timothy Miller	Rd clearance issue	Add pole in line for rd clearance	Lincoln	11/2/2011
111037	10/18/2011	John Thompson	Clearance issue at grain bin	Move primary line away from grain bin	Marion	11/8/2011
111069	10/25/2011	W C Brogle	Clearance issue at grain bin	Move primary line away from grain bin	Lincoln	11/8/2011
110986	10/4/2011	Thompson Drive	Clearance issue over road	Change out poles for clearance	Marion	11/3/2011
111037	10/18/2011	Hourigan Lane	Clearance issue at grain bin	Changed 1-35' & 1-40' pole to 2-60' poles	Marion	11/8/2011
111069	10/25/2011	Norris Rd	Clearance issue at grain bin	Relocated 393' of primary	Lincoln	11/9/2011
111072	10/26/2011	Makers Mark	Clearance from wall on a recently built addition	Reroute 3 phase from building for clearance	Marion	1/4/2012
111306	1/3/2012	Norman Robbins	Low Service	Rerouted service	Marion	1/5/2012
111307	1/3/2012	Marcus Clark	Low Service	Rerouted service	Marion	1/3/2012
110987	10/4/2011	David Sandusky	Low Service	Changed out 2 poles for clearance	Marion	11/10/2011
111113	11/7/2011	Airport Rd	Clearance issue at junk yard	Changed out two poles for clearance	Boyle	11/10/2011
111147	11/14/2011	Dewey Coffey	Clearance issue at grain bin	Changed out two poles for clearance	Casey	11/30/2011
111149	11/14/2011	Dewey Coffey	Clearance issue at grain bin	Changed out 2 poles for clearance	Casey	12/5/2011
111162	11/11/2011	J W Brogle	Clearance issue at grain bin	Move primary line and change svc to urd	Garrard	12/12/2011
111268	12/14/2011	Farris Rd	Clearance issue	Retire 3 phase and relocate single phase	Marion	12/16/2011
111307	1/3/2012	Marcus Clark	Clearance issue	Change pole for clearance on svc wire	Marion	1/3/2012
111259	12/13/2011	Terry Cecil	Clearance issue	Add pole in line and reroute svc for clearance	Nelson	1/3/2012
111223	12/7/2011	Sugar Creek Rd	Grain Bin Clearance	Change out 2 poles for clearance at grain bin	Garrard	1/4/2012
111306	1/3/2012	Jimmy Devine Rd.	Low svc	Add 30-6 pole in line for clearance	Marion	1/5/2012
120019	1/6/2012	Alfred O'Daniel	Driveway Clearance	Added 40-4 pole in line for clearance	Marion	1/19/2012

INTER-COUNTY ENERGY COOPERATIVE'S

Kentucky Living

CELEBRATING THE ENERGY
OF YOUR COMMUNITY

CAREER CREATION

How internships
get students started

COLLEGE PREVIEW ISSUE

- *The Kentucky Living* 2012 College Guide
- Alternatives to the 4-year degree

CHASING CUPID

Get away advice from
romance writers

EXHIBIT 2

Reference Pages:

30C – 30F – 52