

FOR Entire Territory Served

P.S.C. Ky. No. 4

1st Revised Sheet No. 8

Cancelling P.S.C. Ky. No. 4

Original Sheet No. 8

South Kentucky R.E.C.C.  
Somerset, Kentucky

**RULES AND REGULATIONS**

- B. City water piping system must be used for service grounding when available plus standard driven ground. (Watch for plastic pipe.)
- C. All grounds other than the water system are to be of 3/4" galvanized water pipe equipped with a driving point.
- D. Any deviations from above requirement must be approved by the Manager of the Cooperative.

**5. Service To House Trailer**

- A. To secure service for a house trailer, a satisfactory contract must be negotiated between the Cooperative and the person requesting service before any installation is made.
- B. Service shall be provided to a Mobile Home for an installation charge of \$25.00 plus the regular membership fee of \$10.00. This installation charge will include installing a 25' class 7 creosoted pole located near the mobile home on which the service entrance is to be located.
- C. Where more than 1,000 feet of line is necessary, the member may enter into a 5-year contract with the Cooperative to pay 25¢ monthly for each additional 100 feet of line required. (KWH will be allotted for the increased minimum bill.)
- D. If Mobile Home is located where service equipment can be installed on an existing service pole, no installation charge is to be made.
- E. Mobile Home installations requiring a 150 amp or 200 amp Service Entrance are not to be charged the \$25 Installation Fee for the first installation only.
- F. All Service Entrances shall meet the National Electrical Code and South Kentucky RECC requirements before energizing.
- G. All fees or charges are to be paid in advance.

**21. Inspection**

All consumers' wiring must be inspected for compliance with the National Electric Code by an inspector approved by the Cooperative before connection for service by the Cooperative. Fee for such inspection shall be paid at the Cooperative's Office.

When any of the employees of the Cooperative have notice or observe that the wiring in any building, to which electric energy is served by the Cooperative, is in a condition so as to be dangerous to persons or property such employees shall immediately notify the Manager of the Cooperative of such dangerous condition. If the Manager upon investigation determines that such dangerous conditions exists, he may at once have the service to

**CHECKED**  
 PUBLIC SERVICE COMMISSION  
 DEC 17 1970  
*ESC*  
 ENGINEERING DIVISION

DATE OF ISSUE July 27 1970      DATE EFFECTIVE January 1 1971  
 Month      Day      Year                      Month      Day      Year

ISSUED BY *Sam Howard*      Manager      Somerset, Kentucky  
 Name of Officer                      Title                      Address