

FOR Grayson County, Kentucky  
Community, Town or City

**CANCELLED**  
  
July 3, 2022  
  
**KENTUCKY PUBLIC  
SERVICE COMMISSION**

Grayson County Water District  
(Name of Utility)

P.S.C. KY. NO. \_\_\_\_\_  
Original SHEET NO. 36  
CANCELING P.S.C. KY. NO. \_\_\_\_\_  
SHEET NO. \_\_\_\_\_

RULES AND REGULATIONS

2. In areas where the distribution system follows well-defined streets and roads, the customer's point of service will be located at that point on or near the street right-of-way or property line most accessible to the utility from its distribution system. In areas where the distribution system does not follow streets and roads, the point of service will be located as near the customer's property line as practicable. Prior to installation of the meter the utility will consult with the customer as to the most practical location. If possible meters will be installed within 5 feet of the existing water main or the applicant's property at a point which his closest to the existing water main.
3. Depth of service line. All service lines must be laid at a sufficient depth (a minimum of 24 inches) to prevent freezing during the coldest weather normally experienced except where services are not intended for use during freezing weather and are actually drained during such periods.
4. A plumbing permit from the appropriate regulatory agency is required before the utility can establish service.
5. The applicant/customer must furnish and lay the necessary pipe to make the connection from the point of service to the point of usage and be financially responsible for all costs associated with the installation and maintenance of his/her service line plumbing, including a shut-off valve and one-way check valve, installed on his/her property beginning at the outlet side of the water meter. The service line must be kept in good repair and in accordance with utility and Public Service Commission rules and regulations.
6. The installation and maintenance of the water service line must be in accordance with the rules and regulations of the Kentucky Department of Health.
7. A cross-connection of the utility's system with any other source is strictly prohibited.

DATE OF ISSUE August 30, 2005  
Month / Date / Year

DATE EFFECTIVE August 15, 2005  
Month / Date / Year

ISSUED BY *Edwin Nichols*  
(Signature of Officer)

TITLE Chairman

BY AUTHORITY OF ORDER OF THE PUBLIC SERVICE COMMISSION

IN CASE NO. 2004-00511 DATED August 15, 2005

**PUBLIC SERVICE COMMISSION  
OF KENTUCKY  
EFFECTIVE  
8/15/2005  
PURSUANT TO 807 KAR 5:011  
SECTION 9 (1)**

By *[Signature]*  
Executive Director