

FOR Southeastern Marshall County, Kentucky  
Community, Town or City

P.S.C. KY. NO. 1

1<sup>st</sup> Revised SHEET NO. 40

CANCELLING P.S.C. KY. NO. \_\_\_\_\_

SHEET NO. \_\_\_\_\_

Jonathan Creek Water District  
(Name of Utility)

RULES AND REGULATIONS

replacements shall be paid by the customer of the utility and any liability otherwise resulting shall be that of the customer.

4. For purposes of fire protection, including any customer's fire protection system, the utility cannot guarantee a water supply at any particular flow rate or pressure. The fire flow may vary depending upon other water demands on the system, various water facility limitations, or other circumstances. The customer will indemnify and hold harmless the utility and its employees from and against all claims, damages, losses, and expenses incurred as a result of insufficient water supply or deficient system facilities. The District's system is not designed nor intended for fire protection in any manner whatsoever. Any customer using same for fire protection does so at their own full and sole responsibility.

*C 12/15/10*  
AA. Fire Departments. For the purpose of off-setting fifty percent or more of its operation expenses, any fire department not receiving public funds from the Commonwealth of Kentucky, or any political subdivision thereof, may withdraw water from the utility's facilities at no charge, for the extinguishing of fires or the training of firemen. A fire department making such withdrawals shall provide an estimate of its withdrawals to the utility at the end of each month.

AB. Fire Hydrants:

1. In accordance with 807 KAR 5:066 Section 10(2)(b), a new fire hydrant will not be installed unless:
  - a) A professional engineer with a Kentucky registration has certified that the system can provide a minimum fire flow of 250 gallons per minute, and
  - b) The system supporting this flow has the capability of providing this flow for a period of not less than two (2) hours plus consumption at the maximum daily rate.
2. The location, installation, and the responsibility for maintenance of fire hydrants, public and private fire protection facilities, connecting mains, and their ownership may be subject to

DATE OF ISSUE \_\_\_\_\_  
Month / Date / Year

DATE EFFECTIVE \_\_\_\_\_  
Month / Date / Year

ISSUED BY *Dean Kowalski*  
(Signature of Officer)

TITLE *Chairman*

BY AUTHORITY OF ORDER OF THE PUBLIC SERVICE COMMISSION  
IN CASE NO. \_\_\_\_\_ DATED \_\_\_\_\_

PUBLIC SERVICE COMMISSION  
OF KENTUCKY  
EFFECTIVE

JUN 19 2002

PURSUANT TO 807 KAR 5:011.  
SECTION 9 (1)

BY *Stanley Bell*  
SECRETARY OF THE COMMISSION