

For Northwestern Portion of Jessamine County

P.S.C. Ky. No. 2

Revised Sheet No. 14

Cancelling P.S.C. Ky. No. 2

Original Sheet No. 14

Lexington-South Elkhorn  
Water District

**RULES AND REGULATIONS**

19. Boilers and/or Pressure Vessels

Customers having boilers and/or pressure vessels receiving a supply of water from the District must have a reduced pressure back-flow preventor and a check valve on the water supply line and a vacuum valve on the stream line to prevent collapse in case the water supply from the District is discontinued or interrupted for any reason, with or without notice. It is the responsibility of the customer to make provisions for protection of his equipment in case of interrupted or intermittent service.

20. Backflow Preventors

All services shall have a means of backflow prevention, such type and location subject to approval of District.

CANCELLED  
DEC 24 2015  
KENTUCKY PUBLIC  
SERVICE COMMISSION

C The District's standard service shall provide said backflow prevention as a part of its service connection. All other services, including but not limited to lawn sprinkler systems, shall have backflow preventors of a type approved by the District and installed at the cost of the customer. Construction of nonpotable water systems or systems carrying any other nonpotable substances shall be such as to prevent backflow or backsiphonage into a potable water system.

21. Cross-Connections/Interconnections

C All cross-connections are hereby prohibited. Plumbing fixtures, devices or appurtenances shall be installed in a manner that will prevent any possibility of a cross-connection between the potable water supply system, drainage system or other water system.

AUG 14 1991

Date of Issue July 15 1991  
Month Day Year

Date Effective August 14 1991  
Month Day Year

Issued By Jerry Haws  
Jerry Haws, Chairman

BY: [Signature]  
200 West Maple, Nicholasville, KY  
Address

PURSUANT TO 807 KAR 5:011,  
SECTION 1  
EFFECTIVE  
PUBLIC SERVICE COMMISSION  
MANAGER