

**CANCELLED**

February 15, 2024  
 Caldwell County Water District  
 (Name of Utility)  
**KENTUCKY PUBLIC  
 SERVICE COMMISSION**

FOR Caldwell County, Kentucky  
 Community, Town or City

P.S.C. KY. NO. \_\_\_\_\_

\_\_\_\_\_ SHEET NO. \_\_\_\_\_

CANCELLING P.S.C. KY. NO. \_\_\_\_\_

\_\_\_\_\_ SHEET NO. \_\_\_\_\_

RULES AND REGULATIONS

V. Service Lines & Connections:

1. The utility will furnish and install at its own expense for the purpose of connecting its distribution system to the customer's premises that portion of the service connection from its main to and including the meter and meter box. The utility will recoup this expense from the customer in accordance with KRS 278.0152.
2. In areas where the distribution system follows well-defined streets and roads, the customer's point of service will be located at that point on or near the street right-of-way or property line most accessible to the utility from its distribution system. In areas where the distribution system does not follow streets and roads, the point of service will be located as near the customer's property line as practicable. Prior to installation of the meter the utility will consult with the customer as to the most practical location.
3. Depth of service line. All service lines must be laid at a sufficient depth per Kentucky State Plumbing Code Requirements to prevent freezing during the coldest weather normally experienced except where services are not intended for use during freezing weather and are actually drained during such periods.
4. A plumbing permit from the appropriate regulatory agency is required before the utility can set the meter.
5. The applicant/customer must furnish and lay the necessary pipe to make the connection from the point of service to the point of usage and be financially responsible for all costs associated with the installation and maintenance of his/her service line plumbing, including a shut-off valve and one-way check valve, installed on his/her property beginning at the outlet side of the water meter. The service line must be kept in good repair and in accordance with utility and Public Service Commission rules and regulations.
6. The installation and maintenance of the water service line must be in accordance with the rules and regulations of the Kentucky Department of Health.
7. A cross-connection of the utility's system with any other source is strictly prohibited.
8. A well that has or is being used on the premises must be inspected by utility personnel to verify disconnection and separation.

DATE OF ISSUE 07/14/2011  
 Month / Date / Year

DATE EFFECTIVE 09/01/2011  
 Month / Date / Year

ISSUED BY Jimmy Littlefield  
 (Signature of Officer)

TITLE \_\_\_\_\_ Chairman

BY AUTHORITY OF ORDER OF THE PUBLIC SERVICE COMMISSION  
 IN CASE NO. \_\_\_\_\_ DATED \_\_\_\_\_

**KENTUCKY  
 PUBLIC SERVICE COMMISSION**

**JEFF R. DEROUEN  
 EXECUTIVE DIRECTOR**

TARIFF BRANCH

*Burt Kirtley*

EFFECTIVE  
**9/1/2011**  
 PURSUANT TO 807 KAR 5:011 SECTION 9 (1)

**CANCELLED**

February 15, 2024

Caldwell County Water District  
(Name of Utility)

**KENTUCKY PUBLIC  
SERVICE COMMISSION**

FOR Caldwell County, Kentucky  
Community, Town or City

P.S.C. KY. NO. \_\_\_\_\_

\_\_\_\_\_ SHEET NO. \_\_\_\_\_

CANCELLING P.S.C. KY. NO. \_\_\_\_\_

\_\_\_\_\_ SHEET NO. \_\_\_\_\_

RULES AND REGULATIONS

9. All service lines on the customer's side of the meter must consist of copper or PVC pipe with a rating of no less than 200 psi, and should not be less than 3/4 inches.
10. Absolutely no galvanized pipe or fittings can be used in the installation.
11. The utility will not set a meter on a customer's service line at a point that does not deliver 30 psig at the meter.
12. If the applicant/customer's point of usage is at a higher elevation than the meter, the customer should consult with a reputable engineering firm to properly size the service line from the meter to the point of usage.
13. Should an applicant/customer desire a higher pressure due to location or other need, provisions must be made by the applicant for an individual pressure booster system. The manner of connection, location cross-connection protection and type is subject to approval by the utility. The utility reserves the right to require discontinuance and disconnection should the private booster system have a detrimental effect on the utility's system.
14. Piping on the premises of the applicant/customer must be installed so that connections are conveniently located with respect to the utility's lines and mains. A place must be provided for metering that is unobstructed and accessible at all times.
15. The utility may require the applicant/customer at his/her own expense, to install a back-flow preventer and/or pressure regulator.
16. All meters will be installed, renewed, and maintained at the expense of the utility, and the utility reserves the right to approve the size and type of meter used.
17. All taps and connections to the mains of the utility must be made by and/or under the direction and supervision of utility personnel and will incur a meter connection/tap-on charge, an amount that has been approved by the Public Service Commission for such service. Payment of this fee is for the privilege of connecting to the water system and the payment of the fee does not constitute the purchase of a water meter.
18. Should an applicant requesting a 5/8" x 3/4" meter require service on the opposite side of the road from the water main, the utility will provide the service at no additional cost to the customer other

DATE OF ISSUE 07/14/2011  
Month / Date / Year

DATE EFFECTIVE 09/01/2011  
Month / Date / Year

ISSUED BY JIMMY LITTLEFIELD  
(Signature of Officer)

TITLE Chairman

BY AUTHORITY OF ORDER OF THE PUBLIC SERVICE COMMISSION  
IN CASE NO. \_\_\_\_\_ DATED \_\_\_\_\_

**KENTUCKY  
PUBLIC SERVICE COMMISSION**

**JEFF R. DEROUEN  
EXECUTIVE DIRECTOR**

TARIFF BRANCH

*Brent Kirtley*

EFFECTIVE  
**9/1/2011**  
PURSUANT TO 807 KAR 5:011 SECTION 9 (1)

FOR Caldwell County, Kentucky  
Community, Town or City

P.S.C. KY. NO. \_\_\_\_\_

\_\_\_\_\_ SHEET NO. \_\_\_\_\_

Caldwell County Water District  
(Name of Utility)

CANCELLING P.S.C. KY. NO. \_\_\_\_\_

\_\_\_\_\_ SHEET NO. \_\_\_\_\_

**RULES AND REGULATIONS**

than the standard meter connection/tap-on charge. All larger size meters will be charged the actual cost of installing the meter, including, when applicable, the additional costs for crossing the road.

19. Any customer having boilers and/or pressure vessels that receive water from the utility must have a check valve on the water supply line and a vacuum valve on the steam line in order to prevent a collapse where the water supply from the utility may be interrupted or discontinued.



DATE OF ISSUE 07/14/2011  
Month / Date / Year

DATE EFFECTIVE 09/01/2011  
Month / Date / Year

ISSUED BY JIMMY LITTLEFIELD  
(Signature of Officer)

TITLE Chairman

BY AUTHORITY OF ORDER OF THE PUBLIC SERVICE COMMISSION  
IN CASE NO. \_\_\_\_\_ DATED \_\_\_\_\_

