

COMMONWEALTH OF KENTUCKY

BEFORE THE PUBLIC SERVICE COMMISSION

In the Matter of:

THE APPLICATION OF GOSHEN UTILITIES, INC.)
FOR A DEVIATION FROM 807 KAR 5:066) CASE NO. 91-182
SECTION 9(2) REGARDING DEAD ENDS)

O R D E R

By letter received June 7, 1991, Goshen Utilities, Inc. ("Goshen") requested a three year time period to bring its facilities into compliance with 807 KAR 5:066, Section 9(2). This regulation requires a water utility to provide blow-off valves for the purpose of flushing dead-end water mains.


The Commission, having reviewed the evidence of record and being advised, finds that Goshen should be allowed additional time to comply with 807 KAR 5:066, Section 9(2).

IT IS THEREFORE ORDERED that Goshen be and it hereby is given until July 1, 1994 to comply with the provisions of 807 KAR 5:066, Section 9(2).

Done at Frankfort, Kentucky, this 28th day of June, 1991.


PUBLIC SERVICE COMMISSION


Chairman


Vice Chairman

ATTEST


Executive Director


Commissioner