

CASE

NUMBER:

99-441

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACOR
CHL UM82	01	795900	2002-12-05	100.09	100.11	100.06
CHL UM82	01	795901	2002-12-05	100.11	100.04	100.03
CHL UM82	01	795902	2002-12-05	100.07	100.05	099.99
CHL UM82	01	795903	2002-12-05	100.03	100.04	100.02
CHL UM82	01	795904	2002-12-05	100.10	100.03	100.05
CHL UM82	01	795905	2002-12-05	100.10	100.03	100.05
CHL UM82	01	795906	2002-12-05	100.10	100.02	100.04
CHL UM82	01	795907	2002-12-05	100.07	100.03	100.04
CHL UM82	01	795908	2002-12-05	100.10	100.03	100.04
CHL UM82	01	795909	2002-12-05	100.10	100.03	100.04
CHL UM82	01	795910	2002-12-05	100.10	100.03	100.04
CHL UM82	01	795911	2002-12-05	100.10	100.03	100.04
CHL UM82	01	795912	2002-12-05	100.10	100.03	100.04
CHL UM82	01	795913	2002-12-05	100.10	100.03	100.04
CHL UM82	01	795914	2002-12-05	100.10	100.03	100.04
CHL UM82	01	795915	2002-12-05	100.10	100.03	100.04
CHL UM82	01	795916	2002-12-05	100.10	100.03	100.04
CHL UM82	01	795917	2002-12-05	100.07	100.03	099.99
CHL UM82	01	795918	2002-12-05	100.07	100.03	099.99
CHL UM82	01	795919	2002-12-05	100.11	100.03	100.03
CHL UM82	01	795920	2002-12-05	100.08	100.03	099.99
CHL UM82	01	795921	2002-12-05	100.10	100.03	100.03
CHL UM82	01	795922	2002-12-05	100.10	100.03	100.03
CHL UM82	01	795923	2002-12-05	100.10	100.03	100.03
CHL UM82	01	795924	2002-12-05	100.10	100.03	100.03
CHL UM82	01	795925	2002-12-05	100.10	100.03	100.03
CHL UM82	01	795926	2002-12-05	100.10	100.03	100.03
CHL UM82	01	795927	2002-12-05	100.10	100.03	100.03
CHL UM82	01	795928	2002-12-05	100.10	100.03	100.03
CHL UM82	01	795929	2002-12-05	100.10	100.03	100.03
CHL UM82	01	795930	2002-12-05	100.10	100.03	100.03
CHL UM82	01	795931	2002-12-05	100.11	100.03	100.03
CHL UM82	01	795932	2002-12-05	100.10	100.03	100.03
CHL UM82	01	795933	2002-12-05	100.10	100.03	100.03
CHL UM82	01	795934	2002-12-05	100.10	100.03	100.03
CHL UM82	01	795935	2002-12-05	100.10	100.03	100.03
CHL UM82	01	795936	2002-12-05	100.10	100.03	100.03
CHL UM82	01	795937	2002-12-05	100.10	100.03	100.03
CHL UM82	01	795938	2002-12-05	100.10	100.03	100.03
CHL UM82	01	795939	2002-12-05	100.10	100.03	100.03
CHL UM82	01	795940	2002-12-05	100.07	100.03	100.03
CHL UM82	01	795941	2002-12-05	100.07	100.03	100.03
CHL UM82	01	795942	2002-12-05	100.07	100.03	100.03
CHL UM82	01	795943	2002-12-05	100.08	100.03	100.03
CHL UM82	01	795944	2002-12-05	100.08	100.03	100.03
CHL UM82	01	795945	2002-12-05	100.11	100.03	100.03
CHL UM82	01	795946	2002-12-05	100.07	100.03	100.03
CHL UM82	01	795947	2002-12-05	100.08	100.03	100.03
CHL UM82	01	795948	2002-12-05	100.09	100.03	100.03
CHL UM82	01	795949	2002-12-05	100.10	100.03	100.03

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACOR
CHL	UMBE	7960910	2002-12-05	100.10	103.02	100.01
CHL	UMBE	7940911	2002-12-05	100.11	103.05	100.07
CHL	UMBE	7960912	2002-12-05	100.11	103.04	100.07
CHL	UMBE	7960913	2002-12-05	100.11	103.04	100.11
CHL	UMBE	7960914	2002-12-05	100.11	103.04	100.11
CHL	UMBE	7960915	2002-12-05	100.11	103.04	100.11
CHL	UMBE	7960916	2002-12-05	100.11	103.04	100.11
CHL	UMBE	7960917	2002-12-05	100.11	103.04	100.11
CHL	UMBE	7960918	2002-12-05	100.11	103.04	100.11
CHL	UMBE	7960919	2002-12-05	100.11	103.04	100.11
CHL	UMBE	7960920	2002-12-05	100.11	103.04	100.11
CHL	UMBE	7960921	2002-12-05	100.11	103.04	100.11
CHL	UMBE	7960922	2002-12-05	100.11	103.04	100.11
CHL	UMBE	7960923	2002-12-05	100.11	103.04	100.11
CHL	UMBE	7960924	2002-12-05	100.11	103.04	100.11
CHL	UMBE	7960925	2002-12-05	100.11	103.04	100.11
CHL	UMBE	7960926	2002-12-05	100.11	103.04	100.11
CHL	UMBE	7960927	2002-12-05	100.11	103.04	100.11
CHL	UMBE	7960928	2002-12-05	100.11	103.04	100.11
CHL	UMBE	7960929	2002-12-05	100.11	103.04	100.11
CHL	UMBE	7960930	2002-12-05	100.11	103.04	100.11
CHL	UMBE	7960931	2002-12-05	100.11	103.04	100.11
CHL	UMBE	7960932	2002-12-05	100.11	103.04	100.11
CHL	UMBE	7960933	2002-12-05	100.11	103.04	100.11
CHL	UMBE	7960934	2002-12-05	100.11	103.04	100.11
CHL	UMBE	7960935	2002-12-05	100.11	103.04	100.11
CHL	UMBE	7960936	2002-12-05	100.11	103.04	100.11
CHL	UMBE	7960937	2002-12-05	100.11	103.04	100.11
CHL	UMBE	7960938	2002-12-05	100.11	103.04	100.11
CHL	UMBE	7960939	2002-12-05	100.11	103.04	100.11
CHL	UMBE	7960940	2002-12-05	100.11	103.04	100.11
CHL	UMBE	7960941	2002-12-05	100.11	103.04	100.11
CHL	UMBE	7960942	2002-12-05	100.11	103.04	100.11
CHL	UMBE	7960943	2002-12-05	100.11	103.04	100.11
CHL	UMBE	7960944	2002-12-05	100.11	103.04	100.11
CHL	UMBE	7960945	2002-12-05	100.11	103.04	100.11
CHL	UMBE	7960946	2002-12-05	100.11	103.04	100.11
CHL	UMBE	7960947	2002-12-05	100.11	103.04	100.11
CHL	UMBE	7960948	2002-12-05	100.11	103.04	100.11
CHL	UMBE	7960949	2002-12-05	100.11	103.04	100.11
CHL	UMBE	7960950	2002-12-05	100.11	103.04	100.11

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
CHL UNBERGER	01	794109	2002-11-05	100.08	100.01	100.02
CHL UNBERGER	01	794101	2002-11-05	100.07	099.90	099.99
CHL UNBERGER	01	794102	2002-11-05	100.09	100.12	100.04
CHL UNBERGER	01	794103	2002-11-05	100.03	100.05	100.05
CHL UNBERGER	01	794104	2002-11-05	100.08	100.12	100.08
CHL UNBERGER	01	794105	2002-11-05	100.09	100.07	100.04
CHL UNBERGER	01	794107	2002-11-05	100.10	100.04	100.03
CHL UNBERGER	01	794109	2002-11-05	100.08	100.13	100.05
CHL UNBERGER	01	794109	2002-11-05	100.08	100.13	100.05
CHL UNBERGER	01	794110	2002-11-05	100.11	100.14	100.06
CHL UNBERGER	01	794111	2002-11-05	100.09	100.14	100.07
CHL UNBERGER	01	794112	2002-11-05	100.10	100.08	100.07
CHL UNBERGER	01	794113	2002-11-05	100.10	100.13	099.99
CHL UNBERGER	01	794114	2002-11-05	100.08	100.13	100.01
CHL UNBERGER	01	794115	2002-11-05	100.10	100.10	100.04
CHL UNBERGER	01	794117	2002-11-05	100.07	099.95	099.95
CHL UNBERGER	01	794118	2002-11-05	100.09	100.07	100.10
CHL UNBERGER	01	794119	2002-11-05	100.09	099.95	099.95
CHL UNBERGER	01	794120	2002-11-05	100.10	100.14	100.11
CHL UNBERGER	01	794121	2002-11-05	100.09	100.14	100.06
CHL UNBERGER	01	794122	2002-11-05	100.11	100.08	100.06
CHL UNBERGER	01	794123	2002-11-05	100.08	100.13	099.97
CHL UNBERGER	01	794124	2002-11-05	100.09	100.11	100.01
CHL UNBERGER	01	794125	2002-11-05	100.10	100.10	100.04
CHL UNBERGER	01	794126	2002-11-05	100.11	100.11	100.14
CHL UNBERGER	01	794127	2002-11-05	100.10	100.11	100.04
CHL UNBERGER	01	794128	2002-11-05	100.12	100.12	100.04
CHL UNBERGER	01	794129	2002-11-05	100.11	100.11	100.06
CHL UNBERGER	01	794130	2002-11-05	100.10	100.10	100.04
CHL UNBERGER	01	794131	2002-11-05	100.10	100.11	100.02
CHL UNBERGER	01	794132	2002-11-05	100.11	100.11	100.04
CHL UNBERGER	01	794133	2002-11-05	100.10	100.11	100.04
CHL UNBERGER	01	794134	2002-11-05	100.10	100.10	100.04
CHL UNBERGER	01	794135	2002-11-05	100.10	100.10	100.04
CHL UNBERGER	01	794136	2002-11-05	100.10	100.10	100.04
CHL UNBERGER	01	794137	2002-11-05	100.10	100.10	100.04
CHL UNBERGER	01	794138	2002-11-05	100.10	100.10	100.04
CHL UNBERGER	01	794139	2002-11-05	100.10	100.10	100.04
CHL UNBERGER	01	794140	2002-11-05	100.10	100.10	100.04
CHL UNBERGER	01	794141	2002-11-05	100.10	100.10	100.04
CHL UNBERGER	01	794142	2002-11-05	100.10	100.10	100.04
CHL UNBERGER	01	794143	2002-11-05	100.10	100.10	100.04
CHL UNBERGER	01	794144	2002-11-05	100.10	100.10	100.04
CHL UNBERGER	01	794145	2002-11-05	100.10	100.10	100.04
CHL UNBERGER	01	794146	2002-11-05	100.10	100.10	100.04
CHL UNBERGER	01	794147	2002-11-05	100.10	100.10	100.04
CHL UNBERGER	01	794148	2002-11-05	100.10	100.10	100.04
CHL UNBERGER	01	794149	2002-11-05	100.10	100.10	100.04
CHL UNBERGER	01	794150	2002-11-05	100.10	100.10	100.04

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PF FACTOR
CHL 1MS3	01	7945150	05	100.10	100.09	099.98
CHL 1MS3	01	7945151	05	100.11	100.09	100.02
CHL 1MS3	01	7945152	05	100.09	100.09	100.03
CHL 1MS3	01	7945153	05	100.10	100.09	100.03
CHL 1MS3	01	7945154	05	100.10	100.09	100.01
CHL 1MS3	01	7945155	05	100.11	100.09	100.04
CHL 1MS3	01	7945156	05	100.09	100.09	100.03
CHL 1MS3	01	7945157	05	100.09	100.09	100.03
CHL 1MS3	01	7945158	05	100.10	100.09	100.04
CHL 1MS3	01	7945159	05	100.11	100.09	100.04
CHL 1MS3	01	7945160	05	100.07	100.09	100.01
CHL 1MS3	01	7945161	05	100.10	100.09	100.04
CHL 1MS3	01	7945162	05	100.10	100.09	100.04
CHL 1MS3	01	7945163	05	100.09	100.09	100.04
CHL 1MS3	01	7945164	05	100.09	100.09	100.04
CHL 1MS3	01	7945165	05	100.09	100.09	100.04
CHL 1MS3	01	7945166	05	100.09	100.09	100.04
CHL 1MS3	01	7945167	05	100.09	100.09	100.04
CHL 1MS3	01	7945168	05	100.09	100.09	100.04
CHL 1MS3	01	7945169	05	100.09	100.09	100.04
CHL 1MS3	01	7945170	05	100.09	100.09	100.04
CHL 1MS3	01	7945171	05	100.09	100.09	100.04
CHL 1MS3	01	7945172	05	100.09	100.09	100.04
CHL 1MS3	01	7945173	05	100.09	100.09	100.04
CHL 1MS3	01	7945174	05	100.09	100.09	100.04
CHL 1MS3	01	7945175	05	100.09	100.09	100.04
CHL 1MS3	01	7945176	05	100.09	100.09	100.04
CHL 1MS3	01	7945177	05	100.09	100.09	100.04
CHL 1MS3	01	7945178	05	100.09	100.09	100.04
CHL 1MS3	01	7945179	05	100.09	100.09	100.04
CHL 1MS3	01	7945180	05	100.09	100.09	100.04
CHL 1MS3	01	7945181	05	100.09	100.09	100.04
CHL 1MS3	01	7945182	05	100.09	100.09	100.04
CHL 1MS3	01	7945183	05	100.09	100.09	100.04
CHL 1MS3	01	7945184	05	100.09	100.09	100.04
CHL 1MS3	01	7945185	05	100.09	100.09	100.04
CHL 1MS3	01	7945186	05	100.09	100.09	100.04
CHL 1MS3	01	7945187	05	100.09	100.09	100.04
CHL 1MS3	01	7945188	05	100.09	100.09	100.04
CHL 1MS3	01	7945189	05	100.09	100.09	100.04
CHL 1MS3	01	7945190	05	100.09	100.09	100.04
CHL 1MS3	01	7945191	05	100.09	100.09	100.04
CHL 1MS3	01	7945192	05	100.09	100.09	100.04
CHL 1MS3	01	7945193	05	100.09	100.09	100.04
CHL 1MS3	01	7945194	05	100.09	100.09	100.04
CHL 1MS3	01	7945195	05	100.09	100.09	100.04
CHL 1MS3	01	7945196	05	100.09	100.09	100.04
CHL 1MS3	01	7945197	05	100.09	100.09	100.04
CHL 1MS3	01	7945198	05	100.09	100.09	100.04
CHL 1MS3	01	7945199	05	100.09	100.09	100.04
CHL 1MS3	01	7945200	05	100.09	100.09	100.04

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PF FACTOR
CHLUMBER	01	794200	2002-12-05	100.02	100.00	099.99
CHLUMBER	01	794201	2002-12-05	100.12	100.00	100.02
CHLUMBER	01	794202	2002-12-05	100.09	100.00	100.03
CHLUMBER	01	794203	2002-12-05	100.08	099.98	100.07
CHLUMBER	01	794204	2002-12-04	100.10	100.11	100.02
CHLUMBER	01	794205	2002-12-04	100.02	100.04	100.04
CHLUMBER	01	794206	2002-12-04	100.11	100.05	100.04
CHLUMBER	01	794207	2002-12-04	100.14	100.05	100.07
CHLUMBER	01	794208	2002-12-04	100.09	100.10	100.05
CHLUMBER	01	794209	2002-12-04	100.02	099.94	100.03
CHLUMBER	01	794210	2002-12-04	100.10	100.09	100.04
CHLUMBER	01	794211	2002-12-04	100.11	099.92	100.02
CHLUMBER	01	794212	2002-12-04	100.10	100.07	100.04
CHLUMBER	01	794213	2002-12-04	100.09	100.11	100.05
CHLUMBER	01	794214	2002-12-04	100.11	100.03	100.05
CHLUMBER	01	794215	2002-12-04	100.10	100.09	100.05
CHLUMBER	01	794216	2002-12-04	100.09	100.11	100.05
CHLUMBER	01	794217	2002-12-04	100.11	100.07	100.04
CHLUMBER	01	794218	2002-12-04	100.10	100.09	100.04
CHLUMBER	01	794219	2002-12-04	100.11	100.14	100.03
CHLUMBER	01	794220	2002-12-04	100.11	100.04	100.03
CHLUMBER	01	794221	2002-12-04	100.07	100.04	100.03
CHLUMBER	01	794222	2002-12-04	100.07	100.04	100.03
CHLUMBER	01	794223	2002-12-04	100.07	100.04	100.03
CHLUMBER	01	794224	2002-12-04	100.07	100.04	100.03
CHLUMBER	01	794225	2002-12-04	100.07	100.04	100.03
CHLUMBER	01	794226	2002-12-04	100.07	100.04	100.03
CHLUMBER	01	794227	2002-12-04	100.07	100.04	100.03
CHLUMBER	01	794228	2002-12-04	100.07	100.04	100.03
CHLUMBER	01	794229	2002-12-04	100.07	100.04	100.03
CHLUMBER	01	794230	2002-12-04	100.07	100.04	100.03
CHLUMBER	01	794231	2002-12-04	100.07	100.04	100.03
CHLUMBER	01	794232	2002-12-04	100.07	100.04	100.03
CHLUMBER	01	794233	2002-12-04	100.07	100.04	100.03
CHLUMBER	01	794234	2002-12-04	100.07	100.04	100.03
CHLUMBER	01	794235	2002-12-04	100.07	100.04	100.03
CHLUMBER	01	794236	2002-12-04	100.07	100.04	100.03
CHLUMBER	01	794237	2002-12-04	100.07	100.04	100.03
CHLUMBER	01	794238	2002-12-04	100.07	100.04	100.03
CHLUMBER	01	794239	2002-12-04	100.07	100.04	100.03
CHLUMBER	01	794240	2002-12-04	100.07	100.04	100.03
CHLUMBER	01	794241	2002-12-04	100.07	100.04	100.03
CHLUMBER	01	794242	2002-12-04	100.07	100.04	100.03
CHLUMBER	01	794243	2002-12-04	100.07	100.04	100.03
CHLUMBER	01	794244	2002-12-04	100.07	100.04	100.03
CHLUMBER	01	794245	2002-12-04	100.07	100.04	100.03
CHLUMBER	01	794246	2002-12-04	100.07	100.04	100.03
CHLUMBER	01	794247	2002-12-04	100.07	100.04	100.03
CHLUMBER	01	794248	2002-12-04	100.07	100.04	100.03
CHLUMBER	01	794249	2002-12-04	100.07	100.04	100.03
CHLUMBER	01	794250	2002-12-04	100.07	100.04	100.03

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PF FACTOR
CHE LMBE	01	7929250	05	100.11	107.12	100.08
CHE LMBE	01	7929251	05	100.10	100.09	100.06
CHE LMBE	01	7929252	05	100.11	100.09	100.05
CHE LMBE	01	7929253	05	100.11	100.08	100.05
CHE LMBE	01	7929254	05	100.11	100.08	100.05
CHE LMBE	01	7929255	05	100.12	100.04	100.04
CHE LMBE	01	7929256	05	100.07	100.10	100.09
CHE LMBE	01	7929257	05	100.09	100.04	100.02
CHE LMBE	01	7929258	05	100.09	100.04	100.02
CHE LMBE	01	7929259	05	100.09	100.04	100.02
CHE LMBE	01	7929260	05	100.09	100.04	100.02
CHE LMBE	01	7929261	05	100.09	100.04	100.02
CHE LMBE	01	7929262	05	100.09	100.04	100.02
CHE LMBE	01	7929263	05	100.09	100.04	100.02
CHE LMBE	01	7929264	05	100.09	100.04	100.02
CHE LMBE	01	7929265	05	100.09	100.04	100.02
CHE LMBE	01	7929266	05	100.09	100.04	100.02
CHE LMBE	01	7929267	05	100.09	100.04	100.02
CHE LMBE	01	7929268	05	100.09	100.04	100.02
CHE LMBE	01	7929269	05	100.09	100.04	100.02
CHE LMBE	01	7929270	05	100.09	100.04	100.02
CHE LMBE	01	7929271	05	100.09	100.04	100.02
CHE LMBE	01	7929272	05	100.09	100.04	100.02
CHE LMBE	01	7929273	05	100.09	100.04	100.02
CHE LMBE	01	7929274	05	100.09	100.04	100.02
CHE LMBE	01	7929275	05	100.09	100.04	100.02
CHE LMBE	01	7929276	05	100.09	100.04	100.02
CHE LMBE	01	7929277	05	100.09	100.04	100.02
CHE LMBE	01	7929278	05	100.09	100.04	100.02
CHE LMBE	01	7929279	05	100.09	100.04	100.02
CHE LMBE	01	7929280	05	100.09	100.04	100.02
CHE LMBE	01	7929281	05	100.09	100.04	100.02
CHE LMBE	01	7929282	05	100.09	100.04	100.02
CHE LMBE	01	7929283	05	100.09	100.04	100.02
CHE LMBE	01	7929284	05	100.09	100.04	100.02
CHE LMBE	01	7929285	05	100.09	100.04	100.02
CHE LMBE	01	7929286	05	100.09	100.04	100.02
CHE LMBE	01	7929287	05	100.09	100.04	100.02
CHE LMBE	01	7929288	05	100.09	100.04	100.02
CHE LMBE	01	7929289	05	100.09	100.04	100.02
CHE LMBE	01	7929290	05	100.09	100.04	100.02
CHE LMBE	01	7929291	05	100.09	100.04	100.02
CHE LMBE	01	7929292	05	100.09	100.04	100.02
CHE LMBE	01	7929293	05	100.09	100.04	100.02
CHE LMBE	01	7929294	05	100.09	100.04	100.02
CHE LMBE	01	7929295	05	100.09	100.04	100.02
CHE LMBE	01	7929296	05	100.09	100.04	100.02
CHE LMBE	01	7929297	05	100.09	100.04	100.02
CHE LMBE	01	7929298	05	100.09	100.04	100.02
CHE LMBE	01	7929299	05	100.09	100.04	100.02
CHE LMBE	01	7929300	05	100.09	100.04	100.02

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PF FACTOR
CHL	01	7941237	05-05	100.09	100.03	100.03
CHL	01	7941238	05-05	100.09	100.03	100.03
CHL	01	7941239	05-05	100.09	100.03	100.03
CHL	01	7941240	05-05	100.09	100.03	100.03
CHL	01	7941241	05-05	100.09	100.03	100.03
CHL	01	7941242	05-05	100.09	100.03	100.03
CHL	01	7941243	05-05	100.09	100.03	100.03
CHL	01	7941244	05-05	100.09	100.03	100.03
CHL	01	7941245	05-05	100.09	100.03	100.03
CHL	01	7941246	05-05	100.09	100.03	100.03
CHL	01	7941247	05-05	100.09	100.03	100.03
CHL	01	7941248	05-05	100.09	100.03	100.03
CHL	01	7941249	05-05	100.09	100.03	100.03
CHL	01	7941250	05-05	100.09	100.03	100.03
CHL	01	7941251	05-05	100.09	100.03	100.03
CHL	01	7941252	05-05	100.09	100.03	100.03
CHL	01	7941253	05-05	100.09	100.03	100.03
CHL	01	7941254	05-05	100.09	100.03	100.03
CHL	01	7941255	05-05	100.09	100.03	100.03
CHL	01	7941256	05-05	100.09	100.03	100.03
CHL	01	7941257	05-05	100.09	100.03	100.03
CHL	01	7941258	05-05	100.09	100.03	100.03
CHL	01	7941259	05-05	100.09	100.03	100.03
CHL	01	7941260	05-05	100.09	100.03	100.03
CHL	01	7941261	05-05	100.09	100.03	100.03
CHL	01	7941262	05-05	100.09	100.03	100.03
CHL	01	7941263	05-05	100.09	100.03	100.03
CHL	01	7941264	05-05	100.09	100.03	100.03
CHL	01	7941265	05-05	100.09	100.03	100.03
CHL	01	7941266	05-05	100.09	100.03	100.03
CHL	01	7941267	05-05	100.09	100.03	100.03
CHL	01	7941268	05-05	100.09	100.03	100.03
CHL	01	7941269	05-05	100.09	100.03	100.03
CHL	01	7941270	05-05	100.09	100.03	100.03
CHL	01	7941271	05-05	100.09	100.03	100.03
CHL	01	7941272	05-05	100.09	100.03	100.03
CHL	01	7941273	05-05	100.09	100.03	100.03
CHL	01	7941274	05-05	100.09	100.03	100.03
CHL	01	7941275	05-05	100.09	100.03	100.03
CHL	01	7941276	05-05	100.09	100.03	100.03
CHL	01	7941277	05-05	100.09	100.03	100.03
CHL	01	7941278	05-05	100.09	100.03	100.03
CHL	01	7941279	05-05	100.09	100.03	100.03
CHL	01	7941280	05-05	100.09	100.03	100.03
CHL	01	7941281	05-05	100.09	100.03	100.03
CHL	01	7941282	05-05	100.09	100.03	100.03
CHL	01	7941283	05-05	100.09	100.03	100.03
CHL	01	7941284	05-05	100.09	100.03	100.03
CHL	01	7941285	05-05	100.09	100.03	100.03
CHL	01	7941286	05-05	100.09	100.03	100.03
CHL	01	7941287	05-05	100.09	100.03	100.03
CHL	01	7941288	05-05	100.09	100.03	100.03
CHL	01	7941289	05-05	100.09	100.03	100.03
CHL	01	7941290	05-05	100.09	100.03	100.03
CHL	01	7941291	05-05	100.09	100.03	100.03
CHL	01	7941292	05-05	100.09	100.03	100.03
CHL	01	7941293	05-05	100.09	100.03	100.03
CHL	01	7941294	05-05	100.09	100.03	100.03
CHL	01	7941295	05-05	100.09	100.03	100.03
CHL	01	7941296	05-05	100.09	100.03	100.03
CHL	01	7941297	05-05	100.09	100.03	100.03
CHL	01	7941298	05-05	100.09	100.03	100.03
CHL	01	7941299	05-05	100.09	100.03	100.03
CHL	01	7941300	05-05	100.09	100.03	100.03

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PF FACTOR
JOE LAMBERGER	01	7794400	05-05-05	100.14	107.99	100.07
JOE LAMBERGER	01	7794401	05-05-05	100.05	107.99	100.01
JOE LAMBERGER	01	7794402	05-05-05	100.07	107.99	100.02
JOE LAMBERGER	01	7794403	05-05-05	100.09	107.99	100.03
JOE LAMBERGER	01	7794404	05-05-05	100.10	107.99	100.04
JOE LAMBERGER	01	7794405	05-05-05	100.11	107.99	100.05
JOE LAMBERGER	01	7794406	05-05-05	100.12	107.99	100.06
JOE LAMBERGER	01	7794407	05-05-05	100.13	107.99	100.07
JOE LAMBERGER	01	7794408	05-05-05	100.14	107.99	100.08
JOE LAMBERGER	01	7794409	05-05-05	100.15	107.99	100.09
JOE LAMBERGER	01	7794410	05-05-05	100.16	107.99	100.10
JOE LAMBERGER	01	7794411	05-05-05	100.17	107.99	100.11
JOE LAMBERGER	01	7794412	05-05-05	100.18	107.99	100.12
JOE LAMBERGER	01	7794413	05-05-05	100.19	107.99	100.13
JOE LAMBERGER	01	7794414	05-05-05	100.20	107.99	100.14
JOE LAMBERGER	01	7794415	05-05-05	100.21	107.99	100.15
JOE LAMBERGER	01	7794416	05-05-05	100.22	107.99	100.16
JOE LAMBERGER	01	7794417	05-05-05	100.23	107.99	100.17
JOE LAMBERGER	01	7794418	05-05-05	100.24	107.99	100.18
JOE LAMBERGER	01	7794419	05-05-05	100.25	107.99	100.19
JOE LAMBERGER	01	7794420	05-05-05	100.26	107.99	100.20
JOE LAMBERGER	01	7794421	05-05-05	100.27	107.99	100.21
JOE LAMBERGER	01	7794422	05-05-05	100.28	107.99	100.22
JOE LAMBERGER	01	7794423	05-05-05	100.29	107.99	100.23
JOE LAMBERGER	01	7794424	05-05-05	100.30	107.99	100.24
JOE LAMBERGER	01	7794425	05-05-05	100.31	107.99	100.25
JOE LAMBERGER	01	7794426	05-05-05	100.32	107.99	100.26
JOE LAMBERGER	01	7794427	05-05-05	100.33	107.99	100.27
JOE LAMBERGER	01	7794428	05-05-05	100.34	107.99	100.28
JOE LAMBERGER	01	7794429	05-05-05	100.35	107.99	100.29
JOE LAMBERGER	01	7794430	05-05-05	100.36	107.99	100.30
JOE LAMBERGER	01	7794431	05-05-05	100.37	107.99	100.31
JOE LAMBERGER	01	7794432	05-05-05	100.38	107.99	100.32
JOE LAMBERGER	01	7794433	05-05-05	100.39	107.99	100.33
JOE LAMBERGER	01	7794434	05-05-05	100.40	107.99	100.34
JOE LAMBERGER	01	7794435	05-05-05	100.41	107.99	100.35
JOE LAMBERGER	01	7794436	05-05-05	100.42	107.99	100.36
JOE LAMBERGER	01	7794437	05-05-05	100.43	107.99	100.37
JOE LAMBERGER	01	7794438	05-05-05	100.44	107.99	100.38
JOE LAMBERGER	01	7794439	05-05-05	100.45	107.99	100.39
JOE LAMBERGER	01	7794440	05-05-05	100.46	107.99	100.40
JOE LAMBERGER	01	7794441	05-05-05	100.47	107.99	100.41
JOE LAMBERGER	01	7794442	05-05-05	100.48	107.99	100.42
JOE LAMBERGER	01	7794443	05-05-05	100.49	107.99	100.43
JOE LAMBERGER	01	7794444	05-05-05	100.50	107.99	100.44
JOE LAMBERGER	01	7794445	05-05-05	100.51	107.99	100.45
JOE LAMBERGER	01	7794446	05-05-05	100.52	107.99	100.46
JOE LAMBERGER	01	7794447	05-05-05	100.53	107.99	100.47
JOE LAMBERGER	01	7794448	05-05-05	100.54	107.99	100.48
JOE LAMBERGER	01	7794449	05-05-05	100.55	107.99	100.49
JOE LAMBERGER	01	7794450	05-05-05	100.56	107.99	100.50
JOE LAMBERGER	01	7794451	05-05-05	100.57	107.99	100.51
JOE LAMBERGER	01	7794452	05-05-05	100.58	107.99	100.52
JOE LAMBERGER	01	7794453	05-05-05	100.59	107.99	100.53
JOE LAMBERGER	01	7794454	05-05-05	100.60	107.99	100.54
JOE LAMBERGER	01	7794455	05-05-05	100.61	107.99	100.55
JOE LAMBERGER	01	7794456	05-05-05	100.62	107.99	100.56
JOE LAMBERGER	01	7794457	05-05-05	100.63	107.99	100.57
JOE LAMBERGER	01	7794458	05-05-05	100.64	107.99	100.58
JOE LAMBERGER	01	7794459	05-05-05	100.65	107.99	100.59
JOE LAMBERGER	01	7794460	05-05-05	100.66	107.99	100.60
JOE LAMBERGER	01	7794461	05-05-05	100.67	107.99	100.61
JOE LAMBERGER	01	7794462	05-05-05	100.68	107.99	100.62
JOE LAMBERGER	01	7794463	05-05-05	100.69	107.99	100.63
JOE LAMBERGER	01	7794464	05-05-05	100.70	107.99	100.64
JOE LAMBERGER	01	7794465	05-05-05	100.71	107.99	100.65
JOE LAMBERGER	01	7794466	05-05-05	100.72	107.99	100.66
JOE LAMBERGER	01	7794467	05-05-05	100.73	107.99	100.67
JOE LAMBERGER	01	7794468	05-05-05	100.74	107.99	100.68
JOE LAMBERGER	01	7794469	05-05-05	100.75	107.99	100.69
JOE LAMBERGER	01	7794470	05-05-05	100.76	107.99	100.70
JOE LAMBERGER	01	7794471	05-05-05	100.77	107.99	100.71
JOE LAMBERGER	01	7794472	05-05-05	100.78	107.99	100.72
JOE LAMBERGER	01	7794473	05-05-05	100.79	107.99	100.73
JOE LAMBERGER	01	7794474	05-05-05	100.80	107.99	100.74
JOE LAMBERGER	01	7794475	05-05-05	100.81	107.99	100.75
JOE LAMBERGER	01	7794476	05-05-05	100.82	107.99	100.76
JOE LAMBERGER	01	7794477	05-05-05	100.83	107.99	100.77
JOE LAMBERGER	01	7794478	05-05-05	100.84	107.99	100.78
JOE LAMBERGER	01	7794479	05-05-05	100.85	107.99	100.79
JOE LAMBERGER	01	7794480	05-05-05	100.86	107.99	100.80
JOE LAMBERGER	01	7794481	05-05-05	100.87	107.99	100.81
JOE LAMBERGER	01	7794482	05-05-05	100.88	107.99	100.82
JOE LAMBERGER	01	7794483	05-05-05	100.89	107.99	100.83
JOE LAMBERGER	01	7794484	05-05-05	100.90	107.99	100.84
JOE LAMBERGER	01	7794485	05-05-05	100.91	107.99	100.85
JOE LAMBERGER	01	7794486	05-05-05	100.92	107.99	100.86
JOE LAMBERGER	01	7794487	05-05-05	100.93	107.99	100.87
JOE LAMBERGER	01	7794488	05-05-05	100.94	107.99	100.88
JOE LAMBERGER	01	7794489	05-05-05	100.95	107.99	100.89
JOE LAMBERGER	01	7794490	05-05-05	100.96	107.99	100.90
JOE LAMBERGER	01	7794491	05-05-05	100.97	107.99	100.91
JOE LAMBERGER	01	7794492	05-05-05	100.98	107.99	100.92
JOE LAMBERGER	01	7794493	05-05-05	100.99	107.99	100.93
JOE LAMBERGER	01	7794494	05-05-05	101.00	107.99	100.94

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACOR
SCHLUMBERGER	01	794450	200211	100.07	100.04	100.00
SCHLUMBERGER	01	794451	200211	100.10	100.04	100.00
SCHLUMBERGER	01	794452	200211	100.10	100.04	100.00
SCHLUMBERGER	01	794453	200211	100.10	100.04	100.00
SCHLUMBERGER	01	794454	200211	100.10	100.04	100.00
SCHLUMBERGER	01	794455	200211	100.10	100.04	100.00
SCHLUMBERGER	01	794456	200211	100.10	100.04	100.00
SCHLUMBERGER	01	794457	200211	100.07	100.04	100.00
SCHLUMBERGER	01	794458	200211	100.11	100.04	100.00
SCHLUMBERGER	01	794459	200211	100.07	100.04	100.00
SCHLUMBERGER	01	794460	200211	100.07	100.04	100.00
SCHLUMBERGER	01	794461	200211	100.07	100.04	100.00
SCHLUMBERGER	01	794462	200211	100.07	100.04	100.00
SCHLUMBERGER	01	794463	200211	100.07	100.04	100.00
SCHLUMBERGER	01	794464	200211	100.07	100.04	100.00
SCHLUMBERGER	01	794465	200211	100.07	100.04	100.00
SCHLUMBERGER	01	794466	200211	100.07	100.04	100.00
SCHLUMBERGER	01	794467	200211	100.07	100.04	100.00
SCHLUMBERGER	01	794468	200211	100.07	100.04	100.00
SCHLUMBERGER	01	794469	200211	100.07	100.04	100.00
SCHLUMBERGER	01	794470	200211	100.07	100.04	100.00
SCHLUMBERGER	01	794471	200211	100.07	100.04	100.00
SCHLUMBERGER	01	794472	200211	100.07	100.04	100.00
SCHLUMBERGER	01	794473	200211	100.07	100.04	100.00
SCHLUMBERGER	01	794474	200211	100.07	100.04	100.00
SCHLUMBERGER	01	794475	200211	100.07	100.04	100.00
SCHLUMBERGER	01	794476	200211	100.07	100.04	100.00
SCHLUMBERGER	01	794477	200211	100.07	100.04	100.00
SCHLUMBERGER	01	794478	200211	100.07	100.04	100.00
SCHLUMBERGER	01	794479	200211	100.07	100.04	100.00
SCHLUMBERGER	01	794480	200211	100.07	100.04	100.00
SCHLUMBERGER	01	794481	200211	100.07	100.04	100.00
SCHLUMBERGER	01	794482	200211	100.07	100.04	100.00
SCHLUMBERGER	01	794483	200211	100.07	100.04	100.00
SCHLUMBERGER	01	794484	200211	100.07	100.04	100.00
SCHLUMBERGER	01	794485	200211	100.07	100.04	100.00
SCHLUMBERGER	01	794486	200211	100.07	100.04	100.00
SCHLUMBERGER	01	794487	200211	100.07	100.04	100.00
SCHLUMBERGER	01	794488	200211	100.07	100.04	100.00
SCHLUMBERGER	01	794489	200211	100.07	100.04	100.00
SCHLUMBERGER	01	794490	200211	100.07	100.04	100.00
SCHLUMBERGER	01	794491	200211	100.07	100.04	100.00
SCHLUMBERGER	01	794492	200211	100.07	100.04	100.00
SCHLUMBERGER	01	794493	200211	100.07	100.04	100.00
SCHLUMBERGER	01	794494	200211	100.07	100.04	100.00
SCHLUMBERGER	01	794495	200211	100.07	100.04	100.00
SCHLUMBERGER	01	794496	200211	100.07	100.04	100.00
SCHLUMBERGER	01	794497	200211	100.07	100.04	100.00
SCHLUMBERGER	01	794498	200211	100.07	100.04	100.00
SCHLUMBERGER	01	794499	200211	100.07	100.04	100.00
SCHLUMBERGER	01	794500	200211	100.07	100.04	100.00

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PF FACTOR
CHLUMBER	01	7945300	2002-12-05	100.09	100.00	100.00
CHLUMBER	01	7945301	2002-12-05	100.07	100.00	100.00
CHLUMBER	01	7945302	2002-12-05	100.08	100.00	100.00
CHLUMBER	01	7945303	2002-12-05	100.10	100.00	100.00
CHLUMBER	01	7945304	2002-12-05	100.09	100.00	100.00
CHLUMBER	01	7945305	2002-12-05	100.08	100.00	100.00
CHLUMBER	01	7945306	2002-12-05	100.10	100.00	100.00
CHLUMBER	01	7945307	2002-12-05	100.08	100.00	100.00
CHLUMBER	01	7945308	2002-12-05	100.12	100.00	100.00
CHLUMBER	01	7945309	2002-12-05	100.09	100.00	100.00
CHLUMBER	01	7945310	2002-12-05	100.10	100.00	100.00
CHLUMBER	01	7945311	2002-12-05	100.10	100.00	100.00
CHLUMBER	01	7945312	2002-12-05	100.09	100.00	100.00
CHLUMBER	01	7945313	2002-12-05	100.09	100.00	100.00
CHLUMBER	01	7945314	2002-12-05	100.07	100.00	100.00
CHLUMBER	01	7945315	2002-12-05	100.07	100.00	100.00
CHLUMBER	01	7945316	2002-12-05	100.07	100.00	100.00
CHLUMBER	01	7945317	2002-12-05	100.07	100.00	100.00
CHLUMBER	01	7945318	2002-12-05	100.09	100.00	100.00
CHLUMBER	01	7945319	2002-12-05	100.09	100.00	100.00
CHLUMBER	01	7945320	2002-12-05	100.09	100.00	100.00
CHLUMBER	01	7945321	2002-12-05	100.10	100.00	100.00
CHLUMBER	01	7945322	2002-12-05	100.10	100.00	100.00
CHLUMBER	01	7945323	2002-12-05	100.07	100.00	100.00
CHLUMBER	01	7945324	2002-12-05	100.07	100.00	100.00
CHLUMBER	01	7945325	2002-12-05	100.07	100.00	100.00
CHLUMBER	01	7945326	2002-12-05	100.10	100.00	100.00
CHLUMBER	01	7945327	2002-12-05	100.07	100.00	100.00
CHLUMBER	01	7945328	2002-12-05	100.07	100.00	100.00
CHLUMBER	01	7945329	2002-12-05	100.10	100.00	100.00
CHLUMBER	01	7945330	2002-12-05	100.07	100.00	100.00
CHLUMBER	01	7945331	2002-12-05	100.07	100.00	100.00
CHLUMBER	01	7945332	2002-12-05	100.11	100.00	100.00
CHLUMBER	01	7945333	2002-12-05	100.08	100.00	100.00
CHLUMBER	01	7945334	2002-12-05	100.10	100.00	100.00
CHLUMBER	01	7945335	2002-12-05	100.10	100.00	100.00
CHLUMBER	01	7945336	2002-12-05	100.10	100.00	100.00
CHLUMBER	01	7945337	2002-12-05	100.08	100.00	100.00
CHLUMBER	01	7945338	2002-12-05	100.11	100.00	100.00
CHLUMBER	01	7945339	2002-12-05	100.12	100.00	100.00
CHLUMBER	01	7945340	2002-12-05	100.11	100.00	100.00
CHLUMBER	01	7945341	2002-12-05	100.11	100.00	100.00
CHLUMBER	01	7945342	2002-12-05	100.07	100.00	100.00
CHLUMBER	01	7945343	2002-12-05	100.10	100.00	100.00
CHLUMBER	01	7945344	2002-12-05	100.08	100.00	100.00
CHLUMBER	01	7945345	2002-12-05	100.08	100.00	100.00
CHLUMBER	01	7945346	2002-12-05	100.11	100.00	100.00
CHLUMBER	01	7945347	2002-12-05	100.11	100.00	100.00
CHLUMBER	01	7945348	2002-12-05	100.11	100.00	100.00
CHLUMBER	01	7945349	2002-12-05	100.08	100.00	100.00

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACITOR
CHL	MSR	796600	2002-12-05	109.09	100.09	100.00
CHL	MSR	796601	2002-12-05	100.07	100.09	100.04
CHL	MSR	796602	2002-12-05	100.02	100.10	100.06
CHL	MSR	796603	2002-12-05	100.11	099.96	100.02
CHL	MSR	796604	2002-12-05	100.10	100.05	100.07
CHL	MSR	796605	2002-12-05	100.11	100.17	100.02
CHL	MSR	796606	2002-12-05	100.10	100.01	100.00
CHL	MSR	796607	2002-12-05	100.10	100.14	100.06
CHL	MSR	796608	2002-12-05	100.09	100.02	099.98
CHL	MSR	796609	2002-12-05	100.08	100.03	100.00
CHL	MSR	796610	2002-12-05	100.07	100.07	100.00
CHL	MSR	796611	2002-12-05	100.10	100.14	100.05
CHL	MSR	796612	2002-12-05	100.08	100.04	100.02
CHL	MSR	796613	2002-12-05	100.02	100.02	100.01
CHL	MSR	796614	2002-12-05	100.02	100.17	100.07
CHL	MSR	796615	2002-12-05	100.02	100.02	100.05
CHL	MSR	796616	2002-12-05	100.02	100.17	100.02
CHL	MSR	796617	2002-12-05	100.02	099.99	099.98
CHL	MSR	796618	2002-12-05	100.02	100.04	100.10
CHL	MSR	796619	2002-12-05	100.02	100.04	100.10
CHL	MSR	796620	2002-12-05	100.09	099.98	100.04
CHL	MSR	796621	2002-12-05	100.07	100.09	100.01
CHL	MSR	796622	2002-12-05	100.11	100.06	100.07
CHL	MSR	796623	2002-12-05	100.07	100.04	100.04
CHL	MSR	796624	2002-12-05	100.10	099.99	100.04
CHL	MSR	796625	2002-12-05	100.10	100.02	100.05
CHL	MSR	796626	2002-12-05	100.10	099.95	100.02
CHL	MSR	796627	2002-12-05	100.10	100.02	100.02
CHL	MSR	796628	2002-12-05	100.10	100.01	100.02
CHL	MSR	796629	2002-12-05	100.09	100.03	100.06
CHL	MSR	796630	2002-12-05	100.09	100.03	100.06
CHL	MSR	796631	2002-12-05	100.07	100.09	100.04
CHL	MSR	796632	2002-12-05	100.12	100.09	100.10
CHL	MSR	796633	2002-12-05	100.08	100.05	100.02
CHL	MSR	796634	2002-12-05	100.11	100.09	100.09
CHL	MSR	796635	2002-12-05	100.10	100.10	100.05
CHL	MSR	796636	2002-12-05	100.08	100.10	100.05
CHL	MSR	796637	2002-12-05	100.08	099.98	100.03
CHL	MSR	796638	2002-12-05	100.11	100.10	099.98
CHL	MSR	796639	2002-12-05	100.11	100.10	100.05
CHL	MSR	796640	2002-12-05	100.07	099.98	100.04
CHL	MSR	796641	2002-12-05	100.08	100.09	100.07
CHL	MSR	796642	2002-12-05	100.08	100.08	100.07
CHL	MSR	796643	2002-12-05	100.10	100.08	100.08
CHL	MSR	796644	2002-12-05	100.09	100.08	100.07
CHL	MSR	796645	2002-12-05	100.10	100.08	100.08
CHL	MSR	796646	2002-12-05	100.10	100.08	100.08
CHL	MSR	796647	2002-12-05	100.12	100.08	100.08
CHL	MSR	796648	2002-12-05	100.10	100.10	100.08
CHL	MSR	796649	2002-12-05	100.10	100.10	100.08
CHL	MSR	796650	2002-12-05	100.09	100.10	100.08

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACOR
CHL	01	796650	0002-11-05	100.09	099.98	100.02
CHL	01	796651	0002-11-05	100.09	100.11	100.02
CHL	01	796652	0002-11-05	100.07	100.08	100.00
CHL	01	796653	0002-11-05	100.10	100.04	100.02
CHL	01	796654	0002-11-05	100.10	100.03	100.01
CHL	01	796655	0002-11-05	100.15	100.15	100.09
CHL	01	796656	0002-11-05	100.09	100.08	100.09
CHL	01	796657	0002-11-05	100.09	100.07	100.04
CHL	01	796658	0002-11-05	100.10	100.09	100.04
CHL	01	796659	0002-11-05	100.09	100.09	100.02
CHL	01	796660	0002-11-05	100.10	100.09	100.01
CHL	01	796661	0002-11-05	100.09	100.09	100.09
CHL	01	796662	0002-11-05	100.09	100.07	100.09
CHL	01	796663	0002-11-05	100.09	100.04	100.03
CHL	01	796664	0002-11-05	100.09	100.04	100.03
CHL	01	796665	0002-11-05	100.15	100.15	100.09
CHL	01	796666	0002-11-05	100.09	100.08	100.09
CHL	01	796667	0002-11-05	100.15	100.08	100.02
CHL	01	796668	0002-11-05	100.10	100.09	100.01
CHL	01	796669	0002-11-05	100.10	100.09	100.09
CHL	01	796670	0002-11-05	100.11	099.99	100.09
CHL	01	796671	0002-11-05	100.09	100.05	100.04
CHL	01	796672	0002-11-05	100.11	100.04	100.04
CHL	01	796673	0002-11-05	100.11	100.14	100.08
CHL	01	796674	0002-11-05	100.09	100.14	100.08
CHL	01	796675	0002-11-05	100.09	100.09	100.00
CHL	01	796676	0002-11-05	100.09	100.04	100.01
CHL	01	796677	0002-11-05	100.09	100.04	100.04
CHL	01	796678	0002-11-05	100.09	100.04	099.97
CHL	01	796679	0002-11-05	100.11	100.07	100.01
CHL	01	796680	0002-11-05	100.09	100.07	100.01
CHL	01	796681	0002-11-05	100.09	100.05	100.01
CHL	01	796682	0002-11-05	100.07	100.09	099.97
CHL	01	796683	0002-11-05	100.09	100.09	100.02
CHL	01	796684	0002-11-05	100.10	100.04	100.04
CHL	01	796685	0002-11-05	100.08	100.04	100.07
CHL	01	796686	0002-11-05	100.10	100.04	100.04
CHL	01	796687	0002-11-05	100.10	100.04	100.04
CHL	01	796688	0002-11-05	100.10	100.04	100.04
CHL	01	796689	0002-11-05	100.11	100.04	100.09
CHL	01	796690	0002-11-05	100.12	100.04	100.07
CHL	01	796691	0002-11-05	100.09	100.04	100.04
CHL	01	796692	0002-11-05	100.10	100.04	100.04
CHL	01	796693	0002-11-05	100.10	100.04	100.04
CHL	01	796694	0002-11-05	100.10	100.04	100.04
CHL	01	796695	0002-11-05	100.10	100.04	100.04
CHL	01	796696	0002-11-05	100.10	100.04	100.04
CHL	01	796697	0002-11-05	100.10	100.04	100.04
CHL	01	796698	0002-11-05	100.10	100.04	100.04
CHL	01	796699	0002-11-05	100.10	100.04	100.04

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFactor
CHLUMBERGER	D9	780570	2002-11-13	099.927	100.222	099.81
CHLUMBERGER	D9	780571	2002-11-13	100.07	100.222	100.29
CHLUMBERGER	D9	780572	2002-11-13	100.222	099.94	100.11
CHLUMBERGER	D9	780573	2002-11-13	099.99	100.222	099.98
CHLUMBERGER	D9	780574	2002-11-13	100.15	100.222	099.97
CHLUMBERGER	D9	780575	2002-11-13	100.222	100.222	100.12
CHLUMBERGER	D9	780576	2002-11-13	099.75	100.222	100.12
CHLUMBERGER	D9	780577	2002-11-13	100.07	100.222	100.12
CHLUMBERGER	D9	780578	2002-11-13	099.99	100.222	100.40
CHLUMBERGER	D9	780579	2002-11-13	100.04	100.222	099.71
CHLUMBERGER	D9	780580	2002-11-13	100.10	100.222	100.25
CHLUMBERGER	D9	780581	2002-11-13	100.49	100.222	100.04
CHLUMBERGER	D9	780582	2002-11-13	099.78	100.222	100.17
CHLUMBERGER	D9	780583	2002-11-13	100.13	100.222	099.82
CHLUMBERGER	D9	780584	2002-11-13	100.13	100.222	100.03
CHLUMBERGER	D9	780585	2002-11-13	100.13	100.222	100.03
CHLUMBERGER	D9	780586	2002-11-13	100.13	100.222	100.03
CHLUMBERGER	D9	780587	2002-11-13	100.13	100.222	100.03
CHLUMBERGER	D9	780588	2002-11-13	100.13	100.222	100.03
CHLUMBERGER	D9	780589	2002-11-13	100.13	100.222	100.03
CHLUMBERGER	D9	780590	2002-11-13	100.13	100.222	100.03
CHLUMBERGER	D9	780591	2002-11-13	100.13	100.222	100.03
CHLUMBERGER	D9	780592	2002-11-13	100.13	100.222	100.03
CHLUMBERGER	D9	780593	2002-11-13	100.13	100.222	100.03
CHLUMBERGER	D9	780594	2002-11-13	100.13	100.222	100.03
CHLUMBERGER	D9	780595	2002-11-13	100.13	100.222	100.03
CHLUMBERGER	D9	780596	2002-11-13	100.13	100.222	100.03
CHLUMBERGER	D9	780597	2002-11-13	100.13	100.222	100.03
CHLUMBERGER	D9	780598	2002-11-13	100.13	100.222	100.03
CHLUMBERGER	D9	780599	2002-11-13	100.13	100.222	100.03
CHLUMBERGER	D9	780600	2002-11-13	100.13	100.222	100.03
CHLUMBERGER	D9	780601	2002-11-13	100.13	100.222	100.03
CHLUMBERGER	D9	780602	2002-11-13	100.13	100.222	100.03
CHLUMBERGER	D9	780603	2002-11-13	100.13	100.222	100.03
CHLUMBERGER	D9	780604	2002-11-13	100.13	100.222	100.03
CHLUMBERGER	D9	780605	2002-11-13	100.13	100.222	100.03
CHLUMBERGER	D9	780606	2002-11-13	100.13	100.222	100.03
CHLUMBERGER	D9	780607	2002-11-13	100.13	100.222	100.03
CHLUMBERGER	D9	780608	2002-11-13	100.13	100.222	100.03
CHLUMBERGER	D9	780609	2002-11-13	100.13	100.222	100.03
CHLUMBERGER	D9	780610	2002-11-13	100.13	100.222	100.03
CHLUMBERGER	D9	780611	2002-11-13	100.13	100.222	100.03
CHLUMBERGER	D9	780612	2002-11-13	100.13	100.222	100.03
CHLUMBERGER	D9	780613	2002-11-13	100.13	100.222	100.03
CHLUMBERGER	D9	780614	2002-11-13	100.13	100.222	100.03
CHLUMBERGER	D9	780615	2002-11-13	100.13	100.222	100.03
CHLUMBERGER	D9	780616	2002-11-13	100.13	100.222	100.03
CHLUMBERGER	D9	780617	2002-11-13	100.13	100.222	100.03
CHLUMBERGER	D9	780618	2002-11-13	100.13	100.222	100.03
CHLUMBERGER	D9	780619	2002-11-13	100.13	100.222	100.03
CHLUMBERGER	D9	780620	2002-11-13	100.13	100.222	100.03

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACOR
CHL UMSE	D9	7806620	11-11-03	100.15	100.34	100.12
CHL UMSE	D9	7806621	11-11-03	099.91	100.18	100.57
CHL UMSE	D9	7806622	11-11-03	099.95	100.13	100.55
CHL UMSE	D9	7806623	11-11-03	099.93	100.12	100.03
CHL UMSE	D9	7806624	11-11-03	100.25	100.08	100.62
CHL UMSE	D9	7806625	11-11-03	100.23	100.07	100.48
CHL UMSE	D9	7806626	11-11-03	100.13	099.99	100.42
CHL UMSE	D9	7806627	11-11-03	100.10	099.99	100.24
CHL UMSE	D9	7806628	11-11-03	099.97	100.27	100.15
CHL UMSE	D9	7806629	11-11-03	100.00	099.99	100.24
CHL UMSE	D9	7806630	11-11-03	100.04	099.99	099.25
CHL UMSE	D9	7806631	11-11-03	100.04	100.24	100.20
CHL UMSE	D9	7806632	11-11-03	099.76	100.17	100.00
CHL UMSE	D9	7806633	11-11-03	099.94	100.29	099.91
CHL UMSE	D9	7806634	11-11-03	099.87	100.27	100.11
CHL UMSE	D9	7806635	11-11-03	100.00	100.30	100.31
CHL UMSE	D9	7806636	11-11-03	099.97	100.42	100.32
CHL UMSE	D9	7806637	11-11-03	100.00	100.01	100.14
CHL UMSE	D9	7806638	11-11-03	100.13	100.19	100.29
CHL UMSE	D9	7806639	11-11-03	100.15	100.17	099.85
CHL UMSE	D9	7806640	11-11-03	099.79	100.05	100.47
CHL UMSE	D9	7806641	11-11-03	100.05	100.02	099.79
CHL UMSE	D9	7806642	11-11-03	099.87	099.95	100.21
CHL UMSE	D9	7806643	11-11-03	100.02	099.93	099.75
CHL UMSE	D9	7806644	11-11-03	099.80	100.29	099.97
CHL UMSE	D9	7806645	11-11-03	099.97	099.79	099.97
CHL UMSE	D9	7806646	11-11-03	100.00	099.97	100.28
CHL UMSE	D9	7806647	11-11-03	099.90	099.97	100.17
CHL UMSE	D9	7806648	11-11-03	099.96	100.25	100.29
CHL UMSE	D9	7806649	11-11-03	100.14	100.30	100.71
CHL UMSE	D9	7806650	11-11-03	100.07	100.24	100.02
CHL UMSE	D9	7806651	11-11-03	099.97	100.44	100.13
CHL UMSE	D9	7806652	11-11-03	100.05	099.91	099.48
CHL UMSE	D9	7806653	11-11-03	100.03	100.08	100.31
CHL UMSE	D9	7806654	11-11-03	100.03	100.00	100.02
CHL UMSE	D9	7806655	11-11-03	099.92	100.29	100.40
CHL UMSE	D9	7806656	11-11-03	100.05	100.20	100.19
CHL UMSE	D9	7806657	11-11-03	099.76	099.91	099.97
CHL UMSE	D9	7806658	11-11-03	100.07	100.08	100.31
CHL UMSE	D9	7806659	11-11-03	100.03	100.00	100.40
CHL UMSE	D9	7806660	11-11-03	099.98	100.29	100.40
CHL UMSE	D9	7806661	11-11-03	100.00	100.20	100.19
CHL UMSE	D9	7806662	11-11-03	099.95	099.82	100.48
CHL UMSE	D9	7806663	11-11-03	100.23	099.95	100.45
CHL UMSE	D9	7806664	11-11-03	100.00	100.20	099.90
CHL UMSE	D9	7806665	11-11-03	099.97	100.09	100.46
CHL UMSE	D9	7806666	11-11-03	100.07	100.43	099.81
CHL UMSE	D9	7806667	11-11-03	099.89	100.42	100.22
CHL UMSE	D9	7806668	11-11-03	099.89	100.04	

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
CHLUMBER	D9	780670	2002-12-18	100.09	100.29	100.30
CHLUMBER	D9	780671	2002-12-18	100.08	100.04	100.44
CHLUMBER	D9	780672	2002-12-18	99.99	100.19	100.10
CHLUMBER	D9	780673	2002-12-18	99.93	100.34	100.34
CHLUMBER	D9	780674	2002-12-18	99.97	100.35	99.95
CHLUMBER	D9	780675	2002-12-18	100.02	100.38	99.99
CHLUMBER	D9	780676	2002-12-18	99.82	100.11	100.29
CHLUMBER	D9	780677	2002-12-18	99.84	100.08	100.19
CHLUMBER	D9	780678	2002-12-18	100.11	100.28	100.30
CHLUMBER	D9	780679	2002-12-18	99.86	100.28	99.83
CHLUMBER	D9	780680	2002-12-18	100.22	100.48	100.52
CHLUMBER	D9	780681	2002-12-18	100.12	100.48	100.14
CHLUMBER	D9	780682	2002-12-18	100.17	100.48	100.14
CHLUMBER	D9	780683	2002-12-18	100.06	99.94	100.19
CHLUMBER	D9	780684	2002-12-18	100.15	100.13	100.21
CHLUMBER	D9	780685	2002-12-18	100.04	100.34	99.99
CHLUMBER	D9	780686	2002-12-18	99.84	100.24	99.99
CHLUMBER	D9	780687	2002-12-18	99.91	100.33	99.92
CHLUMBER	D9	780688	2002-12-18	99.97	100.33	99.92
CHLUMBER	D9	780689	2002-12-18	100.17	100.33	100.42
CHLUMBER	D9	780690	2002-12-18	100.04	100.17	100.39
CHLUMBER	D9	780691	2002-12-18	99.89	100.34	100.39
CHLUMBER	D9	780692	2002-12-18	99.85	100.34	99.49
CHLUMBER	D9	780693	2002-12-18	100.05	100.14	100.33
CHLUMBER	D9	780694	2002-12-18	100.08	100.27	100.21
CHLUMBER	D9	780695	2002-12-18	99.99	100.27	100.21
CHLUMBER	D9	780696	2002-12-18	100.07	100.42	100.01
CHLUMBER	D9	780697	2002-12-18	99.83	99.87	100.27
CHLUMBER	D9	780698	2002-12-18	100.05	99.94	100.06
CHLUMBER	D9	780699	2002-12-18	99.99	99.97	99.89
CHLUMBER	D9	780700	2002-12-18	100.75	100.23	99.99
CHLUMBER	D9	780701	2002-12-18	100.07	99.99	100.22
CHLUMBER	D9	780702	2002-12-18	100.18	99.99	100.22
CHLUMBER	D9	780703	2002-12-18	99.80	100.34	100.28
CHLUMBER	D9	780704	2002-12-18	99.99	99.99	99.99
CHLUMBER	D9	780705	2002-12-18	99.98	99.98	99.98
CHLUMBER	D9	780706	2002-12-18	99.96	100.35	99.94
CHLUMBER	D9	780707	2002-12-18	100.04	100.38	100.10
CHLUMBER	D9	780708	2002-12-18	100.07	100.37	99.98
CHLUMBER	D9	780709	2002-12-18	99.98	100.34	100.24
CHLUMBER	D9	780710	2002-12-18	99.84	100.32	100.10
CHLUMBER	D9	780711	2002-12-18	99.76	100.19	99.98
CHLUMBER	D9	780712	2002-12-18	99.99	100.23	99.98
CHLUMBER	D9	780713	2002-12-18	100.00	100.30	100.02
CHLUMBER	D9	780714	2002-12-18	99.92	100.15	100.21
CHLUMBER	D9	780715	2002-12-18	100.07	100.04	99.99
CHLUMBER	D9	780716	2002-12-18	99.86	99.92	99.93
CHLUMBER	D9	780717	2002-12-18	99.89	100.24	99.86
CHLUMBER	D9	780718	2002-12-18	99.89	100.24	99.86

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACOR
CHLUMER	D9	780770	11-11-03	099.99	100.06	099.96
CHLUMER	D9	780771	11-11-03	099.84	100.40	100.04
CHLUMER	D9	780772	11-11-03	100.04	099.92	100.04
CHLUMER	D9	780773	11-11-03	099.95	100.06	100.01
CHLUMER	D9	780774	11-11-03	099.82	100.04	099.94
CHLUMER	D9	780775	11-11-03	100.03	100.02	100.02
CHLUMER	D9	780776	11-11-03	100.03	100.42	100.02
CHLUMER	D9	780777	11-11-03	099.99	100.42	099.72
CHLUMER	D9	780778	11-11-03	099.74	099.81	099.89
CHLUMER	D9	780780	11-11-03	100.18	100.17	100.10
CHLUMER	D9	780781	11-11-03	100.04	100.03	100.10
CHLUMER	D9	780782	11-11-03	100.13	099.85	100.06
CHLUMER	D9	780783	11-11-03	099.79	100.37	100.02
CHLUMER	D9	780784	11-11-03	100.02	100.02	100.02
CHLUMER	D9	780785	11-11-03	100.02	100.02	100.02
CHLUMER	D9	780787	11-11-03	100.02	100.02	100.02
CHLUMER	D9	780788	11-11-03	100.02	100.02	100.02
CHLUMER	D9	780789	11-11-03	100.07	100.11	100.02
CHLUMER	D9	780790	11-11-03	099.78	100.40	100.04
CHLUMER	D9	780791	11-11-03	099.78	100.09	099.74
CHLUMER	D9	780792	11-11-03	099.86	099.47	100.04
CHLUMER	D9	780794	11-11-03	099.79	100.37	100.44
CHLUMER	D9	780795	11-11-03	100.17	100.01	099.82
CHLUMER	D9	780797	11-11-03	100.05	100.44	100.15
CHLUMER	D9	780800	11-11-03	100.02	099.94	100.02
CHLUMER	D9	780801	11-11-03	099.94	100.37	100.02
CHLUMER	D9	780802	11-11-03	100.01	100.44	100.02
CHLUMER	D9	780803	11-11-03	099.87	100.09	099.91
CHLUMER	D9	780804	11-11-03	100.04	100.09	100.02
CHLUMER	D9	780805	11-11-03	100.12	100.09	100.02
CHLUMER	D9	780806	11-11-03	099.77	100.03	099.82
CHLUMER	D9	780807	11-11-03	100.08	100.32	100.02
CHLUMER	D9	780809	11-11-03	100.07	100.32	100.02
CHLUMER	D9	780810	11-11-03	100.12	100.32	100.02
CHLUMER	D9	780811	11-11-03	099.83	100.03	099.86
CHLUMER	D9	780812	11-11-03	100.07	100.03	100.01
CHLUMER	D9	780814	11-11-03	099.81	099.99	100.07
CHLUMER	D9	780817	11-11-03	099.89	100.17	099.87
CHLUMER	D9	780818	11-11-03	099.81	100.02	099.80

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PF FACTOR
CHLUMBERGER	D9	7808829	2002-11-18	100.45	100.04	100.48
CHLUMBERGER	D9	7808831	2002-11-18	100.27	100.21	100.47
CHLUMBERGER	D9	7808832	2002-11-18	100.26	100.17	100.27
CHLUMBERGER	D9	7808833	2002-11-18	100.97	100.92	100.41
CHLUMBERGER	D9	7808834	2002-11-18	100.74	100.07	100.72
CHLUMBERGER	D9	7808835	2002-11-18	100.99	100.29	100.41
CHLUMBERGER	D9	7808836	2002-11-18	100.92	100.44	100.44
CHLUMBERGER	D9	7808837	2002-11-18	100.08	100.07	100.14
CHLUMBERGER	D9	7808838	2002-11-18	100.15	100.04	100.25
CHLUMBERGER	D9	7808839	2002-11-18	100.84	100.48	100.83
CHLUMBERGER	D9	7808840	2002-11-18	100.07	100.04	100.04
CHLUMBERGER	D9	7808841	2002-11-18	100.07	100.12	100.21
CHLUMBERGER	D9	7808842	2002-11-18	100.27	100.12	100.44
CHLUMBERGER	D9	7808843	2002-11-18	100.07	100.04	100.04
CHLUMBERGER	D9	7808844	2002-11-18	100.07	100.12	100.21
CHLUMBERGER	D9	7808845	2002-11-18	100.72	100.04	100.44
CHLUMBERGER	D9	7808846	2002-11-18	100.07	100.12	100.21
CHLUMBERGER	D9	7808847	2002-11-18	100.07	100.04	100.04
CHLUMBERGER	D9	7808848	2002-11-18	100.27	100.12	100.44
CHLUMBERGER	D9	7808849	2002-11-18	100.07	100.04	100.04
CHLUMBERGER	D9	7808850	2002-11-18	100.27	100.12	100.44
CHLUMBERGER	D9	7808851	2002-11-18	100.07	100.04	100.04
CHLUMBERGER	D9	7808852	2002-11-18	100.27	100.12	100.44
CHLUMBERGER	D9	7808853	2002-11-18	100.07	100.04	100.04
CHLUMBERGER	D9	7808854	2002-11-18	100.27	100.12	100.44
CHLUMBERGER	D9	7808855	2002-11-18	100.07	100.04	100.04
CHLUMBERGER	D9	7808856	2002-11-18	100.27	100.12	100.44
CHLUMBERGER	D9	7808857	2002-11-18	100.07	100.04	100.04
CHLUMBERGER	D9	7808858	2002-11-18	100.27	100.12	100.44
CHLUMBERGER	D9	7808859	2002-11-18	100.07	100.04	100.04
CHLUMBERGER	D9	7808860	2002-11-18	100.27	100.12	100.44
CHLUMBERGER	D9	7808861	2002-11-18	100.07	100.04	100.04
CHLUMBERGER	D9	7808862	2002-11-18	100.27	100.12	100.44
CHLUMBERGER	D9	7808863	2002-11-18	100.07	100.04	100.04
CHLUMBERGER	D9	7808864	2002-11-18	100.27	100.12	100.44
CHLUMBERGER	D9	7808865	2002-11-18	100.07	100.04	100.04
CHLUMBERGER	D9	7808866	2002-11-18	100.27	100.12	100.44
CHLUMBERGER	D9	7808867	2002-11-18	100.07	100.04	100.04
CHLUMBERGER	D9	7808868	2002-11-18	100.27	100.12	100.44
CHLUMBERGER	D9	7808869	2002-11-18	100.07	100.04	100.04
CHLUMBERGER	D9	7808870	2002-11-18	100.27	100.12	100.44

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACOR
CHL UM8E8R33R	D9	780879	2002-12-11	100.07	100.33	100.17
CHL UM8E8R33R	D9	780871	2002-12-11	100.24	100.34	100.46
CHL UM8E8R33R	D9	780872	2002-12-11	100.05	100.09	100.27
CHL UM8E8R33R	D9	780873	2002-12-11	099.87	100.19	100.17
CHL UM8E8R33R	D9	780874	2002-12-11	100.14	099.94	099.21
CHL UM8E8R33R	D9	780875	2002-12-11	099.72	100.23	099.49
CHL UM8E8R33R	D9	780876	2002-12-11	099.83	099.89	100.24
CHL UM8E8R33R	D9	780877	2002-12-11	100.10	100.09	100.41
CHL UM8E8R33R	D9	780878	2002-12-11	100.14	100.12	100.82
CHL UM8E8R33R	D9	780879	2002-12-11	100.09	100.44	100.49
CHL UM8E8R33R	D9	780880	2002-12-11	100.23	100.04	100.49
CHL UM8E8R33R	D9	780881	2002-12-11	100.25	100.27	100.45
CHL UM8E8R33R	D9	780882	2002-12-11	099.02	100.44	100.41
CHL UM8E8R33R	D9	780883	2002-12-11	100.02	100.23	100.29
CHL UM8E8R33R	D9	780884	2002-12-11	100.02	100.23	100.29
CHL UM8E8R33R	D9	780885	2002-12-11	099.95	100.49	100.24
CHL UM8E8R33R	D9	780886	2002-12-11	099.95	100.24	100.24
CHL UM8E8R33R	D9	780887	2002-12-11	100.06	100.27	100.54
CHL UM8E8R33R	D9	780888	2002-12-11	099.24	100.24	100.04
CHL UM8E8R33R	D9	780889	2002-12-11	099.79	100.17	099.99
CHL UM8E8R33R	D9	780890	2002-12-11	100.11	100.07	100.29
CHL UM8E8R33R	D9	780891	2002-12-11	099.94	099.27	100.06
CHL UM8E8R33R	D9	780892	2002-12-11	100.25	100.33	100.22
CHL UM8E8R33R	D9	780893	2002-12-11	100.96	100.33	100.09
CHL UM8E8R33R	D9	780894	2002-12-11	099.96	100.33	100.09
CHL UM8E8R33R	D9	780895	2002-12-11	099.82	100.12	099.96
CHL UM8E8R33R	D9	780896	2002-12-11	099.87	100.10	100.51
CHL UM8E8R33R	D9	780897	2002-12-11	099.94	099.73	099.80
CHL UM8E8R33R	D9	780898	2002-12-11	099.95	100.13	100.41
CHL UM8E8R33R	D9	780899	2002-12-11	099.77	100.14	100.43
CHL UM8E8R33R	D9	780900	2002-12-11	100.26	100.38	100.22
CHL UM8E8R33R	D9	780901	2002-12-11	099.91	100.44	099.96
CHL UM8E8R33R	D9	780902	2002-12-11	100.05	100.07	100.25
CHL UM8E8R33R	D9	780903	2002-12-11	099.95	100.09	099.26
CHL UM8E8R33R	D9	780904	2002-12-11	100.15	100.28	100.21
CHL UM8E8R33R	D9	780905	2002-12-11	100.09	099.94	100.35
CHL UM8E8R33R	D9	780906	2002-12-11	100.07	099.79	100.16
CHL UM8E8R33R	D9	780907	2002-12-11	100.04	099.97	100.07
CHL UM8E8R33R	D9	780908	2002-12-11	100.13	100.09	100.24
CHL UM8E8R33R	D9	780909	2002-12-11	100.01	100.09	099.78
CHL UM8E8R33R	D9	780910	2002-12-11	100.08	100.20	100.04
CHL UM8E8R33R	D9	780911	2002-12-11	099.94	099.69	099.29
CHL UM8E8R33R	D9	780912	2002-12-11	100.13	100.16	100.06
CHL UM8E8R33R	D9	780913	2002-12-11	099.91	099.69	100.06
CHL UM8E8R33R	D9	780914	2002-12-11	100.08	100.17	100.06
CHL UM8E8R33R	D9	780915	2002-12-11	099.84	099.69	100.06
CHL UM8E8R33R	D9	780916	2002-12-11	099.92	100.10	100.06
CHL UM8E8R33R	D9	780917	2002-12-11	099.92	100.10	100.06
CHL UM8E8R33R	D9	780918	2002-12-11	099.92	100.10	100.06
CHL UM8E8R33R	D9	780919	2002-12-11	099.92	100.10	100.06
CHL UM8E8R33R	D9	780920	2002-12-11	099.92	100.10	100.06

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
UNB	D9	7280320	2002-11-11	100.14	99.72	100.25
UNB	D9	7280321	2002-11-11	109.87	100.31	100.53
UNB	D9	7280322	2002-11-11	100.25	100.33	100.21
UNB	D9	7280323	2002-11-11	100.25	100.39	100.42
UNB	D9	7280324	2002-11-11	100.25	100.10	100.22
UNB	D9	7280325	2002-11-11	100.15	100.12	100.40
UNB	D9	7280327	2002-11-11	100.02	100.12	100.27
UNB	D9	7280328	2002-11-11	100.02	100.04	100.44
UNB	D9	7280329	2002-11-11	100.01	100.04	100.07
UNB	D9	7280331	2002-11-11	100.10	100.04	100.19
UNB	D9	7280332	2002-11-11	100.01	100.03	100.07
UNB	D9	7280333	2002-11-11	100.01	100.03	100.30
UNB	D9	7280334	2002-11-11	100.01	100.03	100.07
UNB	D9	7280335	2002-11-11	100.01	100.03	100.30
UNB	D9	7280336	2002-11-11	100.01	100.03	100.17
UNB	D9	7280337	2002-11-11	100.01	100.03	100.37
UNB	D9	7280338	2002-11-11	100.01	100.03	100.24
UNB	D9	7280339	2002-11-11	100.01	100.03	100.24
UNB	D9	7280340	2002-11-11	100.01	100.03	100.77
UNB	D9	7280341	2002-11-11	100.01	100.03	100.05
UNB	D9	7280342	2002-11-11	100.01	100.03	100.29
UNB	D9	7280343	2002-11-11	100.01	100.03	100.22
UNB	D9	7280344	2002-11-11	100.01	100.03	100.14
UNB	D9	7280345	2002-11-11	100.01	100.03	100.14
UNB	D9	7280346	2002-11-11	100.01	100.03	100.20
UNB	D9	7280347	2002-11-11	100.01	100.03	100.77
UNB	D9	7280348	2002-11-11	100.01	100.03	100.41
UNB	D9	7280349	2002-11-11	100.01	100.03	100.39
UNB	D9	7280350	2002-11-11	100.01	100.03	100.52
UNB	D9	7280351	2002-11-11	100.01	100.03	100.16
UNB	D9	7280352	2002-11-11	100.01	100.03	100.49
UNB	D9	7280353	2002-11-11	100.01	100.03	100.19
UNB	D9	7280354	2002-11-11	100.01	100.03	100.70
UNB	D9	7280355	2002-11-11	100.01	100.03	100.23
UNB	D9	7280356	2002-11-11	100.01	100.03	100.43
UNB	D9	7280357	2002-11-11	100.01	100.03	100.17
UNB	D9	7280358	2002-11-11	100.01	100.03	100.49
UNB	D9	7280359	2002-11-11	100.01	100.03	100.17
UNB	D9	7280360	2002-11-11	100.01	100.03	100.37

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACITOR
CHLUMBER	D9	781070	2002-12-19	100.05	99.97	100.16
CHLUMBER	D9	781071	2002-12-19	99.89	100.15	100.21
CHLUMBER	D9	781072	2002-12-19	99.86	100.21	99.88
CHLUMBER	D9	781073	2002-12-19	100.02	100.15	100.24
CHLUMBER	D9	781074	2002-12-19	99.83	100.26	100.28
CHLUMBER	D9	781075	2002-12-19	100.04	100.15	100.27
CHLUMBER	D9	781076	2002-12-19	100.02	100.19	99.97
CHLUMBER	D9	781077	2002-12-19	100.05	100.18	100.21
CHLUMBER	D9	781078	2002-12-19	99.92	100.11	100.26
CHLUMBER	D9	781079	2002-12-19	99.99	100.11	100.29
CHLUMBER	D9	781080	2002-12-19	99.99	100.21	100.29
CHLUMBER	D9	781081	2002-12-19	99.93	100.11	99.97
CHLUMBER	D9	781082	2002-12-19	100.05	100.17	100.05
CHLUMBER	D9	781083	2002-12-19	99.93	100.17	99.98
CHLUMBER	D9	781084	2002-12-19	100.11	99.94	100.22
CHLUMBER	D9	781085	2002-12-19	100.11	100.15	100.42
CHLUMBER	D9	781086	2002-12-19	100.07	100.22	100.04
CHLUMBER	D9	781087	2002-12-19	100.11	100.22	99.94
CHLUMBER	D9	781088	2002-12-19	99.90	100.25	100.15
CHLUMBER	D9	781089	2002-12-19	100.11	100.25	100.15
CHLUMBER	D9	781090	2002-12-19	100.02	99.97	100.25
CHLUMBER	D9	781091	2002-12-19	99.91	100.28	100.21
CHLUMBER	D9	781092	2002-12-19	99.91	100.28	100.21
CHLUMBER	D9	781093	2002-12-19	99.98	100.09	100.24
CHLUMBER	D9	781094	2002-12-19	99.91	100.35	100.22
CHLUMBER	D9	781095	2002-12-19	100.01	100.18	99.88
CHLUMBER	D9	781096	2002-12-19	99.91	99.72	99.94
CHLUMBER	D9	781097	2002-12-19	99.98	100.44	99.74
CHLUMBER	D9	781098	2002-12-19	100.14	100.21	100.28
CHLUMBER	D9	781099	2002-12-19	100.01	100.04	100.38
CHLUMBER	D9	781100	2002-12-19	100.15	100.44	100.14
CHLUMBER	D9	781101	2002-12-19	100.07	100.25	100.04
CHLUMBER	D9	781102	2002-12-19	99.76	100.14	99.96
CHLUMBER	D9	781103	2002-12-19	99.92	100.20	99.80
CHLUMBER	D9	781104	2002-12-19	100.10	100.07	100.12
CHLUMBER	D9	781105	2002-12-19	100.20	100.27	100.44
CHLUMBER	D9	781106	2002-12-19	100.10	100.67	100.54
CHLUMBER	D9	781107	2002-12-19	100.17	99.95	100.06
CHLUMBER	D9	781108	2002-12-19	100.30	100.26	100.60
CHLUMBER	D9	781109	2002-12-19	100.05	100.32	99.98
CHLUMBER	D9	781110	2002-12-19	100.11	100.32	100.14
CHLUMBER	D9	781111	2002-12-19	100.11	100.14	100.17
CHLUMBER	D9	781112	2002-12-19	99.94	100.18	100.12
CHLUMBER	D9	781113	2002-12-19	100.02	100.20	100.07
CHLUMBER	D9	781114	2002-12-19	100.08	100.16	100.46
CHLUMBER	D9	781115	2002-12-19	100.01	100.39	99.70
CHLUMBER	D9	781116	2002-12-19	100.05	100.26	100.17
CHLUMBER	D9	781117	2002-12-19	99.94	100.16	99.77
CHLUMBER	D9	781118	2002-12-19	99.92	100.16	99.99
CHLUMBER	D9	781119	2002-12-19	100.14	100.39	100.14

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACOR
SCHLUMBERGER	D9	78111210	12-18	099.97	100.29	100.29
SCHLUMBERGER	D9	78111211	12-18	099.94	100.09	100.02
SCHLUMBERGER	D9	78111212	12-18	099.77	100.10	100.02
SCHLUMBERGER	D9	78111213	12-18	100.01	100.17	099.98
SCHLUMBERGER	D9	78111214	12-18	099.87	100.20	100.12
SCHLUMBERGER	D9	78111215	12-18	100.29	100.24	100.42
SCHLUMBERGER	D9	78111216	12-18	099.89	099.79	099.99
SCHLUMBERGER	D9	78111217	12-18	100.10	100.36	100.00
SCHLUMBERGER	D9	78111218	12-18	100.10	100.36	100.14
SCHLUMBERGER	D9	78111219	12-18	100.09	100.40	100.74
SCHLUMBERGER	D9	78111220	12-18	100.10	100.25	100.33
SCHLUMBERGER	D9	78111221	12-18	099.90	100.38	100.30
SCHLUMBERGER	D9	78111222	12-18	100.07	100.19	100.19
SCHLUMBERGER	D9	78111223	12-18	099.21	100.07	100.14
SCHLUMBERGER	D9	78111224	12-18	100.02	100.09	099.89
SCHLUMBERGER	D9	78111225	12-18	100.02	100.24	099.92
SCHLUMBERGER	D9	78111226	12-18	099.94	100.04	100.01
SCHLUMBERGER	D9	78111227	12-18	099.71	099.91	100.01
SCHLUMBERGER	D9	78111228	12-18	099.94	100.04	100.01
SCHLUMBERGER	D9	78111229	12-18	100.05	099.90	100.01
SCHLUMBERGER	D9	78111230	12-18	100.06	100.24	100.41
SCHLUMBERGER	D9	78111231	12-18	099.88	100.05	100.04
SCHLUMBERGER	D9	78111232	12-18	099.88	100.12	099.82
SCHLUMBERGER	D9	78111233	12-18	100.01	100.35	100.16
SCHLUMBERGER	D9	78111234	12-18	100.01	100.12	100.47
SCHLUMBERGER	D9	78111235	12-18	099.84	100.34	099.97
SCHLUMBERGER	D9	78111236	12-18	099.95	100.30	100.07
SCHLUMBERGER	D9	78111237	12-18	100.01	100.16	100.79
SCHLUMBERGER	D9	78111238	12-18	100.12	100.16	099.84
SCHLUMBERGER	D9	78111239	12-18	099.92	100.24	100.79
SCHLUMBERGER	D9	78111240	12-18	100.06	100.05	100.79
SCHLUMBERGER	D9	78111241	12-18	099.88	100.01	099.82
SCHLUMBERGER	D9	78111242	12-18	100.01	100.12	100.41
SCHLUMBERGER	D9	78111243	12-18	099.88	100.12	099.82
SCHLUMBERGER	D9	78111244	12-18	100.01	100.34	100.16
SCHLUMBERGER	D9	78111245	12-18	099.84	100.12	100.47
SCHLUMBERGER	D9	78111246	12-18	099.95	100.30	099.97
SCHLUMBERGER	D9	78111247	12-18	100.01	100.16	100.07
SCHLUMBERGER	D9	78111248	12-18	100.12	100.16	100.79
SCHLUMBERGER	D9	78111249	12-18	099.92	100.24	100.79
SCHLUMBERGER	D9	78111250	12-18	100.08	100.01	099.82
SCHLUMBERGER	D9	78111251	12-18	100.08	100.30	099.82
SCHLUMBERGER	D9	78111252	12-18	099.94	100.01	099.92
SCHLUMBERGER	D9	78111253	12-18	099.97	100.17	100.27
SCHLUMBERGER	D9	78111254	12-18	099.96	100.14	100.20
SCHLUMBERGER	D9	78111255	12-18	099.98	100.32	100.14
SCHLUMBERGER	D9	78111256	12-18	099.94	100.24	100.09
SCHLUMBERGER	D9	78111257	12-18	100.15	100.13	100.48
SCHLUMBERGER	D9	78111258	12-18	100.07	100.08	100.14
SCHLUMBERGER	D9	78111259	12-18	099.83	099.88	099.81
SCHLUMBERGER	D9	78111260	12-18	100.05	100.13	099.92
SCHLUMBERGER	D9	78111261	12-18	100.05	100.13	099.92
SCHLUMBERGER	D9	78111262	12-18	099.99	099.94	100.11
SCHLUMBERGER	D9	78111263	12-18	099.85	100.49	100.28
SCHLUMBERGER	D9	78111264	12-18	099.82	100.49	100.44
SCHLUMBERGER	D9	78111265	12-18	100.01	100.05	100.16
SCHLUMBERGER	D9	78111266	12-18	100.04	100.30	100.16
SCHLUMBERGER	D9	78111267	12-18	099.87	100.10	099.78
SCHLUMBERGER	D9	78111268	12-18	099.87	100.10	099.78

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PF FACTOR
SCHLUMBERGER	D9	7811171	1103	099.99	100.12	099.89
SCHLUMBERGER	D9	7811172	1103	100.14	100.01	100.01
SCHLUMBERGER	D9	7811173	1103	100.06	100.21	100.15
SCHLUMBERGER	D9	7811174	1103	099.96	100.22	100.21
SCHLUMBERGER	D9	7811175	1103	099.75	099.88	099.88
SCHLUMBERGER	D9	7811176	1103	100.09	099.82	099.88
SCHLUMBERGER	D9	7811177	1103	099.97	100.04	100.07
SCHLUMBERGER	D9	7811178	1103	099.92	100.32	100.19
SCHLUMBERGER	D9	7811179	1103	100.10	100.49	100.39
SCHLUMBERGER	D9	7811180	1103	099.97	100.44	100.39
SCHLUMBERGER	D9	7811181	1103	099.92	099.92	100.39
SCHLUMBERGER	D9	7811182	1103	099.87	099.99	099.39
SCHLUMBERGER	D9	7811183	1103	099.97	100.31	099.39
SCHLUMBERGER	D9	7811184	1103	100.00	100.28	100.29
SCHLUMBERGER	D9	7811185	1103	100.18	100.11	100.25
SCHLUMBERGER	D9	7811186	1103	100.12	100.24	100.29
SCHLUMBERGER	D9	7811187	1103	100.02	100.19	100.29
SCHLUMBERGER	D9	7811188	1103	100.12	100.14	100.17
SCHLUMBERGER	D9	7811189	1103	099.89	100.36	100.07
SCHLUMBERGER	D9	7811190	1103	100.05	099.96	100.03
SCHLUMBERGER	D9	7811191	1103	099.90	100.14	099.98
SCHLUMBERGER	D9	7811192	1103	099.81	100.45	099.99
SCHLUMBERGER	D9	7811193	1103	100.15	100.30	100.44
SCHLUMBERGER	D9	7811194	1103	100.07	100.21	100.65
SCHLUMBERGER	D9	7811195	1103	100.10	099.73	099.82
SCHLUMBERGER	D9	7811196	1103	100.04	100.27	100.14
SCHLUMBERGER	D9	7811197	1103	100.10	100.39	100.04
SCHLUMBERGER	D9	7811198	1103	100.00	099.97	100.13
SCHLUMBERGER	D9	7811199	1103	100.02	099.95	100.30
SCHLUMBERGER	D9	7812000	1103	100.06	100.02	099.88
SCHLUMBERGER	D9	7812001	1103	100.03	100.41	100.30
SCHLUMBERGER	D9	7812002	1103	099.97	100.24	100.51
SCHLUMBERGER	D9	7812003	1103	099.90	099.94	100.82
SCHLUMBERGER	D9	7812004	1103	100.00	100.31	100.10
SCHLUMBERGER	D9	7812005	1103	099.92	100.19	099.69
SCHLUMBERGER	D9	7812006	1103	100.00	099.92	100.10
SCHLUMBERGER	D9	7812007	1103	099.88	100.16	099.69
SCHLUMBERGER	D9	7812008	1103	099.92	100.16	100.20
SCHLUMBERGER	D9	7812009	1103	099.84	100.10	099.77
SCHLUMBERGER	D9	7812010	1103	100.01	100.33	099.79
SCHLUMBERGER	D9	7812011	1103	099.85	100.34	100.06
SCHLUMBERGER	D9	7812012	1103	099.88	100.37	100.17
SCHLUMBERGER	D9	7812013	1103	099.86	100.40	100.24
SCHLUMBERGER	D9	7812014	1103	100.01	100.10	100.05

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
CHL	LM62	7814419	2002-11-11	99.98	100.41	100.32
CHL	LM62	7814420	2002-11-11	99.98	100.35	99.92
CHL	LM62	7814421	2002-11-11	99.98	100.32	100.12
CHL	LM62	7814422	2002-11-11	99.98	100.37	100.10
CHL	LM62	7814423	2002-11-11	99.98	100.44	100.30
CHL	LM62	7814424	2002-11-11	100.42	100.21	100.33
CHL	LM62	7814425	2002-11-11	100.32	99.99	100.30
CHL	LM62	7814426	2002-11-11	100.32	100.42	100.30
CHL	LM62	7814427	2002-11-11	99.98	100.39	100.30
CHL	LM62	7814428	2002-11-11	99.98	100.42	100.30
CHL	LM62	7814429	2002-11-11	100.32	100.39	100.30
CHL	LM62	7814430	2002-11-11	99.98	100.42	100.30
CHL	LM62	7814431	2002-11-11	99.98	100.42	100.30
CHL	LM62	7814432	2002-11-11	99.98	100.42	100.30
CHL	LM62	7814433	2002-11-11	99.98	100.42	100.30
CHL	LM62	7814434	2002-11-11	99.98	100.42	100.30
CHL	LM62	7814435	2002-11-11	99.98	100.42	100.30
CHL	LM62	7814436	2002-11-11	99.98	100.42	100.30
CHL	LM62	7814437	2002-11-11	99.98	100.42	100.30
CHL	LM62	7814438	2002-11-11	99.98	100.42	100.30
CHL	LM62	7814439	2002-11-11	99.98	100.42	100.30
CHL	LM62	7814440	2002-11-11	99.98	100.42	100.30
CHL	LM62	7814441	2002-11-11	99.98	100.42	100.30
CHL	LM62	7814442	2002-11-11	99.98	100.42	100.30
CHL	LM62	7814443	2002-11-11	99.98	100.42	100.30
CHL	LM62	7814444	2002-11-11	99.98	100.42	100.30
CHL	LM62	7814445	2002-11-11	99.98	100.42	100.30
CHL	LM62	7814446	2002-11-11	99.98	100.42	100.30
CHL	LM62	7814447	2002-11-11	99.98	100.42	100.30
CHL	LM62	7814448	2002-11-11	99.98	100.42	100.30
CHL	LM62	7814449	2002-11-11	99.98	100.42	100.30
CHL	LM62	7814450	2002-11-11	99.98	100.42	100.30
CHL	LM62	7814451	2002-11-11	99.98	100.42	100.30
CHL	LM62	7814452	2002-11-11	99.98	100.42	100.30
CHL	LM62	7814453	2002-11-11	99.98	100.42	100.30
CHL	LM62	7814454	2002-11-11	99.98	100.42	100.30
CHL	LM62	7814455	2002-11-11	99.98	100.42	100.30
CHL	LM62	7814456	2002-11-11	99.98	100.42	100.30
CHL	LM62	7814457	2002-11-11	99.98	100.42	100.30
CHL	LM62	7814458	2002-11-11	99.98	100.42	100.30
CHL	LM62	7814459	2002-11-11	99.98	100.42	100.30
CHL	LM62	7814460	2002-11-11	99.98	100.42	100.30
CHL	LM62	7814461	2002-11-11	99.98	100.42	100.30
CHL	LM62	7814462	2002-11-11	99.98	100.42	100.30
CHL	LM62	7814463	2002-11-11	99.98	100.42	100.30
CHL	LM62	7814464	2002-11-11	99.98	100.42	100.30
CHL	LM62	7814465	2002-11-11	99.98	100.42	100.30
CHL	LM62	7814466	2002-11-11	99.98	100.42	100.30
CHL	LM62	7814467	2002-11-11	99.98	100.42	100.30
CHL	LM62	7814468	2002-11-11	99.98	100.42	100.30
CHL	LM62	7814469	2002-11-11	99.98	100.42	100.30
CHL	LM62	7814470	2002-11-11	99.98	100.42	100.30

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
CHL	1	781520	110303	84	100.119	100.13
CHL	1	781521	110303	105.15	100.119	100.13
CHL	1	781522	110303	109.77	100.119	100.13
CHL	1	781523	110303	108.05	100.119	100.13
CHL	1	781524	110303	99.93	100.119	100.13
CHL	1	781525	110303	99.93	100.119	100.13
CHL	1	781526	110303	99.93	100.119	100.13
CHL	1	781527	110303	99.93	100.119	100.13
CHL	1	781528	110303	99.93	100.119	100.13
CHL	1	781529	110303	99.93	100.119	100.13
CHL	1	781530	110303	99.93	100.119	100.13
CHL	1	781531	110303	99.93	100.119	100.13
CHL	1	781532	110303	99.93	100.119	100.13
CHL	1	781533	110303	99.93	100.119	100.13
CHL	1	781534	110303	99.93	100.119	100.13
CHL	1	781535	110303	99.93	100.119	100.13
CHL	1	781536	110303	99.93	100.119	100.13
CHL	1	781537	110303	99.93	100.119	100.13
CHL	1	781538	110303	99.93	100.119	100.13
CHL	1	781539	110303	99.93	100.119	100.13
CHL	1	781540	110303	99.93	100.119	100.13
CHL	1	781541	110303	99.93	100.119	100.13
CHL	1	781542	110303	99.93	100.119	100.13
CHL	1	781543	110303	99.93	100.119	100.13
CHL	1	781544	110303	99.93	100.119	100.13
CHL	1	781545	110303	99.93	100.119	100.13
CHL	1	781546	110303	99.93	100.119	100.13
CHL	1	781547	110303	99.93	100.119	100.13
CHL	1	781548	110303	99.93	100.119	100.13
CHL	1	781549	110303	99.93	100.119	100.13
CHL	1	781550	110303	99.93	100.119	100.13
CHL	1	781551	110303	99.93	100.119	100.13
CHL	1	781552	110303	99.93	100.119	100.13
CHL	1	781553	110303	99.93	100.119	100.13
CHL	1	781554	110303	99.93	100.119	100.13
CHL	1	781555	110303	99.93	100.119	100.13
CHL	1	781556	110303	99.93	100.119	100.13
CHL	1	781557	110303	99.93	100.119	100.13
CHL	1	781558	110303	99.93	100.119	100.13
CHL	1	781559	110303	99.93	100.119	100.13
CHL	1	781560	110303	99.93	100.119	100.13
CHL	1	781561	110303	99.93	100.119	100.13
CHL	1	781562	110303	99.93	100.119	100.13
CHL	1	781563	110303	99.93	100.119	100.13
CHL	1	781564	110303	99.93	100.119	100.13
CHL	1	781565	110303	99.93	100.119	100.13
CHL	1	781566	110303	99.93	100.119	100.13
CHL	1	781567	110303	99.93	100.119	100.13
CHL	1	781568	110303	99.93	100.119	100.13
CHL	1	781569	110303	99.93	100.119	100.13
CHL	1	781570	110303	99.93	100.119	100.13
CHL	1	781571	110303	99.93	100.119	100.13
CHL	1	781572	110303	99.93	100.119	100.13
CHL	1	781573	110303	99.93	100.119	100.13
CHL	1	781574	110303	99.93	100.119	100.13
CHL	1	781575	110303	99.93	100.119	100.13
CHL	1	781576	110303	99.93	100.119	100.13
CHL	1	781577	110303	99.93	100.119	100.13
CHL	1	781578	110303	99.93	100.119	100.13
CHL	1	781579	110303	99.93	100.119	100.13
CHL	1	781580	110303	99.93	100.119	100.13
CHL	1	781581	110303	99.93	100.119	100.13
CHL	1	781582	110303	99.93	100.119	100.13
CHL	1	781583	110303	99.93	100.119	100.13
CHL	1	781584	110303	99.93	100.119	100.13
CHL	1	781585	110303	99.93	100.119	100.13
CHL	1	781586	110303	99.93	100.119	100.13
CHL	1	781587	110303	99.93	100.119	100.13
CHL	1	781588	110303	99.93	100.119	100.13
CHL	1	781589	110303	99.93	100.119	100.13
CHL	1	781590	110303	99.93	100.119	100.13
CHL	1	781591	110303	99.93	100.119	100.13
CHL	1	781592	110303	99.93	100.119	100.13
CHL	1	781593	110303	99.93	100.119	100.13
CHL	1	781594	110303	99.93	100.119	100.13
CHL	1	781595	110303	99.93	100.119	100.13
CHL	1	781596	110303	99.93	100.119	100.13
CHL	1	781597	110303	99.93	100.119	100.13
CHL	1	781598	110303	99.93	100.119	100.13
CHL	1	781599	110303	99.93	100.119	100.13
CHL	1	781600	110303	99.93	100.119	100.13

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PF FACTOR
SCHLUMBERGER	D9	7815770	2002-12-18	099.72	099.90	100.06
SCHLUMBERGER	D9	7815771	2002-12-18	100.00	100.07	099.90
SCHLUMBERGER	D9	7815772	2002-12-18	100.11	100.17	100.17
SCHLUMBERGER	D9	7815773	2002-12-18	099.96	099.99	100.16
SCHLUMBERGER	D9	7815774	2002-12-18	099.87	100.25	099.88
SCHLUMBERGER	D9	7815775	2002-12-18	099.99	099.96	100.55
SCHLUMBERGER	D9	7815776	2002-12-18	100.09	100.14	100.04
SCHLUMBERGER	D9	7815777	2002-12-18	099.88	100.11	100.04
SCHLUMBERGER	D9	7815778	2002-12-18	079.97	100.33	099.91
SCHLUMBERGER	D9	7815779	2002-12-18	100.01	100.38	099.91
SCHLUMBERGER	D9	7815780	2002-12-18	079.78	099.85	099.89
SCHLUMBERGER	D9	7815781	2002-12-18	100.07	100.37	100.29
SCHLUMBERGER	D9	7815782	2002-12-18	099.79	100.37	099.73
SCHLUMBERGER	D9	7815783	2002-12-18	099.88	100.27	100.49
SCHLUMBERGER	D9	7815784	2002-12-18	099.98	100.19	099.98
SCHLUMBERGER	D9	7815785	2002-12-18	099.97	100.19	100.24
SCHLUMBERGER	D9	7815786	2002-12-18	100.02	100.32	100.18
SCHLUMBERGER	D9	7815787	2002-12-18	099.89	100.04	099.94
SCHLUMBERGER	D9	7815788	2002-12-18	099.89	100.21	100.09
SCHLUMBERGER	D9	7815789	2002-12-18	099.97	100.21	100.41
SCHLUMBERGER	D9	7815790	2002-12-18	100.01	100.30	099.78
SCHLUMBERGER	D9	7815791	2002-12-18	100.07	100.30	100.21
SCHLUMBERGER	D9	7815792	2002-12-18	100.07	100.32	100.24
SCHLUMBERGER	D9	7815793	2002-12-18	099.90	100.32	100.47
SCHLUMBERGER	D9	7815794	2002-12-18	099.79	100.30	100.31
SCHLUMBERGER	D9	7815795	2002-12-18	099.84	100.09	100.04
SCHLUMBERGER	D9	7815796	2002-12-18	099.89	100.00	099.85
SCHLUMBERGER	D9	7815797	2002-12-18	100.14	100.04	100.29
SCHLUMBERGER	D9	7815798	2002-12-18	099.87	100.33	100.20
SCHLUMBERGER	D9	7815799	2002-12-18	099.90	100.33	100.34
SCHLUMBERGER	D9	7815800	2002-12-18	100.21	100.38	100.34
SCHLUMBERGER	D9	7815801	2002-12-18	099.72	100.14	100.32
SCHLUMBERGER	D9	7815802	2002-12-18	099.94	100.12	100.58
SCHLUMBERGER	D9	7815803	2002-12-18	100.03	100.30	100.07
SCHLUMBERGER	D9	7815804	2002-12-18	100.18	099.79	099.82
SCHLUMBERGER	D9	7815805	2002-12-18	099.86	100.45	100.45
SCHLUMBERGER	D9	7815806	2002-12-18	100.13	099.70	100.32
SCHLUMBERGER	D9	7815807	2002-12-18	100.03	100.23	100.03
SCHLUMBERGER	D9	7815808	2002-12-18	100.16	100.18	100.18
SCHLUMBERGER	D9	7815809	2002-12-18	100.13	100.23	100.03
SCHLUMBERGER	D9	7815810	2002-12-18	100.09	100.33	100.19
SCHLUMBERGER	D9	7815811	2002-12-18	100.13	100.33	100.19
SCHLUMBERGER	D9	7815812	2002-12-18	100.14	100.33	100.19
SCHLUMBERGER	D9	7815813	2002-12-18	100.13	100.33	100.19
SCHLUMBERGER	D9	7815814	2002-12-18	100.14	100.33	100.19
SCHLUMBERGER	D9	7815815	2002-12-18	100.14	100.33	100.19
SCHLUMBERGER	D9	7815816	2002-12-18	100.14	100.33	100.19
SCHLUMBERGER	D9	7815817	2002-12-18	100.14	100.33	100.19
SCHLUMBERGER	D9	7815818	2002-12-18	100.14	100.33	100.19
SCHLUMBERGER	D9	7815819	2002-12-18	100.14	100.33	100.19
SCHLUMBERGER	D9	7815820	2002-12-18	100.14	100.33	100.19
SCHLUMBERGER	D9	7815821	2002-12-18	100.14	100.33	100.19
SCHLUMBERGER	D9	7815822	2002-12-18	100.14	100.33	100.19
SCHLUMBERGER	D9	7815823	2002-12-18	100.14	100.33	100.19
SCHLUMBERGER	D9	7815824	2002-12-18	100.14	100.33	100.19
SCHLUMBERGER	D9	7815825	2002-12-18	100.14	100.33	100.19
SCHLUMBERGER	D9	7815826	2002-12-18	100.14	100.33	100.19
SCHLUMBERGER	D9	7815827	2002-12-18	100.14	100.33	100.19
SCHLUMBERGER	D9	7815828	2002-12-18	100.14	100.33	100.19
SCHLUMBERGER	D9	7815829	2002-12-18	100.14	100.33	100.19
SCHLUMBERGER	D9	7815830	2002-12-18	100.14	100.33	100.19
SCHLUMBERGER	D9	7815831	2002-12-18	100.14	100.33	100.19
SCHLUMBERGER	D9	7815832	2002-12-18	100.14	100.33	100.19
SCHLUMBERGER	D9	7815833	2002-12-18	100.14	100.33	100.19
SCHLUMBERGER	D9	7815834	2002-12-18	100.14	100.33	100.19
SCHLUMBERGER	D9	7815835	2002-12-18	100.14	100.33	100.19
SCHLUMBERGER	D9	7815836	2002-12-18	100.14	100.33	100.19
SCHLUMBERGER	D9	7815837	2002-12-18	100.14	100.33	100.19
SCHLUMBERGER	D9	7815838	2002-12-18	100.14	100.33	100.19
SCHLUMBERGER	D9	7815839	2002-12-18	100.14	100.33	100.19
SCHLUMBERGER	D9	7815840	2002-12-18	100.14	100.33	100.19
SCHLUMBERGER	D9	7815841	2002-12-18	100.14	100.33	100.19
SCHLUMBERGER	D9	7815842	2002-12-18	100.14	100.33	100.19
SCHLUMBERGER	D9	7815843	2002-12-18	100.14	100.33	100.19
SCHLUMBERGER	D9	7815844	2002-12-18	100.14	100.33	100.19
SCHLUMBERGER	D9	7815845	2002-12-18	100.14	100.33	100.19
SCHLUMBERGER	D9	7815846	2002-12-18	100.14	100.33	100.19
SCHLUMBERGER	D9	7815847	2002-12-18	100.14	100.33	100.19
SCHLUMBERGER	D9	7815848	2002-12-18	100.14	100.33	100.19
SCHLUMBERGER	D9	7815849	2002-12-18	100.14	100.33	100.19
SCHLUMBERGER	D9	7815850	2002-12-18	100.14	100.33	100.19
SCHLUMBERGER	D9	7815851	2002-12-18	100.14	100.33	100.19
SCHLUMBERGER	D9	7815852	2002-12-18	100.14	100.33	100.19
SCHLUMBERGER	D9	7815853	2002-12-18	100.14	100.33	100.19
SCHLUMBERGER	D9	7815854	2002-12-18	100.14	100.33	100.19
SCHLUMBERGER	D9	7815855	2002-12-18	100.14	100.33	100.19
SCHLUMBERGER	D9	7815856	2002-12-18	100.14	100.33	100.19
SCHLUMBERGER	D9	7815857	2002-12-18	100.14	100.33	100.19
SCHLUMBERGER	D9	7815858	2002-12-18	100.14	100.33	100.19
SCHLUMBERGER	D9	7815859	2002-12-18	100.14	100.33	100.19
SCHLUMBERGER	D9	7815860	2002-12-18	100.14	100.33	100.19
SCHLUMBERGER	D9	7815861	2002-12-18	100.14	100.33	100.19
SCHLUMBERGER	D9	7815862	2002-12-18	100.14	100.33	100.19
SCHLUMBERGER	D9	7815863	2002-12-18	100.14	100.33	100.19
SCHLUMBERGER	D9	7815864	2002-12-18	100.14	100.33	100.19
SCHLUMBERGER	D9	7815865	2002-12-18	100.14	100.33	100.19
SCHLUMBERGER	D9	7815866	2002-12-18	100.14	100.33	100.19
SCHLUMBERGER	D9	7815867	2002-12-18	100.14	100.33	100.19
SCHLUMBERGER	D9	7815868	2002-12-18	100.14	100.33	100.19
SCHLUMBERGER	D9	7815869	2002-12-18	100.14	100.33	100.19
SCHLUMBERGER	D9	7815870	2002-12-18	100.14	100.33	100.19

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PF FACTOR
SCHLUMBERGER	D9	7814230	2002-12-11	100.04	100.34	100.48
SCHLUMBERGER	D9	7814231	2002-12-11	099.92	100.07	099.86
SCHLUMBERGER	D9	7814232	2002-12-11	100.02	100.27	099.88
SCHLUMBERGER	D9	7814233	2002-12-11	100.00	099.83	100.16
SCHLUMBERGER	D9	7814234	2002-12-11	099.92	100.11	099.83
SCHLUMBERGER	D9	7814235	2002-12-11	100.23	099.76	100.13
SCHLUMBERGER	D9	7814236	2002-12-11	100.10	100.38	100.28
SCHLUMBERGER	D9	7814237	2002-12-11	100.09	100.44	100.48
SCHLUMBERGER	D9	7814238	2002-12-11	100.04	100.11	100.24
SCHLUMBERGER	D9	7814239	2002-12-11	099.87	100.08	100.24
SCHLUMBERGER	D9	7814240	2002-12-11	100.04	100.10	100.40
SCHLUMBERGER	D9	7814241	2002-12-11	100.00	100.38	099.48
SCHLUMBERGER	D9	7814242	2002-12-11	100.02	100.12	100.48
SCHLUMBERGER	D9	7814243	2002-12-11	099.99	100.12	100.40
SCHLUMBERGER	D9	7814244	2002-12-11	099.99	100.13	100.24
SCHLUMBERGER	D9	7814245	2002-12-11	099.92	099.13	100.24
SCHLUMBERGER	D9	7814246	2002-12-11	099.95	099.82	100.24
SCHLUMBERGER	D9	7814247	2002-12-11	100.01	099.44	100.24
SCHLUMBERGER	D9	7814248	2002-12-11	100.20	099.97	100.27
SCHLUMBERGER	D9	7814249	2002-12-11	099.87	100.44	099.88
SCHLUMBERGER	D9	7814250	2002-12-11	100.02	100.39	100.41
SCHLUMBERGER	D9	7814251	2002-12-11	099.72	100.24	100.41
SCHLUMBERGER	D9	7814252	2002-12-11	100.04	100.49	100.48
SCHLUMBERGER	D9	7814253	2002-12-11	100.01	100.24	100.48
SCHLUMBERGER	D9	7814254	2002-12-11	100.01	100.45	100.48
SCHLUMBERGER	D9	7814255	2002-12-11	099.97	100.05	099.89
SCHLUMBERGER	D9	7814256	2002-12-11	099.97	100.05	100.14
SCHLUMBERGER	D9	7814257	2002-12-11	099.99	100.01	100.14
SCHLUMBERGER	D9	7814258	2002-12-11	099.72	099.99	100.02
SCHLUMBERGER	D9	7814259	2002-12-11	099.94	100.33	099.88
SCHLUMBERGER	D9	7814260	2002-12-11	099.05	100.41	100.05
SCHLUMBERGER	D9	7814261	2002-12-11	100.12	100.34	100.37
SCHLUMBERGER	D9	7814262	2002-12-11	100.12	100.05	100.37
SCHLUMBERGER	D9	7814263	2002-12-11	100.12	100.05	100.37
SCHLUMBERGER	D9	7814264	2002-12-11	100.12	100.05	100.37
SCHLUMBERGER	D9	7814265	2002-12-11	100.12	100.05	100.37
SCHLUMBERGER	D9	7814266	2002-12-11	100.12	100.05	100.37
SCHLUMBERGER	D9	7814267	2002-12-11	100.12	100.05	100.37
SCHLUMBERGER	D9	7814268	2002-12-11	100.12	100.05	100.37
SCHLUMBERGER	D9	7814269	2002-12-11	100.12	100.05	100.37
SCHLUMBERGER	D9	7814270	2002-12-11	100.12	100.05	100.37
SCHLUMBERGER	D9	7814271	2002-12-11	100.12	100.05	100.37
SCHLUMBERGER	D9	7814272	2002-12-11	100.12	100.05	100.37
SCHLUMBERGER	D9	7814273	2002-12-11	100.12	100.05	100.37
SCHLUMBERGER	D9	7814274	2002-12-11	100.12	100.05	100.37
SCHLUMBERGER	D9	7814275	2002-12-11	100.12	100.05	100.37
SCHLUMBERGER	D9	7814276	2002-12-11	100.12	100.05	100.37
SCHLUMBERGER	D9	7814277	2002-12-11	100.12	100.05	100.37
SCHLUMBERGER	D9	7814278	2002-12-11	100.12	100.05	100.37
SCHLUMBERGER	D9	7814279	2002-12-11	100.12	100.05	100.37
SCHLUMBERGER	D9	7814280	2002-12-11	100.12	100.05	100.37

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PF FACTOR
CHLUMBER	D9	781470	2002-11-13	099.86	100.27	099.81
CHLUMBER	D9	781471	2002-11-13	100.21	100.11	100.29
CHLUMBER	D9	781472	2002-11-13	099.91	100.25	099.82
CHLUMBER	D9	781473	2002-11-13	099.77	100.02	099.44
CHLUMBER	D9	781474	2002-11-13	100.04	100.02	100.42
CHLUMBER	D9	781475	2002-11-13	100.09	100.02	100.44
CHLUMBER	D9	781476	2002-11-13	100.05	100.43	100.49
CHLUMBER	D9	781477	2002-11-13	100.17	100.23	100.42
CHLUMBER	D9	781478	2002-11-13	099.97	100.44	099.47
CHLUMBER	D9	781479	2002-11-13	099.95	100.33	099.87
CHLUMBER	D9	781480	2002-11-13	099.90	100.10	099.93
CHLUMBER	D9	781481	2002-11-13	100.01	100.27	100.24
CHLUMBER	D9	781482	2002-11-13	099.95	100.52	099.93
CHLUMBER	D9	781483	2002-11-13	100.01	100.27	100.24
CHLUMBER	D9	781484	2002-11-13	099.95	100.52	099.93
CHLUMBER	D9	781485	2002-11-13	100.01	100.27	100.24
CHLUMBER	D9	781486	2002-11-13	099.95	100.52	099.93
CHLUMBER	D9	781487	2002-11-13	100.01	100.27	100.24
CHLUMBER	D9	781488	2002-11-13	099.95	100.52	099.93
CHLUMBER	D9	781489	2002-11-13	100.01	100.27	100.24
CHLUMBER	D9	781490	2002-11-13	099.95	100.52	099.93
CHLUMBER	D9	781491	2002-11-13	100.01	100.27	100.24
CHLUMBER	D9	781492	2002-11-13	099.95	100.52	099.93
CHLUMBER	D9	781493	2002-11-13	100.01	100.27	100.24
CHLUMBER	D9	781494	2002-11-13	099.95	100.52	099.93
CHLUMBER	D9	781495	2002-11-13	100.01	100.27	100.24
CHLUMBER	D9	781496	2002-11-13	099.95	100.52	099.93
CHLUMBER	D9	781497	2002-11-13	100.01	100.27	100.24
CHLUMBER	D9	781498	2002-11-13	099.95	100.52	099.93
CHLUMBER	D9	781499	2002-11-13	100.01	100.27	100.24
CHLUMBER	D9	781500	2002-11-13	099.95	100.52	099.93
CHLUMBER	D9	781501	2002-11-13	100.01	100.27	100.24
CHLUMBER	D9	781502	2002-11-13	099.95	100.52	099.93
CHLUMBER	D9	781503	2002-11-13	100.01	100.27	100.24
CHLUMBER	D9	781504	2002-11-13	099.95	100.52	099.93
CHLUMBER	D9	781505	2002-11-13	100.01	100.27	100.24
CHLUMBER	D9	781506	2002-11-13	099.95	100.52	099.93
CHLUMBER	D9	781507	2002-11-13	100.01	100.27	100.24
CHLUMBER	D9	781508	2002-11-13	099.95	100.52	099.93
CHLUMBER	D9	781509	2002-11-13	100.01	100.27	100.24
CHLUMBER	D9	781510	2002-11-13	099.95	100.52	099.93
CHLUMBER	D9	781511	2002-11-13	100.01	100.27	100.24
CHLUMBER	D9	781512	2002-11-13	099.95	100.52	099.93
CHLUMBER	D9	781513	2002-11-13	100.01	100.27	100.24
CHLUMBER	D9	781514	2002-11-13	099.95	100.52	099.93
CHLUMBER	D9	781515	2002-11-13	100.01	100.27	100.24
CHLUMBER	D9	781516	2002-11-13	099.95	100.52	099.93
CHLUMBER	D9	781517	2002-11-13	100.01	100.27	100.24
CHLUMBER	D9	781518	2002-11-13	099.95	100.52	099.93
CHLUMBER	D9	781519	2002-11-13	100.01	100.27	100.24
CHLUMBER	D9	781520	2002-11-13	099.95	100.52	099.93

LOUISVILLE GAS & ELECTRIC COMPANY
METER SYSTEM (MS)
NEW METERS ADDED LAST YEAR

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACOR
CHLUMBER	D9	781770	2002-11-19	099.85	100.01	100.13
CHLUMBER	D9	781771	2002-11-19	099.95	100.10	100.13
CHLUMBER	D9	781772	2002-11-19	100.00	100.07	100.13
CHLUMBER	D9	781773	2002-11-19	099.82	100.09	099.13
CHLUMBER	D9	781774	2002-11-19	100.05	100.09	100.13
CHLUMBER	D9	781775	2002-11-19	099.22	100.15	100.09
CHLUMBER	D9	781777	2002-11-19	100.10	100.44	100.07
CHLUMBER	D9	781779	2002-11-19	099.78	100.39	100.07
CHLUMBER	D9	781780	2002-11-19	100.04	100.27	100.43
CHLUMBER	D9	781781	2002-11-19	100.11	100.19	100.43
CHLUMBER	D9	781782	2002-11-19	100.10	100.27	100.43
CHLUMBER	D9	781783	2002-11-19	100.03	099.77	100.44
CHLUMBER	D9	781784	2002-11-19	099.94	100.14	100.44
CHLUMBER	D9	781785	2002-11-19	100.02	100.07	100.44
CHLUMBER	D9	781787	2002-11-19	100.11	100.07	100.04
CHLUMBER	D9	781788	2002-11-19	099.81	100.36	100.04
CHLUMBER	D9	781789	2002-11-19	100.18	100.36	099.66
CHLUMBER	D9	781790	2002-11-19	100.13	100.44	099.67
CHLUMBER	D9	781791	2002-11-19	100.07	100.11	099.23
CHLUMBER	D9	781792	2002-11-19	099.74	100.19	100.23
CHLUMBER	D9	781793	2002-11-19	100.09	100.19	100.24
CHLUMBER	D9	781794	2002-11-19	099.97	100.12	100.01
CHLUMBER	D9	781795	2002-11-19	100.01	099.77	099.01
CHLUMBER	D9	781796	2002-11-19	100.05	100.19	099.94
CHLUMBER	D9	781797	2002-11-19	100.05	100.04	099.94
CHLUMBER	D9	781798	2002-11-19	099.85	100.17	100.02
CHLUMBER	D9	781799	2002-11-19	100.01	100.15	099.72
CHLUMBER	D9	781800	2002-11-19	099.96	100.45	099.42
CHLUMBER	D9	781801	2002-11-19	100.79	100.42	099.42
CHLUMBER	D9	781802	2002-11-19	100.07	100.40	100.24
CHLUMBER	D9	781803	2002-11-19	099.97	100.40	100.24
CHLUMBER	D9	781804	2002-11-19	100.05	100.57	100.24
CHLUMBER	D9	781805	2002-11-19	099.98	100.28	100.14
CHLUMBER	D9	781806	2002-11-19	100.00	100.03	100.14
CHLUMBER	D9	781807	2002-11-19	099.99	100.09	099.77
CHLUMBER	D9	781808	2002-11-19	100.00	100.09	100.48
CHLUMBER	D9	781809	2002-11-19	099.94	100.03	100.14
CHLUMBER	D9	781810	2002-11-19	100.00	100.00	100.14
CHLUMBER	D9	781811	2002-11-19	099.87	100.03	100.14
CHLUMBER	D9	781812	2002-11-19	100.00	100.03	100.14
CHLUMBER	D9	781813	2002-11-19	099.94	100.03	100.14
CHLUMBER	D9	781814	2002-11-19	100.00	100.03	100.14
CHLUMBER	D9	781815	2002-11-19	099.94	100.03	100.14
CHLUMBER	D9	781816	2002-11-19	100.00	100.03	100.14
CHLUMBER	D9	781817	2002-11-19	099.82	100.03	100.14
CHLUMBER	D9	781818	2002-11-19	100.05	100.03	100.14

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
02	09	20	11	100.00	100.00	00
02	09	21	11	100.00	100.00	00
02	09	22	11	100.00	100.00	00
02	09	23	11	100.00	100.00	00
02	09	24	11	100.00	100.00	00
02	09	25	11	100.00	100.00	00
02	09	26	11	100.00	100.00	00
02	09	27	11	100.00	100.00	00
02	09	28	11	100.00	100.00	00
02	09	29	11	100.00	100.00	00
02	09	30	11	100.00	100.00	00
02	09	31	11	100.00	100.00	00
02	09	32	11	100.00	100.00	00
02	09	33	11	100.00	100.00	00
02	09	34	11	100.00	100.00	00
02	09	35	11	100.00	100.00	00
02	09	36	11	100.00	100.00	00
02	09	37	11	100.00	100.00	00
02	09	38	11	100.00	100.00	00
02	09	39	11	100.00	100.00	00
02	09	40	11	100.00	100.00	00
02	09	41	11	100.00	100.00	00
02	09	42	11	100.00	100.00	00
02	09	43	11	100.00	100.00	00
02	09	44	11	100.00	100.00	00
02	09	45	11	100.00	100.00	00
02	09	46	11	100.00	100.00	00
02	09	47	11	100.00	100.00	00
02	09	48	11	100.00	100.00	00
02	09	49	11	100.00	100.00	00
02	09	50	11	100.00	100.00	00
02	09	51	11	100.00	100.00	00
02	09	52	11	100.00	100.00	00
02	09	53	11	100.00	100.00	00
02	09	54	11	100.00	100.00	00
02	09	55	11	100.00	100.00	00
02	09	56	11	100.00	100.00	00
02	09	57	11	100.00	100.00	00
02	09	58	11	100.00	100.00	00
02	09	59	11	100.00	100.00	00
02	09	60	11	100.00	100.00	00
02	09	61	11	100.00	100.00	00
02	09	62	11	100.00	100.00	00
02	09	63	11	100.00	100.00	00
02	09	64	11	100.00	100.00	00
02	09	65	11	100.00	100.00	00
02	09	66	11	100.00	100.00	00
02	09	67	11	100.00	100.00	00
02	09	68	11	100.00	100.00	00
02	09	69	11	100.00	100.00	00
02	09	70	11	100.00	100.00	00
02	09	71	11	100.00	100.00	00
02	09	72	11	100.00	100.00	00
02	09	73	11	100.00	100.00	00
02	09	74	11	100.00	100.00	00
02	09	75	11	100.00	100.00	00
02	09	76	11	100.00	100.00	00
02	09	77	11	100.00	100.00	00
02	09	78	11	100.00	100.00	00
02	09	79	11	100.00	100.00	00
02	09	80	11	100.00	100.00	00
02	09	81	11	100.00	100.00	00
02	09	82	11	100.00	100.00	00
02	09	83	11	100.00	100.00	00
02	09	84	11	100.00	100.00	00
02	09	85	11	100.00	100.00	00
02	09	86	11	100.00	100.00	00
02	09	87	11	100.00	100.00	00
02	09	88	11	100.00	100.00	00
02	09	89	11	100.00	100.00	00
02	09	90	11	100.00	100.00	00
02	09	91	11	100.00	100.00	00
02	09	92	11	100.00	100.00	00
02	09	93	11	100.00	100.00	00
02	09	94	11	100.00	100.00	00
02	09	95	11	100.00	100.00	00
02	09	96	11	100.00	100.00	00
02	09	97	11	100.00	100.00	00
02	09	98	11	100.00	100.00	00
02	09	99	11	100.00	100.00	00
02	09	100	11	100.00	100.00	00

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
UICHL	UM62	7819921	2002-12-11	099.83	100.36	099.79
UICHL	UM62	7819924	2002-12-11	099.94	099.97	099.75
UICHL	UM62	7819927	2002-12-11	100.10	100.17	100.00
UICHL	UM62	7819930	2002-12-11	100.05	100.14	099.60
UICHL	UM62	7819933	2002-12-11	100.06	100.37	100.37
UICHL	UM62	7819936	2002-12-11	099.80	100.41	100.10
UICHL	UM62	7819939	2002-12-11	100.02	099.99	099.90
UICHL	UM62	7819942	2002-12-11	100.24	100.36	100.24
UICHL	UM62	7819945	2002-12-11	100.11	100.44	100.20
UICHL	UM62	7819948	2002-12-11	100.04	100.11	099.78
UICHL	UM62	7819951	2002-12-11	100.09	100.34	100.20
UICHL	UM62	7819954	2002-12-11	100.00	100.24	099.72
UICHL	UM62	7819957	2002-12-11	100.04	100.35	100.20
UICHL	UM62	7819960	2002-12-11	100.04	100.30	100.20
UICHL	UM62	7819963	2002-12-11	100.09	100.39	100.27
UICHL	UM62	7819966	2002-12-11	100.01	100.11	099.78
UICHL	UM62	7819969	2002-12-11	100.12	100.08	100.18
UICHL	UM62	7819972	2002-12-11	100.01	100.04	100.01
UICHL	UM62	7819975	2002-12-11	099.99	100.05	100.01
UICHL	UM62	7819978	2002-12-11	100.21	100.35	100.14
UICHL	UM62	7819981	2002-12-11	099.91	100.35	100.14
UICHL	UM62	7819984	2002-12-11	100.04	100.33	100.20
UICHL	UM62	7819987	2002-12-11	099.73	100.49	099.04
UICHL	UM62	7819990	2002-12-11	099.93	100.17	099.15
UICHL	UM62	7819993	2002-12-11	100.05	100.34	100.41
UICHL	UM62	7819996	2002-12-11	100.23	100.38	100.61
UICHL	UM62	7819999	2002-12-11	100.23	100.38	100.61

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACOR
CHL	UM82	7819770	2002-12-11	099.822	099.822	099.79
CHL	UM82	7819771	2002-12-11	099.922	100.022	100.02
CHL	UM82	7819772	2002-12-11	100.05	100.17	099.81
CHL	UM82	7819773	2002-12-11	099.882	099.90	099.94
CHL	UM82	7819774	2002-12-11	099.882	099.90	099.90
CHL	UM82	7819775	2002-12-11	099.882	099.94	099.83
CHL	UM82	7819776	2002-12-11	100.09	100.23	100.12
CHL	UM82	7819777	2002-12-11	100.20	100.32	100.12
CHL	UM82	7819778	2002-12-11	099.94	100.32	099.87
CHL	UM82	7819779	2002-12-11	100.05	100.27	100.24
CHL	UM82	7819780	2002-12-11	099.76	100.23	100.03
CHL	UM82	7819781	2002-12-11	100.17	100.40	100.42
CHL	UM82	7819782	2002-12-11	100.07	100.31	100.34
CHL	UM82	7819783	2002-12-11	100.11	100.42	100.34
CHL	UM82	7819784	2002-12-11	099.79	099.85	099.92
CHL	UM82	7819785	2002-12-11	099.79	100.27	100.14
CHL	UM82	7819786	2002-12-11	100.04	100.42	100.34
CHL	UM82	7819787	2002-12-11	100.04	100.42	100.16
CHL	UM82	7819788	2002-12-11	099.88	099.93	099.94
CHL	UM82	7819789	2002-12-11	099.88	100.03	100.16
CHL	UM82	7819790	2002-12-11	099.88	100.03	099.94
CHL	UM82	7819791	2002-12-11	100.09	100.33	100.14
CHL	UM82	7819792	2002-12-11	099.85	099.33	099.79
CHL	UM82	7819793	2002-12-11	100.08	100.34	100.42
CHL	UM82	7819794	2002-12-11	100.08	100.34	100.42
CHL	UM82	7819795	2002-12-11	100.11	100.42	100.42
CHL	UM82	7819796	2002-12-11	099.90	100.42	100.27
CHL	UM82	7819797	2002-12-11	099.96	100.42	099.72
CHL	UM82	7819798	2002-12-11	099.96	100.42	100.41
CHL	UM82	7819799	2002-12-11	099.84	100.20	100.41
CHL	UM82	7820000	2002-12-11	099.84	100.14	099.72
CHL	UM82	7820001	2002-12-11	100.04	100.14	100.24
CHL	UM82	7820002	2002-12-11	099.85	100.14	099.50
CHL	UM82	7820003	2002-12-11	100.04	100.14	100.39
CHL	UM82	7820004	2002-12-11	099.85	100.14	099.89
CHL	UM82	7820005	2002-12-11	100.04	100.14	100.39
CHL	UM82	7820006	2002-12-11	099.73	100.40	099.76
CHL	UM82	7820007	2002-12-11	099.77	100.40	100.27
CHL	UM82	7820008	2002-12-11	099.77	100.33	099.89
CHL	UM82	7820009	2002-12-11	100.03	100.33	100.40
CHL	UM82	7820010	2002-12-11	100.03	100.33	100.40
CHL	UM82	7820011	2002-12-11	099.96	100.33	100.27
CHL	UM82	7820012	2002-12-11	099.90	100.33	100.23
CHL	UM82	7820013	2002-12-11	100.07	100.33	100.33
CHL	UM82	7820014	2002-12-11	100.08	100.42	099.72
CHL	UM82	7820015	2002-12-11	099.89	100.42	100.20
CHL	UM82	7820016	2002-12-11	099.89	100.42	100.19
CHL	UM82	7820017	2002-12-11	099.89	100.42	100.19
CHL	UM82	7820018	2002-12-11	099.89	100.42	100.19
CHL	UM82	7820019	2002-12-11	099.89	100.42	100.19
CHL	UM82	7820020	2002-12-11	099.89	100.42	100.19

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACOR
CHL	D9	7821160	110303	099.727	100.27	099.27
CHL	D9	7821161	110303	100.057	100.00	100.04
CHL	D9	7821162	110303	100.07	100.21	100.21
CHL	D9	7821163	110303	100.01	099.24	099.24
CHL	D9	7821164	110303	099.22	100.44	100.44
CHL	D9	7821165	110303	100.03	100.03	100.03
CHL	D9	7821166	110303	100.05	100.07	100.07
CHL	D9	7821167	110303	100.05	100.07	100.07
CHL	D9	7821168	110303	100.06	100.10	100.10
CHL	D9	7821169	110303	100.06	100.10	100.10
CHL	D9	7821170	110303	100.06	100.10	100.10
CHL	D9	7821171	110303	100.06	100.10	100.10
CHL	D9	7821172	110303	100.06	100.10	100.10
CHL	D9	7821173	110303	100.06	100.10	100.10
CHL	D9	7821174	110303	100.06	100.10	100.10
CHL	D9	7821175	110303	100.06	100.10	100.10
CHL	D9	7821176	110303	100.06	100.10	100.10
CHL	D9	7821177	110303	100.06	100.10	100.10
CHL	D9	7821178	110303	100.06	100.10	100.10
CHL	D9	7821179	110303	100.06	100.10	100.10
CHL	D9	7821180	110303	100.06	100.10	100.10
CHL	D9	7821181	110303	100.06	100.10	100.10
CHL	D9	7821182	110303	100.06	100.10	100.10
CHL	D9	7821183	110303	100.06	100.10	100.10
CHL	D9	7821184	110303	100.06	100.10	100.10
CHL	D9	7821185	110303	100.06	100.10	100.10
CHL	D9	7821186	110303	100.06	100.10	100.10
CHL	D9	7821187	110303	100.06	100.10	100.10
CHL	D9	7821188	110303	100.06	100.10	100.10
CHL	D9	7821189	110303	100.06	100.10	100.10
CHL	D9	7821190	110303	100.06	100.10	100.10
CHL	D9	7821191	110303	100.06	100.10	100.10
CHL	D9	7821192	110303	100.06	100.10	100.10
CHL	D9	7821193	110303	100.06	100.10	100.10
CHL	D9	7821194	110303	100.06	100.10	100.10
CHL	D9	7821195	110303	100.06	100.10	100.10
CHL	D9	7821196	110303	100.06	100.10	100.10
CHL	D9	7821197	110303	100.06	100.10	100.10
CHL	D9	7821198	110303	100.06	100.10	100.10
CHL	D9	7821199	110303	100.06	100.10	100.10
CHL	D9	7821200	110303	100.06	100.10	100.10

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
CHL	U	7821170	2002-11-11	100.05	099.97	100.11
CHL	U	7821171	2002-11-11	097.91	099.84	100.09
CHL	U	7821172	2002-11-11	100.00	099.99	100.04
CHL	U	7821173	2002-11-11	100.08	100.28	099.80
CHL	U	7821174	2002-11-11	100.07	100.28	100.27
CHL	U	7821175	2002-11-11	100.15	099.88	100.07
CHL	U	7821176	2002-11-11	099.72	100.19	100.07
CHL	U	7821177	2002-11-11	100.15	099.79	100.21
CHL	U	7821178	2002-11-11	099.82	100.22	099.89
CHL	U	7821179	2002-11-11	099.72	100.17	100.03
CHL	U	7821180	2002-11-11	099.04	099.69	100.19
CHL	U	7821181	2002-11-11	099.94	100.12	100.03
CHL	U	7821182	2002-11-11	099.90	100.10	099.79
CHL	U	7821183	2002-11-11	100.21	099.97	100.40
CHL	U	7821184	2002-11-11	099.84	100.09	099.80
CHL	U	7821185	2002-11-11	100.13	099.77	100.40
CHL	U	7821186	2002-11-11	099.77	100.19	100.40
CHL	U	7821187	2002-11-11	100.06	100.12	100.40
CHL	U	7821188	2002-11-11	100.12	100.05	100.40
CHL	U	7821189	2002-11-11	100.06	099.84	100.40
CHL	U	7821190	2002-11-11	099.80	100.29	100.40
CHL	U	7821191	2002-11-11	099.93	100.01	099.44
CHL	U	7821192	2002-11-11	099.73	100.35	100.47
CHL	U	7821193	2002-11-11	099.75	100.19	100.47
CHL	U	7821194	2002-11-11	100.04	100.23	100.44
CHL	U	7821195	2002-11-11	100.03	100.13	100.44
CHL	U	7821196	2002-11-11	100.04	100.30	100.45
CHL	U	7821197	2002-11-11	100.04	100.30	100.45
CHL	U	7821198	2002-11-11	100.02	100.31	100.45
CHL	U	7821199	2002-11-11	100.02	100.31	100.45
CHL	U	7821200	2002-11-11	100.02	100.31	100.45
CHL	U	7821201	2002-11-11	100.02	100.31	100.45
CHL	U	7821202	2002-11-11	100.02	100.31	100.45
CHL	U	7821203	2002-11-11	100.02	100.31	100.45
CHL	U	7821204	2002-11-11	100.02	100.31	100.45
CHL	U	7821205	2002-11-11	099.90	100.27	100.45
CHL	U	7821206	2002-11-11	099.90	100.27	100.45
CHL	U	7821207	2002-11-11	099.92	100.29	100.45
CHL	U	7821208	2002-11-11	100.12	100.24	100.45
CHL	U	7821209	2002-11-11	099.92	100.34	100.45
CHL	U	7821210	2002-11-11	099.85	099.75	100.45
CHL	U	7821211	2002-11-11	099.97	100.41	100.45
CHL	U	7821212	2002-11-11	100.12	100.34	100.45
CHL	U	7821213	2002-11-11	100.06	100.34	100.45
CHL	U	7821214	2002-11-11	099.95	100.35	100.45
CHL	U	7821215	2002-11-11	100.00	100.35	100.45
CHL	U	7821216	2002-11-11	100.00	100.35	100.45
CHL	U	7821217	2002-11-11	100.00	100.35	100.45
CHL	U	7821218	2002-11-11	100.00	100.35	100.45
CHL	U	7821219	2002-11-11	100.00	100.35	100.45
CHL	U	7821220	2002-11-11	100.00	100.35	100.45
CHL	U	7821221	2002-11-11	100.00	100.35	100.45
CHL	U	7821222	2002-11-11	100.00	100.35	100.45
CHL	U	7821223	2002-11-11	100.00	100.35	100.45
CHL	U	7821224	2002-11-11	100.00	100.35	100.45
CHL	U	7821225	2002-11-11	100.00	100.35	100.45
CHL	U	7821226	2002-11-11	100.00	100.35	100.45
CHL	U	7821227	2002-11-11	100.00	100.35	100.45
CHL	U	7821228	2002-11-11	100.00	100.35	100.45
CHL	U	7821229	2002-11-11	100.00	100.35	100.45
CHL	U	7821230	2002-11-11	100.00	100.35	100.45
CHL	U	7821231	2002-11-11	100.00	100.35	100.45
CHL	U	7821232	2002-11-11	100.00	100.35	100.45
CHL	U	7821233	2002-11-11	100.00	100.35	100.45
CHL	U	7821234	2002-11-11	100.00	100.35	100.45
CHL	U	7821235	2002-11-11	100.00	100.35	100.45
CHL	U	7821236	2002-11-11	100.00	100.35	100.45
CHL	U	7821237	2002-11-11	100.00	100.35	100.45
CHL	U	7821238	2002-11-11	100.00	100.35	100.45
CHL	U	7821239	2002-11-11	100.00	100.35	100.45
CHL	U	7821240	2002-11-11	100.00	100.35	100.45
CHL	U	7821241	2002-11-11	100.00	100.35	100.45
CHL	U	7821242	2002-11-11	100.00	100.35	100.45
CHL	U	7821243	2002-11-11	100.00	100.35	100.45
CHL	U	7821244	2002-11-11	100.00	100.35	100.45
CHL	U	7821245	2002-11-11	100.00	100.35	100.45
CHL	U	7821246	2002-11-11	100.00	100.35	100.45
CHL	U	7821247	2002-11-11	100.00	100.35	100.45
CHL	U	7821248	2002-11-11	100.00	100.35	100.45
CHL	U	7821249	2002-11-11	100.00	100.35	100.45
CHL	U	7821250	2002-11-11	100.00	100.35	100.45

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	D9	7822229	2002-12-19	100.04	100.17	100.14
SCHLUMBERGER	D9	7822221	2002-12-19	100.03	100.24	100.20
SCHLUMBERGER	D9	7822222	2002-12-19	100.01	100.21	100.18
SCHLUMBERGER	D9	7822223	2002-12-19	100.00	100.03	099.97
SCHLUMBERGER	D9	7822224	2002-12-19	100.01	099.99	100.13
SCHLUMBERGER	D9	7822225	2002-12-19	099.94	100.19	100.30
SCHLUMBERGER	D9	7822226	2002-12-19	100.04	100.35	100.33
SCHLUMBERGER	D9	7822227	2002-12-19	099.94	100.11	100.22
SCHLUMBERGER	D9	7822228	2002-12-19	100.10	100.45	100.23
SCHLUMBERGER	D9	7822229	2002-12-19	100.01	100.33	100.23
SCHLUMBERGER	D9	7822230	2002-12-19	100.05	100.34	100.23
SCHLUMBERGER	D9	7822231	2002-12-19	099.95	100.32	099.44
SCHLUMBERGER	D9	7822232	2002-12-19	100.16	100.37	100.27
SCHLUMBERGER	D9	7822233	2002-12-19	100.09	100.27	100.19
SCHLUMBERGER	D9	7822234	2002-12-19	100.16	100.23	100.19
SCHLUMBERGER	D9	7822235	2002-12-19	100.08	100.27	099.89
SCHLUMBERGER	D9	7822236	2002-12-19	100.02	100.32	100.19
SCHLUMBERGER	D9	7822237	2002-12-19	099.87	100.22	100.33
SCHLUMBERGER	D9	7822238	2002-12-19	100.02	100.33	100.33
SCHLUMBERGER	D9	7822239	2002-12-19	099.98	100.40	099.97
SCHLUMBERGER	D9	7822240	2002-12-19	100.02	100.38	100.37
SCHLUMBERGER	D9	7822241	2002-12-19	100.01	100.44	100.44
SCHLUMBERGER	D9	7822242	2002-12-19	100.04	100.37	100.44
SCHLUMBERGER	D9	7822243	2002-12-19	099.92	100.43	100.44
SCHLUMBERGER	D9	7822244	2002-12-19	100.04	100.32	099.94
SCHLUMBERGER	D9	7822245	2002-12-19	100.04	100.32	100.33
SCHLUMBERGER	D9	7822246	2002-12-19	100.02	100.49	100.33
SCHLUMBERGER	D9	7822247	2002-12-19	099.97	100.34	100.41
SCHLUMBERGER	D9	7822248	2002-12-19	100.03	100.37	100.41
SCHLUMBERGER	D9	7822249	2002-12-19	100.04	100.34	100.41
SCHLUMBERGER	D9	7822250	2002-12-19	100.07	100.34	100.41
SCHLUMBERGER	D9	7822251	2002-12-19	100.03	100.37	100.41
SCHLUMBERGER	D9	7822252	2002-12-19	099.97	100.34	100.41
SCHLUMBERGER	D9	7822253	2002-12-19	100.03	100.34	100.41
SCHLUMBERGER	D9	7822254	2002-12-19	100.01	100.37	100.41
SCHLUMBERGER	D9	7822255	2002-12-19	100.04	100.37	100.41
SCHLUMBERGER	D9	7822256	2002-12-19	099.96	100.34	100.41
SCHLUMBERGER	D9	7822257	2002-12-19	100.04	100.32	099.94
SCHLUMBERGER	D9	7822258	2002-12-19	100.02	100.34	100.33
SCHLUMBERGER	D9	7822259	2002-12-19	100.02	100.34	100.33
SCHLUMBERGER	D9	7822260	2002-12-19	100.02	100.34	100.33
SCHLUMBERGER	D9	7822261	2002-12-19	100.18	100.34	100.43
SCHLUMBERGER	D9	7822262	2002-12-19	100.05	100.37	100.43
SCHLUMBERGER	D9	7822263	2002-12-19	099.88	100.37	099.93
SCHLUMBERGER	D9	7822264	2002-12-19	100.04	100.32	099.93
SCHLUMBERGER	D9	7822265	2002-12-19	100.04	099.84	099.84
SCHLUMBERGER	D9	7822266	2002-12-19	100.01	099.97	099.84
SCHLUMBERGER	D9	7822267	2002-12-19	099.94	100.47	100.47
SCHLUMBERGER	D9	7822268	2002-12-19	100.03	100.37	100.47
SCHLUMBERGER	D9	7822269	2002-12-19	100.04	100.37	100.47
SCHLUMBERGER	D9	7822270	2002-12-19	099.97	100.37	100.47

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	D9	7822270	2002-12-18	099.91	100.20	100.54
SCHLUMBERGER	D9	7822271	2002-12-18	100.06	100.20	100.53
SCHLUMBERGER	D9	7822272	2002-12-18	100.19	100.24	100.54
SCHLUMBERGER	D9	7822273	2002-12-18	099.98	100.19	100.40
SCHLUMBERGER	D9	7822274	2002-12-18	099.99	100.24	100.12
SCHLUMBERGER	D9	7822275	2002-12-18	100.10	100.44	100.43
SCHLUMBERGER	D9	7822276	2002-12-18	100.02	100.17	099.87
SCHLUMBERGER	D9	7822277	2002-12-18	100.07	100.33	100.12
SCHLUMBERGER	D9	7822278	2002-12-18	099.98	100.41	100.31
SCHLUMBERGER	D9	7822279	2002-12-18	099.98	100.41	100.31
SCHLUMBERGER	D9	7822280	2002-12-18	100.09	100.13	100.19
SCHLUMBERGER	D9	7822281	2002-12-18	100.09	100.39	099.92
SCHLUMBERGER	D9	7822282	2002-12-18	100.09	100.25	100.30
SCHLUMBERGER	D9	7822283	2002-12-18	100.08	100.14	100.11
SCHLUMBERGER	D9	7822284	2002-12-18	100.10	100.14	100.11
SCHLUMBERGER	D9	7822285	2002-12-18	100.10	100.14	100.11
SCHLUMBERGER	D9	7822286	2002-12-18	099.84	100.08	099.93
SCHLUMBERGER	D9	7822287	2002-12-18	099.94	100.08	099.93
SCHLUMBERGER	D9	7822288	2002-12-18	099.94	100.08	099.93
SCHLUMBERGER	D9	7822289	2002-12-18	099.94	100.08	099.93
SCHLUMBERGER	D9	7822290	2002-12-18	100.11	100.34	100.42
SCHLUMBERGER	D9	7822291	2002-12-18	099.79	100.09	099.78
SCHLUMBERGER	D9	7822292	2002-12-18	100.02	100.29	100.31
SCHLUMBERGER	D9	7822293	2002-12-18	100.02	100.29	100.31
SCHLUMBERGER	D9	7822294	2002-12-18	100.02	100.29	100.31
SCHLUMBERGER	D9	7822295	2002-12-18	100.07	100.09	100.04
SCHLUMBERGER	D9	7822296	2002-12-18	100.07	100.09	100.04
SCHLUMBERGER	D9	7822297	2002-12-18	100.07	100.09	100.04
SCHLUMBERGER	D9	7822298	2002-12-18	100.07	100.09	100.04
SCHLUMBERGER	D9	7822299	2002-12-18	100.07	100.09	100.04
SCHLUMBERGER	D9	7822300	2002-12-18	100.07	100.09	100.04
SCHLUMBERGER	D9	7822301	2002-12-18	100.07	100.09	100.04
SCHLUMBERGER	D9	7822302	2002-12-18	100.07	100.09	100.04
SCHLUMBERGER	D9	7822303	2002-12-18	100.07	100.09	100.04
SCHLUMBERGER	D9	7822304	2002-12-18	100.10	100.41	100.07
SCHLUMBERGER	D9	7822305	2002-12-18	099.91	100.37	099.97
SCHLUMBERGER	D9	7822306	2002-12-18	099.91	100.44	100.07
SCHLUMBERGER	D9	7822307	2002-12-18	099.16	100.26	100.10
SCHLUMBERGER	D9	7822308	2002-12-18	100.05	100.39	100.27
SCHLUMBERGER	D9	7822309	2002-12-18	100.05	100.41	100.08
SCHLUMBERGER	D9	7822310	2002-12-18	099.95	100.41	099.98
SCHLUMBERGER	D9	7822311	2002-12-18	100.05	100.37	100.08
SCHLUMBERGER	D9	7822312	2002-12-18	100.05	100.41	100.08
SCHLUMBERGER	D9	7822313	2002-12-18	099.94	100.41	100.08
SCHLUMBERGER	D9	7822314	2002-12-18	099.94	100.41	100.08
SCHLUMBERGER	D9	7822315	2002-12-18	099.94	100.41	100.08
SCHLUMBERGER	D9	7822316	2002-12-18	099.94	100.41	100.08
SCHLUMBERGER	D9	7822317	2002-12-18	099.94	100.41	100.08
SCHLUMBERGER	D9	7822318	2002-12-18	099.94	100.41	100.08
SCHLUMBERGER	D9	7822319	2002-12-18	099.94	100.41	100.08
SCHLUMBERGER	D9	7822320	2002-12-18	099.94	100.41	100.08
SCHLUMBERGER	D9	7822321	2002-12-18	099.94	100.41	100.08
SCHLUMBERGER	D9	7822322	2002-12-18	099.94	100.41	100.08
SCHLUMBERGER	D9	7822323	2002-12-18	099.94	100.41	100.08
SCHLUMBERGER	D9	7822324	2002-12-18	099.94	100.41	100.08
SCHLUMBERGER	D9	7822325	2002-12-18	099.94	100.41	100.08
SCHLUMBERGER	D9	7822326	2002-12-18	099.94	100.41	100.08
SCHLUMBERGER	D9	7822327	2002-12-18	099.94	100.41	100.08
SCHLUMBERGER	D9	7822328	2002-12-18	099.94	100.41	100.08
SCHLUMBERGER	D9	7822329	2002-12-18	099.94	100.41	100.08
SCHLUMBERGER	D9	7822330	2002-12-18	099.94	100.41	100.08
SCHLUMBERGER	D9	7822331	2002-12-18	099.94	100.41	100.08
SCHLUMBERGER	D9	7822332	2002-12-18	099.94	100.41	100.08
SCHLUMBERGER	D9	7822333	2002-12-18	099.94	100.41	100.08
SCHLUMBERGER	D9	7822334	2002-12-18	099.94	100.41	100.08
SCHLUMBERGER	D9	7822335	2002-12-18	099.94	100.41	100.08
SCHLUMBERGER	D9	7822336	2002-12-18	099.94	100.41	100.08
SCHLUMBERGER	D9	7822337	2002-12-18	099.94	100.41	100.08
SCHLUMBERGER	D9	7822338	2002-12-18	099.94	100.41	100.08
SCHLUMBERGER	D9	7822339	2002-12-18	099.94	100.41	100.08
SCHLUMBERGER	D9	7822340	2002-12-18	099.94	100.41	100.08
SCHLUMBERGER	D9	7822341	2002-12-18	099.94	100.41	100.08
SCHLUMBERGER	D9	7822342	2002-12-18	099.94	100.41	100.08
SCHLUMBERGER	D9	7822343	2002-12-18	099.94	100.41	100.08
SCHLUMBERGER	D9	7822344	2002-12-18	099.94	100.41	100.08
SCHLUMBERGER	D9	7822345	2002-12-18	099.94	100.41	100.08
SCHLUMBERGER	D9	7822346	2002-12-18	099.94	100.41	100.08
SCHLUMBERGER	D9	7822347	2002-12-18	099.94	100.41	100.08
SCHLUMBERGER	D9	7822348	2002-12-18	099.94	100.41	100.08
SCHLUMBERGER	D9	7822349	2002-12-18	099.94	100.41	100.08
SCHLUMBERGER	D9	7822350	2002-12-18	099.94	100.41	100.08
SCHLUMBERGER	D9	7822351	2002-12-18	099.94	100.41	100.08
SCHLUMBERGER	D9	7822352	2002-12-18	099.94	100.41	100.08
SCHLUMBERGER	D9	7822353	2002-12-18	099.94	100.41	100.08
SCHLUMBERGER	D9	7822354	2002-12-18	099.94	100.41	100.08
SCHLUMBERGER	D9	7822355	2002-12-18	099.94	100.41	100.08
SCHLUMBERGER	D9	7822356	2002-12-18	099.94	100.41	100.08
SCHLUMBERGER	D9	7822357	2002-12-18	099.94	100.41	100.08
SCHLUMBERGER	D9	7822358	2002-12-18	099.94	100.41	100.08
SCHLUMBERGER	D9	7822359	2002-12-18	099.94	100.41	100.08
SCHLUMBERGER	D9	7822360	2002-12-18	099.94	100.41	100.08

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
CHL	D9	78232324	11/03	100.037	100.44	100.034
CHL	D9	78232325	11/03	100.037	100.44	100.034
CHL	D9	78232326	11/03	100.037	100.44	100.034
CHL	D9	78232327	11/03	100.037	100.44	100.034
CHL	D9	78232328	11/03	100.037	100.44	100.034
CHL	D9	78232329	11/03	100.037	100.44	100.034
CHL	D9	78232330	11/03	100.037	100.44	100.034
CHL	D9	78232331	11/03	100.037	100.44	100.034
CHL	D9	78232332	11/03	100.037	100.44	100.034
CHL	D9	78232333	11/03	100.037	100.44	100.034
CHL	D9	78232334	11/03	100.037	100.44	100.034
CHL	D9	78232335	11/03	100.037	100.44	100.034
CHL	D9	78232336	11/03	100.037	100.44	100.034
CHL	D9	78232337	11/03	100.037	100.44	100.034
CHL	D9	78232338	11/03	100.037	100.44	100.034
CHL	D9	78232339	11/03	100.037	100.44	100.034
CHL	D9	78232340	11/03	100.037	100.44	100.034
CHL	D9	78232341	11/03	100.037	100.44	100.034
CHL	D9	78232342	11/03	100.037	100.44	100.034
CHL	D9	78232343	11/03	100.037	100.44	100.034
CHL	D9	78232344	11/03	100.037	100.44	100.034
CHL	D9	78232345	11/03	100.037	100.44	100.034
CHL	D9	78232346	11/03	100.037	100.44	100.034
CHL	D9	78232347	11/03	100.037	100.44	100.034
CHL	D9	78232348	11/03	100.037	100.44	100.034
CHL	D9	78232349	11/03	100.037	100.44	100.034
CHL	D9	78232350	11/03	100.037	100.44	100.034
CHL	D9	78232351	11/03	100.037	100.44	100.034
CHL	D9	78232352	11/03	100.037	100.44	100.034
CHL	D9	78232353	11/03	100.037	100.44	100.034
CHL	D9	78232354	11/03	100.037	100.44	100.034
CHL	D9	78232355	11/03	100.037	100.44	100.034
CHL	D9	78232356	11/03	100.037	100.44	100.034
CHL	D9	78232357	11/03	100.037	100.44	100.034
CHL	D9	78232358	11/03	100.037	100.44	100.034
CHL	D9	78232359	11/03	100.037	100.44	100.034
CHL	D9	78232360	11/03	100.037	100.44	100.034

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
CHLUMBE	D9	7823770	2002-12-19	99.96	100.34	100.05
CHLUMBE	D9	7823771	2002-12-19	100.13	99.95	100.30
CHLUMBE	D9	7823772	2002-12-19	100.10	100.29	100.10
CHLUMBE	D9	7823773	2002-12-19	100.05	100.08	100.36
CHLUMBE	D9	7823774	2002-12-19	100.17	99.46	100.11
CHLUMBE	D9	7823775	2002-12-19	99.99	100.40	100.24
CHLUMBE	D9	7823776	2002-12-19	100.20	100.15	100.25
CHLUMBE	D9	7823777	2002-12-19	100.05	100.37	100.09
CHLUMBE	D9	7823778	2002-12-19	100.05	100.03	100.33
CHLUMBE	D9	7823779	2002-12-19	100.21	100.44	100.59
CHLUMBE	D9	7823780	2002-12-19	100.04	99.32	100.72
CHLUMBE	D9	7823801	2002-12-19	99.97	100.21	99.93
CHLUMBE	D9	7823802	2002-12-19	100.10	100.10	100.24
CHLUMBE	D9	7823803	2002-12-19	100.13	100.25	100.02
CHLUMBE	D9	7823804	2002-12-19	99.79	99.58	100.36
CHLUMBE	D9	7823805	2002-12-19	99.26	100.21	100.09
CHLUMBE	D9	7823806	2002-12-19	100.14	100.41	100.08
CHLUMBE	D9	7823807	2002-12-19	100.15	100.42	97.34
CHLUMBE	D9	7823808	2002-12-19	100.05	99.71	100.39
CHLUMBE	D9	7823809	2002-12-19	99.95	100.28	99.09
CHLUMBE	D9	7823810	2002-12-19	100.04	100.19	100.12
CHLUMBE	D9	7823811	2002-12-19	99.97	100.49	100.31
CHLUMBE	D9	7823812	2002-12-19	100.11	100.27	100.12
CHLUMBE	D9	7823813	2002-12-19	99.99	99.45	100.01
CHLUMBE	D9	7823814	2002-12-19	100.19	100.37	100.04
CHLUMBE	D9	7823815	2002-12-19	99.95	99.92	100.04
CHLUMBE	D9	7823816	2002-12-19	100.19	100.11	99.89
CHLUMBE	D9	7823817	2002-12-19	99.94	100.31	99.51
CHLUMBE	D9	7823818	2002-12-19	100.07	99.88	100.31
CHLUMBE	D9	7823819	2002-12-19	100.00	100.22	97.94
CHLUMBE	D9	7823820	2002-12-19	99.86	100.15	100.28
CHLUMBE	D9	7823821	2002-12-19	99.88	100.26	100.47
CHLUMBE	D9	7823822	2002-12-19	99.95	99.74	99.79
CHLUMBE	D9	7823823	2002-12-19	100.00	100.08	99.37
CHLUMBE	D9	7823824	2002-12-19	100.00	100.08	100.05
CHLUMBE	D9	7823825	2002-12-19	100.10	100.08	100.11
CHLUMBE	D9	7823826	2002-12-19	100.04	99.89	100.14
CHLUMBE	D9	7823827	2002-12-19	99.11	99.89	99.50
CHLUMBE	D9	7823828	2002-12-19	100.06	100.32	99.98
CHLUMBE	D9	7823829	2002-12-19	99.90	100.13	100.34
CHLUMBE	D9	7823830	2002-12-19	99.85	100.43	100.09
CHLUMBE	D9	7823831	2002-12-19	100.03	100.40	100.27
CHLUMBE	D9	7823832	2002-12-19	99.96	100.10	100.52
CHLUMBE	D9	7823833	2002-12-19	100.00	100.10	100.04
CHLUMBE	D9	7823834	2002-12-19	99.97	100.36	99.04

LOUISVILLE GAS & ELECTRIC COMPANY
METER SUBSYSTEM (MSS)
NEW METERS ADDED LAST YEAR

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACOR
SCM	U	794780	2002-11-10	100.08	079.84	079.73
SCM	U	794781	2002-11-10	100.11	100.02	100.03
SCM	U	794782	2002-11-10	100.10	100.12	100.12
SCM	U	794783	2002-11-10	100.07	100.12	100.05
SCM	U	794784	2002-11-10	100.11	100.12	100.10
SCM	U	794785	2002-11-10	100.11	079.04	100.02
SCM	U	794786	2002-11-10	100.02	100.04	100.04
SCM	U	794787	2002-11-10	100.09	100.14	100.09
SCM	U	794788	2002-11-10	100.11	100.10	100.04
SCM	U	794789	2002-11-10	100.09	100.12	100.07
SCM	U	794790	2002-11-10	100.10	100.09	100.14
SCM	U	794791	2002-11-10	100.09	100.09	100.07
SCM	U	794792	2002-11-10	100.10	100.14	100.04
SCM	U	794793	2002-11-10	100.07	100.11	100.03
SCM	U	794794	2002-11-10	100.12	100.10	100.10
SCM	U	794795	2002-11-10	100.09	100.07	100.12
SCM	U	794796	2002-11-10	100.10	100.12	100.04
SCM	U	794797	2002-11-10	100.07	100.14	100.07
SCM	U	794798	2002-11-10	100.10	100.12	100.04
SCM	U	794799	2002-11-10	100.12	100.07	100.06
SCM	U	794800	2002-11-10	100.07	100.14	100.09
SCM	U	794801	2002-11-10	100.09	100.11	100.06
SCM	U	794802	2002-11-10	100.10	100.14	100.04
SCM	U	794803	2002-11-10	100.09	100.14	100.07
SCM	U	794804	2002-11-10	100.10	100.12	100.05
SCM	U	794805	2002-11-10	100.10	100.07	100.07
SCM	U	794806	2002-11-10	100.10	100.09	100.07
SCM	U	794807	2002-11-10	100.10	100.09	100.05
SCM	U	794808	2002-11-10	100.10	100.09	100.05
SCM	U	794809	2002-11-10	100.10	100.09	100.05
SCM	U	794810	2002-11-10	100.10	100.09	100.05
SCM	U	794811	2002-11-10	100.10	100.09	100.05
SCM	U	794812	2002-11-10	100.10	100.09	100.05
SCM	U	794813	2002-11-10	100.10	100.09	100.05
SCM	U	794814	2002-11-10	100.10	100.09	100.05
SCM	U	794815	2002-11-10	100.10	100.09	100.05
SCM	U	794816	2002-11-10	100.10	100.09	100.05
SCM	U	794817	2002-11-10	100.10	100.09	100.05
SCM	U	794818	2002-11-10	100.10	100.09	100.05
SCM	U	794819	2002-11-10	100.10	100.09	100.05
SCM	U	794820	2002-11-10	100.10	100.09	100.05
SCM	U	794821	2002-11-10	100.10	100.09	100.05
SCM	U	794822	2002-11-10	100.10	100.09	100.05
SCM	U	794823	2002-11-10	100.10	100.09	100.05
SCM	U	794824	2002-11-10	100.10	100.09	100.05
SCM	U	794825	2002-11-10	100.10	100.09	100.05
SCM	U	794826	2002-11-10	100.10	100.09	100.05
SCM	U	794827	2002-11-10	100.10	100.09	100.05
SCM	U	794828	2002-11-10	100.10	100.09	100.05
SCM	U	794829	2002-11-10	100.10	100.09	100.05
SCM	U	794830	2002-11-10	100.10	100.09	100.05
SCM	U	794831	2002-11-10	100.10	100.09	100.05
SCM	U	794832	2002-11-10	100.10	100.09	100.05
SCM	U	794833	2002-11-10	100.10	100.09	100.05
SCM	U	794834	2002-11-10	100.10	100.09	100.05
SCM	U	794835	2002-11-10	100.10	100.09	100.05
SCM	U	794836	2002-11-10	100.10	100.09	100.05
SCM	U	794837	2002-11-10	100.10	100.09	100.05
SCM	U	794838	2002-11-10	100.10	100.09	100.05
SCM	U	794839	2002-11-10	100.10	100.09	100.05
SCM	U	794840	2002-11-10	100.10	100.09	100.05

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
CHL UM82	01	7968330	2002-12-29	100.07	100.05	100.08
CHL UM82	01	7968331	2002-12-29	100.09	100.00	100.09
CHL UM82	01	7968332	2002-12-29	100.07	100.09	100.03
CHL UM82	01	7968333	2002-12-29	100.09	100.04	100.08
CHL UM82	01	7968334	2002-12-29	100.09	100.19	100.08
CHL UM82	01	7968335	2002-12-29	100.10	100.14	100.07
CHL UM82	01	7968336	2002-12-29	100.10	100.09	100.08
CHL UM82	01	7968337	2002-12-29	100.10	100.11	100.09
CHL UM82	01	7968338	2002-12-29	100.10	097.94	097.98
CHL UM82	01	7968339	2002-12-29	100.09	100.09	100.08
CHL UM82	01	7968340	2002-12-29	100.09	100.02	100.10
CHL UM82	01	7968341	2002-12-29	100.09	100.09	100.08
CHL UM82	01	7968342	2002-12-29	100.10	100.11	100.09
CHL UM82	01	7968343	2002-12-29	100.10	100.07	100.08
CHL UM82	01	7968344	2002-12-29	100.10	100.12	100.09
CHL UM82	01	7968345	2002-12-29	100.12	100.07	100.06
CHL UM82	01	7968346	2002-12-29	100.11	100.12	100.06
CHL UM82	01	7968347	2002-12-29	100.09	100.06	100.06
CHL UM82	01	7968348	2002-12-29	100.11	100.15	100.09
CHL UM82	01	7968349	2002-12-29	100.09	100.12	100.09
CHL UM82	01	7968350	2002-12-29	100.09	100.07	100.11
CHL UM82	01	7968351	2002-12-29	100.11	100.07	100.04
CHL UM82	01	7968352	2002-12-29	100.10	100.07	100.05
CHL UM82	01	7968353	2002-12-29	100.09	100.07	100.04
CHL UM82	01	7968354	2002-12-29	100.11	100.14	100.10
CHL UM82	01	7968355	2002-12-29	100.07	100.09	100.04
CHL UM82	01	7968356	2002-12-29	100.07	100.12	100.06
CHL UM82	01	7968357	2002-12-29	100.09	100.05	100.06
CHL UM82	01	7968358	2002-12-29	100.09	100.08	100.06
CHL UM82	01	7968359	2002-12-29	100.09	100.04	100.05
CHL UM82	01	7968360	2002-12-29	100.09	100.07	100.04
CHL UM82	01	7968361	2002-12-29	100.09	100.12	100.05
CHL UM82	01	7968362	2002-12-29	100.10	100.10	100.04
CHL UM82	01	7968363	2002-12-29	100.09	100.07	100.05
CHL UM82	01	7968364	2002-12-29	100.07	100.03	100.04
CHL UM82	01	7968365	2002-12-29	100.14	100.04	100.05
CHL UM82	01	7968366	2002-12-29	100.09	100.08	100.09
CHL UM82	01	7968367	2002-12-29	100.08	100.14	100.09
CHL UM82	01	7968368	2002-12-29	100.10	100.12	100.07
CHL UM82	01	7968369	2002-12-29	100.09	100.13	100.08
CHL UM82	01	7968370	2002-12-29	100.11	100.14	100.08
CHL UM82	01	7968371	2002-12-29	100.09	100.05	100.05
CHL UM82	01	7968372	2002-12-29	100.06	100.01	100.02
CHL UM82	01	7968373	2002-12-29	100.09	100.04	100.08
CHL UM82	01	7968374	2002-12-29	100.11	100.08	100.05
CHL UM82	01	7968375	2002-12-29	100.10	100.04	100.04
CHL UM82	01	7968376	2002-12-29	100.09	100.10	100.04
CHL UM82	01	7968377	2002-12-29	100.10	100.07	100.04
CHL UM82	01	7968378	2002-12-29	100.08	100.01	100.02
CHL UM82	01	7968379	2002-12-29	100.12	097.99	100.04

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFactor
WCHL	UM88	7969730	2002-11-22	100.09	100.02	100.01
WCHL	UM88	7969731	2002-11-22	100.10	100.05	100.07
WCHL	UM88	7969732	2002-11-22	100.08	100.10	100.04
WCHL	UM88	7969733	2002-11-22	100.10	100.11	100.05
WCHL	UM88	7969734	2002-11-22	100.11	100.08	100.08
WCHL	UM88	7969735	2002-11-22	100.08	100.04	100.09
WCHL	UM88	7969736	2002-11-22	100.10	100.09	100.04
WCHL	UM88	7969737	2002-11-22	100.10	100.12	100.06
WCHL	UM88	7969738	2002-11-22	100.09	100.09	100.04
WCHL	UM88	7969739	2002-11-22	100.10	100.11	100.06
WCHL	UM88	7969740	2002-11-22	100.07	100.11	100.10
WCHL	UM88	7969741	2002-11-22	100.09	100.12	100.06
WCHL	UM88	7969742	2002-11-22	100.10	100.11	100.04
WCHL	UM88	7969743	2002-11-22	100.10	100.12	100.06
WCHL	UM88	7969744	2002-11-22	100.09	100.11	100.06
WCHL	UM88	7969745	2002-11-22	100.10	100.12	100.06
WCHL	UM88	7969746	2002-11-22	100.09	100.11	100.06
WCHL	UM88	7969747	2002-11-22	100.10	100.12	100.06
WCHL	UM88	7969748	2002-11-22	100.09	100.11	100.06
WCHL	UM88	7969749	2002-11-22	100.10	100.12	100.06
WCHL	UM88	7969750	2002-11-22	100.09	100.11	100.06
WCHL	UM88	7969751	2002-11-22	100.10	100.12	100.06
WCHL	UM88	7969752	2002-11-22	100.09	100.11	100.06
WCHL	UM88	7969753	2002-11-22	100.10	100.12	100.06
WCHL	UM88	7969754	2002-11-22	100.09	100.11	100.06
WCHL	UM88	7969755	2002-11-22	100.10	100.12	100.06
WCHL	UM88	7969756	2002-11-22	100.09	100.11	100.06
WCHL	UM88	7969757	2002-11-22	100.10	100.12	100.06
WCHL	UM88	7969758	2002-11-22	100.09	100.11	100.06
WCHL	UM88	7969759	2002-11-22	100.10	100.12	100.06
WCHL	UM88	7969760	2002-11-22	100.09	100.11	100.06
WCHL	UM88	7969761	2002-11-22	100.10	100.12	100.06
WCHL	UM88	7969762	2002-11-22	100.09	100.11	100.06
WCHL	UM88	7969763	2002-11-22	100.10	100.12	100.06
WCHL	UM88	7969764	2002-11-22	100.09	100.11	100.06
WCHL	UM88	7969765	2002-11-22	100.10	100.12	100.06
WCHL	UM88	7969766	2002-11-22	100.09	100.11	100.06
WCHL	UM88	7969767	2002-11-22	100.10	100.12	100.06
WCHL	UM88	7969768	2002-11-22	100.09	100.11	100.06
WCHL	UM88	7969769	2002-11-22	100.10	100.12	100.06
WCHL	UM88	7969770	2002-11-22	100.09	100.11	100.06
WCHL	UM88	7969771	2002-11-22	100.10	100.12	100.06
WCHL	UM88	7969772	2002-11-22	100.09	100.11	100.06
WCHL	UM88	7969773	2002-11-22	100.10	100.12	100.06
WCHL	UM88	7969774	2002-11-22	100.09	100.11	100.06
WCHL	UM88	7969775	2002-11-22	100.10	100.12	100.06
WCHL	UM88	7969776	2002-11-22	100.09	100.11	100.06
WCHL	UM88	7969777	2002-11-22	100.10	100.12	100.06
WCHL	UM88	7969778	2002-11-22	100.09	100.11	100.06
WCHL	UM88	7969779	2002-11-22	100.10	100.12	100.06

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	01	797030	2002-12-20	100.09	100.09	100.02
SCHLUMBERGER	01	797031	2002-12-20	100.09	100.04	100.04
SCHLUMBERGER	01	797032	2002-12-20	100.10	100.09	100.04
SCHLUMBERGER	01	797033	2002-12-20	100.10	100.13	100.05
SCHLUMBERGER	01	797034	2002-12-20	100.10	100.08	100.03
SCHLUMBERGER	01	797035	2002-12-20	100.10	100.08	100.07
SCHLUMBERGER	01	797037	2002-12-20	100.11	100.07	100.05
SCHLUMBERGER	01	797038	2002-12-20	100.10	100.04	100.12
SCHLUMBERGER	01	797039	2002-12-20	100.09	100.04	100.09
SCHLUMBERGER	01	797040	2002-12-20	100.10	100.03	100.09
SCHLUMBERGER	01	797041	2002-12-20	100.11	100.04	100.07
SCHLUMBERGER	01	797042	2002-12-20	100.11	100.07	100.14
SCHLUMBERGER	01	797043	2002-12-20	100.11	100.07	100.14
SCHLUMBERGER	01	797044	2002-12-20	100.11	100.07	100.07
SCHLUMBERGER	01	797045	2002-12-20	100.11	100.07	100.07
SCHLUMBERGER	01	797046	2002-12-20	100.11	100.07	100.07
SCHLUMBERGER	01	797047	2002-12-20	100.11	100.07	100.07
SCHLUMBERGER	01	797048	2002-12-20	100.11	100.07	100.07
SCHLUMBERGER	01	797049	2002-12-20	100.11	100.07	100.07
SCHLUMBERGER	01	797050	2002-12-20	100.11	100.07	100.07
SCHLUMBERGER	01	797051	2002-12-20	100.11	100.07	100.07
SCHLUMBERGER	01	797052	2002-12-20	100.11	100.07	100.07
SCHLUMBERGER	01	797053	2002-12-20	100.11	100.07	100.07
SCHLUMBERGER	01	797054	2002-12-20	100.11	100.07	100.07
SCHLUMBERGER	01	797055	2002-12-20	100.11	100.07	100.07
SCHLUMBERGER	01	797056	2002-12-20	100.11	100.07	100.07
SCHLUMBERGER	01	797057	2002-12-20	100.11	100.07	100.07
SCHLUMBERGER	01	797058	2002-12-20	100.11	100.07	100.07
SCHLUMBERGER	01	797059	2002-12-20	100.11	100.07	100.07
SCHLUMBERGER	01	797060	2002-12-20	100.11	100.07	100.07
SCHLUMBERGER	01	797061	2002-12-20	100.11	100.07	100.07
SCHLUMBERGER	01	797062	2002-12-20	100.11	100.07	100.07
SCHLUMBERGER	01	797063	2002-12-20	100.11	100.07	100.07
SCHLUMBERGER	01	797064	2002-12-20	100.11	100.07	100.07
SCHLUMBERGER	01	797065	2002-12-20	100.11	100.07	100.07
SCHLUMBERGER	01	797066	2002-12-20	100.11	100.07	100.07
SCHLUMBERGER	01	797067	2002-12-20	100.11	100.07	100.07
SCHLUMBERGER	01	797068	2002-12-20	100.11	100.07	100.07
SCHLUMBERGER	01	797069	2002-12-20	100.11	100.07	100.07
SCHLUMBERGER	01	797070	2002-12-20	100.11	100.07	100.07
SCHLUMBERGER	01	797071	2002-12-20	100.11	100.07	100.07
SCHLUMBERGER	01	797072	2002-12-20	100.11	100.07	100.07
SCHLUMBERGER	01	797073	2002-12-20	100.11	100.07	100.07
SCHLUMBERGER	01	797074	2002-12-20	100.11	100.07	100.07
SCHLUMBERGER	01	797075	2002-12-20	100.11	100.07	100.07
SCHLUMBERGER	01	797076	2002-12-20	100.11	100.07	100.07
SCHLUMBERGER	01	797077	2002-12-20	100.11	100.07	100.07
SCHLUMBERGER	01	797078	2002-12-20	100.11	100.07	100.07
SCHLUMBERGER	01	797079	2002-12-20	100.11	100.07	100.07
SCHLUMBERGER	01	797080	2002-12-20	100.11	100.07	100.07

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACOR
SCHLUMBERGER	01	7971331	2002-12-29	100.10	100.02	100.01
SCHLUMBERGER	01	7971331	2002-12-29	100.11	100.14	100.03
SCHLUMBERGER	01	7971333	2002-12-29	100.07	100.06	100.02
SCHLUMBERGER	01	7971333	2002-12-29	100.10	100.10	100.02
SCHLUMBERGER	01	7971334	2002-12-29	100.09	100.07	100.02
SCHLUMBERGER	01	7971335	2002-12-29	100.09	100.05	100.02
SCHLUMBERGER	01	7971337	2002-12-29	100.11	100.08	100.04
SCHLUMBERGER	01	7971337	2002-12-29	100.11	100.08	100.04
SCHLUMBERGER	01	7971339	2002-12-29	100.08	100.06	100.02
SCHLUMBERGER	01	7971339	2002-12-29	100.11	100.09	100.02
SCHLUMBERGER	01	7971441	2002-12-29	100.09	100.07	100.02
SCHLUMBERGER	01	7971441	2002-12-29	100.11	100.13	100.02
SCHLUMBERGER	01	7971442	2002-12-29	100.09	100.04	100.04
SCHLUMBERGER	01	7971442	2002-12-29	100.12	100.07	100.04
SCHLUMBERGER	01	7971444	2002-12-29	100.11	100.09	100.02
SCHLUMBERGER	01	7971444	2002-12-29	100.11	100.13	100.02
SCHLUMBERGER	01	7971445	2002-12-29	100.11	100.13	100.02
SCHLUMBERGER	01	7971445	2002-12-29	100.11	100.13	100.02
SCHLUMBERGER	01	7971447	2002-12-29	100.10	100.09	100.02
SCHLUMBERGER	01	7971447	2002-12-29	100.10	100.12	100.02
SCHLUMBERGER	01	7971449	2002-12-29	100.09	100.08	100.02
SCHLUMBERGER	01	7971449	2002-12-29	100.10	100.07	100.02
SCHLUMBERGER	01	7971551	2002-12-29	100.10	100.09	100.02
SCHLUMBERGER	01	7971551	2002-12-29	100.11	100.07	100.02
SCHLUMBERGER	01	7971552	2002-12-29	100.11	100.09	100.02
SCHLUMBERGER	01	7971552	2002-12-29	100.11	100.07	100.02
SCHLUMBERGER	01	7971554	2002-12-29	100.10	100.11	100.02
SCHLUMBERGER	01	7971554	2002-12-29	100.10	100.11	100.02
SCHLUMBERGER	01	7971554	2002-12-29	100.11	100.11	100.02
SCHLUMBERGER	01	7971554	2002-12-29	100.11	100.11	100.02
SCHLUMBERGER	01	7971557	2002-12-29	100.11	100.11	100.02
SCHLUMBERGER	01	7971557	2002-12-29	100.11	100.11	100.02
SCHLUMBERGER	01	7971559	2002-12-29	100.11	100.11	100.02
SCHLUMBERGER	01	7971559	2002-12-29	100.11	100.11	100.02
SCHLUMBERGER	01	7971660	2002-12-29	100.10	100.09	100.02
SCHLUMBERGER	01	7971660	2002-12-29	100.10	100.11	100.02
SCHLUMBERGER	01	7971661	2002-12-29	100.10	100.10	100.02
SCHLUMBERGER	01	7971661	2002-12-29	100.10	100.15	100.02
SCHLUMBERGER	01	7971662	2002-12-29	100.09	100.04	100.02
SCHLUMBERGER	01	7971662	2002-12-29	100.10	100.07	100.02
SCHLUMBERGER	01	7971664	2002-12-29	100.10	100.05	100.02
SCHLUMBERGER	01	7971664	2002-12-29	100.10	100.02	100.02
SCHLUMBERGER	01	7971665	2002-12-29	100.10	100.05	100.10
SCHLUMBERGER	01	7971665	2002-12-29	100.10	100.10	100.10
SCHLUMBERGER	01	7971667	2002-12-29	100.11	100.12	100.10
SCHLUMBERGER	01	7971669	2002-12-29	100.11	100.11	100.08
SCHLUMBERGER	01	7971669	2002-12-29	100.11	100.11	100.08
SCHLUMBERGER	01	7971670	2002-12-29	100.11	100.11	100.14
SCHLUMBERGER	01	7971671	2002-12-29	100.11	100.11	100.14
SCHLUMBERGER	01	7971772	2002-12-29	100.12	100.14	100.02
SCHLUMBERGER	01	7971773	2002-12-29	100.10	100.04	100.02
SCHLUMBERGER	01	7971774	2002-12-29	100.12	100.14	100.02
SCHLUMBERGER	01	7971775	2002-12-29	100.08	100.14	100.02
SCHLUMBERGER	01	7971776	2002-12-29	100.10	100.08	100.01
SCHLUMBERGER	01	7971777	2002-12-29	100.09	100.10	100.02
SCHLUMBERGER	01	7971779	2002-12-29	100.08	100.10	100.02
SCHLUMBERGER	01	7971779	2002-12-29	100.08	100.14	100.02

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PF FACTOR
CHLUMBERGER	01	797180	2002-12-29	100.09	100.09	100.03
CHLUMBERGER	01	797181	2002-12-29	100.09	099.97	100.03
CHLUMBERGER	01	797182	2002-12-29	100.08	100.17	100.03
CHLUMBERGER	01	797183	2002-12-29	100.11	100.14	100.02
CHLUMBERGER	01	797184	2002-12-29	100.08	100.10	100.04
CHLUMBERGER	01	797185	2002-12-29	100.11	100.11	100.07
CHLUMBERGER	01	797186	2002-12-29	100.10	100.10	100.05
CHLUMBERGER	01	797187	2002-12-29	100.08	100.07	100.03
CHLUMBERGER	01	797188	2002-12-29	100.08	100.08	100.03
CHLUMBERGER	01	797189	2002-12-29	100.10	100.09	100.05
CHLUMBERGER	01	797190	2002-12-29	100.08	100.09	100.03
CHLUMBERGER	01	797191	2002-12-29	100.11	100.10	100.03
CHLUMBERGER	01	797192	2002-12-29	100.08	100.07	100.03
CHLUMBERGER	01	797193	2002-12-29	100.08	100.07	100.03
CHLUMBERGER	01	797194	2002-12-29	100.09	100.08	100.03
CHLUMBERGER	01	797195	2002-12-29	100.09	100.08	100.03
CHLUMBERGER	01	797196	2002-12-29	100.07	100.05	100.03
CHLUMBERGER	01	797197	2002-12-29	100.10	100.09	100.03
CHLUMBERGER	01	797198	2002-12-29	100.10	100.09	100.03
CHLUMBERGER	01	797199	2002-12-29	100.08	100.07	100.03
CHLUMBERGER	01	797200	2002-12-29	100.10	100.09	100.03
CHLUMBERGER	01	797201	2002-12-29	100.09	100.08	100.03
CHLUMBERGER	01	797202	2002-12-29	100.11	100.10	100.04
CHLUMBERGER	01	797203	2002-12-29	100.09	100.08	100.03
CHLUMBERGER	01	797204	2002-12-29	100.10	100.09	100.03
CHLUMBERGER	01	797205	2002-12-29	100.11	100.10	100.04
CHLUMBERGER	01	797206	2002-12-29	100.10	100.09	100.03
CHLUMBERGER	01	797207	2002-12-29	100.11	100.10	100.04
CHLUMBERGER	01	797208	2002-12-29	100.10	099.99	100.03
CHLUMBERGER	01	797209	2002-12-29	100.10	100.10	100.03
CHLUMBERGER	01	797210	2002-12-29	100.08	100.08	100.03
CHLUMBERGER	01	797211	2002-12-29	100.08	100.08	100.03
CHLUMBERGER	01	797212	2002-12-29	100.10	100.09	100.03
CHLUMBERGER	01	797213	2002-12-29	100.08	100.08	100.03
CHLUMBERGER	01	797214	2002-12-29	100.10	100.09	100.03
CHLUMBERGER	01	797215	2002-12-29	100.08	100.08	100.03
CHLUMBERGER	01	797216	2002-12-29	100.10	100.09	100.03
CHLUMBERGER	01	797217	2002-12-29	100.10	100.09	100.03
CHLUMBERGER	01	797218	2002-12-29	100.08	100.07	100.03
CHLUMBERGER	01	797219	2002-12-29	100.10	100.09	100.03
CHLUMBERGER	01	797220	2002-12-29	100.08	100.08	100.03
CHLUMBERGER	01	797221	2002-12-29	100.10	100.09	100.03
CHLUMBERGER	01	797222	2002-12-29	100.08	100.08	100.03
CHLUMBERGER	01	797223	2002-12-29	100.10	100.09	100.03
CHLUMBERGER	01	797224	2002-12-29	100.08	100.08	100.03
CHLUMBERGER	01	797225	2002-12-29	100.10	100.09	100.03
CHLUMBERGER	01	797226	2002-12-29	100.08	100.08	100.03
CHLUMBERGER	01	797227	2002-12-29	100.10	100.09	100.03
CHLUMBERGER	01	797228	2002-12-29	100.08	100.08	100.03
CHLUMBERGER	01	797229	2002-12-29	100.10	100.09	100.03
CHLUMBERGER	01	797230	2002-12-29	100.08	100.08	100.03

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	01	797230	2002-12-29	100.09	100.09	100.09
SCHLUMBERGER	01	797231	2002-12-29	100.09	100.18	100.01
SCHLUMBERGER	01	797232	2002-12-29	100.08	099.94	100.04
SCHLUMBERGER	01	797233	2002-12-29	100.08	100.10	099.99
SCHLUMBERGER	01	797234	2002-12-29	100.11	100.12	100.07
SCHLUMBERGER	01	797235	2002-12-29	100.11	100.14	100.12
SCHLUMBERGER	01	797236	2002-12-29	100.08	100.01	100.03
SCHLUMBERGER	01	797237	2002-12-29	100.08	100.14	100.04
SCHLUMBERGER	01	797238	2002-12-29	100.10	100.12	100.07
SCHLUMBERGER	01	797239	2002-12-29	100.10	100.12	100.12
SCHLUMBERGER	01	797240	2002-12-29	100.10	100.11	100.10
SCHLUMBERGER	01	797241	2002-12-29	100.08	100.02	100.12
SCHLUMBERGER	01	797242	2002-12-29	100.11	100.10	100.12
SCHLUMBERGER	01	797243	2002-12-29	100.11	100.09	100.10
SCHLUMBERGER	01	797244	2002-12-29	100.10	100.11	100.05
SCHLUMBERGER	01	797245	2002-12-29	100.08	100.09	100.05
SCHLUMBERGER	01	797246	2002-12-29	100.08	100.06	100.05
SCHLUMBERGER	01	797247	2002-12-29	100.09	100.12	100.06
SCHLUMBERGER	01	797248	2002-12-29	100.09	100.12	100.06
SCHLUMBERGER	01	797249	2002-12-29	100.09	100.13	100.07
SCHLUMBERGER	01	797250	2002-12-29	100.11	100.11	100.10
SCHLUMBERGER	01	797251	2002-12-29	100.11	100.11	100.10
SCHLUMBERGER	01	797252	2002-12-29	100.08	099.99	100.05
SCHLUMBERGER	01	797253	2002-12-29	100.10	100.17	100.06
SCHLUMBERGER	01	797254	2002-12-29	100.12	100.12	100.06
SCHLUMBERGER	01	797255	2002-12-29	100.12	100.12	100.05
SCHLUMBERGER	01	797256	2002-12-29	100.07	100.12	100.05
SCHLUMBERGER	01	797257	2002-12-29	100.07	100.12	100.05
SCHLUMBERGER	01	797258	2002-12-29	100.08	100.09	099.99
SCHLUMBERGER	01	797259	2002-12-29	100.08	100.07	100.06
SCHLUMBERGER	01	797260	2002-12-29	100.09	100.04	100.06
SCHLUMBERGER	01	797261	2002-12-29	100.11	100.15	100.15
SCHLUMBERGER	01	797262	2002-12-29	100.11	100.13	100.05
SCHLUMBERGER	01	797263	2002-12-29	100.10	100.10	100.07
SCHLUMBERGER	01	797264	2002-12-29	100.10	100.09	100.07
SCHLUMBERGER	01	797265	2002-12-29	100.10	100.12	100.07
SCHLUMBERGER	01	797266	2002-12-29	100.10	100.12	100.07
SCHLUMBERGER	01	797267	2002-12-29	100.10	100.12	100.07
SCHLUMBERGER	01	797268	2002-12-29	100.07	100.09	100.07
SCHLUMBERGER	01	797269	2002-12-29	100.08	100.08	100.07
SCHLUMBERGER	01	797270	2002-12-29	100.08	100.09	100.07
SCHLUMBERGER	01	797271	2002-12-29	100.11	100.15	100.07
SCHLUMBERGER	01	797272	2002-12-29	100.09	100.15	100.07
SCHLUMBERGER	01	797273	2002-12-29	100.11	100.15	100.07
SCHLUMBERGER	01	797274	2002-12-29	100.12	100.14	100.08
SCHLUMBERGER	01	797275	2002-12-29	100.12	100.14	100.08
SCHLUMBERGER	01	797276	2002-12-29	100.11	100.14	100.08
SCHLUMBERGER	01	797277	2002-12-29	100.09	100.10	100.08
SCHLUMBERGER	01	797278	2002-12-29	100.10	100.10	100.11
SCHLUMBERGER	01	797279	2002-12-29	100.10	100.10	100.11

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACOR
U	1	7972380	2000011	100.07	100.02	100.00
U	1	7972381	2000011	100.07	100.11	100.00
U	1	7972382	2000011	100.08	100.12	100.05
U	1	7972383	2000011	100.08	100.12	100.07
U	1	7972384	2000011	100.08	100.07	100.09
U	1	7972385	2000011	100.08	100.07	100.11
U	1	7972386	2000011	100.08	100.07	100.04
U	1	7972387	2000011	100.08	100.07	100.07
U	1	7972388	2000011	100.08	100.07	100.07
U	1	7972389	2000011	100.08	100.07	100.07
U	1	7972390	2000011	100.08	100.07	100.07
U	1	7972391	2000011	100.08	100.07	100.04
U	1	7972392	2000011	100.08	100.07	100.04
U	1	7972393	2000011	100.08	100.07	100.04
U	1	7972394	2000011	100.08	100.07	100.04
U	1	7972395	2000011	100.08	100.07	100.04
U	1	7972396	2000011	100.08	100.07	100.04
U	1	7972397	2000011	100.08	100.07	100.04
U	1	7972398	2000011	100.08	100.07	100.04
U	1	7972399	2000011	100.08	100.07	100.04
U	1	7972400	2000011	100.08	100.07	100.04
U	1	7972401	2000011	100.08	100.07	100.04
U	1	7972402	2000011	100.08	100.07	100.04
U	1	7972403	2000011	100.08	100.07	100.04
U	1	7972404	2000011	100.08	100.07	100.04
U	1	7972405	2000011	100.08	100.07	100.04
U	1	7972406	2000011	100.08	100.07	100.04
U	1	7972407	2000011	100.08	100.07	100.04
U	1	7972408	2000011	100.08	100.07	100.04
U	1	7972409	2000011	100.08	100.07	100.04
U	1	7972410	2000011	100.08	100.07	100.04
U	1	7972411	2000011	100.08	100.07	100.04
U	1	7972412	2000011	100.08	100.07	100.04
U	1	7972413	2000011	100.08	100.07	100.04
U	1	7972414	2000011	100.08	100.07	100.04
U	1	7972415	2000011	100.08	100.07	100.04
U	1	7972416	2000011	100.08	100.07	100.04
U	1	7972417	2000011	100.08	100.07	100.04
U	1	7972418	2000011	100.08	100.07	100.04
U	1	7972419	2000011	100.08	100.07	100.04
U	1	7972420	2000011	100.08	100.07	100.04
U	1	7972421	2000011	100.08	100.07	100.04
U	1	7972422	2000011	100.08	100.07	100.04
U	1	7972423	2000011	100.08	100.07	100.04
U	1	7972424	2000011	100.08	100.07	100.04
U	1	7972425	2000011	100.08	100.07	100.04
U	1	7972426	2000011	100.08	100.07	100.04
U	1	7972427	2000011	100.08	100.07	100.04
U	1	7972428	2000011	100.08	100.07	100.04
U	1	7972429	2000011	100.08	100.07	100.04
U	1	7972430	2000011	100.08	100.07	100.04

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	PULL LOAD	LIGHT LOAD	PFACOR
CHLUM	01	797320	2002-11-29	100.11	100.09	100.07
CHLUM	01	797331	2002-11-29	100.12	100.07	100.08
CHLUM	01	797332	2002-11-29	100.10	100.07	100.08
CHLUM	01	797333	2002-11-29	100.08	100.04	099.84
CHLUM	01	797334	2002-11-29	100.11	100.04	100.04
CHLUM	01	797335	2002-11-29	100.11	100.09	100.09
CHLUM	01	797336	2002-11-29	100.10	100.09	100.08
CHLUM	01	797337	2002-11-29	100.10	100.09	100.08
CHLUM	01	797338	2002-11-29	100.10	100.09	100.08
CHLUM	01	797339	2002-11-29	100.10	100.09	100.08
CHLUM	01	797340	2002-11-29	100.10	100.09	100.08
CHLUM	01	797341	2002-11-29	100.10	100.09	100.08
CHLUM	01	797342	2002-11-29	100.10	100.09	100.08
CHLUM	01	797343	2002-11-29	100.10	100.09	100.08
CHLUM	01	797344	2002-11-29	100.10	100.09	100.08
CHLUM	01	797345	2002-11-29	100.10	100.09	100.08
CHLUM	01	797346	2002-11-29	100.10	100.09	100.08
CHLUM	01	797347	2002-11-29	100.10	100.09	100.08
CHLUM	01	797348	2002-11-29	100.10	100.09	100.08
CHLUM	01	797349	2002-11-29	100.10	100.09	100.08
CHLUM	01	797350	2002-11-29	100.10	100.09	100.08
CHLUM	01	797351	2002-11-29	100.10	100.09	100.08
CHLUM	01	797352	2002-11-29	100.10	100.09	100.08
CHLUM	01	797353	2002-11-29	100.10	100.09	100.08
CHLUM	01	797354	2002-11-29	100.10	100.09	100.08
CHLUM	01	797355	2002-11-29	100.10	100.09	100.08
CHLUM	01	797356	2002-11-29	100.10	100.09	100.08
CHLUM	01	797357	2002-11-29	100.10	100.09	100.08
CHLUM	01	797358	2002-11-29	100.10	100.09	100.08
CHLUM	01	797359	2002-11-29	100.10	100.09	100.08
CHLUM	01	797360	2002-11-29	100.10	100.09	100.08
CHLUM	01	797361	2002-11-29	100.10	100.09	100.08
CHLUM	01	797362	2002-11-29	100.10	100.09	100.08
CHLUM	01	797363	2002-11-29	100.10	100.09	100.08
CHLUM	01	797364	2002-11-29	100.10	100.09	100.08
CHLUM	01	797365	2002-11-29	100.10	100.09	100.08
CHLUM	01	797366	2002-11-29	100.10	100.09	100.08
CHLUM	01	797367	2002-11-29	100.10	100.09	100.08
CHLUM	01	797368	2002-11-29	100.10	100.09	100.08
CHLUM	01	797369	2002-11-29	100.10	100.09	100.08
CHLUM	01	797370	2002-11-29	100.10	100.09	100.08
CHLUM	01	797371	2002-11-29	100.10	100.09	100.08
CHLUM	01	797372	2002-11-29	100.10	100.09	100.08
CHLUM	01	797373	2002-11-29	100.10	100.09	100.08
CHLUM	01	797374	2002-11-29	100.10	100.09	100.08
CHLUM	01	797375	2002-11-29	100.10	100.09	100.08
CHLUM	01	797376	2002-11-29	100.10	100.09	100.08
CHLUM	01	797377	2002-11-29	100.10	100.09	100.08
CHLUM	01	797378	2002-11-29	100.10	100.09	100.08
CHLUM	01	797379	2002-11-29	100.10	100.09	100.08

LOUISVILLE GAS & ELECTRIC COMPANY
METER SUBBY STEM (MS3)
NEW METERS ADDED LAST YEAR

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACOR
SCHLUMBERGER	01	7977280	2002-12-29	100.11	100.09	100.06
SCHLUMBERGER	01	7977281	2002-12-29	100.10	100.08	100.05
SCHLUMBERGER	01	7977282	2002-12-29	100.09	100.04	100.05
SCHLUMBERGER	01	7977283	2002-12-29	100.10	100.14	100.07
SCHLUMBERGER	01	7977284	2002-12-29	100.11	100.07	100.05
SCHLUMBERGER	01	7977285	2002-12-29	100.11	100.07	100.12
SCHLUMBERGER	01	7977286	2002-12-29	100.10	100.04	100.07
SCHLUMBERGER	01	7977287	2002-12-29	100.09	099.94	100.04
SCHLUMBERGER	01	7977288	2002-12-29	100.09	100.14	100.00
SCHLUMBERGER	01	7977289	2002-12-29	100.12	100.14	100.06
SCHLUMBERGER	01	7977290	2002-12-29	100.11	100.10	100.09
SCHLUMBERGER	01	7977291	2002-12-29	100.11	100.14	100.05
SCHLUMBERGER	01	7977292	2002-12-29	100.14	100.07	100.02
SCHLUMBERGER	01	7977293	2002-12-29	100.08	100.07	100.02
SCHLUMBERGER	01	7977294	2002-12-29	100.10	100.15	100.00
SCHLUMBERGER	01	7977295	2002-12-29	100.07	100.04	099.98
SCHLUMBERGER	01	7977296	2002-12-29	100.09	100.15	100.00
SCHLUMBERGER	01	7977297	2002-12-29	100.08	100.04	100.02
SCHLUMBERGER	01	7977298	2002-12-29	100.11	100.12	099.97
SCHLUMBERGER	01	7977299	2002-12-29	100.11	100.05	100.02
SCHLUMBERGER	01	7977300	2002-12-29	100.10	100.15	100.02
SCHLUMBERGER	01	7977401	2002-12-29	100.10	100.10	100.12
SCHLUMBERGER	01	7977402	2002-12-29	100.10	100.10	100.08
SCHLUMBERGER	01	7977403	2002-12-29	100.11	100.13	100.04
SCHLUMBERGER	01	7977404	2002-12-29	100.09	100.11	099.99
SCHLUMBERGER	01	7977405	2002-12-29	100.11	100.11	100.12
SCHLUMBERGER	01	7977406	2002-12-29	100.11	100.14	100.07
SCHLUMBERGER	01	7977407	2002-12-29	100.10	100.14	100.07
SCHLUMBERGER	01	7977408	2002-12-29	100.11	100.17	100.05
SCHLUMBERGER	01	7977409	2002-12-29	100.07	100.13	100.02
SCHLUMBERGER	01	7977410	2002-12-29	100.12	100.11	100.05
SCHLUMBERGER	01	7977411	2002-12-29	100.09	100.11	100.07
SCHLUMBERGER	01	7977412	2002-12-29	100.12	100.04	100.10
SCHLUMBERGER	01	7977413	2002-12-29	100.09	100.10	100.02
SCHLUMBERGER	01	7977414	2002-12-29	100.14	099.97	100.00
SCHLUMBERGER	01	7977415	2002-12-29	100.09	100.11	100.06
SCHLUMBERGER	01	7977416	2002-12-29	100.11	100.13	100.02
SCHLUMBERGER	01	7977417	2002-12-29	100.11	100.13	100.06
SCHLUMBERGER	01	7977418	2002-12-29	100.09	100.13	100.04
SCHLUMBERGER	01	7977419	2002-12-29	100.09	100.19	100.04
SCHLUMBERGER	01	7977420	2002-12-29	100.08	100.04	100.05
SCHLUMBERGER	01	7977421	2002-12-29	100.09	100.12	100.09
SCHLUMBERGER	01	7977422	2002-12-29	100.08	100.10	100.05
SCHLUMBERGER	01	7977423	2002-12-29	100.10	100.14	100.08
SCHLUMBERGER	01	7977424	2002-12-29	100.10	100.11	100.06
SCHLUMBERGER	01	7977425	2002-12-29	100.12	100.11	100.06
SCHLUMBERGER	01	7977426	2002-12-29	100.10	100.11	100.09
SCHLUMBERGER	01	7977427	2002-12-29	100.10	100.11	100.06
SCHLUMBERGER	01	7977428	2002-12-29	100.10	100.13	100.09
SCHLUMBERGER	01	7977429	2002-12-29	100.07	100.13	100.08

LOUISVILLE GAS & ELECTRIC COMPANY
METER SYSTEM (MS5)
NEW METERS ADDED LAST YEAR

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACOR
CHL	001	797433	2002-11-29	100.09	100.11	100.02
CHL	001	797434	2002-11-29	100.09	100.11	100.02
CHL	001	797435	2002-11-29	100.11	100.11	100.02
CHL	001	797436	2002-11-29	100.09	100.11	100.02
CHL	001	797437	2002-11-29	100.09	100.11	100.02
CHL	001	797438	2002-11-29	100.11	100.11	100.02
CHL	001	797439	2002-11-29	100.09	100.11	100.02
CHL	001	797440	2002-11-29	100.09	100.11	100.02
CHL	001	797441	2002-11-29	100.09	100.11	100.02
CHL	001	797442	2002-11-29	100.09	100.11	100.02
CHL	001	797443	2002-11-29	100.09	100.11	100.02
CHL	001	797444	2002-11-29	100.09	100.11	100.02
CHL	001	797445	2002-11-29	100.09	100.11	100.02
CHL	001	797446	2002-11-29	100.09	100.11	100.02
CHL	001	797447	2002-11-29	100.09	100.11	100.02
CHL	001	797448	2002-11-29	100.09	100.11	100.02
CHL	001	797449	2002-11-29	100.09	100.11	100.02
CHL	001	797450	2002-11-29	100.09	100.11	100.02
CHL	001	797451	2002-11-29	100.09	100.11	100.02
CHL	001	797452	2002-11-29	100.09	100.11	100.02
CHL	001	797453	2002-11-29	100.09	100.11	100.02
CHL	001	797454	2002-11-29	100.09	100.11	100.02
CHL	001	797455	2002-11-29	100.09	100.11	100.02
CHL	001	797456	2002-11-29	100.09	100.11	100.02
CHL	001	797457	2002-11-29	100.09	100.11	100.02
CHL	001	797458	2002-11-29	100.09	100.11	100.02
CHL	001	797459	2002-11-29	100.09	100.11	100.02
CHL	001	797460	2002-11-29	100.09	100.11	100.02
CHL	001	797461	2002-11-29	100.09	100.11	100.02
CHL	001	797462	2002-11-29	100.09	100.11	100.02
CHL	001	797463	2002-11-29	100.09	100.11	100.02
CHL	001	797464	2002-11-29	100.09	100.11	100.02
CHL	001	797465	2002-11-29	100.09	100.11	100.02
CHL	001	797466	2002-11-29	100.09	100.11	100.02
CHL	001	797467	2002-11-29	100.09	100.11	100.02
CHL	001	797468	2002-11-29	100.09	100.11	100.02
CHL	001	797469	2002-11-29	100.09	100.11	100.02
CHL	001	797470	2002-11-29	100.09	100.11	100.02
CHL	001	797471	2002-11-29	100.09	100.11	100.02
CHL	001	797472	2002-11-29	100.09	100.11	100.02
CHL	001	797473	2002-11-29	100.09	100.11	100.02
CHL	001	797474	2002-11-29	100.09	100.11	100.02
CHL	001	797475	2002-11-29	100.09	100.11	100.02
CHL	001	797476	2002-11-29	100.09	100.11	100.02
CHL	001	797477	2002-11-29	100.09	100.11	100.02
CHL	001	797478	2002-11-29	100.09	100.11	100.02
CHL	001	797479	2002-11-29	100.09	100.11	100.02

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PF FACTOR
SCHLUMBERGER	01	797530	2000-11-11	100-11	100-12	100-02
SCHLUMBERGER	01	797531	2000-11-11	100-11	100-12	100-02
SCHLUMBERGER	01	797532	2000-11-11	100-11	100-12	100-02
SCHLUMBERGER	01	797533	2000-11-11	100-11	100-12	100-02
SCHLUMBERGER	01	797534	2000-11-11	100-11	100-12	100-02
SCHLUMBERGER	01	797535	2000-11-11	100-11	100-12	100-02
SCHLUMBERGER	01	797536	2000-11-11	100-11	100-12	100-02
SCHLUMBERGER	01	797537	2000-11-11	100-11	100-12	100-02
SCHLUMBERGER	01	797538	2000-11-11	100-11	100-12	100-02
SCHLUMBERGER	01	797539	2000-11-11	100-11	100-12	100-02
SCHLUMBERGER	01	797540	2000-11-11	100-11	100-12	100-02
SCHLUMBERGER	01	797541	2000-11-11	100-11	100-12	100-02
SCHLUMBERGER	01	797542	2000-11-11	100-11	100-12	100-02
SCHLUMBERGER	01	797543	2000-11-11	100-11	100-12	100-02
SCHLUMBERGER	01	797544	2000-11-11	100-11	100-12	100-02
SCHLUMBERGER	01	797545	2000-11-11	100-11	100-12	100-02
SCHLUMBERGER	01	797546	2000-11-11	100-11	100-12	100-02
SCHLUMBERGER	01	797547	2000-11-11	100-11	100-12	100-02
SCHLUMBERGER	01	797548	2000-11-11	100-11	100-12	100-02
SCHLUMBERGER	01	797549	2000-11-11	100-11	100-12	100-02
SCHLUMBERGER	01	797550	2000-11-11	100-11	100-12	100-02
SCHLUMBERGER	01	797551	2000-11-11	100-11	100-12	100-02
SCHLUMBERGER	01	797552	2000-11-11	100-11	100-12	100-02
SCHLUMBERGER	01	797553	2000-11-11	100-11	100-12	100-02
SCHLUMBERGER	01	797554	2000-11-11	100-11	100-12	100-02
SCHLUMBERGER	01	797555	2000-11-11	100-11	100-12	100-02
SCHLUMBERGER	01	797556	2000-11-11	100-11	100-12	100-02
SCHLUMBERGER	01	797557	2000-11-11	100-11	100-12	100-02
SCHLUMBERGER	01	797558	2000-11-11	100-11	100-12	100-02
SCHLUMBERGER	01	797559	2000-11-11	100-11	100-12	100-02
SCHLUMBERGER	01	797560	2000-11-11	100-11	100-12	100-02
SCHLUMBERGER	01	797561	2000-11-11	100-11	100-12	100-02
SCHLUMBERGER	01	797562	2000-11-11	100-11	100-12	100-02
SCHLUMBERGER	01	797563	2000-11-11	100-11	100-12	100-02
SCHLUMBERGER	01	797564	2000-11-11	100-11	100-12	100-02
SCHLUMBERGER	01	797565	2000-11-11	100-11	100-12	100-02
SCHLUMBERGER	01	797566	2000-11-11	100-11	100-12	100-02
SCHLUMBERGER	01	797567	2000-11-11	100-11	100-12	100-02
SCHLUMBERGER	01	797568	2000-11-11	100-11	100-12	100-02
SCHLUMBERGER	01	797569	2000-11-11	100-11	100-12	100-02
SCHLUMBERGER	01	797570	2000-11-11	100-11	100-12	100-02
SCHLUMBERGER	01	797571	2000-11-11	100-11	100-12	100-02
SCHLUMBERGER	01	797572	2000-11-11	100-11	100-12	100-02
SCHLUMBERGER	01	797573	2000-11-11	100-11	100-12	100-02
SCHLUMBERGER	01	797574	2000-11-11	100-11	100-12	100-02
SCHLUMBERGER	01	797575	2000-11-11	100-11	100-12	100-02
SCHLUMBERGER	01	797576	2000-11-11	100-11	100-12	100-02
SCHLUMBERGER	01	797577	2000-11-11	100-11	100-12	100-02
SCHLUMBERGER	01	797578	2000-11-11	100-11	100-12	100-02
SCHLUMBERGER	01	797579	2000-11-11	100-11	100-12	100-02

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PF FACTOR
SCHLIMBERGER	01	797580	2002-12-20	100.08	100.10	100.07
SCHLIMBERGER	01	797581	2002-12-20	100.08	099.97	099.99
SCHLIMBERGER	01	797582	2002-12-20	100.11	100.11	100.07
SCHLIMBERGER	01	797583	2002-12-20	100.10	100.06	100.06
SCHLIMBERGER	01	797584	2002-12-20	100.10	100.08	100.06
SCHLIMBERGER	01	797585	2002-12-20	100.11	100.14	100.09
SCHLIMBERGER	01	797586	2002-12-20	100.12	100.07	100.05
SCHLIMBERGER	01	797587	2002-12-20	100.14	100.07	100.13
SCHLIMBERGER	01	797588	2002-12-20	100.10	100.04	100.12
SCHLIMBERGER	01	797589	2002-12-20	100.08	100.04	100.01
SCHLIMBERGER	01	797590	2002-12-20	100.09	099.92	100.08
SCHLIMBERGER	01	797591	2002-12-20	100.09	100.11	099.98
SCHLIMBERGER	01	797592	2002-12-20	100.08	100.17	100.06
SCHLIMBERGER	01	797593	2002-12-20	100.08	100.14	100.08
SCHLIMBERGER	01	797594	2002-12-20	100.10	100.17	100.10
SCHLIMBERGER	01	797595	2002-12-20	100.11	100.17	100.11
SCHLIMBERGER	01	797596	2002-12-20	100.12	100.14	100.10
SCHLIMBERGER	01	797597	2002-12-20	100.10	100.14	100.04
SCHLIMBERGER	01	797598	2002-12-20	100.11	100.08	100.09
SCHLIMBERGER	01	797599	2002-12-20	100.11	100.08	100.12
SCHLIMBERGER	01	797600	2002-12-20	100.09	100.14	100.09
SCHLIMBERGER	01	797601	2002-12-20	100.10	100.11	100.12
SCHLIMBERGER	01	797602	2002-12-20	100.11	100.14	100.03
SCHLIMBERGER	01	797603	2002-12-20	100.10	100.14	100.02
SCHLIMBERGER	01	797604	2002-12-20	100.11	100.14	100.07
SCHLIMBERGER	01	797605	2002-12-20	100.11	100.14	100.06
SCHLIMBERGER	01	797606	2002-12-20	100.11	100.14	100.04
SCHLIMBERGER	01	797607	2002-12-20	100.11	100.14	100.04
SCHLIMBERGER	01	797608	2002-12-20	100.11	100.14	100.02
SCHLIMBERGER	01	797609	2002-12-20	100.11	100.14	100.02
SCHLIMBERGER	01	797610	2002-12-20	100.11	100.14	100.07
SCHLIMBERGER	01	797611	2002-12-20	100.11	100.14	100.04
SCHLIMBERGER	01	797612	2002-12-20	100.11	100.14	100.07
SCHLIMBERGER	01	797613	2002-12-20	100.11	100.14	100.02
SCHLIMBERGER	01	797614	2002-12-20	100.11	100.14	100.04
SCHLIMBERGER	01	797615	2002-12-20	100.11	100.14	100.07
SCHLIMBERGER	01	797616	2002-12-20	100.11	100.14	100.04
SCHLIMBERGER	01	797617	2002-12-20	100.11	100.14	100.04
SCHLIMBERGER	01	797618	2002-12-20	100.11	100.14	100.04
SCHLIMBERGER	01	797619	2002-12-20	100.11	100.14	100.04
SCHLIMBERGER	01	797620	2002-12-20	100.11	100.14	100.04
SCHLIMBERGER	01	797621	2002-12-20	100.11	100.14	100.04
SCHLIMBERGER	01	797622	2002-12-20	100.11	100.14	100.04
SCHLIMBERGER	01	797623	2002-12-20	100.11	100.14	100.04
SCHLIMBERGER	01	797624	2002-12-20	100.11	100.14	100.04
SCHLIMBERGER	01	797625	2002-12-20	100.11	100.14	100.04
SCHLIMBERGER	01	797626	2002-12-20	100.11	100.14	100.04
SCHLIMBERGER	01	797627	2002-12-20	100.11	100.14	100.04
SCHLIMBERGER	01	797628	2002-12-20	100.11	100.14	100.04
SCHLIMBERGER	01	797629	2002-12-20	100.11	100.14	100.04
SCHLIMBERGER	01	797630	2002-12-20	100.11	100.14	100.04

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	PULL LOAD	LIGHT LOAD	PF FACTOR
SCHLUMBERGER	01	7977630	2002-12-20	109.07	100.02	100.04
SCHLUMBERGER	01	7977631	2002-12-20	109.10	100.12	100.09
SCHLUMBERGER	01	7977632	2002-12-20	109.10	100.10	100.13
SCHLUMBERGER	01	7977633	2002-12-20	109.10	100.04	099.92
SCHLUMBERGER	01	7977634	2002-12-20	109.12	100.14	100.07
SCHLUMBERGER	01	7977635	2002-12-20	109.10	100.17	100.10
SCHLUMBERGER	01	7977636	2002-12-20	109.08	100.10	100.05
SCHLUMBERGER	01	7977637	2002-12-20	109.11	100.04	100.05
SCHLUMBERGER	01	7977638	2002-12-20	109.09	100.17	099.97
SCHLUMBERGER	01	7977639	2002-12-20	109.08	100.05	100.04
SCHLUMBERGER	01	7977640	2002-12-20	109.11	100.05	100.13
SCHLUMBERGER	01	7977641	2002-12-20	109.10	100.05	100.06
SCHLUMBERGER	01	7977642	2002-12-20	109.10	100.11	100.06
SCHLUMBERGER	01	7977643	2002-12-20	109.11	100.11	100.09
SCHLUMBERGER	01	7977644	2002-12-20	109.10	100.14	100.11
SCHLUMBERGER	01	7977645	2002-12-20	109.10	100.14	100.02
SCHLUMBERGER	01	7977646	2002-12-20	109.10	100.05	100.04
SCHLUMBERGER	01	7977647	2002-12-20	109.09	100.04	100.02
SCHLUMBERGER	01	7977648	2002-12-20	109.10	100.04	100.04
SCHLUMBERGER	01	7977649	2002-12-20	109.08	100.04	099.99
SCHLUMBERGER	01	7977650	2002-12-20	109.08	100.04	100.04
SCHLUMBERGER	01	7977651	2002-12-20	109.08	100.04	100.04
SCHLUMBERGER	01	7977652	2002-12-20	109.10	100.04	100.04
SCHLUMBERGER	01	7977653	2002-12-20	109.08	100.04	100.04
SCHLUMBERGER	01	7977654	2002-12-20	109.10	100.04	100.04
SCHLUMBERGER	01	7977655	2002-12-20	109.10	100.04	100.04
SCHLUMBERGER	01	7977656	2002-12-20	109.10	100.04	100.04
SCHLUMBERGER	01	7977657	2002-12-20	109.10	100.04	100.04
SCHLUMBERGER	01	7977658	2002-12-20	109.10	100.04	100.04
SCHLUMBERGER	01	7977659	2002-12-20	109.10	100.04	100.04
SCHLUMBERGER	01	7977660	2002-12-20	109.10	100.04	100.04
SCHLUMBERGER	01	7977661	2002-12-20	109.10	100.04	100.04
SCHLUMBERGER	01	7977662	2002-12-20	109.10	100.04	100.04
SCHLUMBERGER	01	7977663	2002-12-20	109.10	100.04	100.04
SCHLUMBERGER	01	7977664	2002-12-20	109.10	100.04	100.04
SCHLUMBERGER	01	7977665	2002-12-20	109.10	100.04	100.04
SCHLUMBERGER	01	7977666	2002-12-20	109.10	100.04	100.04
SCHLUMBERGER	01	7977667	2002-12-20	109.10	100.04	100.04
SCHLUMBERGER	01	7977668	2002-12-20	109.10	100.04	100.04
SCHLUMBERGER	01	7977669	2002-12-20	109.10	100.04	100.04
SCHLUMBERGER	01	7977670	2002-12-20	109.10	100.04	100.04
SCHLUMBERGER	01	7977671	2002-12-20	109.10	100.04	100.04
SCHLUMBERGER	01	7977672	2002-12-20	109.10	100.04	100.04
SCHLUMBERGER	01	7977673	2002-12-20	109.10	100.04	100.04
SCHLUMBERGER	01	7977674	2002-12-20	109.10	100.04	100.04
SCHLUMBERGER	01	7977675	2002-12-20	109.10	100.04	100.04
SCHLUMBERGER	01	7977676	2002-12-20	109.10	100.04	100.04
SCHLUMBERGER	01	7977677	2002-12-20	109.10	100.04	100.04
SCHLUMBERGER	01	7977678	2002-12-20	109.10	100.04	100.04
SCHLUMBERGER	01	7977679	2002-12-20	109.10	100.04	100.04

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	PULL LOAD	LIGHT LOAD	PFACTOR
CH	LM	797480	2002-11-20	100.08	099.97	100.05
CH	LM	797481	2002-11-20	100.11	100.06	100.05
CH	LM	797482	2002-11-20	100.09	100.14	100.06
CH	LM	797483	2002-11-20	100.10	100.09	100.09
CH	LM	797484	2002-11-20	100.08	100.07	100.02
CH	LM	797485	2002-11-20	100.10	100.09	100.06
CH	LM	797486	2002-11-20	100.11	100.17	100.03
CH	LM	797487	2002-11-20	100.11	100.17	100.05
CH	LM	797488	2002-11-20	100.10	100.04	100.02
CH	LM	797489	2002-11-20	100.10	100.06	100.02
CH	LM	797490	2002-11-20	100.07	100.01	100.00
CH	LM	797491	2002-11-20	100.12	100.06	100.04
CH	LM	797492	2002-11-20	100.10	100.03	100.00
CH	LM	797493	2002-11-20	100.07	100.10	100.07
CH	LM	797494	2002-11-20	100.08	100.10	100.07
CH	LM	797495	2002-11-20	100.12	100.04	100.05
CH	LM	797496	2002-11-20	100.12	100.12	100.12
CH	LM	797497	2002-11-20	100.12	100.11	100.02
CH	LM	797498	2002-11-20	100.09	100.01	100.00
CH	LM	797499	2002-11-20	100.07	100.01	100.00
CH	LM	797500	2002-11-20	100.12	100.14	100.14
CH	LM	797501	2002-11-20	100.11	100.20	100.07
CH	LM	797502	2002-11-20	100.11	100.14	100.14
CH	LM	797503	2002-11-20	100.11	100.05	100.05
CH	LM	797504	2002-11-20	100.08	100.18	100.12
CH	LM	797505	2002-11-20	100.09	100.05	100.05
CH	LM	797506	2002-11-20	100.12	100.07	100.12
CH	LM	797507	2002-11-20	100.11	100.09	100.06
CH	LM	797508	2002-11-20	100.07	100.04	100.04
CH	LM	797509	2002-11-20	100.07	100.04	100.04
CH	LM	797510	2002-11-20	100.08	100.03	100.01
CH	LM	797511	2002-11-20	100.08	100.11	100.04
CH	LM	797512	2002-11-20	100.10	100.04	100.00
CH	LM	797513	2002-11-20	100.08	100.03	100.04
CH	LM	797514	2002-11-20	100.10	100.04	100.05
CH	LM	797515	2002-11-20	100.08	100.09	100.08
CH	LM	797516	2002-11-20	100.10	100.05	100.04
CH	LM	797517	2002-11-20	100.08	100.07	100.07
CH	LM	797518	2002-11-20	100.10	100.05	100.04
CH	LM	797519	2002-11-20	100.08	100.12	100.07
CH	LM	797520	2002-11-20	100.11	099.99	100.01
CH	LM	797521	2002-11-20	100.11	100.13	100.08
CH	LM	797522	2002-11-20	100.11	100.09	100.08
CH	LM	797523	2002-11-20	100.11	100.20	100.11
CH	LM	797524	2002-11-20	100.11	100.10	100.09
CH	LM	797525	2002-11-20	100.10	100.08	099.99
CH	LM	797526	2002-11-20	100.09	100.11	100.05
CH	LM	797527	2002-11-20	100.09	100.08	100.04
CH	LM	797528	2002-11-20	100.09	100.07	100.04
CH	LM	797529	2002-11-20	100.09	100.07	100.05

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACIOR
CHL	U	797730	2002-11-12	100.09	100.09	100.09
CHL	U	797731	2002-11-12	100.12	100.09	100.09
CHL	U	797732	2002-11-12	100.09	100.12	100.09
CHL	U	797733	2002-11-12	100.09	100.14	100.09
CHL	U	797734	2002-11-12	100.11	100.14	100.09
CHL	U	797735	2002-11-12	100.09	100.15	100.09
CHL	U	797736	2002-11-12	100.12	100.13	100.09
CHL	U	797737	2002-11-12	100.10	100.10	100.09
CHL	U	797738	2002-11-12	100.09	100.09	100.09
CHL	U	797739	2002-11-12	100.09	100.07	100.09
CHL	U	797740	2002-11-12	100.09	100.04	100.09
CHL	U	797741	2002-11-12	100.09	100.05	100.09
CHL	U	797742	2002-11-12	100.09	100.11	100.09
CHL	U	797743	2002-11-12	100.09	100.07	100.09
CHL	U	797744	2002-11-12	100.09	100.10	100.09
CHL	U	797745	2002-11-12	100.09	100.04	100.09
CHL	U	797746	2002-11-12	100.10	100.07	100.09
CHL	U	797747	2002-11-12	100.10	100.04	100.09
CHL	U	797748	2002-11-12	100.10	100.04	100.09
CHL	U	797749	2002-11-12	100.09	100.07	100.09
CHL	U	797750	2002-11-12	100.11	100.04	100.09
CHL	U	797751	2002-11-12	100.09	100.12	100.09
CHL	U	797752	2002-11-12	100.10	100.05	100.09
CHL	U	797753	2002-11-12	100.09	100.10	100.09
CHL	U	797754	2002-11-12	100.09	100.04	100.09
CHL	U	797755	2002-11-12	100.07	100.09	100.09
CHL	U	797756	2002-11-12	100.09	100.07	100.09
CHL	U	797757	2002-11-12	100.09	100.10	100.09
CHL	U	797758	2002-11-12	100.09	100.09	100.09
CHL	U	797759	2002-11-12	100.09	100.07	100.09
CHL	U	797760	2002-11-12	100.11	100.09	100.09
CHL	U	797761	2002-11-12	100.10	100.09	100.09
CHL	U	797762	2002-11-12	100.10	100.09	100.09
CHL	U	797763	2002-11-12	100.10	100.07	100.09
CHL	U	797764	2002-11-12	100.10	100.09	100.09
CHL	U	797765	2002-11-12	100.10	100.09	100.09
CHL	U	797766	2002-11-12	100.10	100.09	100.09
CHL	U	797767	2002-11-12	100.10	100.09	100.09
CHL	U	797768	2002-11-12	100.10	100.09	100.09
CHL	U	797769	2002-11-12	100.10	100.09	100.09
CHL	U	797770	2002-11-12	100.10	100.09	100.09
CHL	U	797771	2002-11-12	100.07	100.09	100.09
CHL	U	797772	2002-11-12	100.09	100.14	100.09
CHL	U	797773	2002-11-12	100.09	100.14	100.09
CHL	U	797774	2002-11-12	100.09	100.14	100.09
CHL	U	797775	2002-11-12	100.10	100.14	100.09
CHL	U	797776	2002-11-12	100.09	100.14	100.09
CHL	U	797777	2002-11-12	100.09	100.14	100.09
CHL	U	797778	2002-11-12	100.09	100.14	100.09
CHL	U	797779	2002-11-12	100.11	100.14	100.09

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACOR
CHLUMS	01	797780	2002-12-29	100.10	100.10	100.11
CHLUMS	01	797781	2002-12-29	100.07	100.19	100.03
CHLUMS	01	797782	2002-12-29	100.12	100.17	100.13
CHLUMS	01	797783	2002-12-29	100.13	100.17	100.09
CHLUMS	01	797784	2002-12-29	100.09	100.12	100.02
CHLUMS	01	797785	2002-12-29	100.12	100.14	100.06
CHLUMS	01	797786	2002-12-29	100.08	100.14	100.05
CHLUMS	01	797787	2002-12-29	100.11	100.15	100.05
CHLUMS	01	797788	2002-12-29	100.09	100.15	100.03
CHLUMS	01	797789	2002-12-29	100.11	100.15	100.02
CHLUMS	01	797790	2002-12-29	100.11	100.15	100.02
CHLUMS	01	797791	2002-12-29	100.11	100.15	100.02
CHLUMS	01	797792	2002-12-29	100.11	100.15	100.02
CHLUMS	01	797793	2002-12-29	100.11	100.15	100.02
CHLUMS	01	797794	2002-12-29	100.11	100.15	100.02
CHLUMS	01	797795	2002-12-29	100.11	100.15	100.02
CHLUMS	01	797796	2002-12-29	100.11	100.15	100.02
CHLUMS	01	797797	2002-12-29	100.11	100.15	100.02
CHLUMS	01	797798	2002-12-29	100.11	100.15	100.02
CHLUMS	01	797799	2002-12-29	100.11	100.15	100.02
CHLUMS	01	797800	2002-12-29	100.11	100.15	100.02
CHLUMS	01	797801	2002-12-29	100.11	100.15	100.02
CHLUMS	01	797802	2002-12-29	100.11	100.15	100.02
CHLUMS	01	797803	2002-12-29	100.11	100.15	100.02
CHLUMS	01	797804	2002-12-29	100.11	100.15	100.02
CHLUMS	01	797805	2002-12-29	100.11	100.15	100.02
CHLUMS	01	797806	2002-12-29	100.11	100.15	100.02
CHLUMS	01	797807	2002-12-29	100.11	100.15	100.02
CHLUMS	01	797808	2002-12-29	100.11	100.15	100.02
CHLUMS	01	797809	2002-12-29	100.11	100.15	100.02
CHLUMS	01	797810	2002-12-29	100.11	100.15	100.02
CHLUMS	01	797811	2002-12-29	100.11	100.15	100.02
CHLUMS	01	797812	2002-12-29	100.11	100.15	100.02
CHLUMS	01	797813	2002-12-29	100.11	100.15	100.02
CHLUMS	01	797814	2002-12-29	100.11	100.15	100.02
CHLUMS	01	797815	2002-12-29	100.11	100.15	100.02
CHLUMS	01	797816	2002-12-29	100.11	100.15	100.02
CHLUMS	01	797817	2002-12-29	100.11	100.15	100.02
CHLUMS	01	797818	2002-12-29	100.11	100.15	100.02
CHLUMS	01	797819	2002-12-29	100.11	100.15	100.02
CHLUMS	01	797820	2002-12-29	100.11	100.15	100.02
CHLUMS	01	797821	2002-12-29	100.11	100.15	100.02
CHLUMS	01	797822	2002-12-29	100.11	100.15	100.02
CHLUMS	01	797823	2002-12-29	100.11	100.15	100.02
CHLUMS	01	797824	2002-12-29	100.11	100.15	100.02
CHLUMS	01	797825	2002-12-29	100.11	100.15	100.02
CHLUMS	01	797826	2002-12-29	100.11	100.15	100.02
CHLUMS	01	797827	2002-12-29	100.11	100.15	100.02
CHLUMS	01	797828	2002-12-29	100.11	100.15	100.02
CHLUMS	01	797829	2002-12-29	100.11	100.15	100.02
CHLUMS	01	797830	2002-12-29	100.11	100.15	100.02

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACOR
CHL UM82R03ER	001	797800	2002-11-29	100.02	100.04	100.02
CHL UM82R03ER	001	797801	2002-11-29	100.11	100.10	100.07
CHL UM82R03ER	001	797802	2002-11-29	100.11	100.06	100.12
CHL UM82R03ER	001	797803	2002-11-29	100.11	100.12	100.10
CHL UM82R03ER	001	797804	2002-11-29	100.10	100.12	100.13
CHL UM82R03ER	001	797805	2002-11-29	100.10	100.09	100.02
CHL UM82R03ER	001	797806	2002-11-29	100.09	100.07	100.08
CHL UM82R03ER	001	797807	2002-11-29	100.09	100.08	100.09
CHL UM82R03ER	001	797808	2002-11-29	100.10	100.10	100.09
CHL UM82R03ER	001	797809	2002-11-29	100.10	100.12	100.07
CHL UM82R03ER	001	797810	2002-11-29	100.09	100.07	100.04
CHL UM82R03ER	001	797811	2002-11-29	100.09	100.07	100.04
CHL UM82R03ER	001	797812	2002-11-29	100.08	100.09	100.04
CHL UM82R03ER	001	797813	2002-11-29	100.10	100.12	100.11
CHL UM82R03ER	001	797814	2002-11-29	100.10	100.17	100.01
CHL UM82R03ER	001	797815	2002-11-29	100.10	100.09	100.02
CHL UM82R03ER	001	797816	2002-11-29	100.09	100.07	100.03
CHL UM82R03ER	001	797817	2002-11-29	100.10	100.12	100.02
CHL UM82R03ER	001	797818	2002-11-29	100.10	100.09	100.04
CHL UM82R03ER	001	797819	2002-11-29	100.10	100.10	100.06
CHL UM82R03ER	001	797820	2002-11-29	100.10	100.11	100.05
CHL UM82R03ER	001	797821	2002-11-29	100.10	100.07	100.06
CHL UM82R03ER	001	797822	2002-11-29	100.10	100.10	100.11
CHL UM82R03ER	001	797823	2002-11-29	100.09	100.10	100.04
CHL UM82R03ER	001	797824	2002-11-29	100.09	100.10	100.05
CHL UM82R03ER	001	797825	2002-11-29	100.09	100.07	100.04
CHL UM82R03ER	001	797826	2002-11-29	100.09	100.05	100.04
CHL UM82R03ER	001	797827	2002-11-29	100.09	100.05	100.04
CHL UM82R03ER	001	797828	2002-11-29	100.10	100.07	100.03
CHL UM82R03ER	001	797829	2002-11-29	100.10	100.10	100.04
CHL UM82R03ER	001	797830	2002-11-29	100.09	100.10	100.05
CHL UM82R03ER	001	797831	2002-11-29	100.09	100.09	100.04
CHL UM82R03ER	001	797832	2002-11-29	100.10	100.14	100.06
CHL UM82R03ER	001	797833	2002-11-29	100.09	100.07	100.06
CHL UM82R03ER	001	797834	2002-11-29	100.10	100.14	100.09
CHL UM82R03ER	001	797835	2002-11-29	100.10	100.12	100.14
CHL UM82R03ER	001	797836	2002-11-29	100.07	100.07	100.11
CHL UM82R03ER	001	797837	2002-11-29	100.08	100.06	100.11
CHL UM82R03ER	001	797838	2002-11-29	100.08	100.06	100.11
CHL UM82R03ER	001	797839	2002-11-29	100.08	100.06	100.11
CHL UM82R03ER	001	797840	2002-11-29	100.08	100.06	100.11
CHL UM82R03ER	001	797841	2002-11-29	100.08	100.06	100.11
CHL UM82R03ER	001	797842	2002-11-29	100.08	100.06	100.11
CHL UM82R03ER	001	797843	2002-11-29	100.08	100.06	100.11
CHL UM82R03ER	001	797844	2002-11-29	100.08	100.06	100.11
CHL UM82R03ER	001	797845	2002-11-29	100.08	100.06	100.11
CHL UM82R03ER	001	797846	2002-11-29	100.08	100.06	100.11
CHL UM82R03ER	001	797847	2002-11-29	100.08	100.06	100.11
CHL UM82R03ER	001	797848	2002-11-29	100.08	100.06	100.11
CHL UM82R03ER	001	797849	2002-11-29	100.08	100.06	100.11
CHL UM82R03ER	001	797850	2002-11-29	100.08	100.06	100.11
CHL UM82R03ER	001	797851	2002-11-29	100.08	100.06	100.11
CHL UM82R03ER	001	797852	2002-11-29	100.08	100.06	100.11
CHL UM82R03ER	001	797853	2002-11-29	100.08	100.06	100.11
CHL UM82R03ER	001	797854	2002-11-29	100.08	100.06	100.11
CHL UM82R03ER	001	797855	2002-11-29	100.08	100.06	100.11
CHL UM82R03ER	001	797856	2002-11-29	100.08	100.06	100.11
CHL UM82R03ER	001	797857	2002-11-29	100.08	100.06	100.11
CHL UM82R03ER	001	797858	2002-11-29	100.08	100.06	100.11
CHL UM82R03ER	001	797859	2002-11-29	100.08	100.06	100.11
CHL UM82R03ER	001	797860	2002-11-29	100.08	100.06	100.11
CHL UM82R03ER	001	797861	2002-11-29	100.08	100.06	100.11
CHL UM82R03ER	001	797862	2002-11-29	100.08	100.06	100.11
CHL UM82R03ER	001	797863	2002-11-29	100.08	100.06	100.11
CHL UM82R03ER	001	797864	2002-11-29	100.08	100.06	100.11
CHL UM82R03ER	001	797865	2002-11-29	100.08	100.06	100.11
CHL UM82R03ER	001	797866	2002-11-29	100.08	100.06	100.11
CHL UM82R03ER	001	797867	2002-11-29	100.08	100.06	100.11
CHL UM82R03ER	001	797868	2002-11-29	100.08	100.06	100.11
CHL UM82R03ER	001	797869	2002-11-29	100.08	100.06	100.11
CHL UM82R03ER	001	797870	2002-11-29	100.08	100.06	100.11
CHL UM82R03ER	001	797871	2002-11-29	100.08	100.06	100.11
CHL UM82R03ER	001	797872	2002-11-29	100.08	100.06	100.11
CHL UM82R03ER	001	797873	2002-11-29	100.08	100.06	100.11
CHL UM82R03ER	001	797874	2002-11-29	100.08	100.06	100.11
CHL UM82R03ER	001	797875	2002-11-29	100.08	100.06	100.11
CHL UM82R03ER	001	797876	2002-11-29	100.08	100.06	100.11
CHL UM82R03ER	001	797877	2002-11-29	100.08	100.06	100.11
CHL UM82R03ER	001	797878	2002-11-29	100.08	100.06	100.11
CHL UM82R03ER	001	797879	2002-11-29	100.08	100.06	100.11
CHL UM82R03ER	001	797880	2002-11-29	100.08	100.06	100.11

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PF FACTOR
SCHLUMBERGER	01	797930	200001	100.07	100.14	100.05
SCHLUMBERGER	01	797931	200001	100.11	100.14	100.07
SCHLUMBERGER	01	797932	200001	100.10	100.10	100.07
SCHLUMBERGER	01	797933	200001	100.09	100.10	100.07
SCHLUMBERGER	01	797934	200001	100.08	100.11	100.07
SCHLUMBERGER	01	797935	200001	100.08	100.11	100.07
SCHLUMBERGER	01	797936	200001	100.08	100.11	100.07
SCHLUMBERGER	01	797937	200001	100.08	100.11	100.07
SCHLUMBERGER	01	797938	200001	100.08	100.11	100.07
SCHLUMBERGER	01	797939	200001	100.08	100.11	100.07
SCHLUMBERGER	01	797940	200001	100.08	100.11	100.07
SCHLUMBERGER	01	797941	200001	100.08	100.11	100.07
SCHLUMBERGER	01	797942	200001	100.08	100.11	100.07
SCHLUMBERGER	01	797943	200001	100.08	100.11	100.07
SCHLUMBERGER	01	797944	200001	100.08	100.11	100.07
SCHLUMBERGER	01	797945	200001	100.08	100.11	100.07
SCHLUMBERGER	01	797946	200001	100.08	100.11	100.07
SCHLUMBERGER	01	797947	200001	100.08	100.11	100.07
SCHLUMBERGER	01	797948	200001	100.08	100.11	100.07
SCHLUMBERGER	01	797949	200001	100.08	100.11	100.07
SCHLUMBERGER	01	797950	200001	100.08	100.11	100.07
SCHLUMBERGER	01	797951	200001	100.08	100.11	100.07
SCHLUMBERGER	01	797952	200001	100.08	100.11	100.07
SCHLUMBERGER	01	797953	200001	100.08	100.11	100.07
SCHLUMBERGER	01	797954	200001	100.08	100.11	100.07
SCHLUMBERGER	01	797955	200001	100.08	100.11	100.07
SCHLUMBERGER	01	797956	200001	100.08	100.11	100.07
SCHLUMBERGER	01	797957	200001	100.08	100.11	100.07
SCHLUMBERGER	01	797958	200001	100.08	100.11	100.07
SCHLUMBERGER	01	797959	200001	100.08	100.11	100.07
SCHLUMBERGER	01	797960	200001	100.08	100.11	100.07
SCHLUMBERGER	01	797961	200001	100.08	100.11	100.07
SCHLUMBERGER	01	797962	200001	100.08	100.11	100.07
SCHLUMBERGER	01	797963	200001	100.08	100.11	100.07
SCHLUMBERGER	01	797964	200001	100.08	100.11	100.07
SCHLUMBERGER	01	797965	200001	100.08	100.11	100.07
SCHLUMBERGER	01	797966	200001	100.08	100.11	100.07
SCHLUMBERGER	01	797967	200001	100.08	100.11	100.07
SCHLUMBERGER	01	797968	200001	100.08	100.11	100.07
SCHLUMBERGER	01	797969	200001	100.08	100.11	100.07
SCHLUMBERGER	01	797970	200001	100.08	100.11	100.07
SCHLUMBERGER	01	797971	200001	100.08	100.11	100.07
SCHLUMBERGER	01	797972	200001	100.08	100.11	100.07
SCHLUMBERGER	01	797973	200001	100.08	100.11	100.07
SCHLUMBERGER	01	797974	200001	100.08	100.11	100.07
SCHLUMBERGER	01	797975	200001	100.08	100.11	100.07
SCHLUMBERGER	01	797976	200001	100.08	100.11	100.07
SCHLUMBERGER	01	797977	200001	100.08	100.11	100.07
SCHLUMBERGER	01	797978	200001	100.08	100.11	100.07
SCHLUMBERGER	01	797979	200001	100.08	100.11	100.07

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACOR
LM	01	301	00	100.07	100.11	100.09
LM	01	302	00	100.10	100.11	100.09
LM	01	303	00	100.09	100.11	100.09
LM	01	304	00	100.09	100.11	100.09
LM	01	305	00	100.11	100.11	100.09
LM	01	306	00	100.11	100.11	100.09
LM	01	307	00	100.11	100.11	100.09
LM	01	308	00	100.11	100.11	100.09
LM	01	309	00	100.11	100.11	100.09
LM	01	310	00	100.11	100.11	100.09
LM	01	311	00	100.11	100.11	100.09
LM	01	312	00	100.11	100.11	100.09
LM	01	313	00	100.11	100.11	100.09
LM	01	314	00	100.11	100.11	100.09
LM	01	315	00	100.11	100.11	100.09
LM	01	316	00	100.11	100.11	100.09
LM	01	317	00	100.11	100.11	100.09
LM	01	318	00	100.11	100.11	100.09
LM	01	319	00	100.11	100.11	100.09
LM	01	320	00	100.11	100.11	100.09
LM	01	321	00	100.11	100.11	100.09
LM	01	322	00	100.11	100.11	100.09
LM	01	323	00	100.11	100.11	100.09
LM	01	324	00	100.11	100.11	100.09
LM	01	325	00	100.11	100.11	100.09
LM	01	326	00	100.11	100.11	100.09
LM	01	327	00	100.11	100.11	100.09
LM	01	328	00	100.11	100.11	100.09
LM	01	329	00	100.11	100.11	100.09
LM	01	330	00	100.11	100.11	100.09
LM	01	331	00	100.11	100.11	100.09
LM	01	332	00	100.11	100.11	100.09
LM	01	333	00	100.11	100.11	100.09
LM	01	334	00	100.11	100.11	100.09
LM	01	335	00	100.11	100.11	100.09
LM	01	336	00	100.11	100.11	100.09
LM	01	337	00	100.11	100.11	100.09
LM	01	338	00	100.11	100.11	100.09
LM	01	339	00	100.11	100.11	100.09
LM	01	340	00	100.11	100.11	100.09
LM	01	341	00	100.11	100.11	100.09
LM	01	342	00	100.11	100.11	100.09
LM	01	343	00	100.11	100.11	100.09
LM	01	344	00	100.11	100.11	100.09
LM	01	345	00	100.11	100.11	100.09
LM	01	346	00	100.11	100.11	100.09
LM	01	347	00	100.11	100.11	100.09
LM	01	348	00	100.11	100.11	100.09
LM	01	349	00	100.11	100.11	100.09
LM	01	350	00	100.11	100.11	100.09
LM	01	351	00	100.11	100.11	100.09
LM	01	352	00	100.11	100.11	100.09
LM	01	353	00	100.11	100.11	100.09
LM	01	354	00	100.11	100.11	100.09
LM	01	355	00	100.11	100.11	100.09
LM	01	356	00	100.11	100.11	100.09
LM	01	357	00	100.11	100.11	100.09
LM	01	358	00	100.11	100.11	100.09
LM	01	359	00	100.11	100.11	100.09
LM	01	360	00	100.11	100.11	100.09
LM	01	361	00	100.11	100.11	100.09
LM	01	362	00	100.11	100.11	100.09
LM	01	363	00	100.11	100.11	100.09
LM	01	364	00	100.11	100.11	100.09
LM	01	365	00	100.11	100.11	100.09
LM	01	366	00	100.11	100.11	100.09
LM	01	367	00	100.11	100.11	100.09
LM	01	368	00	100.11	100.11	100.09
LM	01	369	00	100.11	100.11	100.09
LM	01	370	00	100.11	100.11	100.09
LM	01	371	00	100.11	100.11	100.09
LM	01	372	00	100.11	100.11	100.09
LM	01	373	00	100.11	100.11	100.09
LM	01	374	00	100.11	100.11	100.09
LM	01	375	00	100.11	100.11	100.09
LM	01	376	00	100.11	100.11	100.09
LM	01	377	00	100.11	100.11	100.09
LM	01	378	00	100.11	100.11	100.09
LM	01	379	00	100.11	100.11	100.09
LM	01	380	00	100.11	100.11	100.09
LM	01	381	00	100.11	100.11	100.09
LM	01	382	00	100.11	100.11	100.09
LM	01	383	00	100.11	100.11	100.09
LM	01	384	00	100.11	100.11	100.09
LM	01	385	00	100.11	100.11	100.09
LM	01	386	00	100.11	100.11	100.09
LM	01	387	00	100.11	100.11	100.09
LM	01	388	00	100.11	100.11	100.09
LM	01	389	00	100.11	100.11	100.09
LM	01	390	00	100.11	100.11	100.09
LM	01	391	00	100.11	100.11	100.09
LM	01	392	00	100.11	100.11	100.09
LM	01	393	00	100.11	100.11	100.09
LM	01	394	00	100.11	100.11	100.09
LM	01	395	00	100.11	100.11	100.09
LM	01	396	00	100.11	100.11	100.09
LM	01	397	00	100.11	100.11	100.09
LM	01	398	00	100.11	100.11	100.09
LM	01	399	00	100.11	100.11	100.09
LM	01	400	00	100.11	100.11	100.09

LOUISVILLE GAS & ELECTRIC COMPANY
METER SYSTEM (MS5)
NEW METERS ADDED LAST YEAR

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
U	0	30	2002-11-11	100.12	100.07	100.03
U	0	31	2002-11-11	100.09	100.08	100.03
U	0	32	2002-11-11	100.11	100.15	100.07
U	0	33	2002-11-11	100.14	100.19	100.02
U	0	34	2002-11-11	100.12	100.09	100.07
U	0	35	2002-11-11	100.10	100.15	100.06
U	0	36	2002-11-11	100.09	100.09	100.10
U	0	37	2002-11-11	100.11	100.09	100.10
U	0	38	2002-11-11	100.08	100.09	100.12
U	0	39	2002-11-11	100.14	100.09	100.04
U	0	40	2002-11-11	100.07	100.07	100.05
U	0	41	2002-11-11	100.14	100.12	100.10
U	0	42	2002-11-11	100.09	100.11	100.01
U	0	43	2002-11-11	100.07	100.07	100.02
U	0	44	2002-11-11	100.07	100.07	100.05
U	0	45	2002-11-11	100.07	100.07	100.04
U	0	46	2002-11-11	100.09	100.07	100.03
U	0	47	2002-11-11	100.09	100.07	100.01
U	0	48	2002-11-11	100.09	100.07	100.00
U	0	49	2002-11-11	100.09	100.07	100.02
U	0	50	2002-11-11	100.09	100.07	100.04
U	0	51	2002-11-11	100.09	100.07	100.05
U	0	52	2002-11-11	100.09	100.07	100.05
U	0	53	2002-11-11	100.09	100.07	100.05
U	0	54	2002-11-11	100.09	100.07	100.05
U	0	55	2002-11-11	100.09	100.07	100.05
U	0	56	2002-11-11	100.09	100.07	100.05
U	0	57	2002-11-11	100.09	100.07	100.05
U	0	58	2002-11-11	100.09	100.07	100.05
U	0	59	2002-11-11	100.09	100.07	100.05
U	0	60	2002-11-11	100.09	100.07	100.05
U	0	61	2002-11-11	100.09	100.07	100.05
U	0	62	2002-11-11	100.09	100.07	100.05
U	0	63	2002-11-11	100.09	100.07	100.05
U	0	64	2002-11-11	100.09	100.07	100.05
U	0	65	2002-11-11	100.09	100.07	100.05
U	0	66	2002-11-11	100.09	100.07	100.05
U	0	67	2002-11-11	100.09	100.07	100.05
U	0	68	2002-11-11	100.09	100.07	100.05
U	0	69	2002-11-11	100.09	100.07	100.05
U	0	70	2002-11-11	100.09	100.07	100.05
U	0	71	2002-11-11	100.09	100.07	100.05
U	0	72	2002-11-11	100.09	100.07	100.05
U	0	73	2002-11-11	100.09	100.07	100.05
U	0	74	2002-11-11	100.09	100.07	100.05
U	0	75	2002-11-11	100.09	100.07	100.05
U	0	76	2002-11-11	100.09	100.07	100.05
U	0	77	2002-11-11	100.09	100.07	100.05
U	0	78	2002-11-11	100.09	100.07	100.05
U	0	79	2002-11-11	100.09	100.07	100.05
U	0	80	2002-11-11	100.09	100.07	100.05
U	0	81	2002-11-11	100.09	100.07	100.05
U	0	82	2002-11-11	100.09	100.07	100.05
U	0	83	2002-11-11	100.09	100.07	100.05
U	0	84	2002-11-11	100.09	100.07	100.05
U	0	85	2002-11-11	100.09	100.07	100.05
U	0	86	2002-11-11	100.09	100.07	100.05
U	0	87	2002-11-11	100.09	100.07	100.05
U	0	88	2002-11-11	100.09	100.07	100.05
U	0	89	2002-11-11	100.09	100.07	100.05
U	0	90	2002-11-11	100.09	100.07	100.05
U	0	91	2002-11-11	100.09	100.07	100.05
U	0	92	2002-11-11	100.09	100.07	100.05
U	0	93	2002-11-11	100.09	100.07	100.05
U	0	94	2002-11-11	100.09	100.07	100.05
U	0	95	2002-11-11	100.09	100.07	100.05
U	0	96	2002-11-11	100.09	100.07	100.05
U	0	97	2002-11-11	100.09	100.07	100.05
U	0	98	2002-11-11	100.09	100.07	100.05
U	0	99	2002-11-11	100.09	100.07	100.05
U	0	100	2002-11-11	100.09	100.07	100.05

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACOR
CHLUMBER	01	7992231	02-11-20	100.09	100.07	100.02
CHLUMBER	01	7992232	02-11-20	100.08	100.15	100.04
CHLUMBER	01	7992233	02-11-20	100.10	100.10	100.10
CHLUMBER	01	7992234	02-11-20	100.10	099.97	100.05
CHLUMBER	01	7992235	02-11-20	100.09	100.12	100.02
CHLUMBER	01	7992236	02-11-20	100.12	100.11	100.04
CHLUMBER	01	7992237	02-11-20	100.11	100.07	100.02
CHLUMBER	01	7992238	02-11-20	100.09	100.14	100.04
CHLUMBER	01	7992239	02-11-20	100.11	100.06	100.09
CHLUMBER	01	7992240	02-11-20	100.11	100.05	100.04
CHLUMBER	01	7992241	02-11-20	100.09	100.07	100.14
CHLUMBER	01	7992242	02-11-20	100.12	100.07	100.05
CHLUMBER	01	7992243	02-11-20	100.10	100.15	100.07
CHLUMBER	01	7992244	02-11-20	100.08	100.13	100.01
CHLUMBER	01	7992245	02-11-20	100.08	100.04	100.01
CHLUMBER	01	7992246	02-11-20	100.10	100.09	100.03
CHLUMBER	01	7992247	02-11-20	100.11	100.11	100.00
CHLUMBER	01	7992248	02-11-20	100.09	100.14	100.00
CHLUMBER	01	7992249	02-11-20	100.10	100.14	100.11
CHLUMBER	01	7992250	02-11-20	100.10	100.10	100.02
CHLUMBER	01	7992251	02-11-20	100.09	100.10	100.04
CHLUMBER	01	7992252	02-11-20	100.09	100.10	100.02
CHLUMBER	01	7992253	02-11-20	100.09	100.10	100.02
CHLUMBER	01	7992254	02-11-20	100.09	100.10	100.02
CHLUMBER	01	7992255	02-11-20	100.09	100.10	100.02
CHLUMBER	01	7992256	02-11-20	100.09	100.10	100.02
CHLUMBER	01	7992257	02-11-20	100.09	100.10	100.02
CHLUMBER	01	7992258	02-11-20	100.09	100.10	100.02
CHLUMBER	01	7992259	02-11-20	100.09	100.10	100.02
CHLUMBER	01	7992260	02-11-20	100.09	100.10	100.02
CHLUMBER	01	7992261	02-11-20	100.09	100.10	100.02
CHLUMBER	01	7992262	02-11-20	100.09	100.10	100.02
CHLUMBER	01	7992263	02-11-20	100.09	100.10	100.02
CHLUMBER	01	7992264	02-11-20	100.09	100.10	100.02
CHLUMBER	01	7992265	02-11-20	100.09	100.10	100.02
CHLUMBER	01	7992266	02-11-20	100.09	100.10	100.02
CHLUMBER	01	7992267	02-11-20	100.09	100.10	100.02
CHLUMBER	01	7992268	02-11-20	100.09	100.10	100.02
CHLUMBER	01	7992269	02-11-20	100.09	100.10	100.02
CHLUMBER	01	7992270	02-11-20	100.09	100.10	100.02
CHLUMBER	01	7992271	02-11-20	100.09	100.10	100.02
CHLUMBER	01	7992272	02-11-20	100.09	100.10	100.02
CHLUMBER	01	7992273	02-11-20	100.09	100.10	100.02
CHLUMBER	01	7992274	02-11-20	100.09	100.10	100.02
CHLUMBER	01	7992275	02-11-20	100.09	100.10	100.02
CHLUMBER	01	7992276	02-11-20	100.09	100.10	100.02
CHLUMBER	01	7992277	02-11-20	100.09	100.10	100.02
CHLUMBER	01	7992278	02-11-20	100.09	100.10	100.02
CHLUMBER	01	7992279	02-11-20	100.09	100.10	100.02

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACITOR
GE	001	77920001	00000001	100.11	100.07	100.11
GE	001	77920002	00000002	100.11	100.07	100.11
GE	001	77920003	00000003	100.11	100.07	100.11
GE	001	77920004	00000004	100.11	100.07	100.11
GE	001	77920005	00000005	100.11	100.07	100.11
GE	001	77920006	00000006	100.11	100.07	100.11
GE	001	77920007	00000007	100.11	100.07	100.11
GE	001	77920008	00000008	100.11	100.07	100.11
GE	001	77920009	00000009	100.11	100.07	100.11
GE	001	77920010	00000010	100.11	100.07	100.11
GE	001	77920011	00000011	100.11	100.07	100.11
GE	001	77920012	00000012	100.11	100.07	100.11
GE	001	77920013	00000013	100.11	100.07	100.11
GE	001	77920014	00000014	100.11	100.07	100.11
GE	001	77920015	00000015	100.11	100.07	100.11
GE	001	77920016	00000016	100.11	100.07	100.11
GE	001	77920017	00000017	100.11	100.07	100.11
GE	001	77920018	00000018	100.11	100.07	100.11
GE	001	77920019	00000019	100.11	100.07	100.11
GE	001	77920020	00000020	100.11	100.07	100.11
GE	001	77920021	00000021	100.11	100.07	100.11
GE	001	77920022	00000022	100.11	100.07	100.11
GE	001	77920023	00000023	100.11	100.07	100.11
GE	001	77920024	00000024	100.11	100.07	100.11
GE	001	77920025	00000025	100.11	100.07	100.11
GE	001	77920026	00000026	100.11	100.07	100.11
GE	001	77920027	00000027	100.11	100.07	100.11
GE	001	77920028	00000028	100.11	100.07	100.11
GE	001	77920029	00000029	100.11	100.07	100.11
GE	001	77920030	00000030	100.11	100.07	100.11
GE	001	77920031	00000031	100.11	100.07	100.11
GE	001	77920032	00000032	100.11	100.07	100.11
GE	001	77920033	00000033	100.11	100.07	100.11
GE	001	77920034	00000034	100.11	100.07	100.11
GE	001	77920035	00000035	100.11	100.07	100.11
GE	001	77920036	00000036	100.11	100.07	100.11
GE	001	77920037	00000037	100.11	100.07	100.11
GE	001	77920038	00000038	100.11	100.07	100.11
GE	001	77920039	00000039	100.11	100.07	100.11
GE	001	77920040	00000040	100.11	100.07	100.11
GE	001	77920041	00000041	100.11	100.07	100.11
GE	001	77920042	00000042	100.11	100.07	100.11
GE	001	77920043	00000043	100.11	100.07	100.11
GE	001	77920044	00000044	100.11	100.07	100.11
GE	001	77920045	00000045	100.11	100.07	100.11
GE	001	77920046	00000046	100.11	100.07	100.11
GE	001	77920047	00000047	100.11	100.07	100.11
GE	001	77920048	00000048	100.11	100.07	100.11
GE	001	77920049	00000049	100.11	100.07	100.11
GE	001	77920050	00000050	100.11	100.07	100.11
GE	001	77920051	00000051	100.11	100.07	100.11
GE	001	77920052	00000052	100.11	100.07	100.11
GE	001	77920053	00000053	100.11	100.07	100.11
GE	001	77920054	00000054	100.11	100.07	100.11
GE	001	77920055	00000055	100.11	100.07	100.11
GE	001	77920056	00000056	100.11	100.07	100.11
GE	001	77920057	00000057	100.11	100.07	100.11
GE	001	77920058	00000058	100.11	100.07	100.11
GE	001	77920059	00000059	100.11	100.07	100.11
GE	001	77920060	00000060	100.11	100.07	100.11
GE	001	77920061	00000061	100.11	100.07	100.11
GE	001	77920062	00000062	100.11	100.07	100.11
GE	001	77920063	00000063	100.11	100.07	100.11
GE	001	77920064	00000064	100.11	100.07	100.11
GE	001	77920065	00000065	100.11	100.07	100.11
GE	001	77920066	00000066	100.11	100.07	100.11
GE	001	77920067	00000067	100.11	100.07	100.11
GE	001	77920068	00000068	100.11	100.07	100.11
GE	001	77920069	00000069	100.11	100.07	100.11
GE	001	77920070	00000070	100.11	100.07	100.11
GE	001	77920071	00000071	100.11	100.07	100.11
GE	001	77920072	00000072	100.11	100.07	100.11
GE	001	77920073	00000073	100.11	100.07	100.11
GE	001	77920074	00000074	100.11	100.07	100.11
GE	001	77920075	00000075	100.11	100.07	100.11
GE	001	77920076	00000076	100.11	100.07	100.11
GE	001	77920077	00000077	100.11	100.07	100.11
GE	001	77920078	00000078	100.11	100.07	100.11
GE	001	77920079	00000079	100.11	100.07	100.11
GE	001	77920080	00000080	100.11	100.07	100.11
GE	001	77920081	00000081	100.11	100.07	100.11
GE	001	77920082	00000082	100.11	100.07	100.11
GE	001	77920083	00000083	100.11	100.07	100.11
GE	001	77920084	00000084	100.11	100.07	100.11
GE	001	77920085	00000085	100.11	100.07	100.11
GE	001	77920086	00000086	100.11	100.07	100.11
GE	001	77920087	00000087	100.11	100.07	100.11
GE	001	77920088	00000088	100.11	100.07	100.11
GE	001	77920089	00000089	100.11	100.07	100.11
GE	001	77920090	00000090	100.11	100.07	100.11
GE	001	77920091	00000091	100.11	100.07	100.11
GE	001	77920092	00000092	100.11	100.07	100.11
GE	001	77920093	00000093	100.11	100.07	100.11
GE	001	77920094	00000094	100.11	100.07	100.11
GE	001	77920095	00000095	100.11	100.07	100.11
GE	001	77920096	00000096	100.11	100.07	100.11
GE	001	77920097	00000097	100.11	100.07	100.11
GE	001	77920098	00000098	100.11	100.07	100.11
GE	001	77920099	00000099	100.11	100.07	100.11
GE	001	77920100	00000100	100.11	100.07	100.11

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PF FACTOR
CHL	UMS	0001	2003	100.10	100.07	100.06
CHL	UMS	0002	2003	100.07	100.04	100.04
CHL	UMS	0003	2003	100.10	100.07	100.07
CHL	UMS	0004	2003	100.07	100.04	100.04
CHL	UMS	0005	2003	100.10	100.07	100.07
CHL	UMS	0006	2003	100.07	100.04	100.04
CHL	UMS	0007	2003	100.10	100.07	100.07
CHL	UMS	0008	2003	100.07	100.04	100.04
CHL	UMS	0009	2003	100.10	100.07	100.07
CHL	UMS	0010	2003	100.07	100.04	100.04
CHL	UMS	0011	2003	100.10	100.07	100.07
CHL	UMS	0012	2003	100.07	100.04	100.04
CHL	UMS	0013	2003	100.10	100.07	100.07
CHL	UMS	0014	2003	100.07	100.04	100.04
CHL	UMS	0015	2003	100.10	100.07	100.07
CHL	UMS	0016	2003	100.07	100.04	100.04
CHL	UMS	0017	2003	100.10	100.07	100.07
CHL	UMS	0018	2003	100.07	100.04	100.04
CHL	UMS	0019	2003	100.10	100.07	100.07
CHL	UMS	0020	2003	100.07	100.04	100.04
CHL	UMS	0021	2003	100.10	100.07	100.07
CHL	UMS	0022	2003	100.07	100.04	100.04
CHL	UMS	0023	2003	100.10	100.07	100.07
CHL	UMS	0024	2003	100.07	100.04	100.04
CHL	UMS	0025	2003	100.10	100.07	100.07
CHL	UMS	0026	2003	100.07	100.04	100.04
CHL	UMS	0027	2003	100.10	100.07	100.07
CHL	UMS	0028	2003	100.07	100.04	100.04
CHL	UMS	0029	2003	100.10	100.07	100.07
CHL	UMS	0030	2003	100.07	100.04	100.04
CHL	UMS	0031	2003	100.10	100.07	100.07
CHL	UMS	0032	2003	100.07	100.04	100.04
CHL	UMS	0033	2003	100.10	100.07	100.07
CHL	UMS	0034	2003	100.07	100.04	100.04
CHL	UMS	0035	2003	100.10	100.07	100.07
CHL	UMS	0036	2003	100.07	100.04	100.04
CHL	UMS	0037	2003	100.10	100.07	100.07
CHL	UMS	0038	2003	100.07	100.04	100.04
CHL	UMS	0039	2003	100.10	100.07	100.07
CHL	UMS	0040	2003	100.07	100.04	100.04
CHL	UMS	0041	2003	100.10	100.07	100.07
CHL	UMS	0042	2003	100.07	100.04	100.04
CHL	UMS	0043	2003	100.10	100.07	100.07
CHL	UMS	0044	2003	100.07	100.04	100.04
CHL	UMS	0045	2003	100.10	100.07	100.07
CHL	UMS	0046	2003	100.07	100.04	100.04
CHL	UMS	0047	2003	100.10	100.07	100.07
CHL	UMS	0048	2003	100.07	100.04	100.04
CHL	UMS	0049	2003	100.10	100.07	100.07
CHL	UMS	0050	2003	100.07	100.04	100.04
CHL	UMS	0051	2003	100.10	100.07	100.07
CHL	UMS	0052	2003	100.07	100.04	100.04
CHL	UMS	0053	2003	100.10	100.07	100.07
CHL	UMS	0054	2003	100.07	100.04	100.04
CHL	UMS	0055	2003	100.10	100.07	100.07
CHL	UMS	0056	2003	100.07	100.04	100.04
CHL	UMS	0057	2003	100.10	100.07	100.07
CHL	UMS	0058	2003	100.07	100.04	100.04
CHL	UMS	0059	2003	100.10	100.07	100.07
CHL	UMS	0060	2003	100.07	100.04	100.04
CHL	UMS	0061	2003	100.10	100.07	100.07
CHL	UMS	0062	2003	100.07	100.04	100.04
CHL	UMS	0063	2003	100.10	100.07	100.07
CHL	UMS	0064	2003	100.07	100.04	100.04
CHL	UMS	0065	2003	100.10	100.07	100.07
CHL	UMS	0066	2003	100.07	100.04	100.04
CHL	UMS	0067	2003	100.10	100.07	100.07
CHL	UMS	0068	2003	100.07	100.04	100.04
CHL	UMS	0069	2003	100.10	100.07	100.07
CHL	UMS	0070	2003	100.07	100.04	100.04
CHL	UMS	0071	2003	100.10	100.07	100.07
CHL	UMS	0072	2003	100.07	100.04	100.04
CHL	UMS	0073	2003	100.10	100.07	100.07
CHL	UMS	0074	2003	100.07	100.04	100.04
CHL	UMS	0075	2003	100.10	100.07	100.07
CHL	UMS	0076	2003	100.07	100.04	100.04
CHL	UMS	0077	2003	100.10	100.07	100.07
CHL	UMS	0078	2003	100.07	100.04	100.04
CHL	UMS	0079	2003	100.10	100.07	100.07
CHL	UMS	0080	2003	100.07	100.04	100.04
CHL	UMS	0081	2003	100.10	100.07	100.07
CHL	UMS	0082	2003	100.07	100.04	100.04
CHL	UMS	0083	2003	100.10	100.07	100.07
CHL	UMS	0084	2003	100.07	100.04	100.04
CHL	UMS	0085	2003	100.10	100.07	100.07
CHL	UMS	0086	2003	100.07	100.04	100.04
CHL	UMS	0087	2003	100.10	100.07	100.07
CHL	UMS	0088	2003	100.07	100.04	100.04
CHL	UMS	0089	2003	100.10	100.07	100.07
CHL	UMS	0090	2003	100.07	100.04	100.04
CHL	UMS	0091	2003	100.10	100.07	100.07
CHL	UMS	0092	2003	100.07	100.04	100.04
CHL	UMS	0093	2003	100.10	100.07	100.07
CHL	UMS	0094	2003	100.07	100.04	100.04
CHL	UMS	0095	2003	100.10	100.07	100.07
CHL	UMS	0096	2003	100.07	100.04	100.04
CHL	UMS	0097	2003	100.10	100.07	100.07
CHL	UMS	0098	2003	100.07	100.04	100.04
CHL	UMS	0099	2003	100.10	100.07	100.07
CHL	UMS	0100	2003	100.07	100.04	100.04

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACOR
01	01	79231	2011	100.11	102.02	100.09
01	01	79232	2011	100.11	102.02	100.07
01	01	79233	2011	100.11	102.02	100.04
01	01	79234	2011	100.11	102.02	100.04
01	01	79235	2011	100.11	102.02	100.04
01	01	79236	2011	100.11	102.02	100.04
01	01	79237	2011	100.11	102.02	100.04
01	01	79238	2011	100.11	102.02	100.04
01	01	79239	2011	100.11	102.02	100.04
01	01	79240	2011	100.11	102.02	100.04
01	01	79241	2011	100.11	102.02	100.04
01	01	79242	2011	100.11	102.02	100.04
01	01	79243	2011	100.11	102.02	100.04
01	01	79244	2011	100.11	102.02	100.04
01	01	79245	2011	100.11	102.02	100.04
01	01	79246	2011	100.11	102.02	100.04
01	01	79247	2011	100.11	102.02	100.04
01	01	79248	2011	100.11	102.02	100.04
01	01	79249	2011	100.11	102.02	100.04
01	01	79250	2011	100.11	102.02	100.04
01	01	79251	2011	100.11	102.02	100.04
01	01	79252	2011	100.11	102.02	100.04
01	01	79253	2011	100.11	102.02	100.04
01	01	79254	2011	100.11	102.02	100.04
01	01	79255	2011	100.11	102.02	100.04
01	01	79256	2011	100.11	102.02	100.04
01	01	79257	2011	100.11	102.02	100.04
01	01	79258	2011	100.11	102.02	100.04
01	01	79259	2011	100.11	102.02	100.04
01	01	79260	2011	100.11	102.02	100.04
01	01	79261	2011	100.11	102.02	100.04
01	01	79262	2011	100.11	102.02	100.04
01	01	79263	2011	100.11	102.02	100.04
01	01	79264	2011	100.11	102.02	100.04
01	01	79265	2011	100.11	102.02	100.04
01	01	79266	2011	100.11	102.02	100.04
01	01	79267	2011	100.11	102.02	100.04
01	01	79268	2011	100.11	102.02	100.04
01	01	79269	2011	100.11	102.02	100.04
01	01	79270	2011	100.11	102.02	100.04
01	01	79271	2011	100.11	102.02	100.04
01	01	79272	2011	100.11	102.02	100.04
01	01	79273	2011	100.11	102.02	100.04
01	01	79274	2011	100.11	102.02	100.04
01	01	79275	2011	100.11	102.02	100.04
01	01	79276	2011	100.11	102.02	100.04
01	01	79277	2011	100.11	102.02	100.04
01	01	79278	2011	100.11	102.02	100.04
01	01	79279	2011	100.11	102.02	100.04
01	01	79280	2011	100.11	102.02	100.04
01	01	79281	2011	100.11	102.02	100.04
01	01	79282	2011	100.11	102.02	100.04
01	01	79283	2011	100.11	102.02	100.04
01	01	79284	2011	100.11	102.02	100.04
01	01	79285	2011	100.11	102.02	100.04
01	01	79286	2011	100.11	102.02	100.04
01	01	79287	2011	100.11	102.02	100.04
01	01	79288	2011	100.11	102.02	100.04
01	01	79289	2011	100.11	102.02	100.04
01	01	79290	2011	100.11	102.02	100.04
01	01	79291	2011	100.11	102.02	100.04
01	01	79292	2011	100.11	102.02	100.04
01	01	79293	2011	100.11	102.02	100.04
01	01	79294	2011	100.11	102.02	100.04
01	01	79295	2011	100.11	102.02	100.04
01	01	79296	2011	100.11	102.02	100.04
01	01	79297	2011	100.11	102.02	100.04
01	01	79298	2011	100.11	102.02	100.04
01	01	79299	2011	100.11	102.02	100.04
01	01	79300	2011	100.11	102.02	100.04

CIMS360A

LOUISVILLE GAS & ELECTRIC COMPANY
METERS SUBSYSTEM (MS5)
NEW METERS ADDED LAST YEAR

01/14/2002
PAGE: 347

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACOR
0001	0001	79988239	00000000	100.10	100.09	100.11
0001	0001	79988240	00000000	100.11	100.11	100.10
0001	0001	79988241	00000000	100.11	100.11	100.10
0001	0001	79988242	00000000	100.11	100.11	100.10
0001	0001	79988243	00000000	100.11	100.11	100.10
0001	0001	79988244	00000000	100.11	100.11	100.10
0001	0001	79988245	00000000	100.11	100.11	100.10
0001	0001	79988246	00000000	100.11	100.11	100.10
0001	0001	79988247	00000000	100.11	100.11	100.10
0001	0001	79988248	00000000	100.11	100.11	100.10
0001	0001	79988249	00000000	100.11	100.11	100.10
0001	0001	79988250	00000000	100.11	100.11	100.10
0001	0001	79988251	00000000	100.11	100.11	100.10
0001	0001	79988252	00000000	100.11	100.11	100.10
0001	0001	79988253	00000000	100.11	100.11	100.10
0001	0001	79988254	00000000	100.11	100.11	100.10
0001	0001	79988255	00000000	100.11	100.11	100.10
0001	0001	79988256	00000000	100.11	100.11	100.10
0001	0001	79988257	00000000	100.11	100.11	100.10
0001	0001	79988258	00000000	100.11	100.11	100.10
0001	0001	79988259	00000000	100.11	100.11	100.10
0001	0001	79988260	00000000	100.11	100.11	100.10
0001	0001	79988261	00000000	100.11	100.11	100.10
0001	0001	79988262	00000000	100.11	100.11	100.10
0001	0001	79988263	00000000	100.11	100.11	100.10
0001	0001	79988264	00000000	100.11	100.11	100.10
0001	0001	79988265	00000000	100.11	100.11	100.10
0001	0001	79988266	00000000	100.11	100.11	100.10
0001	0001	79988267	00000000	100.11	100.11	100.10
0001	0001	79988268	00000000	100.11	100.11	100.10
0001	0001	79988269	00000000	100.11	100.11	100.10
0001	0001	79988270	00000000	100.11	100.11	100.10
0001	0001	79988271	00000000	100.11	100.11	100.10
0001	0001	79988272	00000000	100.11	100.11	100.10
0001	0001	79988273	00000000	100.11	100.11	100.10
0001	0001	79988274	00000000	100.11	100.11	100.10
0001	0001	79988275	00000000	100.11	100.11	100.10
0001	0001	79988276	00000000	100.11	100.11	100.10
0001	0001	79988277	00000000	100.11	100.11	100.10
0001	0001	79988278	00000000	100.11	100.11	100.10
0001	0001	79988279	00000000	100.11	100.11	100.10
0001	0001	79988280	00000000	100.11	100.11	100.10
0001	0001	79988281	00000000	100.11	100.11	100.10
0001	0001	79988282	00000000	100.11	100.11	100.10
0001	0001	79988283	00000000	100.11	100.11	100.10
0001	0001	79988284	00000000	100.11	100.11	100.10
0001	0001	79988285	00000000	100.11	100.11	100.10
0001	0001	79988286	00000000	100.11	100.11	100.10
0001	0001	79988287	00000000	100.11	100.11	100.10
0001	0001	79988288	00000000	100.11	100.11	100.10
0001	0001	79988289	00000000	100.11	100.11	100.10
0001	0001	79988290	00000000	100.11	100.11	100.10
0001	0001	79988291	00000000	100.11	100.11	100.10
0001	0001	79988292	00000000	100.11	100.11	100.10
0001	0001	79988293	00000000	100.11	100.11	100.10
0001	0001	79988294	00000000	100.11	100.11	100.10
0001	0001	79988295	00000000	100.11	100.11	100.10
0001	0001	79988296	00000000	100.11	100.11	100.10
0001	0001	79988297	00000000	100.11	100.11	100.10
0001	0001	79988298	00000000	100.11	100.11	100.10
0001	0001	79988299	00000000	100.11	100.11	100.10
0001	0001	79988300	00000000	100.11	100.11	100.10

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
STC LINEELECTR	01	7928280	2002-11-11	100.09	100.13	100.04
STC LINEELECTR	01	7928281	2002-11-11	100.09	100.13	100.04
STC LINEELECTR	01	7928282	2002-11-11	100.11	100.13	100.04
STC LINEELECTR	01	7928283	2002-11-11	100.11	100.13	100.04
STC LINEELECTR	01	7928284	2002-11-11	100.09	100.13	100.04
STC LINEELECTR	01	7928285	2002-11-11	100.09	100.13	100.04
STC LINEELECTR	01	7928286	2002-11-11	100.11	100.13	100.04
STC LINEELECTR	01	7928287	2002-11-11	100.09	100.13	100.04
STC LINEELECTR	01	7928288	2002-11-11	100.09	100.13	100.04
STC LINEELECTR	01	7928289	2002-11-11	100.10	100.13	100.04
STC LINEELECTR	01	7928290	2002-11-11	100.09	100.13	100.04
STC LINEELECTR	01	7928291	2002-11-11	100.09	100.13	100.04
STC LINEELECTR	01	7928292	2002-11-11	100.09	100.13	100.04
STC LINEELECTR	01	7928293	2002-11-11	100.09	100.13	100.04
STC LINEELECTR	01	7928294	2002-11-11	100.09	100.13	100.04
STC LINEELECTR	01	7928295	2002-11-11	100.09	100.13	100.04
STC LINEELECTR	01	7928296	2002-11-11	100.09	100.13	100.04
STC LINEELECTR	01	7928297	2002-11-11	100.09	100.13	100.04
STC LINEELECTR	01	7928298	2002-11-11	100.10	100.13	100.04
STC LINEELECTR	01	7928299	2002-11-11	100.10	100.13	100.04
STC LINEELECTR	01	7928300	2002-11-11	100.10	100.13	100.04
STC LINEELECTR	01	7928301	2002-11-11	100.10	100.13	100.04
STC LINEELECTR	01	7928302	2002-11-11	100.10	100.13	100.04
STC LINEELECTR	01	7928303	2002-11-11	100.10	100.13	100.04
STC LINEELECTR	01	7928304	2002-11-11	100.10	100.13	100.04
STC LINEELECTR	01	7928305	2002-11-11	100.10	100.13	100.04
STC LINEELECTR	01	7928306	2002-11-11	100.10	100.13	100.04
STC LINEELECTR	01	7928307	2002-11-11	100.10	100.13	100.04
STC LINEELECTR	01	7928308	2002-11-11	100.10	100.13	100.04
STC LINEELECTR	01	7928309	2002-11-11	100.10	100.13	100.04
STC LINEELECTR	01	7928310	2002-11-11	100.10	100.13	100.04
STC LINEELECTR	01	7928311	2002-11-11	100.10	100.13	100.04
STC LINEELECTR	01	7928312	2002-11-11	100.10	100.13	100.04
STC LINEELECTR	01	7928313	2002-11-11	100.10	100.13	100.04
STC LINEELECTR	01	7928314	2002-11-11	100.10	100.13	100.04
STC LINEELECTR	01	7928315	2002-11-11	100.10	100.13	100.04
STC LINEELECTR	01	7928316	2002-11-11	100.10	100.13	100.04
STC LINEELECTR	01	7928317	2002-11-11	100.10	100.13	100.04
STC LINEELECTR	01	7928318	2002-11-11	100.10	100.13	100.04
STC LINEELECTR	01	7928319	2002-11-11	100.10	100.13	100.04
STC LINEELECTR	01	7928320	2002-11-11	100.10	100.13	100.04

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACOR
0001	0001	7993931	00000000	100.10	079.20	079.76
0001	0001	7993932	00000000	100.11	100.19	100.16
0001	0001	7993933	00000000	100.11	100.11	100.04
0001	0001	7993934	00000000	100.10	100.07	100.05
0001	0001	7993935	00000000	100.10	102.04	100.04
0001	0001	7993936	00000000	100.10	100.04	100.16
0001	0001	7993937	00000000	100.10	100.04	100.04
0001	0001	7993938	00000000	100.10	100.14	100.10
0001	0001	7993939	00000000	100.10	100.14	100.06
0001	0001	7993940	00000000	100.10	100.07	100.04
0001	0001	7993941	00000000	100.10	100.07	100.04
0001	0001	7993942	00000000	100.10	100.07	100.04
0001	0001	7993943	00000000	100.10	100.07	100.04
0001	0001	7993944	00000000	100.10	100.07	100.04
0001	0001	7993945	00000000	100.10	100.07	100.04
0001	0001	7993946	00000000	100.10	100.07	100.04
0001	0001	7993947	00000000	100.10	100.07	100.04
0001	0001	7993948	00000000	100.10	100.07	100.04
0001	0001	7993949	00000000	100.10	100.07	100.04
0001	0001	7993950	00000000	100.10	100.07	100.04
0001	0001	7993951	00000000	100.10	100.07	100.04
0001	0001	7993952	00000000	100.10	100.07	100.04
0001	0001	7993953	00000000	100.10	100.07	100.04
0001	0001	7993954	00000000	100.10	100.07	100.04
0001	0001	7993955	00000000	100.10	100.07	100.04
0001	0001	7993956	00000000	100.10	100.07	100.04
0001	0001	7993957	00000000	100.10	100.07	100.04
0001	0001	7993958	00000000	100.10	100.07	100.04
0001	0001	7993959	00000000	100.10	100.07	100.04
0001	0001	7993960	00000000	100.10	100.07	100.04
0001	0001	7993961	00000000	100.10	100.07	100.04
0001	0001	7993962	00000000	100.10	100.07	100.04
0001	0001	7993963	00000000	100.10	100.07	100.04
0001	0001	7993964	00000000	100.10	100.07	100.04
0001	0001	7993965	00000000	100.10	100.07	100.04
0001	0001	7993966	00000000	100.10	100.07	100.04
0001	0001	7993967	00000000	100.10	100.07	100.04
0001	0001	7993968	00000000	100.10	100.07	100.04
0001	0001	7993969	00000000	100.10	100.07	100.04
0001	0001	7993970	00000000	100.10	100.07	100.04
0001	0001	7993971	00000000	100.10	100.07	100.04
0001	0001	7993972	00000000	100.10	100.07	100.04
0001	0001	7993973	00000000	100.10	100.07	100.04
0001	0001	7993974	00000000	100.10	100.07	100.04
0001	0001	7993975	00000000	100.10	100.07	100.04
0001	0001	7993976	00000000	100.10	100.07	100.04
0001	0001	7993977	00000000	100.10	100.07	100.04
0001	0001	7993978	00000000	100.10	100.07	100.04
0001	0001	7993979	00000000	100.10	100.07	100.04
0001	0001	7993980	00000000	100.10	100.07	100.04
0001	0001	7993981	00000000	100.10	100.07	100.04
0001	0001	7993982	00000000	100.10	100.07	100.04
0001	0001	7993983	00000000	100.10	100.07	100.04
0001	0001	7993984	00000000	100.10	100.07	100.04
0001	0001	7993985	00000000	100.10	100.07	100.04
0001	0001	7993986	00000000	100.10	100.07	100.04
0001	0001	7993987	00000000	100.10	100.07	100.04
0001	0001	7993988	00000000	100.10	100.07	100.04
0001	0001	7993989	00000000	100.10	100.07	100.04
0001	0001	7993990	00000000	100.10	100.07	100.04
0001	0001	7993991	00000000	100.10	100.07	100.04
0001	0001	7993992	00000000	100.10	100.07	100.04
0001	0001	7993993	00000000	100.10	100.07	100.04
0001	0001	7993994	00000000	100.10	100.07	100.04
0001	0001	7993995	00000000	100.10	100.07	100.04
0001	0001	7993996	00000000	100.10	100.07	100.04
0001	0001	7993997	00000000	100.10	100.07	100.04
0001	0001	7993998	00000000	100.10	100.07	100.04
0001	0001	7993999	00000000	100.10	100.07	100.04
0001	0001	7994000	00000000	100.10	100.07	100.04

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLIMBERGER	01	798720	2002-11-20	100.09	100.09	100.06
SCHLIMBERGER	01	798721	2002-11-20	100.09	100.10	100.01
SCHLIMBERGER	01	798722	2002-11-20	100.08	100.03	100.05
SCHLIMBERGER	01	798723	2002-11-20	100.11	100.14	100.06
SCHLIMBERGER	01	798724	2002-11-20	100.09	100.05	100.05
SCHLIMBERGER	01	798725	2002-11-20	100.10	100.02	100.11
SCHLIMBERGER	01	798726	2002-11-20	100.10	100.02	100.06
SCHLIMBERGER	01	798727	2002-11-20	100.10	100.04	100.06
SCHLIMBERGER	01	798728	2002-11-20	100.10	100.11	100.07
SCHLIMBERGER	01	798729	2002-11-20	100.11	100.17	097.92
SCHLIMBERGER	01	798730	2002-11-20	100.12	100.10	100.05
SCHLIMBERGER	01	798731	2002-11-20	100.07	100.14	100.07
SCHLIMBERGER	01	798732	2002-11-20	100.11	100.18	100.01
SCHLIMBERGER	01	798733	2002-11-20	100.09	100.10	100.02
SCHLIMBERGER	01	798734	2002-11-20	100.09	100.10	100.07
SCHLIMBERGER	01	798735	2002-11-20	100.09	100.10	100.00
SCHLIMBERGER	01	798736	2002-11-20	100.09	100.12	100.00
SCHLIMBERGER	01	798737	2002-11-20	100.09	100.11	100.14
SCHLIMBERGER	01	798738	2002-11-20	100.10	100.14	100.10
SCHLIMBERGER	01	798739	2002-11-20	100.09	100.02	100.00
SCHLIMBERGER	01	798740	2002-11-20	100.09	100.04	100.04
SCHLIMBERGER	01	798741	2002-11-20	100.10	100.11	100.08
SCHLIMBERGER	01	798742	2002-11-20	100.10	100.05	100.05
SCHLIMBERGER	01	798743	2002-11-20	100.10	100.14	100.10
SCHLIMBERGER	01	798744	2002-11-20	100.09	100.14	100.10
SCHLIMBERGER	01	798745	2002-11-20	100.09	100.04	100.00
SCHLIMBERGER	01	798746	2002-11-20	100.09	100.02	100.01
SCHLIMBERGER	01	798747	2002-11-20	100.09	100.04	100.04
SCHLIMBERGER	01	798748	2002-11-20	100.09	100.07	100.04
SCHLIMBERGER	01	798749	2002-11-20	100.09	100.07	100.00
SCHLIMBERGER	01	798750	2002-11-20	100.09	100.04	100.04
SCHLIMBERGER	01	798751	2002-11-20	100.10	100.11	100.08
SCHLIMBERGER	01	798752	2002-11-20	100.10	100.05	100.05
SCHLIMBERGER	01	798753	2002-11-20	100.10	100.11	100.02
SCHLIMBERGER	01	798754	2002-11-20	100.09	100.07	100.00
SCHLIMBERGER	01	798755	2002-11-20	100.09	100.04	100.04
SCHLIMBERGER	01	798756	2002-11-20	100.09	100.04	100.04
SCHLIMBERGER	01	798757	2002-11-20	100.10	100.14	100.01
SCHLIMBERGER	01	798758	2002-11-20	100.09	100.14	100.04
SCHLIMBERGER	01	798759	2002-11-20	100.10	100.14	100.04
SCHLIMBERGER	01	798760	2002-11-20	100.09	100.04	097.92
SCHLIMBERGER	01	798761	2002-11-20	100.09	100.04	100.04
SCHLIMBERGER	01	798762	2002-11-20	100.09	100.14	100.04
SCHLIMBERGER	01	798763	2002-11-20	100.09	100.04	100.07
SCHLIMBERGER	01	798764	2002-11-20	100.09	100.04	100.07
SCHLIMBERGER	01	798765	2002-11-20	100.09	100.04	100.04
SCHLIMBERGER	01	798766	2002-11-20	100.09	100.04	100.04
SCHLIMBERGER	01	798767	2002-11-20	100.09	100.04	100.04
SCHLIMBERGER	01	798768	2002-11-20	100.09	100.04	100.04
SCHLIMBERGER	01	798769	2002-11-20	100.09	100.04	100.04
SCHLIMBERGER	01	798770	2002-11-20	100.09	100.04	100.04
SCHLIMBERGER	01	798771	2002-11-20	100.09	100.04	100.04
SCHLIMBERGER	01	798772	2002-11-20	100.09	100.04	100.04
SCHLIMBERGER	01	798773	2002-11-20	100.09	100.04	100.04
SCHLIMBERGER	01	798774	2002-11-20	100.10	100.04	100.04
SCHLIMBERGER	01	798775	2002-11-20	100.10	100.04	100.04
SCHLIMBERGER	01	798776	2002-11-20	100.09	100.11	100.08
SCHLIMBERGER	01	798777	2002-11-20	100.09	100.11	100.08
SCHLIMBERGER	01	798778	2002-11-20	100.10	100.11	100.08
SCHLIMBERGER	01	798779	2002-11-20	100.10	100.11	100.08

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
CHL LMS2RCE	01	798230	2002-12-29	100.07	100.02	100.01
CHL LMS2RCE	01	798231	2002-12-29	100.02	100.14	100.08
CHL LMS2RCE	01	798232	2002-12-29	100.07	100.08	099.99
CHL LMS2RCE	01	798233	2002-12-29	100.09	100.58	100.04
CHL LMS2RCE	01	798234	2002-12-29	100.08	100.00	100.01
CHL LMS2RCE	01	798235	2002-12-29	100.08	100.02	100.02
CHL LMS2RCE	01	798236	2002-12-29	100.09	100.04	100.04
CHL LMS2RCE	01	798237	2002-12-29	100.09	100.07	100.03
CHL LMS2RCE	01	798238	2002-12-29	100.08	100.11	100.08
CHL LMS2RCE	01	798239	2002-12-29	100.09	100.07	100.08
CHL LMS2RCE	01	798240	2002-12-29	100.07	100.11	100.02
CHL LMS2RCE	01	798241	2002-12-29	100.08	100.07	100.08
CHL LMS2RCE	01	798242	2002-12-29	100.09	100.07	100.08
CHL LMS2RCE	01	798243	2002-12-29	100.09	100.14	100.05
CHL LMS2RCE	01	798244	2002-12-29	100.09	100.07	100.08
CHL LMS2RCE	01	798245	2002-12-29	100.08	100.07	100.08
CHL LMS2RCE	01	798246	2002-12-29	100.08	100.11	100.08
CHL LMS2RCE	01	798247	2002-12-29	100.09	100.07	100.08
CHL LMS2RCE	01	798248	2002-12-29	100.09	100.07	100.08
CHL LMS2RCE	01	798249	2002-12-29	100.08	100.07	100.08
CHL LMS2RCE	01	798250	2002-12-29	100.08	100.07	100.08
CHL LMS2RCE	01	798251	2002-12-29	100.09	100.07	100.08
CHL LMS2RCE	01	798252	2002-12-29	100.08	100.07	100.08
CHL LMS2RCE	01	798253	2002-12-29	100.09	100.07	100.08
CHL LMS2RCE	01	798254	2002-12-29	100.08	100.07	100.08
CHL LMS2RCE	01	798255	2002-12-29	100.09	100.07	100.08
CHL LMS2RCE	01	798256	2002-12-29	100.08	100.07	100.08
CHL LMS2RCE	01	798257	2002-12-29	100.09	100.07	100.08
CHL LMS2RCE	01	798258	2002-12-29	100.08	100.07	100.08
CHL LMS2RCE	01	798259	2002-12-29	100.09	100.07	100.08
CHL LMS2RCE	01	798260	2002-12-29	100.08	100.07	100.08
CHL LMS2RCE	01	798261	2002-12-29	100.09	100.07	100.08
CHL LMS2RCE	01	798262	2002-12-29	100.08	100.07	100.08
CHL LMS2RCE	01	798263	2002-12-29	100.09	100.07	100.08
CHL LMS2RCE	01	798264	2002-12-29	100.08	100.07	100.08
CHL LMS2RCE	01	798265	2002-12-29	100.09	100.07	100.08
CHL LMS2RCE	01	798266	2002-12-29	100.08	100.07	100.08
CHL LMS2RCE	01	798267	2002-12-29	100.09	100.07	100.08
CHL LMS2RCE	01	798268	2002-12-29	100.08	100.07	100.08
CHL LMS2RCE	01	798269	2002-12-29	100.09	100.07	100.08
CHL LMS2RCE	01	798270	2002-12-29	100.08	100.07	100.08
CHL LMS2RCE	01	798271	2002-12-29	100.09	100.07	100.08
CHL LMS2RCE	01	798272	2002-12-29	100.08	100.07	100.08
CHL LMS2RCE	01	798273	2002-12-29	100.09	100.07	100.08
CHL LMS2RCE	01	798274	2002-12-29	100.08	100.07	100.08
CHL LMS2RCE	01	798275	2002-12-29	100.09	100.07	100.08
CHL LMS2RCE	01	798276	2002-12-29	100.08	100.07	100.08
CHL LMS2RCE	01	798277	2002-12-29	100.09	100.07	100.08
CHL LMS2RCE	01	798278	2002-12-29	100.08	100.07	100.08
CHL LMS2RCE	01	798279	2002-12-29	100.09	100.07	100.08
CHL LMS2RCE	01	798280	2002-12-29	100.08	100.07	100.08
CHL LMS2RCE	01	798281	2002-12-29	100.09	100.07	100.08
CHL LMS2RCE	01	798282	2002-12-29	100.08	100.07	100.08
CHL LMS2RCE	01	798283	2002-12-29	100.09	100.07	100.08
CHL LMS2RCE	01	798284	2002-12-29	100.08	100.07	100.08
CHL LMS2RCE	01	798285	2002-12-29	100.09	100.07	100.08
CHL LMS2RCE	01	798286	2002-12-29	100.08	100.07	100.08
CHL LMS2RCE	01	798287	2002-12-29	100.09	100.07	100.08
CHL LMS2RCE	01	798288	2002-12-29	100.08	100.07	100.08
CHL LMS2RCE	01	798289	2002-12-29	100.09	100.07	100.08
CHL LMS2RCE	01	798290	2002-12-29	100.08	100.07	100.08
CHL LMS2RCE	01	798291	2002-12-29	100.09	100.07	100.08
CHL LMS2RCE	01	798292	2002-12-29	100.08	100.07	100.08
CHL LMS2RCE	01	798293	2002-12-29	100.09	100.07	100.08
CHL LMS2RCE	01	798294	2002-12-29	100.08	100.07	100.08
CHL LMS2RCE	01	798295	2002-12-29	100.09	100.07	100.08
CHL LMS2RCE	01	798296	2002-12-29	100.08	100.07	100.08
CHL LMS2RCE	01	798297	2002-12-29	100.09	100.07	100.08
CHL LMS2RCE	01	798298	2002-12-29	100.08	100.07	100.08
CHL LMS2RCE	01	798299	2002-12-29	100.09	100.07	100.08
CHL LMS2RCE	01	798300	2002-12-29	100.08	100.07	100.08

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PF FACTOR
UC#	UC#	7990121	2000211	100.07	100.07	0.99
UC#	UC#	7990122	2000211	100.07	100.07	0.99
UC#	UC#	7990123	2000211	100.07	100.07	0.99
UC#	UC#	7990124	2000211	100.07	100.07	0.99
UC#	UC#	7990125	2000211	100.07	100.07	0.99
UC#	UC#	7990126	2000211	100.07	100.07	0.99
UC#	UC#	7990127	2000211	100.07	100.07	0.99
UC#	UC#	7990128	2000211	100.07	100.07	0.99
UC#	UC#	7990129	2000211	100.07	100.07	0.99
UC#	UC#	7990130	2000211	100.07	100.07	0.99
UC#	UC#	7990131	2000211	100.07	100.07	0.99
UC#	UC#	7990132	2000211	100.07	100.07	0.99
UC#	UC#	7990133	2000211	100.07	100.07	0.99
UC#	UC#	7990134	2000211	100.07	100.07	0.99
UC#	UC#	7990135	2000211	100.07	100.07	0.99
UC#	UC#	7990136	2000211	100.07	100.07	0.99
UC#	UC#	7990137	2000211	100.07	100.07	0.99
UC#	UC#	7990138	2000211	100.07	100.07	0.99
UC#	UC#	7990139	2000211	100.07	100.07	0.99
UC#	UC#	7990140	2000211	100.07	100.07	0.99
UC#	UC#	7990141	2000211	100.07	100.07	0.99
UC#	UC#	7990142	2000211	100.07	100.07	0.99
UC#	UC#	7990143	2000211	100.07	100.07	0.99
UC#	UC#	7990144	2000211	100.07	100.07	0.99
UC#	UC#	7990145	2000211	100.07	100.07	0.99
UC#	UC#	7990146	2000211	100.07	100.07	0.99
UC#	UC#	7990147	2000211	100.07	100.07	0.99
UC#	UC#	7990148	2000211	100.07	100.07	0.99
UC#	UC#	7990149	2000211	100.07	100.07	0.99
UC#	UC#	7990150	2000211	100.07	100.07	0.99
UC#	UC#	7990151	2000211	100.07	100.07	0.99
UC#	UC#	7990152	2000211	100.07	100.07	0.99
UC#	UC#	7990153	2000211	100.07	100.07	0.99
UC#	UC#	7990154	2000211	100.07	100.07	0.99
UC#	UC#	7990155	2000211	100.07	100.07	0.99
UC#	UC#	7990156	2000211	100.07	100.07	0.99
UC#	UC#	7990157	2000211	100.07	100.07	0.99
UC#	UC#	7990158	2000211	100.07	100.07	0.99
UC#	UC#	7990159	2000211	100.07	100.07	0.99
UC#	UC#	7990160	2000211	100.07	100.07	0.99
UC#	UC#	7990161	2000211	100.07	100.07	0.99
UC#	UC#	7990162	2000211	100.07	100.07	0.99
UC#	UC#	7990163	2000211	100.07	100.07	0.99
UC#	UC#	7990164	2000211	100.07	100.07	0.99
UC#	UC#	7990165	2000211	100.07	100.07	0.99
UC#	UC#	7990166	2000211	100.07	100.07	0.99
UC#	UC#	7990167	2000211	100.07	100.07	0.99
UC#	UC#	7990168	2000211	100.07	100.07	0.99
UC#	UC#	7990169	2000211	100.07	100.07	0.99
UC#	UC#	7990170	2000211	100.07	100.07	0.99
UC#	UC#	7990171	2000211	100.07	100.07	0.99
UC#	UC#	7990172	2000211	100.07	100.07	0.99
UC#	UC#	7990173	2000211	100.07	100.07	0.99
UC#	UC#	7990174	2000211	100.07	100.07	0.99
UC#	UC#	7990175	2000211	100.07	100.07	0.99
UC#	UC#	7990176	2000211	100.07	100.07	0.99
UC#	UC#	7990177	2000211	100.07	100.07	0.99
UC#	UC#	7990178	2000211	100.07	100.07	0.99
UC#	UC#	7990179	2000211	100.07	100.07	0.99
UC#	UC#	7990180	2000211	100.07	100.07	0.99
UC#	UC#	7990181	2000211	100.07	100.07	0.99
UC#	UC#	7990182	2000211	100.07	100.07	0.99
UC#	UC#	7990183	2000211	100.07	100.07	0.99
UC#	UC#	7990184	2000211	100.07	100.07	0.99
UC#	UC#	7990185	2000211	100.07	100.07	0.99
UC#	UC#	7990186	2000211	100.07	100.07	0.99
UC#	UC#	7990187	2000211	100.07	100.07	0.99
UC#	UC#	7990188	2000211	100.07	100.07	0.99
UC#	UC#	7990189	2000211	100.07	100.07	0.99
UC#	UC#	7990190	2000211	100.07	100.07	0.99
UC#	UC#	7990191	2000211	100.07	100.07	0.99
UC#	UC#	7990192	2000211	100.07	100.07	0.99
UC#	UC#	7990193	2000211	100.07	100.07	0.99
UC#	UC#	7990194	2000211	100.07	100.07	0.99
UC#	UC#	7990195	2000211	100.07	100.07	0.99
UC#	UC#	7990196	2000211	100.07	100.07	0.99
UC#	UC#	7990197	2000211	100.07	100.07	0.99
UC#	UC#	7990198	2000211	100.07	100.07	0.99
UC#	UC#	7990199	2000211	100.07	100.07	0.99
UC#	UC#	7990200	2000211	100.07	100.07	0.99

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PF FACTOR
GE	01	799030	200002	100.09	100.02	100.02
GE	01	799031	200002	100.09	100.02	100.02
GE	01	799032	200002	100.09	100.02	100.02
GE	01	799033	200002	100.09	100.02	100.02
GE	01	799034	200002	100.09	100.02	100.02
GE	01	799035	200002	100.09	100.02	100.02
GE	01	799036	200002	100.09	100.02	100.02
GE	01	799037	200002	100.09	100.02	100.02
GE	01	799038	200002	100.09	100.02	100.02
GE	01	799039	200002	100.09	100.02	100.02
GE	01	799040	200002	100.09	100.02	100.02
GE	01	799041	200002	100.09	100.02	100.02
GE	01	799042	200002	100.09	100.02	100.02
GE	01	799043	200002	100.09	100.02	100.02
GE	01	799044	200002	100.09	100.02	100.02
GE	01	799045	200002	100.09	100.02	100.02
GE	01	799046	200002	100.09	100.02	100.02
GE	01	799047	200002	100.09	100.02	100.02
GE	01	799048	200002	100.09	100.02	100.02
GE	01	799049	200002	100.09	100.02	100.02
GE	01	799050	200002	100.09	100.02	100.02
GE	01	799051	200002	100.09	100.02	100.02
GE	01	799052	200002	100.09	100.02	100.02
GE	01	799053	200002	100.09	100.02	100.02
GE	01	799054	200002	100.09	100.02	100.02
GE	01	799055	200002	100.09	100.02	100.02
GE	01	799056	200002	100.09	100.02	100.02
GE	01	799057	200002	100.09	100.02	100.02
GE	01	799058	200002	100.09	100.02	100.02
GE	01	799059	200002	100.09	100.02	100.02
GE	01	799060	200002	100.09	100.02	100.02
GE	01	799061	200002	100.09	100.02	100.02
GE	01	799062	200002	100.09	100.02	100.02
GE	01	799063	200002	100.09	100.02	100.02
GE	01	799064	200002	100.09	100.02	100.02
GE	01	799065	200002	100.09	100.02	100.02
GE	01	799066	200002	100.09	100.02	100.02
GE	01	799067	200002	100.09	100.02	100.02
GE	01	799068	200002	100.09	100.02	100.02
GE	01	799069	200002	100.09	100.02	100.02
GE	01	799070	200002	100.09	100.02	100.02
GE	01	799071	200002	100.09	100.02	100.02
GE	01	799072	200002	100.09	100.02	100.02
GE	01	799073	200002	100.09	100.02	100.02
GE	01	799074	200002	100.09	100.02	100.02
GE	01	799075	200002	100.09	100.02	100.02
GE	01	799076	200002	100.09	100.02	100.02
GE	01	799077	200002	100.09	100.02	100.02
GE	01	799078	200002	100.09	100.02	100.02
GE	01	799079	200002	100.09	100.02	100.02

LOUISVILLE GAS & ELECTRIC COMPANY
METER
NEW METERS ADDED LAST YEAR

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACOR
CHL	01	7991089	2002-11-11	100.09	100.07	099.99
CHL	01	7991088	2002-11-11	100.11	100.10	100.07
CHL	01	7991087	2002-11-11	100.12	100.11	100.06
CHL	01	7991086	2002-11-11	100.13	100.12	100.04
CHL	01	7991085	2002-11-11	100.14	100.13	100.03
CHL	01	7991084	2002-11-11	100.15	100.14	100.02
CHL	01	7991083	2002-11-11	100.16	100.15	100.01
CHL	01	7991082	2002-11-11	100.17	100.16	100.00
CHL	01	7991081	2002-11-11	100.18	100.17	100.00
CHL	01	7991080	2002-11-11	100.19	100.18	100.00
CHL	01	7991079	2002-11-11	100.20	100.19	100.00
CHL	01	7991078	2002-11-11	100.21	100.20	100.00
CHL	01	7991077	2002-11-11	100.22	100.21	100.00
CHL	01	7991076	2002-11-11	100.23	100.22	100.00
CHL	01	7991075	2002-11-11	100.24	100.23	100.00
CHL	01	7991074	2002-11-11	100.25	100.24	100.00
CHL	01	7991073	2002-11-11	100.26	100.25	100.00
CHL	01	7991072	2002-11-11	100.27	100.26	100.00
CHL	01	7991071	2002-11-11	100.28	100.27	100.00
CHL	01	7991070	2002-11-11	100.29	100.28	100.00
CHL	01	7991069	2002-11-11	100.30	100.29	100.00
CHL	01	7991068	2002-11-11	100.31	100.30	100.00
CHL	01	7991067	2002-11-11	100.32	100.31	100.00
CHL	01	7991066	2002-11-11	100.33	100.32	100.00
CHL	01	7991065	2002-11-11	100.34	100.33	100.00
CHL	01	7991064	2002-11-11	100.35	100.34	100.00
CHL	01	7991063	2002-11-11	100.36	100.35	100.00
CHL	01	7991062	2002-11-11	100.37	100.36	100.00
CHL	01	7991061	2002-11-11	100.38	100.37	100.00
CHL	01	7991060	2002-11-11	100.39	100.38	100.00
CHL	01	7991059	2002-11-11	100.40	100.39	100.00
CHL	01	7991058	2002-11-11	100.41	100.40	100.00
CHL	01	7991057	2002-11-11	100.42	100.41	100.00
CHL	01	7991056	2002-11-11	100.43	100.42	100.00
CHL	01	7991055	2002-11-11	100.44	100.43	100.00
CHL	01	7991054	2002-11-11	100.45	100.44	100.00
CHL	01	7991053	2002-11-11	100.46	100.45	100.00
CHL	01	7991052	2002-11-11	100.47	100.46	100.00
CHL	01	7991051	2002-11-11	100.48	100.47	100.00
CHL	01	7991050	2002-11-11	100.49	100.48	100.00
CHL	01	7991049	2002-11-11	100.50	100.49	100.00
CHL	01	7991048	2002-11-11	100.51	100.50	100.00
CHL	01	7991047	2002-11-11	100.52	100.51	100.00
CHL	01	7991046	2002-11-11	100.53	100.52	100.00
CHL	01	7991045	2002-11-11	100.54	100.53	100.00
CHL	01	7991044	2002-11-11	100.55	100.54	100.00
CHL	01	7991043	2002-11-11	100.56	100.55	100.00
CHL	01	7991042	2002-11-11	100.57	100.56	100.00
CHL	01	7991041	2002-11-11	100.58	100.57	100.00
CHL	01	7991040	2002-11-11	100.59	100.58	100.00
CHL	01	7991039	2002-11-11	100.60	100.59	100.00
CHL	01	7991038	2002-11-11	100.61	100.60	100.00
CHL	01	7991037	2002-11-11	100.62	100.61	100.00
CHL	01	7991036	2002-11-11	100.63	100.62	100.00
CHL	01	7991035	2002-11-11	100.64	100.63	100.00
CHL	01	7991034	2002-11-11	100.65	100.64	100.00
CHL	01	7991033	2002-11-11	100.66	100.65	100.00
CHL	01	7991032	2002-11-11	100.67	100.66	100.00
CHL	01	7991031	2002-11-11	100.68	100.67	100.00
CHL	01	7991030	2002-11-11	100.69	100.68	100.00
CHL	01	7991029	2002-11-11	100.70	100.69	100.00
CHL	01	7991028	2002-11-11	100.71	100.70	100.00
CHL	01	7991027	2002-11-11	100.72	100.71	100.00
CHL	01	7991026	2002-11-11	100.73	100.72	100.00
CHL	01	7991025	2002-11-11	100.74	100.73	100.00
CHL	01	7991024	2002-11-11	100.75	100.74	100.00
CHL	01	7991023	2002-11-11	100.76	100.75	100.00
CHL	01	7991022	2002-11-11	100.77	100.76	100.00
CHL	01	7991021	2002-11-11	100.78	100.77	100.00
CHL	01	7991020	2002-11-11	100.79	100.78	100.00
CHL	01	7991019	2002-11-11	100.80	100.79	100.00
CHL	01	7991018	2002-11-11	100.81	100.80	100.00
CHL	01	7991017	2002-11-11	100.82	100.81	100.00
CHL	01	7991016	2002-11-11	100.83	100.82	100.00
CHL	01	7991015	2002-11-11	100.84	100.83	100.00
CHL	01	7991014	2002-11-11	100.85	100.84	100.00
CHL	01	7991013	2002-11-11	100.86	100.85	100.00
CHL	01	7991012	2002-11-11	100.87	100.86	100.00
CHL	01	7991011	2002-11-11	100.88	100.87	100.00
CHL	01	7991010	2002-11-11	100.89	100.88	100.00
CHL	01	7991009	2002-11-11	100.90	100.89	100.00
CHL	01	7991008	2002-11-11	100.91	100.90	100.00
CHL	01	7991007	2002-11-11	100.92	100.91	100.00
CHL	01	7991006	2002-11-11	100.93	100.92	100.00
CHL	01	7991005	2002-11-11	100.94	100.93	100.00
CHL	01	7991004	2002-11-11	100.95	100.94	100.00
CHL	01	7991003	2002-11-11	100.96	100.95	100.00
CHL	01	7991002	2002-11-11	100.97	100.96	100.00
CHL	01	7991001	2002-11-11	100.98	100.97	100.00
CHL	01	7991000	2002-11-11	100.99	100.98	100.00
CHL	01	7990999	2002-11-11	100.00	100.00	100.00

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACOR
CHL	U	799180	2000-11-20	100.08	100.07	100.04
CHL	U	799181	2000-11-20	100.10	100.07	100.04
CHL	U	799182	2000-11-20	100.12	100.14	100.09
CHL	U	799183	2000-11-20	100.10	100.14	100.09
CHL	U	799184	2000-11-20	100.10	100.12	100.09
CHL	U	799185	2000-11-20	100.12	100.07	100.09
CHL	U	799186	2000-11-20	100.10	100.09	100.09
CHL	U	799187	2000-11-20	100.10	100.09	100.09
CHL	U	799188	2000-11-20	100.10	100.09	100.09
CHL	U	799189	2000-11-20	100.10	100.09	100.09
CHL	U	799190	2000-11-20	100.10	100.09	100.09
CHL	U	799191	2000-11-20	100.10	100.09	100.09
CHL	U	799192	2000-11-20	100.10	100.09	100.09
CHL	U	799193	2000-11-20	100.10	100.09	100.09
CHL	U	799194	2000-11-20	100.10	100.09	100.09
CHL	U	799195	2000-11-20	100.10	100.09	100.09
CHL	U	799196	2000-11-20	100.10	100.09	100.09
CHL	U	799197	2000-11-20	100.10	100.09	100.09
CHL	U	799198	2000-11-20	100.10	100.09	100.09
CHL	U	799199	2000-11-20	100.10	100.09	100.09
CHL	U	799200	2000-11-20	100.10	100.09	100.09
CHL	U	799201	2000-11-20	100.10	100.09	100.09
CHL	U	799202	2000-11-20	100.10	100.09	100.09
CHL	U	799203	2000-11-20	100.10	100.09	100.09
CHL	U	799204	2000-11-20	100.10	100.09	100.09
CHL	U	799205	2000-11-20	100.10	100.09	100.09
CHL	U	799206	2000-11-20	100.10	100.09	100.09
CHL	U	799207	2000-11-20	100.10	100.09	100.09
CHL	U	799208	2000-11-20	100.10	100.09	100.09
CHL	U	799209	2000-11-20	100.10	100.09	100.09
CHL	U	799210	2000-11-20	100.10	100.09	100.09
CHL	U	799211	2000-11-20	100.10	100.09	100.09
CHL	U	799212	2000-11-20	100.10	100.09	100.09
CHL	U	799213	2000-11-20	100.10	100.09	100.09
CHL	U	799214	2000-11-20	100.10	100.09	100.09
CHL	U	799215	2000-11-20	100.10	100.09	100.09
CHL	U	799216	2000-11-20	100.10	100.09	100.09
CHL	U	799217	2000-11-20	100.10	100.09	100.09
CHL	U	799218	2000-11-20	100.10	100.09	100.09
CHL	U	799219	2000-11-20	100.10	100.09	100.09
CHL	U	799220	2000-11-20	100.10	100.09	100.09
CHL	U	799221	2000-11-20	100.10	100.09	100.09
CHL	U	799222	2000-11-20	100.10	100.09	100.09
CHL	U	799223	2000-11-20	100.10	100.09	100.09
CHL	U	799224	2000-11-20	100.10	100.09	100.09
CHL	U	799225	2000-11-20	100.10	100.09	100.09
CHL	U	799226	2000-11-20	100.10	100.09	100.09
CHL	U	799227	2000-11-20	100.10	100.09	100.09
CHL	U	799228	2000-11-20	100.10	100.09	100.09
CHL	U	799229	2000-11-20	100.10	100.09	100.09
CHL	U	799230	2000-11-20	100.10	100.09	100.09

C1MS90A

LOUISVILLE GAS & ELECTRIC COMPANY
METER 205127EM (0851)
NEW METERS ADDED LAST YEAR

01/14/2003
PAGE: 362

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PF FACTOR
CHEMUR	01	799230	2002-11-11	100.10	100.42	100.02
CHEMUR	01	799231	2002-11-11	100.09	100.49	100.00
CHEMUR	01	799232	2002-11-11	100.12	100.09	100.05
CHEMUR	01	799233	2002-11-11	100.14	100.14	100.06
CHEMUR	01	799234	2002-11-11	100.09	100.14	100.12
CHEMUR	01	799235	2002-11-11	100.03	100.14	100.01
CHEMUR	01	799236	2002-11-11	100.03	100.09	100.07
CHEMUR	01	799237	2002-11-11	100.11	100.09	100.11
CHEMUR	01	799238	2002-11-11	100.10	100.11	100.09
CHEMUR	01	799239	2002-11-11	100.10	100.11	100.08
CHEMUR	01	799240	2002-11-11	100.10	100.11	100.08
CHEMUR	01	799241	2002-11-11	100.10	100.11	100.08
CHEMUR	01	799242	2002-11-11	100.10	100.11	100.08
CHEMUR	01	799243	2002-11-11	100.10	100.11	100.08
CHEMUR	01	799244	2002-11-11	100.10	100.11	100.08
CHEMUR	01	799245	2002-11-11	100.10	100.11	100.08
CHEMUR	01	799246	2002-11-11	100.10	100.11	100.08
CHEMUR	01	799247	2002-11-11	100.10	100.11	100.08
CHEMUR	01	799248	2002-11-11	100.10	100.11	100.08
CHEMUR	01	799249	2002-11-11	100.10	100.11	100.08
CHEMUR	01	799250	2002-11-11	100.10	100.11	100.08
CHEMUR	01	799251	2002-11-11	100.10	100.11	100.08
CHEMUR	01	799252	2002-11-11	100.10	100.11	100.08
CHEMUR	01	799253	2002-11-11	100.10	100.11	100.08
CHEMUR	01	799254	2002-11-11	100.10	100.11	100.08
CHEMUR	01	799255	2002-11-11	100.10	100.11	100.08
CHEMUR	01	799256	2002-11-11	100.10	100.11	100.08
CHEMUR	01	799257	2002-11-11	100.10	100.11	100.08
CHEMUR	01	799258	2002-11-11	100.10	100.11	100.08
CHEMUR	01	799259	2002-11-11	100.10	100.11	100.08
CHEMUR	01	799260	2002-11-11	100.10	100.11	100.08
CHEMUR	01	799261	2002-11-11	100.10	100.11	100.08
CHEMUR	01	799262	2002-11-11	100.10	100.11	100.08
CHEMUR	01	799263	2002-11-11	100.10	100.11	100.08
CHEMUR	01	799264	2002-11-11	100.10	100.11	100.08
CHEMUR	01	799265	2002-11-11	100.10	100.11	100.08
CHEMUR	01	799266	2002-11-11	100.10	100.11	100.08
CHEMUR	01	799267	2002-11-11	100.10	100.11	100.08
CHEMUR	01	799268	2002-11-11	100.10	100.11	100.08
CHEMUR	01	799269	2002-11-11	100.10	100.11	100.08
CHEMUR	01	799270	2002-11-11	100.10	100.11	100.08
CHEMUR	01	799271	2002-11-11	100.10	100.11	100.08
CHEMUR	01	799272	2002-11-11	100.10	100.11	100.08
CHEMUR	01	799273	2002-11-11	100.10	100.11	100.08
CHEMUR	01	799274	2002-11-11	100.10	100.11	100.08
CHEMUR	01	799275	2002-11-11	100.10	100.11	100.08
CHEMUR	01	799276	2002-11-11	100.10	100.11	100.08
CHEMUR	01	799277	2002-11-11	100.10	100.11	100.08
CHEMUR	01	799278	2002-11-11	100.10	100.11	100.08
CHEMUR	01	799279	2002-11-11	100.10	100.11	100.08

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PF FACTOR
CHL	01	7993380	20021120	100.11	100.08	100.08
CHL	01	7993381	20021120	100.11	100.08	100.08
CHL	01	7993382	20021120	100.11	100.08	100.08
CHL	01	7993383	20021120	100.11	100.08	100.08
CHL	01	7993384	20021120	100.11	100.08	100.08
CHL	01	7993385	20021120	100.11	100.08	100.08
CHL	01	7993386	20021120	100.11	100.08	100.08
CHL	01	7993387	20021120	100.11	100.08	100.08
CHL	01	7993388	20021120	100.11	100.08	100.08
CHL	01	7993389	20021120	100.11	100.08	100.08
CHL	01	7993390	20021120	100.11	100.08	100.08
CHL	01	7993391	20021120	100.11	100.08	100.08
CHL	01	7993392	20021120	100.11	100.08	100.08
CHL	01	7993393	20021120	100.11	100.08	100.08
CHL	01	7993394	20021120	100.11	100.08	100.08
CHL	01	7993395	20021120	100.11	100.08	100.08
CHL	01	7993396	20021120	100.11	100.08	100.08
CHL	01	7993397	20021120	100.11	100.08	100.08
CHL	01	7993398	20021120	100.11	100.08	100.08
CHL	01	7993399	20021120	100.11	100.08	100.08
CHL	01	7993400	20021120	100.11	100.08	100.08
CHL	01	7993401	20021120	100.11	100.08	100.08
CHL	01	7993402	20021120	100.11	100.08	100.08
CHL	01	7993403	20021120	100.11	100.08	100.08
CHL	01	7993404	20021120	100.11	100.08	100.08
CHL	01	7993405	20021120	100.11	100.08	100.08
CHL	01	7993406	20021120	100.11	100.08	100.08
CHL	01	7993407	20021120	100.11	100.08	100.08
CHL	01	7993408	20021120	100.11	100.08	100.08
CHL	01	7993409	20021120	100.11	100.08	100.08
CHL	01	7993410	20021120	100.11	100.08	100.08
CHL	01	7993411	20021120	100.11	100.08	100.08
CHL	01	7993412	20021120	100.11	100.08	100.08
CHL	01	7993413	20021120	100.11	100.08	100.08
CHL	01	7993414	20021120	100.11	100.08	100.08
CHL	01	7993415	20021120	100.11	100.08	100.08
CHL	01	7993416	20021120	100.11	100.08	100.08
CHL	01	7993417	20021120	100.11	100.08	100.08
CHL	01	7993418	20021120	100.11	100.08	100.08
CHL	01	7993419	20021120	100.11	100.08	100.08
CHL	01	7993420	20021120	100.11	100.08	100.08
CHL	01	7993421	20021120	100.11	100.08	100.08
CHL	01	7993422	20021120	100.11	100.08	100.08
CHL	01	7993423	20021120	100.11	100.08	100.08
CHL	01	7993424	20021120	100.11	100.08	100.08
CHL	01	7993425	20021120	100.11	100.08	100.08
CHL	01	7993426	20021120	100.11	100.08	100.08
CHL	01	7993427	20021120	100.11	100.08	100.08
CHL	01	7993428	20021120	100.11	100.08	100.08
CHL	01	7993429	20021120	100.11	100.08	100.08
CHL	01	7993430	20021120	100.11	100.08	100.08

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACOR
CHL	01	799431	2002-11-20	100.10	100.14	100.10
CHL	01	799432	2002-11-20	100.10	100.14	100.12
CHL	01	799433	2002-11-20	100.12	100.09	100.02
CHL	01	799434	2002-11-20	100.09	100.09	100.09
CHL	01	799435	2002-11-20	100.09	100.04	100.07
CHL	01	799436	2002-11-20	100.11	100.12	100.04
CHL	01	799437	2002-11-20	100.11	100.08	100.00
CHL	01	799438	2002-11-20	100.08	100.09	100.01
CHL	01	799439	2002-11-20	100.12	100.04	100.09
CHL	01	799440	2002-11-20	100.09	100.13	100.05
CHL	01	799441	2002-11-20	100.09	100.10	100.10
CHL	01	799442	2002-11-20	100.09	100.10	100.10
CHL	01	799443	2002-11-20	100.09	100.07	100.10
CHL	01	799444	2002-11-20	100.10	100.07	100.10
CHL	01	799445	2002-11-20	100.09	100.04	100.00
CHL	01	799446	2002-11-20	100.09	100.04	100.07
CHL	01	799447	2002-11-20	100.09	100.04	100.07
CHL	01	799448	2002-11-20	100.09	100.04	100.07
CHL	01	799449	2002-11-20	100.09	100.04	100.07
CHL	01	799450	2002-11-20	100.09	100.04	100.07
CHL	01	799451	2002-11-20	100.09	100.04	100.07
CHL	01	799452	2002-11-20	100.09	100.04	100.07
CHL	01	799453	2002-11-20	100.09	100.04	100.07
CHL	01	799454	2002-11-20	100.09	100.04	100.07
CHL	01	799455	2002-11-20	100.09	100.04	100.07
CHL	01	799456	2002-11-20	100.09	100.04	100.07
CHL	01	799457	2002-11-20	100.09	100.04	100.07
CHL	01	799458	2002-11-20	100.09	100.04	100.07
CHL	01	799459	2002-11-20	100.09	100.04	100.07
CHL	01	799460	2002-11-20	100.09	100.04	100.07
CHL	01	799461	2002-11-20	100.09	100.04	100.07
CHL	01	799462	2002-11-20	100.09	100.04	100.07
CHL	01	799463	2002-11-20	100.09	100.04	100.07
CHL	01	799464	2002-11-20	100.09	100.04	100.07
CHL	01	799465	2002-11-20	100.09	100.04	100.07
CHL	01	799466	2002-11-20	100.09	100.04	100.07
CHL	01	799467	2002-11-20	100.09	100.04	100.07
CHL	01	799468	2002-11-20	100.09	100.04	100.07
CHL	01	799469	2002-11-20	100.09	100.04	100.07
CHL	01	799470	2002-11-20	100.09	100.04	100.07
CHL	01	799471	2002-11-20	100.09	100.04	100.07
CHL	01	799472	2002-11-20	100.09	100.04	100.07
CHL	01	799473	2002-11-20	100.09	100.04	100.07
CHL	01	799474	2002-11-20	100.09	100.04	100.07
CHL	01	799475	2002-11-20	100.09	100.04	100.07
CHL	01	799476	2002-11-20	100.09	100.04	100.07
CHL	01	799477	2002-11-20	100.09	100.04	100.07
CHL	01	799478	2002-11-20	100.09	100.04	100.07
CHL	01	799479	2002-11-20	100.09	100.04	100.07

C126960A

LOUISVILLE GAS & ELECTRIC COMPANY
METER SUBSYSTEM (MS)
NEW METERS ADDED LAST YEAR

01/14/2003
PAGE: 368

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PF FACTOR
UL	U	799530	0002	100.12	100.07	100.12
UL	U	799531	0002	100.11	100.07	100.09
UL	U	799532	0002	100.11	100.07	100.12
UL	U	799533	0002	100.11	100.07	100.12
UL	U	799534	0002	100.10	100.07	100.12
UL	U	799535	0002	100.10	100.07	100.12
UL	U	799536	0002	100.10	100.07	100.12
UL	U	799537	0002	100.10	100.07	100.12
UL	U	799538	0002	100.10	100.07	100.12
UL	U	799539	0002	100.10	100.07	100.12
UL	U	799540	0002	100.10	100.07	100.12
UL	U	799541	0002	100.10	100.07	100.12
UL	U	799542	0002	100.10	100.07	100.12
UL	U	799543	0002	100.10	100.07	100.12
UL	U	799544	0002	100.10	100.07	100.12
UL	U	799545	0002	100.10	100.07	100.12
UL	U	799546	0002	100.10	100.07	100.12
UL	U	799547	0002	100.10	100.07	100.12
UL	U	799548	0002	100.10	100.07	100.12
UL	U	799549	0002	100.10	100.07	100.12
UL	U	799550	0002	100.10	100.07	100.12
UL	U	799551	0002	100.10	100.07	100.12
UL	U	799552	0002	100.10	100.07	100.12
UL	U	799553	0002	100.10	100.07	100.12
UL	U	799554	0002	100.10	100.07	100.12
UL	U	799555	0002	100.10	100.07	100.12
UL	U	799556	0002	100.10	100.07	100.12
UL	U	799557	0002	100.10	100.07	100.12
UL	U	799558	0002	100.10	100.07	100.12
UL	U	799559	0002	100.10	100.07	100.12
UL	U	799560	0002	100.10	100.07	100.12
UL	U	799561	0002	100.10	100.07	100.12
UL	U	799562	0002	100.10	100.07	100.12
UL	U	799563	0002	100.10	100.07	100.12
UL	U	799564	0002	100.10	100.07	100.12
UL	U	799565	0002	100.10	100.07	100.12
UL	U	799566	0002	100.10	100.07	100.12
UL	U	799567	0002	100.10	100.07	100.12
UL	U	799568	0002	100.10	100.07	100.12
UL	U	799569	0002	100.10	100.07	100.12
UL	U	799570	0002	100.10	100.07	100.12
UL	U	799571	0002	100.10	100.07	100.12
UL	U	799572	0002	100.10	100.07	100.12
UL	U	799573	0002	100.10	100.07	100.12
UL	U	799574	0002	100.10	100.07	100.12
UL	U	799575	0002	100.10	100.07	100.12
UL	U	799576	0002	100.10	100.07	100.12
UL	U	799577	0002	100.10	100.07	100.12
UL	U	799578	0002	100.10	100.07	100.12
UL	U	799579	0002	100.10	100.07	100.12

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PF FACTOR
SCHLUMBERGER	01	7994331	2000-11-11	106.08	109.07	100.07
SCHLUMBERGER	01	7994332	2000-11-11	106.10	109.07	100.07
SCHLUMBERGER	01	7994333	2000-11-11	106.08	109.07	100.07
SCHLUMBERGER	01	7994334	2000-11-11	106.09	109.07	100.07
SCHLUMBERGER	01	7994335	2000-11-11	106.10	109.07	100.07
SCHLUMBERGER	01	7994336	2000-11-11	106.10	109.07	100.07
SCHLUMBERGER	01	7994337	2000-11-11	106.10	109.07	100.07
SCHLUMBERGER	01	7994338	2000-11-11	106.10	109.07	100.07
SCHLUMBERGER	01	7994339	2000-11-11	106.10	109.07	100.07
SCHLUMBERGER	01	7994340	2000-11-11	106.10	109.07	100.07
SCHLUMBERGER	01	7994341	2000-11-11	106.10	109.07	100.07
SCHLUMBERGER	01	7994342	2000-11-11	106.10	109.07	100.07
SCHLUMBERGER	01	7994343	2000-11-11	106.10	109.07	100.07
SCHLUMBERGER	01	7994344	2000-11-11	106.10	109.07	100.07
SCHLUMBERGER	01	7994345	2000-11-11	106.10	109.07	100.07
SCHLUMBERGER	01	7994346	2000-11-11	106.10	109.07	100.07
SCHLUMBERGER	01	7994347	2000-11-11	106.10	109.07	100.07
SCHLUMBERGER	01	7994348	2000-11-11	106.10	109.07	100.07
SCHLUMBERGER	01	7994349	2000-11-11	106.10	109.07	100.07
SCHLUMBERGER	01	7994350	2000-11-11	106.10	109.07	100.07
SCHLUMBERGER	01	7994351	2000-11-11	106.10	109.07	100.07
SCHLUMBERGER	01	7994352	2000-11-11	106.10	109.07	100.07
SCHLUMBERGER	01	7994353	2000-11-11	106.10	109.07	100.07
SCHLUMBERGER	01	7994354	2000-11-11	106.10	109.07	100.07
SCHLUMBERGER	01	7994355	2000-11-11	106.10	109.07	100.07
SCHLUMBERGER	01	7994356	2000-11-11	106.10	109.07	100.07
SCHLUMBERGER	01	7994357	2000-11-11	106.10	109.07	100.07
SCHLUMBERGER	01	7994358	2000-11-11	106.10	109.07	100.07
SCHLUMBERGER	01	7994359	2000-11-11	106.10	109.07	100.07
SCHLUMBERGER	01	7994360	2000-11-11	106.10	109.07	100.07
SCHLUMBERGER	01	7994361	2000-11-11	106.10	109.07	100.07
SCHLUMBERGER	01	7994362	2000-11-11	106.10	109.07	100.07
SCHLUMBERGER	01	7994363	2000-11-11	106.10	109.07	100.07
SCHLUMBERGER	01	7994364	2000-11-11	106.10	109.07	100.07
SCHLUMBERGER	01	7994365	2000-11-11	106.10	109.07	100.07
SCHLUMBERGER	01	7994366	2000-11-11	106.10	109.07	100.07
SCHLUMBERGER	01	7994367	2000-11-11	106.10	109.07	100.07
SCHLUMBERGER	01	7994368	2000-11-11	106.10	109.07	100.07
SCHLUMBERGER	01	7994369	2000-11-11	106.10	109.07	100.07
SCHLUMBERGER	01	7994370	2000-11-11	106.10	109.07	100.07
SCHLUMBERGER	01	7994371	2000-11-11	106.10	109.07	100.07
SCHLUMBERGER	01	7994372	2000-11-11	106.10	109.07	100.07
SCHLUMBERGER	01	7994373	2000-11-11	106.10	109.07	100.07
SCHLUMBERGER	01	7994374	2000-11-11	106.10	109.07	100.07
SCHLUMBERGER	01	7994375	2000-11-11	106.10	109.07	100.07
SCHLUMBERGER	01	7994376	2000-11-11	106.10	109.07	100.07
SCHLUMBERGER	01	7994377	2000-11-11	106.10	109.07	100.07
SCHLUMBERGER	01	7994378	2000-11-11	106.10	109.07	100.07
SCHLUMBERGER	01	7994379	2000-11-11	106.10	109.07	100.07

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACOR
UCC	004	7997229	2002-11-11	100.09	100.13	100.07
UCC	004	7997230	2002-11-11	100.09	100.13	100.07
UCC	004	7997231	2002-11-11	100.09	100.13	100.07
UCC	004	7997232	2002-11-11	100.09	100.13	100.07
UCC	004	7997233	2002-11-11	100.09	100.13	100.07
UCC	004	7997234	2002-11-11	100.09	100.13	100.07
UCC	004	7997235	2002-11-11	100.09	100.13	100.07
UCC	004	7997236	2002-11-11	100.09	100.13	100.07
UCC	004	7997237	2002-11-11	100.09	100.13	100.07
UCC	004	7997238	2002-11-11	100.09	100.13	100.07
UCC	004	7997239	2002-11-11	100.09	100.13	100.07
UCC	004	7997240	2002-11-11	100.09	100.13	100.07
UCC	004	7997241	2002-11-11	100.09	100.13	100.07
UCC	004	7997242	2002-11-11	100.09	100.13	100.07
UCC	004	7997243	2002-11-11	100.09	100.13	100.07
UCC	004	7997244	2002-11-11	100.09	100.13	100.07
UCC	004	7997245	2002-11-11	100.09	100.13	100.07
UCC	004	7997246	2002-11-11	100.09	100.13	100.07
UCC	004	7997247	2002-11-11	100.09	100.13	100.07
UCC	004	7997248	2002-11-11	100.09	100.13	100.07
UCC	004	7997249	2002-11-11	100.09	100.13	100.07
UCC	004	7997250	2002-11-11	100.09	100.13	100.07
UCC	004	7997251	2002-11-11	100.09	100.13	100.07
UCC	004	7997252	2002-11-11	100.09	100.13	100.07
UCC	004	7997253	2002-11-11	100.09	100.13	100.07
UCC	004	7997254	2002-11-11	100.09	100.13	100.07
UCC	004	7997255	2002-11-11	100.09	100.13	100.07
UCC	004	7997256	2002-11-11	100.09	100.13	100.07
UCC	004	7997257	2002-11-11	100.09	100.13	100.07
UCC	004	7997258	2002-11-11	100.09	100.13	100.07
UCC	004	7997259	2002-11-11	100.09	100.13	100.07
UCC	004	7997260	2002-11-11	100.09	100.13	100.07
UCC	004	7997261	2002-11-11	100.09	100.13	100.07
UCC	004	7997262	2002-11-11	100.09	100.13	100.07
UCC	004	7997263	2002-11-11	100.09	100.13	100.07
UCC	004	7997264	2002-11-11	100.09	100.13	100.07
UCC	004	7997265	2002-11-11	100.09	100.13	100.07
UCC	004	7997266	2002-11-11	100.09	100.13	100.07
UCC	004	7997267	2002-11-11	100.09	100.13	100.07
UCC	004	7997268	2002-11-11	100.09	100.13	100.07
UCC	004	7997269	2002-11-11	100.09	100.13	100.07
UCC	004	7997270	2002-11-11	100.09	100.13	100.07
UCC	004	7997271	2002-11-11	100.09	100.13	100.07
UCC	004	7997272	2002-11-11	100.09	100.13	100.07
UCC	004	7997273	2002-11-11	100.09	100.13	100.07
UCC	004	7997274	2002-11-11	100.09	100.13	100.07
UCC	004	7997275	2002-11-11	100.09	100.13	100.07
UCC	004	7997276	2002-11-11	100.09	100.13	100.07
UCC	004	7997277	2002-11-11	100.09	100.13	100.07
UCC	004	7997278	2002-11-11	100.09	100.13	100.07
UCC	004	7997279	2002-11-11	100.09	100.13	100.07
UCC	004	7997280	2002-11-11	100.09	100.13	100.07
UCC	004	7997281	2002-11-11	100.09	100.13	100.07
UCC	004	7997282	2002-11-11	100.09	100.13	100.07
UCC	004	7997283	2002-11-11	100.09	100.13	100.07
UCC	004	7997284	2002-11-11	100.09	100.13	100.07
UCC	004	7997285	2002-11-11	100.09	100.13	100.07
UCC	004	7997286	2002-11-11	100.09	100.13	100.07
UCC	004	7997287	2002-11-11	100.09	100.13	100.07
UCC	004	7997288	2002-11-11	100.09	100.13	100.07
UCC	004	7997289	2002-11-11	100.09	100.13	100.07
UCC	004	7997290	2002-11-11	100.09	100.13	100.07
UCC	004	7997291	2002-11-11	100.09	100.13	100.07
UCC	004	7997292	2002-11-11	100.09	100.13	100.07
UCC	004	7997293	2002-11-11	100.09	100.13	100.07
UCC	004	7997294	2002-11-11	100.09	100.13	100.07
UCC	004	7997295	2002-11-11	100.09	100.13	100.07
UCC	004	7997296	2002-11-11	100.09	100.13	100.07
UCC	004	7997297	2002-11-11	100.09	100.13	100.07
UCC	004	7997298	2002-11-11	100.09	100.13	100.07
UCC	004	7997299	2002-11-11	100.09	100.13	100.07
UCC	004	7997300	2002-11-11	100.09	100.13	100.07

CIMS960A

LOUISVILLE GAS & ELECTRIC COMPANY
METER SUBSYSTEM (MSS)
NEW METERS ADDED LAST YEAR

01/14/2003
PAGE: 372

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACOR
SCHLUMBERGER	01	799730	2002-13-20	100.12	102.08	100.12
SCHLUMBERGER	01	799731	2002-13-20	100.11	103.12	100.12
TOTAL NEW METERS		18552				

RECEIVED

MAR 03 2003

PUBLIC SERVICE
COMMISSION

Attachment A

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

PAGE 1
 RUN DATE: 1/14/03
 RUN TIME: 13.26.53

RECEIVED

MAR 03 2003

PUBLIC SERVICE
 COMMISSION

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	C1S	C386424	03-19-02	99.9	99.9	100.0
SCHLUMBERGER	C1S	C386425	03-19-02	100.0	100.0	100.0
SCHLUMBERGER	C1S	C386426	03-19-02	99.9	100.0	100.0
SCHLUMBERGER	C1S	C386427	03-19-02	99.9	99.9	99.9
SCHLUMBERGER	C1S	C386428	03-19-02	99.9	100.0	100.0
SCHLUMBERGER	C1S	C386429	03-19-02	100.0	100.0	100.0
SCHLUMBERGER	C1S	C386430	03-19-02	99.9	100.3	100.0
SCHLUMBERGER	C1S	C386431	03-19-02	99.9	100.0	100.0
SCHLUMBERGER	C1S	C386432	03-19-02	99.9	100.0	100.0
SCHLUMBERGER	C1S	C386433	03-19-02	100.0	100.0	100.0
SCHLUMBERGER	C1S	C386434	03-19-02	99.9	100.0	100.0
SCHLUMBERGER	C1S	C386435	03-19-02	99.9	100.1	100.0
SCHLUMBERGER	C1S	C386436	03-19-02	99.9	100.0	100.0
SCHLUMBERGER	C1S	C386437	03-19-02	99.9	100.0	99.9
SCHLUMBERGER	C1S	C386438	03-19-02	100.0	99.9	100.0
SCHLUMBERGER	C1S	C386439	03-19-02	99.9	100.0	100.0
SCHLUMBERGER	C1S	C386440	03-19-02	99.9	99.9	100.0
SCHLUMBERGER	C1S	C386441	03-19-02	100.0	100.0	100.0
SCHLUMBERGER	C1S	C386442	03-19-02	100.0	100.0	100.0
SCHLUMBERGER	C1S	C386443	03-19-02	99.9	100.0	100.0
SCHLUMBERGER	C1S	C386444	03-19-02	100.0	100.0	100.0
SCHLUMBERGER	C1S	C386445	03-19-02	100.0	100.0	100.0
SCHLUMBERGER	C1S	C386446	03-19-02	100.0	100.0	99.9
SCHLUMBERGER	C1S	C386447	03-19-02	99.9	100.0	100.1
SCHLUMBERGER	C1S	C386448	03-19-02	99.9	99.9	99.9
SCHLUMBERGER	C1S	C386449	03-19-02	99.9	99.9	100.0
SCHLUMBERGER	C1S	C386450	03-19-02	99.9	100.0	100.0
SCHLUMBERGER	C1S	C386451	03-19-02	99.9	100.0	100.0
SCHLUMBERGER	C1S	C386452	03-19-02	100.0	100.0	100.0
SCHLUMBERGER	C1S	C386453	03-19-02	100.0	100.0	100.0
SCHLUMBERGER	C1S	C386454	03-19-02	100.0	100.0	100.0
SCHLUMBERGER	C1S	C386455	03-19-02	99.9	99.9	99.9
SCHLUMBERGER	C1S	C386456	03-19-02	100.0	99.9	100.0
SCHLUMBERGER	C1S	C386457	03-19-02	99.9	99.9	100.0
SCHLUMBERGER	C1S	C386458	03-19-02	99.9	100.0	99.9
SCHLUMBERGER	C1S	C386459	03-19-02	100.0	99.9	100.0
SCHLUMBERGER	C1S	C386460	03-19-02	100.0	100.1	100.0
SCHLUMBERGER	C1S	C386461	03-19-02	99.9	99.9	100.0
SCHLUMBERGER	C1S	C386462	03-19-02	100.0	99.9	100.0
SCHLUMBERGER	C1S	C386463	03-19-02	99.9	99.9	100.0
SCHLUMBERGER	C1S	C386464	03-19-02	100.0	100.0	100.0
SCHLUMBERGER	C1S	C386465	03-19-02	99.9	99.9	100.0
SCHLUMBERGER	C1S	C386466	03-19-02	100.0	99.9	100.0
SCHLUMBERGER	C1S	C386467	03-19-02	99.9	100.0	100.0
SCHLUMBERGER	C1S	C386468	03-19-02	100.0	100.0	100.0
SCHLUMBERGER	C1S	C386469	03-19-02	100.0	100.0	100.0
SCHLUMBERGER	C1S	C386470	03-19-02	99.9	100.0	100.0
SCHLUMBERGER	C1S	C386471	03-19-02	99.9	99.9	100.0
SCHLUMBERGER	C1S	C407137	12-13-02	100.0	99.9	100.0
SCHLUMBERGER	C1S	C407138	12-13-02	100.0	100.0	100.0
SCHLUMBERGER	C1S	C407139	12-13-02	100.0	99.9	100.0

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

PAGE 2
 RUN DATE: 1/14/03
 RUN TIME: 13.26.53

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	C1S	C407140	12-13-02	99.9	99.9	100.0
SCHLUMBERGER	C1S	C407141	12-13-02	100.0	99.9	100.0
SCHLUMBERGER	C1S	C407142	12-13-02	99.9	100.0	100.0
SCHLUMBERGER	C1S	C407143	12-13-02	100.0	100.0	100.0
SCHLUMBERGER	C1S	C407144	12-13-02	100.0	100.0	100.0
SCHLUMBERGER	C1S	C407145	12-13-02	100.0	100.1	100.0
SCHLUMBERGER	C1S	C407146	12-13-02	100.0	100.0	100.0
SCHLUMBERGER	C1S	C407147	12-13-02	100.0	100.0	100.0
SCHLUMBERGER	C1S	C407148	12-13-02	100.0	100.0	100.0
SCHLUMBERGER	C1S	C407149	12-13-02	100.0	100.0	100.0
SCHLUMBERGER	C1S	C407150	12-13-02	99.9	100.0	99.9
SCHLUMBERGER	C1S	C407151	12-13-02	99.9	100.0	100.0
SCHLUMBERGER	C1S	C407152	12-13-02	100.0	100.0	99.9
SCHLUMBERGER	C1S	C407153	12-13-02	99.9	99.9	99.9
SCHLUMBERGER	C1S	C407154	12-13-02	100.0	100.0	100.0
SCHLUMBERGER	C1S	C407155	12-13-02	100.0	100.0	100.0
SCHLUMBERGER	C1S	C407156	12-13-02	99.9	100.0	99.9
SCHLUMBERGER	C1S	C407157	12-13-02	100.0	100.0	100.0
SCHLUMBERGER	C1S	C407158	12-13-02	100.0	100.0	100.0
SCHLUMBERGER	C1S	C407159	12-13-02	100.0	100.1	100.0
SCHLUMBERGER	C1S	C407160	12-13-02	100.0	99.9	100.0
SCHLUMBERGER	C1S	C407161	12-13-02	99.9	99.9	100.0
SCHLUMBERGER	C1S	C407162	12-13-02	100.0	100.0	100.0
SCHLUMBERGER	C1S	C407163	12-13-02	100.0	99.9	100.0
SCHLUMBERGER	C1S	C407164	12-13-02	99.9	100.0	100.0
SCHLUMBERGER	C1S	C407165	12-13-02	100.0	100.0	100.0
SCHLUMBERGER	C1S	C407166	12-13-02	100.0	100.0	100.0
SCHLUMBERGER	C1S	C407167	12-13-02	99.9	99.9	100.0
SCHLUMBERGER	C1S	C407168	12-13-02	100.0	100.0	100.0
SCHLUMBERGER	C1S	C407169	12-13-02	100.0	100.0	100.0
SCHLUMBERGER	C1S	C407170	12-13-02	100.0	99.9	100.0
SCHLUMBERGER	C1S	C407171	12-13-02	99.9	100.0	100.0
SCHLUMBERGER	C1S	C407172	12-13-02	99.9	100.0	100.0
SCHLUMBERGER	C1S	C407173	12-13-02	100.0	100.0	100.0
SCHLUMBERGER	C1S	C407174	12-13-02	100.0	100.0	100.0
SCHLUMBERGER	C1S	C407175	12-13-02	99.9	100.0	100.0
SCHLUMBERGER	C1S	C407176	12-13-02	100.0	100.0	100.0
SCHLUMBERGER	C1S	C407177	12-13-02	100.0	100.0	100.0
SCHLUMBERGER	C1S	C407178	12-13-02	99.9	100.0	100.0
SCHLUMBERGER	C1S	C407179	12-13-02	100.0	100.0	100.0
SCHLUMBERGER	C1S	C407180	12-13-02	100.0	99.9	100.0
SCHLUMBERGER	C1S	C407181	12-13-02	100.0	100.0	100.0
SCHLUMBERGER	C1S	C407182	12-13-02	99.9	100.0	100.0
SCHLUMBERGER	C1S	C407183	12-13-02	99.9	100.1	99.9
SCHLUMBERGER	C1S	C407184	12-13-02	100.0	100.0	100.0
SCHLUMBERGER	C1S	C407185	12-13-02	100.0	99.9	100.0
SCHLUMBERGER	C1S	C407186	12-13-02	99.9	99.9	100.0
SCHLUMBERGER	C1S	C407187	12-13-02	100.0	99.9	100.0
SCHLUMBERGER	C1S	C407188	12-13-02	100.0	99.9	100.0
SCHLUMBERGER	C1S	C407189	12-13-02	100.0	100.0	100.0
SCHLUMBERGER	C1S	C407190	12-13-02	100.0	99.9	100.0

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	C1S	C407191	12-13-02	100.0	99.9	100.0
SCHLUMBERGER	C1S	C407192	12-13-02	100.0	100.0	100.0
SCHLUMBERGER	C1S	C407193	12-13-02	100.0	100.0	100.0
SCHLUMBERGER	C1S	C407194	12-13-02	100.0	100.0	100.0
SCHLUMBERGER	C1S	C407195	12-13-02	99.9	99.9	100.0
SCHLUMBERGER	C1S	C407196	12-13-02	100.0	100.0	100.0
SCHLUMBERGER	C1S	C407197	12-13-02	99.9	100.0	100.0
SCHLUMBERGER	C1S	C407198	12-13-02	100.0	100.1	100.0
SCHLUMBERGER	C1S	C407199	12-13-02	99.9	99.9	99.9
SCHLUMBERGER	C1S	C407200	12-13-02	100.0	100.0	100.0
SCHLUMBERGER	C1S	C407201	12-13-02	100.0	100.0	100.0
SCHLUMBERGER	C1S	C407202	12-13-02	99.9	99.9	100.0
SCHLUMBERGER	C1S	C407203	12-13-02	99.9	100.0	100.0
SCHLUMBERGER	C1S	C407204	12-13-02	99.9	99.9	100.0
SCHLUMBERGER	C1S	C407205	12-13-02	99.9	100.0	100.0
SCHLUMBERGER	C1S	C407206	12-13-02	100.0	100.0	100.0
SCHLUMBERGER	C1S	C407207	12-13-02	99.9	100.0	100.0
SCHLUMBERGER	C1S	C407208	12-13-02	99.9	99.9	100.0
SCHLUMBERGER	C1S	C407209	12-13-02	100.0	100.0	100.0
SCHLUMBERGER	C1S	C407210	12-13-02	100.0	100.0	100.0
SCHLUMBERGER	C1S	C407211	12-13-02	99.9	100.0	100.0
SCHLUMBERGER	C1S	C407212	12-13-02	100.0	100.0	100.1
SCHLUMBERGER	C1S	C407213	12-13-02	100.0	100.0	100.1
SCHLUMBERGER	C1S	C407214	12-13-02	100.0	99.9	100.0
SCHLUMBERGER	C1S	C407215	12-13-02	100.0	100.0	100.0
SCHLUMBERGER	C1S	C407216	12-13-02	99.9	100.1	100.0
SCHLUMBERGER	C1S	C407217	12-13-02	99.9	100.0	100.0
SCHLUMBERGER	C1S	C407218	12-13-02	99.9	99.9	100.0
SCHLUMBERGER	C1S	C407219	12-13-02	100.0	100.1	100.1
SCHLUMBERGER	C1S	C407220	12-13-02	100.0	99.9	100.0
SCHLUMBERGER	C1S	C407221	12-13-02	100.0	100.1	100.0
SCHLUMBERGER	C1S	C407222	12-13-02	99.9	100.0	100.0
SCHLUMBERGER	C1S	C407223	12-13-02	99.9	99.9	100.0
SCHLUMBERGER	C1S	C407224	12-13-02	99.9	99.9	100.0
SCHLUMBERGER	C1S	C407225	12-13-02	100.0	100.0	100.0
SCHLUMBERGER	C1S	C407226	12-13-02	100.0	99.9	100.0
SCHLUMBERGER	C1S	C407227	12-13-02	99.9	100.0	100.0
SCHLUMBERGER	C1S	C407228	12-13-02	100.0	100.0	100.0
SCHLUMBERGER	C1S	C407229	12-13-02	99.9	100.0	100.0
SCHLUMBERGER	C1S	C407230	12-13-02	100.0	100.1	100.0
SCHLUMBERGER	C1S	C407231	12-13-02	100.0	100.0	100.0
SCHLUMBERGER	C1S	C407232	12-13-02	100.0	100.0	100.0
SCHLUMBERGER	C1S	C407233	12-13-02	99.9	100.0	100.0
SCHLUMBERGER	C1S	C407234	12-13-02	100.0	100.0	100.0
SCHLUMBERGER	C1S	C407235	12-13-02	100.0	100.0	100.0
SCHLUMBERGER	C1S	C407236	12-13-02	99.9	100.0	99.9

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

PAGE 4
 RUN DATE: 1/14/03
 RUN TIME: 13.26.53

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	J5S	C383484	02-07-02	100.1	99.9	100.1
SCHLUMBERGER	J5S	C383485	02-07-02	100.1	99.9	100.0
SCHLUMBERGER	J5S	C383486	02-07-02	100.1	100.2	100.0
SCHLUMBERGER	J5S	C383487	02-07-02	100.1	100.0	99.9
SCHLUMBERGER	J5S	C383488	02-07-02	100.0	99.9	99.8
SCHLUMBERGER	J5S	C383489	02-07-02	100.2	100.2	99.9
SCHLUMBERGER	J5S	C383490	02-07-02	100.1	100.2	100.2
SCHLUMBERGER	J5S	C383491	02-07-02	100.0	99.9	100.0
SCHLUMBERGER	J5S	C383492	02-07-02	100.1	100.1	99.6
SCHLUMBERGER	J5S	C383493	02-07-02	100.1	100.1	100.0
SCHLUMBERGER	J5S	C383494	02-07-02	100.1	100.1	99.8
SCHLUMBERGER	J5S	C383495	02-07-02	100.2	100.2	100.0
SCHLUMBERGER	J5S	C383496	02-07-02	100.3	100.1	99.8
SCHLUMBERGER	J5S	C383497	02-07-02	100.0	100.0	99.8
SCHLUMBERGER	J5S	C383498	02-07-02	99.9	99.6	99.6
SCHLUMBERGER	J5S	C383499	02-07-02	100.1	100.1	100.0
SCHLUMBERGER	J5S	C383500	02-07-02	100.1	99.7	99.8
SCHLUMBERGER	J5S	C383501	02-07-02	100.1	100.1	100.1
SCHLUMBERGER	J5S	C383502	02-07-02	100.0	99.8	100.0
SCHLUMBERGER	J5S	C383503	02-07-02	99.8	99.7	99.4
SCHLUMBERGER	J5S	C383504	02-07-02	100.1	100.0	99.8
SCHLUMBERGER	J5S	C383505	02-07-02	100.0	99.7	99.9
SCHLUMBERGER	J5S	C383506	02-07-02	100.1	99.9	100.2
SCHLUMBERGER	J5S	C383507	02-07-02	100.1	99.9	99.9
SCHLUMBERGER	J5S	C383508	02-07-02	100.1	99.9	99.8
SCHLUMBERGER	J5S	C383509	02-07-02	99.9	99.9	99.9
SCHLUMBERGER	J5S	C383510	02-07-02	100.1	100.0	99.9
SCHLUMBERGER	J5S	C383511	02-07-02	100.1	100.1	100.3
SCHLUMBERGER	J5S	C383512	02-07-02	100.3	100.5	99.3
SCHLUMBERGER	J5S	C383513	02-07-02	100.1	100.2	100.4
SCHLUMBERGER	J5S	C383514	02-07-02	100.2	99.7	100.1
SCHLUMBERGER	J5S	C383515	02-07-02	100.0	99.7	99.7
SCHLUMBERGER	J5S	C383516	02-07-02	99.9	100.1	99.6
SCHLUMBERGER	J5S	C383517	02-07-02	99.9	100.1	99.6
SCHLUMBERGER	J5S	C383518	02-07-02	100.2	100.5	100.2
SCHLUMBERGER	J5S	C383519	02-07-02	100.0	99.7	100.0
SCHLUMBERGER	J5S	C383520	02-07-02	100.0	100.0	100.0
SCHLUMBERGER	J5S	C383521	02-07-02	100.1	99.8	100.2
SCHLUMBERGER	J5S	C383522	02-07-02	99.9	99.7	99.9
SCHLUMBERGER	J5S	C383523	02-07-02	100.0	99.8	99.7
SCHLUMBERGER	J5S	C383524	02-07-02	100.2	99.9	99.9
SCHLUMBERGER	J5S	C383525	02-07-02	99.9	100.2	99.8
SCHLUMBERGER	J5S	C383526	02-07-02	100.0	100.0	99.8
SCHLUMBERGER	J5S	C383527	02-07-02	99.8	99.8	99.9
SCHLUMBERGER	J5S	C383528	02-07-02	100.2	100.0	99.9
SCHLUMBERGER	J5S	C383529	02-07-02	99.9	99.7	99.8
SCHLUMBERGER	J5S	C383530	02-07-02	100.0	100.0	99.8
SCHLUMBERGER	J5S	C383531	02-07-02	100.2	100.0	100.0
SCHLUMBERGER	J5S	C383532	02-07-02	100.0	99.7	99.7
SCHLUMBERGER	J5S	C383533	02-07-02	99.9	99.9	99.9
SCHLUMBERGER	J5S	C383534	02-07-02	100.0	99.9	99.8

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

PAGE 5
 RUN DATE: 1/14/03
 RUN TIME: 13.26.53

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	J5S	C383535	02-07-02	100.1	100.0	99.9
SCHLUMBERGER	J5S	C383536	02-07-02	100.0	99.7	99.7
SCHLUMBERGER	J5S	C383537	02-07-02	99.9	99.9	99.8
SCHLUMBERGER	J5S	C383538	02-07-02	100.0	100.0	100.0
SCHLUMBERGER	J5S	C383539	02-07-02	99.9	100.1	99.8
SCHLUMBERGER	J5S	C383540	02-07-02	99.9	100.1	100.0
SCHLUMBERGER	J5S	C383541	02-07-02	100.1	99.9	100.2
SCHLUMBERGER	J5S	C383542	02-07-02	100.0	99.8	99.8
SCHLUMBERGER	J5S	C383543	02-07-02	99.9	99.6	99.6
SCHLUMBERGER	J5S	C383544	02-07-02	100.3	100.2	100.3
SCHLUMBERGER	J5S	C383545	02-07-02	100.0	99.9	99.9
SCHLUMBERGER	J5S	C383546	02-07-02	100.3	99.8	100.1
SCHLUMBERGER	J5S	C383547	02-07-02	99.9	100.0	99.8
SCHLUMBERGER	J5S	C383548	02-07-02	100.0	99.9	99.8
SCHLUMBERGER	J5S	C383549	02-07-02	100.0	99.9	99.5
SCHLUMBERGER	J5S	C383550	02-07-02	100.1	99.7	100.2
SCHLUMBERGER	J5S	C383551	02-07-02	99.9	99.8	99.9
SCHLUMBERGER	J5S	C383552	02-07-02	100.0	99.8	99.5
SCHLUMBERGER	J5S	C383553	02-07-02	100.2	100.1	100.2
SCHLUMBERGER	J5S	C383554	02-07-02	99.8	99.9	99.9
SCHLUMBERGER	J5S	C383555	02-07-02	99.9	99.8	100.0
SCHLUMBERGER	J5S	C383556	02-07-02	100.0	99.9	99.9
SCHLUMBERGER	J5S	C383557	02-07-02	100.0	99.7	99.7
SCHLUMBERGER	J5S	C383558	02-07-02	100.2	100.0	100.1
SCHLUMBERGER	J5S	C383559	02-07-02	99.8	99.8	99.9
SCHLUMBERGER	J5S	C383560	02-07-02	100.0	99.9	99.9
SCHLUMBERGER	J5S	C383561	02-07-02	100.1	99.9	100.0
SCHLUMBERGER	J5S	C383562	02-07-02	100.1	100.1	99.9
SCHLUMBERGER	J5S	C383563	02-07-02	100.3	100.1	100.0
SCHLUMBERGER	J5S	C383564	02-07-02	100.2	100.0	99.7
SCHLUMBERGER	J5S	C383565	02-07-02	100.1	100.0	100.0
SCHLUMBERGER	J5S	C383566	02-07-02	100.1	100.2	100.0
SCHLUMBERGER	J5S	C383567	02-07-02	100.1	100.0	100.0
SCHLUMBERGER	J5S	C383568	02-07-02	100.1	100.0	100.0
SCHLUMBERGER	J5S	C383569	02-07-02	100.2	100.1	99.9
SCHLUMBERGER	J5S	C383570	02-07-02	100.2	100.1	100.2
SCHLUMBERGER	J5S	C383571	02-07-02	100.1	99.9	99.8
SCHLUMBERGER	J5S	C383572	02-07-02	100.0	99.8	100.0
SCHLUMBERGER	J5S	C383573	02-07-02	100.1	100.2	100.2
SCHLUMBERGER	J5S	C383574	02-07-02	100.1	99.9	100.1
SCHLUMBERGER	J5S	C383575	02-07-02	100.0	99.9	99.9
SCHLUMBERGER	J5S	C383576	02-07-02	100.2	99.6	100.5
SCHLUMBERGER	J5S	C383577	02-07-02	100.0	99.9	99.9
SCHLUMBERGER	J5S	C383578	02-07-02	100.1	99.8	100.0
SCHLUMBERGER	J5S	C383579	02-07-02	100.0	100.2	100.0
SCHLUMBERGER	J5S	C383580	02-07-02	100.1	99.8	99.7
SCHLUMBERGER	J5S	C383581	02-07-02	100.2	100.1	100.1
SCHLUMBERGER	J5S	C383582	02-07-02	100.2	99.9	99.9
SCHLUMBERGER	J5S	C383583	02-07-02	99.9	99.8	99.8
SCHLUMBERGER	J5S	C383584	02-07-02	100.1	99.7	99.3
SCHLUMBERGER	J5S	C383585	02-07-02	100.0	99.9	99.8

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

PAGE 6
 RUN DATE: 1/14/03
 RUN TIME: 13.26.53

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PF FACTOR
SCHLUMBERGER	J55	C383586	02-07-02	99.8	99.9	99.5
SCHLUMBERGER	J55	C383587	02-07-02	100.0	99.9	99.7
SCHLUMBERGER	J55	C383588	02-07-02	99.8	99.8	99.9
SCHLUMBERGER	J55	C383589	02-07-02	100.0	100.0	99.8
SCHLUMBERGER	J55	C383590	02-07-02	100.1	100.1	100.2
SCHLUMBERGER	J55	C383591	02-07-02	99.9	99.9	99.6
SCHLUMBERGER	J55	C383592	02-07-02	100.0	99.8	99.9
SCHLUMBERGER	J55	C383593	02-07-02	99.9	99.7	100.0
SCHLUMBERGER	J55	C383594	02-07-02	100.1	99.7	99.8
SCHLUMBERGER	J55	C383595	02-07-02	99.8	99.8	100.1
SCHLUMBERGER	J55	C383596	02-07-02	100.1	100.0	99.7
SCHLUMBERGER	J55	C383597	02-07-02	99.8	99.8	99.9
SCHLUMBERGER	J55	C383598	02-07-02	100.3	100.1	100.2
SCHLUMBERGER	J55	C383599	02-07-02	100.0	100.0	100.1
SCHLUMBERGER	J55	C383600	02-07-02	100.0	99.9	100.2
SCHLUMBERGER	J55	C383601	02-07-02	99.9	99.9	99.6
SCHLUMBERGER	J55	C383602	02-07-02	100.1	99.9	100.0
SCHLUMBERGER	J55	C383603	02-07-02	100.1	99.7	100.0
SCHLUMBERGER	J55	C383604	02-07-02	100.2	100.0	100.1
SCHLUMBERGER	J55	C383605	02-07-02	99.9	99.8	99.8
SCHLUMBERGER	J55	C383606	02-07-02	100.1	99.9	99.3
SCHLUMBERGER	J55	C383607	02-07-02	100.0	99.9	100.0
SCHLUMBERGER	J55	C383608	02-07-02	100.2	99.8	100.3
SCHLUMBERGER	J55	C383609	02-07-02	99.9	99.6	99.9
SCHLUMBERGER	J55	C383610	02-07-02	100.1	100.2	100.0
SCHLUMBERGER	J55	C383611	02-07-02	100.0	99.9	99.9
SCHLUMBERGER	J55	C383612	02-07-02	100.1	99.8	100.0
SCHLUMBERGER	J55	C383613	02-07-02	100.0	99.9	99.8
SCHLUMBERGER	J55	C383614	02-07-02	100.0	99.8	99.7
SCHLUMBERGER	J55	C383615	02-07-02	100.1	100.2	100.0
SCHLUMBERGER	J55	C383616	02-07-02	100.0	99.9	99.9
SCHLUMBERGER	J55	C383617	02-07-02	100.1	99.9	99.7
SCHLUMBERGER	J55	C383618	02-07-02	100.0	99.9	99.7
SCHLUMBERGER	J55	C383619	02-07-02	100.0	99.8	99.6
SCHLUMBERGER	J55	C383620	02-07-02	100.0	99.7	99.9
SCHLUMBERGER	J55	C383621	02-07-02	100.1	99.9	100.2
SCHLUMBERGER	J55	C383622	02-07-02	100.1	100.0	100.1
SCHLUMBERGER	J55	C383623	02-07-02	100.2	99.9	100.2
SCHLUMBERGER	J55	C383624	02-07-02	100.0	99.8	100.2
SCHLUMBERGER	J55	C383625	02-07-02	100.0	99.9	99.9
SCHLUMBERGER	J55	C383626	02-07-02	100.0	99.9	99.5
SCHLUMBERGER	J55	C383627	02-07-02	100.1	100.0	100.0
SCHLUMBERGER	J55	C383628	02-07-02	100.1	100.0	99.8
SCHLUMBERGER	J55	C383629	02-07-02	100.2	100.1	100.3
SCHLUMBERGER	J55	C383630	02-07-02	99.8	99.9	99.8
SCHLUMBERGER	J55	C383631	02-07-02	100.1	99.8	99.9
SCHLUMBERGER	J55	C383632	02-07-02	100.0	99.7	99.5
SCHLUMBERGER	J55	C383633	02-07-02	100.0	99.8	99.8
SCHLUMBERGER	J55	C383634	02-07-02	100.1	99.8	99.9
SCHLUMBERGER	J55	C383635	02-07-02	100.0	100.0	100.2
SCHLUMBERGER	J55	C383636	02-07-02	100.3	100.1	100.0

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

MANUFACTURER	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	C383637	02-07-02	100.2	99.9	99.9
SCHLUMBERGER	C383638	02-07-02	100.2	100.3	99.9
SCHLUMBERGER	C383639	02-07-02	100.0	100.0	100.1
SCHLUMBERGER	C383640	02-07-02	99.9	99.9	99.8
SCHLUMBERGER	C383641	02-07-02	100.1	100.0	100.1
SCHLUMBERGER	C383642	02-07-02	100.3	100.1	99.8
SCHLUMBERGER	C383643	02-07-02	99.8	99.6	99.9
SCHLUMBERGER	C383644	02-07-02	100.1	99.9	99.5
SCHLUMBERGER	C383645	02-07-02	100.0	99.7	100.0
SCHLUMBERGER	C383646	02-07-02	99.8	99.6	99.5
SCHLUMBERGER	C383647	02-07-02	100.0	99.9	99.5
SCHLUMBERGER	C383648	02-07-02	100.1	100.0	100.0
SCHLUMBERGER	C383649	02-07-02	100.2	99.8	100.5
SCHLUMBERGER	C383650	02-07-02	99.9	99.7	99.5
SCHLUMBERGER	C383651	02-07-02	100.1	99.8	100.2
SCHLUMBERGER	C383652	02-07-02	99.8	99.9	100.1
SCHLUMBERGER	C383653	02-07-02	100.2	99.9	100.0
SCHLUMBERGER	C383654	02-07-02	100.0	99.8	99.9
SCHLUMBERGER	C383655	02-07-02	99.8	99.8	99.7
SCHLUMBERGER	C383656	02-07-02	100.1	100.0	100.0
SCHLUMBERGER	C383657	02-07-02	100.0	100.0	100.0
SCHLUMBERGER	C383658	02-07-02	100.1	100.0	100.0
SCHLUMBERGER	C383659	02-07-02	99.9	100.1	99.6
SCHLUMBERGER	C383660	02-07-02	99.9	99.6	99.7
SCHLUMBERGER	C383661	02-07-02	100.1	99.9	99.9
SCHLUMBERGER	C383662	02-07-02	100.3	99.9	99.8
SCHLUMBERGER	C383663	02-07-02	100.1	100.1	100.2
SCHLUMBERGER	C383664	02-07-02	100.3	99.9	100.1
SCHLUMBERGER	C383665	02-07-02	100.2	100.1	100.2
SCHLUMBERGER	C383666	02-07-02	100.0	100.1	99.8
SCHLUMBERGER	C383667	02-07-02	99.9	99.8	99.8
SCHLUMBERGER	C383668	02-07-02	100.0	99.8	100.0
SCHLUMBERGER	C383669	02-07-02	100.0	99.9	99.9
SCHLUMBERGER	C383670	02-07-02	100.0	99.8	99.6
SCHLUMBERGER	C383671	02-07-02	100.0	99.9	100.0
SCHLUMBERGER	C383672	02-07-02	99.9	100.0	99.9
SCHLUMBERGER	C383673	02-07-02	99.9	99.9	100.0
SCHLUMBERGER	C383674	02-07-02	99.9	99.8	100.0
SCHLUMBERGER	C383675	02-07-02	99.9	99.8	99.9
SCHLUMBERGER	C383676	02-12-02	100.0	99.8	99.9
SCHLUMBERGER	C383677	02-12-02	100.2	100.0	100.0
SCHLUMBERGER	C383678	02-12-02	100.2	99.9	100.2
SCHLUMBERGER	C383679	02-12-02	100.0	99.9	100.0
SCHLUMBERGER	C383680	02-12-02	99.8	99.7	99.5
SCHLUMBERGER	C383681	02-12-02	100.0	99.8	99.8
SCHLUMBERGER	C383682	02-12-02	99.9	99.7	99.7
SCHLUMBERGER	C383683	02-12-02	100.1	99.9	100.0
SCHLUMBERGER	C383684	02-12-02	100.0	99.8	99.8
SCHLUMBERGER	C383685	02-12-02	100.3	100.3	100.3
SCHLUMBERGER	C383686	02-12-02	100.0	100.3	100.3
SCHLUMBERGER	C383687	02-12-02	100.0	99.9	100.1

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	J55	C383688	02-12-02	99.9	99.8	99.8
SCHLUMBERGER	J55	C383689	02-12-02	100.2	100.2	100.3
SCHLUMBERGER	J55	C383690	02-12-02	100.0	100.1	100.3
SCHLUMBERGER	J55	C383691	02-12-02	99.9	100.0	100.0
SCHLUMBERGER	J55	C383692	02-12-02	100.1	100.1	100.3
SCHLUMBERGER	J55	C383693	02-12-02	100.3	99.9	100.1
SCHLUMBERGER	J55	C383694	02-12-02	100.0	100.0	100.1
SCHLUMBERGER	J55	C383695	02-12-02	100.1	99.9	100.1
SCHLUMBERGER	J55	C383696	02-12-02	99.9	99.9	99.7
SCHLUMBERGER	J55	C383697	02-12-02	100.0	99.8	99.5
SCHLUMBERGER	J55	C383698	02-12-02	100.0	99.7	100.0
SCHLUMBERGER	J55	C383699	02-12-02	99.8	100.2	100.3
SCHLUMBERGER	J55	C383700	02-12-02	100.0	99.9	99.7
SCHLUMBERGER	J55	C383701	02-12-02	100.1	99.6	99.9
SCHLUMBERGER	J55	C383702	02-12-02	100.0	100.2	99.6
SCHLUMBERGER	J55	C383703	02-12-02	100.0	100.0	99.9
SCHLUMBERGER	J55	C383704	02-12-02	99.8	99.7	99.9
SCHLUMBERGER	J55	C383705	02-12-02	99.9	99.6	99.6
SCHLUMBERGER	J55	C383706	02-12-02	99.8	99.8	99.6
SCHLUMBERGER	J55	C383707	02-12-02	100.0	99.8	99.6
SCHLUMBERGER	J55	C383708	02-12-02	100.0	99.8	99.7
SCHLUMBERGER	J55	C383709	02-12-02	100.2	100.3	100.1
SCHLUMBERGER	J55	C383710	02-12-02	100.1	100.0	100.0
SCHLUMBERGER	J55	C383711	02-12-02	100.1	100.0	100.4
SCHLUMBERGER	J55	C383712	02-12-02	99.9	99.8	100.0
SCHLUMBERGER	J55	C383713	02-12-02	100.0	100.1	100.2
SCHLUMBERGER	J55	C383714	02-12-02	99.9	99.9	99.8
SCHLUMBERGER	J55	C383715	02-12-02	99.9	100.0	100.0
SCHLUMBERGER	J55	C383716	02-12-02	100.3	100.1	100.0
SCHLUMBERGER	J55	C383717	02-12-02	99.9	99.7	99.5
SCHLUMBERGER	J55	C383718	02-12-02	100.0	99.9	99.9
SCHLUMBERGER	J55	C383719	02-12-02	99.9	100.1	100.1
SCHLUMBERGER	J55	C383720	02-12-02	100.0	99.9	99.8
SCHLUMBERGER	J55	C383721	02-12-02	100.2	100.2	99.8
SCHLUMBERGER	J55	C383722	02-12-02	100.0	99.6	100.0
SCHLUMBERGER	J55	C383723	02-12-02	100.0	99.8	100.3
SCHLUMBERGER	J55	C383724	02-12-02	99.8	99.8	100.4
SCHLUMBERGER	J55	C383725	02-12-02	100.1	100.3	100.0
SCHLUMBERGER	J55	C383726	02-12-02	100.0	99.9	100.0
SCHLUMBERGER	J55	C383727	02-12-02	100.2	100.1	100.4
SCHLUMBERGER	J55	C383728	02-12-02	100.0	100.0	100.0
SCHLUMBERGER	J55	C383729	02-12-02	99.8	100.1	99.8
SCHLUMBERGER	J55	C383730	02-12-02	100.2	99.9	100.5
SCHLUMBERGER	J55	C383731	02-12-02	100.0	99.8	100.3
SCHLUMBERGER	J55	C383732	02-12-02	100.0	100.1	99.7
SCHLUMBERGER	J55	C383733	02-12-02	100.1	100.0	99.9
SCHLUMBERGER	J55	C383734	02-12-02	100.1	100.4	100.3
SCHLUMBERGER	J55	C383735	02-12-02	100.1	99.8	100.3
SCHLUMBERGER	J55	C383736	02-12-02	100.3	100.1	99.9
SCHLUMBERGER	J55	C383737	02-12-02	99.8	99.8	99.9
SCHLUMBERGER	J55	C383738	02-12-02	100.0	99.9	100.3

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	J55	C383739	02-12-02	100.1	99.9	100.2
SCHLUMBERGER	J55	C383740	02-12-02	100.2	100.0	99.9
SCHLUMBERGER	J55	C383741	02-12-02	100.1	100.1	100.0
SCHLUMBERGER	J55	C383742	02-12-02	99.9	100.3	99.8
SCHLUMBERGER	J55	C383743	02-12-02	100.1	99.9	100.0
SCHLUMBERGER	J55	C383744	02-12-02	100.1	100.3	100.1
SCHLUMBERGER	J55	C383745	02-12-02	100.0	99.9	99.9
SCHLUMBERGER	J55	C383746	02-12-02	99.9	100.0	100.0
SCHLUMBERGER	J55	C383747	02-12-02	100.2	100.1	100.0
SCHLUMBERGER	J55	C383748	02-12-02	99.8	99.9	100.0
SCHLUMBERGER	J55	C383749	02-12-02	100.1	100.3	100.0
SCHLUMBERGER	J55	C383750	02-12-02	100.0	100.1	99.8
SCHLUMBERGER	J55	C383751	02-12-02	99.9	99.6	99.7
SCHLUMBERGER	J55	C383752	02-12-02	100.1	99.9	100.4
SCHLUMBERGER	J55	C383753	02-12-02	99.9	99.7	99.8
SCHLUMBERGER	J55	C383754	02-12-02	99.9	100.1	100.1
SCHLUMBERGER	J55	C383755	02-12-02	99.9	99.8	99.6
SCHLUMBERGER	J55	C383756	02-12-02	100.0	99.9	99.9
SCHLUMBERGER	J55	C383757	02-12-02	99.9	100.1	100.2
SCHLUMBERGER	J55	C383758	02-12-02	99.9	99.7	99.7
SCHLUMBERGER	J55	C383759	02-12-02	100.1	99.9	100.4
SCHLUMBERGER	J55	C383760	02-12-02	100.3	100.4	100.0
SCHLUMBERGER	J55	C383761	02-12-02	100.0	99.9	99.9
SCHLUMBERGER	J55	C383762	02-12-02	99.9	100.5	100.0
SCHLUMBERGER	J55	C383763	02-12-02	99.9	99.6	99.5
SCHLUMBERGER	J55	C383764	02-12-02	100.0	100.2	99.8
SCHLUMBERGER	J55	C383765	02-12-02	100.1	99.9	99.8
SCHLUMBERGER	J55	C383766	02-12-02	100.0	99.6	100.3
SCHLUMBERGER	J55	C383767	02-12-02	100.0	100.2	99.9
SCHLUMBERGER	J55	C383768	02-12-02	99.9	100.2	99.9
SCHLUMBERGER	J55	C383769	02-12-02	99.9	99.9	99.5
SCHLUMBERGER	J55	C383770	02-12-02	100.1	99.9	99.9
SCHLUMBERGER	J55	C383771	02-12-02	100.2	100.2	100.1
SCHLUMBERGER	J55	C383772	02-12-02	100.1	100.0	100.0
SCHLUMBERGER	J55	C383773	02-12-02	100.0	100.1	99.4
SCHLUMBERGER	J55	C383774	02-12-02	100.0	100.1	99.4
SCHLUMBERGER	J55	C383775	02-12-02	100.0	99.7	99.8
SCHLUMBERGER	J55	C383776	02-12-02	100.1	99.7	99.4
SCHLUMBERGER	J55	C383777	02-12-02	99.8	99.9	100.1
SCHLUMBERGER	J55	C383778	02-12-02	100.3	99.7	100.3
SCHLUMBERGER	J55	C383779	02-12-02	100.1	100.2	99.9
SCHLUMBERGER	J55	C383780	02-12-02	99.9	100.1	99.8
SCHLUMBERGER	J55	C383781	02-12-02	100.1	100.0	100.4
SCHLUMBERGER	J55	C383782	02-12-02	100.1	100.2	99.5
SCHLUMBERGER	J55	C383783	02-12-02	99.9	100.0	100.3
SCHLUMBERGER	J55	C383784	02-12-02	99.9	100.1	99.7
SCHLUMBERGER	J55	C383785	02-12-02	100.0	100.1	100.0
SCHLUMBERGER	J55	C383786	02-12-02	99.9	100.1	99.6
SCHLUMBERGER	J55	C383787	02-12-02	100.1	100.0	99.7
SCHLUMBERGER	J55	C383788	02-12-02	99.9	100.0	100.2
SCHLUMBERGER	J55	C383789	02-12-02	100.0	100.1	99.8

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

PAGE 10
 RUN DATE: 1/14/03
 RUN TIME: 13.26.53

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	J5S	C383790	02-12-02	100.0	99.9	99.9
SCHLUMBERGER	J5S	C383791	02-12-02	100.1	99.8	99.9
SCHLUMBERGER	J5S	C383792	02-12-02	100.0	100.0	100.0
SCHLUMBERGER	J5S	C383793	02-12-02	100.0	99.8	100.2
SCHLUMBERGER	J5S	C383794	02-12-02	100.1	99.9	100.0
SCHLUMBERGER	J5S	C383795	02-12-02	100.0	99.9	99.9
SCHLUMBERGER	J5S	C383796	02-12-02	100.2	100.0	100.0
SCHLUMBERGER	J5S	C383797	02-12-02	100.0	100.0	100.0
SCHLUMBERGER	J5S	C383798	02-12-02	99.9	99.8	99.8
SCHLUMBERGER	J5S	C383799	02-12-02	100.1	99.9	100.3
SCHLUMBERGER	J5S	C383800	02-12-02	99.9	100.1	99.9
SCHLUMBERGER	J5S	C383801	02-12-02	100.1	100.0	99.8
SCHLUMBERGER	J5S	C383802	02-12-02	99.9	99.8	99.6
SCHLUMBERGER	J5S	C383803	02-12-02	100.0	99.7	99.8
SCHLUMBERGER	J5S	C383804	02-12-02	100.0	99.9	99.6
SCHLUMBERGER	J5S	C383805	02-12-02	100.1	100.0	99.8
SCHLUMBERGER	J5S	C383806	02-12-02	100.0	100.1	99.7
SCHLUMBERGER	J5S	C383807	02-12-02	100.0	99.7	100.0
SCHLUMBERGER	J5S	C383808	02-12-02	100.0	99.8	100.1
SCHLUMBERGER	J5S	C383809	02-12-02	100.0	99.9	99.7
SCHLUMBERGER	J5S	C383810	02-12-02	99.8	99.9	99.3
SCHLUMBERGER	J5S	C383811	02-12-02	99.8	100.3	99.8
SCHLUMBERGER	J5S	C383812	02-12-02	100.0	100.1	100.3
SCHLUMBERGER	J5S	C383813	02-12-02	100.0	99.9	100.0
SCHLUMBERGER	J5S	C383814	02-12-02	100.2	99.8	99.9
SCHLUMBERGER	J5S	C383815	02-12-02	100.1	100.2	99.9
SCHLUMBERGER	J5S	C383816	02-12-02	100.1	100.0	100.0
SCHLUMBERGER	J5S	C383817	02-12-02	99.7	99.8	99.6
SCHLUMBERGER	J5S	C383818	02-12-02	99.9	100.3	99.6
SCHLUMBERGER	J5S	C383819	02-12-02	100.1	100.1	99.7
SCHLUMBERGER	J5S	C383820	02-12-02	100.2	99.8	99.9
SCHLUMBERGER	J5S	C383821	02-12-02	100.1	100.0	99.5
SCHLUMBERGER	J5S	C383822	02-12-02	100.0	100.1	99.9
SCHLUMBERGER	J5S	C383823	02-12-02	100.1	100.0	99.9
SCHLUMBERGER	J5S	C383824	02-12-02	100.0	100.2	100.0
SCHLUMBERGER	J5S	C383825	02-12-02	100.1	99.7	99.7
SCHLUMBERGER	J5S	C383826	02-12-02	100.1	99.8	100.2
SCHLUMBERGER	J5S	C383827	02-12-02	100.0	99.7	100.1
SCHLUMBERGER	J5S	C383828	02-12-02	100.0	100.0	100.1
SCHLUMBERGER	J5S	C383829	02-12-02	99.8	99.8	100.0
SCHLUMBERGER	J5S	C383830	02-12-02	99.9	99.9	100.0
SCHLUMBERGER	J5S	C383831	02-12-02	99.9	100.1	99.9
SCHLUMBERGER	J5S	C383832	02-12-02	100.0	99.8	99.4
SCHLUMBERGER	J5S	C383833	02-12-02	100.1	99.9	99.5
SCHLUMBERGER	J5S	C383834	02-12-02	99.9	100.1	99.6
SCHLUMBERGER	J5S	C383835	02-12-02	100.1	100.0	99.8
SCHLUMBERGER	J5S	C383836	02-12-02	100.1	99.8	100.3
SCHLUMBERGER	J5S	C383837	02-12-02	99.9	99.9	99.7
SCHLUMBERGER	J5S	C383838	02-12-02	100.0	100.1	99.9
SCHLUMBERGER	J5S	C383839	02-12-02	99.9	99.9	99.5
SCHLUMBERGER	J5S	C383840	02-12-02	100.0	100.0	99.7

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

PAGE 11
 RUN DATE: 1/14/03
 RUN TIME: 13.26.53

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	J5S	C383841	02-12-02	100.2	99.9	100.3
SCHLUMBERGER	J5S	C383842	02-12-02	99.9	99.7	99.7
SCHLUMBERGER	J5S	C383843	02-12-02	99.9	99.8	99.8
SCHLUMBERGER	J5S	C383844	02-12-02	100.1	100.0	99.5
SCHLUMBERGER	J5S	C383845	02-12-02	100.2	100.2	100.2
SCHLUMBERGER	J5S	C383846	02-12-02	100.0	99.8	99.9
SCHLUMBERGER	J5S	C383847	02-12-02	100.1	100.3	100.2
SCHLUMBERGER	J5S	C383848	02-12-02	100.1	100.3	99.5
SCHLUMBERGER	J5S	C383849	02-12-02	100.0	99.8	99.9
SCHLUMBERGER	J5S	C383850	02-12-02	100.2	100.0	100.1
SCHLUMBERGER	J5S	C383851	02-12-02	99.9	100.2	100.0
SCHLUMBERGER	J5S	C383852	02-12-02	100.0	99.7	100.0
SCHLUMBERGER	J5S	C383853	02-12-02	100.0	99.7	100.0
SCHLUMBERGER	J5S	C383854	02-12-02	100.0	100.1	100.2
SCHLUMBERGER	J5S	C383855	02-12-02	100.0	99.6	99.9
SCHLUMBERGER	J5S	C383856	02-12-02	100.1	100.1	99.8
SCHLUMBERGER	J5S	C383857	02-12-02	100.0	99.7	100.1
SCHLUMBERGER	J5S	C383858	02-12-02	100.0	100.0	100.0
SCHLUMBERGER	J5S	C383859	02-12-02	100.1	100.1	100.0
SCHLUMBERGER	J5S	C383860	02-12-02	100.0	99.8	100.1
SCHLUMBERGER	J5S	C383861	02-12-02	99.9	99.7	100.1
SCHLUMBERGER	J5S	C383862	02-12-02	100.1	100.1	100.0
SCHLUMBERGER	J5S	C383863	02-12-02	99.9	99.8	100.1
SCHLUMBERGER	J5S	C383864	02-12-02	99.9	99.7	99.6
SCHLUMBERGER	J5S	C383865	02-12-02	100.0	99.9	100.0
SCHLUMBERGER	J5S	C383866	02-12-02	100.0	99.8	99.7
SCHLUMBERGER	J5S	C383867	02-12-02	100.1	99.7	99.9
SCHLUMBERGER	J5S	C383868	02-12-02	100.1	100.0	100.0
SCHLUMBERGER	J5S	C383869	02-12-02	99.9	100.0	100.1
SCHLUMBERGER	J5S	C383870	02-12-02	99.9	100.0	99.8
SCHLUMBERGER	J5S	C383871	02-12-02	100.0	100.3	100.3
SCHLUMBERGER	J5S	C383872	02-12-02	99.9	99.9	99.5
SCHLUMBERGER	J5S	C383873	02-12-02	100.1	99.9	100.1
SCHLUMBERGER	J5S	C383874	02-12-02	100.1	99.9	99.9
SCHLUMBERGER	J5S	C383875	02-12-02	100.0	100.0	99.9
SCHLUMBERGER	J5S	C383876	02-12-02	100.1	99.8	100.1
SCHLUMBERGER	J5S	C383877	02-12-02	100.1	100.3	100.6
SCHLUMBERGER	J5S	C383878	02-12-02	99.9	99.7	100.2
SCHLUMBERGER	J5S	C383879	02-12-02	99.9	100.0	99.7
SCHLUMBERGER	J5S	C383880	02-12-02	100.1	99.8	99.7
SCHLUMBERGER	J5S	C383881	02-12-02	100.2	99.8	99.9
SCHLUMBERGER	J5S	C383882	02-12-02	100.0	100.4	99.9
SCHLUMBERGER	J5S	C383883	02-12-02	100.0	99.9	99.9
SCHLUMBERGER	J5S	C383884	02-12-02	100.2	99.9	100.4
SCHLUMBERGER	J5S	C383885	02-12-02	100.1	100.0	100.2
SCHLUMBERGER	J5S	C383886	02-12-02	100.1	99.9	99.6
SCHLUMBERGER	J5S	C383887	02-12-02	100.0	100.1	100.3
SCHLUMBERGER	J5S	C383888	02-12-02	99.8	99.6	99.5
SCHLUMBERGER	J5S	C383889	02-12-02	100.0	99.9	100.2
SCHLUMBERGER	J5S	C383890	02-12-02	100.2	100.1	100.0
SCHLUMBERGER	J5S	C383891	02-12-02	100.0	100.1	100.0

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

PAGE 12
 RUN DATE: 1/14/03
 RUN TIME: 13.26.53

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	J55	C383892	02-12-02	100.0	100.0	99.9
SCHLUMBERGER	J55	C383893	02-12-02	100.0	100.0	99.9
SCHLUMBERGER	J55	C383894	02-12-02	100.2	100.1	100.1
SCHLUMBERGER	J55	C383895	02-12-02	99.9	100.0	99.9
SCHLUMBERGER	J55	C383896	02-12-02	100.2	100.2	100.0
SCHLUMBERGER	J55	C383897	02-12-02	99.9	99.8	99.9
SCHLUMBERGER	J55	C383898	02-12-02	100.0	99.7	100.1
SCHLUMBERGER	J55	C383899	02-12-02	100.2	100.1	100.1
SCHLUMBERGER	J55	C383900	02-12-02	99.9	99.7	99.3
SCHLUMBERGER	J55	C383901	02-12-02	99.9	99.8	100.3
SCHLUMBERGER	J55	C383902	02-12-02	100.2	99.7	100.4
SCHLUMBERGER	J55	C383903	02-12-02	100.3	99.9	99.8
SCHLUMBERGER	J55	C383904	02-12-02	100.0	99.9	99.8
SCHLUMBERGER	J55	C383905	02-12-02	100.2	100.0	100.3
SCHLUMBERGER	J55	C383906	02-12-02	99.9	99.8	99.5
SCHLUMBERGER	J55	C383907	02-12-02	99.9	100.1	99.8
SCHLUMBERGER	J55	C383908	02-12-02	99.9	99.8	99.4
SCHLUMBERGER	J55	C383909	02-12-02	100.0	100.0	100.2
SCHLUMBERGER	J55	C383910	02-12-02	100.2	100.1	100.0
SCHLUMBERGER	J55	C383911	02-12-02	99.9	99.7	99.7
SCHLUMBERGER	J55	C383912	02-12-02	99.9	99.9	100.1
SCHLUMBERGER	J55	C383913	02-12-02	100.0	100.0	99.8
SCHLUMBERGER	J55	C383914	02-12-02	100.0	99.6	99.6
SCHLUMBERGER	J55	C383915	02-12-02	99.9	99.8	99.8
SCHLUMBERGER	J55	C383916	02-12-02	100.0	100.2	99.9
SCHLUMBERGER	J55	C383917	02-12-02	100.1	99.7	100.0
SCHLUMBERGER	J55	C383918	02-12-02	100.1	99.9	100.0
SCHLUMBERGER	J55	C383919	02-12-02	99.9	99.6	99.8
SCHLUMBERGER	J55	C383920	02-12-02	100.1	100.3	100.4
SCHLUMBERGER	J55	C383921	02-12-02	100.0	100.4	99.9
SCHLUMBERGER	J55	C383922	02-12-02	99.9	100.0	99.7
SCHLUMBERGER	J55	C383923	02-12-02	100.0	99.9	100.1
SCHLUMBERGER	J55	C383924	02-12-02	100.0	100.0	99.7
SCHLUMBERGER	J55	C383925	02-12-02	100.0	100.0	100.0
SCHLUMBERGER	J55	C383926	02-12-02	100.0	100.1	100.1
SCHLUMBERGER	J55	C383927	02-12-02	99.9	100.1	99.8
SCHLUMBERGER	J55	C383928	02-12-02	99.9	100.3	99.9
SCHLUMBERGER	J55	C383929	02-12-02	100.1	100.1	99.8
SCHLUMBERGER	J55	C383930	02-12-02	100.2	100.4	100.4
SCHLUMBERGER	J55	C383931	02-12-02	100.0	99.9	99.7
SCHLUMBERGER	J55	C383932	02-12-02	100.0	100.1	99.8
SCHLUMBERGER	J55	C383933	02-12-02	99.8	100.4	100.4
SCHLUMBERGER	J55	C383934	02-12-02	100.2	100.0	100.3
SCHLUMBERGER	J55	C383935	02-12-02	100.1	99.9	99.7
SCHLUMBERGER	J55	C383936	02-12-02	99.9	99.9	100.0
SCHLUMBERGER	J55	C383937	02-12-02	100.2	99.9	99.6
SCHLUMBERGER	J55	C383938	02-12-02	100.0	99.8	99.8
SCHLUMBERGER	J55	C383939	02-12-02	99.9	99.9	99.6
SCHLUMBERGER	J55	C383940	02-12-02	100.0	100.0	99.8
SCHLUMBERGER	J55	C383941	02-12-02	100.2	99.9	100.1
SCHLUMBERGER	J55	C383942	02-12-02	100.0	99.9	100.1

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

PAGE 13
 RUN DATE: 1/14/03
 RUN TIME: 13.26.53

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PF FACTOR
SCHLUMBERGER	J55	C383943	02-12-02	100.0	100.1	100.0
SCHLUMBERGER	J55	C383944	02-12-02	100.0	100.0	100.3
SCHLUMBERGER	J55	C383945	02-12-02	100.1	100.1	100.1
SCHLUMBERGER	J55	C383946	02-12-02	100.0	99.9	99.8
SCHLUMBERGER	J55	C383947	02-12-02	100.1	99.9	100.0
SCHLUMBERGER	J55	C383948	02-12-02	99.9	99.7	99.9
SCHLUMBERGER	J55	C383949	02-12-02	100.1	99.9	99.6
SCHLUMBERGER	J55	C383950	02-12-02	100.3	100.1	100.3
SCHLUMBERGER	J55	C383951	02-12-02	100.1	100.1	99.9
SCHLUMBERGER	J55	C383952	02-12-02	99.9	100.1	100.0
SCHLUMBERGER	J55	C383953	02-12-02	100.2	100.2	100.0
SCHLUMBERGER	J55	C383954	02-12-02	99.9	100.1	100.3
SCHLUMBERGER	J55	C383955	02-12-02	100.0	100.3	100.2
SCHLUMBERGER	J55	C383956	02-12-02	100.1	99.9	99.9
SCHLUMBERGER	J55	C383957	02-12-02	100.0	99.8	100.0
SCHLUMBERGER	J55	C383958	02-12-02	100.1	100.0	99.8
SCHLUMBERGER	J55	C383959	02-12-02	100.1	100.0	100.3
SCHLUMBERGER	J55	C383960	02-12-02	100.0	100.1	100.0
SCHLUMBERGER	J55	C383961	02-12-02	100.1	100.1	100.3
SCHLUMBERGER	J55	C383962	02-12-02	100.2	100.3	100.1
SCHLUMBERGER	J55	C383963	02-12-02	100.2	99.6	99.9
SCHLUMBERGER	J55	C383964	02-12-02	99.9	100.2	99.9
SCHLUMBERGER	J55	C383965	02-12-02	100.1	100.1	99.9
SCHLUMBERGER	J55	C383966	02-12-02	99.9	100.1	99.7
SCHLUMBERGER	J55	C383967	02-12-02	99.9	99.7	100.0
SCHLUMBERGER	J55	C383968	02-12-02	99.8	99.7	99.9
SCHLUMBERGER	J55	C383969	02-12-02	100.3	100.4	99.7
SCHLUMBERGER	J55	C383970	02-12-02	99.9	100.0	99.8
SCHLUMBERGER	J55	C383971	02-12-02	100.0	100.1	100.3
SCHLUMBERGER	J55	C383972	02-12-02	99.9	99.7	99.8
SCHLUMBERGER	J55	C383973	02-12-02	100.1	100.1	99.8
SCHLUMBERGER	J55	C383974	02-12-02	100.0	99.7	99.7
SCHLUMBERGER	J55	C383975	02-12-02	100.2	100.1	100.4
SCHLUMBERGER	J55	C383976	02-12-02	100.0	99.7	99.4
SCHLUMBERGER	J55	C383977	02-12-02	100.0	100.0	99.8
SCHLUMBERGER	J55	C383978	02-12-02	99.9	100.0	99.5
SCHLUMBERGER	J55	C383979	02-12-02	100.0	99.8	100.1
SCHLUMBERGER	J55	C383980	02-12-02	100.3	100.0	100.2
SCHLUMBERGER	J55	C383981	02-12-02	100.2	100.1	99.7
SCHLUMBERGER	J55	C383982	02-12-02	100.0	99.9	99.9
SCHLUMBERGER	J55	C383983	02-12-02	99.9	100.3	99.9
SCHLUMBERGER	J55	C383984	02-12-02	100.0	100.0	100.0
SCHLUMBERGER	J55	C383985	02-12-02	100.0	100.1	100.0
SCHLUMBERGER	J55	C383986	02-12-02	100.1	100.1	100.0
SCHLUMBERGER	J55	C383987	02-12-02	99.9	100.0	99.9
SCHLUMBERGER	J55	C383988	02-12-02	99.9	100.1	99.7
SCHLUMBERGER	J55	C383989	02-12-02	100.1	99.9	99.9
SCHLUMBERGER	J55	C383990	02-12-02	100.2	100.0	100.3
SCHLUMBERGER	J55	C383991	02-12-02	100.0	99.9	99.7
SCHLUMBERGER	J55	C383992	02-12-02	100.1	100.1	100.0
SCHLUMBERGER	J55	C383993	02-12-02	100.1	99.9	100.5

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	J5S	C383994	02-12-02	100.0	100.0	100.0
SCHLUMBERGER	J5S	C383995	02-12-02	100.2	99.9	99.7
SCHLUMBERGER	J5S	C383996	02-12-02	99.9	100.1	99.5
SCHLUMBERGER	J5S	C383997	02-12-02	100.0	99.6	99.9
SCHLUMBERGER	J5S	C383998	02-12-02	100.0	100.1	99.9
SCHLUMBERGER	J5S	C383999	02-12-02	99.9	100.1	99.9
SCHLUMBERGER	J5S	C384000	02-12-02	100.1	100.2	100.1
SCHLUMBERGER	J5S	C384001	02-12-02	99.9	100.0	100.1
SCHLUMBERGER	J5S	C384002	02-12-02	100.1	99.8	99.8
SCHLUMBERGER	J5S	C384003	02-12-02	99.8	99.7	99.7
SCHLUMBERGER	J5S	C384004	02-12-02	100.1	99.9	100.5
SCHLUMBERGER	J5S	C384005	02-12-02	100.1	99.9	100.5
SCHLUMBERGER	J5S	C384006	02-12-02	100.0	100.0	99.8
SCHLUMBERGER	J5S	C384007	02-12-02	99.8	99.6	99.8
SCHLUMBERGER	J5S	C384008	02-12-02	100.2	100.1	100.2
SCHLUMBERGER	J5S	C384009	02-12-02	100.0	100.2	99.8
SCHLUMBERGER	J5S	C384010	02-12-02	100.0	99.9	99.7
SCHLUMBERGER	J5S	C384011	02-12-02	99.9	100.1	100.0
SCHLUMBERGER	J5S	C384012	02-12-02	99.9	99.8	99.6
SCHLUMBERGER	J5S	C384013	02-12-02	100.0	100.1	100.0
SCHLUMBERGER	J5S	C384014	02-12-02	100.1	99.9	99.6
SCHLUMBERGER	J5S	C384015	02-12-02	100.1	100.0	100.1
SCHLUMBERGER	J5S	C384016	02-12-02	100.0	100.0	100.1
SCHLUMBERGER	J5S	C384017	02-12-02	100.1	99.7	99.4
SCHLUMBERGER	J5S	C384018	02-12-02	100.1	99.9	99.7
SCHLUMBERGER	J5S	C384019	02-12-02	100.0	100.0	99.9
SCHLUMBERGER	J5S	C384020	02-12-02	100.0	100.0	100.3
SCHLUMBERGER	J5S	C384021	02-12-02	100.0	100.1	99.6
SCHLUMBERGER	J5S	C384022	02-12-02	100.2	100.0	99.9
SCHLUMBERGER	J5S	C384023	02-12-02	100.0	100.0	100.0
SCHLUMBERGER	J5S	C384024	02-12-02	100.1	99.7	100.4
SCHLUMBERGER	J5S	C384025	02-12-02	100.0	99.8	99.7
SCHLUMBERGER	J5S	C384026	02-12-02	100.0	99.7	99.8
SCHLUMBERGER	J5S	C384027	02-12-02	100.0	100.1	99.9
SCHLUMBERGER	J5S	C384028	02-12-02	100.0	100.0	99.9
SCHLUMBERGER	J5S	C384029	02-12-02	99.9	99.9	99.5
SCHLUMBERGER	J5S	C384030	02-12-02	99.9	100.0	100.1
SCHLUMBERGER	J5S	C384031	02-12-02	100.0	99.7	99.5
SCHLUMBERGER	J5S	C384032	02-12-02	100.1	99.9	100.2
SCHLUMBERGER	J5S	C384033	02-12-02	99.9	100.2	100.1
SCHLUMBERGER	J5S	C384034	02-12-02	99.9	100.0	99.6
SCHLUMBERGER	J5S	C384035	02-12-02	100.1	100.0	100.1
SCHLUMBERGER	J5S	C384036	02-12-02	100.0	99.9	99.8
SCHLUMBERGER	J5S	C384037	02-12-02	99.9	100.3	100.1
SCHLUMBERGER	J5S	C384038	02-12-02	100.0	100.1	99.9
SCHLUMBERGER	J5S	C384039	02-12-02	100.2	100.0	99.7
SCHLUMBERGER	J5S	C384040	02-12-02	99.9	99.9	99.8
SCHLUMBERGER	J5S	C384041	02-12-02	99.9	100.1	100.1
SCHLUMBERGER	J5S	C384042	02-12-02	100.0	100.0	99.8
SCHLUMBERGER	J5S	C384043	02-12-02	100.0	100.3	99.8
SCHLUMBERGER	J5S	C384044	02-12-02	100.2	100.2	99.6

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

PAGE 15
 RUN DATE: 1/14/03
 RUN TIME: 13.26.53

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PF FACTOR
SCHLUMBERGER	J5S	C384045	02-12-02	100.0	100.2	99.6
SCHLUMBERGER	J5S	C384046	02-12-02	100.2	100.2	100.2
SCHLUMBERGER	J5S	C384047	02-12-02	100.0	99.9	99.8
SCHLUMBERGER	J5S	C384048	02-12-02	100.0	100.2	99.8
SCHLUMBERGER	J5S	C384049	02-12-02	99.9	99.8	99.6
SCHLUMBERGER	J5S	C384050	02-12-02	100.2	100.1	100.4
SCHLUMBERGER	J5S	C384051	02-12-02	100.1	100.1	99.6
SCHLUMBERGER	J5S	C384052	02-12-02	100.0	100.0	99.8
SCHLUMBERGER	J5S	C384053	02-12-02	100.2	100.1	100.4
SCHLUMBERGER	J5S	C384054	02-12-02	100.1	99.7	100.2
SCHLUMBERGER	J5S	C384055	02-12-02	100.1	100.1	100.1
SCHLUMBERGER	J5S	C384056	02-12-02	100.1	100.0	100.0
SCHLUMBERGER	J5S	C384057	02-12-02	100.1	100.4	99.8
SCHLUMBERGER	J5S	C384058	02-12-02	99.9	100.3	99.7
SCHLUMBERGER	J5S	C384059	02-12-02	100.0	100.3	99.9
SCHLUMBERGER	J5S	C384060	02-12-02	100.0	99.7	99.8
SCHLUMBERGER	J5S	C384061	02-12-02	99.9	100.0	99.7
SCHLUMBERGER	J5S	C384062	02-12-02	100.2	100.2	99.8
SCHLUMBERGER	J5S	C384063	02-12-02	99.9	99.7	99.8
SCHLUMBERGER	J5S	C384064	02-12-02	100.0	100.1	99.8
SCHLUMBERGER	J5S	C384065	02-12-02	100.0	100.0	99.7
SCHLUMBERGER	J5S	C384066	02-12-02	100.2	100.1	99.7
SCHLUMBERGER	J5S	C384067	02-12-02	99.9	99.9	99.7
SCHLUMBERGER	J5S	C384068	02-12-02	100.0	99.8	100.0
SCHLUMBERGER	J5S	C384069	02-12-02	100.0	100.2	100.4
SCHLUMBERGER	J5S	C384070	02-12-02	100.0	99.8	99.9
SCHLUMBERGER	J5S	C384071	02-12-02	100.1	99.8	100.1
SCHLUMBERGER	J5S	C384072	02-12-02	99.9	100.1	99.3
SCHLUMBERGER	J5S	C384073	02-12-02	100.0	100.0	99.9
SCHLUMBERGER	J5S	C384074	02-12-02	100.1	99.8	99.7
SCHLUMBERGER	J5S	C384075	02-12-02	100.0	100.1	99.9
SCHLUMBERGER	J5S	C384076	02-12-02	99.9	100.1	99.8
SCHLUMBERGER	J5S	C384077	02-12-02	100.1	100.0	99.8
SCHLUMBERGER	J5S	C384078	02-12-02	100.1	100.0	99.9
SCHLUMBERGER	J5S	C384079	02-12-02	100.0	100.1	100.0
SCHLUMBERGER	J5S	C384080	02-12-02	100.0	99.7	99.4
SCHLUMBERGER	J5S	C384081	02-12-02	100.0	99.8	99.8
SCHLUMBERGER	J5S	C384082	02-12-02	100.0	100.1	100.0
SCHLUMBERGER	J5S	C384083	02-12-02	100.1	99.9	99.9
SCHLUMBERGER	J5S	C384084	02-12-02	100.0	99.9	99.9
SCHLUMBERGER	J5S	C384085	02-12-02	99.9	99.9	99.7
SCHLUMBERGER	J5S	C384086	02-12-02	100.0	99.9	99.5
SCHLUMBERGER	J5S	C384087	02-12-02	100.0	99.9	99.9
SCHLUMBERGER	J5S	C384088	02-12-02	100.1	100.4	100.4
SCHLUMBERGER	J5S	C384089	02-12-02	100.0	100.0	99.6
SCHLUMBERGER	J5S	C384090	02-12-02	100.0	99.9	99.4
SCHLUMBERGER	J5S	C384091	02-12-02	100.1	100.3	100.7
SCHLUMBERGER	J5S	C384092	02-12-02	100.2	100.2	99.8
SCHLUMBERGER	J5S	C384093	02-12-02	100.2	100.1	99.8
SCHLUMBERGER	J5S	C384094	02-12-02	100.3	100.0	100.0
SCHLUMBERGER	J5S	C384095	02-12-02	100.2	100.0	99.9

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

PAGE 16
 RUN DATE: 1/14/03
 RUN TIME: 13.26.53

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	J5S	C384096	02-12-02	100.1	99.8	100.2
SCHLUMBERGER	J5S	C384097	02-12-02	100.0	100.1	99.8
SCHLUMBERGER	J5S	C384098	02-12-02	99.9	99.6	99.5
SCHLUMBERGER	J5S	C384099	02-12-02	100.0	99.9	100.0
SCHLUMBERGER	J5S	C384100	02-12-02	100.0	100.0	99.9
SCHLUMBERGER	J5S	C384101	02-12-02	100.0	100.0	99.7
SCHLUMBERGER	J5S	C384102	02-12-02	100.1	100.1	99.8
SCHLUMBERGER	J5S	C384103	02-12-02	99.9	100.0	99.8
SCHLUMBERGER	J5S	C384104	02-12-02	100.1	100.2	99.7
SCHLUMBERGER	J5S	C384105	02-12-02	99.9	99.6	99.8
SCHLUMBERGER	J5S	C384106	02-12-02	100.0	100.1	100.2
SCHLUMBERGER	J5S	C384107	02-12-02	100.0	99.8	99.6
SCHLUMBERGER	J5S	C384108	02-12-02	100.0	100.1	99.7
SCHLUMBERGER	J5S	C384109	02-12-02	100.0	99.6	100.1
SCHLUMBERGER	J5S	C384110	02-12-02	100.0	99.7	100.1
SCHLUMBERGER	J5S	C384111	02-12-02	100.0	100.0	99.9
SCHLUMBERGER	J5S	C384112	02-12-02	99.9	99.9	99.9
SCHLUMBERGER	J5S	C384113	02-12-02	100.0	99.9	99.4
SCHLUMBERGER	J5S	C384114	02-12-02	100.0	100.2	99.8
SCHLUMBERGER	J5S	C384115	02-12-02	99.9	99.8	99.6
SCHLUMBERGER	J5S	C384116	02-12-02	99.9	99.9	99.6
SCHLUMBERGER	J5S	C384117	02-12-02	100.0	100.0	99.5
SCHLUMBERGER	J5S	C384118	02-12-02	100.0	100.2	99.5
SCHLUMBERGER	J5S	C384119	02-12-02	100.1	100.4	99.8
SCHLUMBERGER	J5S	C384120	02-12-02	99.9	100.1	99.7
SCHLUMBERGER	J5S	C384121	02-12-02	100.2	99.9	100.3
SCHLUMBERGER	J5S	C384122	02-12-02	100.0	99.9	99.7
SCHLUMBERGER	J5S	C384123	02-12-02	99.9	100.0	99.6
SCHLUMBERGER	J5S	C384124	02-12-02	100.1	99.6	100.2
SCHLUMBERGER	J5S	C384125	02-12-02	100.0	100.1	100.1
SCHLUMBERGER	J5S	C384126	02-12-02	100.0	100.3	99.8
SCHLUMBERGER	J5S	C384127	02-12-02	100.2	100.1	100.4
SCHLUMBERGER	J5S	C384128	02-12-02	100.0	100.1	100.0
SCHLUMBERGER	J5S	C384129	02-12-02	99.9	99.9	100.2
SCHLUMBERGER	J5S	C384130	02-12-02	100.1	100.0	100.2
SCHLUMBERGER	J5S	C384131	02-12-02	100.1	99.9	100.0
SCHLUMBERGER	J5S	C384132	02-12-02	100.0	99.9	99.5
SCHLUMBERGER	J5S	C384133	02-12-02	99.8	99.9	99.6
SCHLUMBERGER	J5S	C384134	02-12-02	100.0	99.9	99.5
SCHLUMBERGER	J5S	C384135	02-12-02	100.0	99.8	100.0
SCHLUMBERGER	J5S	C384136	02-12-02	100.2	99.8	100.3
SCHLUMBERGER	J5S	C384137	02-12-02	100.1	100.3	99.7
SCHLUMBERGER	J5S	C384138	02-12-02	100.1	99.9	100.1
SCHLUMBERGER	J5S	C384139	02-12-02	100.0	99.9	99.8
SCHLUMBERGER	J5S	C384140	02-12-02	99.9	100.0	100.0
SCHLUMBERGER	J5S	C384141	02-12-02	100.0	99.7	99.8
SCHLUMBERGER	J5S	C384142	02-12-02	99.9	100.0	99.8
SCHLUMBERGER	J5S	C384143	02-12-02	100.0	99.9	99.6
SCHLUMBERGER	J5S	C384144	02-12-02	100.0	100.4	100.2
SCHLUMBERGER	J5S	C384145	02-12-02	99.9	99.6	100.1
SCHLUMBERGER	J5S	C384146	02-12-02	99.9	99.8	99.7

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

PAGE 17
 RUN DATE: 1/14/03
 RUN TIME: 13.26.53

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	J55	C384147	02-12-02	100.1	100.0	100.5
SCHLUMBERGER	J55	C384148	02-12-02	100.0	100.0	100.1
SCHLUMBERGER	J55	C384149	02-12-02	99.9	99.9	99.8
SCHLUMBERGER	J55	C384150	02-12-02	99.9	100.1	99.8
SCHLUMBERGER	J55	C384151	02-12-02	100.0	100.2	100.0
SCHLUMBERGER	J55	C384152	02-12-02	100.0	99.7	99.9
SCHLUMBERGER	J55	C384153	02-12-02	99.9	100.0	100.2
SCHLUMBERGER	J55	C384154	02-12-02	100.1	100.4	99.9
SCHLUMBERGER	J55	C384155	02-12-02	99.9	99.9	99.6
SCHLUMBERGER	J55	C384156	02-12-02	100.0	99.8	99.9
SCHLUMBERGER	J55	C384157	02-12-02	100.2	100.2	100.2
SCHLUMBERGER	J55	C384158	02-12-02	100.0	99.8	99.7
SCHLUMBERGER	J55	C384159	02-12-02	99.9	99.9	99.6
SCHLUMBERGER	J55	C384160	02-12-02	100.2	100.1	100.0
SCHLUMBERGER	J55	C384161	02-12-02	100.0	99.8	99.9
SCHLUMBERGER	J55	C384162	02-12-02	100.0	100.3	99.5
SCHLUMBERGER	J55	C384163	02-12-02	99.9	100.0	99.8
SCHLUMBERGER	J55	C384164	02-12-02	100.0	100.1	99.9
SCHLUMBERGER	J55	C384165	02-12-02	100.2	100.1	100.1
SCHLUMBERGER	J55	C384166	02-12-02	99.9	100.0	99.5
SCHLUMBERGER	J55	C384167	02-12-02	100.1	100.1	99.9
SCHLUMBERGER	J55	C384168	02-12-02	99.9	99.7	100.0
SCHLUMBERGER	J55	C384169	02-12-02	100.0	99.9	99.6
SCHLUMBERGER	J55	C384170	02-12-02	100.0	99.8	100.0
SCHLUMBERGER	J55	C384171	02-12-02	100.0	99.9	100.5
SCHLUMBERGER	J55	C384172	02-12-02	99.9	100.0	100.1
SCHLUMBERGER	J55	C384173	02-12-02	100.0	99.9	99.6
SCHLUMBERGER	J55	C384174	02-12-02	100.0	99.8	99.6
SCHLUMBERGER	J55	C384175	02-12-02	100.0	99.8	100.0
SCHLUMBERGER	J55	C384176	02-12-02	100.1	99.9	100.2
SCHLUMBERGER	J55	C384177	02-12-02	99.9	99.9	99.6
SCHLUMBERGER	J55	C384178	02-12-02	100.0	99.7	99.9
SCHLUMBERGER	J55	C384179	02-12-02	100.1	100.1	99.9
SCHLUMBERGER	J55	C384180	02-12-02	99.9	100.1	100.0
SCHLUMBERGER	J55	C384181	02-12-02	100.0	99.8	99.9
SCHLUMBERGER	J55	C384182	02-12-02	99.9	100.0	99.8
SCHLUMBERGER	J55	C384183	02-12-02	100.1	100.0	99.7
SCHLUMBERGER	J55	C384184	02-12-02	100.2	100.0	100.3
SCHLUMBERGER	J55	C384185	02-12-02	99.9	100.2	99.7
SCHLUMBERGER	J55	C384186	02-12-02	100.0	100.1	100.1
SCHLUMBERGER	J55	C384187	02-12-02	100.0	100.1	100.0
SCHLUMBERGER	J55	C384188	02-12-02	99.9	99.8	99.8
SCHLUMBERGER	J55	C384189	02-12-02	99.8	99.8	99.4
SCHLUMBERGER	J55	C384190	02-12-02	100.0	100.3	99.9
SCHLUMBERGER	J55	C384191	02-12-02	100.0	100.1	100.2
SCHLUMBERGER	J55	C384192	02-12-02	99.9	100.0	100.0
SCHLUMBERGER	J55	C384193	02-12-02	100.1	100.2	99.9
SCHLUMBERGER	J55	C384194	02-12-02	100.1	100.0	99.9
SCHLUMBERGER	J55	C384195	02-12-02	100.0	100.1	99.7
SCHLUMBERGER	J55	C384196	02-12-02	100.0	99.8	100.0
SCHLUMBERGER	J55	C384197	02-12-02	99.9	99.9	99.8

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

PAGE 18
 RUN DATE: 1/14/03
 RUN TIME: 13.26.53

MANUFACTURER	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PF FACTOR
SCHLUMBERGER	C384198	02-12-02	99.9	100.1	100.1
SCHLUMBERGER	C384199	02-12-02	99.9	100.0	99.7
SCHLUMBERGER	C384200	02-12-02	100.0	99.7	99.9
SCHLUMBERGER	C384201	02-12-02	100.1	100.1	100.0
SCHLUMBERGER	C384202	02-12-02	100.0	100.1	99.7
SCHLUMBERGER	C384203	02-12-02	100.0	100.1	99.7
SCHLUMBERGER	C384204	02-12-02	100.0	100.2	100.0
SCHLUMBERGER	C384205	02-12-02	100.0	100.1	99.7
SCHLUMBERGER	C384206	02-12-02	100.0	100.0	99.9
SCHLUMBERGER	C384207	02-12-02	100.2	100.0	100.5
SCHLUMBERGER	C384208	02-12-02	99.9	99.8	100.0
SCHLUMBERGER	C384209	02-12-02	100.0	99.9	99.4
SCHLUMBERGER	C384210	02-12-02	100.1	100.0	100.1
SCHLUMBERGER	C384211	02-12-02	99.8	99.7	99.5
SCHLUMBERGER	C384212	02-12-02	100.1	99.9	99.9
SCHLUMBERGER	C384213	02-12-02	100.0	100.2	100.1
SCHLUMBERGER	C384214	02-12-02	100.2	100.1	100.0
SCHLUMBERGER	C384215	02-12-02	100.0	99.8	99.8
SCHLUMBERGER	C384216	02-12-02	100.0	99.7	99.5
SCHLUMBERGER	C384217	02-12-02	100.1	99.9	100.4
SCHLUMBERGER	C384218	02-12-02	100.0	100.3	99.9
SCHLUMBERGER	C384219	02-12-02	100.1	100.0	99.8
SCHLUMBERGER	C384220	02-12-02	99.9	100.0	99.4
SCHLUMBERGER	C384221	02-12-02	100.0	100.0	99.9
SCHLUMBERGER	C384222	02-12-02	100.0	100.0	100.0
SCHLUMBERGER	C384223	02-12-02	100.2	100.0	100.1
SCHLUMBERGER	C384224	02-12-02	99.9	100.3	99.6
SCHLUMBERGER	C384225	02-12-02	99.9	99.9	99.9
SCHLUMBERGER	C384226	02-12-02	100.1	99.9	99.8
SCHLUMBERGER	C384227	02-12-02	100.0	100.0	100.5
SCHLUMBERGER	C384228	02-12-02	99.9	100.0	100.0
SCHLUMBERGER	C384229	02-12-02	99.9	99.9	99.5
SCHLUMBERGER	C384230	02-12-02	100.0	99.9	99.9
SCHLUMBERGER	C384231	02-12-02	100.2	100.0	99.8
SCHLUMBERGER	C384232	02-12-02	100.0	100.0	99.6
SCHLUMBERGER	C384233	02-12-02	99.9	99.7	99.9
SCHLUMBERGER	C384234	02-12-02	100.1	100.0	100.0
SCHLUMBERGER	C384235	02-12-02	99.9	100.0	99.8
SCHLUMBERGER	C384236	02-12-02	100.0	100.1	100.3
SCHLUMBERGER	C384237	02-12-02	100.0	99.8	100.0
SCHLUMBERGER	C384238	02-12-02	100.0	100.2	99.9
SCHLUMBERGER	C384239	02-12-02	100.3	99.9	99.8
SCHLUMBERGER	C384240	02-12-02	100.0	99.8	99.7
SCHLUMBERGER	C384241	02-12-02	100.1	100.2	100.3
SCHLUMBERGER	C384242	02-12-02	100.0	99.9	99.8
SCHLUMBERGER	C384243	02-12-02	100.1	99.9	99.6
SCHLUMBERGER	C384244	02-12-02	100.1	99.9	99.9
SCHLUMBERGER	C384245	02-12-02	100.3	100.1	100.1
SCHLUMBERGER	C384246	02-12-02	100.0	99.8	99.6
SCHLUMBERGER	C384247	02-12-02	100.2	100.2	100.0
SCHLUMBERGER	C384248	02-12-02	100.0	100.2	99.9

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

PAGE 19
 RUN DATE: 1/14/03
 RUN TIME: 13.26.53

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	J55	C384249	02-12-02	100.1	100.1	100.2
SCHLUMBERGER	J55	C384250	02-12-02	100.0	99.8	99.8
SCHLUMBERGER	J55	C384251	02-12-02	99.9	99.8	99.9
SCHLUMBERGER	J55	C384252	02-12-02	100.1	99.9	99.7
SCHLUMBERGER	J55	C384253	02-12-02	100.0	99.8	100.3
SCHLUMBERGER	J55	C384254	02-12-02	100.0	100.0	99.8
SCHLUMBERGER	J55	C384255	02-12-02	100.0	100.2	100.4
SCHLUMBERGER	J55	C384256	02-12-02	100.0	100.0	100.2
SCHLUMBERGER	J55	C384257	02-12-02	99.8	100.2	99.7
SCHLUMBERGER	J55	C384258	02-12-02	100.1	100.2	99.9
SCHLUMBERGER	J55	C384259	02-12-02	100.1	100.0	100.2
SCHLUMBERGER	J55	C384260	02-12-02	100.3	99.6	99.8
SCHLUMBERGER	J55	C384261	02-12-02	99.9	100.0	99.7
SCHLUMBERGER	J55	C384262	02-12-02	99.9	100.1	100.3
SCHLUMBERGER	J55	C384263	02-12-02	99.9	99.9	99.8
SCHLUMBERGER	J55	C384264	02-12-02	100.0	99.7	99.7
SCHLUMBERGER	J55	C384265	02-12-02	100.0	100.0	100.1
SCHLUMBERGER	J55	C384266	02-12-02	100.0	99.9	100.0
SCHLUMBERGER	J55	C384267	02-12-02	99.8	99.8	99.4
SCHLUMBERGER	J55	C384268	02-12-02	100.0	99.6	99.9
SCHLUMBERGER	J55	C384269	02-12-02	99.9	100.0	99.9
SCHLUMBERGER	J55	C384270	02-12-02	100.3	100.1	100.1
SCHLUMBERGER	J55	C384271	02-12-02	100.0	99.8	99.6
SCHLUMBERGER	J55	C384272	02-12-02	100.0	99.8	99.6
SCHLUMBERGER	J55	C384273	02-12-02	99.9	100.0	99.5
SCHLUMBERGER	J55	C384274	02-12-02	100.0	100.0	100.0
SCHLUMBERGER	J55	C384275	02-12-02	99.8	99.9	99.6
SCHLUMBERGER	J55	C384276	02-12-02	99.9	99.9	100.3
SCHLUMBERGER	J55	C384277	02-12-02	99.9	99.8	100.0
SCHLUMBERGER	J55	C384278	02-12-02	100.1	100.1	100.2
SCHLUMBERGER	J55	C384279	02-12-02	99.9	99.7	100.0
SCHLUMBERGER	J55	C384280	02-12-02	100.0	99.7	100.0
SCHLUMBERGER	J55	C384281	02-12-02	100.0	99.9	100.0
SCHLUMBERGER	J55	C384282	02-12-02	100.1	99.9	100.0
SCHLUMBERGER	J55	C384283	02-12-02	100.1	100.1	99.6
SCHLUMBERGER	J55	C384284	02-12-02	100.3	100.1	100.0
SCHLUMBERGER	J55	C384285	02-12-02	100.0	100.1	100.0
SCHLUMBERGER	J55	C384286	02-12-02	100.0	99.8	100.1
SCHLUMBERGER	J55	C384287	02-12-02	100.0	99.7	99.8
SCHLUMBERGER	J55	C384288	02-12-02	99.9	99.8	99.8
SCHLUMBERGER	J55	C384289	02-12-02	100.1	100.2	100.2
SCHLUMBERGER	J55	C384290	02-12-02	100.2	100.1	100.4
SCHLUMBERGER	J55	C384291	02-12-02	100.0	99.8	100.0
SCHLUMBERGER	J55	C384292	02-12-02	100.0	99.6	99.9
SCHLUMBERGER	J55	C384293	02-12-02	100.0	99.7	100.6
SCHLUMBERGER	J55	C384294	02-12-02	100.2	100.5	100.0
SCHLUMBERGER	J55	C384295	02-12-02	100.0	99.9	100.2
SCHLUMBERGER	J55	C384296	02-12-02	99.8	100.2	99.9
SCHLUMBERGER	J55	C384297	02-12-02	99.9	99.9	100.1
SCHLUMBERGER	J55	C384298	02-12-02	100.1	100.4	99.8
SCHLUMBERGER	J55	C384299	02-12-02	100.0	100.1	100.0

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

PAGE 20
 RUN DATE: 1/14/03
 RUN TIME: 13.26.53

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	J55	C384300	02-12-02	99.9	99.8	99.9
SCHLUMBERGER	J55	C384301	02-12-02	100.0	100.0	99.6
SCHLUMBERGER	J55	C384302	02-12-02	100.0	99.9	99.9
SCHLUMBERGER	J55	C384303	02-12-02	100.0	100.1	100.0
SCHLUMBERGER	J55	C384304	02-12-02	100.1	100.0	100.0
SCHLUMBERGER	J55	C384305	02-12-02	100.1	100.1	99.7
SCHLUMBERGER	J55	C384306	02-12-02	100.0	100.2	100.2
SCHLUMBERGER	J55	C384307	02-12-02	100.0	100.0	100.2
SCHLUMBERGER	J55	C384308	02-12-02	99.9	99.7	99.7
SCHLUMBERGER	J55	C384309	02-12-02	100.2	100.1	100.0
SCHLUMBERGER	J55	C384310	02-12-02	99.9	100.1	99.8
SCHLUMBERGER	J55	C384311	02-12-02	100.1	100.1	100.2
SCHLUMBERGER	J55	C384312	02-12-02	100.2	99.8	100.5
SCHLUMBERGER	J55	C384313	02-12-02	100.0	100.0	99.8
SCHLUMBERGER	J55	C384314	02-12-02	100.2	100.3	100.3
SCHLUMBERGER	J55	C384315	02-12-02	100.3	100.0	99.8
SCHLUMBERGER	J55	C384316	02-12-02	99.9	100.0	99.6
SCHLUMBERGER	J55	C384317	02-12-02	99.9	100.0	100.2
SCHLUMBERGER	J55	C384318	02-12-02	100.1	100.0	100.2
SCHLUMBERGER	J55	C384319	02-12-02	99.9	99.8	99.8
SCHLUMBERGER	J55	C384320	02-12-02	100.0	99.6	99.9
SCHLUMBERGER	J55	C384321	02-12-02	99.8	99.7	99.7
SCHLUMBERGER	J55	C384322	02-12-02	100.0	100.2	100.3
SCHLUMBERGER	J55	C384323	02-12-02	100.2	99.8	100.4
SCHLUMBERGER	J55	C384324	02-12-02	99.9	99.8	99.6
SCHLUMBERGER	J55	C384325	02-12-02	99.8	99.7	99.8
SCHLUMBERGER	J55	C384326	02-12-02	100.3	100.1	99.7
SCHLUMBERGER	J55	C384327	02-12-02	100.2	100.0	100.3
SCHLUMBERGER	J55	C384328	02-12-02	99.9	100.0	99.9
SCHLUMBERGER	J55	C384329	02-12-02	99.8	99.9	100.0
SCHLUMBERGER	J55	C384330	02-12-02	100.0	99.9	99.5
SCHLUMBERGER	J55	C384331	02-12-02	99.9	100.1	99.9
SCHLUMBERGER	J55	C384332	02-12-02	100.1	99.8	100.1
SCHLUMBERGER	J55	C384333	02-12-02	100.1	99.9	100.1
SCHLUMBERGER	J55	C384334	02-12-02	99.9	99.9	99.8
SCHLUMBERGER	J55	C384335	02-12-02	100.1	99.7	100.0
SCHLUMBERGER	J55	C384336	02-12-02	100.0	99.8	100.1
SCHLUMBERGER	J55	C384337	02-12-02	99.9	99.9	99.9
SCHLUMBERGER	J55	C384338	02-12-02	99.8	99.9	100.1
SCHLUMBERGER	J55	C384339	02-12-02	100.0	99.9	100.2
SCHLUMBERGER	J55	C384340	02-12-02	100.0	100.1	100.2
SCHLUMBERGER	J55	C384341	02-12-02	99.9	99.6	100.0
SCHLUMBERGER	J55	C384342	02-12-02	99.9	100.0	99.9
SCHLUMBERGER	J55	C384343	02-12-02	100.3	100.2	100.1
SCHLUMBERGER	J55	C384344	02-12-02	100.1	99.7	100.2
SCHLUMBERGER	J55	C384345	02-12-02	99.9	99.9	100.1
SCHLUMBERGER	J55	C384346	02-12-02	100.2	99.9	99.9
SCHLUMBERGER	J55	C384347	02-12-02	100.0	99.8	99.8
SCHLUMBERGER	J55	C384348	02-12-02	100.0	99.7	99.6
SCHLUMBERGER	J55	C384349	02-12-02	99.9	99.8	100.1
SCHLUMBERGER	J55	C384350	02-12-02	100.0	99.8	100.0

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

PAGE 21
 RUN DATE: 1/14/03
 RUN TIME: 13.26.53

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	J55	C384351	02-12-02	100.0	99.8	99.8
SCHLUMBERGER	J55	C384352	02-12-02	99.9	100.2	99.8
SCHLUMBERGER	J55	C384353	02-12-02	100.2	99.8	99.6
SCHLUMBERGER	J55	C384354	02-12-02	99.8	99.9	100.1
SCHLUMBERGER	J55	C384355	02-12-02	100.3	100.2	100.5
SCHLUMBERGER	J55	C384356	02-12-02	100.0	99.9	100.0
SCHLUMBERGER	J55	C384357	02-12-02	100.1	100.1	99.8
SCHLUMBERGER	J55	C384358	02-12-02	100.2	100.0	100.4
SCHLUMBERGER	J55	C384359	02-12-02	99.9	99.7	99.6
SCHLUMBERGER	J55	C384360	02-12-02	100.3	100.1	100.0
SCHLUMBERGER	J55	C384361	02-12-02	99.9	99.7	100.4
SCHLUMBERGER	J55	C384362	02-12-02	100.0	100.0	99.7
SCHLUMBERGER	J55	C384363	02-12-02	99.9	99.7	99.6
SCHLUMBERGER	J55	C384364	02-12-02	99.9	100.0	100.2
SCHLUMBERGER	J55	C384365	02-12-02	100.0	100.0	100.6
SCHLUMBERGER	J55	C384366	02-12-02	100.0	99.7	100.2
SCHLUMBERGER	J55	C384367	02-12-02	100.0	100.2	99.6
SCHLUMBERGER	J55	C384368	02-12-02	99.9	99.6	100.2
SCHLUMBERGER	J55	C384369	02-12-02	100.0	99.9	100.0
SCHLUMBERGER	J55	C384370	02-12-02	99.9	99.8	100.3
SCHLUMBERGER	J55	C384371	02-12-02	100.0	99.8	99.9
SCHLUMBERGER	J55	C384372	02-12-02	100.1	100.1	100.2
SCHLUMBERGER	J55	C384373	02-12-02	100.0	100.1	99.7
SCHLUMBERGER	J55	C384374	02-12-02	100.0	100.0	100.4
SCHLUMBERGER	J55	C384375	02-12-02	100.2	99.9	100.4
SCHLUMBERGER	J55	C384376	02-12-02	99.9	99.8	99.8
SCHLUMBERGER	J55	C384377	02-12-02	100.0	100.1	100.1
SCHLUMBERGER	J55	C384378	02-12-02	100.0	99.9	99.8
SCHLUMBERGER	J55	C384379	02-12-02	100.1	99.7	100.2
SCHLUMBERGER	J55	C384380	02-12-02	100.0	99.8	100.1
SCHLUMBERGER	J55	C384381	02-12-02	99.9	99.8	100.0
SCHLUMBERGER	J55	C384382	02-12-02	100.1	100.2	99.7
SCHLUMBERGER	J55	C384383	02-12-02	99.8	99.8	100.1
SCHLUMBERGER	J55	C384384	02-12-02	100.0	99.7	100.1
SCHLUMBERGER	J55	C384385	02-12-02	99.8	99.8	100.1
SCHLUMBERGER	J55	C384386	02-12-02	100.1	100.1	100.2
SCHLUMBERGER	J55	C384387	02-12-02	99.9	100.0	99.7
SCHLUMBERGER	J55	C384388	02-12-02	99.9	99.7	100.1
SCHLUMBERGER	J55	C384389	02-12-02	100.0	99.8	100.0
SCHLUMBERGER	J55	C384390	02-12-02	100.1	99.9	100.1
SCHLUMBERGER	J55	C384391	02-12-02	99.9	99.9	99.9
SCHLUMBERGER	J55	C384392	02-12-02	99.9	100.2	99.9
SCHLUMBERGER	J55	C384393	02-12-02	99.9	99.7	100.1
SCHLUMBERGER	J55	C384394	02-12-02	100.0	100.0	99.6
SCHLUMBERGER	J55	C384395	02-12-02	100.2	100.0	100.1
SCHLUMBERGER	J55	C384396	02-12-02	100.2	99.9	100.2
SCHLUMBERGER	J55	C384397	02-12-02	100.0	99.8	100.1
SCHLUMBERGER	J55	C384398	02-12-02	99.9	99.8	99.8
SCHLUMBERGER	J55	C384399	02-12-02	100.1	100.0	100.0
SCHLUMBERGER	J55	C384400	02-12-02	100.0	99.8	99.9
SCHLUMBERGER	J55	C384401	02-12-02	99.9	99.7	100.1

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

PAGE 22
 RUN DATE: 1/14/03
 RUN TIME: 13.26.53

MANUFACTURER	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	C384402	02-12-02	100.2	100.0	100.5
SCHLUMBERGER	C384403	02-12-02	100.1	100.1	99.5
SCHLUMBERGER	C384404	02-12-02	99.9	100.1	100.1
SCHLUMBERGER	C384405	02-12-02	100.2	100.0	100.1
SCHLUMBERGER	C384406	02-12-02	100.0	99.9	100.0
SCHLUMBERGER	C384407	02-12-02	99.8	100.0	100.2
SCHLUMBERGER	C384408	02-12-02	100.3	100.2	100.3
SCHLUMBERGER	C384409	02-12-02	99.8	100.0	99.8
SCHLUMBERGER	C384410	02-12-02	99.9	99.8	99.7
SCHLUMBERGER	C384411	02-12-02	100.0	100.1	100.0
SCHLUMBERGER	C384412	02-12-02	100.1	100.1	100.0
SCHLUMBERGER	C384413	02-12-02	100.1	99.9	99.9
SCHLUMBERGER	C384414	02-12-02	100.0	99.8	99.5
SCHLUMBERGER	C384415	02-12-02	100.1	99.7	100.0
SCHLUMBERGER	C384416	02-12-02	100.0	99.4	99.4
SCHLUMBERGER	C384417	02-12-02	100.2	100.1	100.5
SCHLUMBERGER	C384418	02-12-02	99.9	99.6	100.1
SCHLUMBERGER	C384419	02-12-02	99.9	100.1	99.8
SCHLUMBERGER	C384420	02-12-02	100.0	99.7	99.9
SCHLUMBERGER	C384421	02-12-02	99.9	99.7	99.6
SCHLUMBERGER	C384422	02-12-02	100.0	100.0	100.2
SCHLUMBERGER	C384423	02-12-02	100.1	99.9	99.5
SCHLUMBERGER	C384424	02-12-02	100.2	100.0	99.9
SCHLUMBERGER	C384425	02-12-02	100.2	100.1	100.0
SCHLUMBERGER	C384426	02-12-02	100.2	100.1	100.2
SCHLUMBERGER	C384427	02-12-02	100.2	100.0	100.5
SCHLUMBERGER	C384428	02-12-02	100.2	100.3	100.2
SCHLUMBERGER	C384429	02-12-02	100.0	100.0	100.3
SCHLUMBERGER	C384430	02-12-02	100.0	99.8	99.6
SCHLUMBERGER	C384431	02-12-02	100.1	100.1	100.0
SCHLUMBERGER	C384432	02-12-02	99.9	100.2	99.4
SCHLUMBERGER	C384433	02-12-02	99.9	99.9	99.4
SCHLUMBERGER	C384434	02-12-02	100.1	100.0	100.0
SCHLUMBERGER	C384435	02-12-02	99.9	99.7	99.9
SCHLUMBERGER	C384436	02-12-02	100.1	99.8	100.3
SCHLUMBERGER	C384437	02-12-02	99.9	99.8	100.2
SCHLUMBERGER	C384438	02-12-02	100.0	99.8	100.2
SCHLUMBERGER	C384439	02-12-02	100.0	99.8	99.8
SCHLUMBERGER	C384440	02-12-02	100.0	100.0	100.3
SCHLUMBERGER	C384441	02-12-02	100.0	99.8	100.0
SCHLUMBERGER	C384442	02-12-02	100.1	99.5	100.3
SCHLUMBERGER	C384443	02-12-02	100.2	100.1	99.4
SCHLUMBERGER	C384444	02-12-02	100.1	100.0	100.3
SCHLUMBERGER	C384445	02-12-02	100.1	100.2	100.5
SCHLUMBERGER	C384446	02-12-02	100.0	99.8	100.4
SCHLUMBERGER	C384447	02-12-02	100.0	100.1	99.5
SCHLUMBERGER	C384448	02-12-02	100.2	99.9	99.8
SCHLUMBERGER	C384449	02-12-02	100.1	99.9	100.2
SCHLUMBERGER	C384450	02-11-02	100.0	99.7	100.0
SCHLUMBERGER	C384451	02-11-02	100.0	100.0	100.3
SCHLUMBERGER	C384452	02-11-02	100.2	100.0	100.1

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

PAGE 23
 RUN DATE: 1/14/03
 RUN TIME: 13.26.53

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	J5S	C384453	02-11-02	100.0	99.9	99.9
SCHLUMBERGER	J5S	C384454	02-11-02	100.0	100.0	100.1
SCHLUMBERGER	J5S	C384455	02-11-02	100.0	99.8	100.5
SCHLUMBERGER	J5S	C384456	02-11-02	100.0	100.2	99.9
SCHLUMBERGER	J5S	C384457	02-11-02	100.0	99.7	99.7
SCHLUMBERGER	J5S	C384458	02-11-02	100.1	99.9	99.5
SCHLUMBERGER	J5S	C384459	02-11-02	100.1	100.2	99.8
SCHLUMBERGER	J5S	C384460	02-11-02	99.9	99.9	99.7
SCHLUMBERGER	J5S	C384461	02-11-02	100.1	99.8	99.8
SCHLUMBERGER	J5S	C384462	02-11-02	100.2	100.2	99.9
SCHLUMBERGER	J5S	C384463	02-11-02	99.9	99.8	100.0
SCHLUMBERGER	J5S	C384464	02-11-02	100.1	100.2	99.7
SCHLUMBERGER	J5S	C384465	02-11-02	100.2	99.9	100.2
SCHLUMBERGER	J5S	C384466	02-11-02	100.2	100.4	99.7
SCHLUMBERGER	J5S	C384467	02-11-02	100.2	100.4	100.2
SCHLUMBERGER	J5S	C384468	02-11-02	99.9	100.1	99.9
SCHLUMBERGER	J5S	C384469	02-11-02	100.0	100.2	100.1
SCHLUMBERGER	J5S	C384470	02-11-02	100.2	100.1	99.9
SCHLUMBERGER	J5S	C384471	02-11-02	99.9	100.1	100.1
SCHLUMBERGER	J5S	C384472	02-11-02	100.1	99.9	99.8
SCHLUMBERGER	J5S	C384473	02-11-02	100.0	99.8	100.2
SCHLUMBERGER	J5S	C384474	02-11-02	100.0	99.9	99.9
SCHLUMBERGER	J5S	C384475	02-11-02	100.0	99.6	99.8
SCHLUMBERGER	J5S	C384476	02-11-02	100.1	99.9	100.0
SCHLUMBERGER	J5S	C384477	02-11-02	100.2	100.4	100.2
SCHLUMBERGER	J5S	C384478	02-11-02	100.0	99.9	100.0
SCHLUMBERGER	J5S	C384479	02-11-02	100.1	99.8	100.0
SCHLUMBERGER	J5S	C384480	02-11-02	100.1	100.1	99.9
SCHLUMBERGER	J5S	C384481	02-11-02	100.1	99.7	99.7
SCHLUMBERGER	J5S	C384482	02-11-02	100.1	100.4	100.5
SCHLUMBERGER	J5S	C384483	02-11-02	100.0	99.7	99.9
SCHLUMBERGER	J5S	C384484	02-11-02	100.0	99.7	99.6
SCHLUMBERGER	J5S	C384485	02-11-02	100.2	100.0	99.6
SCHLUMBERGER	J5S	C384486	02-11-02	100.0	100.1	99.7
SCHLUMBERGER	J5S	C384487	02-11-02	99.9	99.7	99.5
SCHLUMBERGER	J5S	C384488	02-11-02	100.1	100.0	100.3
SCHLUMBERGER	J5S	C384489	02-11-02	100.1	100.0	100.1
SCHLUMBERGER	J5S	C384490	02-11-02	100.1	99.9	99.7
SCHLUMBERGER	J5S	C384491	02-11-02	100.1	99.7	99.9
SCHLUMBERGER	J5S	C384492	02-11-02	100.0	99.8	99.7
SCHLUMBERGER	J5S	C384493	02-11-02	100.0	100.2	99.8
SCHLUMBERGER	J5S	C384494	02-11-02	99.8	99.7	99.8
SCHLUMBERGER	J5S	C384495	02-11-02	100.1	100.2	99.5
SCHLUMBERGER	J5S	C384496	02-11-02	99.9	100.0	100.0
SCHLUMBERGER	J5S	C384497	02-11-02	99.9	99.7	99.9
SCHLUMBERGER	J5S	C384498	02-11-02	99.9	99.7	99.8
SCHLUMBERGER	J5S	C384499	02-11-02	100.1	99.7	99.7
SCHLUMBERGER	J5S	C384500	02-11-02	100.1	99.8	100.0
SCHLUMBERGER	J5S	C384501	02-11-02	100.0	99.7	99.6
SCHLUMBERGER	J5S	C384502	02-11-02	99.9	100.2	99.9
SCHLUMBERGER	J5S	C384503	02-11-02	99.9	100.1	100.4

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

MANUFACTURER	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	C384504	02-11-02	100.2	100.1	100.1
SCHLUMBERGER	C384505	02-11-02	100.0	99.9	100.3
SCHLUMBERGER	C384506	02-11-02	100.0	99.7	99.7
SCHLUMBERGER	C384507	02-11-02	100.0	100.1	100.1
SCHLUMBERGER	C384508	02-11-02	100.1	99.9	100.1
SCHLUMBERGER	C384509	02-11-02	100.1	100.2	99.7
SCHLUMBERGER	C384510	02-11-02	100.1	99.9	100.1
SCHLUMBERGER	C384511	02-11-02	100.2	100.2	100.6
SCHLUMBERGER	C384512	02-11-02	100.2	99.9	99.9
SCHLUMBERGER	C384513	02-11-02	99.9	100.3	99.4
SCHLUMBERGER	C384514	02-11-02	99.9	99.9	100.1
SCHLUMBERGER	C384515	02-11-02	99.9	100.1	99.6
SCHLUMBERGER	C384516	02-11-02	99.9	99.9	99.6
SCHLUMBERGER	C384517	02-11-02	99.9	99.7	99.6
SCHLUMBERGER	C384518	02-11-02	99.9	100.0	99.5
SCHLUMBERGER	C384519	02-11-02	100.2	100.1	100.0
SCHLUMBERGER	C384520	02-11-02	100.3	100.0	100.0
SCHLUMBERGER	C384521	02-11-02	100.2	100.1	100.2
SCHLUMBERGER	C384522	02-11-02	100.0	100.0	100.1
SCHLUMBERGER	C384523	02-11-02	99.9	100.2	99.5
SCHLUMBERGER	C384524	02-11-02	100.1	99.9	99.9
SCHLUMBERGER	C384525	02-11-02	100.2	99.9	100.2
SCHLUMBERGER	C384526	02-11-02	100.0	99.7	100.1
SCHLUMBERGER	C384527	02-11-02	100.0	99.8	100.4
SCHLUMBERGER	C384528	02-11-02	99.9	100.0	100.2
SCHLUMBERGER	C384529	02-11-02	99.8	100.0	99.6
SCHLUMBERGER	C384530	02-11-02	99.8	99.9	99.6
SCHLUMBERGER	C384531	02-11-02	100.0	100.2	100.0
SCHLUMBERGER	C384532	02-11-02	100.1	99.8	100.1
SCHLUMBERGER	C384533	02-11-02	99.9	99.7	99.8
SCHLUMBERGER	C384534	02-11-02	100.2	99.8	99.7
SCHLUMBERGER	C384535	02-11-02	100.2	100.0	99.8
SCHLUMBERGER	C384536	02-11-02	100.0	100.1	100.0
SCHLUMBERGER	C384537	02-11-02	100.0	100.2	100.1
SCHLUMBERGER	C384538	02-11-02	100.0	99.7	99.9
SCHLUMBERGER	C384539	02-11-02	100.1	99.9	99.8
SCHLUMBERGER	C384540	02-11-02	100.1	100.1	99.9
SCHLUMBERGER	C384541	02-11-02	100.1	100.3	99.9
SCHLUMBERGER	C384542	02-11-02	100.1	99.9	100.1
SCHLUMBERGER	C384543	02-11-02	100.2	100.0	99.9
SCHLUMBERGER	C384544	02-11-02	99.9	99.7	100.2
SCHLUMBERGER	C384545	02-11-02	100.0	100.0	99.7
SCHLUMBERGER	C384546	02-11-02	100.0	99.6	100.1
SCHLUMBERGER	C384547	02-11-02	100.2	99.7	99.8
SCHLUMBERGER	C384548	02-11-02	99.9	99.7	100.1
SCHLUMBERGER	C384549	02-11-02	100.1	100.1	100.0
SCHLUMBERGER	C384550	02-11-02	99.8	99.9	100.0
SCHLUMBERGER	C384551	02-11-02	99.9	100.0	100.0
SCHLUMBERGER	C384552	02-11-02	100.2	100.3	100.1
SCHLUMBERGER	C384553	02-11-02	99.9	99.8	100.0
SCHLUMBERGER	C384554	02-11-02	100.0	99.8	100.4

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	J55	C384555	02-11-02	100.1	100.0	99.8
SCHLUMBERGER	J55	C384556	02-11-02	100.2	100.1	100.0
SCHLUMBERGER	J55	C384557	02-11-02	99.9	100.2	99.8
SCHLUMBERGER	J55	C384558	02-11-02	100.0	99.7	100.4
SCHLUMBERGER	J55	C384559	02-11-02	100.1	100.2	100.2
SCHLUMBERGER	J55	C384560	02-11-02	100.1	100.0	100.0
SCHLUMBERGER	J55	C384561	02-11-02	100.1	100.3	100.2
SCHLUMBERGER	J55	C384562	02-11-02	100.0	99.9	100.4
SCHLUMBERGER	J55	C384563	02-11-02	100.1	100.1	100.3
SCHLUMBERGER	J55	C384564	02-11-02	100.1	100.1	100.1
SCHLUMBERGER	J55	C384565	02-11-02	100.1	99.7	100.3
SCHLUMBERGER	J55	C384566	02-11-02	100.2	100.0	100.3
SCHLUMBERGER	J55	C384567	02-11-02	100.2	100.0	100.4
SCHLUMBERGER	J55	C384568	02-11-02	100.1	100.0	100.2
SCHLUMBERGER	J55	C384569	02-11-02	99.9	100.0	100.2
SCHLUMBERGER	J55	C384570	02-11-02	100.0	99.8	99.8
SCHLUMBERGER	J55	C384571	02-11-02	100.1	99.8	100.0
SCHLUMBERGER	J55	C384572	02-11-02	100.0	100.3	100.3
SCHLUMBERGER	J55	C384573	02-11-02	100.0	100.2	100.1
SCHLUMBERGER	J55	C384574	02-11-02	100.0	99.8	99.9
SCHLUMBERGER	J55	C384575	02-11-02	100.2	99.8	100.3
SCHLUMBERGER	J55	C384576	02-11-02	100.3	100.0	99.8
SCHLUMBERGER	J55	C384577	02-11-02	100.2	100.1	100.0
SCHLUMBERGER	J55	C384578	02-11-02	100.0	99.9	100.0
SCHLUMBERGER	J55	C384579	02-11-02	100.3	100.1	99.9
SCHLUMBERGER	J55	C384580	02-11-02	100.2	100.0	100.2
SCHLUMBERGER	J55	C384581	02-11-02	99.8	99.7	99.8
SCHLUMBERGER	J55	C384582	02-11-02	100.1	100.2	99.9
SCHLUMBERGER	J55	C384583	02-11-02	100.1	100.0	100.0
SCHLUMBERGER	J55	C384584	02-11-02	99.8	100.0	100.1
SCHLUMBERGER	J55	C384585	02-11-02	100.0	100.2	100.1
SCHLUMBERGER	J55	C384586	02-11-02	100.1	100.1	99.9
SCHLUMBERGER	J55	C384587	02-11-02	100.1	100.0	100.3
SCHLUMBERGER	J55	C384588	02-11-02	99.9	100.0	99.9
SCHLUMBERGER	J55	C384589	02-11-02	100.0	99.8	100.1
SCHLUMBERGER	J55	C384590	02-11-02	100.0	100.0	99.8
SCHLUMBERGER	J55	C384591	02-11-02	99.9	100.0	99.6
SCHLUMBERGER	J55	C384592	02-11-02	100.1	99.8	100.1
SCHLUMBERGER	J55	C384593	02-11-02	100.1	99.9	100.0
SCHLUMBERGER	J55	C384594	02-11-02	100.0	100.1	99.8
SCHLUMBERGER	J55	C384595	02-11-02	100.1	99.9	100.0
SCHLUMBERGER	J55	C384596	02-11-02	99.9	100.3	100.2
SCHLUMBERGER	J55	C384597	02-11-02	100.0	99.7	99.8
SCHLUMBERGER	J55	C384598	02-11-02	100.0	100.0	99.8
SCHLUMBERGER	J55	C384599	02-11-02	100.0	100.2	100.2
SCHLUMBERGER	J55	C384600	02-11-02	99.9	100.0	100.1
SCHLUMBERGER	J55	C384601	02-11-02	100.0	99.9	99.8
SCHLUMBERGER	J55	C384602	02-11-02	100.0	100.0	100.2
SCHLUMBERGER	J55	C384603	02-11-02	100.0	100.0	100.1
SCHLUMBERGER	J55	C384604	02-11-02	100.0	100.0	99.6
SCHLUMBERGER	J55	C384605	02-11-02	100.0	100.0	100.2

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

PAGE 26
 RUN DATE: 1/14/03
 RUN TIME: 13.26.53

MANUFACTURER	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	C384606	02-11-02	99.8	100.2	100.0
SCHLUMBERGER	C384607	02-11-02	100.0	99.9	100.2
SCHLUMBERGER	C384608	02-11-02	100.0	100.1	99.9
SCHLUMBERGER	C384609	02-11-02	99.9	99.9	99.8
SCHLUMBERGER	C384610	02-11-02	100.1	99.8	99.6
SCHLUMBERGER	C384611	02-11-02	100.1	100.3	99.9
SCHLUMBERGER	C384612	02-11-02	100.2	99.8	100.3
SCHLUMBERGER	C384613	02-11-02	99.9	99.6	99.8
SCHLUMBERGER	C384614	02-11-02	100.3	100.2	100.1
SCHLUMBERGER	C384615	02-11-02	99.9	100.0	100.0
SCHLUMBERGER	C384616	02-11-02	100.0	100.0	99.8
SCHLUMBERGER	C384617	02-11-02	100.1	100.0	100.4
SCHLUMBERGER	C384618	02-11-02	100.0	100.1	99.6
SCHLUMBERGER	C384619	02-11-02	99.9	100.2	100.1
SCHLUMBERGER	C384620	02-11-02	100.0	99.9	100.2
SCHLUMBERGER	C384621	02-11-02	100.0	99.9	100.2
SCHLUMBERGER	C384622	02-11-02	100.1	100.0	100.4
SCHLUMBERGER	C384623	02-11-02	100.1	99.9	100.1
SCHLUMBERGER	C384624	02-11-02	100.1	100.0	100.3
SCHLUMBERGER	C384625	02-11-02	100.3	99.8	100.3
SCHLUMBERGER	C384626	02-11-02	99.9	99.9	100.2
SCHLUMBERGER	C384627	02-11-02	100.1	99.8	100.0
SCHLUMBERGER	C384628	02-11-02	100.0	100.1	100.0
SCHLUMBERGER	C384629	02-11-02	100.0	100.1	99.9
SCHLUMBERGER	C384630	02-11-02	100.0	100.1	100.1
SCHLUMBERGER	C384631	02-11-02	100.0	100.1	100.0
SCHLUMBERGER	C384632	02-11-02	99.8	99.8	99.9
SCHLUMBERGER	C384633	02-11-02	100.0	99.7	100.0
SCHLUMBERGER	C384634	02-11-02	99.9	99.6	100.1
SCHLUMBERGER	C384635	02-11-02	100.1	100.1	99.8
SCHLUMBERGER	C384636	02-11-02	100.0	100.0	99.9
SCHLUMBERGER	C384637	02-11-02	100.1	100.2	100.0
SCHLUMBERGER	C384638	02-11-02	100.2	100.3	99.7
SCHLUMBERGER	C384639	02-11-02	100.1	100.0	99.9
SCHLUMBERGER	C384640	02-11-02	99.9	99.7	99.8
SCHLUMBERGER	C384641	02-11-02	100.1	100.1	100.1
SCHLUMBERGER	C384642	02-11-02	100.1	100.1	99.8
SCHLUMBERGER	C384643	02-11-02	100.1	100.0	99.8
SCHLUMBERGER	C384644	02-11-02	100.1	99.8	99.8
SCHLUMBERGER	C384645	02-11-02	100.1	99.9	99.9
SCHLUMBERGER	C384646	02-11-02	100.1	99.8	99.8
SCHLUMBERGER	C384647	02-11-02	100.0	99.8	100.1
SCHLUMBERGER	C384648	02-11-02	100.0	100.0	99.7
SCHLUMBERGER	C384649	02-11-02	99.9	100.4	99.4
SCHLUMBERGER	C384650	02-11-02	100.0	100.2	100.1
SCHLUMBERGER	C384651	02-11-02	100.0	100.0	100.0
SCHLUMBERGER	C384652	02-11-02	99.9	99.9	99.6
SCHLUMBERGER	C384653	02-11-02	100.1	99.9	100.1
SCHLUMBERGER	C384654	02-11-02	100.0	100.0	99.7
SCHLUMBERGER	C384655	02-11-02	100.0	100.0	99.8
SCHLUMBERGER	C384656	02-11-02	100.2	99.8	100.2

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

PAGE 27
 RUN DATE: 1/14/03
 RUN TIME: 13.26.53

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PEAFCTOR
SCHLUMBERGER	J5S	C384657	02-11-02	100.0	100.0	99.9
SCHLUMBERGER	J5S	C384658	02-11-02	100.2	100.0	100.1
SCHLUMBERGER	J5S	C384659	02-11-02	100.0	99.9	99.8
SCHLUMBERGER	J5S	C384660	02-11-02	100.3	100.0	100.0
SCHLUMBERGER	J5S	C384661	02-11-02	100.2	100.0	99.8
SCHLUMBERGER	J5S	C384662	02-11-02	100.1	100.0	100.1
SCHLUMBERGER	J5S	C384663	02-11-02	100.1	99.9	99.9
SCHLUMBERGER	J5S	C384664	02-11-02	100.1	100.3	99.7
SCHLUMBERGER	J5S	C384665	02-11-02	100.0	100.0	100.0
SCHLUMBERGER	J5S	C384666	02-11-02	100.2	99.9	99.9
SCHLUMBERGER	J5S	C384667	02-11-02	100.2	100.2	100.0
SCHLUMBERGER	J5S	C384668	02-11-02	100.1	100.2	99.8
SCHLUMBERGER	J5S	C384669	02-11-02	100.0	100.0	99.9
SCHLUMBERGER	J5S	C384670	02-11-02	100.1	100.0	99.7
SCHLUMBERGER	J5S	C384671	02-11-02	100.1	100.3	99.7
SCHLUMBERGER	J5S	C384672	02-11-02	99.8	99.8	99.8
SCHLUMBERGER	J5S	C384673	02-11-02	100.2	99.8	99.8
SCHLUMBERGER	J5S	C384674	02-11-02	100.1	100.1	100.1
SCHLUMBERGER	J5S	C384675	02-11-02	100.0	100.2	100.0
SCHLUMBERGER	J5S	C384676	02-11-02	100.0	100.2	100.0
SCHLUMBERGER	J5S	C384677	02-11-02	100.0	99.7	99.7
SCHLUMBERGER	J5S	C384678	02-11-02	100.0	99.7	99.8
SCHLUMBERGER	J5S	C384679	02-11-02	99.9	100.0	99.7
SCHLUMBERGER	J5S	C384680	02-11-02	100.2	100.0	99.9
SCHLUMBERGER	J5S	C384681	02-11-02	100.0	100.1	100.1
SCHLUMBERGER	J5S	C384682	02-11-02	99.8	99.6	99.7
SCHLUMBERGER	J5S	C384683	02-11-02	99.9	100.0	99.8
SCHLUMBERGER	J5S	C384684	02-11-02	100.0	99.9	99.9
SCHLUMBERGER	J5S	C384685	02-11-02	99.9	99.8	99.7
SCHLUMBERGER	J5S	C384686	02-11-02	100.1	99.7	100.1
SCHLUMBERGER	J5S	C384687	02-11-02	99.9	99.8	99.7
SCHLUMBERGER	J5S	C384688	02-11-02	100.0	100.2	99.8
SCHLUMBERGER	J5S	C384689	02-11-02	99.9	99.9	99.4
SCHLUMBERGER	J5S	C384690	02-11-02	100.0	99.9	99.5
SCHLUMBERGER	J5S	C384691	02-11-02	100.1	100.1	100.0
SCHLUMBERGER	J5S	C384692	02-11-02	99.9	99.9	100.0
SCHLUMBERGER	J5S	C384693	02-11-02	99.9	99.7	99.8
SCHLUMBERGER	J5S	C384694	02-11-02	100.0	99.7	100.4
SCHLUMBERGER	J5S	C384695	02-11-02	99.9	99.9	99.7
SCHLUMBERGER	J5S	C384696	02-11-02	100.1	99.9	100.1
SCHLUMBERGER	J5S	C384697	02-11-02	100.1	99.9	100.1
SCHLUMBERGER	J5S	C384698	02-11-02	100.1	99.9	100.3
SCHLUMBERGER	J5S	C384699	02-11-02	100.1	99.9	100.1
SCHLUMBERGER	J5S	C384700	02-11-02	100.0	99.8	99.9
SCHLUMBERGER	J5S	C384701	02-11-02	100.0	100.0	99.6
SCHLUMBERGER	J5S	C384702	02-11-02	99.8	99.9	99.8
SCHLUMBERGER	J5S	C384703	02-11-02	99.9	99.9	99.7
SCHLUMBERGER	J5S	C384704	02-11-02	100.0	99.8	99.5
SCHLUMBERGER	J5S	C384705	02-11-02	100.0	99.8	99.9
SCHLUMBERGER	J5S	C384706	02-11-02	100.0	99.6	99.9
SCHLUMBERGER	J5S	C384707	02-11-02	100.1	100.2	100.0

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PPFACTOR
SCHLUMBERGER	J5S	C384708	02-11-02	99.9	99.8	100.3
SCHLUMBERGER	J5S	C384709	02-11-02	100.0	99.9	99.8
SCHLUMBERGER	J5S	C384710	02-11-02	100.0	100.0	100.0
SCHLUMBERGER	J5S	C384711	02-11-02	100.0	100.0	100.1
SCHLUMBERGER	J5S	C384712	02-11-02	100.1	100.3	99.5
SCHLUMBERGER	J5S	C384713	02-11-02	100.2	99.6	100.4
SCHLUMBERGER	J5S	C384714	02-11-02	100.1	99.8	99.8
SCHLUMBERGER	J5S	C384715	02-11-02	100.0	100.3	99.9
SCHLUMBERGER	J5S	C384716	02-11-02	99.9	99.8	99.6
SCHLUMBERGER	J5S	C384717	02-11-02	100.1	99.9	99.6
SCHLUMBERGER	J5S	C384718	02-11-02	100.2	100.0	99.8
SCHLUMBERGER	J5S	C384719	02-11-02	100.1	100.0	99.7
SCHLUMBERGER	J5S	C384720	02-11-02	100.1	100.1	99.9
SCHLUMBERGER	J5S	C384721	02-11-02	99.9	100.1	99.5
SCHLUMBERGER	J5S	C384722	02-11-02	100.0	100.0	99.6
SCHLUMBERGER	J5S	C384723	02-11-02	100.1	99.7	100.1
SCHLUMBERGER	J5S	C384724	02-11-02	100.0	99.7	100.1
SCHLUMBERGER	J5S	C384725	02-11-02	100.1	100.0	99.7
SCHLUMBERGER	J5S	C384726	02-11-02	100.2	99.9	100.0
SCHLUMBERGER	J5S	C384727	02-11-02	100.0	99.7	99.8
SCHLUMBERGER	J5S	C384728	02-11-02	100.0	99.7	99.5
SCHLUMBERGER	J5S	C384729	02-11-02	100.0	100.0	100.0
SCHLUMBERGER	J5S	C384730	02-11-02	100.0	99.6	99.7
SCHLUMBERGER	J5S	C384731	02-11-02	100.2	100.1	100.2
SCHLUMBERGER	J5S	C384732	02-11-02	100.0	100.2	99.9
SCHLUMBERGER	J5S	C384733	02-11-02	100.2	100.2	100.0
SCHLUMBERGER	J5S	C384734	02-11-02	100.0	100.2	99.8
SCHLUMBERGER	J5S	C384735	02-11-02	100.2	99.9	100.0
SCHLUMBERGER	J5S	C384736	02-11-02	99.9	99.8	99.7
SCHLUMBERGER	J5S	C384737	02-11-02	100.2	100.0	100.0
SCHLUMBERGER	J5S	C384738	02-11-02	100.2	99.8	99.8
SCHLUMBERGER	J5S	C384739	02-11-02	100.1	100.3	99.8
SCHLUMBERGER	J5S	C384740	02-11-02	99.8	99.8	99.5
SCHLUMBERGER	J5S	C384741	02-11-02	100.1	99.9	99.7
SCHLUMBERGER	J5S	C384742	02-11-02	100.0	99.9	100.0
SCHLUMBERGER	J5S	C384743	02-11-02	100.1	99.6	99.4
SCHLUMBERGER	J5S	C384744	02-11-02	100.0	99.8	99.6
SCHLUMBERGER	J5S	C384745	02-11-02	100.0	99.8	99.9
SCHLUMBERGER	J5S	C384746	02-11-02	100.1	100.2	100.0
SCHLUMBERGER	J5S	C384747	02-11-02	100.0	100.1	100.1
SCHLUMBERGER	J5S	C384748	02-11-02	99.9	99.6	99.5
SCHLUMBERGER	J5S	C384749	02-11-02	100.0	100.0	99.9
SCHLUMBERGER	J5S	C384750	02-11-02	100.0	99.8	99.9
SCHLUMBERGER	J5S	C384751	02-11-02	100.1	99.8	100.0
SCHLUMBERGER	J5S	C384752	02-11-02	99.8	99.9	99.3
SCHLUMBERGER	J5S	C384753	02-11-02	100.3	99.7	100.2
SCHLUMBERGER	J5S	C384754	02-11-02	100.1	100.0	100.1
SCHLUMBERGER	J5S	C384755	02-11-02	100.1	99.9	100.1
SCHLUMBERGER	J5S	C384756	02-11-02	100.1	100.3	100.0
SCHLUMBERGER	J5S	C384757	02-11-02	100.3	100.3	100.2
SCHLUMBERGER	J5S	C384758	02-11-02	100.1	100.1	100.0

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

PAGE 29
 RUN DATE: 1/14/03
 RUN TIME: 13.26.53

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	J55	C384759	02-11-02	100.1	99.7	100.2
SCHLUMBERGER	J55	C384760	02-11-02	99.8	100.1	99.4
SCHLUMBERGER	J55	C384761	02-11-02	100.1	99.9	99.6
SCHLUMBERGER	J55	C384762	02-11-02	100.1	100.2	100.3
SCHLUMBERGER	J55	C384763	02-11-02	99.9	99.9	99.9
SCHLUMBERGER	J55	C384764	02-11-02	99.9	99.9	99.6
SCHLUMBERGER	J55	C384765	02-11-02	100.0	100.0	99.9
SCHLUMBERGER	J55	C384766	02-11-02	100.0	100.3	99.7
SCHLUMBERGER	J55	C384767	02-11-02	100.0	99.9	100.0
SCHLUMBERGER	J55	C384768	02-11-02	100.1	100.0	99.8
SCHLUMBERGER	J55	C384769	02-11-02	100.0	100.0	99.8
SCHLUMBERGER	J55	C384770	02-11-02	100.1	99.9	100.1
SCHLUMBERGER	J55	C384771	02-11-02	100.1	99.9	99.9
SCHLUMBERGER	J55	C384772	02-11-02	100.0	99.8	99.9
SCHLUMBERGER	J55	C384773	02-11-02	100.2	100.1	99.8
SCHLUMBERGER	J55	C384774	02-11-02	99.9	100.0	99.8
SCHLUMBERGER	J55	C384775	02-11-02	100.1	99.9	100.1
SCHLUMBERGER	J55	C384776	02-11-02	100.1	100.2	99.9
SCHLUMBERGER	J55	C384777	02-11-02	100.2	100.2	99.9
SCHLUMBERGER	J55	C384778	02-11-02	100.0	99.9	99.6
SCHLUMBERGER	J55	C384779	02-11-02	100.0	99.8	100.0
SCHLUMBERGER	J55	C384780	02-11-02	100.0	99.9	100.5
SCHLUMBERGER	J55	C384781	02-11-02	100.2	100.2	100.1
SCHLUMBERGER	J55	C384782	02-11-02	100.1	100.0	100.0
SCHLUMBERGER	J55	C384783	02-11-02	100.1	100.0	100.1
SCHLUMBERGER	J55	C384784	02-11-02	100.0	99.8	100.1
SCHLUMBERGER	J55	C384785	02-11-02	100.1	99.7	100.0
SCHLUMBERGER	J55	C384786	02-11-02	100.0	99.8	100.1
SCHLUMBERGER	J55	C384787	02-11-02	99.9	100.1	99.6
SCHLUMBERGER	J55	C384788	02-11-02	100.1	100.1	100.3
SCHLUMBERGER	J55	C384789	02-11-02	99.9	99.8	100.1
SCHLUMBERGER	J55	C384790	02-11-02	100.3	100.3	100.2
SCHLUMBERGER	J55	C384791	02-11-02	99.9	100.0	99.8
SCHLUMBERGER	J55	C384792	02-11-02	100.1	99.9	100.1
SCHLUMBERGER	J55	C384793	02-11-02	100.0	100.3	100.0
SCHLUMBERGER	J55	C384794	02-11-02	100.0	99.9	99.9
SCHLUMBERGER	J55	C384795	02-11-02	100.0	99.5	99.5
SCHLUMBERGER	J55	C384796	02-11-02	100.2	99.8	99.9
SCHLUMBERGER	J55	C384797	02-11-02	100.1	100.1	100.2
SCHLUMBERGER	J55	C384798	02-11-02	100.2	99.9	99.8
SCHLUMBERGER	J55	C384799	02-11-02	99.9	99.8	99.9
SCHLUMBERGER	J55	C384800	02-11-02	99.9	99.8	100.0
SCHLUMBERGER	J55	C384801	02-11-02	100.0	99.8	99.8
SCHLUMBERGER	J55	C384802	02-11-02	100.0	99.9	100.0
SCHLUMBERGER	J55	C384803	02-11-02	100.0	99.8	99.8
SCHLUMBERGER	J55	C384804	02-11-02	100.1	99.9	100.2
SCHLUMBERGER	J55	C384805	02-11-02	99.8	99.9	99.7
SCHLUMBERGER	J55	C384806	02-11-02	100.0	100.0	99.5
SCHLUMBERGER	J55	C384807	02-11-02	100.1	99.8	100.3
SCHLUMBERGER	J55	C384808	02-11-02	99.9	99.6	100.1
SCHLUMBERGER	J55	C384809	02-11-02	99.9	99.8	100.2

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

PAGE 30
 RUN DATE: 1/14/03
 RUN TIME: 13.26.53

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	J55	C384810	02-11-02	100.0	100.1	100.5
SCHLUMBERGER	J55	C384811	02-11-02	100.0	99.6	99.8
SCHLUMBERGER	J55	C384812	02-11-02	100.0	99.7	100.0
SCHLUMBERGER	J55	C384813	02-11-02	100.0	99.9	99.5
SCHLUMBERGER	J55	C384814	02-11-02	99.9	99.9	99.9
SCHLUMBERGER	J55	C384815	02-11-02	100.1	99.9	100.4
SCHLUMBERGER	J55	C384816	02-11-02	99.9	100.0	100.1
SCHLUMBERGER	J55	C384817	02-11-02	100.0	99.9	100.0
SCHLUMBERGER	J55	C384818	02-11-02	100.0	99.9	100.0
SCHLUMBERGER	J55	C384819	02-11-02	100.0	99.9	99.5
SCHLUMBERGER	J55	C384820	02-11-02	100.1	99.8	99.7
SCHLUMBERGER	J55	C384821	02-11-02	99.9	100.0	100.1
SCHLUMBERGER	J55	C384822	02-11-02	100.0	99.8	100.3
SCHLUMBERGER	J55	C384823	02-11-02	100.0	100.1	100.1
SCHLUMBERGER	J55	C384824	02-11-02	100.0	99.9	99.9
SCHLUMBERGER	J55	C384825	02-11-02	99.8	99.8	99.5
SCHLUMBERGER	J55	C384826	02-11-02	100.0	100.0	100.0
SCHLUMBERGER	J55	C384827	02-11-02	99.9	100.2	100.5
SCHLUMBERGER	J55	C384828	02-11-02	99.9	100.0	99.4
SCHLUMBERGER	J55	C384829	02-11-02	99.8	99.9	99.7
SCHLUMBERGER	J55	C384830	02-11-02	100.0	99.9	100.3
SCHLUMBERGER	J55	C384831	02-11-02	100.2	99.9	100.1
SCHLUMBERGER	J55	C384832	02-11-02	100.0	99.8	99.8
SCHLUMBERGER	J55	C384833	02-11-02	100.0	99.7	99.6
SCHLUMBERGER	J55	C384834	02-11-02	99.8	100.1	99.8
SCHLUMBERGER	J55	C384835	02-11-02	100.1	99.9	99.8
SCHLUMBERGER	J55	C384836	02-11-02	99.9	100.2	100.1
SCHLUMBERGER	J55	C384837	02-11-02	100.1	100.1	99.6
SCHLUMBERGER	J55	C384838	02-11-02	100.1	100.2	100.1
SCHLUMBERGER	J55	C384839	02-11-02	99.9	99.8	100.1
SCHLUMBERGER	J55	C384840	02-11-02	99.9	100.1	99.8
SCHLUMBERGER	J55	C384841	02-11-02	100.1	99.9	99.9
SCHLUMBERGER	J55	C384842	02-11-02	100.1	99.7	100.2
SCHLUMBERGER	J55	C384843	02-11-02	99.9	99.9	100.1
SCHLUMBERGER	J55	C384844	02-11-02	99.9	99.9	99.8
SCHLUMBERGER	J55	C384845	02-11-02	100.0	100.0	99.9
SCHLUMBERGER	J55	C384846	02-11-02	100.1	99.9	100.3
SCHLUMBERGER	J55	C384847	02-11-02	100.1	100.1	100.1
SCHLUMBERGER	J55	C384848	02-11-02	100.2	100.1	99.8
SCHLUMBERGER	J55	C384849	02-11-02	100.1	100.1	100.1
SCHLUMBERGER	J55	C384850	02-11-02	100.0	99.9	99.8
SCHLUMBERGER	J55	C384851	02-11-02	99.9	99.9	99.7
SCHLUMBERGER	J55	C384852	02-11-02	99.8	99.7	99.7
SCHLUMBERGER	J55	C384853	02-11-02	100.0	100.1	99.9
SCHLUMBERGER	J55	C384854	02-11-02	100.1	100.1	99.5
SCHLUMBERGER	J55	C384855	02-11-02	100.0	99.9	100.1
SCHLUMBERGER	J55	C384856	02-11-02	99.9	100.0	99.8
SCHLUMBERGER	J55	C384857	02-11-02	100.1	99.9	99.8
SCHLUMBERGER	J55	C384858	02-11-02	100.1	99.7	100.6
SCHLUMBERGER	J55	C384859	02-11-02	100.1	99.9	99.7
SCHLUMBERGER	J55	C384860	02-11-02	99.9	99.8	99.9

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	J55	C384861	02-11-02	100.1	100.1	99.8
SCHLUMBERGER	J55	C384862	02-11-02	100.1	100.2	99.9
SCHLUMBERGER	J55	C384863	02-11-02	99.9	99.8	99.5
SCHLUMBERGER	J55	C384864	02-11-02	100.1	99.9	99.5
SCHLUMBERGER	J55	C384865	02-11-02	99.9	99.6	99.7
SCHLUMBERGER	J55	C384866	02-11-02	100.1	100.3	100.1
SCHLUMBERGER	J55	C384867	02-11-02	100.3	100.3	100.3
SCHLUMBERGER	J55	C384868	02-11-02	100.1	100.0	100.5
SCHLUMBERGER	J55	C384869	02-11-02	100.1	100.8	99.6
SCHLUMBERGER	J55	C384870	02-11-02	100.2	99.8	100.1
SCHLUMBERGER	J55	C384871	02-11-02	100.1	100.3	99.9
SCHLUMBERGER	J55	C384872	02-11-02	100.0	100.1	100.0
SCHLUMBERGER	J55	C384873	02-11-02	100.0	100.1	100.2
SCHLUMBERGER	J55	C384874	02-11-02	100.1	100.0	99.9
SCHLUMBERGER	J55	C384875	02-11-02	100.2	100.3	100.1
SCHLUMBERGER	J55	C384876	02-11-02	100.0	99.6	99.6
SCHLUMBERGER	J55	C384877	02-11-02	100.0	100.1	100.1
SCHLUMBERGER	J55	C384878	02-11-02	99.9	100.0	99.8
SCHLUMBERGER	J55	C384879	02-11-02	100.1	100.1	99.7
SCHLUMBERGER	J55	C384880	02-11-02	99.9	100.0	99.8
SCHLUMBERGER	J55	C384881	02-11-02	99.9	99.9	99.9
SCHLUMBERGER	J55	C384882	02-11-02	100.3	100.2	100.3
SCHLUMBERGER	J55	C384883	02-11-02	100.1	100.1	100.0
SCHLUMBERGER	J55	C384884	02-11-02	100.1	100.2	99.9
SCHLUMBERGER	J55	C384885	02-11-02	100.3	100.0	100.1
SCHLUMBERGER	J55	C384886	02-11-02	100.2	100.4	100.5
SCHLUMBERGER	J55	C384887	02-11-02	100.0	99.9	99.8
SCHLUMBERGER	J55	C384888	02-11-02	100.0	100.0	99.9
SCHLUMBERGER	J55	C384889	02-11-02	99.9	99.8	100.1
SCHLUMBERGER	J55	C384890	02-11-02	100.0	99.8	99.6
SCHLUMBERGER	J55	C384891	02-11-02	100.2	100.2	99.4
SCHLUMBERGER	J55	C384892	02-11-02	100.2	99.9	100.0
SCHLUMBERGER	J55	C384893	02-11-02	100.2	100.1	99.9
SCHLUMBERGER	J55	C384894	02-11-02	100.0	100.0	100.2
SCHLUMBERGER	J55	C384895	02-11-02	100.1	100.0	100.0
SCHLUMBERGER	J55	C384896	02-11-02	100.1	99.7	100.0
SCHLUMBERGER	J55	C384897	02-11-02	100.2	100.3	100.3
SCHLUMBERGER	J55	C384898	02-11-02	99.8	99.9	100.0
SCHLUMBERGER	J55	C384899	02-11-02	99.9	99.9	99.9
SCHLUMBERGER	J55	C384900	02-11-02	100.1	100.1	100.0
SCHLUMBERGER	J55	C384901	02-11-02	100.1	100.1	99.8
SCHLUMBERGER	J55	C384902	02-11-02	100.0	99.8	99.7
SCHLUMBERGER	J55	C384903	02-11-02	100.1	99.7	99.9
SCHLUMBERGER	J55	C384904	02-11-02	100.2	99.9	100.0
SCHLUMBERGER	J55	C384905	02-11-02	100.1	100.0	99.8
SCHLUMBERGER	J55	C384906	02-11-02	100.0	99.8	99.9
SCHLUMBERGER	J55	C384907	02-11-02	100.1	99.9	100.1
SCHLUMBERGER	J55	C384908	02-11-02	100.1	100.0	99.8
SCHLUMBERGER	J55	C384909	02-11-02	100.1	100.0	100.0
SCHLUMBERGER	J55	C384910	02-11-02	99.9	99.8	100.4
SCHLUMBERGER	J55	C384911	02-11-02	100.0	100.0	99.6

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

PAGE 32
 RUN DATE: 1/14/03
 RUN TIME: 13.26.53

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	J5S	C384912	02-11-02	99.9	99.7	99.9
SCHLUMBERGER	J5S	C384913	02-11-02	100.1	100.0	99.8
SCHLUMBERGER	J5S	C384914	02-11-02	100.1	99.8	99.7
SCHLUMBERGER	J5S	C384915	02-11-02	99.9	99.8	99.7
SCHLUMBERGER	J5S	C384916	02-11-02	99.9	99.7	100.2
SCHLUMBERGER	J5S	C384917	02-11-02	100.0	99.7	100.4
SCHLUMBERGER	J5S	C384918	02-11-02	100.0	99.9	99.9
SCHLUMBERGER	J5S	C384919	02-11-02	99.9	99.8	100.1
SCHLUMBERGER	J5S	C384920	02-11-02	100.0	99.9	99.9
SCHLUMBERGER	J5S	C384921	02-11-02	99.9	99.6	99.9
SCHLUMBERGER	J5S	C384922	02-11-02	100.0	100.0	100.1
SCHLUMBERGER	J5S	C384923	02-11-02	100.2	100.0	100.2
SCHLUMBERGER	J5S	C384924	02-11-02	100.2	100.2	100.4
SCHLUMBERGER	J5S	C384925	02-11-02	100.0	100.0	100.2
SCHLUMBERGER	J5S	C384926	02-11-02	100.1	100.2	100.1
SCHLUMBERGER	J5S	C384927	02-11-02	100.0	100.1	99.8
SCHLUMBERGER	J5S	C384928	02-11-02	100.0	99.9	100.0
SCHLUMBERGER	J5S	C384929	02-11-02	100.0	99.9	99.6
SCHLUMBERGER	J5S	C384930	02-11-02	99.8	99.8	99.9
SCHLUMBERGER	J5S	C384931	02-11-02	100.1	100.4	100.3
SCHLUMBERGER	J5S	C384932	02-11-02	99.8	100.0	100.1
SCHLUMBERGER	J5S	C384933	02-11-02	99.8	99.9	99.9
SCHLUMBERGER	J5S	C384934	02-11-02	100.0	99.9	99.6
SCHLUMBERGER	J5S	C384935	02-11-02	99.9	99.7	99.7
SCHLUMBERGER	J5S	C384936	02-11-02	100.0	100.0	99.9
SCHLUMBERGER	J5S	C384937	02-11-02	99.9	100.0	99.8
SCHLUMBERGER	J5S	C384938	02-11-02	99.9	99.8	100.0
SCHLUMBERGER	J5S	C384939	02-11-02	100.1	100.0	100.1
SCHLUMBERGER	J5S	C384940	02-11-02	100.1	100.3	100.0
SCHLUMBERGER	J5S	C384941	02-11-02	99.8	99.7	99.7
SCHLUMBERGER	J5S	C384942	02-11-02	100.1	99.7	99.7
SCHLUMBERGER	J5S	C384943	02-11-02	100.0	100.0	100.1
SCHLUMBERGER	J5S	C384944	02-11-02	100.0	99.8	99.7
SCHLUMBERGER	J5S	C384945	02-11-02	100.3	100.0	99.9
SCHLUMBERGER	J5S	C384946	02-11-02	100.1	100.0	99.9
SCHLUMBERGER	J5S	C384947	02-11-02	100.0	99.8	99.7
SCHLUMBERGER	J5S	C384948	02-11-02	100.0	99.9	99.5
SCHLUMBERGER	J5S	C384949	02-11-02	100.1	100.0	100.0
SCHLUMBERGER	J5S	C384950	02-11-02	99.9	99.7	99.6
SCHLUMBERGER	J5S	C384951	02-11-02	100.2	100.0	100.2
SCHLUMBERGER	J5S	C384952	02-11-02	100.1	99.7	100.0
SCHLUMBERGER	J5S	C384953	02-11-02	99.9	99.8	99.8
SCHLUMBERGER	J5S	C384954	02-11-02	100.0	100.0	100.0
SCHLUMBERGER	J5S	C384955	02-11-02	100.1	99.7	100.4
SCHLUMBERGER	J5S	C384956	02-11-02	100.1	100.3	100.3
SCHLUMBERGER	J5S	C384957	02-11-02	100.3	99.9	100.2
SCHLUMBERGER	J5S	C384958	02-11-02	100.0	99.8	100.1
SCHLUMBERGER	J5S	C384959	02-11-02	100.0	99.9	99.8
SCHLUMBERGER	J5S	C384960	02-11-02	100.2	99.8	99.8
SCHLUMBERGER	J5S	C384961	02-11-02	100.2	99.8	100.3
SCHLUMBERGER	J5S	C384962	02-11-02	100.3	100.0	100.4

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	J55	C384963	02-11-02	100.1	100.0	100.1
SCHLUMBERGER	J55	C384964	02-11-02	100.1	99.8	99.7
SCHLUMBERGER	J55	C384965	02-11-02	100.1	100.2	100.2
SCHLUMBERGER	J55	C384966	02-11-02	100.0	99.8	99.8
SCHLUMBERGER	J55	C384967	02-11-02	99.9	99.8	99.9
SCHLUMBERGER	J55	C384968	02-11-02	99.7	99.9	99.9
SCHLUMBERGER	J55	C384969	02-11-02	100.0	99.8	99.8
SCHLUMBERGER	J55	C384970	02-11-02	100.2	100.0	100.0
SCHLUMBERGER	J55	C384971	02-11-02	100.1	99.6	99.6
SCHLUMBERGER	J55	C384972	02-11-02	100.1	100.0	100.0
SCHLUMBERGER	J55	C384973	02-11-02	100.0	99.7	100.0
SCHLUMBERGER	J55	C384974	02-11-02	99.8	99.7	99.8
SCHLUMBERGER	J55	C384975	02-11-02	100.3	99.9	100.3
SCHLUMBERGER	J55	C384976	02-11-02	100.1	99.8	100.1
SCHLUMBERGER	J55	C384977	02-11-02	100.0	100.1	100.0
SCHLUMBERGER	J55	C384978	02-11-02	99.9	99.6	99.6
SCHLUMBERGER	J55	C384979	02-11-02	100.1	100.2	100.2
SCHLUMBERGER	J55	C384980	02-11-02	100.0	99.7	100.0
SCHLUMBERGER	J55	C384981	02-11-02	99.9	99.7	99.7
SCHLUMBERGER	J55	C384982	02-11-02	100.0	100.0	100.0
SCHLUMBERGER	J55	C384983	02-11-02	100.1	99.9	100.0
SCHLUMBERGER	J55	C384984	02-11-02	100.1	99.8	99.9
SCHLUMBERGER	J55	C384985	02-11-02	100.1	99.8	100.2
SCHLUMBERGER	J55	C384986	02-11-02	100.0	99.9	99.7
SCHLUMBERGER	J55	C384987	02-11-02	100.0	100.0	100.0
SCHLUMBERGER	J55	C384988	02-11-02	100.1	99.9	100.5
SCHLUMBERGER	J55	C384989	02-11-02	100.1	99.9	100.2
SCHLUMBERGER	J55	C384990	02-11-02	100.0	99.8	100.2
SCHLUMBERGER	J55	C384991	02-11-02	100.0	100.0	100.0
SCHLUMBERGER	J55	C384992	02-11-02	100.3	100.3	100.0
SCHLUMBERGER	J55	C384993	02-11-02	100.1	99.6	99.6
SCHLUMBERGER	J55	C384994	02-11-02	100.1	100.0	99.7
SCHLUMBERGER	J55	C384995	02-11-02	100.0	99.9	99.9
SCHLUMBERGER	J55	C384996	02-11-02	100.3	100.4	100.4
SCHLUMBERGER	J55	C384997	02-11-02	99.9	99.7	100.0
SCHLUMBERGER	J55	C384998	02-11-02	100.0	100.1	100.3
SCHLUMBERGER	J55	C384999	02-11-02	100.0	99.9	99.9
SCHLUMBERGER	J55	C385000	02-11-02	99.9	100.0	99.8
SCHLUMBERGER	J55	C385001	02-11-02	100.0	99.7	99.9
SCHLUMBERGER	J55	C385002	02-11-02	100.0	99.7	99.9
SCHLUMBERGER	J55	C385003	02-11-02	100.0	100.1	100.4
SCHLUMBERGER	J55	C385004	02-11-02	100.0	100.2	99.8
SCHLUMBERGER	J55	C385005	02-11-02	100.0	100.1	100.2
SCHLUMBERGER	J55	C385006	02-11-02	100.0	100.3	99.9
SCHLUMBERGER	J55	C385007	02-11-02	100.3	100.0	99.8
SCHLUMBERGER	J55	C385008	02-11-02	100.0	99.8	100.5
SCHLUMBERGER	J55	C385009	02-11-02	100.0	99.8	100.1
SCHLUMBERGER	J55	C385010	02-11-02	100.0	99.9	99.8
SCHLUMBERGER	J55	C385011	02-11-02	100.1	99.9	100.2
SCHLUMBERGER	J55	C385012	02-11-02	100.0	99.9	100.0
SCHLUMBERGER	J55	C385013	02-11-02	100.1	100.0	100.0

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

PAGE 34
 RUN DATE: 1/14/03
 RUN TIME: 13.26.53

MANUFACTURER	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	C385014	02-11-02	100.1	100.0	99.7
SCHLUMBERGER	C385015	02-11-02	100.0	99.7	100.4
SCHLUMBERGER	C385016	02-11-02	100.0	99.8	100.0
SCHLUMBERGER	C385017	02-11-02	100.2	99.8	99.6
SCHLUMBERGER	C385018	02-11-02	99.9	99.8	99.7
SCHLUMBERGER	C385019	02-11-02	100.0	99.8	100.1
SCHLUMBERGER	C385020	02-11-02	100.2	100.3	100.4
SCHLUMBERGER	C385021	02-11-02	99.9	100.2	100.2
SCHLUMBERGER	C385022	02-11-02	100.0	100.5	100.3
SCHLUMBERGER	C385023	02-11-02	100.1	99.8	100.2
SCHLUMBERGER	C385024	02-11-02	99.9	100.2	99.8
SCHLUMBERGER	C385025	02-11-02	100.0	100.3	100.2
SCHLUMBERGER	C385026	02-11-02	100.1	100.2	99.9
SCHLUMBERGER	C385027	02-11-02	99.9	100.0	99.8
SCHLUMBERGER	C385028	02-11-02	100.0	100.0	100.1
SCHLUMBERGER	C385029	02-11-02	99.8	99.7	99.6
SCHLUMBERGER	C385030	02-11-02	100.0	100.2	99.5
SCHLUMBERGER	C385031	02-11-02	100.2	99.9	100.3
SCHLUMBERGER	C385032	02-11-02	100.0	99.8	100.0
SCHLUMBERGER	C385033	02-11-02	100.0	99.9	99.6
SCHLUMBERGER	C385034	02-11-02	100.1	99.7	100.0
SCHLUMBERGER	C385035	02-11-02	100.0	100.0	99.8
SCHLUMBERGER	C385036	02-11-02	100.1	100.2	100.1
SCHLUMBERGER	C385037	02-11-02	100.0	100.1	100.2
SCHLUMBERGER	C385038	02-11-02	100.1	99.7	99.7
SCHLUMBERGER	C385039	02-11-02	99.8	99.7	100.0
SCHLUMBERGER	C385040	02-11-02	99.8	99.9	100.0
SCHLUMBERGER	C385041	02-11-02	100.2	99.7	100.0
SCHLUMBERGER	C385042	02-11-02	100.1	100.0	100.2
SCHLUMBERGER	C385043	02-11-02	100.2	100.2	100.0
SCHLUMBERGER	C385044	02-11-02	100.0	100.0	100.1
SCHLUMBERGER	C385045	02-11-02	99.9	99.9	99.7
SCHLUMBERGER	C385046	02-11-02	99.9	99.9	100.2
SCHLUMBERGER	C385047	02-11-02	100.2	100.0	100.0
SCHLUMBERGER	C385048	02-11-02	100.2	99.9	100.4
SCHLUMBERGER	C385049	02-11-02	99.9	99.7	100.2
SCHLUMBERGER	C385050	02-11-02	100.1	100.2	100.3
SCHLUMBERGER	C385051	02-11-02	100.0	99.9	100.0
SCHLUMBERGER	C385052	02-11-02	100.0	99.8	100.2
SCHLUMBERGER	C385053	02-11-02	100.1	99.9	100.2
SCHLUMBERGER	C385054	02-11-02	99.9	99.7	99.9
SCHLUMBERGER	C385055	02-11-02	99.9	99.8	99.5
SCHLUMBERGER	C385056	02-11-02	100.0	100.1	100.2
SCHLUMBERGER	C385057	02-11-02	100.0	100.1	100.0
SCHLUMBERGER	C385058	02-11-02	100.0	99.7	100.1
SCHLUMBERGER	C385059	02-11-02	100.1	99.8	100.2
SCHLUMBERGER	C385060	02-11-02	100.0	100.0	100.2
SCHLUMBERGER	C385061	02-11-02	100.0	99.8	100.1
SCHLUMBERGER	C385062	02-11-02	100.2	100.4	100.4
SCHLUMBERGER	C385063	02-11-02	99.9	99.8	100.1
SCHLUMBERGER	C385064	02-11-02	100.0	99.7	100.1

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

PAGE 35
 RUN DATE: 1/14/03
 RUN TIME: 13.26.53

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	J5S	C385065	02-11-02	100.0	99.9	100.2
SCHLUMBERGER	J5S	C385066	02-11-02	100.1	99.8	100.0
SCHLUMBERGER	J5S	C385067	02-11-02	100.1	99.9	100.0
SCHLUMBERGER	J5S	C385068	02-11-02	100.0	99.6	99.4
SCHLUMBERGER	J5S	C385069	02-11-02	100.0	100.0	99.9
SCHLUMBERGER	J5S	C385070	02-11-02	100.1	100.0	99.7
SCHLUMBERGER	J5S	C385071	02-11-02	99.9	100.0	99.9
SCHLUMBERGER	J5S	C385072	02-11-02	100.2	100.2	99.9
SCHLUMBERGER	J5S	C385073	02-11-02	99.8	100.2	100.1
SCHLUMBERGER	J5S	C385074	02-11-02	100.1	99.7	100.0
SCHLUMBERGER	J5S	C385075	02-11-02	100.1	100.0	100.2
SCHLUMBERGER	J5S	C385076	02-11-02	100.0	99.8	100.2
SCHLUMBERGER	J5S	C385077	02-11-02	100.2	99.7	99.9
SCHLUMBERGER	J5S	C385078	02-11-02	100.3	99.6	100.0
SCHLUMBERGER	J5S	C385079	02-11-02	100.0	100.0	99.7
SCHLUMBERGER	J5S	C385080	02-11-02	100.0	99.8	100.0
SCHLUMBERGER	J5S	C385081	02-11-02	99.9	99.8	99.9
SCHLUMBERGER	J5S	C385082	02-11-02	100.2	99.7	100.1
SCHLUMBERGER	J5S	C385083	02-11-02	100.2	100.2	100.0
SCHLUMBERGER	J5S	C385084	02-11-02	100.2	100.2	100.4
SCHLUMBERGER	J5S	C385085	02-11-02	100.2	100.2	100.4
SCHLUMBERGER	J5S	C385086	02-11-02	100.2	100.3	100.3
SCHLUMBERGER	J5S	C385087	02-11-02	100.1	100.2	100.5
SCHLUMBERGER	J5S	C385088	02-11-02	100.0	100.1	100.1
SCHLUMBERGER	J5S	C385089	02-11-02	99.8	99.8	100.0
SCHLUMBERGER	J5S	C385090	02-11-02	100.0	99.6	100.3
SCHLUMBERGER	J5S	C385091	02-11-02	100.0	99.8	100.2
SCHLUMBERGER	J5S	C385092	02-11-02	100.0	99.7	100.0
SCHLUMBERGER	J5S	C385093	02-11-02	100.1	99.7	100.0
SCHLUMBERGER	J5S	C385094	02-11-02	100.0	100.5	99.8
SCHLUMBERGER	J5S	C385095	02-11-02	100.1	99.8	100.1
SCHLUMBERGER	J5S	C385096	02-11-02	100.1	99.8	99.9
SCHLUMBERGER	J5S	C385097	02-11-02	100.1	100.0	100.1
SCHLUMBERGER	J5S	C385098	02-11-02	100.1	99.7	100.2
SCHLUMBERGER	J5S	C385099	02-11-02	100.0	99.9	100.2
SCHLUMBERGER	J5S	C385100	02-11-02	100.2	100.0	99.9
SCHLUMBERGER	J5S	C385101	02-11-02	100.1	99.9	100.6
SCHLUMBERGER	J5S	C385102	02-11-02	100.1	99.8	100.0
SCHLUMBERGER	J5S	C385103	02-11-02	99.9	99.7	99.7
SCHLUMBERGER	J5S	C385104	02-11-02	100.0	99.6	100.3
SCHLUMBERGER	J5S	C385105	02-11-02	100.1	100.1	99.8
SCHLUMBERGER	J5S	C385106	02-11-02	100.2	100.3	100.4
SCHLUMBERGER	J5S	C385107	02-11-02	100.1	100.4	99.9
SCHLUMBERGER	J5S	C385108	02-11-02	100.1	100.3	100.3
SCHLUMBERGER	J5S	C385109	02-11-02	99.8	99.9	99.7
SCHLUMBERGER	J5S	C385110	02-11-02	100.0	100.0	100.3
SCHLUMBERGER	J5S	C385111	02-11-02	100.1	99.9	99.9
SCHLUMBERGER	J5S	C385112	02-11-02	100.1	100.2	100.0
SCHLUMBERGER	J5S	C385113	02-11-02	100.2	100.4	100.3
SCHLUMBERGER	J5S	C385114	02-11-02	100.1	99.8	100.2
SCHLUMBERGER	J5S	C385115	02-11-02	100.2	99.9	99.7

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

PAGE 36
 RUN DATE: 1/14/03
 RUN TIME: 13.26.53

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	J5S	C385116	02-11-02	99.9	100.0	99.8
SCHLUMBERGER	J5S	C385117	02-11-02	100.2	99.9	100.1
SCHLUMBERGER	J5S	C385118	02-11-02	99.8	100.1	99.7
SCHLUMBERGER	J5S	C385119	02-11-02	99.9	99.8	99.4
SCHLUMBERGER	J5S	C385120	02-11-02	100.0	99.9	100.1
SCHLUMBERGER	J5S	C385121	02-11-02	99.9	99.8	100.0
SCHLUMBERGER	J5S	C385122	02-11-02	100.2	99.9	100.2
SCHLUMBERGER	J5S	C385123	02-11-02	100.0	100.0	99.6
SCHLUMBERGER	J5S	C385124	02-11-02	100.1	99.9	99.9
SCHLUMBERGER	J5S	C385125	02-11-02	100.1	99.9	100.2
SCHLUMBERGER	J5S	C385126	02-11-02	100.0	100.0	100.3
SCHLUMBERGER	J5S	C385127	02-11-02	100.2	99.9	100.3
SCHLUMBERGER	J5S	C385128	02-11-02	100.2	100.1	99.4
SCHLUMBERGER	J5S	C385129	02-11-02	100.0	99.9	99.3
SCHLUMBERGER	J5S	C385130	02-11-02	100.0	100.0	99.9
SCHLUMBERGER	J5S	C385131	02-11-02	100.0	99.8	99.7
SCHLUMBERGER	J5S	C385132	02-11-02	99.9	100.0	99.4
SCHLUMBERGER	J5S	C385133	02-11-02	99.8	100.0	99.4
SCHLUMBERGER	J5S	C385134	02-11-02	100.1	99.9	99.4
SCHLUMBERGER	J5S	C385135	02-11-02	100.0	99.9	100.4
SCHLUMBERGER	J5S	C385136	02-11-02	100.3	100.1	100.1
SCHLUMBERGER	J5S	C385137	02-11-02	100.0	99.7	100.4
SCHLUMBERGER	J5S	C385138	02-11-02	100.1	100.1	100.1
SCHLUMBERGER	J5S	C385139	02-11-02	100.2	99.9	100.0
SCHLUMBERGER	J5S	C385140	02-11-02	100.1	100.0	99.7
SCHLUMBERGER	J5S	C385141	02-11-02	99.9	100.1	100.0
SCHLUMBERGER	J5S	C385142	02-11-02	100.3	100.3	100.2
SCHLUMBERGER	J5S	C385143	02-11-02	100.2	99.8	100.2
SCHLUMBERGER	J5S	C385144	02-11-02	99.9	99.7	99.7
SCHLUMBERGER	J5S	C385145	02-11-02	99.9	99.7	99.7
SCHLUMBERGER	J5S	C385146	02-11-02	99.8	99.7	100.0
SCHLUMBERGER	J5S	C385147	02-11-02	100.1	100.2	100.1
SCHLUMBERGER	J5S	C385148	02-11-02	100.1	100.1	100.6
SCHLUMBERGER	J5S	C385149	02-11-02	99.9	100.4	99.9
SCHLUMBERGER	J5S	C385150	02-11-02	100.0	99.7	99.9
SCHLUMBERGER	J5S	C385151	02-11-02	100.0	99.8	100.0
SCHLUMBERGER	J5S	C385152	02-11-02	100.3	100.1	100.4
SCHLUMBERGER	J5S	C385153	02-11-02	100.0	100.2	99.6
SCHLUMBERGER	J5S	C385154	02-11-02	100.1	99.9	99.8
SCHLUMBERGER	J5S	C385155	02-11-02	100.0	99.8	100.2
SCHLUMBERGER	J5S	C385156	02-11-02	100.1	100.0	100.0
SCHLUMBERGER	J5S	C385157	02-11-02	100.0	99.8	99.7
SCHLUMBERGER	J5S	C385158	02-11-02	100.0	100.0	100.0
SCHLUMBERGER	J5S	C385159	02-11-02	100.0	100.1	99.6
SCHLUMBERGER	J5S	C385160	02-11-02	99.9	100.2	99.9
SCHLUMBERGER	J5S	C385161	02-11-02	100.1	99.6	99.4
SCHLUMBERGER	J5S	C385162	02-11-02	100.1	100.3	100.0
SCHLUMBERGER	J5S	C385163	02-11-02	100.3	99.9	99.4
SCHLUMBERGER	J5S	C385164	02-11-02	100.0	99.9	99.9
SCHLUMBERGER	J5S	C385165	02-11-02	100.0	100.1	99.7
SCHLUMBERGER	J5S	C385166	02-11-02	99.8	99.6	100.1

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	J55	C385167	02-11-02	100.0	100.1	99.8
SCHLUMBERGER	J55	C385168	02-11-02	100.0	100.3	100.2
SCHLUMBERGER	J55	C385169	02-11-02	99.9	100.1	99.7
SCHLUMBERGER	J55	C385170	02-11-02	100.1	99.7	99.3
SCHLUMBERGER	J55	C385171	02-11-02	99.9	100.0	99.9
SCHLUMBERGER	J55	C385172	02-11-02	100.1	100.0	99.9
SCHLUMBERGER	J55	C385173	02-11-02	99.9	99.8	99.9
SCHLUMBERGER	J55	C385174	02-11-02	100.2	99.9	99.9
SCHLUMBERGER	J55	C385175	02-11-02	100.0	100.0	99.5
SCHLUMBERGER	J55	C385176	02-11-02	99.9	99.7	99.9
SCHLUMBERGER	J55	C385177	02-11-02	100.0	99.7	99.8
SCHLUMBERGER	J55	C385178	02-11-02	100.1	100.0	100.0
SCHLUMBERGER	J55	C385179	02-11-02	100.1	100.1	99.7
SCHLUMBERGER	J55	C385180	02-11-02	99.9	100.0	100.1
SCHLUMBERGER	J55	C385181	02-11-02	100.1	99.9	100.3
SCHLUMBERGER	J55	C385182	02-11-02	100.0	100.4	100.4
SCHLUMBERGER	J55	C385183	02-11-02	100.0	100.0	100.1
SCHLUMBERGER	J55	C385184	02-11-02	100.2	99.6	99.8
SCHLUMBERGER	J55	C385185	02-11-02	100.1	99.9	99.8
SCHLUMBERGER	J55	C385186	02-11-02	100.0	99.8	99.8
SCHLUMBERGER	J55	C385187	02-11-02	100.0	99.8	100.0
SCHLUMBERGER	J55	C385188	02-11-02	99.9	100.1	99.9
SCHLUMBERGER	J55	C385189	02-11-02	100.2	100.0	100.0
SCHLUMBERGER	J55	C385190	02-11-02	100.1	100.1	100.1
SCHLUMBERGER	J55	C385191	02-11-02	100.0	99.7	100.0
SCHLUMBERGER	J55	C385192	02-11-02	99.9	100.0	100.2
SCHLUMBERGER	J55	C385193	02-11-02	99.9	99.7	99.4
SCHLUMBERGER	J55	C385194	02-11-02	100.0	99.6	99.8
SCHLUMBERGER	J55	C385195	02-11-02	100.0	99.7	100.1
SCHLUMBERGER	J55	C385196	02-11-02	100.0	99.9	100.2
SCHLUMBERGER	J55	C385197	02-11-02	100.0	99.9	99.6
SCHLUMBERGER	J55	C385198	02-11-02	100.1	99.8	100.2
SCHLUMBERGER	J55	C385199	02-11-02	99.9	99.7	99.9
SCHLUMBERGER	J55	C385200	02-11-02	100.2	100.2	100.1
SCHLUMBERGER	J55	C385201	02-11-02	100.0	99.8	99.6
SCHLUMBERGER	J55	C385202	02-11-02	100.0	99.8	99.8
SCHLUMBERGER	J55	C385203	02-11-02	99.8	99.8	99.9
SCHLUMBERGER	J55	C385204	02-11-02	100.2	100.3	99.8
SCHLUMBERGER	J55	C385205	02-11-02	100.2	100.3	100.4
SCHLUMBERGER	J55	C385206	02-11-02	99.9	99.9	100.4
SCHLUMBERGER	J55	C385207	02-11-02	100.0	100.0	100.0
SCHLUMBERGER	J55	C385208	02-11-02	100.0	99.8	100.5
SCHLUMBERGER	J55	C385209	02-11-02	100.0	100.2	100.3
SCHLUMBERGER	J55	C385210	02-11-02	100.0	99.7	99.7
SCHLUMBERGER	J55	C385211	02-11-02	99.9	99.8	99.4
SCHLUMBERGER	J55	C385212	02-11-02	99.9	99.7	99.5
SCHLUMBERGER	J55	C385213	02-11-02	99.8	100.4	99.8
SCHLUMBERGER	J55	C385214	02-11-02	99.9	100.0	100.2
SCHLUMBERGER	J55	C385215	02-11-02	100.0	99.7	99.6
SCHLUMBERGER	J55	C385216	02-11-02	100.0	99.7	99.7
SCHLUMBERGER	J55	C385217	02-11-02	100.1	100.2	99.9
SCHLUMBERGER	J55	C385218	02-11-02	100.1	100.2	99.8

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

PAGE 38
 RUN DATE: 1/14/03
 RUN TIME: 13.26.53

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	J5S	C385218	02-11-02	100.0	99.9	99.8
SCHLUMBERGER	J5S	C385219	02-11-02	100.0	99.7	99.9
SCHLUMBERGER	J5S	C385220	02-11-02	100.0	99.6	99.9
SCHLUMBERGER	J5S	C385221	02-11-02	99.9	100.0	100.0
SCHLUMBERGER	J5S	C385222	02-11-02	99.9	99.9	99.4
SCHLUMBERGER	J5S	C385223	02-11-02	100.0	99.8	99.7
SCHLUMBERGER	J5S	C385224	02-11-02	100.2	100.0	100.3
SCHLUMBERGER	J5S	C385225	02-11-02	99.9	99.7	99.9
SCHLUMBERGER	J5S	C385226	02-11-02	100.1	100.2	100.0
SCHLUMBERGER	J5S	C385227	02-11-02	100.2	99.9	100.2
SCHLUMBERGER	J5S	C385228	02-11-02	100.0	100.5	99.9
SCHLUMBERGER	J5S	C385229	02-11-02	100.0	100.0	99.9
SCHLUMBERGER	J5S	C385230	02-11-02	100.0	99.8	99.9
SCHLUMBERGER	J5S	C385231	02-11-02	100.0	99.8	100.3
SCHLUMBERGER	J5S	C385232	02-11-02	99.9	99.8	100.0
SCHLUMBERGER	J5S	C385233	02-11-02	100.1	100.3	99.8
SCHLUMBERGER	J5S	C385234	02-11-02	100.2	100.5	99.8
SCHLUMBERGER	J5S	C385235	02-11-02	100.2	99.9	100.4
SCHLUMBERGER	J5S	C385236	02-11-02	100.1	99.7	99.6
SCHLUMBERGER	J5S	C385237	02-11-02	100.0	99.9	100.2
SCHLUMBERGER	J5S	C385238	02-11-02	100.2	99.9	100.1
SCHLUMBERGER	J5S	C385239	02-11-02	100.2	100.1	100.4
SCHLUMBERGER	J5S	C385240	02-11-02	100.1	100.2	100.1
SCHLUMBERGER	J5S	C385241	02-11-02	100.0	100.1	100.1
SCHLUMBERGER	J5S	C385242	02-11-02	100.2	99.9	100.2
SCHLUMBERGER	J5S	C385243	02-11-02	100.2	100.3	100.0
SCHLUMBERGER	J5S	C385244	02-11-02	100.1	99.7	100.2
SCHLUMBERGER	J5S	C385245	02-11-02	100.1	100.1	100.1
SCHLUMBERGER	J5S	C385246	02-11-02	100.0	99.8	99.9
SCHLUMBERGER	J5S	C385247	02-11-02	100.0	99.9	99.8
SCHLUMBERGER	J5S	C385248	02-11-02	100.0	99.8	99.6
SCHLUMBERGER	J5S	C385249	02-11-02	100.0	100.1	99.9
SCHLUMBERGER	J5S	C385250	02-11-02	100.0	99.7	99.7
SCHLUMBERGER	J5S	C385251	02-11-02	100.2	100.5	99.8
SCHLUMBERGER	J5S	C385252	02-11-02	100.1	99.7	99.9
SCHLUMBERGER	J5S	C385253	02-11-02	100.1	100.0	100.3
SCHLUMBERGER	J5S	C385254	02-11-02	100.0	99.6	100.2
SCHLUMBERGER	J5S	C385255	02-11-02	100.1	100.1	99.9
SCHLUMBERGER	J5S	C385256	02-11-02	100.0	100.2	100.2
SCHLUMBERGER	J5S	C385257	02-11-02	100.0	99.6	100.2
SCHLUMBERGER	J5S	C385258	02-11-02	99.9	99.9	99.9
SCHLUMBERGER	J5S	C385259	02-11-02	100.0	99.9	99.7
SCHLUMBERGER	J5S	C385260	02-11-02	100.0	99.3	100.4
SCHLUMBERGER	J5S	C385261	02-11-02	100.2	100.0	100.0
SCHLUMBERGER	J5S	C385262	02-11-02	100.1	100.1	100.1
SCHLUMBERGER	J5S	C385263	02-11-02	100.1	100.0	100.2
SCHLUMBERGER	J5S	C385264	02-11-02	100.1	99.6	100.1
SCHLUMBERGER	J5S	C385265	02-11-02	100.1	100.2	99.9
SCHLUMBERGER	J5S	C385266	02-11-02	100.0	99.8	100.2
SCHLUMBERGER	J5S	C385267	02-11-02	100.2	99.9	100.2
SCHLUMBERGER	J5S	C385268	02-11-02	100.0	100.0	100.1

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	J55	C385269	02-11-02	100.0	100.1	99.6
SCHLUMBERGER	J55	C385270	02-11-02	100.0	100.2	99.9
SCHLUMBERGER	J55	C385271	02-11-02	100.0	100.2	99.4
SCHLUMBERGER	J55	C385272	02-11-02	100.0	99.7	99.9
SCHLUMBERGER	J55	C385273	02-11-02	100.0	100.0	100.3
SCHLUMBERGER	J55	C385274	02-11-02	99.9	100.1	100.0
SCHLUMBERGER	J55	C385275	02-11-02	100.0	99.8	100.1
SCHLUMBERGER	J55	C385276	02-11-02	100.0	100.0	99.9
SCHLUMBERGER	J55	C385277	02-11-02	99.9	99.9	99.5
SCHLUMBERGER	J55	C385278	02-11-02	99.9	99.8	99.8
SCHLUMBERGER	J55	C385279	02-11-02	99.9	99.7	99.7
SCHLUMBERGER	J55	C385280	02-11-02	99.9	100.0	100.0
SCHLUMBERGER	J55	C385281	02-11-02	100.0	99.8	100.2
SCHLUMBERGER	J55	C385282	02-11-02	100.1	99.7	100.0
SCHLUMBERGER	J55	C385283	02-11-02	100.2	100.0	100.0
SCHLUMBERGER	J55	C385284	02-11-02	100.2	100.0	100.1
SCHLUMBERGER	J55	C385285	02-11-02	99.9	99.7	99.6
SCHLUMBERGER	J55	C385286	02-11-02	100.1	99.8	100.4
SCHLUMBERGER	J55	C385287	02-11-02	100.1	100.2	100.1
SCHLUMBERGER	J55	C385288	02-11-02	100.1	100.3	100.3
SCHLUMBERGER	J55	C385289	02-11-02	100.1	99.9	99.6
SCHLUMBERGER	J55	C385290	02-11-02	100.1	99.6	99.7
SCHLUMBERGER	J55	C385291	02-11-02	100.0	100.0	100.2
SCHLUMBERGER	J55	C385292	02-11-02	100.2	100.0	100.1
SCHLUMBERGER	J55	C385293	02-11-02	100.1	100.2	100.1
SCHLUMBERGER	J55	C385294	02-11-02	100.3	99.6	99.9
SCHLUMBERGER	J55	C385295	02-11-02	100.0	100.2	99.8
SCHLUMBERGER	J55	C385296	02-11-02	100.0	100.1	99.8
SCHLUMBERGER	J55	C385297	02-11-02	100.1	100.5	100.1
SCHLUMBERGER	J55	C385298	02-11-02	100.1	100.3	100.1
SCHLUMBERGER	J55	C385299	02-11-02	100.2	99.9	100.3
SCHLUMBERGER	J55	C385300	02-11-02	100.2	100.2	99.9
SCHLUMBERGER	J55	C385301	02-11-02	100.2	99.7	100.0
SCHLUMBERGER	J55	C385302	02-11-02	100.2	99.9	100.5
SCHLUMBERGER	J55	C385303	02-11-02	99.9	100.3	99.6
SCHLUMBERGER	J55	C385304	02-11-02	99.9	99.6	100.1
SCHLUMBERGER	J55	C385305	02-11-02	100.0	99.8	100.1
SCHLUMBERGER	J55	C385306	02-11-02	100.0	99.9	100.1
SCHLUMBERGER	J55	C385307	02-11-02	99.9	99.9	99.9
SCHLUMBERGER	J55	C385308	02-11-02	100.1	99.9	100.0
SCHLUMBERGER	J55	C385309	02-11-02	99.9	99.7	99.7
SCHLUMBERGER	J55	C385310	02-11-02	100.0	99.8	100.1
SCHLUMBERGER	J55	C385311	02-11-02	100.0	99.9	99.8
SCHLUMBERGER	J55	C385312	02-11-02	100.1	99.9	99.8
SCHLUMBERGER	J55	C385313	02-11-02	99.9	99.9	99.9
SCHLUMBERGER	J55	C385314	02-11-02	99.9	100.0	100.0
SCHLUMBERGER	J55	C385315	02-11-02	99.9	100.3	99.7
SCHLUMBERGER	J55	C385316	02-11-02	100.0	100.0	99.9
SCHLUMBERGER	J55	C385317	02-11-02	100.2	100.3	100.0
SCHLUMBERGER	J55	C385318	02-11-02	100.2	99.9	100.3
SCHLUMBERGER	J55	C385319	02-11-02	99.9	99.7	100.1

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

PAGE 40
 RUN DATE: 1/14/03
 RUN TIME: 13.26.53

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	J55	C385320	02-11-02	100.0	100.3	99.9
SCHLUMBERGER	J55	C385321	02-11-02	100.2	99.9	100.3
SCHLUMBERGER	J55	C385322	02-11-02	100.0	100.1	99.8
SCHLUMBERGER	J55	C385323	02-11-02	100.0	100.0	100.1
SCHLUMBERGER	J55	C385324	02-11-02	100.0	100.0	100.4
SCHLUMBERGER	J55	C385325	02-11-02	100.0	100.0	100.0
SCHLUMBERGER	J55	C385326	02-11-02	100.0	99.8	100.0
SCHLUMBERGER	J55	C385327	02-11-02	100.0	99.8	100.0
SCHLUMBERGER	J55	C385328	02-11-02	100.1	99.9	99.5
SCHLUMBERGER	J55	C385329	02-11-02	100.0	100.3	99.9
SCHLUMBERGER	J55	C385330	02-11-02	100.2	99.9	100.0
SCHLUMBERGER	J55	C385331	02-11-02	100.0	99.8	100.0
SCHLUMBERGER	J55	C385332	02-11-02	100.1	100.0	100.2
SCHLUMBERGER	J55	C385333	02-11-02	100.1	100.1	100.0
SCHLUMBERGER	J55	C385334	02-11-02	100.0	100.1	99.9
SCHLUMBERGER	J55	C385335	02-11-02	100.0	99.9	99.5
SCHLUMBERGER	J55	C385336	02-11-02	100.1	100.2	100.2
SCHLUMBERGER	J55	C385337	02-11-02	99.9	99.8	100.1
SCHLUMBERGER	J55	C385338	02-11-02	100.0	100.2	100.0
SCHLUMBERGER	J55	C385339	02-11-02	99.9	99.8	100.4
SCHLUMBERGER	J55	C385340	02-11-02	100.3	100.1	100.3
SCHLUMBERGER	J55	C385341	02-11-02	99.9	99.8	99.5
SCHLUMBERGER	J55	C385342	02-11-02	100.1	99.8	99.6
SCHLUMBERGER	J55	C385343	02-11-02	100.0	99.9	99.8
SCHLUMBERGER	J55	C385344	02-11-02	99.9	99.8	99.5
SCHLUMBERGER	J55	C385345	02-11-02	100.1	100.3	99.9
SCHLUMBERGER	J55	C385346	02-11-02	99.9	99.9	99.6
SCHLUMBERGER	J55	C385347	02-11-02	100.0	100.0	99.7
SCHLUMBERGER	J55	C385348	02-11-02	100.0	100.0	99.8
SCHLUMBERGER	J55	C385349	02-11-02	100.0	100.1	99.8
SCHLUMBERGER	J55	C385350	02-11-02	100.1	100.2	99.9
SCHLUMBERGER	J55	C385351	02-11-02	99.9	99.9	100.1
SCHLUMBERGER	J55	C385352	02-11-02	99.9	99.9	99.5
SCHLUMBERGER	J55	C385353	02-11-02	100.1	100.1	100.3
SCHLUMBERGER	J55	C385354	02-11-02	100.0	100.1	100.0
SCHLUMBERGER	J55	C385355	02-11-02	100.0	99.9	100.2
SCHLUMBERGER	J55	C385356	02-11-02	100.1	100.1	100.3
SCHLUMBERGER	J55	C385357	02-11-02	100.1	100.1	99.9
SCHLUMBERGER	J55	C385358	02-11-02	100.0	99.8	100.1
SCHLUMBERGER	J55	C385359	02-11-02	100.0	99.9	99.6
SCHLUMBERGER	J55	C385360	02-11-02	99.9	99.8	99.8
SCHLUMBERGER	J55	C385361	02-11-02	100.0	99.8	99.8
SCHLUMBERGER	J55	C385362	02-11-02	100.0	99.9	99.7
SCHLUMBERGER	J55	C385363	02-11-02	100.2	100.1	100.0
SCHLUMBERGER	J55	C385364	02-11-02	100.0	99.9	99.7
SCHLUMBERGER	J55	C385365	02-11-02	99.9	100.0	100.0
SCHLUMBERGER	J55	C385366	02-11-02	100.0	99.9	99.7
SCHLUMBERGER	J55	C385367	02-11-02	100.0	99.8	99.6
SCHLUMBERGER	J55	C385368	02-11-02	100.1	99.8	100.0
SCHLUMBERGER	J55	C385369	02-11-02	100.0	100.0	100.3
SCHLUMBERGER	J55	C385370	02-11-02	100.0	99.9	99.8

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	J55	C385371	02-11-02	100.0	99.9	100.0
SCHLUMBERGER	J55	C385372	02-11-02	100.1	99.9	100.0
SCHLUMBERGER	J55	C385373	02-11-02	99.9	99.9	100.0
SCHLUMBERGER	J55	C385374	02-11-02	99.9	99.9	100.0
SCHLUMBERGER	J55	C385375	02-11-02	100.0	99.7	99.7
SCHLUMBERGER	J55	C385376	02-11-02	99.9	100.1	99.7
SCHLUMBERGER	J55	C385377	02-11-02	100.1	99.8	100.4
SCHLUMBERGER	J55	C385378	02-11-02	100.3	99.8	100.5
SCHLUMBERGER	J55	C385379	02-11-02	99.9	100.0	100.0
SCHLUMBERGER	J55	C385380	02-11-02	100.0	99.8	99.9
SCHLUMBERGER	J55	C385381	02-11-02	100.1	99.8	100.2
SCHLUMBERGER	J55	C385382	02-11-02	100.0	99.9	99.5
SCHLUMBERGER	J55	C385383	02-11-02	100.1	99.8	100.0
SCHLUMBERGER	J55	C385384	02-11-02	99.9	99.8	100.1
SCHLUMBERGER	J55	C385385	02-11-02	100.0	99.9	99.7
SCHLUMBERGER	J55	C385386	02-11-02	100.0	100.2	100.1
SCHLUMBERGER	J55	C385387	02-11-02	100.1	100.3	100.4
SCHLUMBERGER	J55	C385388	02-11-02	100.0	99.7	99.9
SCHLUMBERGER	J55	C385389	02-11-02	100.0	100.2	100.2
SCHLUMBERGER	J55	C385390	02-11-02	100.0	100.4	100.1
SCHLUMBERGER	J55	C385391	02-11-02	100.0	100.0	99.7
SCHLUMBERGER	J55	C385392	02-11-02	100.0	100.1	100.1
SCHLUMBERGER	J55	C385393	02-11-02	100.0	100.1	100.0
SCHLUMBERGER	J55	C385394	02-11-02	100.0	100.1	100.0
SCHLUMBERGER	J55	C385395	02-11-02	100.3	99.7	99.8
SCHLUMBERGER	J55	C385396	02-11-02	100.1	99.9	100.3
SCHLUMBERGER	J55	C385397	02-11-02	100.0	99.7	99.9
SCHLUMBERGER	J55	C385398	02-11-02	100.0	100.1	100.1
SCHLUMBERGER	J55	C385399	02-11-02	100.2	100.1	100.1
SCHLUMBERGER	J55	C385400	02-11-02	100.0	100.0	99.8
SCHLUMBERGER	J55	C385401	02-11-02	100.3	100.2	100.2
SCHLUMBERGER	J55	C385402	02-11-02	100.1	100.1	99.8
SCHLUMBERGER	J55	C385403	02-11-02	100.1	99.9	100.3
SCHLUMBERGER	J55	C385404	02-11-02	100.1	100.1	99.8
SCHLUMBERGER	J55	C385405	02-11-02	100.2	100.0	99.8
SCHLUMBERGER	J55	C385406	02-11-02	100.1	99.8	100.0
SCHLUMBERGER	J55	C385407	02-11-02	100.0	99.7	99.9
SCHLUMBERGER	J55	C385408	02-11-02	100.1	99.9	100.0
SCHLUMBERGER	J55	C385409	02-11-02	100.0	100.3	100.0
SCHLUMBERGER	J55	C385410	02-11-02	100.1	100.1	99.6
SCHLUMBERGER	J55	C385411	02-11-02	100.1	99.7	99.9
SCHLUMBERGER	J55	C385412	02-11-02	100.0	100.0	99.9
SCHLUMBERGER	J55	C385413	02-11-02	100.1	99.8	100.0
SCHLUMBERGER	J55	C385414	02-11-02	99.9	99.8	99.8
SCHLUMBERGER	J55	C385415	02-11-02	100.1	100.0	99.8
SCHLUMBERGER	J55	C385416	02-11-02	99.9	99.8	100.0
SCHLUMBERGER	J55	C385417	02-11-02	100.1	99.7	100.0
SCHLUMBERGER	J55	C385418	02-11-02	99.9	100.3	99.3
SCHLUMBERGER	J55	C385419	02-11-02	100.1	100.0	100.1
SCHLUMBERGER	J55	C385420	02-11-02	100.0	99.9	100.3
SCHLUMBERGER	J55	C385421	02-11-02	100.1	100.0	100.2

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

MANUFACTURER	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	C385422	02-11-02	100.1	100.0	99.7
SCHLUMBERGER	C385423	02-11-02	100.1	100.0	100.0
SCHLUMBERGER	C385424	02-11-02	100.0	100.0	100.0
SCHLUMBERGER	C385425	02-11-02	100.0	99.8	100.0
SCHLUMBERGER	C385426	02-11-02	100.1	100.1	99.9
SCHLUMBERGER	C385427	02-11-02	100.2	100.2	100.3
SCHLUMBERGER	C385428	02-11-02	100.0	99.8	99.9
SCHLUMBERGER	C385429	02-11-02	100.2	100.0	100.1
SCHLUMBERGER	C385430	02-11-02	100.1	99.8	100.0
SCHLUMBERGER	C385431	02-11-02	100.2	100.0	100.2
SCHLUMBERGER	C385432	02-11-02	99.9	100.0	100.3
SCHLUMBERGER	C385433	02-11-02	100.0	99.8	99.8
SCHLUMBERGER	C385434	02-11-02	100.2	100.1	100.0
SCHLUMBERGER	C385435	02-11-02	100.2	100.0	99.9
SCHLUMBERGER	C385436	02-11-02	99.9	99.7	99.8
SCHLUMBERGER	C385437	02-11-02	100.1	99.9	100.0
SCHLUMBERGER	C385438	02-11-02	100.2	100.0	100.2
SCHLUMBERGER	C385439	02-11-02	100.1	100.2	100.0
SCHLUMBERGER	C385440	02-11-02	100.1	100.0	99.6
SCHLUMBERGER	C385441	02-11-02	99.9	99.8	99.8
SCHLUMBERGER	C385442	02-11-02	100.3	100.4	100.3
SCHLUMBERGER	C385443	02-11-02	100.3	99.8	100.0
SCHLUMBERGER	C385444	02-11-02	100.2	100.1	100.4
SCHLUMBERGER	C385445	02-11-02	100.1	99.7	100.1
SCHLUMBERGER	C385446	02-11-02	99.9	100.1	99.8
SCHLUMBERGER	C385447	02-11-02	100.0	99.9	99.6
SCHLUMBERGER	C385448	02-11-02	100.1	99.8	99.9
SCHLUMBERGER	C385449	02-11-02	99.9	99.9	100.0
SCHLUMBERGER	C385450	02-11-02	100.1	100.1	99.9
SCHLUMBERGER	C385451	02-11-02	100.0	100.1	100.1
SCHLUMBERGER	C385452	02-11-02	99.8	100.2	99.6
SCHLUMBERGER	C385453	02-11-02	100.1	99.7	100.1
SCHLUMBERGER	C385454	02-11-02	99.9	99.6	99.6
SCHLUMBERGER	C385455	02-11-02	100.1	100.1	100.0
SCHLUMBERGER	C385456	02-11-02	100.1	100.3	100.1
SCHLUMBERGER	C385457	02-11-02	99.9	100.1	99.9
SCHLUMBERGER	C385458	02-11-02	99.9	100.1	99.9
SCHLUMBERGER	C385459	02-11-02	99.9	100.3	100.3
SCHLUMBERGER	C385460	02-11-02	100.3	100.3	100.1
SCHLUMBERGER	C385461	02-11-02	99.9	100.0	99.9
SCHLUMBERGER	C385462	02-11-02	100.1	99.9	100.1
SCHLUMBERGER	C385463	02-11-02	99.8	99.9	99.5
SCHLUMBERGER	C385464	02-11-02	100.1	99.9	99.9
SCHLUMBERGER	C385465	02-11-02	100.3	100.0	100.1
SCHLUMBERGER	C385466	02-11-02	100.1	99.8	100.0
SCHLUMBERGER	C385467	02-11-02	100.1	100.0	99.9
SCHLUMBERGER	C385468	02-11-02	99.9	99.9	100.2
SCHLUMBERGER	C385469	02-11-02	100.0	99.8	99.8
SCHLUMBERGER	C385470	02-11-02	100.1	100.2	99.7
SCHLUMBERGER	C385471	02-11-02	100.2	99.6	100.0
SCHLUMBERGER	C385472	02-11-02	100.0	99.7	100.2

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	J55	C385473	02-11-02	100.1	99.6	99.9
SCHLUMBERGER	J55	C385474	02-11-02	99.9	99.6	99.9
SCHLUMBERGER	J55	C385475	02-11-02	100.0	99.8	100.0
SCHLUMBERGER	J55	C385476	02-11-02	100.1	99.6	100.3
SCHLUMBERGER	J55	C385477	02-11-02	99.9	100.2	99.6
SCHLUMBERGER	J55	C385478	02-11-02	100.1	100.0	100.0
SCHLUMBERGER	J55	C385479	02-11-02	100.2	100.0	100.3
SCHLUMBERGER	J55	C385480	02-11-02	100.0	99.8	99.5
SCHLUMBERGER	J55	C385481	02-11-02	100.2	99.8	100.3
SCHLUMBERGER	J55	C385482	02-11-02	100.3	100.0	100.0
SCHLUMBERGER	J55	C385483	02-11-02	100.1	100.1	100.3
SCHLUMBERGER	J55	C385484	02-11-02	100.1	99.9	100.0
SCHLUMBERGER	J55	C385485	02-11-02	100.3	100.1	100.0
SCHLUMBERGER	J55	C385486	02-11-02	99.9	100.1	99.8
SCHLUMBERGER	J55	C385487	02-11-02	100.1	100.1	100.2
SCHLUMBERGER	J55	C385488	02-11-02	99.8	100.2	99.9
SCHLUMBERGER	J55	C385489	02-11-02	100.2	99.9	100.1
SCHLUMBERGER	J55	C385490	02-11-02	100.2	100.0	100.0
SCHLUMBERGER	J55	C385491	02-11-02	100.1	100.1	100.2
SCHLUMBERGER	J55	C385492	02-11-02	100.1	100.1	99.8
SCHLUMBERGER	J55	C385493	02-11-02	100.0	100.2	100.0
SCHLUMBERGER	J55	C385494	02-11-02	100.0	100.0	100.1
SCHLUMBERGER	J55	C385495	02-11-02	99.8	99.7	100.1
SCHLUMBERGER	J55	C385496	02-11-02	100.0	99.9	99.5
SCHLUMBERGER	J55	C385497	02-11-02	100.0	100.0	99.9
SCHLUMBERGER	J55	C385498	02-11-02	99.9	99.8	99.9
SCHLUMBERGER	J55	C385499	02-11-02	100.3	100.2	99.7
SCHLUMBERGER	J55	C385500	02-11-02	100.0	99.6	99.9
SCHLUMBERGER	J55	C385501	02-11-02	99.9	99.7	99.6
SCHLUMBERGER	J55	C385502	02-11-02	100.3	100.3	100.6
SCHLUMBERGER	J55	C385503	02-11-02	100.1	99.8	100.0
SCHLUMBERGER	J55	C385504	02-11-02	100.1	100.2	99.8
SCHLUMBERGER	J55	C385505	02-11-02	100.1	100.0	99.7
SCHLUMBERGER	J55	C385506	02-11-02	99.9	99.8	99.6
SCHLUMBERGER	J55	C385507	02-11-02	100.1	100.0	99.8
SCHLUMBERGER	J55	C385508	02-11-02	100.1	99.8	99.9
SCHLUMBERGER	J55	C385509	02-11-02	100.1	99.8	99.8
SCHLUMBERGER	J55	C385510	02-11-02	100.1	100.2	100.0
SCHLUMBERGER	J55	C385511	02-11-02	99.9	99.8	99.7
SCHLUMBERGER	J55	C385512	02-11-02	100.0	100.2	99.9
SCHLUMBERGER	J55	C385513	02-11-02	100.3	100.2	99.9
SCHLUMBERGER	J55	C385514	02-11-02	100.1	100.0	100.0
SCHLUMBERGER	J55	C385515	02-11-02	100.1	100.1	99.7
SCHLUMBERGER	J55	C385516	02-11-02	100.2	99.8	99.8
SCHLUMBERGER	J55	C385517	02-11-02	100.2	99.8	99.7
SCHLUMBERGER	J55	C385518	02-11-02	100.1	100.2	100.5
SCHLUMBERGER	J55	C385519	02-11-02	99.9	99.9	99.7
SCHLUMBERGER	J55	C385520	02-11-02	99.8	99.9	99.6
SCHLUMBERGER	J55	C385521	02-11-02	99.9	100.0	99.8
SCHLUMBERGER	J55	C385522	02-11-02	100.0	99.8	100.0
SCHLUMBERGER	J55	C385523	02-11-02	100.0	100.3	99.9

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

PAGE 44
 RUN DATE: 1/14/03
 RUN TIME: 13.26.53

MANUFACTURER	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	C385524	02-11-02	100.3	100.0	99.7
SCHLUMBERGER	C385525	02-11-02	100.0	99.8	99.8
SCHLUMBERGER	C385526	02-11-02	100.1	100.0	99.8
SCHLUMBERGER	C385527	02-11-02	100.2	99.8	100.5
SCHLUMBERGER	C385528	02-11-02	100.0	99.7	99.9
SCHLUMBERGER	C385529	02-11-02	100.0	99.9	99.9
SCHLUMBERGER	C385530	02-11-02	100.0	100.0	100.0
SCHLUMBERGER	C385531	02-11-02	100.2	100.3	99.7
SCHLUMBERGER	C385532	02-11-02	100.0	99.6	99.7
SCHLUMBERGER	C385533	02-11-02	100.2	100.1	99.8
SCHLUMBERGER	C385534	02-11-02	100.1	99.9	100.3
SCHLUMBERGER	C385535	02-11-02	100.1	100.1	100.0
SCHLUMBERGER	C385536	02-11-02	100.2	99.9	99.8
SCHLUMBERGER	C385537	02-11-02	100.0	100.0	100.0
SCHLUMBERGER	C385538	02-11-02	100.0	99.7	100.0
SCHLUMBERGER	C385539	02-11-02	100.0	100.0	100.2
SCHLUMBERGER	C385540	02-11-02	100.0	99.8	99.8
SCHLUMBERGER	C385541	02-11-02	100.1	99.9	99.9
SCHLUMBERGER	C385542	02-11-02	100.1	100.0	99.8
SCHLUMBERGER	C385543	02-11-02	100.2	99.8	100.5
SCHLUMBERGER	C385544	02-11-02	100.1	100.1	100.0
SCHLUMBERGER	C385545	02-11-02	100.0	100.3	100.2
SCHLUMBERGER	C385546	02-11-02	100.0	100.1	99.9
SCHLUMBERGER	C385547	02-11-02	100.2	99.9	99.9
SCHLUMBERGER	C385548	02-11-02	99.9	99.8	99.8
SCHLUMBERGER	C385549	02-11-02	100.1	100.0	99.9
SCHLUMBERGER	C385550	02-11-02	100.2	100.0	99.6
SCHLUMBERGER	C385551	02-11-02	99.9	99.8	99.4
SCHLUMBERGER	C385552	02-11-02	99.9	99.6	99.4
SCHLUMBERGER	C385553	02-11-02	99.8	99.9	99.7
SCHLUMBERGER	C385554	02-11-02	100.0	99.6	99.4
SCHLUMBERGER	C385555	02-11-02	99.8	99.6	99.4
SCHLUMBERGER	C385556	02-11-02	100.0	99.8	99.9
SCHLUMBERGER	C385557	02-11-02	99.8	99.7	99.7
SCHLUMBERGER	C385558	02-11-02	100.2	100.0	100.2
SCHLUMBERGER	C385559	02-11-02	100.0	100.0	100.2
SCHLUMBERGER	C385560	02-11-02	99.8	99.9	100.3
SCHLUMBERGER	C385561	02-11-02	100.1	99.9	99.7
SCHLUMBERGER	C385562	02-11-02	100.1	100.0	99.8
SCHLUMBERGER	C385563	02-11-02	100.0	99.9	99.8
SCHLUMBERGER	C385564	02-11-02	100.0	100.0	99.7
SCHLUMBERGER	C385565	02-11-02	100.1	99.9	100.0
SCHLUMBERGER	C385566	02-11-02	100.0	100.1	100.2
SCHLUMBERGER	C385567	02-11-02	99.9	100.1	100.4
SCHLUMBERGER	C385568	02-11-02	99.9	99.8	100.2
SCHLUMBERGER	C385569	02-11-02	100.1	100.0	100.0
SCHLUMBERGER	C385570	02-11-02	99.9	100.0	100.0
SCHLUMBERGER	C385571	02-11-02	100.0	99.9	99.7
SCHLUMBERGER	C385572	02-11-02	100.0	99.9	100.0
SCHLUMBERGER	C385573	02-11-02	99.9	99.9	99.5
SCHLUMBERGER	C385574	02-11-02	100.0	99.9	99.8

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	J55	C385575	02-11-02	99.8	99.7	99.6
SCHLUMBERGER	J55	C385576	02-11-02	100.0	100.0	99.7
SCHLUMBERGER	J55	C385577	02-11-02	100.1	100.3	99.7
SCHLUMBERGER	J55	C385578	02-11-02	100.0	100.3	100.3
SCHLUMBERGER	J55	C385579	02-11-02	99.9	99.8	99.6
SCHLUMBERGER	J55	C385580	02-11-02	100.1	100.1	100.4
SCHLUMBERGER	J55	C385581	02-11-02	100.2	100.2	99.9
SCHLUMBERGER	J55	C385582	02-11-02	100.1	100.1	99.7
SCHLUMBERGER	J55	C385583	02-11-02	100.0	100.1	99.9
SCHLUMBERGER	J55	C385584	02-11-02	100.1	100.2	100.3
SCHLUMBERGER	J55	C385585	02-11-02	99.9	99.8	99.5
SCHLUMBERGER	J55	C385586	02-11-02	99.9	99.8	99.8
SCHLUMBERGER	J55	C385587	02-11-02	99.9	99.8	99.7
SCHLUMBERGER	J55	C385588	02-11-02	100.1	100.1	99.8
SCHLUMBERGER	J55	C385589	02-11-02	99.8	99.8	99.6
SCHLUMBERGER	J55	C385590	02-11-02	100.0	99.9	99.6
SCHLUMBERGER	J55	C385591	02-11-02	100.1	99.6	100.4
SCHLUMBERGER	J55	C385592	02-11-02	100.0	100.0	99.5
SCHLUMBERGER	J55	C385593	02-11-02	100.0	100.0	99.9
SCHLUMBERGER	J55	C385594	02-11-02	99.9	99.9	99.7
SCHLUMBERGER	J55	C385595	02-11-02	100.2	100.0	99.6
SCHLUMBERGER	J55	C385596	02-11-02	100.0	99.8	100.0
SCHLUMBERGER	J55	C385597	02-11-02	100.0	99.9	100.2
SCHLUMBERGER	J55	C385598	02-11-02	99.9	100.0	99.7
SCHLUMBERGER	J55	C385599	02-11-02	100.0	99.9	99.7
SCHLUMBERGER	J55	C385600	02-11-02	100.3	100.0	100.1
SCHLUMBERGER	J55	C385601	02-11-02	100.0	100.2	99.9
SCHLUMBERGER	J55	C385602	02-11-02	100.2	99.7	99.6
SCHLUMBERGER	J55	C385603	02-11-02	100.1	100.4	100.1
SCHLUMBERGER	J55	C385604	02-11-02	99.9	99.8	99.6
SCHLUMBERGER	J55	C385605	02-11-02	99.8	99.8	99.6
SCHLUMBERGER	J55	C385606	02-11-02	100.0	100.1	99.8
SCHLUMBERGER	J55	C385607	02-11-02	99.9	99.8	100.1
SCHLUMBERGER	J55	C385608	02-11-02	100.1	99.9	99.8
SCHLUMBERGER	J55	C385609	02-11-02	100.0	99.7	100.0
SCHLUMBERGER	J55	C385610	02-11-02	100.0	99.9	100.1
SCHLUMBERGER	J55	C385611	02-11-02	99.9	100.2	99.6
SCHLUMBERGER	J55	C385612	02-11-02	100.0	99.8	99.9
SCHLUMBERGER	J55	C385613	02-11-02	100.0	100.0	100.3
SCHLUMBERGER	J55	C385614	02-11-02	99.9	100.1	99.9
SCHLUMBERGER	J55	C385615	02-11-02	100.2	99.9	99.8
SCHLUMBERGER	J55	C385616	02-11-02	99.8	100.2	100.0
SCHLUMBERGER	J55	C385617	02-11-02	99.8	100.1	99.5
SCHLUMBERGER	J55	C385618	02-11-02	100.0	100.1	100.0
SCHLUMBERGER	J55	C385619	02-11-02	99.8	99.7	99.5
SCHLUMBERGER	J55	C385620	02-11-02	100.0	100.0	100.1
SCHLUMBERGER	J55	C385621	02-11-02	99.9	99.8	99.6
SCHLUMBERGER	J55	C385622	02-11-02	99.8	100.0	99.6
SCHLUMBERGER	J55	C385623	02-11-02	100.0	99.7	100.1
SCHLUMBERGER	J55	C385624	02-11-02	100.0	99.8	99.8
SCHLUMBERGER	J55	C385625	02-11-02	99.9	99.7	99.4

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	J5S	C385626	02-11-02	100.0	99.8	100.2
SCHLUMBERGER	J5S	C385627	02-11-02	99.9	100.3	99.7
SCHLUMBERGER	J5S	C385628	02-11-02	100.0	99.9	100.1
SCHLUMBERGER	J5S	C385629	02-11-02	100.0	100.0	100.1
SCHLUMBERGER	J5S	C385630	02-11-02	99.9	100.0	99.6
SCHLUMBERGER	J5S	C385631	02-11-02	99.9	100.0	99.7
SCHLUMBERGER	J5S	C385632	02-11-02	100.2	99.6	100.0
SCHLUMBERGER	J5S	C385633	02-11-02	100.3	99.9	100.4
SCHLUMBERGER	J5S	C385635	02-11-02	100.1	100.2	100.1
SCHLUMBERGER	J5S	C385636	02-08-02	100.1	100.0	99.7
SCHLUMBERGER	J5S	C385637	02-08-02	100.0	100.0	99.9
SCHLUMBERGER	J5S	C385638	02-08-02	100.1	99.8	99.6
SCHLUMBERGER	J5S	C385639	02-08-02	100.0	99.8	100.1
SCHLUMBERGER	J5S	C385640	02-08-02	100.0	100.0	99.8
SCHLUMBERGER	J5S	C385641	02-08-02	99.9	99.7	99.8
SCHLUMBERGER	J5S	C385642	02-08-02	99.8	99.7	100.4
SCHLUMBERGER	J5S	C385643	02-08-02	100.2	99.8	99.6
SCHLUMBERGER	J5S	C385644	02-08-02	100.1	100.1	100.3
SCHLUMBERGER	J5S	C385645	02-08-02	99.8	99.8	100.0
SCHLUMBERGER	J5S	C385646	02-08-02	99.8	99.8	99.3
SCHLUMBERGER	J5S	C385647	02-08-02	100.1	100.0	100.7
SCHLUMBERGER	J5S	C385648	02-08-02	100.2	100.1	100.0
SCHLUMBERGER	J5S	C385649	02-08-02	99.9	100.0	100.2
SCHLUMBERGER	J5S	C385650	02-08-02	100.0	99.8	100.0
SCHLUMBERGER	J5S	C385651	02-08-02	99.8	99.8	99.8
SCHLUMBERGER	J5S	C385652	02-08-02	100.2	99.8	99.8
SCHLUMBERGER	J5S	C385653	02-08-02	99.9	100.2	99.5
SCHLUMBERGER	J5S	C385654	02-08-02	100.1	100.0	99.9
SCHLUMBERGER	J5S	C385655	02-08-02	100.1	100.1	99.9
SCHLUMBERGER	J5S	C385656	02-08-02	99.9	100.1	99.7
SCHLUMBERGER	J5S	C385657	02-08-02	100.0	100.0	99.8
SCHLUMBERGER	J5S	C385658	02-08-02	100.0	100.1	99.9
SCHLUMBERGER	J5S	C385659	02-08-02	99.9	100.4	99.6
SCHLUMBERGER	J5S	C385660	02-08-02	100.2	100.3	100.5
SCHLUMBERGER	J5S	C385661	02-08-02	100.0	99.8	99.7
SCHLUMBERGER	J5S	C385662	02-08-02	100.1	99.9	99.8
SCHLUMBERGER	J5S	C385664	02-08-02	100.0	100.4	99.8
SCHLUMBERGER	J5S	C385665	02-08-02	100.1	100.3	99.6
SCHLUMBERGER	J5S	C385666	02-08-02	99.9	100.3	100.0
SCHLUMBERGER	J5S	C385667	02-08-02	99.9	100.1	99.3
SCHLUMBERGER	J5S	C385668	02-08-02	99.8	100.1	99.7
SCHLUMBERGER	J5S	C385669	02-08-02	99.8	100.1	100.1
SCHLUMBERGER	J5S	C385670	02-08-02	99.8	99.8	99.9
SCHLUMBERGER	J5S	C385671	02-08-02	99.9	100.1	99.8
SCHLUMBERGER	J5S	C385672	02-08-02	100.0	100.1	100.1
SCHLUMBERGER	J5S	C385673	02-08-02	100.0	100.0	99.8
SCHLUMBERGER	J5S	C385674	02-08-02	100.0	99.8	99.8
SCHLUMBERGER	J5S	C385675	02-08-02	100.0	100.2	99.9
SCHLUMBERGER	J5S	C385676	02-08-02	99.8	100.4	99.8

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	J55	C385677	02-08-02	99.8	99.7	99.5
SCHLUMBERGER	J55	C385678	02-08-02	99.9	100.0	99.8
SCHLUMBERGER	J55	C385679	02-08-02	100.0	100.1	99.8
SCHLUMBERGER	J55	C385680	02-08-02	99.9	100.0	99.8
SCHLUMBERGER	J55	C385681	02-08-02	99.9	100.0	99.7
SCHLUMBERGER	J55	C385682	02-08-02	99.9	100.1	99.9
SCHLUMBERGER	J55	C385683	02-08-02	100.0	99.8	99.8
SCHLUMBERGER	J55	C385684	02-08-02	99.8	100.0	99.4
SCHLUMBERGER	J55	C385685	02-08-02	99.8	100.2	99.8
SCHLUMBERGER	J55	C385686	02-08-02	100.0	100.2	99.8
SCHLUMBERGER	J55	C385687	02-08-02	100.1	100.2	100.0
SCHLUMBERGER	J55	C385688	02-08-02	99.9	99.7	100.1
SCHLUMBERGER	J55	C385689	02-08-02	100.0	99.9	100.2
SCHLUMBERGER	J55	C385690	02-08-02	99.8	99.8	99.4
SCHLUMBERGER	J55	C385691	02-08-02	100.1	99.7	99.8
SCHLUMBERGER	J55	C385692	02-08-02	100.1	99.9	100.5
SCHLUMBERGER	J55	C385693	02-08-02	99.8	99.7	99.6
SCHLUMBERGER	J55	C385694	02-08-02	100.2	100.4	99.5
SCHLUMBERGER	J55	C385695	02-08-02	100.0	100.0	99.7
SCHLUMBERGER	J55	C385696	02-08-02	100.1	99.7	100.0
SCHLUMBERGER	J55	C385697	02-08-02	100.0	99.8	100.2
SCHLUMBERGER	J55	C385698	02-08-02	100.1	99.9	100.0
SCHLUMBERGER	J55	C385699	02-08-02	99.8	99.9	99.7
SCHLUMBERGER	J55	C385700	02-08-02	99.8	100.1	99.9
SCHLUMBERGER	J55	C385701	02-08-02	100.0	100.0	100.1
SCHLUMBERGER	J55	C385702	02-08-02	99.9	99.9	100.0
SCHLUMBERGER	J55	C385703	02-08-02	100.0	99.8	99.9
SCHLUMBERGER	J55	C385704	02-08-02	99.8	100.2	99.7
SCHLUMBERGER	J55	C385705	02-08-02	100.0	100.0	100.0
SCHLUMBERGER	J55	C385706	02-08-02	100.0	100.0	100.2
SCHLUMBERGER	J55	C385707	02-08-02	100.2	99.9	99.6
SCHLUMBERGER	J55	C385708	02-08-02	100.0	99.9	99.8
SCHLUMBERGER	J55	C385709	02-08-02	99.9	100.1	100.0
SCHLUMBERGER	J55	C385710	02-08-02	100.1	99.8	99.9
SCHLUMBERGER	J55	C385711	02-08-02	99.8	100.0	99.7
SCHLUMBERGER	J55	C385712	02-08-02	99.9	99.8	99.4
SCHLUMBERGER	J55	C385713	02-08-02	99.8	100.0	99.7
SCHLUMBERGER	J55	C385714	02-08-02	99.9	99.6	99.7
SCHLUMBERGER	J55	C385715	02-08-02	100.0	100.1	100.2
SCHLUMBERGER	J55	C385716	02-08-02	100.0	99.9	100.0
SCHLUMBERGER	J55	C385717	02-08-02	99.9	100.0	99.7
SCHLUMBERGER	J55	C385718	02-08-02	100.0	100.2	100.0
SCHLUMBERGER	J55	C385719	02-08-02	100.0	100.0	99.9
SCHLUMBERGER	J55	C385720	02-08-02	100.2	100.0	99.8
SCHLUMBERGER	J55	C385721	02-08-02	99.8	100.1	100.0
SCHLUMBERGER	J55	C385722	02-08-02	99.8	99.6	99.5
SCHLUMBERGER	J55	C385723	02-08-02	100.1	99.9	100.2
SCHLUMBERGER	J55	C385724	02-08-02	100.1	99.8	99.5
SCHLUMBERGER	J55	C385725	02-08-02	100.0	99.9	99.5
SCHLUMBERGER	J55	C385726	02-08-02	100.2	99.7	99.8
SCHLUMBERGER	J55	C385727	02-08-02	100.3	99.7	100.2

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	J5S	C385728	02-08-02	100.0	99.9	99.9
SCHLUMBERGER	J5S	C385729	02-08-02	100.1	99.9	99.8
SCHLUMBERGER	J5S	C385730	02-08-02	100.0	99.7	99.7
SCHLUMBERGER	J5S	C385731	02-08-02	99.8	99.9	99.6
SCHLUMBERGER	J5S	C385732	02-08-02	100.1	100.0	100.3
SCHLUMBERGER	J5S	C385733	02-08-02	99.9	100.2	99.9
SCHLUMBERGER	J5S	C385734	02-08-02	100.1	100.1	100.0
SCHLUMBERGER	J5S	C385735	02-08-02	99.9	100.0	99.4
SCHLUMBERGER	J5S	C385736	02-08-02	100.1	100.1	100.4
SCHLUMBERGER	J5S	C385737	02-08-02	99.8	100.0	99.4
SCHLUMBERGER	J5S	C385738	02-08-02	99.8	99.6	99.7
SCHLUMBERGER	J5S	C385739	02-08-02	100.3	99.8	99.7
SCHLUMBERGER	J5S	C385740	02-08-02	99.8	99.8	99.5
SCHLUMBERGER	J5S	C385741	02-08-02	100.0	99.9	99.9
SCHLUMBERGER	J5S	C385742	02-08-02	100.0	100.0	99.6
SCHLUMBERGER	J5S	C385743	02-08-02	100.0	99.9	99.8
SCHLUMBERGER	J5S	C385744	02-08-02	99.8	99.8	100.1
SCHLUMBERGER	J5S	C385745	02-08-02	100.2	100.1	100.0
SCHLUMBERGER	J5S	C385746	02-08-02	99.9	99.7	99.4
SCHLUMBERGER	J5S	C385747	02-08-02	99.9	100.0	99.9
SCHLUMBERGER	J5S	C385748	02-08-02	99.9	99.7	100.0
SCHLUMBERGER	J5S	C385749	02-08-02	100.0	99.8	99.9
SCHLUMBERGER	J5S	C385750	02-08-02	99.8	100.0	100.0
SCHLUMBERGER	J5S	C385751	02-08-02	100.1	100.0	99.9
SCHLUMBERGER	J5S	C385752	02-08-02	99.8	99.7	99.7
SCHLUMBERGER	J5S	C385753	02-08-02	99.8	99.9	99.3
SCHLUMBERGER	J5S	C385754	02-08-02	100.0	99.9	99.3
SCHLUMBERGER	J5S	C385755	02-08-02	100.1	100.0	100.5
SCHLUMBERGER	J5S	C385756	02-08-02	99.9	99.7	99.8
SCHLUMBERGER	J5S	C385757	02-08-02	99.9	99.8	99.7
SCHLUMBERGER	J5S	C385758	02-08-02	99.9	99.8	99.7
SCHLUMBERGER	J5S	C385759	02-08-02	100.1	99.8	99.9
SCHLUMBERGER	J5S	C385760	02-08-02	100.1	99.7	100.2
SCHLUMBERGER	J5S	C385761	02-08-02	100.2	99.9	100.2
SCHLUMBERGER	J5S	C385762	02-08-02	100.2	100.1	99.8
SCHLUMBERGER	J5S	C385763	02-08-02	100.2	100.0	99.6
SCHLUMBERGER	J5S	C385764	02-08-02	100.2	100.0	99.7
SCHLUMBERGER	J5S	C385765	02-08-02	100.1	100.0	99.7
SCHLUMBERGER	J5S	C385766	02-08-02	99.9	99.9	100.2
SCHLUMBERGER	J5S	C385767	02-08-02	100.0	99.7	99.7
SCHLUMBERGER	J5S	C385768	02-08-02	100.3	100.1	99.9
SCHLUMBERGER	J5S	C385769	02-08-02	100.1	100.0	99.6
SCHLUMBERGER	J5S	C385770	02-08-02	100.0	99.9	100.1
SCHLUMBERGER	J5S	C385771	02-08-02	100.0	99.9	100.3
SCHLUMBERGER	J5S	C385772	02-08-02	99.8	100.0	99.5
SCHLUMBERGER	J5S	C385773	02-08-02	99.8	99.8	100.0
SCHLUMBERGER	J5S	C385774	02-08-02	99.9	99.8	99.7
SCHLUMBERGER	J5S	C385775	02-08-02	100.1	100.5	99.9
SCHLUMBERGER	J5S	C385776	02-08-02	100.2	100.3	99.8
SCHLUMBERGER	J5S	C385777	02-08-02	100.1	100.1	99.9
SCHLUMBERGER	J5S	C385778	02-08-02	99.9	99.6	99.9

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

PAGE 49
 RUN DATE: 1/14/03
 RUN TIME: 13.26.53

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	J5S	C385779	02-08-02	100.0	99.9	99.7
SCHLUMBERGER	J5S	C385780	02-08-02	100.1	100.3	100.2
SCHLUMBERGER	J5S	C385781	02-08-02	99.9	99.9	99.6
SCHLUMBERGER	J5S	C385782	02-08-02	100.1	99.9	100.0
SCHLUMBERGER	J5S	C385783	02-08-02	99.9	99.7	99.5
SCHLUMBERGER	J5S	C385784	02-08-02	99.8	99.7	100.0
SCHLUMBERGER	J5S	C385785	02-08-02	100.0	99.8	100.1
SCHLUMBERGER	J5S	C385786	02-08-02	99.9	100.1	99.4
SCHLUMBERGER	J5S	C385787	02-08-02	100.0	100.2	99.8
SCHLUMBERGER	J5S	C385788	02-08-02	99.9	99.8	99.7
SCHLUMBERGER	J5S	C385789	02-08-02	100.2	99.7	100.0
SCHLUMBERGER	J5S	C385790	02-08-02	100.3	100.4	100.1
SCHLUMBERGER	J5S	C385791	02-08-02	99.8	100.0	99.7
SCHLUMBERGER	J5S	C385792	02-08-02	100.2	99.7	100.0
SCHLUMBERGER	J5S	C385793	02-08-02	99.9	99.8	99.9
SCHLUMBERGER	J5S	C385794	02-08-02	99.8	99.7	99.3
SCHLUMBERGER	J5S	C385795	02-08-02	100.1	100.2	99.6
SCHLUMBERGER	J5S	C385796	02-08-02	99.9	99.8	99.9
SCHLUMBERGER	J5S	C385797	02-08-02	99.9	100.0	100.1
SCHLUMBERGER	J5S	C385798	02-08-02	99.9	100.2	100.0
SCHLUMBERGER	J5S	C385799	02-08-02	100.1	100.0	100.0
SCHLUMBERGER	J5S	C385800	02-08-02	100.2	100.1	100.4
SCHLUMBERGER	J5S	C385801	02-08-02	100.0	99.9	100.0
SCHLUMBERGER	J5S	C385802	02-08-02	100.2	100.1	100.0
SCHLUMBERGER	J5S	C385803	02-08-02	99.9	100.0	99.8
SCHLUMBERGER	J5S	C385804	02-08-02	100.0	100.1	99.6
SCHLUMBERGER	J5S	C385805	02-08-02	99.9	99.7	100.0
SCHLUMBERGER	J5S	C385806	02-08-02	99.9	99.7	99.7
SCHLUMBERGER	J5S	C385807	02-08-02	100.0	100.0	99.7
SCHLUMBERGER	J5S	C385808	02-08-02	100.0	99.9	99.7
SCHLUMBERGER	J5S	C385809	02-08-02	99.8	99.8	99.5
SCHLUMBERGER	J5S	C385810	02-08-02	100.1	99.6	99.8
SCHLUMBERGER	J5S	C385811	02-08-02	100.1	99.9	100.0
SCHLUMBERGER	J5S	C385812	02-08-02	99.9	99.8	100.0
SCHLUMBERGER	J5S	C385813	02-08-02	99.9	99.9	100.0
SCHLUMBERGER	J5S	C385814	02-08-02	100.1	100.0	100.0
SCHLUMBERGER	J5S	C385815	02-08-02	99.8	99.9	99.6
SCHLUMBERGER	J5S	C385816	02-08-02	100.1	100.3	100.0
SCHLUMBERGER	J5S	C385817	02-08-02	100.0	100.0	99.9
SCHLUMBERGER	J5S	C385818	02-08-02	100.0	99.7	100.1
SCHLUMBERGER	J5S	C385819	02-08-02	99.9	99.7	100.3
SCHLUMBERGER	J5S	C385820	02-08-02	99.9	99.6	99.5
SCHLUMBERGER	J5S	C385821	02-08-02	99.8	100.0	99.9
SCHLUMBERGER	J5S	C385822	02-08-02	100.0	100.1	100.0
SCHLUMBERGER	J5S	C385823	02-08-02	99.9	100.2	99.7
SCHLUMBERGER	J5S	C385824	02-08-02	99.8	100.0	100.0
SCHLUMBERGER	J5S	C385825	02-08-02	100.1	99.9	99.8
SCHLUMBERGER	J5S	C385826	02-08-02	99.9	100.2	99.6
SCHLUMBERGER	J5S	C385827	02-08-02	99.8	99.9	99.5
SCHLUMBERGER	J5S	C385828	02-08-02	99.9	99.9	99.8
SCHLUMBERGER	J5S	C385829	02-08-02	100.0	100.1	99.5

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	J5S	C385830	02-08-02	100.0	100.0	100.0
SCHLUMBERGER	J5S	C385831	02-08-02	100.0	100.3	100.0
SCHLUMBERGER	J5S	C385832	02-08-02	100.1	100.1	99.8
SCHLUMBERGER	J5S	C385833	02-08-02	100.3	100.0	100.4
SCHLUMBERGER	J5S	C385834	02-08-02	99.9	100.0	99.7
SCHLUMBERGER	J5S	C385835	02-08-02	99.8	99.9	99.4
SCHLUMBERGER	J5S	C385836	02-08-02	100.1	100.0	99.9
SCHLUMBERGER	J5S	C385837	02-08-02	99.9	99.8	99.8
SCHLUMBERGER	J5S	C385838	02-08-02	100.2	100.2	99.8
SCHLUMBERGER	J5S	C385839	02-08-02	100.2	99.7	100.1
SCHLUMBERGER	J5S	C385840	02-08-02	99.8	99.8	99.7
SCHLUMBERGER	J5S	C385841	02-08-02	99.9	99.8	99.9
SCHLUMBERGER	J5S	C385842	02-08-02	99.8	99.8	99.5
SCHLUMBERGER	J5S	C385843	02-08-02	100.2	99.8	99.8
SCHLUMBERGER	J5S	C385844	02-08-02	100.0	100.1	100.1
SCHLUMBERGER	J5S	C385845	02-08-02	100.1	99.8	99.6
SCHLUMBERGER	J5S	C385846	02-08-02	99.8	99.8	99.5
SCHLUMBERGER	J5S	C385847	02-08-02	100.0	99.7	100.2
SCHLUMBERGER	J5S	C385848	02-08-02	100.0	99.8	99.9
SCHLUMBERGER	J5S	C385849	02-08-02	99.9	100.0	99.8
SCHLUMBERGER	J5S	C385850	02-08-02	99.9	99.9	99.9
SCHLUMBERGER	J5S	C385851	02-08-02	99.9	100.1	99.8
SCHLUMBERGER	J5S	C385852	02-08-02	100.0	99.9	100.3
SCHLUMBERGER	J5S	C385853	02-08-02	99.7	99.9	99.8
SCHLUMBERGER	J5S	C385854	02-08-02	100.1	100.0	100.2
SCHLUMBERGER	J5S	C385855	02-08-02	100.2	100.0	99.6
SCHLUMBERGER	J5S	C385856	02-08-02	99.8	100.0	99.7
SCHLUMBERGER	J5S	C385857	02-08-02	99.9	99.7	99.6
SCHLUMBERGER	J5S	C385858	02-08-02	99.8	100.3	100.1
SCHLUMBERGER	J5S	C385859	02-08-02	99.9	100.0	99.6
SCHLUMBERGER	J5S	C385860	02-08-02	99.8	100.0	99.8
SCHLUMBERGER	J5S	C385861	02-08-02	100.3	99.7	99.7
SCHLUMBERGER	J5S	C385862	02-08-02	99.8	100.1	100.4
SCHLUMBERGER	J5S	C385863	02-08-02	99.8	99.7	100.2
SCHLUMBERGER	J5S	C385864	02-08-02	99.9	100.4	100.4
SCHLUMBERGER	J5S	C385865	02-08-02	99.9	100.0	100.0
SCHLUMBERGER	J5S	C385866	02-08-02	99.9	99.8	99.4
SCHLUMBERGER	J5S	C385867	02-08-02	100.0	99.8	99.8
SCHLUMBERGER	J5S	C385868	02-08-02	100.0	100.1	100.0
SCHLUMBERGER	J5S	C385869	02-08-02	100.0	100.0	100.0
SCHLUMBERGER	J5S	C385870	02-08-02	100.0	99.9	99.8
SCHLUMBERGER	J5S	C385871	02-08-02	99.9	100.1	99.8
SCHLUMBERGER	J5S	C385872	02-08-02	99.9	99.9	99.8
SCHLUMBERGER	J5S	C385873	02-08-02	99.8	99.7	99.4
SCHLUMBERGER	J5S	C385874	02-08-02	100.0	100.3	100.4
SCHLUMBERGER	J5S	C385875	02-08-02	100.0	100.0	99.7
SCHLUMBERGER	J5S	C385876	02-08-02	100.2	99.8	100.1
SCHLUMBERGER	J5S	C385877	02-08-02	100.0	99.7	100.0
SCHLUMBERGER	J5S	C385878	02-08-02	100.0	99.9	99.9
SCHLUMBERGER	J5S	C385879	02-08-02	100.2	100.3	100.1
SCHLUMBERGER	J5S	C385880	02-08-02	100.0	99.9	99.7

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

PAGE 51
 RUN DATE: 1/14/03
 RUN TIME: 13.26.53

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	J5S	C385881	02-08-02	99.8	99.7	99.8
SCHLUMBERGER	J5S	C385882	02-08-02	100.0	100.0	100.5
SCHLUMBERGER	J5S	C385883	02-08-02	100.0	100.0	100.3
SCHLUMBERGER	J5S	C385884	02-08-02	100.0	99.8	99.4
SCHLUMBERGER	J5S	C385885	02-08-02	100.1	99.8	99.8
SCHLUMBERGER	J5S	C385886	02-08-02	100.0	100.0	100.1
SCHLUMBERGER	J5S	C385887	02-08-02	100.0	99.9	100.1
SCHLUMBERGER	J5S	C385888	02-08-02	99.9	100.1	99.6
SCHLUMBERGER	J5S	C385889	02-08-02	99.8	99.6	100.2
SCHLUMBERGER	J5S	C385890	02-08-02	99.9	99.8	99.9
SCHLUMBERGER	J5S	C385891	02-08-02	99.9	100.2	100.1
SCHLUMBERGER	J5S	C385892	02-08-02	99.8	100.0	99.9
SCHLUMBERGER	J5S	C385893	02-08-02	100.2	100.1	100.1
SCHLUMBERGER	J5S	C385894	02-08-02	100.0	100.0	100.1
SCHLUMBERGER	J5S	C385895	02-08-02	100.0	100.0	99.7
SCHLUMBERGER	J5S	C385896	02-08-02	100.0	99.6	99.8
SCHLUMBERGER	J5S	C385897	02-08-02	100.0	99.9	100.3
SCHLUMBERGER	J5S	C385898	02-08-02	99.9	100.2	100.0
SCHLUMBERGER	J5S	C385899	02-08-02	99.9	99.6	100.0
SCHLUMBERGER	J5S	C385900	02-08-02	100.0	100.0	100.2
SCHLUMBERGER	J5S	C385901	02-08-02	100.3	100.3	100.0
SCHLUMBERGER	J5S	C385902	02-08-02	100.2	100.0	100.0
SCHLUMBERGER	J5S	C385903	02-08-02	99.9	100.0	99.9
SCHLUMBERGER	J5S	C385904	02-08-02	99.8	99.9	100.2
SCHLUMBERGER	J5S	C385905	02-08-02	99.9	100.0	100.0
SCHLUMBERGER	J5S	C385906	02-08-02	99.8	99.9	99.6
SCHLUMBERGER	J5S	C385907	02-08-02	100.1	100.3	100.2
SCHLUMBERGER	J5S	C385908	02-08-02	100.0	100.0	99.7
SCHLUMBERGER	J5S	C385909	02-08-02	100.1	99.9	99.8
SCHLUMBERGER	J5S	C385910	02-08-02	99.8	100.1	99.7
SCHLUMBERGER	J5S	C385911	02-08-02	100.1	100.0	99.9
SCHLUMBERGER	J5S	C385912	02-08-02	99.8	99.7	100.0
SCHLUMBERGER	J5S	C385913	02-08-02	100.0	99.8	100.0
SCHLUMBERGER	J5S	C385914	02-08-02	99.8	99.8	99.9
SCHLUMBERGER	J5S	C385915	02-08-02	100.1	99.8	100.2
SCHLUMBERGER	J5S	C385916	02-08-02	99.7	99.8	99.9
SCHLUMBERGER	J5S	C385917	02-08-02	99.9	100.0	99.4
SCHLUMBERGER	J5S	C385918	02-08-02	99.9	99.8	99.9
SCHLUMBERGER	J5S	C385919	02-08-02	100.0	99.9	99.8
SCHLUMBERGER	J5S	C385920	02-08-02	100.1	100.1	100.2
SCHLUMBERGER	J5S	C385921	02-08-02	99.8	100.0	99.8
SCHLUMBERGER	J5S	C385922	02-08-02	99.9	99.7	99.8
SCHLUMBERGER	J5S	C385923	02-08-02	99.9	100.0	100.2
SCHLUMBERGER	J5S	C385924	02-08-02	100.0	100.0	99.8
SCHLUMBERGER	J5S	C385925	02-08-02	99.9	100.0	100.2
SCHLUMBERGER	J5S	C385926	02-08-02	99.9	99.8	99.7
SCHLUMBERGER	J5S	C385927	02-08-02	99.9	100.0	100.1
SCHLUMBERGER	J5S	C385928	02-08-02	99.9	99.8	99.7
SCHLUMBERGER	J5S	C385929	02-08-02	100.1	100.0	100.4
SCHLUMBERGER	J5S	C385930	02-08-02	99.9	99.9	99.8
SCHLUMBERGER	J5S	C385931	02-08-02	99.8	99.9	100.2
SCHLUMBERGER	J5S			99.8	99.7	100.4

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

PAGE 52
 RUN DATE: 1/14/03
 RUN TIME: 13.26.53

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	J55	C385932	02-08-02	99.9	100.0	99.9
SCHLUMBERGER	J55	C385933	02-08-02	100.0	99.8	100.0
SCHLUMBERGER	J55	C385934	02-08-02	99.8	100.0	99.9
SCHLUMBERGER	J55	C385935	02-08-02	100.0	100.0	100.2
SCHLUMBERGER	J55	C385936	02-08-02	99.9	99.9	99.9
SCHLUMBERGER	J55	C385937	02-07-02	99.9	99.7	100.4
SCHLUMBERGER	J55	C385938	02-07-02	100.0	99.8	100.1
SCHLUMBERGER	J55	C385939	02-08-02	100.0	99.9	99.8
SCHLUMBERGER	J55	C385940	02-08-02	100.1	99.8	99.8
SCHLUMBERGER	J55	C385941	02-07-02	100.0	100.0	99.7
SCHLUMBERGER	J55	C385942	02-08-02	100.1	100.0	99.9
SCHLUMBERGER	J55	C385943	02-07-02	99.9	99.9	99.8
SCHLUMBERGER	J55	C385944	02-07-02	99.9	99.7	100.1
SCHLUMBERGER	J55	C385945	02-07-02	99.9	99.9	99.7
SCHLUMBERGER	J55	C385946	02-07-02	100.2	100.1	100.2
SCHLUMBERGER	J55	C385947	02-07-02	99.9	99.9	99.8
SCHLUMBERGER	J55	C385948	02-07-02	100.2	100.2	99.9
SCHLUMBERGER	J55	C385949	02-07-02	99.9	99.9	100.0
SCHLUMBERGER	J55	C385950	02-07-02	99.9	100.0	99.9
SCHLUMBERGER	J55	C385951	02-07-02	100.1	100.2	100.6
SCHLUMBERGER	J55	C385952	02-07-02	100.1	100.2	100.0
SCHLUMBERGER	J55	C385953	02-07-02	99.9	99.8	99.6
SCHLUMBERGER	J55	C385954	02-07-02	100.1	99.9	99.7
SCHLUMBERGER	J55	C385955	02-07-02	100.0	100.0	99.6
SCHLUMBERGER	J55	C385956	02-07-02	100.2	100.1	99.8
SCHLUMBERGER	J55	C385957	02-07-02	100.0	100.0	99.7
SCHLUMBERGER	J55	C385958	02-07-02	100.0	99.8	100.1
SCHLUMBERGER	J55	C385959	02-07-02	100.0	100.1	100.1
SCHLUMBERGER	J55	C385960	02-07-02	99.9	99.7	100.1
SCHLUMBERGER	J55	C385961	02-07-02	100.0	100.1	99.7
SCHLUMBERGER	J55	C385962	02-07-02	99.9	99.8	99.8
SCHLUMBERGER	J55	C385963	02-07-02	99.9	99.7	99.9
SCHLUMBERGER	J55	C385964	02-07-02	99.8	99.6	99.5
SCHLUMBERGER	J55	C385965	02-07-02	100.1	100.0	100.1
SCHLUMBERGER	J55	C385966	02-07-02	99.9	99.9	99.9
SCHLUMBERGER	J55	C385967	02-07-02	100.0	99.8	99.8
SCHLUMBERGER	J55	C385968	02-07-02	100.0	100.1	100.0
SCHLUMBERGER	J55	C385969	02-07-02	100.0	99.9	99.5
SCHLUMBERGER	J55	C385970	02-07-02	100.0	99.6	99.5
SCHLUMBERGER	J55	C385971	02-07-02	100.1	99.8	100.2
SCHLUMBERGER	J55	C385972	02-07-02	100.2	100.3	100.1
SCHLUMBERGER	J55	C385973	02-07-02	99.8	99.7	100.3
SCHLUMBERGER	J55	C385974	02-07-02	99.9	99.8	99.6
SCHLUMBERGER	J55	C385975	02-07-02	100.2	100.4	100.2
SCHLUMBERGER	J55	C385976	02-07-02	100.0	100.1	100.2
SCHLUMBERGER	J55	C385977	02-07-02	99.8	100.0	99.9
SCHLUMBERGER	J55	C385978	02-07-02	100.2	99.8	100.3
SCHLUMBERGER	J55	C385979	02-07-02	99.9	100.4	99.8
SCHLUMBERGER	J55	C385980	02-07-02	100.0	100.0	100.1
SCHLUMBERGER	J55	C385981	02-07-02	100.1	99.7	99.8
SCHLUMBERGER	J55	C385982	02-07-02	100.1	100.2	100.0

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	J55	C385983	02-07-02	100.3	99.7	100.1
SCHLUMBERGER	J55	C385984	02-07-02	99.9	99.8	99.8
SCHLUMBERGER	J55	C385985	02-07-02	99.9	100.1	99.9
SCHLUMBERGER	J55	C385986	02-07-02	99.8	99.6	99.8
SCHLUMBERGER	J55	C385987	02-07-02	99.8	99.8	99.8
SCHLUMBERGER	J55	C385988	02-07-02	100.1	100.3	100.2
SCHLUMBERGER	J55	C385989	02-07-02	100.0	99.9	100.2
SCHLUMBERGER	J55	C385990	02-07-02	100.0	99.9	99.8
SCHLUMBERGER	J55	C385991	02-07-02	99.9	100.0	100.1
SCHLUMBERGER	J55	C385992	02-07-02	99.8	99.8	99.7
SCHLUMBERGER	J55	C385993	02-07-02	99.9	100.1	100.3
SCHLUMBERGER	J55	C385994	02-07-02	99.9	99.9	99.7
SCHLUMBERGER	J55	C385995	02-07-02	100.2	99.9	100.1
SCHLUMBERGER	J55	C385996	02-07-02	100.0	99.8	99.7
SCHLUMBERGER	J55	C385997	02-07-02	100.0	99.8	100.0
SCHLUMBERGER	J55	C385998	02-07-02	99.8	100.0	99.8
SCHLUMBERGER	J55	C385999	02-07-02	99.9	100.0	99.4
SCHLUMBERGER	J55	C386000	02-07-02	99.9	99.8	99.5
SCHLUMBERGER	J55	C386001	02-07-02	100.1	99.8	99.8
SCHLUMBERGER	J55	C386002	02-07-02	100.1	100.2	99.8
SCHLUMBERGER	J55	C386003	02-07-02	100.2	100.3	100.0
SCHLUMBERGER	J55	C386004	02-07-02	100.1	99.9	99.9
SCHLUMBERGER	J55	C386005	02-07-02	100.1	99.9	99.7
SCHLUMBERGER	J55	C386006	02-07-02	100.0	100.1	100.1
SCHLUMBERGER	J55	C386007	02-07-02	99.8	99.6	99.9
SCHLUMBERGER	J55	C386008	02-07-02	99.9	99.7	99.7
SCHLUMBERGER	J55	C386009	02-07-02	100.2	99.6	100.2
SCHLUMBERGER	J55	C386010	02-07-02	100.0	100.0	100.2
SCHLUMBERGER	J55	C386011	02-07-02	99.9	99.9	100.0
SCHLUMBERGER	J55	C386012	02-07-02	100.1	100.1	99.8
SCHLUMBERGER	J55	C386013	02-07-02	100.1	99.9	100.0
SCHLUMBERGER	J55	C386014	02-07-02	100.2	99.7	99.8
SCHLUMBERGER	J55	C386015	02-07-02	99.9	100.2	100.0
SCHLUMBERGER	J55	C386016	02-07-02	100.0	100.0	100.0
SCHLUMBERGER	J55	C386017	02-07-02	99.8	100.0	99.9
SCHLUMBERGER	J55	C386018	02-07-02	100.1	99.9	100.0
SCHLUMBERGER	J55	C386019	02-07-02	99.9	100.0	99.6
SCHLUMBERGER	J55	C386020	02-07-02	100.1	99.7	100.1
SCHLUMBERGER	J55	C386021	02-07-02	100.1	100.0	99.7
SCHLUMBERGER	J55	C386022	02-07-02	100.0	100.2	99.8
SCHLUMBERGER	J55	C386023	02-07-02	100.0	100.4	100.3
SCHLUMBERGER	J55	C386024	02-07-02	99.9	99.7	99.6
SCHLUMBERGER	J55	C386025	02-07-02	100.3	99.9	99.7
SCHLUMBERGER	J55	C386026	02-07-02	100.0	99.6	99.9
SCHLUMBERGER	J55	C386027	02-07-02	99.9	99.7	99.8
SCHLUMBERGER	J55	C386028	02-07-02	99.8	99.6	99.5
SCHLUMBERGER	J55	C386029	02-07-02	100.1	100.1	100.1
SCHLUMBERGER	J55	C386030	02-07-02	100.0	100.4	100.1
SCHLUMBERGER	J55	C386031	02-07-02	100.1	99.7	99.6
SCHLUMBERGER	J55	C386032	02-07-02	100.2	99.7	100.3
SCHLUMBERGER	J55	C386033	02-07-02	100.0	100.2	100.4

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

PAGE 54
 RUN DATE: 1/14/03
 RUN TIME: 13.26.53

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	J5S	C386034	02-07-02	100.3	99.8	99.9
SCHLUMBERGER	J5S	C386035	02-07-02	99.9	100.0	99.5
SCHLUMBERGER	J5S	C386036	02-07-02	99.8	100.1	99.6
SCHLUMBERGER	J5S	C386037	02-07-02	99.8	100.1	99.8
SCHLUMBERGER	J5S	C386038	02-07-02	99.9	99.8	100.3
SCHLUMBERGER	J5S	C386039	02-07-02	99.9	99.9	99.9
SCHLUMBERGER	J5S	C386040	02-07-02	99.9	100.0	99.8
SCHLUMBERGER	J5S	C386041	02-07-02	99.8	100.0	99.9
SCHLUMBERGER	J5S	C386042	02-07-02	99.8	100.0	99.4
SCHLUMBERGER	J5S	C386043	02-07-02	100.0	99.8	99.9
SCHLUMBERGER	J5S	C386044	02-07-02	100.3	99.8	99.9
SCHLUMBERGER	J5S	C386045	02-07-02	100.1	100.0	100.4
SCHLUMBERGER	J5S	C386046	02-07-02	99.7	100.0	100.0
SCHLUMBERGER	J5S	C386047	02-07-02	100.0	99.9	99.7
SCHLUMBERGER	J5S	C386048	02-07-02	100.0	100.2	99.8
SCHLUMBERGER	J5S	C386049	02-07-02	99.9	99.7	99.6
SCHLUMBERGER	J5S	C386050	02-07-02	100.0	99.7	99.6
SCHLUMBERGER	J5S	C386051	02-07-02	99.9	100.0	99.6
SCHLUMBERGER	J5S	C386052	02-07-02	99.9	99.7	100.3
SCHLUMBERGER	J5S	C386053	02-07-02	99.8	99.8	99.9
SCHLUMBERGER	J5S	C386054	02-07-02	99.9	100.1	99.8
SCHLUMBERGER	J5S	C386055	02-07-02	99.9	99.8	99.6
SCHLUMBERGER	J5S	C386056	02-07-02	99.8	100.1	99.6
SCHLUMBERGER	J5S	C386057	02-07-02	99.8	100.1	100.2
SCHLUMBERGER	J5S	C386058	02-07-02	99.9	100.1	99.6
SCHLUMBERGER	J5S	C386059	02-07-02	99.9	100.1	100.2
SCHLUMBERGER	J5S	C386060	02-07-02	99.9	100.1	100.0
SCHLUMBERGER	J5S	C386061	02-07-02	99.9	100.0	99.3
SCHLUMBERGER	J5S	C386062	02-07-02	100.1	99.8	99.7
SCHLUMBERGER	J5S	C386063	02-07-02	99.9	99.9	99.5
SCHLUMBERGER	J5S	C386064	02-07-02	100.2	99.9	99.8
SCHLUMBERGER	J5S	C386065	02-07-02	99.9	100.1	100.1
SCHLUMBERGER	J5S	C386066	02-07-02	99.9	99.9	100.2
SCHLUMBERGER	J5S	C386067	02-07-02	100.1	99.7	99.4
SCHLUMBERGER	J5S	C386068	02-07-02	99.9	100.0	100.5
SCHLUMBERGER	J5S	C386069	02-07-02	100.0	100.0	100.1
SCHLUMBERGER	J5S	C386070	02-07-02	99.8	100.0	99.9
SCHLUMBERGER	J5S	C386071	02-07-02	99.9	99.7	99.6
SCHLUMBERGER	J5S	C386072	02-07-02	100.0	100.1	99.8
SCHLUMBERGER	J5S	C386073	02-07-02	100.0	99.8	100.2
SCHLUMBERGER	J5S	C386074	02-07-02	99.9	100.0	99.9
SCHLUMBERGER	J5S	C386075	02-07-02	99.9	100.0	99.5
SCHLUMBERGER	J5S	C386076	02-07-02	100.1	100.2	99.8
SCHLUMBERGER	J5S	C386077	02-07-02	99.9	99.9	99.9
SCHLUMBERGER	J5S	C386078	02-07-02	100.0	100.0	99.9
SCHLUMBERGER	J5S	C386079	02-07-02	100.0	100.0	99.8
SCHLUMBERGER	J5S	C386080	02-07-02	100.3	99.7	99.7
SCHLUMBERGER	J5S	C386081	02-07-02	100.2	100.1	100.0
SCHLUMBERGER	J5S	C386082	02-07-02	99.8	99.7	99.7
SCHLUMBERGER	J5S	C386083	02-07-02	100.0	100.2	99.7
SCHLUMBERGER	J5S	C386084	02-07-02	100.2	100.4	100.2

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	J55	C386085	02-07-02	100.0	99.9	99.8
SCHLUMBERGER	J55	C386086	02-07-02	99.8	99.9	99.9
SCHLUMBERGER	J55	C386087	02-07-02	100.0	100.1	99.9
SCHLUMBERGER	J55	C386088	02-07-02	99.8	100.0	99.9
SCHLUMBERGER	J55	C386089	02-07-02	99.9	100.0	99.4
SCHLUMBERGER	J55	C386090	02-07-02	100.0	99.6	99.9
SCHLUMBERGER	J55	C386091	02-07-02	99.8	100.0	99.8
SCHLUMBERGER	J55	C386092	02-07-02	100.0	99.7	100.1
SCHLUMBERGER	J55	C386093	02-07-02	99.9	99.9	99.8
SCHLUMBERGER	J55	C386094	02-07-02	100.2	100.2	100.1
SCHLUMBERGER	J55	C386095	02-07-02	99.8	100.0	99.6
SCHLUMBERGER	J55	C386096	02-07-02	99.9	100.0	99.5
SCHLUMBERGER	J55	C386097	02-07-02	100.2	99.7	99.9
SCHLUMBERGER	J55	C386098	02-07-02	99.8	99.7	99.8
SCHLUMBERGER	J55	C386099	02-07-02	100.1	100.0	99.7
SCHLUMBERGER	J55	C386100	02-07-02	100.1	100.1	100.2
SCHLUMBERGER	J55	C386101	02-07-02	100.0	100.0	99.9
SCHLUMBERGER	J55	C386102	02-07-02	100.0	100.1	100.0
SCHLUMBERGER	J55	C386103	02-07-02	99.8	99.7	100.0
SCHLUMBERGER	J55	C386104	02-07-02	99.9	99.7	99.6
SCHLUMBERGER	J55	C386105	02-07-02	99.8	99.9	99.7
SCHLUMBERGER	J55	C386106	02-07-02	99.8	100.0	99.9
SCHLUMBERGER	J55	C386107	02-07-02	99.9	100.1	100.4
SCHLUMBERGER	J55	C386108	02-07-02	100.2	99.9	100.4
SCHLUMBERGER	J55	C386109	02-07-02	99.8	100.2	99.7
SCHLUMBERGER	J55	C386110	02-07-02	99.8	100.2	100.4
SCHLUMBERGER	J55	C386111	02-07-02	99.9	99.8	99.4
SCHLUMBERGER	J55	C386112	02-07-02	100.0	100.4	100.3
SCHLUMBERGER	J55	C386113	02-07-02	99.8	99.9	99.7
SCHLUMBERGER	J55	C386114	02-07-02	99.9	100.0	99.8
SCHLUMBERGER	J55	C386115	02-07-02	100.0	100.1	99.8
SCHLUMBERGER	J55	C386116	02-07-02	100.0	100.0	100.2
SCHLUMBERGER	J55	C386117	02-07-02	100.1	99.8	100.1
SCHLUMBERGER	J55	C386118	02-07-02	100.3	99.8	99.9
SCHLUMBERGER	J55	C386119	02-07-02	99.8	99.8	100.3
SCHLUMBERGER	J55	C386120	02-07-02	99.8	100.3	100.3
SCHLUMBERGER	J55	C386121	02-07-02	100.1	100.2	99.9
SCHLUMBERGER	J55	C386122	02-07-02	99.9	99.7	100.0
SCHLUMBERGER	J55	C386123	02-07-02	100.2	99.9	100.0
SCHLUMBERGER	J55	C386124	02-07-02	99.8	100.2	99.7
SCHLUMBERGER	J55	C386125	02-07-02	100.1	100.2	100.2
SCHLUMBERGER	J55	C386126	02-07-02	100.0	100.3	100.2
SCHLUMBERGER	J55	C386127	02-07-02	99.9	100.0	99.6
SCHLUMBERGER	J55	C386128	02-07-02	99.9	99.8	99.7
SCHLUMBERGER	J55	C386129	02-07-02	100.0	99.8	99.7
SCHLUMBERGER	J55	C386130	02-07-02	100.0	100.1	100.1
SCHLUMBERGER	J55	C386131	02-07-02	99.8	100.1	99.7
SCHLUMBERGER	J55	C386132	02-07-02	100.2	100.0	99.9
SCHLUMBERGER	J55	C386133	02-07-02	99.8	99.7	99.3
SCHLUMBERGER	J55	C386134	02-07-02	99.8	100.2	99.7
SCHLUMBERGER	J55	C386135	02-07-02	99.8	99.7	99.6

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

PAGE 56
 RUN DATE: 1/14/03
 RUN TIME: 13.26.53

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	J5S	C386136	02-07-02	100.0	99.9	99.6
SCHLUMBERGER	J5S	C386137	02-07-02	99.8	100.0	99.7
SCHLUMBERGER	J5S	C386138	02-07-02	100.3	100.4	100.8
SCHLUMBERGER	J5S	C386139	02-07-02	100.1	99.9	100.1
SCHLUMBERGER	J5S	C386140	02-07-02	100.0	99.9	99.5
SCHLUMBERGER	J5S	C386141	02-07-02	100.2	100.1	100.2
SCHLUMBERGER	J5S	C386142	02-07-02	100.1	99.9	99.8
SCHLUMBERGER	J5S	C386143	02-07-02	100.0	100.1	99.9
SCHLUMBERGER	J5S	C386144	02-07-02	100.0	99.8	100.0
SCHLUMBERGER	J5S	C386145	02-07-02	99.9	99.8	99.5
SCHLUMBERGER	J5S	C386146	02-07-02	99.8	100.1	99.8
SCHLUMBERGER	J5S	C386147	02-07-02	99.8	99.7	99.7
SCHLUMBERGER	J5S	C386148	02-07-02	100.0	100.2	99.9
SCHLUMBERGER	J5S	C386149	02-07-02	99.9	100.2	99.9
SCHLUMBERGER	J5S	C386150	02-07-02	99.8	99.9	99.3
SCHLUMBERGER	J5S	C386151	02-07-02	99.9	99.9	99.8
SCHLUMBERGER	J5S	C386152	02-07-02	100.0	100.1	99.9
SCHLUMBERGER	J5S	C386153	02-07-02	100.0	99.8	100.0
SCHLUMBERGER	J5S	C386154	02-07-02	99.8	100.0	100.3
SCHLUMBERGER	J5S	C386155	02-07-02	99.8	99.8	100.1
SCHLUMBERGER	J5S	C386156	02-07-02	99.8	100.0	99.5
SCHLUMBERGER	J5S	C386157	02-07-02	100.2	99.8	99.6
SCHLUMBERGER	J5S	C386158	02-07-02	100.2	100.1	100.1
SCHLUMBERGER	J5S	C386159	02-07-02	100.0	100.2	100.1
SCHLUMBERGER	J5S	C386160	02-07-02	100.1	100.0	100.2
SCHLUMBERGER	J5S	C386161	02-07-02	100.0	100.1	99.8
SCHLUMBERGER	J5S	C386162	02-07-02	99.9	100.0	99.9
SCHLUMBERGER	J5S	C386163	02-07-02	99.8	99.8	99.6
SCHLUMBERGER	J5S	C386164	02-07-02	99.8	100.0	100.2
SCHLUMBERGER	J5S	C386165	02-07-02	99.8	99.9	100.5
SCHLUMBERGER	J5S	C386166	02-07-02	100.0	99.9	99.8
SCHLUMBERGER	J5S	C386167	02-07-02	99.8	100.2	100.2
SCHLUMBERGER	J5S	C386168	02-07-02	99.9	100.1	100.3
SCHLUMBERGER	J5S	C386169	02-07-02	99.8	99.6	99.8
SCHLUMBERGER	J5S	C386170	02-07-02	99.9	100.2	99.6
SCHLUMBERGER	J5S	C386171	02-07-02	100.1	100.4	99.9
SCHLUMBERGER	J5S	C386172	02-07-02	100.3	99.7	100.1
SCHLUMBERGER	J5S	C386173	02-07-02	100.0	100.3	100.2
SCHLUMBERGER	J5S	C386174	02-07-02	100.0	99.7	100.3
SCHLUMBERGER	J5S	C386175	02-07-02	100.2	100.1	100.0
SCHLUMBERGER	J5S	C386176	02-07-02	99.8	99.7	99.3
SCHLUMBERGER	J5S	C386177	02-07-02	100.0	99.7	100.3
SCHLUMBERGER	J5S	C386178	02-07-02	100.2	99.9	100.3
SCHLUMBERGER	J5S	C386179	02-07-02	100.0	99.8	100.8
SCHLUMBERGER	J5S	C386180	02-07-02	99.8	99.8	99.9
SCHLUMBERGER	J5S	C386181	02-07-02	100.2	100.0	100.2
SCHLUMBERGER	J5S	C386182	02-07-02	100.0	100.1	99.7
SCHLUMBERGER	J5S	C386183	02-07-02	99.9	99.8	99.5
SCHLUMBERGER	J5S	C386184	02-07-02	99.8	99.9	99.6
SCHLUMBERGER	J5S	C386185	02-07-02	99.9	100.1	100.2
SCHLUMBERGER	J5S	C386186	02-07-02	100.2	99.9	100.0

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

PAGE 57
 RUN DATE: 1/14/03
 RUN TIME: 13.26.53

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	J5S	C386187	02-07-02	100.0	100.0	100.0
SCHLUMBERGER	J5S	C386188	02-07-02	100.2	100.0	100.2
SCHLUMBERGER	J5S	C386189	02-07-02	99.9	100.2	99.5
SCHLUMBERGER	J5S	C386190	02-07-02	99.8	99.8	99.6
SCHLUMBERGER	J5S	C386191	02-07-02	99.9	99.6	100.5
SCHLUMBERGER	J5S	C386192	02-07-02	99.9	100.1	99.8
SCHLUMBERGER	J5S	C386193	02-07-02	99.8	99.9	99.4
SCHLUMBERGER	J5S	C386194	02-07-02	100.0	100.0	99.7
SCHLUMBERGER	J5S	C386195	02-07-02	99.8	99.9	99.8
SCHLUMBERGER	J5S	C386196	02-07-02	99.8	99.8	99.5
SCHLUMBERGER	J5S	C386197	02-07-02	99.9	99.9	100.0
SCHLUMBERGER	J5S	C386198	02-07-02	99.8	100.0	99.8
SCHLUMBERGER	J5S	C386199	02-07-02	100.1	100.2	99.8
SCHLUMBERGER	J5S	C386200	02-07-02	100.2	99.9	99.6
SCHLUMBERGER	J5S	C386201	02-07-02	100.1	100.1	99.4
SCHLUMBERGER	J5S	C386202	02-07-02	100.0	100.0	99.9
SCHLUMBERGER	J5S	C386203	02-07-02	100.0	100.2	100.5
SCHLUMBERGER	J5S	C386204	02-07-02	100.0	100.1	99.9
SCHLUMBERGER	J5S	C386205	02-07-02	99.9	100.2	99.9
SCHLUMBERGER	J5S	C386206	02-07-02	100.0	100.0	99.9
SCHLUMBERGER	J5S	C386207	02-07-02	100.2	99.9	99.5
SCHLUMBERGER	J5S	C386208	02-07-02	100.1	100.2	100.1
SCHLUMBERGER	J5S	C386209	02-07-02	99.8	100.2	99.3
SCHLUMBERGER	J5S	C386210	02-07-02	99.7	99.9	100.2
SCHLUMBERGER	J5S	C386211	02-07-02	100.0	99.9	99.8
SCHLUMBERGER	J5S	C386212	02-07-02	99.9	100.0	100.2
SCHLUMBERGER	J5S	C386213	02-07-02	100.0	100.0	99.9
SCHLUMBERGER	J5S	C386214	02-07-02	100.0	100.1	100.2
SCHLUMBERGER	J5S	C386215	02-07-02	99.8	99.8	99.8
SCHLUMBERGER	J5S	C386216	02-07-02	99.9	99.6	99.8
SCHLUMBERGER	J5S	C386217	02-07-02	100.0	100.0	99.5
SCHLUMBERGER	J5S	C386218	02-07-02	99.9	100.0	99.6
SCHLUMBERGER	J5S	C386219	02-07-02	100.1	99.7	99.7
SCHLUMBERGER	J5S	C386220	02-07-02	100.0	100.2	99.8
SCHLUMBERGER	J5S	C386221	02-07-02	100.1	100.0	99.7
SCHLUMBERGER	J5S	C386222	02-07-02	100.2	100.1	100.5
SCHLUMBERGER	J5S	C386223	02-07-02	99.9	99.8	100.0
SCHLUMBERGER	J5S	C386224	02-07-02	99.9	100.3	100.0
SCHLUMBERGER	J5S	C386225	02-07-02	99.9	99.7	99.8
SCHLUMBERGER	J5S	C386226	02-07-02	99.9	100.0	100.1
SCHLUMBERGER	J5S	C386227	02-07-02	99.8	99.7	100.0
SCHLUMBERGER	J5S	C386228	02-07-02	99.8	99.9	100.5
SCHLUMBERGER	J5S	C386229	02-07-02	100.0	99.9	100.0
SCHLUMBERGER	J5S	C386230	02-07-02	99.8	99.8	100.5
SCHLUMBERGER	J5S	C386231	02-07-02	100.0	99.8	100.2
SCHLUMBERGER	J5S	C386232	02-07-02	99.8	99.9	99.9
SCHLUMBERGER	J5S	C386233	02-07-02	100.0	100.2	99.9
SCHLUMBERGER	J5S	C386234	02-07-02	100.0	100.1	99.7
SCHLUMBERGER	J5S	C386235	02-07-02	99.9	100.0	100.1
SCHLUMBERGER	J5S	C386236	02-07-02	100.0	100.2	100.2
SCHLUMBERGER	J5S	C386237	02-07-02	99.9	99.9	99.7

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

PAGE 58
 RUN DATE: 1/14/03
 RUN TIME: 13.26.53

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	J5S	C386238	02-07-02	99.8	99.8	100.0
SCHLUMBERGER	J5S	C386239	02-07-02	99.8	99.9	99.5
SCHLUMBERGER	J5S	C386240	02-07-02	99.9	100.1	99.7
SCHLUMBERGER	J5S	C386241	02-07-02	100.1	100.0	99.6
SCHLUMBERGER	J5S	C386242	02-07-02	100.2	100.0	100.6
SCHLUMBERGER	J5S	C386243	02-07-02	100.0	99.9	99.8
SCHLUMBERGER	J5S	C386244	02-07-02	100.0	99.8	100.3
SCHLUMBERGER	J5S	C386245	02-07-02	100.0	99.9	100.2
SCHLUMBERGER	J5S	C386246	02-07-02	100.0	99.9	100.3
SCHLUMBERGER	J5S	C386247	02-07-02	100.2	100.0	99.7
SCHLUMBERGER	J5S	C386248	02-07-02	100.2	100.0	100.3
SCHLUMBERGER	J5S	C386249	02-07-02	99.9	99.6	100.1
SCHLUMBERGER	J5S	C386250	02-07-02	99.8	100.0	99.8
SCHLUMBERGER	J5S	C386251	02-07-02	100.1	99.8	100.2
SCHLUMBERGER	J5S	C386252	02-07-02	100.0	99.8	100.3
SCHLUMBERGER	J5S	C386253	02-07-02	99.9	99.9	99.5
SCHLUMBERGER	J5S	C386254	02-07-02	100.3	100.0	100.5
SCHLUMBERGER	J5S	C386255	02-07-02	100.0	99.9	99.9
SCHLUMBERGER	J5S	C386256	02-07-02	100.0	99.7	100.1
SCHLUMBERGER	J5S	C386257	02-07-02	100.0	99.7	99.7
SCHLUMBERGER	J5S	C386258	02-07-02	99.9	100.1	99.6
SCHLUMBERGER	J5S	C386259	02-07-02	99.9	100.2	100.0
SCHLUMBERGER	J5S	C386260	02-07-02	99.8	100.0	100.2
SCHLUMBERGER	J5S	C386261	02-07-02	99.8	99.8	99.5
SCHLUMBERGER	J5S	C386262	02-07-02	99.9	99.9	99.5
SCHLUMBERGER	J5S	C386263	02-07-02	99.9	99.9	99.9
SCHLUMBERGER	J5S	C386264	02-07-02	100.0	100.0	100.2
SCHLUMBERGER	J5S	C386265	02-07-02	100.0	100.2	100.1
SCHLUMBERGER	J5S	C386266	02-07-02	99.9	100.1	99.3
SCHLUMBERGER	J5S	C386267	02-07-02	100.0	100.0	99.9
SCHLUMBERGER	J5S	C386268	02-07-02	100.1	100.1	100.5
SCHLUMBERGER	J5S	C386269	02-07-02	100.1	99.9	100.0
SCHLUMBERGER	J5S	C386270	02-07-02	99.8	100.0	100.4
SCHLUMBERGER	J5S	C386271	02-07-02	99.9	99.7	99.7
SCHLUMBERGER	J5S	C386272	02-07-02	100.0	100.0	100.1
SCHLUMBERGER	J5S	C386273	02-07-02	99.9	99.9	100.4
SCHLUMBERGER	J5S	C386274	02-07-02	100.0	99.9	99.9
SCHLUMBERGER	J5S	C386275	02-07-02	100.2	100.2	99.6
SCHLUMBERGER	J5S	C386276	02-07-02	99.9	99.8	100.1
SCHLUMBERGER	J5S	C386277	02-07-02	99.9	100.0	99.9
SCHLUMBERGER	J5S	C386278	02-07-02	100.1	100.0	100.3
SCHLUMBERGER	J5S	C386279	02-07-02	99.9	100.4	100.3
SCHLUMBERGER	J5S	C386280	02-07-02	99.9	100.3	99.7
SCHLUMBERGER	J5S	C386281	02-07-02	100.0	100.1	100.1
SCHLUMBERGER	J5S	C386282	02-07-02	100.0	99.8	99.7
SCHLUMBERGER	J5S	C386283	02-07-02	99.9	100.0	99.9
SCHLUMBERGER	J5S	C386284	02-07-02	99.8	99.6	99.8
SCHLUMBERGER	J5S	C386285	02-07-02	100.1	100.0	100.3
SCHLUMBERGER	J5S	C386286	02-07-02	100.1	100.0	100.4
SCHLUMBERGER	J5S	C386287	02-07-02	99.8	100.4	99.6
SCHLUMBERGER	J5S	C386288	02-07-02	99.9	99.8	99.9

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	J55	C386289	02-07-02	100.0	100.0	99.9
SCHLUMBERGER	J55	C386290	02-07-02	99.8	100.0	99.4
SCHLUMBERGER	J55	C386291	02-07-02	99.9	99.9	99.5
SCHLUMBERGER	J55	C386292	02-07-02	100.1	99.6	99.8
SCHLUMBERGER	J55	C386293	02-07-02	99.9	99.7	99.7
SCHLUMBERGER	J55	C386294	02-07-02	100.0	99.9	100.2
SCHLUMBERGER	J55	C386295	02-07-02	100.0	100.0	100.1
SCHLUMBERGER	J55	C386296	02-07-02	100.0	100.0	100.0
SCHLUMBERGER	J55	C386297	02-07-02	100.0	99.7	100.3
SCHLUMBERGER	J55	C386298	02-07-02	99.8	99.7	99.7
SCHLUMBERGER	J55	C386299	02-07-02	100.3	99.8	99.5
SCHLUMBERGER	J55	C386300	02-07-02	99.8	100.2	99.8
SCHLUMBERGER	J55	C386301	02-07-02	99.8	100.3	99.8
SCHLUMBERGER	J55	C386302	02-07-02	99.9	100.0	99.6
SCHLUMBERGER	J55	C386303	02-07-02	99.8	100.0	99.5
SCHLUMBERGER	J55	C386304	02-07-02	99.7	100.2	100.0
SCHLUMBERGER	J55	C386305	02-07-02	99.8	100.1	99.8
SCHLUMBERGER	J55	C386306	02-07-02	100.0	100.2	99.7
SCHLUMBERGER	J55	C386307	02-07-02	99.9	100.2	99.5
SCHLUMBERGER	J55	C386308	02-07-02	99.9	100.0	99.8
SCHLUMBERGER	J55	C386309	02-07-02	99.9	100.1	99.8
SCHLUMBERGER	J55	C386310	02-07-02	99.8	100.1	99.6
SCHLUMBERGER	J55	C386311	02-07-02	100.0	100.1	99.8
SCHLUMBERGER	J55	C386312	02-07-02	100.0	99.6	99.8
SCHLUMBERGER	J55	C386313	02-07-02	99.9	99.9	100.6
SCHLUMBERGER	J55	C386314	02-07-02	100.1	99.8	100.0
SCHLUMBERGER	J55	C386315	02-07-02	100.0	99.9	99.8
SCHLUMBERGER	J55	C386316	02-07-02	99.8	100.1	99.5
SCHLUMBERGER	J55	C386317	02-07-02	99.8	99.6	99.7
SCHLUMBERGER	J55	C386318	02-07-02	99.9	99.6	99.7
SCHLUMBERGER	J55	C386319	02-07-02	99.8	99.9	99.9
SCHLUMBERGER	J55	C386320	02-07-02	99.9	100.0	99.9
SCHLUMBERGER	J55	C386321	02-07-02	99.9	100.1	100.1
SCHLUMBERGER	J55	C386322	02-07-02	100.0	100.2	99.8
SCHLUMBERGER	J55	C386323	02-07-02	99.9	99.8	99.9
SCHLUMBERGER	J55	C386324	02-07-02	100.2	100.3	100.0
SCHLUMBERGER	J55	C386325	02-07-02	100.0	99.7	99.9
SCHLUMBERGER	J55	C386326	02-07-02	99.9	99.6	99.5
SCHLUMBERGER	J55	C386327	02-07-02	99.9	99.6	99.5
SCHLUMBERGER	J55	C386328	02-07-02	99.9	100.1	99.9
SCHLUMBERGER	J55	C386329	02-07-02	100.1	99.7	99.7
SCHLUMBERGER	J55	C386330	02-07-02	99.8	99.7	100.0
SCHLUMBERGER	J55	C386331	02-07-02	99.8	100.3	99.7
SCHLUMBERGER	J55	C386332	02-07-02	99.9	99.8	99.7
SCHLUMBERGER	J55	C386333	02-07-02	99.9	99.9	100.6
SCHLUMBERGER	J55	C386334	02-07-02	100.1	99.9	100.0
SCHLUMBERGER	J55	C386335	02-07-02	99.8	99.7	99.8
SCHLUMBERGER	J55	C386336	02-07-02	100.0	100.2	100.2
SCHLUMBERGER	J55	C386337	02-07-02	100.2	99.9	100.0
SCHLUMBERGER	J55	C386338	02-07-02	99.7	99.9	99.4
SCHLUMBERGER	J55	C386339	02-07-02	99.9	100.0	99.8

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	J55	C386340	02-07-02	100.1	99.7	99.9
SCHLUMBERGER	J55	C386341	02-07-02	99.9	99.7	99.5
SCHLUMBERGER	J55	C386342	02-07-02	99.9	100.0	99.9
SCHLUMBERGER	J55	C386343	02-07-02	99.8	100.0	100.2
SCHLUMBERGER	J55	C386344	02-07-02	100.1	99.7	99.6
SCHLUMBERGER	J55	C386345	02-07-02	100.0	100.2	99.6
SCHLUMBERGER	J55	C386346	02-07-02	99.8	99.8	99.7
SCHLUMBERGER	J55	C386347	02-07-02	100.1	100.2	100.1
SCHLUMBERGER	J55	C386348	02-07-02	100.1	99.7	100.0
SCHLUMBERGER	J55	C386349	02-07-02	99.8	99.9	99.6
SCHLUMBERGER	J55	C386350	02-07-02	100.1	100.4	99.4
SCHLUMBERGER	J55	C386351	02-07-02	99.9	99.9	99.7
SCHLUMBERGER	J55	C386352	02-07-02	99.8	100.4	99.6
SCHLUMBERGER	J55	C386353	02-07-02	99.8	100.5	99.8
SCHLUMBERGER	J55	C386354	02-07-02	99.8	99.8	99.9
SCHLUMBERGER	J55	C386355	02-07-02	99.9	100.1	99.7
SCHLUMBERGER	J55	C386356	02-07-02	99.8	99.7	99.9
SCHLUMBERGER	J55	C386357	02-07-02	99.8	99.8	99.8
SCHLUMBERGER	J55	C386358	02-07-02	99.9	100.1	100.2
SCHLUMBERGER	J55	C386359	02-07-02	99.9	99.8	99.7
SCHLUMBERGER	J55	C386360	02-07-02	100.1	100.2	100.1
SCHLUMBERGER	J55	C386361	02-07-02	99.9	99.8	99.4
SCHLUMBERGER	J55	C386362	02-07-02	100.1	99.9	100.1
SCHLUMBERGER	J55	C386363	02-07-02	100.0	99.9	100.1
SCHLUMBERGER	J55	C386640	04-11-02	100.2	100.3	100.5
SCHLUMBERGER	J55	C386641	04-11-02	99.9	99.7	99.7
SCHLUMBERGER	J55	C386642	04-11-02	99.9	99.9	99.8
SCHLUMBERGER	J55	C386643	04-11-02	100.0	100.3	100.1
SCHLUMBERGER	J55	C386644	04-11-02	99.9	99.9	100.0
SCHLUMBERGER	J55	C386645	04-11-02	99.8	100.1	99.8
SCHLUMBERGER	J55	C386646	04-11-02	100.0	99.7	100.1
SCHLUMBERGER	J55	C386647	04-11-02	99.9	99.7	99.7
SCHLUMBERGER	J55	C386648	04-11-02	100.0	100.0	99.9
SCHLUMBERGER	J55	C386649	04-11-02	100.1	100.2	100.2
SCHLUMBERGER	J55	C386650	04-11-02	99.9	99.7	99.8
SCHLUMBERGER	J55	C386651	04-11-02	99.8	99.7	99.8
SCHLUMBERGER	J55	C386652	04-11-02	99.8	99.6	99.8
SCHLUMBERGER	J55	C386653	04-11-02	100.0	99.9	99.8
SCHLUMBERGER	J55	C386654	04-11-02	99.9	99.8	99.7
SCHLUMBERGER	J55	C386655	04-11-02	100.0	99.7	99.9
SCHLUMBERGER	J55	C386656	04-11-02	100.0	99.8	100.0
SCHLUMBERGER	J55	C386657	04-11-02	100.1	100.0	100.2
SCHLUMBERGER	J55	C386658	04-11-02	99.8	99.8	99.9
SCHLUMBERGER	J55	C386659	04-11-02	100.0	100.0	100.0
SCHLUMBERGER	J55	C386660	04-11-02	99.9	100.0	99.9
SCHLUMBERGER	J55	C386661	04-11-02	99.9	99.8	99.7
SCHLUMBERGER	J55	C386662	04-11-02	100.2	99.9	100.0
SCHLUMBERGER	J55	C386663	04-11-02	99.9	99.8	99.9
SCHLUMBERGER	J55	C386664	04-11-02	100.0	100.0	99.9
SCHLUMBERGER	J55	C386665	04-11-02	99.9	100.0	99.9
SCHLUMBERGER	J55	C386666	04-11-02	100.0	100.0	99.7

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

PAGE 61
 RUN DATE: 1/14/03
 RUN TIME: 13.26.53

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	J55	C386667	04-11-02	99.9	100.1	99.6
SCHLUMBERGER	J55	C386668	04-11-02	100.0	99.6	99.9
SCHLUMBERGER	J55	C386669	04-11-02	100.0	100.0	99.8
SCHLUMBERGER	J55	C386670	04-10-02	100.0	100.1	100.0
SCHLUMBERGER	J55	C386671	04-10-02	99.8	99.8	100.0
SCHLUMBERGER	J55	C386672	04-10-02	99.9	99.9	99.8
SCHLUMBERGER	J55	C386673	04-10-02	99.9	99.9	99.8
SCHLUMBERGER	J55	C386674	04-10-02	100.0	99.8	100.1
SCHLUMBERGER	J55	C386675	04-10-02	100.0	100.1	99.9
SCHLUMBERGER	J55	C386676	04-10-02	99.9	99.6	99.8
SCHLUMBERGER	J55	C386677	04-10-02	100.0	99.8	100.1
SCHLUMBERGER	J55	C386678	04-10-02	99.9	100.1	99.7
SCHLUMBERGER	J55	C386679	04-10-02	100.0	99.8	100.1
SCHLUMBERGER	J55	C386680	04-10-02	100.2	99.8	99.7
SCHLUMBERGER	J55	C386681	04-10-02	100.2	100.0	100.1
SCHLUMBERGER	J55	C386682	04-10-02	100.1	100.1	100.1
SCHLUMBERGER	J55	C386683	04-10-02	100.1	99.8	100.2
SCHLUMBERGER	J55	C386684	04-10-02	100.0	100.1	100.2
SCHLUMBERGER	J55	C386685	04-10-02	100.0	99.9	100.1
SCHLUMBERGER	J55	C386686	04-10-02	100.1	99.9	99.7
SCHLUMBERGER	J55	C386687	04-10-02	99.8	99.7	99.5
SCHLUMBERGER	J55	C386688	04-10-02	100.1	100.1	99.9
SCHLUMBERGER	J55	C386689	04-10-02	100.2	100.0	99.9
SCHLUMBERGER	J55	C386690	04-10-02	100.1	99.7	100.0
SCHLUMBERGER	J55	C386691	04-10-02	100.0	99.8	99.9
SCHLUMBERGER	J55	C386692	04-10-02	99.9	100.0	99.8
SCHLUMBERGER	J55	C386693	04-10-02	100.0	100.2	100.3
SCHLUMBERGER	J55	C386694	04-10-02	100.0	100.1	100.0
SCHLUMBERGER	J55	C386695	04-10-02	100.0	100.0	99.9
SCHLUMBERGER	J55	C386696	04-10-02	100.0	99.7	100.2
SCHLUMBERGER	J55	C386697	04-10-02	100.0	99.8	100.1
SCHLUMBERGER	J55	C386698	04-10-02	100.0	100.2	99.8
SCHLUMBERGER	J55	C386699	04-10-02	100.1	100.0	100.2
SCHLUMBERGER	J55	C386700	04-10-02	99.9	99.8	99.5
SCHLUMBERGER	J55	C386701	04-10-02	99.8	99.8	99.7
SCHLUMBERGER	J55	C386702	04-10-02	99.9	99.6	99.8
SCHLUMBERGER	J55	C386703	04-10-02	100.2	100.2	100.0
SCHLUMBERGER	J55	C386704	04-10-02	100.2	100.0	100.0
SCHLUMBERGER	J55	C386705	04-10-02	100.1	100.0	99.9
SCHLUMBERGER	J55	C386706	04-10-02	100.1	99.9	100.0
SCHLUMBERGER	J55	C386707	04-10-02	100.0	99.9	99.6
SCHLUMBERGER	J55	C386708	04-10-02	100.1	100.0	100.1
SCHLUMBERGER	J55	C386709	04-10-02	99.9	99.6	99.8
SCHLUMBERGER	J55	C386710	04-10-02	100.1	100.1	99.9
SCHLUMBERGER	J55	C386711	04-10-02	99.9	99.8	99.9
SCHLUMBERGER	J55	C386712	04-10-02	100.1	99.7	99.3
SCHLUMBERGER	J55	C386713	04-10-02	100.0	100.1	99.8
SCHLUMBERGER	J55	C386714	04-10-02	100.1	99.8	100.1
SCHLUMBERGER	J55	C386715	04-10-02	100.1	100.1	100.1
SCHLUMBERGER	J55	C386716	04-10-02	100.0	100.0	99.7
SCHLUMBERGER	J55	C386717	04-10-02	99.9	99.7	99.9

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

PAGE 62
 RUN DATE: 1/14/03
 RUN TIME: 13.26.53

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	J5S	C386718	04-10-02	100.3	99.8	99.6
SCHLUMBERGER	J5S	C386719	04-10-02	99.9	99.8	99.6
SCHLUMBERGER	J5S	C386720	04-10-02	100.0	100.3	99.8
SCHLUMBERGER	J5S	C386721	04-10-02	100.1	99.9	99.6
SCHLUMBERGER	J5S	C386722	04-10-02	100.3	100.0	100.1
SCHLUMBERGER	J5S	C386723	04-10-02	100.0	99.8	99.9
SCHLUMBERGER	J5S	C386724	04-10-02	100.0	99.8	99.7
SCHLUMBERGER	J5S	C386725	04-10-02	100.2	100.2	100.2
SCHLUMBERGER	J5S	C386726	04-10-02	100.1	100.1	99.9
SCHLUMBERGER	J5S	C386727	04-10-02	99.9	100.0	99.9
SCHLUMBERGER	J5S	C386728	04-10-02	100.1	100.1	99.9
SCHLUMBERGER	J5S	C386729	04-10-02	100.0	100.2	100.1
SCHLUMBERGER	J5S	C386730	04-10-02	100.2	99.9	99.7
SCHLUMBERGER	J5S	C386731	04-10-02	100.0	99.8	100.1
SCHLUMBERGER	J5S	C386732	04-10-02	100.0	100.4	100.2
SCHLUMBERGER	J5S	C386733	04-10-02	100.0	100.0	100.2
SCHLUMBERGER	J5S	C386734	04-10-02	100.1	100.1	99.7
SCHLUMBERGER	J5S	C386735	04-10-02	100.0	100.1	100.2
SCHLUMBERGER	J5S	C386736	04-10-02	100.0	99.9	99.8
SCHLUMBERGER	J5S	C386737	04-10-02	100.0	100.0	99.7
SCHLUMBERGER	J5S	C386738	04-10-02	100.1	100.0	99.9
SCHLUMBERGER	J5S	C386739	04-10-02	100.0	100.1	100.0
SCHLUMBERGER	J5S	C386740	04-10-02	100.0	99.8	100.2
SCHLUMBERGER	J5S	C386741	04-10-02	100.1	99.6	100.2
SCHLUMBERGER	J5S	C386742	04-10-02	99.8	100.1	99.9
SCHLUMBERGER	J5S	C386743	04-10-02	100.0	99.8	100.1
SCHLUMBERGER	J5S	C386744	04-10-02	100.0	100.2	99.3
SCHLUMBERGER	J5S	C386745	04-10-02	100.0	100.0	99.3
SCHLUMBERGER	J5S	C386746	04-10-02	100.0	99.7	99.8
SCHLUMBERGER	J5S	C386747	04-10-02	100.1	100.1	99.8
SCHLUMBERGER	J5S	C386748	04-10-02	99.8	99.9	100.0
SCHLUMBERGER	J5S	C386749	04-10-02	99.9	99.7	100.0
SCHLUMBERGER	J5S	C386750	04-10-02	100.1	99.8	99.6
SCHLUMBERGER	J5S	C386751	04-10-02	100.0	99.9	99.8
SCHLUMBERGER	J5S	C386752	04-10-02	100.1	99.9	100.2
SCHLUMBERGER	J5S	C386753	04-10-02	100.1	100.1	99.9
SCHLUMBERGER	J5S	C386754	04-10-02	100.0	99.8	100.0
SCHLUMBERGER	J5S	C386755	04-10-02	100.1	100.1	100.3
SCHLUMBERGER	J5S	C386756	04-10-02	100.0	99.8	100.0
SCHLUMBERGER	J5S	C386757	04-10-02	100.1	100.2	99.5
SCHLUMBERGER	J5S	C386758	04-10-02	100.1	100.0	100.3
SCHLUMBERGER	J5S	C386759	04-10-02	99.9	99.8	100.1
SCHLUMBERGER	J5S	C386760	04-10-02	99.9	100.0	100.0
SCHLUMBERGER	J5S	C386761	04-10-02	100.1	99.7	99.5
SCHLUMBERGER	J5S	C386762	04-10-02	100.1	99.8	99.8
SCHLUMBERGER	J5S	C386763	04-10-02	99.9	100.0	99.6
SCHLUMBERGER	J5S	C386764	04-10-02	100.0	100.0	100.2
SCHLUMBERGER	J5S	C386765	04-10-02	100.0	99.7	99.8
SCHLUMBERGER	J5S	C386766	04-10-02	100.0	100.2	99.9
SCHLUMBERGER	J5S	C386767	04-10-02	99.9	99.7	99.9
SCHLUMBERGER	J5S	C386768	04-10-02	100.0	99.7	99.8

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

PAGE 63
 RUN DATE: 1/14/03
 RUN TIME: 13.26.53

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	J5S	C386769	04-10-02	100.1	100.0	99.9
SCHLUMBERGER	J5S	C386770	04-10-02	100.1	100.1	100.1
SCHLUMBERGER	J5S	C386771	04-10-02	100.0	100.1	99.7
SCHLUMBERGER	J5S	C386772	04-10-02	99.9	99.8	99.8
SCHLUMBERGER	J5S	C386773	04-10-02	99.8	99.9	99.8
SCHLUMBERGER	J5S	C386774	04-10-02	100.1	100.3	100.2
SCHLUMBERGER	J5S	C386775	04-10-02	100.0	100.0	100.1
SCHLUMBERGER	J5S	C386776	04-10-02	100.1	99.8	99.8
SCHLUMBERGER	J5S	C386777	04-10-02	99.9	99.7	99.7
SCHLUMBERGER	J5S	C386778	04-10-02	99.9	99.9	99.7
SCHLUMBERGER	J5S	C386779	04-10-02	100.1	100.2	100.1
SCHLUMBERGER	J5S	C386780	04-10-02	100.2	99.8	99.9
SCHLUMBERGER	J5S	C386781	04-10-02	100.0	99.9	99.8
SCHLUMBERGER	J5S	C386782	04-10-02	100.1	100.4	100.2
SCHLUMBERGER	J5S	C386783	04-10-02	99.8	99.9	99.9
SCHLUMBERGER	J5S	C386784	04-10-02	99.9	99.9	99.6
SCHLUMBERGER	J5S	C386785	04-10-02	99.9	99.8	99.6
SCHLUMBERGER	J5S	C386786	04-10-02	100.1	99.7	100.0
SCHLUMBERGER	J5S	C386787	04-10-02	100.0	99.8	100.1
SCHLUMBERGER	J5S	C386788	04-10-02	99.9	99.8	100.2
SCHLUMBERGER	J5S	C386789	04-10-02	100.1	100.0	100.1
SCHLUMBERGER	J5S	C386790	04-10-02	100.0	99.7	100.2
SCHLUMBERGER	J5S	C386791	04-10-02	99.9	99.8	99.8
SCHLUMBERGER	J5S	C386792	04-10-02	99.8	99.9	99.3
SCHLUMBERGER	J5S	C386793	04-10-02	100.0	99.7	100.2
SCHLUMBERGER	J5S	C386794	04-10-02	100.0	99.8	99.7
SCHLUMBERGER	J5S	C386795	04-10-02	99.9	99.8	99.9
SCHLUMBERGER	J5S	C386796	04-10-02	100.1	100.2	100.1
SCHLUMBERGER	J5S	C386797	04-10-02	100.0	99.8	99.7
SCHLUMBERGER	J5S	C386798	04-10-02	100.0	99.9	100.1
SCHLUMBERGER	J5S	C386799	04-10-02	100.0	99.8	99.8
SCHLUMBERGER	J5S	C386800	04-10-02	100.0	99.8	99.9
SCHLUMBERGER	J5S	C386801	04-10-02	99.8	99.6	99.7
SCHLUMBERGER	J5S	C386802	04-10-02	100.0	99.8	100.1
SCHLUMBERGER	J5S	C386803	04-10-02	99.9	99.6	99.9
SCHLUMBERGER	J5S	C386804	04-10-02	100.0	99.9	99.9
SCHLUMBERGER	J5S	C386805	04-10-02	99.9	99.9	100.1
SCHLUMBERGER	J5S	C386806	04-10-02	99.9	99.9	99.8
SCHLUMBERGER	J5S	C386807	04-10-02	100.2	100.1	100.4
SCHLUMBERGER	J5S	C386808	04-10-02	100.0	99.7	100.1
SCHLUMBERGER	J5S	C386809	04-10-02	100.0	100.1	100.1
SCHLUMBERGER	J5S	C386810	04-10-02	99.9	100.0	99.5
SCHLUMBERGER	J5S	C386811	04-10-02	100.0	100.1	100.0
SCHLUMBERGER	J5S	C386812	04-10-02	100.1	99.7	100.2
SCHLUMBERGER	J5S	C386813	04-10-02	100.0	99.9	99.8
SCHLUMBERGER	J5S	C386814	04-10-02	99.9	99.7	99.8
SCHLUMBERGER	J5S	C386815	04-10-02	100.0	100.0	100.2
SCHLUMBERGER	J5S	C386816	04-10-02	100.0	100.0	100.2
SCHLUMBERGER	J5S	C386817	04-10-02	100.0	100.1	100.2
SCHLUMBERGER	J5S	C386818	04-10-02	100.0	100.1	99.7
SCHLUMBERGER	J5S	C386819	04-10-02	100.1	100.0	100.1

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	J5S	C386820	04-10-02	100.2	100.0	100.0
SCHLUMBERGER	J5S	C386821	04-10-02	100.0	100.0	99.8
SCHLUMBERGER	J5S	C386822	04-10-02	100.0	99.8	99.7
SCHLUMBERGER	J5S	C386823	04-10-02	100.3	100.3	100.3
SCHLUMBERGER	J5S	C386824	04-10-02	100.1	100.1	100.0
SCHLUMBERGER	J5S	C386825	04-10-02	99.9	99.7	99.3
SCHLUMBERGER	J5S	C386826	04-10-02	100.1	100.0	100.2
SCHLUMBERGER	J5S	C386827	04-10-02	100.1	99.8	100.3
SCHLUMBERGER	J5S	C386828	04-10-02	100.1	100.0	99.8
SCHLUMBERGER	J5S	C386829	04-10-02	100.0	100.0	100.1
SCHLUMBERGER	J5S	C386830	04-10-02	100.0	100.0	100.1
SCHLUMBERGER	J5S	C386831	04-10-02	100.1	99.7	99.7
SCHLUMBERGER	J5S	C386832	04-10-02	100.1	100.0	100.0
SCHLUMBERGER	J5S	C386833	04-10-02	99.9	100.0	99.9
SCHLUMBERGER	J5S	C386834	04-10-02	100.1	99.8	100.1
SCHLUMBERGER	J5S	C386835	04-10-02	100.0	100.1	100.2
SCHLUMBERGER	J5S	C386836	04-10-02	100.0	99.6	99.5
SCHLUMBERGER	J5S	C386837	04-10-02	100.0	99.9	100.1
SCHLUMBERGER	J5S	C386838	04-10-02	99.9	99.6	99.6
SCHLUMBERGER	J5S	C386839	04-10-02	99.9	99.8	99.8
SCHLUMBERGER	J5S	C386840	04-10-02	100.3	100.2	100.1
SCHLUMBERGER	J5S	C386841	04-10-02	100.1	100.2	99.8
SCHLUMBERGER	J5S	C386842	04-10-02	99.9	99.8	99.8
SCHLUMBERGER	J5S	C386843	04-10-02	100.0	100.1	100.0
SCHLUMBERGER	J5S	C386844	04-10-02	100.1	99.9	100.2
SCHLUMBERGER	J5S	C386845	04-10-02	100.0	99.9	99.9
SCHLUMBERGER	J5S	C386846	04-10-02	99.9	99.7	99.7
SCHLUMBERGER	J5S	C386847	04-10-02	100.1	99.9	100.2
SCHLUMBERGER	J5S	C386848	04-10-02	100.1	100.0	99.6
SCHLUMBERGER	J5S	C386849	04-10-02	100.0	100.1	99.7
SCHLUMBERGER	J5S	C386850	04-10-02	100.1	99.6	99.8
SCHLUMBERGER	J5S	C386851	04-10-02	100.0	100.0	99.9
SCHLUMBERGER	J5S	C386852	04-10-02	99.9	100.0	100.1
SCHLUMBERGER	J5S	C386853	04-10-02	100.0	99.8	100.1
SCHLUMBERGER	J5S	C386854	04-10-02	100.0	99.9	100.1
SCHLUMBERGER	J5S	C386855	04-10-02	100.0	100.0	100.0
SCHLUMBERGER	J5S	C386856	04-10-02	100.1	100.1	99.9
SCHLUMBERGER	J5S	C386857	04-10-02	100.1	99.9	99.8
SCHLUMBERGER	J5S	C386858	04-10-02	99.9	99.9	99.9
SCHLUMBERGER	J5S	C386859	04-10-02	99.9	99.9	99.6
SCHLUMBERGER	J5S	C386860	04-10-02	100.0	100.0	100.2
SCHLUMBERGER	J5S	C386861	04-10-02	100.0	100.2	99.8
SCHLUMBERGER	J5S	C386862	04-10-02	99.9	100.0	99.6
SCHLUMBERGER	J5S	C386863	04-10-02	99.8	99.9	99.4
SCHLUMBERGER	J5S	C386864	04-10-02	100.1	100.0	99.8
SCHLUMBERGER	J5S	C386865	04-10-02	100.0	99.9	100.4
SCHLUMBERGER	J5S	C386866	04-10-02	99.8	99.8	99.8
SCHLUMBERGER	J5S	C386867	04-10-02	100.1	100.0	99.7
SCHLUMBERGER	J5S	C386868	04-10-02	99.9	99.7	99.9
SCHLUMBERGER	J5S	C386869	04-10-02	100.0	100.0	99.6
SCHLUMBERGER	J5S	C386870	04-10-02	99.9	99.9	100.0
SCHLUMBERGER	J5S					99.5

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

PAGE 65
 RUN DATE: 1/14/03
 RUN TIME: 13.26.53

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	J55	C386871	04-10-02	100.2	100.1	100.7
SCHLUMBERGER	J55	C386872	04-10-02	100.0	100.0	99.7
SCHLUMBERGER	J55	C386873	04-10-02	100.0	100.1	99.6
SCHLUMBERGER	J55	C386874	04-10-02	100.1	99.8	99.9
SCHLUMBERGER	J55	C386875	04-10-02	100.0	99.7	99.9
SCHLUMBERGER	J55	C386876	04-10-02	100.0	99.7	99.5
SCHLUMBERGER	J55	C386877	04-10-02	100.0	100.0	100.1
SCHLUMBERGER	J55	C386878	04-10-02	100.0	99.8	100.0
SCHLUMBERGER	J55	C386879	04-10-02	100.3	100.0	100.2
SCHLUMBERGER	J55	C386880	04-10-02	100.0	100.0	99.8
SCHLUMBERGER	J55	C386881	04-10-02	100.0	99.7	99.9
SCHLUMBERGER	J55	C386882	04-10-02	100.3	99.9	99.9
SCHLUMBERGER	J55	C386883	04-10-02	100.0	99.8	99.6
SCHLUMBERGER	J55	C386884	04-10-02	100.1	99.9	99.9
SCHLUMBERGER	J55	C386885	04-10-02	100.0	99.8	99.5
SCHLUMBERGER	J55	C386886	04-10-02	99.9	100.0	99.7
SCHLUMBERGER	J55	C386887	04-10-02	100.0	99.9	99.8
SCHLUMBERGER	J55	C386888	04-10-02	100.0	99.9	100.0
SCHLUMBERGER	J55	C386889	04-10-02	100.0	100.1	100.3
SCHLUMBERGER	J55	C386890	04-10-02	100.0	100.2	100.0
SCHLUMBERGER	J55	C386891	04-10-02	100.1	100.0	100.1
SCHLUMBERGER	J55	C386892	04-10-02	100.0	99.9	100.0
SCHLUMBERGER	J55	C386893	04-10-02	100.1	99.8	100.0
SCHLUMBERGER	J55	C386894	04-10-02	100.1	100.1	99.7
SCHLUMBERGER	J55	C386895	04-10-02	100.1	100.0	99.8
SCHLUMBERGER	J55	C386896	04-10-02	100.0	99.9	99.8
SCHLUMBERGER	J55	C386897	04-10-02	100.1	100.0	100.1
SCHLUMBERGER	J55	C386898	04-10-02	100.0	99.9	99.9
SCHLUMBERGER	J55	C386899	04-10-02	100.1	100.2	100.2
SCHLUMBERGER	J55	C386900	04-10-02	100.1	99.9	100.1
SCHLUMBERGER	J55	C386901	04-10-02	100.0	99.9	100.1
SCHLUMBERGER	J55	C386902	04-10-02	100.1	99.9	99.9
SCHLUMBERGER	J55	C386903	04-10-02	100.2	99.9	100.4
SCHLUMBERGER	J55	C386904	04-10-02	100.0	100.2	99.9
SCHLUMBERGER	J55	C386905	04-10-02	100.0	99.7	99.7
SCHLUMBERGER	J55	C386906	04-10-02	100.0	99.9	100.0
SCHLUMBERGER	J55	C386907	04-10-02	100.0	100.1	99.8
SCHLUMBERGER	J55	C386908	04-10-02	99.9	99.9	99.9
SCHLUMBERGER	J55	C386909	04-10-02	100.1	100.1	99.9
SCHLUMBERGER	J55	C386910	04-10-02	99.9	99.9	99.9
SCHLUMBERGER	J55	C386911	04-10-02	100.1	100.0	99.8
SCHLUMBERGER	J55	C386912	04-10-02	99.9	99.9	99.9
SCHLUMBERGER	J55	C386913	04-10-02	100.0	99.9	100.0
SCHLUMBERGER	J55	C386914	04-10-02	100.2	100.0	99.7
SCHLUMBERGER	J55	C386915	04-10-02	100.0	99.6	99.9
SCHLUMBERGER	J55	C386916	04-10-02	100.0	99.8	99.9
SCHLUMBERGER	J55	C386917	04-10-02	100.1	100.0	99.8
SCHLUMBERGER	J55	C386918	04-10-02	99.9	99.7	99.9
SCHLUMBERGER	J55	C386919	04-10-02	100.0	100.1	100.1
SCHLUMBERGER	J55	C386920	04-10-02	100.2	100.1	100.0
SCHLUMBERGER	J55	C386921	04-10-02	100.2	100.0	99.9

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

PAGE 66
 RUN DATE: 1/14/03
 RUN TIME: 13.26.53

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	J5S	C386922	04-10-02	100.1	100.1	100.2
SCHLUMBERGER	J5S	C386923	04-10-02	99.9	100.1	100.1
SCHLUMBERGER	J5S	C386924	04-10-02	100.3	99.8	99.8
SCHLUMBERGER	J5S	C386925	04-10-02	100.0	99.8	99.6
SCHLUMBERGER	J5S	C386926	04-10-02	100.1	100.0	100.4
SCHLUMBERGER	J5S	C386927	04-10-02	100.2	100.0	100.1
SCHLUMBERGER	J5S	C386928	04-10-02	100.0	99.9	99.8
SCHLUMBERGER	J5S	C386929	04-10-02	99.9	99.8	100.0
SCHLUMBERGER	J5S	C386930	04-10-02	100.1	100.2	100.2
SCHLUMBERGER	J5S	C386931	04-10-02	100.2	99.9	100.1
SCHLUMBERGER	J5S	C386932	04-10-02	100.1	100.0	100.0
SCHLUMBERGER	J5S	C386933	04-10-02	99.9	99.8	100.1
SCHLUMBERGER	J5S	C386934	04-10-02	100.2	100.0	100.1
SCHLUMBERGER	J5S	C386935	04-10-02	100.0	100.2	99.9
SCHLUMBERGER	J5S	C386936	04-10-02	100.0	100.0	100.2
SCHLUMBERGER	J5S	C386937	04-10-02	100.1	100.3	100.5
SCHLUMBERGER	J5S	C386938	04-10-02	99.9	99.8	99.7
SCHLUMBERGER	J5S	C386939	04-10-02	100.0	100.1	99.8
SCHLUMBERGER	J5S	C386940	04-10-02	100.1	100.1	99.9
SCHLUMBERGER	J5S	C386941	04-10-02	99.9	100.0	99.9
SCHLUMBERGER	J5S	C386942	04-10-02	100.0	99.8	99.8
SCHLUMBERGER	J5S	C386943	04-10-02	100.0	99.9	100.0
SCHLUMBERGER	J5S	C386944	04-10-02	100.1	99.9	100.1
SCHLUMBERGER	J5S	C386945	04-10-02	100.0	100.0	100.0
SCHLUMBERGER	J5S	C386946	04-10-02	100.1	100.0	100.2
SCHLUMBERGER	J5S	C386947	04-10-02	99.9	99.9	99.9
SCHLUMBERGER	J5S	C386948	04-10-02	99.9	99.6	100.0
SCHLUMBERGER	J5S	C386949	04-10-02	100.0	100.2	100.0
SCHLUMBERGER	J5S	C386950	04-10-02	99.9	100.1	100.2
SCHLUMBERGER	J5S	C386951	04-10-02	100.1	100.1	100.3
SCHLUMBERGER	J5S	C386952	04-10-02	100.0	100.2	100.3
SCHLUMBERGER	J5S	C386953	04-10-02	100.1	100.1	100.2
SCHLUMBERGER	J5S	C386954	04-10-02	100.2	99.9	100.0
SCHLUMBERGER	J5S	C386955	04-10-02	100.0	100.1	99.9
SCHLUMBERGER	J5S	C386956	04-10-02	100.1	100.1	100.1
SCHLUMBERGER	J5S	C386957	04-10-02	99.9	99.8	100.0
SCHLUMBERGER	J5S	C386958	04-10-02	100.2	100.1	100.2
SCHLUMBERGER	J5S	C386959	04-10-02	100.1	99.7	100.1
SCHLUMBERGER	J5S	C386960	04-10-02	100.0	99.9	100.0
SCHLUMBERGER	J5S	C386961	04-10-02	100.0	99.9	100.0
SCHLUMBERGER	J5S	C386962	04-10-02	100.0	100.0	99.9
SCHLUMBERGER	J5S	C386963	04-10-02	99.8	99.7	99.7
SCHLUMBERGER	J5S	C386964	04-10-02	100.0	99.7	100.0
SCHLUMBERGER	J5S	C386965	04-10-02	100.3	100.2	100.1
SCHLUMBERGER	J5S	C386966	04-10-02	100.3	100.4	100.2
SCHLUMBERGER	J5S	C386967	04-10-02	100.0	100.1	100.0
SCHLUMBERGER	J5S	C386968	04-10-02	100.1	100.0	100.2
SCHLUMBERGER	J5S	C386969	04-10-02	100.0	99.8	99.8
SCHLUMBERGER	J5S	C386970	04-10-02	100.1	99.9	99.7
SCHLUMBERGER	J5S	C386971	04-10-02	100.0	99.8	99.7
SCHLUMBERGER	J5S	C386972	04-10-02	100.0	100.0	99.6

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	J55	C386973	04-10-02	100.0	99.8	99.9
SCHLUMBERGER	J55	C386974	04-10-02	99.8	99.8	99.9
SCHLUMBERGER	J55	C386975	04-10-02	100.1	99.9	100.3
SCHLUMBERGER	J55	C386976	04-10-02	100.0	99.9	100.0
SCHLUMBERGER	J55	C386977	04-10-02	100.1	99.7	100.1
SCHLUMBERGER	J55	C386978	04-10-02	100.1	99.9	99.8
SCHLUMBERGER	J55	C386979	04-10-02	100.1	100.2	100.2
SCHLUMBERGER	J55	C386980	04-10-02	100.0	99.8	99.8
SCHLUMBERGER	J55	C386981	04-10-02	100.2	99.8	100.1
SCHLUMBERGER	J55	C386982	04-10-02	99.8	100.2	99.9
SCHLUMBERGER	J55	C386983	04-10-02	100.1	100.2	100.2
SCHLUMBERGER	J55	C386984	04-10-02	100.0	99.7	100.0
SCHLUMBERGER	J55	C386985	04-10-02	100.0	99.9	100.0
SCHLUMBERGER	J55	C386986	04-10-02	100.0	99.9	100.0
SCHLUMBERGER	J55	C386987	04-10-02	100.2	100.0	100.3
SCHLUMBERGER	J55	C386988	04-10-02	100.1	99.8	100.0
SCHLUMBERGER	J55	C386989	04-10-02	100.0	99.8	100.0
SCHLUMBERGER	J55	C386990	04-10-02	100.0	99.8	100.0
SCHLUMBERGER	J55	C386991	04-10-02	100.0	99.9	99.9
SCHLUMBERGER	J55	C386992	04-10-02	100.1	100.1	100.1
SCHLUMBERGER	J55	C386993	04-10-02	100.0	99.8	100.3
SCHLUMBERGER	J55	C386994	04-10-02	100.0	99.9	100.0
SCHLUMBERGER	J55	C386995	04-10-02	100.0	99.9	99.5
SCHLUMBERGER	J55	C386996	04-10-02	100.0	100.0	99.9
SCHLUMBERGER	J55	C386997	04-10-02	100.0	100.1	100.2
SCHLUMBERGER	J55	C386998	04-10-02	99.9	99.7	99.9
SCHLUMBERGER	J55	C386999	04-10-02	100.1	99.7	99.9
SCHLUMBERGER	J55	C387000	04-10-02	100.0	99.8	100.0
SCHLUMBERGER	J55	C387001	04-10-02	100.0	99.7	100.0
SCHLUMBERGER	J55	C387002	04-10-02	100.1	99.9	99.9
SCHLUMBERGER	J55	C387003	04-10-02	100.1	100.2	100.1
SCHLUMBERGER	J55	C387004	04-10-02	99.9	99.8	100.0
SCHLUMBERGER	J55	C387005	04-10-02	100.0	99.8	99.8
SCHLUMBERGER	J55	C387006	04-10-02	100.1	99.8	99.9
SCHLUMBERGER	J55	C387007	04-10-02	100.0	100.0	100.0
SCHLUMBERGER	J55	C387008	04-10-02	100.0	99.7	100.1
SCHLUMBERGER	J55	C387009	04-10-02	100.2	100.2	100.2
SCHLUMBERGER	J55	C387010	04-10-02	100.1	99.9	99.7
SCHLUMBERGER	J55	C387011	04-10-02	100.0	99.9	99.8
SCHLUMBERGER	J55	C387012	04-10-02	100.0	99.9	100.1
SCHLUMBERGER	J55	C387013	04-10-02	99.9	99.9	99.7
SCHLUMBERGER	J55	C387014	04-10-02	100.0	99.9	99.9
SCHLUMBERGER	J55	C387015	04-10-02	100.0	99.9	100.0
SCHLUMBERGER	J55	C387016	04-10-02	100.1	100.0	100.0
SCHLUMBERGER	J55	C387017	04-10-02	100.1	99.9	100.0
SCHLUMBERGER	J55	C387018	04-10-02	100.1	99.8	100.0
SCHLUMBERGER	J55	C387019	04-10-02	99.8	99.7	99.6
SCHLUMBERGER	J55	C387020	04-10-02	100.0	100.0	99.9
SCHLUMBERGER	J55	C387021	04-10-02	99.9	99.6	100.0
SCHLUMBERGER	J55	C387022	04-10-02	100.1	99.4	99.9
SCHLUMBERGER	J55	C387023	04-10-02	100.0	99.7	99.8

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

PAGE 68
 RUN DATE: 1/14/03
 RUN TIME: 13.26.53

MANUFACTURER	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	C387024	04-10-02	100.1	99.9	99.8
SCHLUMBERGER	C387025	04-10-02	100.0	99.7	100.1
SCHLUMBERGER	C387026	04-10-02	100.0	99.9	100.0
SCHLUMBERGER	C387027	04-10-02	100.2	99.9	99.7
SCHLUMBERGER	C387028	04-10-02	100.2	100.2	99.7
SCHLUMBERGER	C387029	04-10-02	100.0	99.7	99.9
SCHLUMBERGER	C387030	04-10-02	99.9	99.8	99.9
SCHLUMBERGER	C387031	04-10-02	100.1	99.7	99.9
SCHLUMBERGER	C387032	04-10-02	100.1	99.9	100.3
SCHLUMBERGER	C387033	04-10-02	100.1	100.0	100.1
SCHLUMBERGER	C387034	04-10-02	100.2	99.8	99.9
SCHLUMBERGER	C387035	04-10-02	99.9	99.8	100.0
SCHLUMBERGER	C387036	04-10-02	100.0	100.0	100.0
SCHLUMBERGER	C387037	04-10-02	99.9	99.7	100.1
SCHLUMBERGER	C387038	04-10-02	100.1	99.9	100.0
SCHLUMBERGER	C387039	04-10-02	99.9	99.8	99.9
SCHLUMBERGER	C387040	04-10-02	100.0	99.8	99.9
SCHLUMBERGER	C387041	04-10-02	100.0	99.7	99.5
SCHLUMBERGER	C387042	04-10-02	100.1	99.7	100.0
SCHLUMBERGER	C387043	04-10-02	99.9	99.8	100.0
SCHLUMBERGER	C387044	04-10-02	100.0	99.9	99.7
SCHLUMBERGER	C387045	04-10-02	100.1	100.0	99.7
SCHLUMBERGER	C387046	04-10-02	100.1	99.9	100.0
SCHLUMBERGER	C387047	04-10-02	99.9	99.9	100.0
SCHLUMBERGER	C387048	04-10-02	99.8	99.9	99.8
SCHLUMBERGER	C387049	04-10-02	100.0	100.0	100.0
SCHLUMBERGER	C387050	04-10-02	100.0	100.1	99.9
SCHLUMBERGER	C387051	04-10-02	100.1	99.8	100.0
SCHLUMBERGER	C387052	04-10-02	100.1	99.8	99.6
SCHLUMBERGER	C387053	04-10-02	99.9	99.9	100.2
SCHLUMBERGER	C387054	04-10-02	99.9	100.0	100.1
SCHLUMBERGER	C387055	04-10-02	99.9	99.8	99.9
SCHLUMBERGER	C387056	04-10-02	100.0	99.8	100.1
SCHLUMBERGER	C387057	04-10-02	100.0	99.8	99.7
SCHLUMBERGER	C387058	04-10-02	100.1	99.9	100.2
SCHLUMBERGER	C387059	04-10-02	100.0	99.7	100.0
SCHLUMBERGER	C387060	04-10-02	100.1	99.8	100.1
SCHLUMBERGER	C387061	04-10-02	100.1	100.0	99.7
SCHLUMBERGER	C387062	04-10-02	99.9	100.0	99.9
SCHLUMBERGER	C387063	04-10-02	100.1	100.0	99.9
SCHLUMBERGER	C387064	04-10-02	100.0	99.8	100.2
SCHLUMBERGER	C387065	04-10-02	99.9	100.0	99.9
SCHLUMBERGER	C387066	04-10-02	100.0	99.7	99.8
SCHLUMBERGER	C387067	04-10-02	100.0	100.1	100.2
SCHLUMBERGER	C387068	04-10-02	100.0	99.8	99.9
SCHLUMBERGER	C387069	04-10-02	100.0	99.7	100.1
SCHLUMBERGER	C387070	04-10-02	100.0	99.9	99.8
SCHLUMBERGER	C387071	04-10-02	99.9	99.9	100.2
SCHLUMBERGER	C387072	04-10-02	99.9	99.8	99.5
SCHLUMBERGER	C387073	04-10-02	100.0	99.8	100.1
SCHLUMBERGER	C387074	04-10-02	100.0	99.8	100.0

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

PAGE 69
 RUN DATE: 1/14/03
 RUN TIME: 13.26.53

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	J55	C387075	04-10-02	99.9	100.1	99.7
SCHLUMBERGER	J55	C387076	04-10-02	100.0	100.0	99.7
SCHLUMBERGER	J55	C387077	04-10-02	100.1	100.2	100.1
SCHLUMBERGER	J55	C387078	04-10-02	100.1	99.9	99.7
SCHLUMBERGER	J55	C387079	04-10-02	100.0	99.7	99.8
SCHLUMBERGER	J55	C387080	04-10-02	99.9	100.0	99.5
SCHLUMBERGER	J55	C387081	04-10-02	100.0	99.9	100.0
SCHLUMBERGER	J55	C387082	04-10-02	100.1	100.2	99.9
SCHLUMBERGER	J55	C387083	04-10-02	100.0	99.7	99.9
SCHLUMBERGER	J55	C387084	04-10-02	100.0	100.0	100.0
SCHLUMBERGER	J55	C387085	04-10-02	100.1	100.0	100.0
SCHLUMBERGER	J55	C387086	04-10-02	99.9	99.7	99.7
SCHLUMBERGER	J55	C387087	04-10-02	100.1	100.3	100.0
SCHLUMBERGER	J55	C387088	04-10-02	99.9	99.8	99.9
SCHLUMBERGER	J55	C387089	04-10-02	99.9	99.7	100.0
SCHLUMBERGER	J55	C387090	04-10-02	100.1	99.7	99.8
SCHLUMBERGER	J55	C387091	04-10-02	100.2	99.9	99.7
SCHLUMBERGER	J55	C387092	04-10-02	99.8	100.0	99.7
SCHLUMBERGER	J55	C387093	04-10-02	100.0	99.9	99.9
SCHLUMBERGER	J55	C387094	04-10-02	100.0	99.9	100.0
SCHLUMBERGER	J55	C387095	04-10-02	100.2	99.7	99.7
SCHLUMBERGER	J55	C387096	04-10-02	100.1	99.8	100.0
SCHLUMBERGER	J55	C387097	04-10-02	99.9	99.9	99.8
SCHLUMBERGER	J55	C387098	04-10-02	99.9	99.9	99.8
SCHLUMBERGER	J55	C387099	04-10-02	100.1	100.0	99.7
SCHLUMBERGER	J55	C387100	04-10-02	100.0	99.7	99.7
SCHLUMBERGER	J55	C387101	04-10-02	99.9	99.8	99.7
SCHLUMBERGER	J55	C387102	04-10-02	100.1	99.9	99.9
SCHLUMBERGER	J55	C387103	04-10-02	100.1	100.1	99.8
SCHLUMBERGER	J55	C387104	04-10-02	100.0	99.8	99.7
SCHLUMBERGER	J55	C387105	04-10-02	100.0	100.0	99.8
SCHLUMBERGER	J55	C387106	04-10-02	100.2	99.9	100.1
SCHLUMBERGER	J55	C387107	04-10-02	100.0	99.9	99.6
SCHLUMBERGER	J55	C387108	04-10-02	100.0	99.8	99.7
SCHLUMBERGER	J55	C387109	04-10-02	100.1	99.8	100.1
SCHLUMBERGER	J55	C387110	04-10-02	100.0	99.8	99.7
SCHLUMBERGER	J55	C387111	04-10-02	99.9	99.8	99.8
SCHLUMBERGER	J55	C387112	04-10-02	100.0	99.8	99.8
SCHLUMBERGER	J55	C387113	04-10-02	99.9	99.8	99.7
SCHLUMBERGER	J55	C387114	04-10-02	100.0	100.0	99.9
SCHLUMBERGER	J55	C387115	04-10-02	100.1	99.8	100.1
SCHLUMBERGER	J55	C387116	04-10-02	100.0	99.8	100.1
SCHLUMBERGER	J55	C387117	04-10-02	100.0	100.0	99.8
SCHLUMBERGER	J55	C387118	04-10-02	100.0	99.8	100.1
SCHLUMBERGER	J55	C387119	04-10-02	100.1	99.8	99.8
SCHLUMBERGER	J55	C387120	04-10-02	100.0	100.0	99.7
SCHLUMBERGER	J55	C387121	04-10-02	99.9	99.6	99.7
SCHLUMBERGER	J55	C387122	04-10-02	100.2	99.7	100.0
SCHLUMBERGER	J55	C387123	04-10-02	100.0	99.9	100.0
SCHLUMBERGER	J55	C387124	04-10-02	100.1	99.8	99.8
SCHLUMBERGER	J55	C387125	04-10-02	99.9	99.8	100.0

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

PAGE 70
 RUN DATE: 1/14/03
 RUN TIME: 13.26.53

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	J5S	C387126	04-10-02	100.1	100.0	100.1
SCHLUMBERGER	J5S	C387127	04-10-02	100.1	99.7	99.7
SCHLUMBERGER	J5S	C387128	04-10-02	100.0	99.7	99.6
SCHLUMBERGER	J5S	C387129	04-10-02	100.2	100.0	100.1
SCHLUMBERGER	J5S	C387130	04-10-02	100.0	100.0	99.9
SCHLUMBERGER	J5S	C387131	04-10-02	100.0	99.8	99.5
SCHLUMBERGER	J5S	C387132	04-10-02	99.9	99.7	100.0
SCHLUMBERGER	J5S	C387133	04-10-02	100.2	100.1	100.3
SCHLUMBERGER	J5S	C387134	04-10-02	99.9	100.0	99.5
SCHLUMBERGER	J5S	C387135	04-10-02	99.9	100.0	99.6
SCHLUMBERGER	J5S	C387136	04-10-02	100.1	100.1	99.9
SCHLUMBERGER	J5S	C387137	04-10-02	100.1	99.9	99.8
SCHLUMBERGER	J5S	C387138	04-10-02	99.9	100.0	99.5
SCHLUMBERGER	J5S	C387139	04-10-02	99.8	99.7	99.3
SCHLUMBERGER	J5S	C387140	04-10-02	99.8	99.9	99.5
SCHLUMBERGER	J5S	C387141	04-10-02	100.1	100.1	99.8
SCHLUMBERGER	J5S	C387142	04-10-02	100.0	99.9	99.9
SCHLUMBERGER	J5S	C387143	04-10-02	99.9	99.9	99.8
SCHLUMBERGER	J5S	C387144	04-10-02	100.2	99.8	99.8
SCHLUMBERGER	J5S	C387145	04-10-02	100.2	100.2	99.9
SCHLUMBERGER	J5S	C387146	04-10-02	100.0	99.9	100.0
SCHLUMBERGER	J5S	C387147	04-10-02	100.0	100.1	100.0
SCHLUMBERGER	J5S	C387148	04-10-02	99.9	99.9	99.6
SCHLUMBERGER	J5S	C387149	04-10-02	100.1	99.8	99.8
SCHLUMBERGER	J5S	C387150	04-10-02	100.1	100.0	100.2
SCHLUMBERGER	J5S	C387151	04-10-02	99.9	99.8	99.8
SCHLUMBERGER	J5S	C387152	04-10-02	100.0	99.7	99.9
SCHLUMBERGER	J5S	C387153	04-10-02	100.0	100.0	99.9
SCHLUMBERGER	J5S	C387154	04-10-02	100.1	100.0	99.9
SCHLUMBERGER	J5S	C387155	04-10-02	99.8	99.8	100.0
SCHLUMBERGER	J5S	C387156	04-10-02	100.1	100.0	99.8
SCHLUMBERGER	J5S	C387157	04-10-02	100.1	99.9	99.9
SCHLUMBERGER	J5S	C387158	04-10-02	100.0	100.1	99.6
SCHLUMBERGER	J5S	C387159	04-10-02	100.0	100.2	99.5
SCHLUMBERGER	J5S	C387160	04-10-02	100.0	99.9	99.9
SCHLUMBERGER	J5S	C387161	04-10-02	99.9	99.9	99.7
SCHLUMBERGER	J5S	C387162	04-10-02	100.0	99.9	99.8
SCHLUMBERGER	J5S	C387163	04-10-02	100.2	99.9	99.4
SCHLUMBERGER	J5S	C387164	04-10-02	100.0	99.9	99.8
SCHLUMBERGER	J5S	C387165	04-10-02	100.0	99.9	99.5
SCHLUMBERGER	J5S	C387166	04-10-02	100.0	100.0	100.3
SCHLUMBERGER	J5S	C387167	04-10-02	100.0	99.8	99.8
SCHLUMBERGER	J5S	C387168	04-10-02	100.0	100.1	99.7
SCHLUMBERGER	J5S	C387169	04-10-02	100.1	99.7	99.9
SCHLUMBERGER	J5S	C387170	04-10-02	100.0	99.9	99.6
SCHLUMBERGER	J5S	C387171	04-10-02	100.3	99.8	99.6
SCHLUMBERGER	J5S	C387172	04-10-02	100.2	99.9	100.2
SCHLUMBERGER	J5S	C387173	04-10-02	99.8	99.7	99.7
SCHLUMBERGER	J5S	C387174	04-10-02	100.1	100.0	99.9
SCHLUMBERGER	J5S	C387175	04-10-02	100.0	99.9	99.9
SCHLUMBERGER	J5S	C387176	04-10-02	99.9	99.6	99.6

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

PAGE 71
 RUN DATE: 1/14/03
 RUN TIME: 13.26.53

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	J55	C387177	04-10-02	100.0	100.0	99.9
SCHLUMBERGER	J55	C387178	04-10-02	100.1	100.0	99.9
SCHLUMBERGER	J55	C387179	04-10-02	100.0	100.2	99.8
SCHLUMBERGER	J55	C387180	04-10-02	100.1	100.1	99.5
SCHLUMBERGER	J55	C387181	04-10-02	100.1	99.9	99.9
SCHLUMBERGER	J55	C387182	04-10-02	100.0	99.8	99.7
SCHLUMBERGER	J55	C387183	04-10-02	99.9	99.9	100.2
SCHLUMBERGER	J55	C387184	04-10-02	100.0	100.1	99.7
SCHLUMBERGER	J55	C387185	04-10-02	99.9	100.0	99.4
SCHLUMBERGER	J55	C387186	04-10-02	100.0	100.0	99.9
SCHLUMBERGER	J55	C387187	04-10-02	100.3	100.0	99.6
SCHLUMBERGER	J55	C387188	04-10-02	100.0	99.9	100.0
SCHLUMBERGER	J55	C387189	04-10-02	99.9	99.8	99.9
SCHLUMBERGER	J55	C387190	04-10-02	99.9	100.2	100.1
SCHLUMBERGER	J55	C387191	04-10-02	99.9	99.8	99.8
SCHLUMBERGER	J55	C387192	04-10-02	100.1	99.8	99.7
SCHLUMBERGER	J55	C387193	04-10-02	100.1	100.1	100.1
SCHLUMBERGER	J55	C387194	04-10-02	99.9	99.8	99.9
SCHLUMBERGER	J55	C387195	04-10-02	100.0	100.0	99.9
SCHLUMBERGER	J55	C387196	04-10-02	100.1	100.3	100.1
SCHLUMBERGER	J55	C387197	04-10-02	100.0	99.9	100.0
SCHLUMBERGER	J55	C387198	04-10-02	100.0	100.0	100.1
SCHLUMBERGER	J55	C387199	04-10-02	100.0	99.8	99.8
SCHLUMBERGER	J55	C387200	04-10-02	100.0	100.0	99.5
SCHLUMBERGER	J55	C387201	04-10-02	100.0	99.9	100.1
SCHLUMBERGER	J55	C387202	04-10-02	100.0	100.0	100.0
SCHLUMBERGER	J55	C387203	04-10-02	100.1	99.9	99.9
SCHLUMBERGER	J55	C387204	04-10-02	100.2	99.8	99.9
SCHLUMBERGER	J55	C387205	04-10-02	100.0	99.9	99.9
SCHLUMBERGER	J55	C387206	04-10-02	100.0	100.0	100.3
SCHLUMBERGER	J55	C387207	04-10-02	100.0	99.9	100.0
SCHLUMBERGER	J55	C387208	04-10-02	100.0	99.8	99.6
SCHLUMBERGER	J55	C387209	04-10-02	100.1	100.1	100.3
SCHLUMBERGER	J55	C387210	04-10-02	100.1	99.8	100.0
SCHLUMBERGER	J55	C387211	04-10-02	100.0	99.6	99.9
SCHLUMBERGER	J55	C387212	04-10-02	99.9	100.1	100.0
SCHLUMBERGER	J55	C387213	04-10-02	100.1	100.1	99.8
SCHLUMBERGER	J55	C387214	04-10-02	100.3	100.3	100.0
SCHLUMBERGER	J55	C387215	04-10-02	100.1	100.3	100.1
SCHLUMBERGER	J55	C387216	04-10-02	100.1	100.1	100.1
SCHLUMBERGER	J55	C387217	04-10-02	100.0	100.0	100.0
SCHLUMBERGER	J55	C387218	04-10-02	100.0	100.0	99.8
SCHLUMBERGER	J55	C387219	04-10-02	100.1	100.1	99.7
SCHLUMBERGER	J55	C387220	04-10-02	99.9	100.0	99.9
SCHLUMBERGER	J55	C387221	04-10-02	100.0	99.9	100.0
SCHLUMBERGER	J55	C387222	04-10-02	99.9	99.7	99.8
SCHLUMBERGER	J55	C387223	04-10-02	99.9	99.9	99.8
SCHLUMBERGER	J55	C387224	04-10-02	100.1	100.0	100.0
SCHLUMBERGER	J55	C387225	04-10-02	100.1	100.0	99.9
SCHLUMBERGER	J55	C387226	04-10-02	100.1	99.9	100.0
SCHLUMBERGER	J55	C387227	04-10-02	100.1	99.9	100.0

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	J5S	C387228	04-10-02	100.0	100.0	99.9
SCHLUMBERGER	J5S	C387229	04-10-02	100.1	100.3	100.1
SCHLUMBERGER	J5S	C387230	04-10-02	100.0	100.1	99.8
SCHLUMBERGER	J5S	C387231	04-10-02	100.0	100.0	99.9
SCHLUMBERGER	J5S	C387232	04-10-02	100.1	99.9	99.9
SCHLUMBERGER	J5S	C387233	04-10-02	100.0	100.0	99.9
SCHLUMBERGER	J5S	C387234	04-10-02	100.0	99.8	99.7
SCHLUMBERGER	J5S	C387235	04-10-02	100.0	100.0	99.7
SCHLUMBERGER	J5S	C387236	04-10-02	100.0	100.2	100.0
SCHLUMBERGER	J5S	C387237	04-10-02	100.0	99.9	99.8
SCHLUMBERGER	J5S	C387238	04-10-02	100.1	99.9	100.4
SCHLUMBERGER	J5S	C387239	04-10-02	100.0	100.0	100.2
SCHLUMBERGER	J5S	C387240	04-10-02	100.1	100.1	100.3
SCHLUMBERGER	J5S	C387241	04-10-02	99.8	99.8	100.2
SCHLUMBERGER	J5S	C387242	04-10-02	99.9	99.8	99.7
SCHLUMBERGER	J5S	C387243	04-10-02	99.9	100.2	100.2
SCHLUMBERGER	J5S	C387244	04-10-02	100.0	99.9	99.5
SCHLUMBERGER	J5S	C387245	04-10-02	100.0	99.8	99.8
SCHLUMBERGER	J5S	C387246	04-10-02	100.1	99.8	100.0
SCHLUMBERGER	J5S	C387247	04-10-02	100.1	100.1	100.1
SCHLUMBERGER	J5S	C387248	04-10-02	99.9	99.9	99.8
SCHLUMBERGER	J5S	C387249	04-10-02	100.0	100.0	99.6
SCHLUMBERGER	J5S	C387250	04-10-02	100.0	99.8	99.8
SCHLUMBERGER	J5S	C387251	04-10-02	100.2	100.0	100.3
SCHLUMBERGER	J5S	C387252	04-10-02	100.0	99.8	99.9
SCHLUMBERGER	J5S	C387253	04-10-02	100.0	99.6	99.9
SCHLUMBERGER	J5S	C387254	04-10-02	99.9	99.8	99.7
SCHLUMBERGER	J5S	C387255	04-10-02	99.9	100.1	100.0
SCHLUMBERGER	J5S	C387256	04-10-02	100.0	99.8	100.3
SCHLUMBERGER	J5S	C387257	04-10-02	100.0	100.1	99.7
SCHLUMBERGER	J5S	C387258	04-10-02	100.0	99.8	100.3
SCHLUMBERGER	J5S	C387259	04-10-02	100.1	99.8	100.4
SCHLUMBERGER	J5S	C387260	04-10-02	100.1	99.7	100.1
SCHLUMBERGER	J5S	C387261	04-10-02	100.0	100.0	100.0
SCHLUMBERGER	J5S	C387262	04-10-02	100.2	100.2	99.9
SCHLUMBERGER	J5S	C387263	04-10-02	100.1	99.9	100.1
SCHLUMBERGER	J5S	C387264	04-10-02	100.0	100.0	100.2
SCHLUMBERGER	J5S	C387265	04-10-02	99.9	99.9	99.6
SCHLUMBERGER	J5S	C387266	04-10-02	99.9	99.9	100.0
SCHLUMBERGER	J5S	C387267	04-10-02	100.0	100.2	100.0
SCHLUMBERGER	J5S	C387268	04-10-02	100.2	99.9	100.1
SCHLUMBERGER	J5S	C387269	04-10-02	100.0	100.1	100.0
SCHLUMBERGER	J5S	C387270	04-10-02	100.1	99.8	100.2
SCHLUMBERGER	J5S	C387271	04-10-02	99.9	99.7	100.0
SCHLUMBERGER	J5S	C387272	04-10-02	100.0	99.7	99.9
SCHLUMBERGER	J5S	C387273	04-10-02	100.0	99.7	100.2
SCHLUMBERGER	J5S	C387274	04-10-02	100.1	100.1	100.3
SCHLUMBERGER	J5S	C387275	04-10-02	100.0	99.8	100.0
SCHLUMBERGER	J5S	C387276	04-10-02	100.0	99.8	99.8
SCHLUMBERGER	J5S	C387277	04-10-02	100.0	99.8	99.9
SCHLUMBERGER	J5S	C387278	04-10-02	99.9	99.9	99.9

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	J55	C387279	04-10-02	100.0	100.1	100.1
SCHLUMBERGER	J55	C387280	04-10-02	100.0	100.1	100.0
SCHLUMBERGER	J55	C387281	04-10-02	100.0	99.9	99.9
SCHLUMBERGER	J55	C387282	04-10-02	100.0	99.9	99.8
SCHLUMBERGER	J55	C387283	04-10-02	100.2	99.9	99.8
SCHLUMBERGER	J55	C387284	04-10-02	99.8	99.7	99.7
SCHLUMBERGER	J55	C387285	04-10-02	100.0	100.0	99.5
SCHLUMBERGER	J55	C387286	04-10-02	100.1	100.1	100.2
SCHLUMBERGER	J55	C387287	04-10-02	100.1	100.1	100.3
SCHLUMBERGER	J55	C387288	04-10-02	100.0	99.9	100.1
SCHLUMBERGER	J55	C387289	04-10-02	100.2	100.2	100.3
SCHLUMBERGER	J55	C387290	04-10-02	100.0	100.1	99.8
SCHLUMBERGER	J55	C387291	04-10-02	100.2	100.3	100.4
SCHLUMBERGER	J55	C387292	04-10-02	100.3	100.2	100.1
SCHLUMBERGER	J55	C387293	04-10-02	100.0	100.0	99.8
SCHLUMBERGER	J55	C387294	04-10-02	100.1	100.1	100.0
SCHLUMBERGER	J55	C387295	04-10-02	100.0	100.0	99.9
SCHLUMBERGER	J55	C387296	04-10-02	100.3	99.8	99.9
SCHLUMBERGER	J55	C387297	04-10-02	100.0	99.9	99.7
SCHLUMBERGER	J55	C387298	04-10-02	100.0	99.8	99.8
SCHLUMBERGER	J55	C387299	04-10-02	100.0	100.0	99.6
SCHLUMBERGER	J55	C387300	04-10-02	100.0	99.7	100.1
SCHLUMBERGER	J55	C387301	04-10-02	100.0	99.8	100.0
SCHLUMBERGER	J55	C387302	04-10-02	100.1	100.1	100.2
SCHLUMBERGER	J55	C387303	04-10-02	100.0	99.9	99.7
SCHLUMBERGER	J55	C387304	04-10-02	100.0	100.2	99.8
SCHLUMBERGER	J55	C387305	04-10-02	100.1	99.8	100.3
SCHLUMBERGER	J55	C387306	04-10-02	100.0	100.1	99.8
SCHLUMBERGER	J55	C387307	04-10-02	100.1	100.1	99.9
SCHLUMBERGER	J55	C387308	04-10-02	100.0	100.0	100.1
SCHLUMBERGER	J55	C387309	04-10-02	100.0	99.9	99.9
SCHLUMBERGER	J55	C387310	04-10-02	100.1	99.9	100.2
SCHLUMBERGER	J55	C387311	04-10-02	100.1	99.9	100.3
SCHLUMBERGER	J55	C387312	04-10-02	100.1	100.1	100.0
SCHLUMBERGER	J55	C387313	04-10-02	100.0	99.7	99.7
SCHLUMBERGER	J55	C387314	04-10-02	100.0	100.0	99.8
SCHLUMBERGER	J55	C387315	04-10-02	100.0	100.0	100.0
SCHLUMBERGER	J55	C387316	04-10-02	100.0	100.2	100.2
SCHLUMBERGER	J55	C387317	04-10-02	99.9	99.9	99.8
SCHLUMBERGER	J55	C387318	04-10-02	100.1	100.1	100.2
SCHLUMBERGER	J55	C387319	04-10-02	100.1	99.8	99.8
SCHLUMBERGER	J55	C387320	04-10-02	99.9	99.9	100.0
SCHLUMBERGER	J55	C387321	04-10-02	100.3	100.1	100.5
SCHLUMBERGER	J55	C387322	04-10-02	100.1	100.0	100.2
SCHLUMBERGER	J55	C387323	04-10-02	100.1	99.7	100.2
SCHLUMBERGER	J55	C387324	04-10-02	100.0	100.0	99.9
SCHLUMBERGER	J55	C387325	04-10-02	100.0	99.8	99.8
SCHLUMBERGER	J55	C387326	04-10-02	99.9	99.9	99.7
SCHLUMBERGER	J55	C387327	04-10-02	100.0	100.1	100.1
SCHLUMBERGER	J55	C387328	04-10-02	99.9	100.0	100.0
SCHLUMBERGER	J55	C387329	04-10-02	100.0	99.9	100.3

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

PAGE 74
 RUN DATE: 1/14/03
 RUN TIME: 13.26.53

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	J55	C387330	04-10-02	100.0	100.0	99.9
SCHLUMBERGER	J55	C387331	04-10-02	100.1	100.0	100.2
SCHLUMBERGER	J55	C387332	04-10-02	100.1	100.0	100.0
SCHLUMBERGER	J55	C387333	04-10-02	100.2	100.1	100.3
SCHLUMBERGER	J55	C387334	04-10-02	100.1	99.9	100.1
SCHLUMBERGER	J55	C387335	04-10-02	100.0	100.0	100.1
SCHLUMBERGER	J55	C387336	04-10-02	100.1	100.0	100.0
SCHLUMBERGER	J55	C387337	04-10-02	100.1	100.1	100.0
SCHLUMBERGER	J55	C387338	04-10-02	100.2	100.0	99.9
SCHLUMBERGER	J55	C387339	04-10-02	100.0	99.9	100.0
SCHLUMBERGER	J55	C387340	04-10-02	100.0	100.0	100.0
SCHLUMBERGER	J55	C387341	04-10-02	100.1	100.0	100.1
SCHLUMBERGER	J55	C387342	04-10-02	100.1	100.0	100.2
SCHLUMBERGER	J55	C387343	04-10-02	99.8	99.7	99.5
SCHLUMBERGER	J55	C387344	04-10-02	100.2	100.4	100.3
SCHLUMBERGER	J55	C387345	04-10-02	99.9	100.2	99.9
SCHLUMBERGER	J55	C387346	04-10-02	100.2	99.7	100.0
SCHLUMBERGER	J55	C387347	04-10-02	100.0	99.7	99.9
SCHLUMBERGER	J55	C387348	04-10-02	100.1	99.8	100.0
SCHLUMBERGER	J55	C387349	04-10-02	100.0	100.0	100.0
SCHLUMBERGER	J55	C387350	04-10-02	100.0	100.2	100.1
SCHLUMBERGER	J55	C387351	04-10-02	100.1	100.1	100.0
SCHLUMBERGER	J55	C387352	04-10-02	100.1	99.8	100.3
SCHLUMBERGER	J55	C387353	04-10-02	100.0	100.1	100.0
SCHLUMBERGER	J55	C387354	04-10-02	99.9	99.9	99.8
SCHLUMBERGER	J55	C387355	04-10-02	100.0	99.8	100.0
SCHLUMBERGER	J55	C387356	04-10-02	100.1	100.2	99.9
SCHLUMBERGER	J55	C387357	04-10-02	100.0	100.3	99.6
SCHLUMBERGER	J55	C387358	04-10-02	100.0	100.1	100.1
SCHLUMBERGER	J55	C387359	04-10-02	99.8	99.8	99.9
SCHLUMBERGER	J55	C387360	04-10-02	100.0	99.9	99.7
SCHLUMBERGER	J55	C387361	04-10-02	100.1	99.8	99.8
SCHLUMBERGER	J55	C387362	04-10-02	100.1	100.1	100.2
SCHLUMBERGER	J55	C387363	04-10-02	100.0	99.7	100.1
SCHLUMBERGER	J55	C387364	04-10-02	100.0	99.9	99.8
SCHLUMBERGER	J55	C387365	04-10-02	100.1	100.0	100.0
SCHLUMBERGER	J55	C387366	04-10-02	99.8	99.7	99.9
SCHLUMBERGER	J55	C387367	04-10-02	100.0	100.1	99.8
SCHLUMBERGER	J55	C387368	04-10-02	100.0	99.8	100.1
SCHLUMBERGER	J55	C387369	04-10-02	100.0	99.8	100.1
SCHLUMBERGER	J55	C387370	04-10-02	100.0	100.1	100.1
SCHLUMBERGER	J55	C387371	04-10-02	100.1	99.9	100.0
SCHLUMBERGER	J55	C387372	04-10-02	99.9	100.0	99.7
SCHLUMBERGER	J55	C387373	04-10-02	100.0	100.0	100.0
SCHLUMBERGER	J55	C387374	04-10-02	100.1	100.1	100.0
SCHLUMBERGER	J55	C387375	04-10-02	100.0	99.9	99.6
SCHLUMBERGER	J55	C387376	04-10-02	100.0	99.9	100.1
SCHLUMBERGER	J55	C387377	04-10-02	100.0	99.8	100.0
SCHLUMBERGER	J55	C387378	04-10-02	100.0	99.9	99.8
SCHLUMBERGER	J55	C387379	04-10-02	100.0	99.9	100.0
SCHLUMBERGER	J55	C387380	04-10-02	100.0	99.9	99.4

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

PAGE 75
 RUN DATE: 1/14/03
 RUN TIME: 13.26.53

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	J55	C387381	04-10-02	100.1	99.6	100.0
SCHLUMBERGER	J55	C387382	04-10-02	100.1	100.0	99.9
SCHLUMBERGER	J55	C387383	04-10-02	100.1	100.0	100.3
SCHLUMBERGER	J55	C387384	04-10-02	100.0	99.8	99.9
SCHLUMBERGER	J55	C387385	04-10-02	100.0	100.1	99.8
SCHLUMBERGER	J55	C387386	04-10-02	100.1	100.0	99.9
SCHLUMBERGER	J55	C387387	04-10-02	100.0	99.8	99.8
SCHLUMBERGER	J55	C387388	04-10-02	99.9	100.1	99.9
SCHLUMBERGER	J55	C387389	04-10-02	100.1	99.9	99.9
SCHLUMBERGER	J55	C387390	04-10-02	100.2	100.1	100.1
SCHLUMBERGER	J55	C387391	04-10-02	100.1	99.9	100.0
SCHLUMBERGER	J55	C387392	04-10-02	100.1	100.1	100.0
SCHLUMBERGER	J55	C387393	04-10-02	100.1	100.1	100.2
SCHLUMBERGER	J55	C387394	04-10-02	99.9	100.0	99.9
SCHLUMBERGER	J55	C387395	04-10-02	100.0	100.0	99.8
SCHLUMBERGER	J55	C387396	04-10-02	100.0	99.8	100.2
SCHLUMBERGER	J55	C387397	04-10-02	100.0	100.0	99.9
SCHLUMBERGER	J55	C387398	04-10-02	100.0	99.9	99.8
SCHLUMBERGER	J55	C387399	04-10-02	100.0	100.0	99.8
SCHLUMBERGER	J55	C387400	04-10-02	100.0	99.8	100.0
SCHLUMBERGER	J55	C387401	04-10-02	100.2	100.0	100.2
SCHLUMBERGER	J55	C387402	04-10-02	100.0	100.0	99.6
SCHLUMBERGER	J55	C387403	04-10-02	100.0	99.8	99.8
SCHLUMBERGER	J55	C387404	04-10-02	100.1	100.1	100.2
SCHLUMBERGER	J55	C387405	04-10-02	100.1	100.5	100.0
SCHLUMBERGER	J55	C387406	04-10-02	100.0	99.7	100.0
SCHLUMBERGER	J55	C387407	04-10-02	100.0	100.2	99.9
SCHLUMBERGER	J55	C387408	04-10-02	100.0	100.0	100.1
SCHLUMBERGER	J55	C387409	04-10-02	99.9	99.8	100.2
SCHLUMBERGER	J55	C387410	04-10-02	100.0	99.9	100.1
SCHLUMBERGER	J55	C387411	04-10-02	100.1	100.1	99.8
SCHLUMBERGER	J55	C387412	04-10-02	99.8	99.9	100.1
SCHLUMBERGER	J55	C387413	04-10-02	99.9	99.9	99.9
SCHLUMBERGER	J55	C387414	04-10-02	100.0	99.7	99.8
SCHLUMBERGER	J55	C387415	04-10-02	100.0	99.8	100.0
SCHLUMBERGER	J55	C387416	04-10-02	100.0	99.9	99.9
SCHLUMBERGER	J55	C387417	04-10-02	100.0	99.6	99.9
SCHLUMBERGER	J55	C387418	04-10-02	100.1	100.2	99.9
SCHLUMBERGER	J55	C387419	04-10-02	100.0	99.9	100.0
SCHLUMBERGER	J55	C387420	04-10-02	100.1	99.9	100.2
SCHLUMBERGER	J55	C387421	04-10-02	100.1	99.9	100.1
SCHLUMBERGER	J55	C387422	04-10-02	100.2	100.2	100.2
SCHLUMBERGER	J55	C387423	04-10-02	100.0	100.1	99.6
SCHLUMBERGER	J55	C387424	04-10-02	100.0	99.8	99.8
SCHLUMBERGER	J55	C387425	04-10-02	99.9	99.8	100.0
SCHLUMBERGER	J55	C387426	04-10-02	99.9	99.8	99.7
SCHLUMBERGER	J55	C387427	04-10-02	99.9	100.0	99.9
SCHLUMBERGER	J55	C387428	04-10-02	100.0	99.9	100.2
SCHLUMBERGER	J55	C387429	04-10-02	100.1	100.1	99.9
SCHLUMBERGER	J55	C387430	04-10-02	100.1	100.0	99.8
SCHLUMBERGER	J55	C387431	04-10-02	100.0	99.9	100.0

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

PAGE 76
 RUN DATE: 1/14/03
 RUN TIME: 13.26.53

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	J5S	C387432	04-10-02	100.0	100.0	100.2
SCHLUMBERGER	J5S	C387433	04-10-02	100.0	100.2	99.5
SCHLUMBERGER	J5S	C387434	04-10-02	100.1	99.9	99.7
SCHLUMBERGER	J5S	C387435	04-10-02	100.2	100.3	100.3
SCHLUMBERGER	J5S	C387436	04-10-02	100.1	100.2	99.7
SCHLUMBERGER	J5S	C387437	04-10-02	100.0	99.9	99.9
SCHLUMBERGER	J5S	C387438	04-10-02	100.0	100.1	100.2
SCHLUMBERGER	J5S	C387439	04-10-02	100.0	100.0	99.8
SCHLUMBERGER	J5S	C387440	04-10-02	99.9	99.7	99.3
SCHLUMBERGER	J5S	C387441	04-10-02	100.1	100.0	99.8
SCHLUMBERGER	J5S	C387442	04-10-02	100.0	99.9	99.7
SCHLUMBERGER	J5S	C387443	04-10-02	100.1	100.0	100.3
SCHLUMBERGER	J5S	C387444	04-10-02	100.1	99.9	100.3
SCHLUMBERGER	J5S	C387445	04-10-02	100.1	99.9	100.1
SCHLUMBERGER	J5S	C387446	04-10-02	100.0	100.2	100.0
SCHLUMBERGER	J5S	C387447	04-10-02	100.0	99.9	99.8
SCHLUMBERGER	J5S	C387448	04-10-02	100.0	99.7	99.9
SCHLUMBERGER	J5S	C387449	04-10-02	100.0	99.8	99.8
SCHLUMBERGER	J5S	C387450	04-10-02	100.1	100.5	100.3
SCHLUMBERGER	J5S	C387451	04-10-02	100.0	100.0	100.3
SCHLUMBERGER	J5S	C387452	04-10-02	99.9	99.7	100.1
SCHLUMBERGER	J5S	C387453	04-10-02	99.9	100.0	99.7
SCHLUMBERGER	J5S	C387454	04-10-02	99.9	100.2	99.6
SCHLUMBERGER	J5S	C387455	04-10-02	100.1	100.0	100.2
SCHLUMBERGER	J5S	C387456	04-10-02	100.0	100.1	100.0
SCHLUMBERGER	J5S	C387457	04-10-02	100.0	100.0	99.9
SCHLUMBERGER	J5S	C387458	04-10-02	100.0	100.0	99.8
SCHLUMBERGER	J5S	C387459	04-10-02	100.0	99.8	99.6
SCHLUMBERGER	J5S	C387460	04-10-02	100.0	100.0	99.3
SCHLUMBERGER	J5S	C387461	04-10-02	100.0	100.0	99.8
SCHLUMBERGER	J5S	C387462	04-10-02	100.0	100.0	100.0
SCHLUMBERGER	J5S	C387463	04-10-02	100.0	100.1	100.1
SCHLUMBERGER	J5S	C387464	04-10-02	100.0	99.9	99.3
SCHLUMBERGER	J5S	C387465	04-09-02	100.2	100.1	100.3
SCHLUMBERGER	J5S	C387466	04-09-02	100.3	100.0	100.3
SCHLUMBERGER	J5S	C387467	04-09-02	100.1	100.1	100.3
SCHLUMBERGER	J5S	C387468	04-09-02	100.1	99.8	100.0
SCHLUMBERGER	J5S	C387469	04-09-02	100.0	100.0	100.1
SCHLUMBERGER	J5S	C387470	04-09-02	100.0	99.9	99.8
SCHLUMBERGER	J5S	C387471	04-09-02	99.8	99.6	100.1
SCHLUMBERGER	J5S	C387472	04-09-02	100.0	100.0	100.0
SCHLUMBERGER	J5S	C387473	04-09-02	100.0	99.9	100.2
SCHLUMBERGER	J5S	C387474	04-09-02	100.0	99.9	99.9
SCHLUMBERGER	J5S	C387475	04-09-02	100.0	99.8	100.2
SCHLUMBERGER	J5S	C387476	04-09-02	99.9	100.2	99.5
SCHLUMBERGER	J5S	C387477	04-09-02	100.1	100.1	100.3
SCHLUMBERGER	J5S	C387478	04-09-02	100.1	100.0	100.2
SCHLUMBERGER	J5S	C387479	04-09-02	100.0	99.9	99.7
SCHLUMBERGER	J5S	C387480	04-09-02	100.0	99.9	100.1
SCHLUMBERGER	J5S	C387481	04-09-02	100.1	100.3	100.1
SCHLUMBERGER	J5S	C387482	04-09-02	99.9	100.0	99.8

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	J55	C387483	04-09-02	100.0	99.9	99.8
SCHLUMBERGER	J55	C387484	04-09-02	100.2	100.1	99.9
SCHLUMBERGER	J55	C387485	04-09-02	100.2	99.9	100.0
SCHLUMBERGER	J55	C387486	04-09-02	100.0	100.0	99.6
SCHLUMBERGER	J55	C387487	04-09-02	99.9	99.8	99.8
SCHLUMBERGER	J55	C387488	04-09-02	100.0	99.6	99.8
SCHLUMBERGER	J55	C387489	04-09-02	100.1	99.9	100.0
SCHLUMBERGER	J55	C387490	04-09-02	100.0	100.0	99.9
SCHLUMBERGER	J55	C387491	04-09-02	100.1	100.2	100.1
SCHLUMBERGER	J55	C387492	04-09-02	99.9	99.9	99.9
SCHLUMBERGER	J55	C387493	04-09-02	100.0	100.0	99.8
SCHLUMBERGER	J55	C387494	04-09-02	100.0	100.1	99.9
SCHLUMBERGER	J55	C387495	04-09-02	100.0	100.0	100.4
SCHLUMBERGER	J55	C387496	04-09-02	100.0	100.1	100.0
SCHLUMBERGER	J55	C387497	04-09-02	100.0	100.0	100.0
SCHLUMBERGER	J55	C387498	04-09-02	100.1	100.0	100.0
SCHLUMBERGER	J55	C387499	04-09-02	100.2	100.0	100.2
SCHLUMBERGER	J55	C387500	04-09-02	100.0	99.9	100.0
SCHLUMBERGER	J55	C387501	04-09-02	100.1	100.1	99.8
SCHLUMBERGER	J55	C387502	04-09-02	100.0	100.1	100.2
SCHLUMBERGER	J55	C387503	04-09-02	100.1	99.9	100.0
SCHLUMBERGER	J55	C387504	04-09-02	100.1	99.8	100.0
SCHLUMBERGER	J55	C387505	04-09-02	100.0	99.8	100.2
SCHLUMBERGER	J55	C387506	04-09-02	100.1	99.8	99.8
SCHLUMBERGER	J55	C387507	04-09-02	100.0	99.9	100.1
SCHLUMBERGER	J55	C387508	04-09-02	100.0	100.0	99.7
SCHLUMBERGER	J55	C387509	04-09-02	100.0	100.0	99.9
SCHLUMBERGER	J55	C387510	04-09-02	100.0	99.9	99.9
SCHLUMBERGER	J55	C387511	04-09-02	100.2	100.2	99.8
SCHLUMBERGER	J55	C387512	04-09-02	100.2	99.7	100.3
SCHLUMBERGER	J55	C387513	04-09-02	100.0	99.9	99.9
SCHLUMBERGER	J55	C387514	04-09-02	99.9	99.8	100.0
SCHLUMBERGER	J55	C387515	04-09-02	100.1	99.8	99.7
SCHLUMBERGER	J55	C387516	04-09-02	100.0	99.9	99.8
SCHLUMBERGER	J55	C387517	04-09-02	100.1	100.2	99.8
SCHLUMBERGER	J55	C387518	04-09-02	99.9	99.9	100.2
SCHLUMBERGER	J55	C387519	04-09-02	100.1	100.0	100.2
SCHLUMBERGER	J55	C387520	04-09-02	100.0	99.8	99.8
SCHLUMBERGER	J55	C387521	04-09-02	99.9	99.8	100.1
SCHLUMBERGER	J55	C387522	04-09-02	99.9	99.8	99.9
SCHLUMBERGER	J55	C387523	04-09-02	100.0	100.1	100.0
SCHLUMBERGER	J55	C387524	04-09-02	99.9	99.9	100.0
SCHLUMBERGER	J55	C387525	04-09-02	100.0	100.1	100.1
SCHLUMBERGER	J55	C387526	04-09-02	100.0	99.9	100.0
SCHLUMBERGER	J55	C387527	04-09-02	99.8	99.8	99.7
SCHLUMBERGER	J55	C387528	04-09-02	100.0	99.9	99.8
SCHLUMBERGER	J55	C387529	04-09-02	99.9	99.9	99.7
SCHLUMBERGER	J55	C387530	04-09-02	100.0	100.1	100.0
SCHLUMBERGER	J55	C387531	04-09-02	100.0	99.8	100.0
SCHLUMBERGER	J55	C387532	04-09-02	100.0	100.4	99.7
SCHLUMBERGER	J55	C387533	04-09-02	100.0	99.9	99.7

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

PAGE 78
 RUN DATE: 1/14/03
 RUN TIME: 13.26.53

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	J5S	C387534	04-09-02	100.0	100.0	99.6
SCHLUMBERGER	J5S	C387535	04-09-02	100.0	100.0	99.7
SCHLUMBERGER	J5S	C387536	04-09-02	100.2	100.0	100.1
SCHLUMBERGER	J5S	C387537	04-09-02	100.0	100.0	99.8
SCHLUMBERGER	J5S	C387538	04-09-02	100.0	100.1	99.7
SCHLUMBERGER	J5S	C387539	04-09-02	99.9	99.8	99.7
SCHLUMBERGER	J5S	C387540	04-09-02	100.0	100.0	100.1
SCHLUMBERGER	J5S	C387541	04-09-02	100.0	100.0	99.9
SCHLUMBERGER	J5S	C387542	04-09-02	100.1	100.0	100.2
SCHLUMBERGER	J5S	C387543	04-09-02	100.2	100.0	100.3
SCHLUMBERGER	J5S	C387544	04-09-02	100.3	99.8	99.9
SCHLUMBERGER	J5S	C387545	04-09-02	100.1	99.9	100.1
SCHLUMBERGER	J5S	C387546	04-09-02	99.8	99.9	99.7
SCHLUMBERGER	J5S	C387547	04-09-02	100.0	99.9	99.6
SCHLUMBERGER	J5S	C387548	04-09-02	100.1	100.2	100.2
SCHLUMBERGER	J5S	C387549	04-09-02	99.9	99.7	99.9
SCHLUMBERGER	J5S	C387550	04-09-02	99.9	100.1	100.2
SCHLUMBERGER	J5S	C387551	04-09-02	100.0	100.0	100.1
SCHLUMBERGER	J5S	C387552	04-09-02	99.9	99.9	99.7
SCHLUMBERGER	J5S	C387553	04-09-02	100.1	100.0	100.2
SCHLUMBERGER	J5S	C387554	04-09-02	100.0	99.9	99.9
SCHLUMBERGER	J5S	C387555	04-09-02	100.2	100.0	100.3
SCHLUMBERGER	J5S	C387556	04-09-02	100.0	99.9	100.0
SCHLUMBERGER	J5S	C387557	04-09-02	100.0	99.9	99.5
SCHLUMBERGER	J5S	C387558	04-09-02	100.0	100.0	99.9
SCHLUMBERGER	J5S	C387559	04-09-02	99.8	100.1	99.7
SCHLUMBERGER	J5S	C387560	04-09-02	99.9	100.1	99.9
SCHLUMBERGER	J5S	C387561	04-09-02	100.2	100.1	100.0
SCHLUMBERGER	J5S	C387562	04-09-02	100.1	100.0	100.0
SCHLUMBERGER	J5S	C387563	04-09-02	100.0	100.1	100.0
SCHLUMBERGER	J5S	C387564	04-09-02	100.0	100.1	100.1
SCHLUMBERGER	J5S	C387565	04-09-02	100.1	100.2	100.1
SCHLUMBERGER	J5S	C387566	04-09-02	100.0	100.0	100.4
SCHLUMBERGER	J5S	C387567	04-09-02	100.0	100.0	100.1
SCHLUMBERGER	J5S	C387568	04-09-02	99.9	100.0	100.0
SCHLUMBERGER	J5S	C387569	04-09-02	99.9	100.0	99.8
SCHLUMBERGER	J5S	C387570	04-09-02	99.9	99.8	100.1
SCHLUMBERGER	J5S	C387571	04-09-02	100.0	99.8	99.7
SCHLUMBERGER	J5S	C387572	04-09-02	100.0	100.1	99.8
SCHLUMBERGER	J5S	C387573	04-09-02	100.1	99.9	100.1
SCHLUMBERGER	J5S	C387574	04-09-02	100.0	100.1	100.0
SCHLUMBERGER	J5S	C387575	04-09-02	100.1	100.4	100.2
SCHLUMBERGER	J5S	C387576	04-09-02	100.0	99.9	99.6
SCHLUMBERGER	J5S	C387577	04-09-02	100.1	100.3	100.1
SCHLUMBERGER	J5S	C387578	04-09-02	100.0	99.9	99.8
SCHLUMBERGER	J5S	C387579	04-09-02	99.9	99.8	99.7
SCHLUMBERGER	J5S	C387580	04-09-02	100.0	99.7	100.0
SCHLUMBERGER	J5S	C387581	04-09-02	100.0	100.1	100.0
SCHLUMBERGER	J5S	C387582	04-09-02	100.1	99.9	100.2
SCHLUMBERGER	J5S	C387583	04-09-02	100.0	100.1	100.1
SCHLUMBERGER	J5S	C387584	04-09-02	99.9	99.7	99.8

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	J55	C387585	04-09-02	99.8	99.8	99.6
SCHLUMBERGER	J55	C387586	04-09-02	100.0	100.1	99.9
SCHLUMBERGER	J55	C387587	04-09-02	99.8	99.9	99.8
SCHLUMBERGER	J55	C387588	04-09-02	99.9	100.0	99.8
SCHLUMBERGER	J55	C387589	04-10-02	100.1	100.1	100.1
SCHLUMBERGER	J55	C387590	04-09-02	100.1	99.9	99.9
SCHLUMBERGER	J55	C387591	04-09-02	100.1	100.1	100.1
SCHLUMBERGER	J55	C387592	04-09-02	99.9	99.8	99.9
SCHLUMBERGER	J55	C387593	04-09-02	100.0	100.0	100.1
SCHLUMBERGER	J55	C387594	04-09-02	100.0	100.0	99.8
SCHLUMBERGER	J55	C387595	04-09-02	99.9	99.6	99.9
SCHLUMBERGER	J55	C387596	04-09-02	100.0	100.0	100.3
SCHLUMBERGER	J55	C387597	04-09-02	100.0	100.2	100.3
SCHLUMBERGER	J55	C387598	04-09-02	100.0	99.6	100.1
SCHLUMBERGER	J55	C387599	04-09-02	99.8	99.6	99.6
SCHLUMBERGER	J55	C387728	06-11-02	100.0	99.6	100.6
SCHLUMBERGER	J55	C387729	06-11-02	100.0	99.9	100.3
SCHLUMBERGER	J55	C387730	06-11-02	100.0	100.0	100.2
SCHLUMBERGER	J55	C387731	06-11-02	100.0	99.9	100.2
SCHLUMBERGER	J55	C387732	06-11-02	99.9	99.9	100.0
SCHLUMBERGER	J55	C387733	06-11-02	99.8	99.7	99.8
SCHLUMBERGER	J55	C387734	06-11-02	100.0	99.8	100.1
SCHLUMBERGER	J55	C387735	06-11-02	100.1	99.9	100.1
SCHLUMBERGER	J55	C387736	06-11-02	100.1	99.8	100.3
SCHLUMBERGER	J55	C387737	06-11-02	100.1	100.3	100.4
SCHLUMBERGER	J55	C387738	06-11-02	100.3	99.8	100.0
SCHLUMBERGER	J55	C387739	06-11-02	100.1	100.0	99.7
SCHLUMBERGER	J55	C387740	06-11-02	99.9	99.8	100.2
SCHLUMBERGER	J55	C387741	06-11-02	100.1	100.1	100.2
SCHLUMBERGER	J55	C387742	06-11-02	100.0	100.2	100.1
SCHLUMBERGER	J55	C387743	06-11-02	99.9	99.8	99.8
SCHLUMBERGER	J55	C387744	06-11-02	100.1	100.1	100.1
SCHLUMBERGER	J55	C387745	06-11-02	99.9	100.0	100.2
SCHLUMBERGER	J55	C387746	06-11-02	100.1	100.1	100.1
SCHLUMBERGER	J55	C387747	06-11-02	99.9	100.0	100.0
SCHLUMBERGER	J55	C387748	06-11-02	100.1	100.1	100.8
SCHLUMBERGER	J55	C387749	06-11-02	99.8	99.8	100.0
SCHLUMBERGER	J55	C387750	06-11-02	100.2	100.4	100.0
SCHLUMBERGER	J55	C387751	06-11-02	99.8	100.1	99.8
SCHLUMBERGER	J55	C387752	06-11-02	99.9	100.2	99.8
SCHLUMBERGER	J55	C387753	06-11-02	100.1	99.8	100.0
SCHLUMBERGER	J55	C387754	06-11-02	99.9	99.9	99.9
SCHLUMBERGER	J55	C387755	06-11-02	99.9	100.2	99.9
SCHLUMBERGER	J55	C387756	06-11-02	100.2	100.2	100.7
SCHLUMBERGER	J55	C387757	06-11-02	99.9	100.1	99.8
SCHLUMBERGER	J55	C387758	06-11-02	100.1	100.1	100.4
SCHLUMBERGER	J55	C387759	06-11-02	100.2	100.3	100.4
SCHLUMBERGER	J55	C387760	06-11-02	99.9	100.1	100.1
SCHLUMBERGER	J55	C387761	06-11-02	100.1	100.0	100.2
SCHLUMBERGER	J55	C387762	06-11-02	100.2	100.1	100.0
SCHLUMBERGER	J55	C387763	06-11-02	99.9	100.1	99.7

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	J5S	C387764	06-11-02	100.0	100.2	100.0
SCHLUMBERGER	J5S	C387765	06-11-02	100.0	100.2	100.0
SCHLUMBERGER	J5S	C387766	06-11-02	100.0	99.8	100.3
SCHLUMBERGER	J5S	C387767	06-11-02	100.0	99.8	100.2
SCHLUMBERGER	J5S	C387768	06-11-02	100.0	99.8	99.8
SCHLUMBERGER	J5S	C387769	06-11-02	100.1	100.2	100.3
SCHLUMBERGER	J5S	C387770	06-11-02	100.1	99.8	100.4
SCHLUMBERGER	J5S	C387771	06-11-02	100.1	100.2	100.2
SCHLUMBERGER	J5S	C387772	06-11-02	100.1	99.8	99.9
SCHLUMBERGER	J5S	C387773	06-11-02	100.0	100.3	100.1
SCHLUMBERGER	J5S	C387774	06-11-02	99.8	99.8	99.7
SCHLUMBERGER	J5S	C387775	06-11-02	100.1	100.3	100.4
SCHLUMBERGER	J5S	C387776	06-11-02	100.1	99.9	100.1
SCHLUMBERGER	J5S	C387777	06-11-02	100.2	100.4	100.2
SCHLUMBERGER	J5S	C387778	06-11-02	99.9	99.9	100.0
SCHLUMBERGER	J5S	C387779	06-11-02	99.8	99.6	99.7
SCHLUMBERGER	J5S	C387780	06-11-02	100.1	100.0	100.6
SCHLUMBERGER	J5S	C387781	06-11-02	100.3	100.1	100.7
SCHLUMBERGER	J5S	C387782	06-11-02	100.2	100.0	100.5
SCHLUMBERGER	J5S	C387783	06-11-02	100.1	100.3	100.1
SCHLUMBERGER	J5S	C387784	06-11-02	100.2	100.2	99.9
SCHLUMBERGER	J5S	C387785	06-11-02	100.1	100.0	100.4
SCHLUMBERGER	J5S	C387786	06-11-02	100.3	100.0	100.4
SCHLUMBERGER	J5S	C387787	06-11-02	100.0	99.7	100.2
SCHLUMBERGER	J5S	C387788	06-11-02	100.0	99.9	100.2
SCHLUMBERGER	J5S	C387789	06-11-02	100.1	100.3	100.3
SCHLUMBERGER	J5S	C387790	06-11-02	100.2	100.1	100.5
SCHLUMBERGER	J5S	C387791	06-11-02	100.0	99.8	100.1
SCHLUMBERGER	J5S	C387792	06-11-02	100.2	100.3	100.4
SCHLUMBERGER	J5S	C387793	06-11-02	100.0	100.0	100.3
SCHLUMBERGER	J5S	C387794	06-11-02	99.9	100.0	100.4
SCHLUMBERGER	J5S	C387795	06-11-02	100.2	99.7	100.4
SCHLUMBERGER	J5S	C387796	06-11-02	100.0	100.1	100.2
SCHLUMBERGER	J5S	C387797	06-11-02	100.1	99.6	100.4
SCHLUMBERGER	J5S	C387798	06-11-02	100.2	99.9	100.3
SCHLUMBERGER	J5S	C387799	06-11-02	100.1	99.8	100.3
SCHLUMBERGER	J5S	C387800	06-11-02	100.2	100.2	100.6
SCHLUMBERGER	J5S	C387801	06-11-02	99.8	100.0	100.0
SCHLUMBERGER	J5S	C387802	06-11-02	100.0	100.1	99.9
SCHLUMBERGER	J5S	C387803	06-11-02	100.1	99.9	100.4
SCHLUMBERGER	J5S	C387804	06-11-02	99.9	99.9	100.0
SCHLUMBERGER	J5S	C387805	06-11-02	100.2	99.9	100.4
SCHLUMBERGER	J5S	C387806	06-11-02	100.0	99.8	100.1
SCHLUMBERGER	J5S	C387807	06-11-02	100.1	100.2	100.0
SCHLUMBERGER	J5S	C387808	06-11-02	100.3	100.1	100.4
SCHLUMBERGER	J5S	C387809	06-11-02	99.8	99.8	100.0
SCHLUMBERGER	J5S	C387810	06-11-02	100.1	99.8	100.2
SCHLUMBERGER	J5S	C387811	06-11-02	99.8	100.0	99.9
SCHLUMBERGER	J5S	C387812	06-11-02	100.1	100.0	100.5
SCHLUMBERGER	J5S	C387813	06-11-02	100.1	99.9	100.8
SCHLUMBERGER	J5S	C387814	06-11-02	100.1	99.9	100.5

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	J55	C387815	06-11-02	99.9	99.8	100.7
SCHLUMBERGER	J55	C387816	06-11-02	100.3	100.0	100.5
SCHLUMBERGER	J55	C387817	06-11-02	100.1	100.4	100.2
SCHLUMBERGER	J55	C387818	06-11-02	99.9	100.0	100.1
SCHLUMBERGER	J55	C387819	06-11-02	100.0	99.8	100.2
SCHLUMBERGER	J55	C387820	06-11-02	99.9	100.0	100.4
SCHLUMBERGER	J55	C387821	06-11-02	100.3	100.0	100.4
SCHLUMBERGER	J55	C387822	06-11-02	99.9	99.6	100.3
SCHLUMBERGER	J55	C387823	06-11-02	100.0	99.7	100.0
SCHLUMBERGER	J55	C387824	06-11-02	99.8	99.8	100.1
SCHLUMBERGER	J55	C387825	06-11-02	99.9	100.2	99.9
SCHLUMBERGER	J55	C387826	06-11-02	100.0	99.9	100.3
SCHLUMBERGER	J55	C387827	06-11-02	100.0	100.0	100.2
SCHLUMBERGER	J55	C387828	06-11-02	100.1	99.9	100.5
SCHLUMBERGER	J55	C387829	06-11-02	100.1	100.0	100.1
SCHLUMBERGER	J55	C387830	06-11-02	100.2	99.7	100.0
SCHLUMBERGER	J55	C387831	06-11-02	100.2	99.8	100.3
SCHLUMBERGER	J55	C387832	06-11-02	100.0	99.8	100.3
SCHLUMBERGER	J55	C387833	06-11-02	100.0	100.0	100.3
SCHLUMBERGER	J55	C387834	06-11-02	100.2	99.9	100.4
SCHLUMBERGER	J55	C387835	06-11-02	100.0	100.1	99.8
SCHLUMBERGER	J55	C387836	06-11-02	100.3	100.1	100.4
SCHLUMBERGER	J55	C387837	06-11-02	100.1	100.4	100.5
SCHLUMBERGER	J55	C387838	06-11-02	99.9	100.2	99.7
SCHLUMBERGER	J55	C387839	06-11-02	100.2	100.2	100.1
SCHLUMBERGER	J55	C387840	06-11-02	100.0	100.3	100.1
SCHLUMBERGER	J55	C387841	06-11-02	100.0	99.6	100.1
SCHLUMBERGER	J55	C387842	06-11-02	100.0	100.2	100.0
SCHLUMBERGER	J55	C387843	06-11-02	100.2	100.2	100.5
SCHLUMBERGER	J55	C387844	06-11-02	100.0	100.1	100.5
SCHLUMBERGER	J55	C387845	06-11-02	99.9	100.2	99.4
SCHLUMBERGER	J55	C387846	06-11-02	100.2	100.2	99.9
SCHLUMBERGER	J55	C387847	06-11-02	100.1	100.1	99.9
SCHLUMBERGER	J55	C387848	06-11-02	100.1	100.0	99.9
SCHLUMBERGER	J55	C387849	06-11-02	99.8	99.8	99.7
SCHLUMBERGER	J55	C387850	06-11-02	100.2	100.2	100.4
SCHLUMBERGER	J55	C387851	06-11-02	100.0	100.1	100.3
SCHLUMBERGER	J55	C387852	06-11-02	99.9	99.7	99.5
SCHLUMBERGER	J55	C387853	06-11-02	100.2	100.2	100.2
SCHLUMBERGER	J55	C387854	06-11-02	100.0	100.1	100.4
SCHLUMBERGER	J55	C387855	06-11-02	100.2	99.7	100.4
SCHLUMBERGER	J55	C387856	06-11-02	100.1	100.0	100.3
SCHLUMBERGER	J55	C387857	06-11-02	100.3	100.0	100.5
SCHLUMBERGER	J55	C387858	06-11-02	100.0	100.1	100.3
SCHLUMBERGER	J55	C387859	06-11-02	100.0	100.1	100.1
SCHLUMBERGER	J55	C387860	06-11-02	99.8	99.6	99.8
SCHLUMBERGER	J55	C387861	06-11-02	100.1	99.9	99.8
SCHLUMBERGER	J55	C387862	06-11-02	100.1	100.1	100.4
SCHLUMBERGER	J55	C387863	06-11-02	100.0	100.0	99.7
SCHLUMBERGER	J55	C387864	06-11-02	100.1	99.8	100.3
SCHLUMBERGER	J55	C387865	06-11-02	100.0	99.9	100.1

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

PAGE 82
 RUN DATE: 1/14/03
 RUN TIME: 13.26.53

MANUFACTURER	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	C387866	06-11-02	99.9	99.7	100.1
SCHLUMBERGER	C387867	06-11-02	100.0	99.9	100.3
SCHLUMBERGER	C387868	06-11-02	100.0	100.1	100.0
SCHLUMBERGER	C387869	06-11-02	99.9	99.9	100.0
SCHLUMBERGER	C387870	06-11-02	100.0	100.0	99.7
SCHLUMBERGER	C387871	06-11-02	100.1	100.1	100.4
SCHLUMBERGER	C387872	06-11-02	99.9	99.7	99.9
SCHLUMBERGER	C387873	06-11-02	99.8	100.2	99.6
SCHLUMBERGER	C387874	06-11-02	100.3	99.8	100.5
SCHLUMBERGER	C387875	06-11-02	100.0	99.6	100.3
SCHLUMBERGER	C387876	06-11-02	100.1	100.1	100.4
SCHLUMBERGER	C387877	06-11-02	100.0	99.7	100.2
SCHLUMBERGER	C387878	06-11-02	99.9	100.2	100.1
SCHLUMBERGER	C387879	06-11-02	100.0	99.8	100.0
SCHLUMBERGER	C387880	06-11-02	99.8	100.0	99.6
SCHLUMBERGER	C387881	06-11-02	100.1	99.9	99.9
SCHLUMBERGER	C387882	06-11-02	100.1	100.1	99.8
SCHLUMBERGER	C387883	06-11-02	100.1	99.9	99.8
SCHLUMBERGER	C387884	06-11-02	100.0	100.2	99.8
SCHLUMBERGER	C387885	06-11-02	100.2	99.6	100.1
SCHLUMBERGER	C387886	06-11-02	100.0	100.1	100.1
SCHLUMBERGER	C387887	06-11-02	100.1	99.9	100.1
SCHLUMBERGER	C387888	06-11-02	99.9	100.0	99.9
SCHLUMBERGER	C387889	06-11-02	99.9	99.8	99.9
SCHLUMBERGER	C387890	06-11-02	100.1	99.9	100.0
SCHLUMBERGER	C387891	06-11-02	100.2	100.1	100.0
SCHLUMBERGER	C387892	06-11-02	100.0	100.0	100.1
SCHLUMBERGER	C387893	06-11-02	99.9	99.9	100.4
SCHLUMBERGER	C387894	06-11-02	100.1	99.9	100.4
SCHLUMBERGER	C387895	06-11-02	100.1	100.1	100.2
SCHLUMBERGER	C387896	06-11-02	100.0	100.1	100.2
SCHLUMBERGER	C387897	06-11-02	99.9	99.8	100.0
SCHLUMBERGER	C387898	06-11-02	99.9	100.0	99.9
SCHLUMBERGER	C387899	06-11-02	99.9	99.9	100.1
SCHLUMBERGER	C387900	06-11-02	99.9	99.8	100.3
SCHLUMBERGER	C387901	06-11-02	100.1	100.1	99.8
SCHLUMBERGER	C387902	06-11-02	100.1	100.2	99.9
SCHLUMBERGER	C387903	06-11-02	100.0	100.1	99.9
SCHLUMBERGER	C387904	06-11-02	99.8	100.0	99.8
SCHLUMBERGER	C387905	06-11-02	100.0	99.9	99.6
SCHLUMBERGER	C387906	06-11-02	100.3	100.0	100.6
SCHLUMBERGER	C387907	06-11-02	100.1	99.9	99.7
SCHLUMBERGER	C387908	06-11-02	100.0	100.0	100.1
SCHLUMBERGER	C387909	06-11-02	100.1	100.3	100.4
SCHLUMBERGER	C387910	06-11-02	99.8	100.2	100.2
SCHLUMBERGER	C387911	06-11-02	100.1	100.0	100.3
SCHLUMBERGER	C387912	06-11-02	100.0	100.0	99.8
SCHLUMBERGER	C387913	06-11-02	100.1	100.1	100.1
SCHLUMBERGER	C387914	06-11-02	100.0	100.3	99.9
SCHLUMBERGER	C387915	06-11-02	100.0	100.0	100.1
SCHLUMBERGER	C387916	06-11-02	100.0	99.8	99.8

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	J55	C387917	06-11-02	100.1	100.1	100.1
SCHLUMBERGER	J55	C387918	06-11-02	99.9	99.9	99.8
SCHLUMBERGER	J55	C387919	06-11-02	100.0	100.0	100.3
SCHLUMBERGER	J55	C387920	06-11-02	99.8	99.8	100.1
SCHLUMBERGER	J55	C387921	06-11-02	100.0	100.3	100.5
SCHLUMBERGER	J55	C387922	06-11-02	100.1	99.9	100.0
SCHLUMBERGER	J55	C387923	06-11-02	100.2	100.1	100.0
SCHLUMBERGER	J55	C387924	06-11-02	99.8	100.0	100.1
SCHLUMBERGER	J55	C387925	06-11-02	100.0	100.3	100.0
SCHLUMBERGER	J55	C387926	06-11-02	99.8	99.9	100.2
SCHLUMBERGER	J55	C387927	06-11-02	100.3	100.1	100.4
SCHLUMBERGER	J55	C387928	06-11-02	99.8	100.1	100.2
SCHLUMBERGER	J55	C387929	06-11-02	99.8	100.0	100.3
SCHLUMBERGER	J55	C387930	06-11-02	99.9	100.0	100.1
SCHLUMBERGER	J55	C387931	06-11-02	100.0	99.9	100.4
SCHLUMBERGER	J55	C387932	06-11-02	100.1	100.0	100.0
SCHLUMBERGER	J55	C387933	06-11-02	100.2	99.9	100.4
SCHLUMBERGER	J55	C387934	06-11-02	99.9	100.1	100.2
SCHLUMBERGER	J55	C387935	06-11-02	99.9	99.6	100.3
SCHLUMBERGER	J55	C387936	06-11-02	100.1	99.7	100.2
SCHLUMBERGER	J55	C387937	06-11-02	99.9	100.1	100.3
SCHLUMBERGER	J55	C387938	06-11-02	100.0	100.5	100.8
SCHLUMBERGER	J55	C387939	06-11-02	100.0	99.6	100.1
SCHLUMBERGER	J55	C387940	06-11-02	100.3	99.8	99.8
SCHLUMBERGER	J55	C387941	06-11-02	100.0	99.6	100.5
SCHLUMBERGER	J55	C387942	06-11-02	100.0	100.4	99.8
SCHLUMBERGER	J55	C387943	06-11-02	100.1	100.0	100.6
SCHLUMBERGER	J55	C387944	06-11-02	100.0	99.7	100.1
SCHLUMBERGER	J55	C387945	06-11-02	100.0	99.9	99.9
SCHLUMBERGER	J55	C387946	06-11-02	100.1	100.1	99.8
SCHLUMBERGER	J55	C387947	06-11-02	99.8	99.8	100.0
SCHLUMBERGER	J55	C387948	06-11-02	99.8	99.8	100.1
SCHLUMBERGER	J55	C387949	06-11-02	100.2	99.8	100.2
SCHLUMBERGER	J55	C387950	06-11-02	100.1	100.0	100.1
SCHLUMBERGER	J55	C387951	06-11-02	100.0	99.7	100.2
SCHLUMBERGER	J55	C387952	06-11-02	100.2	99.8	100.5
SCHLUMBERGER	J55	C387953	06-11-02	100.1	100.1	100.2
SCHLUMBERGER	J55	C387954	06-11-02	100.1	100.2	100.3
SCHLUMBERGER	J55	C387955	06-11-02	100.0	99.8	100.0
SCHLUMBERGER	J55	C387956	06-11-02	99.9	100.1	99.8
SCHLUMBERGER	J55	C387957	06-11-02	99.9	100.0	100.2
SCHLUMBERGER	J55	C387958	06-11-02	100.0	100.1	100.2
SCHLUMBERGER	J55	C387959	06-11-02	100.1	99.8	100.4
SCHLUMBERGER	J55	C387960	06-11-02	100.2	99.7	100.0
SCHLUMBERGER	J55	C387961	06-11-02	100.1	100.2	100.2
SCHLUMBERGER	J55	C387962	06-11-02	100.1	100.2	100.2
SCHLUMBERGER	J55	C387963	06-11-02	100.0	99.9	100.0
SCHLUMBERGER	J55	C387964	06-11-02	100.1	100.1	100.6
SCHLUMBERGER	J55	C387965	06-11-02	100.0	99.6	99.7
SCHLUMBERGER	J55	C387966	06-11-02	100.0	99.9	99.8
SCHLUMBERGER	J55	C387967	06-11-02	99.9	99.8	100.1

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	J5S	C387968	06-11-02	100.1	100.3	100.2
SCHLUMBERGER	J5S	C387969	06-11-02	100.0	99.7	100.0
SCHLUMBERGER	J5S	C387970	06-11-02	100.1	100.0	99.6
SCHLUMBERGER	J5S	C387971	06-11-02	99.9	100.2	100.1
SCHLUMBERGER	J5S	C387972	06-11-02	99.9	99.7	100.3
SCHLUMBERGER	J5S	C387973	06-11-02	99.9	99.9	100.2
SCHLUMBERGER	J5S	C387974	06-11-02	100.0	100.5	99.9
SCHLUMBERGER	J5S	C387975	06-11-02	100.0	99.9	100.2
SCHLUMBERGER	J5S	C387976	06-11-02	100.1	100.0	100.1
SCHLUMBERGER	J5S	C387977	06-11-02	100.0	100.1	100.3
SCHLUMBERGER	J5S	C387978	06-11-02	100.1	99.9	99.6
SCHLUMBERGER	J5S	C387979	06-11-02	99.9	100.1	99.9
SCHLUMBERGER	J5S	C387980	06-11-02	100.2	100.1	100.5
SCHLUMBERGER	J5S	C387981	06-11-02	100.2	99.8	99.8
SCHLUMBERGER	J5S	C387982	06-11-02	100.2	99.9	100.1
SCHLUMBERGER	J5S	C387983	06-11-02	99.8	99.8	99.8
SCHLUMBERGER	J5S	C387984	06-11-02	100.1	100.4	100.2
SCHLUMBERGER	J5S	C387985	06-11-02	100.2	99.9	100.4
SCHLUMBERGER	J5S	C387986	06-11-02	100.1	99.8	99.8
SCHLUMBERGER	J5S	C387987	06-11-02	100.1	100.2	100.0
SCHLUMBERGER	J5S	C387988	06-11-02	99.9	99.8	99.8
SCHLUMBERGER	J5S	C387989	06-11-02	99.8	99.9	100.4
SCHLUMBERGER	J5S	C387990	06-11-02	99.8	99.8	99.5
SCHLUMBERGER	J5S	C387991	06-11-02	99.9	100.3	99.8
SCHLUMBERGER	J5S	C387992	06-11-02	99.9	100.0	99.8
SCHLUMBERGER	J5S	C387993	06-11-02	99.9	100.1	100.1
SCHLUMBERGER	J5S	C387994	06-11-02	100.1	100.0	99.5
SCHLUMBERGER	J5S	C387995	06-11-02	100.0	99.7	100.2
SCHLUMBERGER	J5S	C387996	06-11-02	100.0	100.1	100.1
SCHLUMBERGER	J5S	C387997	06-11-02	100.0	100.0	99.9
SCHLUMBERGER	J5S	C387998	06-11-02	100.2	100.1	100.7
SCHLUMBERGER	J5S	C387999	06-11-02	99.9	99.9	100.3
SCHLUMBERGER	J5S	C388000	06-11-02	99.9	99.9	100.2
SCHLUMBERGER	J5S	C388001	06-11-02	100.2	100.4	100.3
SCHLUMBERGER	J5S	C388002	06-11-02	99.9	99.8	99.7
SCHLUMBERGER	J5S	C388003	06-11-02	100.1	100.1	100.0
SCHLUMBERGER	J5S	C388004	06-11-02	100.1	100.3	100.0
SCHLUMBERGER	J5S	C388005	06-11-02	99.9	100.3	100.3
SCHLUMBERGER	J5S	C388006	06-11-02	100.2	100.4	100.4
SCHLUMBERGER	J5S	C388007	06-11-02	100.1	99.7	100.3
SCHLUMBERGER	J5S	C388008	06-11-02	100.3	100.3	100.4
SCHLUMBERGER	J5S	C388009	06-11-02	100.0	99.9	100.0
SCHLUMBERGER	J5S	C388010	06-11-02	99.9	100.0	100.4
SCHLUMBERGER	J5S	C388011	06-11-02	100.0	100.1	100.4
SCHLUMBERGER	J5S	C388012	06-11-02	99.9	99.7	99.8
SCHLUMBERGER	J5S	C388013	06-11-02	99.8	99.7	100.2
SCHLUMBERGER	J5S	C388014	06-11-02	100.0	99.8	100.3
SCHLUMBERGER	J5S	C388015	06-11-02	100.2	100.0	100.0
SCHLUMBERGER	J5S	C388016	06-11-02	100.0	100.2	99.9
SCHLUMBERGER	J5S	C388017	06-11-02	99.9	100.2	100.6
SCHLUMBERGER	J5S	C388018	06-11-02	99.8	99.9	100.3

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

PAGE 85
 RUN DATE: 1/14/03
 RUN TIME: 13.26.53

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	J5S	C388019	06-11-02	99.9	100.0	100.1
SCHLUMBERGER	J5S	C388020	06-11-02	99.8	99.8	99.7
SCHLUMBERGER	J5S	C388021	06-11-02	100.0	100.1	100.3
SCHLUMBERGER	J5S	C388022	06-11-02	100.0	100.1	100.4
SCHLUMBERGER	J5S	C388023	06-11-02	100.0	99.8	100.3
SCHLUMBERGER	J5S	C388024	06-11-02	100.1	100.2	100.1
SCHLUMBERGER	J5S	C388025	06-11-02	100.2	100.5	100.6
SCHLUMBERGER	J5S	C388026	06-11-02	100.1	100.1	99.9
SCHLUMBERGER	J5S	C388027	06-11-02	100.0	100.1	99.7
SCHLUMBERGER	J5S	C388028	06-11-02	99.9	99.9	100.4
SCHLUMBERGER	J5S	C388029	06-11-02	100.2	99.9	100.4
SCHLUMBERGER	J5S	C388030	06-11-02	99.9	100.1	100.1
SCHLUMBERGER	J5S	C388031	06-11-02	99.9	100.2	100.0
SCHLUMBERGER	J5S	C388032	06-11-02	100.2	99.9	100.0
SCHLUMBERGER	J5S	C388033	06-11-02	100.1	100.2	100.4
SCHLUMBERGER	J5S	C388034	06-11-02	100.1	100.1	99.8
SCHLUMBERGER	J5S	C388035	06-11-02	100.0	100.0	99.7
SCHLUMBERGER	J5S	C388036	06-11-02	99.9	100.1	99.7
SCHLUMBERGER	J5S	C388037	06-11-02	100.1	99.8	100.1
SCHLUMBERGER	J5S	C388038	06-11-02	100.0	100.2	100.4
SCHLUMBERGER	J5S	C388039	06-11-02	99.9	100.1	99.6
SCHLUMBERGER	J5S	C388040	06-11-02	100.1	100.0	99.7
SCHLUMBERGER	J5S	C388041	06-11-02	100.1	99.8	100.0
SCHLUMBERGER	J5S	C388042	06-11-02	100.2	99.8	100.6
SCHLUMBERGER	J5S	C388043	06-11-02	100.0	100.0	99.9
SCHLUMBERGER	J5S	C388044	06-11-02	100.0	99.8	99.7
SCHLUMBERGER	J5S	C388045	06-11-02	99.9	99.7	99.9
SCHLUMBERGER	J5S	C388046	06-11-02	100.3	100.1	100.5
SCHLUMBERGER	J5S	C388047	06-11-02	99.8	99.6	100.0
SCHLUMBERGER	J5S	C388048	06-11-02	100.1	99.9	100.0
SCHLUMBERGER	J5S	C388049	06-11-02	99.9	99.9	99.9
SCHLUMBERGER	J5S	C388050	06-11-02	100.1	100.1	100.1
SCHLUMBERGER	J5S	C388051	06-11-02	100.1	100.1	99.6
SCHLUMBERGER	J5S	C388052	06-11-02	100.1	99.7	99.8
SCHLUMBERGER	J5S	C388053	06-11-02	100.1	99.6	99.8
SCHLUMBERGER	J5S	C388054	06-11-02	100.2	99.7	99.6
SCHLUMBERGER	J5S	C388055	06-11-02	100.0	99.9	99.6
SCHLUMBERGER	J5S	C388056	06-11-02	99.9	99.9	99.4
SCHLUMBERGER	J5S	C388057	06-11-02	100.0	100.1	100.1
SCHLUMBERGER	J5S	C388058	06-11-02	100.0	99.7	99.8
SCHLUMBERGER	J5S	C388059	06-11-02	100.0	100.2	99.5
SCHLUMBERGER	J5S	C388060	06-11-02	99.9	99.7	99.8
SCHLUMBERGER	J5S	C388061	06-11-02	99.9	99.8	100.1
SCHLUMBERGER	J5S	C388062	06-11-02	100.0	100.0	99.5
SCHLUMBERGER	J5S	C388063	06-11-02	99.9	99.8	99.7
SCHLUMBERGER	J5S	C388064	06-11-02	99.9	100.1	99.9
SCHLUMBERGER	J5S	C388065	06-11-02	100.2	100.0	100.5
SCHLUMBERGER	J5S	C388066	06-11-02	100.0	100.1	99.9
SCHLUMBERGER	J5S	C388067	06-11-02	100.0	100.2	100.0
SCHLUMBERGER	J5S	C388068	06-11-02	99.8	100.2	100.0
SCHLUMBERGER	J5S	C388069	06-11-02	100.2	99.8	99.7

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	J5S	C388070	06-11-02	99.9	99.8	99.8
SCHLUMBERGER	J5S	C388071	06-11-02	100.0	99.8	99.7
SCHLUMBERGER	J5S	C388072	06-11-02	100.1	99.9	100.3
SCHLUMBERGER	J5S	C388073	06-11-02	100.1	99.7	100.3
SCHLUMBERGER	J5S	C388074	06-11-02	99.9	100.0	99.6
SCHLUMBERGER	J5S	C388075	06-11-02	100.1	100.0	100.0
SCHLUMBERGER	J5S	C388076	06-11-02	99.9	99.9	99.7
SCHLUMBERGER	J5S	C388077	06-11-02	100.1	99.8	99.9
SCHLUMBERGER	J5S	C388078	06-11-02	100.0	99.7	99.8
SCHLUMBERGER	J5S	C388079	06-11-02	100.0	99.8	99.9
SCHLUMBERGER	J5S	C388080	06-11-02	100.1	99.9	99.9
SCHLUMBERGER	J5S	C388081	06-11-02	100.0	99.9	99.7
SCHLUMBERGER	J5S	C388082	06-11-02	100.1	99.8	100.3
SCHLUMBERGER	J5S	C388083	06-11-02	100.1	100.1	100.1
SCHLUMBERGER	J5S	C388084	06-11-02	100.1	99.8	99.8
SCHLUMBERGER	J5S	C388085	06-11-02	100.1	99.8	99.8
SCHLUMBERGER	J5S	C388086	06-11-02	99.9	99.7	100.2
SCHLUMBERGER	J5S	C388087	06-11-02	100.0	99.7	99.8
SCHLUMBERGER	J5S	C388088	06-11-02	99.8	99.7	99.6
SCHLUMBERGER	J5S	C388089	06-11-02	100.2	99.8	99.9
SCHLUMBERGER	J5S	C388090	06-11-02	100.0	99.9	99.6
SCHLUMBERGER	J5S	C388091	06-11-02	100.0	99.9	100.0
SCHLUMBERGER	J5S	C388092	06-11-02	100.0	99.7	99.9
SCHLUMBERGER	J5S	C388093	06-11-02	100.0	99.8	99.9
SCHLUMBERGER	J5S	C388094	06-11-02	100.1	99.7	100.3
SCHLUMBERGER	J5S	C388095	06-11-02	100.1	99.6	99.9
SCHLUMBERGER	J5S	C388096	06-11-02	99.8	100.0	99.9
SCHLUMBERGER	J5S	C388097	06-11-02	100.0	99.9	99.8
SCHLUMBERGER	J5S	C388098	06-11-02	99.9	99.7	100.0
SCHLUMBERGER	J5S	C388099	06-11-02	100.1	99.7	100.1
SCHLUMBERGER	J5S	C388100	06-11-02	100.0	100.0	99.5
SCHLUMBERGER	J5S	C388101	06-11-02	100.1	100.0	100.3
SCHLUMBERGER	J5S	C388102	06-11-02	100.0	100.1	100.3
SCHLUMBERGER	J5S	C388103	06-11-02	99.9	100.1	99.6
SCHLUMBERGER	J5S	C388104	06-11-02	100.1	99.7	100.0
SCHLUMBERGER	J5S	C388105	06-11-02	100.1	100.0	99.7
SCHLUMBERGER	J5S	C388106	06-11-02	100.0	99.8	100.2
SCHLUMBERGER	J5S	C388107	06-11-02	100.1	100.4	100.9
SCHLUMBERGER	J5S	C388108	06-11-02	100.2	100.0	100.1
SCHLUMBERGER	J5S	C388109	06-11-02	99.9	99.8	100.4
SCHLUMBERGER	J5S	C388110	06-11-02	100.0	99.8	99.5
SCHLUMBERGER	J5S	C388111	06-11-02	100.1	100.1	99.9
SCHLUMBERGER	J5S	C388112	06-11-02	100.0	100.1	99.7
SCHLUMBERGER	J5S	C388113	06-11-02	100.0	100.0	99.8
SCHLUMBERGER	J5S	C388114	06-11-02	100.1	99.9	99.9
SCHLUMBERGER	J5S	C388115	06-11-02	99.9	99.8	99.7
SCHLUMBERGER	J5S	C388116	06-11-02	100.2	99.7	99.9
SCHLUMBERGER	J5S	C388117	06-11-02	100.2	100.0	100.1
SCHLUMBERGER	J5S	C388118	06-11-02	100.1	100.5	99.9
SCHLUMBERGER	J5S	C388119	06-11-02	100.0	99.7	100.1
SCHLUMBERGER	J5S	C388120	06-11-02	100.3	99.9	99.7

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	J55	C388121	06-11-02	100.0	100.1	99.8
SCHLUMBERGER	J55	C388122	06-11-02	100.0	99.9	99.8
SCHLUMBERGER	J55	C388123	06-11-02	100.0	100.0	100.0
SCHLUMBERGER	J55	C388124	06-11-02	100.0	100.1	99.8
SCHLUMBERGER	J55	C388125	06-11-02	100.0	99.9	99.6
SCHLUMBERGER	J55	C388126	06-11-02	100.0	99.7	100.1
SCHLUMBERGER	J55	C388127	06-11-02	99.8	99.7	99.7
SCHLUMBERGER	J55	C388128	06-11-02	100.0	100.0	100.1
SCHLUMBERGER	J55	C388129	06-11-02	100.1	99.9	100.0
SCHLUMBERGER	J55	C388130	06-11-02	100.2	99.8	99.7
SCHLUMBERGER	J55	C388131	06-11-02	100.0	99.8	100.2
SCHLUMBERGER	J55	C388132	06-11-02	100.0	99.9	99.7
SCHLUMBERGER	J55	C388133	06-11-02	100.0	99.8	99.9
SCHLUMBERGER	J55	C388134	06-11-02	99.8	99.8	99.6
SCHLUMBERGER	J55	C388135	06-11-02	100.0	99.9	99.9
SCHLUMBERGER	J55	C388136	06-11-02	100.0	100.1	99.9
SCHLUMBERGER	J55	C388137	06-11-02	100.1	99.7	100.2
SCHLUMBERGER	J55	C388138	06-11-02	100.0	100.0	100.2
SCHLUMBERGER	J55	C388139	06-11-02	100.3	99.7	99.7
SCHLUMBERGER	J55	C388140	06-11-02	99.9	99.9	100.1
SCHLUMBERGER	J55	C388141	06-11-02	100.1	99.6	100.2
SCHLUMBERGER	J55	C388142	06-11-02	100.1	99.9	100.0
SCHLUMBERGER	J55	C388143	06-11-02	100.2	99.8	100.0
SCHLUMBERGER	J55	C388144	06-11-02	100.0	100.0	99.8
SCHLUMBERGER	J55	C388145	06-11-02	99.9	100.1	100.0
SCHLUMBERGER	J55	C388146	06-11-02	100.2	100.1	100.0
SCHLUMBERGER	J55	C388147	06-11-02	100.0	99.8	100.3
SCHLUMBERGER	J55	C388148	06-11-02	100.0	99.9	99.7
SCHLUMBERGER	J55	C388149	06-11-02	100.1	99.9	99.9
SCHLUMBERGER	J55	C388150	06-11-02	100.1	100.0	99.9
SCHLUMBERGER	J55	C388151	06-11-02	99.8	99.7	99.5
SCHLUMBERGER	J55	C388152	06-11-02	99.9	99.8	99.6
SCHLUMBERGER	J55	C388153	06-11-02	99.9	99.8	100.0
SCHLUMBERGER	J55	C388154	06-11-02	100.0	100.1	99.9
SCHLUMBERGER	J55	C388155	06-11-02	100.1	99.9	99.7
SCHLUMBERGER	J55	C388156	06-11-02	100.2	100.1	99.8
SCHLUMBERGER	J55	C388157	06-11-02	100.1	100.1	100.1
SCHLUMBERGER	J55	C388158	06-11-02	99.9	99.9	99.7
SCHLUMBERGER	J55	C388159	06-11-02	100.0	99.6	99.8
SCHLUMBERGER	J55	C388160	06-11-02	100.0	99.8	100.0
SCHLUMBERGER	J55	C388161	06-11-02	99.8	99.6	99.6
SCHLUMBERGER	J55	C388162	06-11-02	99.9	99.7	100.1
SCHLUMBERGER	J55	C388163	06-11-02	100.0	100.0	100.1
SCHLUMBERGER	J55	C388164	06-11-02	100.1	100.1	100.3
SCHLUMBERGER	J55	C388165	06-11-02	100.0	99.8	99.5
SCHLUMBERGER	J55	C388166	06-11-02	100.1	99.8	100.1
SCHLUMBERGER	J55	C388167	06-11-02	100.0	100.0	100.9
SCHLUMBERGER	J55	C388168	06-11-02	100.1	100.0	100.3
SCHLUMBERGER	J55	C388169	06-11-02	100.1	99.9	100.4
SCHLUMBERGER	J55	C388170	06-11-02	100.1	99.9	100.1
SCHLUMBERGER	J55	C388171	06-11-02	100.0	99.7	99.9

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

PAGE 88
 RUN DATE: 1/14/03
 RUN TIME: 13.26.53

MANUFACTURER	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	C388172	06-11-02	100.0	99.7	100.1
SCHLUMBERGER	C388173	06-11-02	100.0	100.0	99.8
SCHLUMBERGER	C388174	06-11-02	100.0	99.8	100.0
SCHLUMBERGER	C388175	06-11-02	100.2	100.1	100.0
SCHLUMBERGER	C388176	06-11-02	99.9	99.9	99.8
SCHLUMBERGER	C388177	06-11-02	99.9	100.2	99.8
SCHLUMBERGER	C388178	06-11-02	100.0	99.8	100.2
SCHLUMBERGER	C388179	06-11-02	99.9	100.0	100.0
SCHLUMBERGER	C388180	06-11-02	100.0	100.1	100.0
SCHLUMBERGER	C388181	06-11-02	100.1	100.0	99.8
SCHLUMBERGER	C388182	06-11-02	100.1	99.7	100.3
SCHLUMBERGER	C388183	06-11-02	100.0	99.6	99.7
SCHLUMBERGER	C388184	06-11-02	100.0	99.7	100.0
SCHLUMBERGER	C388185	06-11-02	100.1	100.2	99.8
SCHLUMBERGER	C388186	06-11-02	99.8	99.6	99.9
SCHLUMBERGER	C388187	06-11-02	100.1	99.9	100.1
SCHLUMBERGER	C388188	06-11-02	100.3	99.9	100.4
SCHLUMBERGER	C388189	06-11-02	100.2	99.8	100.0
SCHLUMBERGER	C388190	06-11-02	100.0	99.9	99.7
SCHLUMBERGER	C388191	06-11-02	100.1	100.1	99.9
SCHLUMBERGER	C388192	06-11-02	100.2	100.1	100.4
SCHLUMBERGER	C388193	06-11-02	100.1	100.3	99.9
SCHLUMBERGER	C388194	06-11-02	99.9	100.3	99.8
SCHLUMBERGER	C388195	06-11-02	100.2	100.1	99.9
SCHLUMBERGER	C388196	06-11-02	100.1	99.8	100.0
SCHLUMBERGER	C388197	06-11-02	99.9	100.1	99.9
SCHLUMBERGER	C388198	06-11-02	100.1	99.9	99.4
SCHLUMBERGER	C388199	06-11-02	100.1	99.9	99.8
SCHLUMBERGER	C388200	06-11-02	100.0	99.8	100.1
SCHLUMBERGER	C388201	06-11-02	100.0	100.0	100.1
SCHLUMBERGER	C388202	06-11-02	100.3	100.2	100.1
SCHLUMBERGER	C388203	06-11-02	99.9	99.8	99.8
SCHLUMBERGER	C388204	06-11-02	99.9	100.1	99.9
SCHLUMBERGER	C388205	06-11-02	100.3	100.1	100.3
SCHLUMBERGER	C388206	06-11-02	100.0	99.8	99.9
SCHLUMBERGER	C388207	06-11-02	100.1	100.3	100.6
SCHLUMBERGER	C388208	06-11-02	100.3	99.9	99.8
SCHLUMBERGER	C388209	06-11-02	100.0	100.0	99.7
SCHLUMBERGER	C388210	06-11-02	99.9	99.7	99.6
SCHLUMBERGER	C388211	06-11-02	99.9	99.9	99.9
SCHLUMBERGER	C388212	06-11-02	100.2	99.8	100.1
SCHLUMBERGER	C388213	06-11-02	100.2	100.0	100.4
SCHLUMBERGER	C388214	06-11-02	100.1	100.4	100.1
SCHLUMBERGER	C388215	06-11-02	100.0	100.1	100.1
SCHLUMBERGER	C388216	06-11-02	99.9	99.6	99.8
SCHLUMBERGER	C388217	06-11-02	100.0	99.8	100.2
SCHLUMBERGER	C388218	06-11-02	100.1	99.9	100.0
SCHLUMBERGER	C388219	06-11-02	99.9	100.0	100.0
SCHLUMBERGER	C388220	06-11-02	99.9	99.9	99.7
SCHLUMBERGER	C388221	06-11-02	100.1	100.0	99.9
SCHLUMBERGER	C388222	06-11-02	99.8	99.8	100.0

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

MANUFACTURER	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	C388223	06-11-02	100.3	100.0	99.6
SCHLUMBERGER	C388224	06-11-02	100.0	99.8	100.0
SCHLUMBERGER	C388225	06-11-02	100.3	100.0	99.9
SCHLUMBERGER	C388226	06-11-02	100.0	100.0	100.1
SCHLUMBERGER	C388227	06-11-02	100.0	100.1	99.5
SCHLUMBERGER	C388228	06-11-02	100.0	100.1	100.1
SCHLUMBERGER	C388229	06-11-02	100.0	100.2	99.8
SCHLUMBERGER	C388230	06-11-02	100.0	100.3	99.9
SCHLUMBERGER	C388231	06-11-02	99.9	99.7	99.8
SCHLUMBERGER	C388232	06-11-02	99.9	99.9	99.7
SCHLUMBERGER	C388233	06-11-02	99.9	100.1	99.6
SCHLUMBERGER	C388234	06-11-02	100.1	100.1	100.1
SCHLUMBERGER	C388235	06-11-02	100.2	99.7	100.0
SCHLUMBERGER	C388236	06-11-02	100.1	99.7	99.8
SCHLUMBERGER	C388237	06-11-02	100.2	100.1	100.0
SCHLUMBERGER	C388238	06-11-02	100.1	100.1	99.9
SCHLUMBERGER	C388239	06-11-02	99.9	99.8	99.8
SCHLUMBERGER	C388240	06-11-02	100.1	99.8	99.5
SCHLUMBERGER	C388241	06-11-02	100.1	100.1	100.3
SCHLUMBERGER	C388242	06-11-02	100.2	100.0	99.7
SCHLUMBERGER	C388243	06-11-02	99.9	99.9	99.6
SCHLUMBERGER	C388244	06-11-02	100.2	100.1	99.6
SCHLUMBERGER	C388245	06-11-02	100.2	100.1	100.4
SCHLUMBERGER	C388246	06-11-02	100.0	99.8	100.4
SCHLUMBERGER	C388247	06-11-02	100.0	99.9	100.0
SCHLUMBERGER	C388248	06-11-02	100.0	99.6	99.8
SCHLUMBERGER	C388249	06-11-02	100.0	99.9	99.7
SCHLUMBERGER	C388250	06-11-02	100.1	100.0	100.1
SCHLUMBERGER	C388251	06-11-02	100.1	100.0	99.9
SCHLUMBERGER	C388252	06-11-02	100.2	100.0	100.3
SCHLUMBERGER	C388253	06-11-02	100.2	99.8	100.0
SCHLUMBERGER	C388254	06-11-02	100.1	99.8	99.9
SCHLUMBERGER	C388255	06-11-02	100.1	99.9	99.7
SCHLUMBERGER	C388256	06-11-02	100.2	100.1	99.9
SCHLUMBERGER	C388257	06-11-02	100.1	99.9	99.9
SCHLUMBERGER	C388258	06-11-02	99.9	100.0	99.5
SCHLUMBERGER	C388259	06-11-02	100.0	99.9	100.2
SCHLUMBERGER	C388260	06-11-02	100.3	99.9	100.0
SCHLUMBERGER	C388261	06-11-02	100.0	99.7	99.8
SCHLUMBERGER	C388262	06-11-02	100.1	99.9	100.2
SCHLUMBERGER	C388263	06-11-02	99.8	99.9	100.0
SCHLUMBERGER	C388264	06-11-02	100.1	99.9	100.1
SCHLUMBERGER	C388265	06-11-02	100.0	100.0	99.7
SCHLUMBERGER	C388266	06-11-02	100.1	100.1	99.6
SCHLUMBERGER	C388267	06-11-02	100.1	99.6	99.8
SCHLUMBERGER	C388268	06-11-02	99.9	99.8	100.2
SCHLUMBERGER	C388269	06-11-02	99.9	99.8	100.0
SCHLUMBERGER	C388270	06-11-02	100.1	100.0	100.2
SCHLUMBERGER	C388271	06-11-02	100.1	99.9	99.9
SCHLUMBERGER	C388272	06-11-02	100.2	100.1	100.1
SCHLUMBERGER	C388273	06-11-02	99.9	100.1	100.0

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	J5S	C388274	06-11-02	100.1	99.9	99.9
SCHLUMBERGER	J5S	C388275	06-11-02	100.0	99.8	100.0
SCHLUMBERGER	J5S	C388276	06-11-02	100.0	99.8	100.0
SCHLUMBERGER	J5S	C388277	06-11-02	100.3	99.8	100.0
SCHLUMBERGER	J5S	C388278	06-11-02	100.0	99.9	99.8
SCHLUMBERGER	J5S	C388279	06-11-02	100.0	99.9	99.7
SCHLUMBERGER	J5S	C388280	06-11-02	100.0	100.0	100.0
SCHLUMBERGER	J5S	C388281	06-11-02	100.0	99.9	99.7
SCHLUMBERGER	J5S	C388282	06-11-02	100.0	100.2	100.1
SCHLUMBERGER	J5S	C388283	06-11-02	100.1	99.8	100.0
SCHLUMBERGER	J5S	C388284	06-11-02	100.2	100.0	99.9
SCHLUMBERGER	J5S	C388285	06-11-02	100.0	99.9	100.1
SCHLUMBERGER	J5S	C388286	06-11-02	100.1	100.0	100.0
SCHLUMBERGER	J5S	C388287	06-11-02	100.1	100.0	100.2
SCHLUMBERGER	J5S	C388288	06-11-02	99.9	100.0	99.8
SCHLUMBERGER	J5S	C388289	06-11-02	100.1	100.1	99.9
SCHLUMBERGER	J5S	C388290	06-11-02	99.9	99.6	99.9
SCHLUMBERGER	J5S	C388291	06-11-02	100.0	99.8	99.7
SCHLUMBERGER	J5S	C388292	06-11-02	100.1	99.6	99.9
SCHLUMBERGER	J5S	C388293	06-11-02	99.9	99.6	99.8
SCHLUMBERGER	J5S	C388294	06-11-02	99.8	99.7	99.7
SCHLUMBERGER	J5S	C388295	06-11-02	100.1	100.0	100.4
SCHLUMBERGER	J5S	C388296	06-11-02	100.0	99.8	99.8
SCHLUMBERGER	J5S	C388297	06-11-02	100.0	100.1	100.0
SCHLUMBERGER	J5S	C388298	06-11-02	100.1	100.2	100.0
SCHLUMBERGER	J5S	C388299	06-11-02	100.1	100.0	99.9
SCHLUMBERGER	J5S	C388300	06-11-02	100.1	100.3	99.9
SCHLUMBERGER	J5S	C388301	06-11-02	100.2	100.1	99.8
SCHLUMBERGER	J5S	C388302	06-11-02	100.1	99.8	100.2
SCHLUMBERGER	J5S	C388303	06-11-02	100.3	100.3	100.0
SCHLUMBERGER	J5S	C388304	06-11-02	100.1	99.9	100.0
SCHLUMBERGER	J5S	C388305	06-11-02	100.1	99.8	99.8
SCHLUMBERGER	J5S	C388306	06-11-02	100.1	99.9	100.0
SCHLUMBERGER	J5S	C388307	06-11-02	100.1	99.8	100.1
SCHLUMBERGER	J5S	C388308	06-11-02	99.9	99.8	99.5
SCHLUMBERGER	J5S	C388309	06-11-02	100.2	100.1	99.7
SCHLUMBERGER	J5S	C388310	06-11-02	100.3	99.8	99.6
SCHLUMBERGER	J5S	C388311	06-11-02	100.0	99.9	99.6
SCHLUMBERGER	J5S	C388312	06-11-02	100.0	99.9	99.8
SCHLUMBERGER	J5S	C388313	06-11-02	100.0	99.9	99.8
SCHLUMBERGER	J5S	C388314	06-11-02	100.1	99.9	100.0
SCHLUMBERGER	J5S	C388315	06-11-02	100.2	100.0	100.1
SCHLUMBERGER	J5S	C388316	06-11-02	100.0	99.9	100.2
SCHLUMBERGER	J5S	C388317	06-11-02	99.9	100.1	100.2
SCHLUMBERGER	J5S	C388318	06-11-02	100.0	99.7	99.8
SCHLUMBERGER	J5S	C388319	06-11-02	100.1	99.9	99.6
SCHLUMBERGER	J5S	C388320	06-11-02	100.0	99.9	100.0
SCHLUMBERGER	J5S	C388321	06-11-02	100.0	99.8	99.8
SCHLUMBERGER	J5S	C388322	06-11-02	100.2	100.0	99.9
SCHLUMBERGER	J5S	C388323	06-11-02	100.0	99.7	99.7
SCHLUMBERGER	J5S	C388324	06-11-02	100.1	99.8	99.8

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

PAGE 91
 RUN DATE: 1/14/03
 RUN TIME: 13.26.53

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	J5S	C388325	06-11-02	100.0	99.9	99.8
SCHLUMBERGER	J5S	C388326	06-11-02	100.2	99.9	99.9
SCHLUMBERGER	J5S	C388327	06-11-02	100.2	99.8	99.6
SCHLUMBERGER	J5S	C388328	06-11-02	99.9	99.7	99.8
SCHLUMBERGER	J5S	C388329	06-11-02	100.1	99.7	100.0
SCHLUMBERGER	J5S	C388330	06-11-02	99.8	99.7	99.9
SCHLUMBERGER	J5S	C388331	06-11-02	100.2	99.9	100.1
SCHLUMBERGER	J5S	C388332	06-11-02	100.1	100.1	99.8
SCHLUMBERGER	J5S	C388333	06-11-02	100.0	99.9	99.8
SCHLUMBERGER	J5S	C388334	06-11-02	100.1	100.1	100.1
SCHLUMBERGER	J5S	C388335	06-11-02	100.1	100.4	100.1
SCHLUMBERGER	J5S	C388336	06-11-02	100.1	99.8	99.6
SCHLUMBERGER	J5S	C388337	06-11-02	99.9	99.8	99.9
SCHLUMBERGER	J5S	C388338	06-11-02	100.0	100.0	100.0
SCHLUMBERGER	J5S	C388339	06-11-02	100.0	100.0	100.2
SCHLUMBERGER	J5S	C388340	06-11-02	100.2	100.1	100.0
SCHLUMBERGER	J5S	C388341	06-11-02	100.1	99.8	100.0
SCHLUMBERGER	J5S	C388342	06-11-02	100.2	99.9	100.3
SCHLUMBERGER	J5S	C388343	06-11-02	99.9	99.9	100.1
SCHLUMBERGER	J5S	C388344	06-11-02	100.2	99.6	100.1
SCHLUMBERGER	J5S	C388345	06-11-02	100.0	99.7	99.6
SCHLUMBERGER	J5S	C388346	06-11-02	100.2	100.2	99.9
SCHLUMBERGER	J5S	C388347	06-11-02	99.9	99.6	99.8
SCHLUMBERGER	J5S	C388348	06-11-02	100.0	100.1	100.0
SCHLUMBERGER	J5S	C388349	06-11-02	100.0	99.9	99.5
SCHLUMBERGER	J5S	C388350	06-11-02	100.1	100.1	99.6
SCHLUMBERGER	J5S	C388351	06-11-02	99.9	99.8	99.7
SCHLUMBERGER	J5S	C388352	06-11-02	100.1	100.2	100.0
SCHLUMBERGER	J5S	C388353	06-11-02	100.2	100.0	100.1
SCHLUMBERGER	J5S	C388354	06-11-02	100.0	100.1	99.9
SCHLUMBERGER	J5S	C388355	06-11-02	100.2	99.7	100.1
SCHLUMBERGER	J5S	C388356	06-11-02	99.9	99.7	99.6
SCHLUMBERGER	J5S	C388357	06-11-02	100.2	100.2	99.8
SCHLUMBERGER	J5S	C388358	06-11-02	100.0	99.7	99.5
SCHLUMBERGER	J5S	C388359	06-11-02	99.8	99.9	99.5
SCHLUMBERGER	J5S	C388360	06-11-02	100.1	99.9	99.9
SCHLUMBERGER	J5S	C388361	06-11-02	100.0	100.2	99.9
SCHLUMBERGER	J5S	C388362	06-11-02	100.1	100.0	100.1
SCHLUMBERGER	J5S	C388363	06-11-02	100.0	99.9	99.8
SCHLUMBERGER	J5S	C388364	06-11-02	99.9	99.8	99.9
SCHLUMBERGER	J5S	C388365	06-11-02	100.1	99.9	99.5
SCHLUMBERGER	J5S	C388366	06-11-02	100.2	100.0	100.1
SCHLUMBERGER	J5S	C388367	06-11-02	100.1	99.7	100.0
SCHLUMBERGER	J5S	C388368	06-11-02	100.1	99.7	99.9
SCHLUMBERGER	J5S	C388369	06-11-02	100.2	100.2	100.0
SCHLUMBERGER	J5S	C388370	06-11-02	100.1	99.8	99.9
SCHLUMBERGER	J5S	C388371	06-11-02	100.1	99.8	100.2
SCHLUMBERGER	J5S	C388372	06-11-02	100.2	100.2	100.1
SCHLUMBERGER	J5S	C388373	06-11-02	100.0	99.9	99.6
SCHLUMBERGER	J5S	C388374	06-11-02	100.0	99.9	99.7
SCHLUMBERGER	J5S	C388375	06-11-02	99.8	99.7	99.5

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

PAGE 92
 RUN DATE: 1/14/03
 RUN TIME: 13.26.53

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	J55	C388376	06-11-02	100.2	99.8	100.1
SCHLUMBERGER	J55	C388377	06-11-02	100.1	99.9	100.0
SCHLUMBERGER	J55	C388378	06-11-02	100.0	100.2	99.6
SCHLUMBERGER	J55	C388379	06-11-02	100.0	99.9	99.8
SCHLUMBERGER	J55	C388380	06-11-02	100.1	100.2	99.6
SCHLUMBERGER	J55	C388381	06-11-02	100.1	99.7	99.9
SCHLUMBERGER	J55	C388382	06-11-02	100.2	100.1	99.6
SCHLUMBERGER	J55	C388383	06-11-02	100.2	99.9	99.9
SCHLUMBERGER	J55	C388384	06-11-02	100.2	100.0	99.6
SCHLUMBERGER	J55	C388385	06-11-02	100.1	99.9	99.9
SCHLUMBERGER	J55	C388386	06-11-02	100.1	100.1	99.9
SCHLUMBERGER	J55	C388387	06-11-02	100.0	99.9	99.5
SCHLUMBERGER	J55	C388388	06-11-02	99.9	100.2	99.5
SCHLUMBERGER	J55	C388389	06-11-02	100.1	100.1	99.8
SCHLUMBERGER	J55	C388390	06-11-02	99.9	100.0	100.0
SCHLUMBERGER	J55	C388391	06-11-02	100.0	99.6	99.8
SCHLUMBERGER	J55	C388392	06-11-02	100.2	100.1	99.7
SCHLUMBERGER	J55	C388393	06-11-02	100.0	100.1	99.7
SCHLUMBERGER	J55	C388394	06-11-02	100.1	99.9	100.0
SCHLUMBERGER	J55	C388395	06-11-02	100.0	100.0	99.6
SCHLUMBERGER	J55	C388396	06-11-02	100.1	99.8	100.0
SCHLUMBERGER	J55	C388397	06-11-02	99.9	99.9	99.6
SCHLUMBERGER	J55	C388398	06-11-02	100.2	100.1	100.0
SCHLUMBERGER	J55	C388399	06-11-02	100.1	99.7	99.4
SCHLUMBERGER	J55	C388400	06-11-02	99.9	99.6	99.5
SCHLUMBERGER	J55	C388401	06-11-02	100.2	99.8	100.0
SCHLUMBERGER	J55	C388402	06-11-02	99.9	100.0	99.6
SCHLUMBERGER	J55	C388403	06-11-02	100.0	99.8	99.8
SCHLUMBERGER	J55	C388404	06-11-02	99.9	99.7	99.5
SCHLUMBERGER	J55	C388405	06-11-02	100.2	100.0	99.7
SCHLUMBERGER	J55	C388406	06-11-02	100.2	99.9	99.6
SCHLUMBERGER	J55	C388407	06-11-02	99.9	99.9	99.8
SCHLUMBERGER	J55	C388408	06-11-02	100.0	99.8	99.8
SCHLUMBERGER	J55	C388409	06-11-02	100.0	99.8	100.4
SCHLUMBERGER	J55	C388410	06-11-02	100.0	99.8	100.5
SCHLUMBERGER	J55	C388411	06-11-02	100.3	99.9	100.2
SCHLUMBERGER	J55	C388412	06-11-02	100.1	99.9	99.9
SCHLUMBERGER	J55	C388413	06-11-02	100.3	100.1	99.9
SCHLUMBERGER	J55	C388414	06-11-02	100.1	100.1	99.8
SCHLUMBERGER	J55	C388415	06-11-02	100.0	99.8	99.6
SCHLUMBERGER	J55	C388416	06-11-02	99.9	99.8	99.5
SCHLUMBERGER	J55	C388417	06-11-02	100.1	99.9	99.8
SCHLUMBERGER	J55	C388418	06-11-02	100.0	99.9	99.8
SCHLUMBERGER	J55	C388419	06-11-02	100.0	100.1	100.0
SCHLUMBERGER	J55	C388420	06-11-02	100.0	99.8	99.4
SCHLUMBERGER	J55	C388421	06-11-02	100.1	100.1	100.0
SCHLUMBERGER	J55	C388422	06-11-02	100.0	99.9	99.8
SCHLUMBERGER	J55	C388423	06-11-02	100.0	99.7	99.8
SCHLUMBERGER	J55	C388424	06-11-02	100.1	100.0	99.6
SCHLUMBERGER	J55	C388425	06-11-02	100.0	99.8	99.9
SCHLUMBERGER	J55	C388426	06-11-02	100.1	99.7	100.1

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

PAGE 93
 RUN DATE: 1/14/03
 RUN TIME: 13.26.53

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	J55	C388427	06-11-02	100.0	100.0	100.4
SCHLUMBERGER	J55	C388428	06-11-02	100.0	100.0	99.9
SCHLUMBERGER	J55	C388429	06-11-02	100.0	100.0	99.8
SCHLUMBERGER	J55	C388430	06-11-02	100.2	100.0	99.8
SCHLUMBERGER	J55	C388431	06-11-02	100.3	100.0	100.2
SCHLUMBERGER	J55	C388432	06-11-02	100.1	99.9	99.6
SCHLUMBERGER	J55	C388433	06-11-02	100.0	99.9	99.9
SCHLUMBERGER	J55	C388434	06-11-02	100.1	99.9	99.9
SCHLUMBERGER	J55	C388435	06-11-02	100.1	99.9	99.6
SCHLUMBERGER	J55	C388436	06-11-02	100.1	100.0	100.1
SCHLUMBERGER	J55	C388437	06-11-02	100.0	100.2	100.1
SCHLUMBERGER	J55	C388438	06-11-02	100.1	99.8	99.8
SCHLUMBERGER	J55	C388439	06-11-02	100.2	100.0	100.1
SCHLUMBERGER	J55	C388440	06-11-02	100.0	99.9	100.0
SCHLUMBERGER	J55	C388441	06-11-02	100.0	99.8	99.6
SCHLUMBERGER	J55	C388442	06-11-02	100.1	100.4	100.0
SCHLUMBERGER	J55	C388443	06-11-02	100.1	100.0	100.2
SCHLUMBERGER	J55	C388444	06-11-02	100.1	99.9	99.7
SCHLUMBERGER	J55	C388445	06-11-02	100.0	99.9	99.7
SCHLUMBERGER	J55	C388446	06-11-02	100.0	100.0	99.5
SCHLUMBERGER	J55	C388447	06-11-02	100.0	100.0	100.0
SCHLUMBERGER	J55	C388448	06-11-02	100.0	99.8	100.0
SCHLUMBERGER	J55	C388449	06-11-02	100.3	99.9	99.9
SCHLUMBERGER	J55	C388450	06-11-02	100.2	99.9	99.8
SCHLUMBERGER	J55	C388451	06-11-02	100.0	100.1	99.5
SCHLUMBERGER	J55	C388452	06-11-02	100.1	100.0	100.3
SCHLUMBERGER	J55	C388453	06-11-02	100.1	100.2	100.1
SCHLUMBERGER	J55	C388454	06-11-02	100.1	100.1	99.9
SCHLUMBERGER	J55	C388455	06-11-02	100.2	100.0	100.1
SCHLUMBERGER	J55	C388456	06-11-02	99.9	99.8	99.9
SCHLUMBERGER	J55	C388457	06-11-02	100.1	100.1	100.1
SCHLUMBERGER	J55	C388458	06-11-02	100.0	100.0	100.1
SCHLUMBERGER	J55	C388459	06-11-02	100.0	99.8	100.0
SCHLUMBERGER	J55	C388460	06-11-02	100.1	100.2	99.7
SCHLUMBERGER	J55	C388461	06-11-02	100.1	100.1	99.5
SCHLUMBERGER	J55	C388462	06-11-02	100.1	100.0	99.5
SCHLUMBERGER	J55	C388463	06-11-02	100.2	100.1	99.8
SCHLUMBERGER	J55	C388464	06-11-02	100.1	100.3	99.8
SCHLUMBERGER	J55	C388465	06-11-02	100.3	99.9	99.8
SCHLUMBERGER	J55	C388466	06-11-02	100.2	100.1	99.7
SCHLUMBERGER	J55	C388467	06-11-02	100.0	99.9	99.8
SCHLUMBERGER	J55	C388468	06-11-02	100.3	100.2	99.9
SCHLUMBERGER	J55	C388469	06-11-02	100.3	100.0	100.3
SCHLUMBERGER	J55	C388470	06-11-02	100.1	100.1	99.9
SCHLUMBERGER	J55	C388471	06-11-02	100.1	100.1	100.2
SCHLUMBERGER	J55	C388472	06-11-02	100.0	99.8	99.8
SCHLUMBERGER	J55	C388473	06-11-02	100.2	100.2	100.1
SCHLUMBERGER	J55	C388474	06-11-02	100.2	100.2	100.0
SCHLUMBERGER	J55	C388475	06-11-02	100.0	99.8	100.0
SCHLUMBERGER	J55	C388476	06-11-02	100.2	100.2	99.7
SCHLUMBERGER	J55	C388477	06-11-02	100.0	100.2	99.7

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

PAGE 94
 RUN DATE: 1/14/03
 RUN TIME: 13.26.53

MANUFACTURER	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	C388478	06-11-02	99.8	99.6	99.4
SCHLUMBERGER	C388479	06-11-02	100.2	100.1	100.0
SCHLUMBERGER	C388480	06-11-02	100.0	100.0	99.9
SCHLUMBERGER	C388481	06-11-02	99.9	99.9	100.3
SCHLUMBERGER	C388482	06-11-02	100.3	100.1	99.9
SCHLUMBERGER	C388483	06-11-02	100.0	100.0	100.1
SCHLUMBERGER	C388484	06-11-02	100.2	99.9	100.0
SCHLUMBERGER	C388485	06-11-02	100.0	100.1	100.0
SCHLUMBERGER	C388486	06-11-02	100.2	100.3	100.3
SCHLUMBERGER	C388487	06-11-02	100.2	100.3	100.3
SCHLUMBERGER	C388488	06-11-02	99.9	99.7	99.7
SCHLUMBERGER	C388489	06-11-02	100.0	99.8	99.9
SCHLUMBERGER	C388490	06-11-02	99.9	99.8	99.8
SCHLUMBERGER	C388491	06-11-02	100.2	100.1	100.0
SCHLUMBERGER	C388492	06-11-02	100.3	100.0	99.7
SCHLUMBERGER	C388493	06-11-02	99.9	99.9	100.0
SCHLUMBERGER	C388494	06-11-02	100.0	100.1	100.3
SCHLUMBERGER	C388495	06-11-02	100.2	99.8	99.6
SCHLUMBERGER	C388496	06-11-02	99.9	100.0	99.4
SCHLUMBERGER	C388497	06-11-02	100.0	99.8	99.4
SCHLUMBERGER	C388498	06-11-02	100.2	100.2	100.3
SCHLUMBERGER	C388499	06-11-02	100.1	99.9	99.7
SCHLUMBERGER	C388500	06-11-02	100.0	99.9	99.7
SCHLUMBERGER	C388501	06-11-02	100.2	99.7	99.8
SCHLUMBERGER	C388502	06-11-02	100.1	100.0	100.1
SCHLUMBERGER	C388503	06-11-02	100.1	99.9	99.7
SCHLUMBERGER	C388504	06-11-02	100.1	100.2	99.8
SCHLUMBERGER	C388505	06-11-02	100.0	99.9	99.9
SCHLUMBERGER	C388506	06-11-02	100.3	100.2	99.9
SCHLUMBERGER	C388507	06-11-02	99.8	99.9	99.6
SCHLUMBERGER	C388508	06-11-02	100.2	100.1	100.0
SCHLUMBERGER	C388509	06-11-02	100.0	99.9	99.9
SCHLUMBERGER	C388510	06-11-02	100.1	99.9	100.1
SCHLUMBERGER	C388511	06-11-02	100.0	99.9	100.0
SCHLUMBERGER	C388512	06-11-02	100.1	100.0	100.0
SCHLUMBERGER	C388513	06-11-02	100.1	99.8	99.8
SCHLUMBERGER	C388514	06-11-02	100.3	100.0	99.9
SCHLUMBERGER	C388515	06-11-02	100.0	100.0	99.6
SCHLUMBERGER	C388516	06-11-02	100.0	99.9	100.0
SCHLUMBERGER	C388517	06-11-02	100.0	100.0	100.0
SCHLUMBERGER	C388518	06-11-02	100.2	100.1	99.9
SCHLUMBERGER	C388519	06-11-02	100.0	100.1	99.9
SCHLUMBERGER	C388520	06-11-02	99.9	100.2	99.7
SCHLUMBERGER	C388521	06-11-02	100.0	99.9	99.7
SCHLUMBERGER	C388522	06-11-02	100.1	99.9	99.8
SCHLUMBERGER	C388523	06-11-02	100.2	99.7	100.1
SCHLUMBERGER	C388524	06-11-02	100.1	99.9	100.0
SCHLUMBERGER	C388525	06-11-02	99.8	99.7	99.9
SCHLUMBERGER	C388526	06-11-02	100.2	100.1	100.0
SCHLUMBERGER	C388527	06-11-02	100.3	99.9	100.1
SCHLUMBERGER	C388528	06-11-02	100.1	99.8	100.0

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

PAGE 95
 RUN DATE: 1/14/03
 RUN TIME: 13.26.53

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	J5S	C388529	06-11-02	100.2	100.2	100.1
SCHLUMBERGER	J5S	C388530	06-11-02	100.0	100.0	100.1
SCHLUMBERGER	J5S	C388531	06-11-02	100.0	99.6	99.8
SCHLUMBERGER	J5S	C388532	06-11-02	100.1	99.7	100.1
SCHLUMBERGER	J5S	C388533	06-11-02	100.2	100.1	99.8
SCHLUMBERGER	J5S	C388534	06-11-02	100.2	99.8	100.4
SCHLUMBERGER	J5S	C388535	06-11-02	100.1	100.0	100.2
SCHLUMBERGER	J5S	C388536	06-11-02	99.9	100.0	100.1
SCHLUMBERGER	J5S	C388537	06-11-02	100.2	99.7	99.8
SCHLUMBERGER	J5S	C388538	06-11-02	100.0	99.6	99.5
SCHLUMBERGER	J5S	C388539	06-11-02	100.2	99.8	100.1
SCHLUMBERGER	J5S	C388540	06-11-02	99.9	100.1	99.7
SCHLUMBERGER	J5S	C388541	06-11-02	100.0	99.9	100.2
SCHLUMBERGER	J5S	C388542	06-11-02	100.0	99.9	100.0
SCHLUMBERGER	J5S	C388543	06-11-02	99.8	99.9	99.8
SCHLUMBERGER	J5S	C388544	06-11-02	99.9	100.0	100.1
SCHLUMBERGER	J5S	C388545	06-11-02	100.1	100.3	100.0
SCHLUMBERGER	J5S	C388546	06-11-02	100.1	99.8	100.0
SCHLUMBERGER	J5S	C388547	06-11-02	100.1	99.8	99.8
SCHLUMBERGER	J5S	C388548	06-11-02	100.1	99.8	100.2
SCHLUMBERGER	J5S	C388549	06-11-02	100.2	100.0	100.0
SCHLUMBERGER	J5S	C388550	06-11-02	100.1	100.0	99.8
SCHLUMBERGER	J5S	C388551	06-11-02	100.1	99.7	99.7
SCHLUMBERGER	J5S	C388552	06-11-02	100.1	100.0	99.9
SCHLUMBERGER	J5S	C388553	06-11-02	100.0	100.0	100.2
SCHLUMBERGER	J5S	C388554	06-11-02	100.2	99.8	100.0
SCHLUMBERGER	J5S	C388555	06-11-02	100.0	100.3	100.1
SCHLUMBERGER	J5S	C388556	06-11-02	100.0	99.9	99.9
SCHLUMBERGER	J5S	C388557	06-11-02	99.9	99.8	99.8
SCHLUMBERGER	J5S	C388558	06-11-02	99.9	99.7	100.0
SCHLUMBERGER	J5S	C388559	06-11-02	100.0	99.8	99.8
SCHLUMBERGER	J5S	C388560	06-11-02	100.1	99.9	100.1
SCHLUMBERGER	J5S	C388561	06-11-02	100.0	100.0	100.0
SCHLUMBERGER	J5S	C388562	06-11-02	100.1	100.2	100.2
SCHLUMBERGER	J5S	C388563	06-11-02	100.0	99.7	100.0
SCHLUMBERGER	J5S	C388564	06-11-02	100.2	99.7	99.9
SCHLUMBERGER	J5S	C388565	06-11-02	100.2	100.1	99.9
SCHLUMBERGER	J5S	C388566	06-11-02	100.0	100.0	99.6
SCHLUMBERGER	J5S	C388567	06-11-02	100.0	99.7	99.9
SCHLUMBERGER	J5S	C388568	06-11-02	100.1	100.2	100.2
SCHLUMBERGER	J5S	C388569	06-11-02	100.2	100.0	100.2
SCHLUMBERGER	J5S	C388570	06-11-02	100.3	99.8	100.3
SCHLUMBERGER	J5S	C388571	06-11-02	99.9	100.5	99.9
SCHLUMBERGER	J5S	C388572	06-11-02	100.2	99.9	99.8
SCHLUMBERGER	J5S	C388573	06-11-02	100.3	100.2	99.9
SCHLUMBERGER	J5S	C388574	06-11-02	100.2	100.1	100.0
SCHLUMBERGER	J5S	C388575	06-11-02	99.9	99.6	99.9
SCHLUMBERGER	J5S	C388576	06-11-02	100.2	99.8	100.0
SCHLUMBERGER	J5S	C388577	06-11-02	100.2	100.3	100.2
SCHLUMBERGER	J5S	C388578	06-11-02	100.1	100.4	100.1
SCHLUMBERGER	J5S	C388579	06-11-02	100.2	100.1	100.1

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

PAGE 96
 RUN DATE: 1/14/03
 RUN TIME: 13.26.53

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	J5S	C388580	06-11-02	100.0	100.0	100.0
SCHLUMBERGER	J5S	C388581	06-11-02	100.1	99.8	99.5
SCHLUMBERGER	J5S	C388582	06-11-02	100.3	99.8	99.8
SCHLUMBERGER	J5S	C388583	06-11-02	100.1	99.8	100.3
SCHLUMBERGER	J5S	C388584	06-11-02	100.2	100.0	99.8
SCHLUMBERGER	J5S	C388585	06-11-02	100.2	100.0	99.9
SCHLUMBERGER	J5S	C388586	06-11-02	100.2	99.7	99.9
SCHLUMBERGER	J5S	C388587	06-11-02	100.0	99.7	99.8
SCHLUMBERGER	J5S	C388588	06-11-02	99.9	100.0	99.9
SCHLUMBERGER	J5S	C388589	06-11-02	100.2	100.1	99.7
SCHLUMBERGER	J5S	C388590	06-11-02	100.1	99.8	99.9
SCHLUMBERGER	J5S	C388591	06-11-02	100.2	100.0	99.7
SCHLUMBERGER	J5S	C388592	06-11-02	99.9	100.1	99.7
SCHLUMBERGER	J5S	C388593	06-11-02	99.9	99.9	100.1
SCHLUMBERGER	J5S	C388594	06-11-02	99.9	100.2	99.9
SCHLUMBERGER	J5S	C388595	06-11-02	100.0	100.1	99.8
SCHLUMBERGER	J5S	C388596	06-11-02	100.1	100.0	99.9
SCHLUMBERGER	J5S	C388597	06-11-02	100.3	100.1	99.9
SCHLUMBERGER	J5S	C388598	06-11-02	100.1	99.9	99.9
SCHLUMBERGER	J5S	C388599	06-11-02	100.0	100.0	100.0
SCHLUMBERGER	J5S	C388600	06-11-02	100.0	100.0	99.7
SCHLUMBERGER	J5S	C388601	06-11-02	100.1	99.9	99.7
SCHLUMBERGER	J5S	C388602	06-11-02	100.1	99.8	99.8
SCHLUMBERGER	J5S	C388603	06-11-02	100.2	100.0	99.6
SCHLUMBERGER	J5S	C388604	06-11-02	100.0	99.9	100.1
SCHLUMBERGER	J5S	C388605	06-11-02	100.1	100.0	100.3
SCHLUMBERGER	J5S	C388606	06-11-02	100.2	100.0	100.0
SCHLUMBERGER	J5S	C388607	06-11-02	100.1	99.7	99.7
SCHLUMBERGER	J5S	C388608	06-11-02	100.1	100.0	100.0
SCHLUMBERGER	J5S	C388609	06-11-02	99.9	100.2	99.5
SCHLUMBERGER	J5S	C388610	06-11-02	100.3	100.0	99.6
SCHLUMBERGER	J5S	C388611	06-11-02	99.9	99.9	99.9
SCHLUMBERGER	J5S	C388612	06-11-02	100.0	99.7	99.8
SCHLUMBERGER	J5S	C388613	06-11-02	100.2	100.1	99.8
SCHLUMBERGER	J5S	C388614	06-11-02	100.2	99.9	100.2
SCHLUMBERGER	J5S	C388615	06-11-02	100.1	100.3	100.2
SCHLUMBERGER	J5S	C388616	06-11-02	100.2	100.1	99.8
SCHLUMBERGER	J5S	C388617	06-11-02	100.1	100.0	99.8
SCHLUMBERGER	J5S	C388618	06-11-02	100.2	100.2	100.3
SCHLUMBERGER	J5S	C388619	06-11-02	100.1	99.7	99.5
SCHLUMBERGER	J5S	C388620	06-11-02	100.2	99.9	100.3
SCHLUMBERGER	J5S	C388621	06-11-02	100.2	99.8	99.9
SCHLUMBERGER	J5S	C388622	06-11-02	99.9	99.7	99.7
SCHLUMBERGER	J5S	C388623	06-11-02	100.1	100.1	99.9
SCHLUMBERGER	J5S	C388624	06-11-02	100.1	99.7	100.3
SCHLUMBERGER	J5S	C388625	06-11-02	99.9	100.0	99.9
SCHLUMBERGER	J5S	C388626	06-11-02	100.0	100.0	100.0
SCHLUMBERGER	J5S	C388627	06-11-02	100.2	99.9	100.2
SCHLUMBERGER	J5S	C388628	06-11-02	100.1	99.9	99.9
SCHLUMBERGER	J5S	C388629	06-11-02	100.2	99.8	100.0
SCHLUMBERGER	J5S	C388630	06-11-02	99.9	99.7	99.8

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	J55	C388631	06-11-02	100.2	100.2	99.9
SCHLUMBERGER	J55	C388632	06-11-02	99.9	99.9	99.5
SCHLUMBERGER	J55	C388633	06-11-02	100.1	99.9	99.7
SCHLUMBERGER	J55	C388634	06-11-02	100.1	99.9	100.1
SCHLUMBERGER	J55	C388635	06-11-02	100.2	100.0	100.2
SCHLUMBERGER	J55	C388636	06-11-02	99.8	99.8	99.7
SCHLUMBERGER	J55	C388637	06-11-02	100.1	100.2	99.6
SCHLUMBERGER	J55	C388638	06-11-02	100.2	99.7	99.8
SCHLUMBERGER	J55	C388639	06-11-02	100.0	99.6	99.8
SCHLUMBERGER	J55	C388640	06-11-02	100.1	99.9	99.9
SCHLUMBERGER	J55	C388641	06-11-02	99.9	99.8	99.6
SCHLUMBERGER	J55	C388642	06-11-02	100.2	99.7	99.9
SCHLUMBERGER	J55	C388643	06-11-02	100.0	100.4	100.0
SCHLUMBERGER	J55	C388644	06-11-02	100.0	99.6	99.7
SCHLUMBERGER	J55	C388645	06-11-02	100.1	99.8	100.5
SCHLUMBERGER	J55	C388646	06-11-02	99.9	99.7	100.0
SCHLUMBERGER	J55	C388647	06-11-02	100.3	100.0	100.2
SCHLUMBERGER	J55	C388648	06-11-02	100.1	100.0	100.1
SCHLUMBERGER	J55	C388649	06-11-02	100.1	100.1	99.6
SCHLUMBERGER	J55	C388650	06-11-02	100.1	100.0	100.0
SCHLUMBERGER	J55	C388651	06-11-02	100.1	100.0	99.9
SCHLUMBERGER	J55	C388652	06-11-02	99.9	99.8	99.8
SCHLUMBERGER	J55	C388653	06-11-02	100.2	100.2	100.2
SCHLUMBERGER	J55	C388654	06-11-02	100.1	100.2	99.9
SCHLUMBERGER	J55	C388655	06-11-02	100.0	99.8	100.0
SCHLUMBERGER	J55	C388656	06-11-02	100.2	99.9	99.9
SCHLUMBERGER	J55	C388657	06-11-02	100.1	100.1	100.0
SCHLUMBERGER	J55	C388658	06-11-02	99.8	99.7	99.5
SCHLUMBERGER	J55	C388659	06-11-02	100.0	99.7	99.7
SCHLUMBERGER	J55	C388660	06-11-02	99.8	100.0	99.6
SCHLUMBERGER	J55	C388661	06-11-02	100.0	99.8	100.0
SCHLUMBERGER	J55	C388662	06-11-02	100.0	100.0	100.0
SCHLUMBERGER	J55	C388663	06-11-02	100.2	100.3	100.0
SCHLUMBERGER	J55	C388664	06-11-02	100.0	100.0	100.0
SCHLUMBERGER	J55	C388665	06-11-02	100.1	100.2	99.9
SCHLUMBERGER	J55	C388666	06-11-02	100.1	99.6	100.0
SCHLUMBERGER	J55	C388667	06-11-02	100.1	100.0	100.0
SCHLUMBERGER	J55	C388668	06-11-02	100.1	99.9	100.0
SCHLUMBERGER	J55	C388669	06-11-02	100.1	99.9	99.4
SCHLUMBERGER	J55	C388670	06-11-02	100.0	99.9	99.5
SCHLUMBERGER	J55	C388671	06-11-02	100.1	99.9	99.7
SCHLUMBERGER	J55	C388672	06-11-02	100.0	100.1	100.3
SCHLUMBERGER	J55	C388673	06-11-02	100.2	100.1	100.1
SCHLUMBERGER	J55	C388674	06-11-02	99.9	100.1	99.9
SCHLUMBERGER	J55	C388675	06-11-02	100.0	99.8	99.8
SCHLUMBERGER	J55	C388676	06-11-02	100.1	99.9	100.0
SCHLUMBERGER	J55	C388677	06-11-02	99.9	100.3	99.8
SCHLUMBERGER	J55	C388678	06-11-02	100.2	99.7	99.9
SCHLUMBERGER	J55	C388679	06-11-02	100.1	99.7	99.8
SCHLUMBERGER	J55	C388680	06-11-02	100.2	100.0	100.0
SCHLUMBERGER	J55	C388681	06-11-02	100.1	99.7	99.8

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

PAGE 98
 RUN DATE: 1/14/03
 RUN TIME: 13.26.53

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	J5S	C388682	06-11-02	100.1	100.0	99.9
SCHLUMBERGER	J5S	C388683	06-11-02	100.2	99.9	100.3
SCHLUMBERGER	J5S	C388684	06-11-02	100.0	99.9	100.0
SCHLUMBERGER	J5S	C388685	06-11-02	99.9	100.2	99.9
SCHLUMBERGER	J5S	C388686	06-11-02	100.0	99.6	99.9
SCHLUMBERGER	J5S	C388687	06-11-02	99.9	99.6	99.6
SCHLUMBERGER	J5S	C388688	06-18-02	100.1	100.0	99.9
SCHLUMBERGER	J5S	C388689	06-18-02	100.3	99.9	100.1
SCHLUMBERGER	J5S	C388690	06-18-02	100.0	99.7	100.3
SCHLUMBERGER	J5S	C388691	06-18-02	99.9	100.4	100.0
SCHLUMBERGER	J5S	C388692	06-18-02	100.1	100.2	100.0
SCHLUMBERGER	J5S	C388693	06-18-02	100.2	99.8	100.6
SCHLUMBERGER	J5S	C388694	06-18-02	100.1	100.0	100.1
SCHLUMBERGER	J5S	C388695	06-18-02	100.1	99.6	100.1
SCHLUMBERGER	J5S	C388696	06-18-02	100.1	100.3	99.8
SCHLUMBERGER	J5S	C388697	06-18-02	99.9	100.0	99.7
SCHLUMBERGER	J5S	C388698	06-18-02	99.9	100.1	100.3
SCHLUMBERGER	J5S	C388699	06-18-02	99.9	100.1	99.7
SCHLUMBERGER	J5S	C388700	06-18-02	99.9	100.1	99.9
SCHLUMBERGER	J5S	C388701	06-18-02	99.9	99.9	99.6
SCHLUMBERGER	J5S	C388702	06-18-02	100.0	100.0	100.2
SCHLUMBERGER	J5S	C388703	06-18-02	100.3	99.9	100.1
SCHLUMBERGER	J5S	C388704	06-18-02	99.9	100.2	99.9
SCHLUMBERGER	J5S	C388705	06-18-02	100.1	100.2	99.5
SCHLUMBERGER	J5S	C388706	06-18-02	100.1	100.3	100.4
SCHLUMBERGER	J5S	C388707	06-18-02	100.1	99.6	100.0
SCHLUMBERGER	J5S	C388708	06-18-02	100.1	100.0	99.9
SCHLUMBERGER	J5S	C388709	06-18-02	100.1	99.7	100.3
SCHLUMBERGER	J5S	C388710	06-18-02	100.0	99.8	99.7
SCHLUMBERGER	J5S	C388711	06-18-02	100.0	99.9	100.1
SCHLUMBERGER	J5S	C388712	06-18-02	100.0	99.9	100.0
SCHLUMBERGER	J5S	C388713	06-18-02	100.0	99.9	100.0
SCHLUMBERGER	J5S	C388714	06-18-02	100.2	100.1	100.0
SCHLUMBERGER	J5S	C388715	06-18-02	100.0	100.4	99.9
SCHLUMBERGER	J5S	C388716	06-18-02	100.3	99.7	99.6
SCHLUMBERGER	J5S	C388717	06-18-02	100.1	99.7	100.0
SCHLUMBERGER	J5S	C388718	06-18-02	99.9	100.2	99.7
SCHLUMBERGER	J5S	C388719	06-18-02	100.0	100.2	100.3
SCHLUMBERGER	J5S	C388720	06-18-02	99.9	99.8	100.0
SCHLUMBERGER	J5S	C388721	06-18-02	100.2	100.4	100.2
SCHLUMBERGER	J5S	C388722	06-18-02	100.0	100.3	99.7
SCHLUMBERGER	J5S	C388723	06-18-02	100.0	99.8	99.7
SCHLUMBERGER	J5S	C388724	06-18-02	100.2	100.2	99.9
SCHLUMBERGER	J5S	C388725	06-18-02	99.8	100.0	99.8
SCHLUMBERGER	J5S	C388726	06-18-02	99.9	99.7	99.8
SCHLUMBERGER	J5S	C388727	06-18-02	100.2	100.3	99.9
SCHLUMBERGER	J5S	C388728	06-18-02	99.9	100.2	100.4
SCHLUMBERGER	J5S	C388729	06-18-02	99.9	99.7	99.7
SCHLUMBERGER	J5S	C388730	06-18-02	100.0	99.8	100.1
SCHLUMBERGER	J5S	C388731	06-18-02	100.2	99.8	100.3
SCHLUMBERGER	J5S	C388732	06-18-02	100.1	99.8	99.8

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	J5S	C388733	06-18-02	99.8	99.6	99.7
SCHLUMBERGER	J5S	C388734	06-18-02	99.9	99.9	99.7
SCHLUMBERGER	J5S	C388735	06-18-02	100.0	99.8	99.7
SCHLUMBERGER	J5S	C388736	06-18-02	99.9	100.0	99.8
SCHLUMBERGER	J5S	C388737	06-18-02	100.1	100.0	100.7
SCHLUMBERGER	J5S	C388738	06-18-02	100.0	100.1	99.9
SCHLUMBERGER	J5S	C388739	06-18-02	100.1	100.4	100.1
SCHLUMBERGER	J5S	C388740	06-18-02	100.0	99.8	99.9
SCHLUMBERGER	J5S	C388741	06-18-02	99.8	99.6	100.1
SCHLUMBERGER	J5S	C388742	06-18-02	100.1	100.2	100.1
SCHLUMBERGER	J5S	C388743	06-18-02	100.1	100.5	100.2
SCHLUMBERGER	J5S	C388744	06-18-02	100.2	100.3	100.2
SCHLUMBERGER	J5S	C388745	06-18-02	100.3	100.0	100.1
SCHLUMBERGER	J5S	C388746	06-18-02	100.1	100.1	100.0
SCHLUMBERGER	J5S	C388747	06-18-02	99.9	100.2	99.9
SCHLUMBERGER	J5S	C388748	06-18-02	99.9	100.5	99.9
SCHLUMBERGER	J5S	C388749	06-18-02	100.1	99.8	100.1
SCHLUMBERGER	J5S	C388750	06-18-02	100.1	99.9	100.2
SCHLUMBERGER	J5S	C388751	06-18-02	100.1	100.3	100.2
SCHLUMBERGER	J5S	C388752	06-18-02	99.9	99.8	100.2
SCHLUMBERGER	J5S	C388753	06-18-02	100.1	99.8	100.3
SCHLUMBERGER	J5S	C388754	06-18-02	99.9	100.1	100.3
SCHLUMBERGER	J5S	C388755	06-18-02	100.1	99.6	99.9
SCHLUMBERGER	J5S	C388756	06-18-02	100.1	100.0	100.2
SCHLUMBERGER	J5S	C388757	06-18-02	100.1	100.0	100.1
SCHLUMBERGER	J5S	C388758	05-18-02	99.8	100.0	99.7
SCHLUMBERGER	J5S	C388759	06-18-02	100.2	100.0	100.1
SCHLUMBERGER	J5S	C388760	06-18-02	100.0	99.8	100.3
SCHLUMBERGER	J5S	C388761	05-18-02	100.1	100.2	100.3
SCHLUMBERGER	J5S	C388762	06-18-02	100.1	100.1	100.3
SCHLUMBERGER	J5S	C388763	06-18-02	100.0	100.2	100.6
SCHLUMBERGER	J5S	C388764	06-18-02	100.1	100.0	99.6
SCHLUMBERGER	J5S	C388765	06-18-02	100.1	100.5	100.3
SCHLUMBERGER	J5S	C388766	06-18-02	100.1	99.8	100.1
SCHLUMBERGER	J5S	C388767	06-18-02	99.9	100.1	100.4
SCHLUMBERGER	J5S	C388768	06-18-02	100.1	100.1	99.9
SCHLUMBERGER	J5S	C388769	06-18-02	100.0	99.7	100.1
SCHLUMBERGER	J5S	C388770	06-18-02	100.0	99.8	100.1
SCHLUMBERGER	J5S	C388771	06-18-02	100.0	100.2	100.0
SCHLUMBERGER	J5S	C388772	06-18-02	99.9	99.9	100.1
SCHLUMBERGER	J5S	C388773	06-18-02	99.9	99.7	99.6
SCHLUMBERGER	J5S	C388774	06-18-02	99.9	99.8	99.6
SCHLUMBERGER	J5S	C388775	06-18-02	99.9	99.7	99.6
SCHLUMBERGER	J5S	C388776	06-18-02	100.0	99.7	99.8
SCHLUMBERGER	J5S	C388777	06-18-02	100.0	100.0	99.9
SCHLUMBERGER	J5S	C388778	06-18-02	100.1	100.0	100.2
SCHLUMBERGER	J5S	C388779	06-18-02	99.9	99.7	99.5
SCHLUMBERGER	J5S	C388780	06-18-02	100.2	100.0	100.2
SCHLUMBERGER	J5S	C388781	06-18-02	100.1	99.9	100.2
SCHLUMBERGER	J5S	C388782	06-18-02	100.1	99.8	99.7
SCHLUMBERGER	J5S	C388783	06-18-02	100.0	100.0	100.0

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

PAGE 100
 RUN DATE: 1/14/03
 RUN TIME: 13.26.53

MANUFACTURER	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	C388784	06-18-02	100.0	100.2	99.8
SCHLUMBERGER	C388785	06-18-02	99.9	100.1	99.9
SCHLUMBERGER	C388786	06-18-02	100.1	100.0	100.1
SCHLUMBERGER	C388787	06-18-02	99.9	99.8	99.6
SCHLUMBERGER	C388788	06-18-02	99.9	99.7	99.9
SCHLUMBERGER	C388789	06-18-02	100.1	99.8	100.3
SCHLUMBERGER	C388790	06-18-02	100.0	100.0	100.0
SCHLUMBERGER	C388791	06-18-02	100.2	99.9	99.9
SCHLUMBERGER	C388792	06-18-02	100.2	99.9	99.9
SCHLUMBERGER	C388793	06-18-02	100.0	99.8	100.0
SCHLUMBERGER	C388794	06-18-02	100.0	99.8	100.4
SCHLUMBERGER	C388795	06-18-02	100.0	100.2	99.9
SCHLUMBERGER	C388796	06-18-02	100.1	99.6	100.1
SCHLUMBERGER	C388797	06-18-02	100.1	99.8	99.8
SCHLUMBERGER	C388798	06-18-02	100.1	100.0	99.8
SCHLUMBERGER	C388799	06-18-02	100.1	99.9	100.1
SCHLUMBERGER	C388800	06-18-02	100.0	100.1	100.0
SCHLUMBERGER	C388801	06-18-02	100.1	99.8	100.2
SCHLUMBERGER	C388802	06-18-02	100.1	100.5	99.7
SCHLUMBERGER	C388803	06-18-02	99.9	99.7	100.0
SCHLUMBERGER	C388804	06-18-02	100.1	100.5	100.0
SCHLUMBERGER	C388805	06-18-02	100.0	99.8	99.6
SCHLUMBERGER	C388806	06-18-02	100.2	99.8	100.1
SCHLUMBERGER	C388807	06-18-02	100.0	99.7	99.4
SCHLUMBERGER	C388808	06-18-02	99.9	99.8	100.2
SCHLUMBERGER	C388809	06-18-02	99.9	100.0	100.0
SCHLUMBERGER	C388810	06-18-02	100.2	99.9	100.0
SCHLUMBERGER	C388811	06-18-02	99.9	100.2	99.6
SCHLUMBERGER	C388812	06-18-02	99.9	99.9	100.1
SCHLUMBERGER	C388813	06-18-02	100.3	99.8	99.7
SCHLUMBERGER	C388814	06-18-02	100.0	100.1	100.3
SCHLUMBERGER	C388815	06-18-02	100.1	100.0	100.3
SCHLUMBERGER	C388816	06-18-02	100.3	100.1	99.9
SCHLUMBERGER	C388817	06-18-02	99.9	99.8	99.7
SCHLUMBERGER	C388818	06-18-02	99.9	99.7	99.8
SCHLUMBERGER	C388819	06-18-02	100.0	99.7	100.0
SCHLUMBERGER	C388820	06-18-02	100.1	100.0	99.7
SCHLUMBERGER	C388821	06-18-02	100.1	99.8	100.2
SCHLUMBERGER	C388822	06-18-02	100.0	100.0	100.0
SCHLUMBERGER	C388823	06-18-02	100.2	99.8	100.1
SCHLUMBERGER	C388824	06-18-02	100.0	99.8	100.0
SCHLUMBERGER	C388825	06-18-02	100.0	99.8	100.2
SCHLUMBERGER	C388826	06-18-02	100.1	99.7	100.4
SCHLUMBERGER	C388827	06-18-02	100.1	99.7	100.2
SCHLUMBERGER	C388828	06-18-02	100.0	100.1	100.3
SCHLUMBERGER	C388829	06-18-02	100.0	99.8	99.7
SCHLUMBERGER	C388830	06-18-02	100.1	100.3	100.1
SCHLUMBERGER	C388831	06-18-02	100.0	100.2	99.5
SCHLUMBERGER	C388832	06-18-02	100.0	99.9	99.9
SCHLUMBERGER	C388833	06-18-02	100.0	99.7	99.7
SCHLUMBERGER	C388834	06-18-02	100.1	100.1	100.3

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

MANUFACTURER	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	C388835	06-18-02	100.1	100.2	99.7
SCHLUMBERGER	C388836	06-18-02	100.1	99.8	100.2
SCHLUMBERGER	C388837	06-18-02	100.0	99.7	99.9
SCHLUMBERGER	C388838	06-18-02	100.1	100.0	99.7
SCHLUMBERGER	C388839	06-18-02	100.0	99.9	100.1
SCHLUMBERGER	C388840	06-18-02	100.2	99.9	99.9
SCHLUMBERGER	C388841	06-18-02	100.0	99.7	100.0
SCHLUMBERGER	C388842	06-18-02	100.0	100.2	99.9
SCHLUMBERGER	C388843	06-18-02	100.1	99.8	100.0
SCHLUMBERGER	C388844	06-18-02	100.1	100.2	99.8
SCHLUMBERGER	C388845	06-18-02	100.1	99.7	100.1
SCHLUMBERGER	C388846	06-18-02	100.2	99.7	100.1
SCHLUMBERGER	C388847	06-18-02	99.9	99.7	100.2
SCHLUMBERGER	C388848	06-18-02	100.0	100.1	100.5
SCHLUMBERGER	C388849	06-18-02	100.3	100.0	100.2
SCHLUMBERGER	C388850	06-18-02	99.9	99.6	100.0
SCHLUMBERGER	C388851	06-18-02	100.1	100.0	99.9
SCHLUMBERGER	C388852	06-18-02	100.1	100.4	99.9
SCHLUMBERGER	C388853	06-18-02	100.0	99.9	100.0
SCHLUMBERGER	C388854	06-18-02	100.2	99.9	100.3
SCHLUMBERGER	C388855	06-18-02	100.2	99.9	100.0
SCHLUMBERGER	C388856	06-18-02	100.0	100.1	100.0
SCHLUMBERGER	C388857	06-18-02	100.0	99.7	99.8
SCHLUMBERGER	C388858	06-18-02	100.1	99.7	99.4
SCHLUMBERGER	C388859	06-18-02	100.0	100.3	100.0
SCHLUMBERGER	C388860	06-18-02	99.9	99.6	99.8
SCHLUMBERGER	C388861	06-18-02	100.1	99.7	100.0
SCHLUMBERGER	C388862	06-18-02	100.1	99.6	99.6
SCHLUMBERGER	C388863	06-18-02	100.0	100.0	99.8
SCHLUMBERGER	C388864	06-18-02	99.9	100.0	100.1
SCHLUMBERGER	C388865	06-18-02	100.0	99.9	99.9
SCHLUMBERGER	C388866	06-18-02	100.1	99.6	99.6
SCHLUMBERGER	C388867	06-18-02	100.3	99.8	100.1
SCHLUMBERGER	C388868	06-18-02	99.9	99.6	100.0
SCHLUMBERGER	C388869	06-18-02	100.0	100.2	100.1
SCHLUMBERGER	C388870	06-18-02	100.0	100.3	99.9
SCHLUMBERGER	C388871	06-18-02	100.0	99.7	100.1
SCHLUMBERGER	C388872	06-18-02	99.9	99.6	99.9
SCHLUMBERGER	C388873	06-18-02	99.9	99.9	99.6
SCHLUMBERGER	C388874	06-18-02	100.0	99.9	100.2
SCHLUMBERGER	C388875	06-18-02	100.2	99.9	100.5
SCHLUMBERGER	C388876	06-18-02	100.0	100.0	99.4
SCHLUMBERGER	C388877	06-18-02	100.1	100.1	99.8
SCHLUMBERGER	C388878	06-18-02	100.3	100.2	100.2
SCHLUMBERGER	C388879	06-18-02	100.0	99.9	100.2
SCHLUMBERGER	C388880	06-18-02	100.0	100.2	100.1
SCHLUMBERGER	C388881	06-18-02	100.1	99.7	100.0
SCHLUMBERGER	C388882	06-18-02	100.0	99.9	99.9
SCHLUMBERGER	C388883	06-18-02	100.0	99.9	99.7
SCHLUMBERGER	C388884	06-18-02	100.1	99.8	100.4
SCHLUMBERGER	C388885	06-18-02	100.1	99.9	100.1

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	J55	C388886	06-18-02	99.8	100.2	100.0
SCHLUMBERGER	J55	C388887	06-18-02	100.0	99.6	99.8
SCHLUMBERGER	J55	C388888	06-18-02	100.2	100.1	100.0
SCHLUMBERGER	J55	C388889	06-18-02	100.1	99.6	99.6
SCHLUMBERGER	J55	C388890	06-18-02	100.2	100.0	100.1
SCHLUMBERGER	J55	C388891	06-18-02	100.1	99.7	99.6
SCHLUMBERGER	J55	C388892	06-18-02	100.0	99.7	99.8
SCHLUMBERGER	J55	C388893	06-18-02	100.1	100.1	100.0
SCHLUMBERGER	J55	C388894	06-18-02	100.1	100.2	99.9
SCHLUMBERGER	J55	C388895	06-18-02	100.2	100.4	100.2
SCHLUMBERGER	J55	C388896	06-18-02	100.2	99.7	100.2
SCHLUMBERGER	J55	C388897	06-18-02	100.1	100.4	100.2
SCHLUMBERGER	J55	C388898	06-18-02	100.1	99.8	100.2
SCHLUMBERGER	J55	C388899	06-18-02	100.2	99.9	99.8
SCHLUMBERGER	J55	C388900	06-18-02	100.0	99.7	99.9
SCHLUMBERGER	J55	C388901	06-17-02	100.1	99.6	99.9
SCHLUMBERGER	J55	C388902	06-17-02	100.0	99.7	99.7
SCHLUMBERGER	J55	C388903	06-17-02	100.0	100.5	100.1
SCHLUMBERGER	J55	C388904	06-17-02	100.1	100.1	100.0
SCHLUMBERGER	J55	C388905	06-17-02	99.9	99.9	99.7
SCHLUMBERGER	J55	C388906	06-17-02	99.9	99.7	100.0
SCHLUMBERGER	J55	C388907	06-17-02	99.9	100.0	99.9
SCHLUMBERGER	J55	C388908	06-17-02	99.9	99.9	99.7
SCHLUMBERGER	J55	C388909	06-17-02	100.1	100.0	100.2
SCHLUMBERGER	J55	C388910	06-17-02	100.0	99.8	100.0
SCHLUMBERGER	J55	C388911	06-17-02	100.2	100.2	100.4
SCHLUMBERGER	J55	C388912	06-17-02	100.2	100.1	100.2
SCHLUMBERGER	J55	C388913	06-17-02	100.1	99.8	99.8
SCHLUMBERGER	J55	C388914	06-17-02	100.0	100.2	99.6
SCHLUMBERGER	J55	C388915	06-17-02	100.0	100.0	99.6
SCHLUMBERGER	J55	C388916	06-17-02	99.9	99.7	100.3
SCHLUMBERGER	J55	C388917	06-17-02	100.0	99.9	100.0
SCHLUMBERGER	J55	C388918	06-17-02	100.0	99.9	100.1
SCHLUMBERGER	J55	C388919	06-17-02	100.1	99.8	100.4
SCHLUMBERGER	J55	C388920	06-17-02	100.0	99.6	99.4
SCHLUMBERGER	J55	C388921	06-17-02	100.3	99.7	100.1
SCHLUMBERGER	J55	C388922	06-17-02	100.0	99.7	99.9
SCHLUMBERGER	J55	C388923	06-17-02	100.0	100.0	99.8
SCHLUMBERGER	J55	C388924	06-17-02	100.1	99.7	99.5
SCHLUMBERGER	J55	C388925	06-17-02	99.9	99.6	99.5
SCHLUMBERGER	J55	C388926	06-17-02	100.3	99.6	100.3
SCHLUMBERGER	J55	C388927	06-17-02	100.2	99.6	100.4
SCHLUMBERGER	J55	C388928	06-17-02	99.9	100.2	99.7
SCHLUMBERGER	J55	C388929	06-17-02	100.1	99.7	100.1
SCHLUMBERGER	J55	C388930	06-17-02	99.9	99.8	100.0
SCHLUMBERGER	J55	C388931	06-17-02	100.3	99.9	100.6
SCHLUMBERGER	J55	C388932	06-17-02	99.9	99.8	99.7
SCHLUMBERGER	J55	C388933	06-17-02	100.0	99.9	99.6
SCHLUMBERGER	J55	C388934	06-17-02	99.9	99.7	99.6
SCHLUMBERGER	J55	C388935	06-17-02	99.9	99.8	100.3
SCHLUMBERGER	J55	C388936	06-17-02	100.0	99.9	100.0

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

PAGE 103
 RUN DATE: 1/14/03
 RUN TIME: 13.26.53

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	J55	C388937	06-17-02	100.0	99.9	100.3
SCHLUMBERGER	J55	C388938	06-17-02	100.0	99.9	99.9
SCHLUMBERGER	J55	C388939	06-17-02	100.1	99.8	99.8
SCHLUMBERGER	J55	C388940	06-17-02	100.2	100.0	99.9
SCHLUMBERGER	J55	C388941	06-17-02	100.0	99.9	99.8
SCHLUMBERGER	J55	C388942	06-17-02	100.0	99.9	100.2
SCHLUMBERGER	J55	C388943	06-17-02	100.1	100.3	100.0
SCHLUMBERGER	J55	C388944	06-17-02	100.1	99.6	100.2
SCHLUMBERGER	J55	C388945	06-17-02	100.0	99.9	99.7
SCHLUMBERGER	J55	C388946	06-17-02	100.0	99.8	99.7
SCHLUMBERGER	J55	C388947	06-17-02	100.0	100.2	99.6
SCHLUMBERGER	J55	C388948	06-17-02	100.1	99.6	99.6
SCHLUMBERGER	J55	C388949	06-17-02	99.9	99.8	99.4
SCHLUMBERGER	J55	C388950	06-17-02	100.0	99.8	99.9
SCHLUMBERGER	J55	C388951	06-17-02	99.9	99.7	100.0
SCHLUMBERGER	J55	C388952	06-17-02	100.0	99.7	100.0
SCHLUMBERGER	J55	C388953	06-17-02	100.0	99.9	99.9
SCHLUMBERGER	J55	C388954	06-17-02	99.9	99.7	99.7
SCHLUMBERGER	J55	C388955	06-17-02	100.0	100.0	99.8
SCHLUMBERGER	J55	C388956	06-17-02	99.9	99.9	100.0
SCHLUMBERGER	J55	C388957	06-17-02	99.9	100.1	99.5
SCHLUMBERGER	J55	C388958	06-17-02	100.1	99.7	99.8
SCHLUMBERGER	J55	C388959	06-17-02	100.0	100.0	99.6
SCHLUMBERGER	J55	C388960	06-17-02	100.0	99.7	99.7
SCHLUMBERGER	J55	C388961	06-17-02	99.9	99.8	99.5
SCHLUMBERGER	J55	C388962	06-17-02	100.1	99.7	99.5
SCHLUMBERGER	J55	C388963	06-17-02	100.1	99.9	100.4
SCHLUMBERGER	J55	C388964	06-17-02	100.1	100.1	100.2
SCHLUMBERGER	J55	C388965	06-17-02	100.0	100.0	99.5
SCHLUMBERGER	J55	C388966	06-17-02	100.1	100.0	100.0
SCHLUMBERGER	J55	C388967	06-17-02	100.1	99.6	99.4
SCHLUMBERGER	J55	C388968	06-18-02	100.3	99.7	99.9
SCHLUMBERGER	J55	C388969	06-17-02	100.1	100.0	100.0
SCHLUMBERGER	J55	C388970	06-17-02	100.1	100.0	100.0
SCHLUMBERGER	J55	C388971	06-17-02	100.1	99.8	100.1
SCHLUMBERGER	J55	C388972	06-17-02	100.3	99.7	99.8
SCHLUMBERGER	J55	C388973	06-17-02	100.1	99.7	99.9
SCHLUMBERGER	J55	C388974	06-17-02	100.2	100.0	100.2
SCHLUMBERGER	J55	C388975	06-17-02	100.2	100.0	100.3
SCHLUMBERGER	J55	C388976	06-17-02	100.0	99.8	100.0
SCHLUMBERGER	J55	C388977	06-17-02	100.0	99.8	99.8
SCHLUMBERGER	J55	C388978	06-17-02	100.2	100.3	100.2
SCHLUMBERGER	J55	C388979	06-17-02	100.2	100.0	100.2
SCHLUMBERGER	J55	C388980	06-17-02	99.9	99.6	99.8
SCHLUMBERGER	J55	C388981	06-17-02	100.1	99.6	99.7
SCHLUMBERGER	J55	C388982	06-17-02	100.0	100.0	99.9
SCHLUMBERGER	J55	C388983	06-17-02	100.1	100.0	100.1
SCHLUMBERGER	J55	C388984	06-17-02	100.0	100.2	100.2
SCHLUMBERGER	J55	C388985	06-17-02	100.0	99.6	99.7
SCHLUMBERGER	J55	C388986	06-17-02	100.0	100.0	99.6
SCHLUMBERGER	J55	C388987	06-17-02	100.2	99.7	100.1

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

PAGE 104
 RUN DATE: 1/14/03
 RUN TIME: 13.26.53

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	J5S	C388988	06-17-02	100.0	99.7	99.8
SCHLUMBERGER	J5S	C388989	06-17-02	100.0	99.8	99.5
SCHLUMBERGER	J5S	C388990	06-17-02	100.0	99.8	100.0
SCHLUMBERGER	J5S	C388991	06-17-02	99.9	99.8	99.8
SCHLUMBERGER	J5S	C388992	06-17-02	100.2	100.1	99.7
SCHLUMBERGER	J5S	C388993	06-17-02	100.2	99.6	100.0
SCHLUMBERGER	J5S	C388994	06-17-02	100.2	99.9	100.1
SCHLUMBERGER	J5S	C388995	06-17-02	100.1	99.8	100.2
SCHLUMBERGER	J5S	C388996	06-17-02	100.0	99.8	99.6
SCHLUMBERGER	J5S	C388997	06-17-02	100.1	99.8	100.0
SCHLUMBERGER	J5S	C388998	06-17-02	99.9	100.2	99.7
SCHLUMBERGER	J5S	C388999	06-17-02	100.0	100.0	100.3
SCHLUMBERGER	J5S	C389000	06-17-02	100.1	100.0	100.1
SCHLUMBERGER	J5S	C389001	06-17-02	99.9	99.7	99.8
SCHLUMBERGER	J5S	C389002	06-17-02	100.2	100.1	100.0
SCHLUMBERGER	J5S	C389003	06-17-02	99.9	99.8	99.8
SCHLUMBERGER	J5S	C389004	06-17-02	99.9	100.2	100.0
SCHLUMBERGER	J5S	C389005	06-17-02	100.3	100.1	100.2
SCHLUMBERGER	J5S	C389006	06-17-02	100.0	99.7	99.7
SCHLUMBERGER	J5S	C389007	06-17-02	100.2	99.7	100.4
SCHLUMBERGER	J5S	C389008	06-17-02	100.3	99.9	99.7
SCHLUMBERGER	J5S	C389009	06-17-02	100.2	99.9	100.1
SCHLUMBERGER	J5S	C389010	06-17-02	99.9	99.9	100.1
SCHLUMBERGER	J5S	C389011	06-17-02	100.0	99.9	99.6
SCHLUMBERGER	J5S	C389012	06-17-02	100.0	100.4	99.9
SCHLUMBERGER	J5S	C389013	06-17-02	100.0	100.2	99.8
SCHLUMBERGER	J5S	C389014	06-17-02	100.0	99.8	99.7
SCHLUMBERGER	J5S	C389015	06-17-02	100.1	100.3	99.8
SCHLUMBERGER	J5S	C389016	06-17-02	100.0	99.7	100.2
SCHLUMBERGER	J5S	C389017	06-17-02	99.9	99.8	99.9
SCHLUMBERGER	J5S	C389018	06-17-02	100.1	99.8	99.7
SCHLUMBERGER	J5S	C389019	06-17-02	100.0	100.3	99.7
SCHLUMBERGER	J5S	C389020	06-17-02	99.9	99.6	100.0
SCHLUMBERGER	J5S	C389021	06-17-02	100.0	99.8	100.2
SCHLUMBERGER	J5S	C389022	06-17-02	99.9	100.5	100.0
SCHLUMBERGER	J5S	C389023	06-17-02	100.0	100.0	100.0
SCHLUMBERGER	J5S	C389024	06-17-02	100.2	99.7	99.8
SCHLUMBERGER	J5S	C389025	06-17-02	100.1	100.0	100.2
SCHLUMBERGER	J5S	C389026	06-17-02	100.2	99.7	100.2
SCHLUMBERGER	J5S	C389027	06-17-02	100.0	99.7	99.6
SCHLUMBERGER	J5S	C389028	06-17-02	100.0	100.5	100.1
SCHLUMBERGER	J5S	C389029	06-17-02	100.0	99.9	99.7
SCHLUMBERGER	J5S	C389030	06-17-02	99.9	99.8	99.9
SCHLUMBERGER	J5S	C389031	06-17-02	100.0	99.8	99.5
SCHLUMBERGER	J5S	C389032	06-17-02	100.0	100.1	99.6
SCHLUMBERGER	J5S	C389033	06-17-02	100.1	99.9	100.1
SCHLUMBERGER	J5S	C389034	06-17-02	100.1	99.7	100.1
SCHLUMBERGER	J5S	C389035	06-17-02	99.9	99.7	99.6
SCHLUMBERGER	J5S	C389036	06-17-02	100.2	99.7	99.9
SCHLUMBERGER	J5S	C389037	06-17-02	100.0	100.5	99.5
SCHLUMBERGER	J5S	C389038	06-17-02	100.1	99.9	99.7

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

PAGE 105
 RUN DATE: 1/14/03
 RUN TIME: 13.26.53

MANUFACTURER	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	C389039	06-17-02	100.1	100.2	99.8
SCHLUMBERGER	C389040	06-17-02	99.9	99.6	99.7
SCHLUMBERGER	C389041	06-17-02	100.1	99.8	100.3
SCHLUMBERGER	C389042	06-17-02	100.2	100.1	100.0
SCHLUMBERGER	C389043	06-17-02	99.8	99.7	99.3
SCHLUMBERGER	C389044	06-17-02	99.9	100.1	100.2
SCHLUMBERGER	C389045	06-17-02	100.1	99.9	100.0
SCHLUMBERGER	C389046	06-17-02	100.0	100.0	100.1
SCHLUMBERGER	C389047	06-17-02	100.2	100.4	100.3
SCHLUMBERGER	C389048	06-17-02	100.1	100.1	100.2
SCHLUMBERGER	C389049	06-17-02	100.0	99.6	100.0
SCHLUMBERGER	C389050	06-17-02	100.0	100.2	100.0
SCHLUMBERGER	C389051	06-17-02	99.9	99.8	99.7
SCHLUMBERGER	C389052	06-17-02	99.9	99.6	100.0
SCHLUMBERGER	C389053	06-17-02	100.0	99.9	100.2
SCHLUMBERGER	C389054	06-17-02	100.0	99.7	100.1
SCHLUMBERGER	C389055	06-17-02	100.1	100.0	100.5
SCHLUMBERGER	C389056	06-17-02	100.0	100.4	100.0
SCHLUMBERGER	C389057	06-17-02	100.0	100.0	99.9
SCHLUMBERGER	C389058	06-17-02	100.0	99.8	100.2
SCHLUMBERGER	C389059	06-17-02	100.2	99.8	100.0
SCHLUMBERGER	C389060	06-17-02	99.9	99.6	99.8
SCHLUMBERGER	C389061	06-17-02	100.2	100.1	100.2
SCHLUMBERGER	C389062	06-17-02	100.0	99.8	99.9
SCHLUMBERGER	C389063	06-17-02	100.1	99.7	99.7
SCHLUMBERGER	C389064	06-17-02	100.3	100.2	99.8
SCHLUMBERGER	C389065	06-17-02	100.0	99.7	100.1
SCHLUMBERGER	C389066	06-17-02	100.1	100.1	99.5
SCHLUMBERGER	C389067	06-17-02	100.0	99.6	99.9
SCHLUMBERGER	C389068	06-17-02	100.1	99.7	99.7
SCHLUMBERGER	C389069	06-17-02	100.1	99.9	100.3
SCHLUMBERGER	C389070	06-17-02	100.1	99.9	100.1
SCHLUMBERGER	C389071	06-17-02	99.8	100.0	99.3
SCHLUMBERGER	C389072	06-17-02	100.0	100.2	99.8
SCHLUMBERGER	C389073	06-17-02	100.1	99.9	100.1
SCHLUMBERGER	C389074	06-17-02	100.1	100.1	99.9
SCHLUMBERGER	C389075	06-17-02	100.0	100.1	99.5
SCHLUMBERGER	C389076	06-17-02	100.2	99.6	100.0
SCHLUMBERGER	C389077	06-17-02	100.1	100.2	100.1
SCHLUMBERGER	C389078	06-17-02	99.9	99.6	99.7
SCHLUMBERGER	C389079	06-17-02	100.1	100.2	100.5
SCHLUMBERGER	C389080	06-17-02	99.9	99.7	99.9
SCHLUMBERGER	C389081	06-17-02	100.1	99.7	99.9
SCHLUMBERGER	C389082	06-17-02	99.9	99.7	99.7
SCHLUMBERGER	C389083	06-17-02	100.0	99.6	99.5
SCHLUMBERGER	C389084	06-17-02	99.9	99.7	99.6
SCHLUMBERGER	C389085	06-17-02	100.0	99.7	100.1
SCHLUMBERGER	C389086	06-17-02	99.9	99.9	99.9
SCHLUMBERGER	C389087	06-17-02	100.1	99.9	100.3
SCHLUMBERGER	C389088	06-17-02	100.0	99.8	100.1
SCHLUMBERGER	C389089	06-17-02	99.9	99.8	99.7

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	J55	C389090	06-17-02	99.9	99.7	99.9
SCHLUMBERGER	J55	C389091	06-17-02	99.9	99.7	99.4
SCHLUMBERGER	J55	C389092	06-17-02	100.2	100.0	100.1
SCHLUMBERGER	J55	C389093	06-17-02	99.9	99.7	100.0
SCHLUMBERGER	J55	C389094	06-17-02	100.0	99.6	99.9
SCHLUMBERGER	J55	C389095	06-17-02	100.1	100.2	100.4
SCHLUMBERGER	J55	C389096	06-17-02	100.0	99.7	99.7
SCHLUMBERGER	J55	C389097	06-17-02	100.0	100.0	100.0
SCHLUMBERGER	J55	C389098	06-17-02	100.1	100.1	100.2
SCHLUMBERGER	J55	C389099	06-17-02	100.1	100.3	100.1
SCHLUMBERGER	J55	C389100	06-17-02	100.1	99.9	99.3
SCHLUMBERGER	J55	C389101	06-17-02	99.8	100.0	99.8
SCHLUMBERGER	J55	C389102	06-17-02	100.0	99.9	99.8
SCHLUMBERGER	J55	C389103	06-17-02	100.1	100.1	100.1
SCHLUMBERGER	J55	C389104	06-17-02	100.2	99.8	100.3
SCHLUMBERGER	J55	C389105	06-17-02	100.0	99.9	100.2
SCHLUMBERGER	J55	C389106	06-17-02	100.3	100.1	100.1
SCHLUMBERGER	J55	C389107	06-17-02	100.2	100.1	100.2
SCHLUMBERGER	J55	C389108	06-17-02	100.1	99.7	100.1
SCHLUMBERGER	J55	C389109	06-17-02	100.0	100.4	99.7
SCHLUMBERGER	J55	C389110	06-17-02	100.1	99.6	100.4
SCHLUMBERGER	J55	C389111	06-17-02	100.0	99.8	100.1
SCHLUMBERGER	J55	C389112	06-17-02	99.9	99.8	99.3
SCHLUMBERGER	J55	C389113	06-17-02	100.1	100.1	100.2
SCHLUMBERGER	J55	C389114	06-17-02	100.0	99.6	99.9
SCHLUMBERGER	J55	C389115	06-17-02	99.9	100.1	100.0
SCHLUMBERGER	J55	C389116	06-17-02	100.1	99.8	100.2
SCHLUMBERGER	J55	C389117	06-17-02	99.8	99.8	99.6
SCHLUMBERGER	J55	C389118	06-17-02	99.9	100.2	100.0
SCHLUMBERGER	J55	C389119	06-17-02	100.0	99.7	100.2
SCHLUMBERGER	J55	C389120	06-17-02	100.1	99.8	100.4
SCHLUMBERGER	J55	C389121	06-17-02	100.1	100.0	100.0
SCHLUMBERGER	J55	C389122	06-17-02	99.8	99.6	99.6
SCHLUMBERGER	J55	C389123	06-17-02	100.2	100.3	100.3
SCHLUMBERGER	J55	C389124	06-17-02	100.0	99.7	99.6
SCHLUMBERGER	J55	C389125	06-17-02	100.1	100.1	99.9
SCHLUMBERGER	J55	C389126	06-17-02	100.0	99.8	99.3
SCHLUMBERGER	J55	C389127	06-17-02	100.0	99.8	99.9
SCHLUMBERGER	J55	C389128	06-17-02	99.9	99.6	99.9
SCHLUMBERGER	J55	C389129	06-17-02	100.1	99.7	100.2
SCHLUMBERGER	J55	C389130	06-17-02	100.2	99.7	100.2
SCHLUMBERGER	J55	C389131	06-17-02	100.0	100.0	99.7
SCHLUMBERGER	J55	C389132	06-17-02	100.0	99.7	99.4
SCHLUMBERGER	J55	C389133	06-17-02	99.9	99.8	99.8
SCHLUMBERGER	J55	C389134	06-17-02	99.9	99.7	99.8
SCHLUMBERGER	J55	C389135	06-17-02	100.0	99.7	99.8
SCHLUMBERGER	J55	C389136	06-17-02	99.9	100.1	99.6
SCHLUMBERGER	J55	C389137	06-17-02	100.1	100.3	99.3
SCHLUMBERGER	J55	C389138	06-17-02	100.1	100.1	100.1
SCHLUMBERGER	J55	C389139	06-17-02	99.9	99.7	99.9
SCHLUMBERGER	J55	C389140	06-17-02	100.0	100.3	100.4

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

PAGE 107
 RUN DATE: 1/14/03
 RUN TIME: 13.26.53

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	J5S	C389141	06-17-02	100.2	100.1	100.4
SCHLUMBERGER	J5S	C389142	06-17-02	100.2	100.2	100.1
SCHLUMBERGER	J5S	C389143	06-17-02	99.8	99.7	99.6
SCHLUMBERGER	J5S	C389144	06-17-02	99.9	99.9	99.5
SCHLUMBERGER	J5S	C389145	06-17-02	100.0	100.5	100.2
SCHLUMBERGER	J5S	C389146	06-17-02	100.2	100.1	100.2
SCHLUMBERGER	J5S	C389147	06-17-02	100.1	100.0	100.1
SCHLUMBERGER	J5S	C389148	06-17-02	99.9	99.8	99.9
SCHLUMBERGER	J5S	C389149	06-17-02	100.1	100.2	99.5
SCHLUMBERGER	J5S	C389150	06-17-02	100.0	99.7	100.0
SCHLUMBERGER	J5S	C389151	06-17-02	100.1	99.7	99.9
SCHLUMBERGER	J5S	C389152	06-17-02	100.0	99.7	100.2
SCHLUMBERGER	J5S	C389153	06-17-02	99.9	100.2	99.6
SCHLUMBERGER	J5S	C389154	06-17-02	100.3	100.0	100.1
SCHLUMBERGER	J5S	C389155	06-17-02	100.0	99.8	99.5
SCHLUMBERGER	J5S	C389156	06-17-02	100.1	99.8	99.9
SCHLUMBERGER	J5S	C389157	06-17-02	100.0	100.1	99.4
SCHLUMBERGER	J5S	C389158	06-17-02	100.1	99.7	100.6
SCHLUMBERGER	J5S	C389159	06-17-02	99.9	99.7	99.6
SCHLUMBERGER	J5S	C389160	06-17-02	99.9	99.7	100.3
SCHLUMBERGER	J5S	C389161	06-17-02	100.1	99.9	99.9
SCHLUMBERGER	J5S	C389162	06-17-02	99.9	99.8	100.0
SCHLUMBERGER	J5S	C389163	06-17-02	100.0	99.8	99.5
SCHLUMBERGER	J5S	C389164	06-17-02	99.9	99.6	99.8
SCHLUMBERGER	J5S	C389165	06-17-02	100.0	99.6	100.6
SCHLUMBERGER	J5S	C389166	06-17-02	100.2	100.0	100.0
SCHLUMBERGER	J5S	C389167	06-17-02	100.1	99.9	99.8
SCHLUMBERGER	J5S	C389168	06-17-02	100.0	99.7	99.6
SCHLUMBERGER	J5S	C389169	06-17-02	99.9	100.2	99.8
SCHLUMBERGER	J5S	C389170	06-17-02	100.2	100.1	100.2
SCHLUMBERGER	J5S	C389171	06-17-02	100.1	100.1	100.1
SCHLUMBERGER	J5S	C389172	06-17-02	99.9	99.9	99.6
SCHLUMBERGER	J5S	C389173	06-17-02	100.2	99.6	99.8
SCHLUMBERGER	J5S	C389174	06-17-02	100.1	99.8	100.0
SCHLUMBERGER	J5S	C389175	06-17-02	100.0	99.8	99.7
SCHLUMBERGER	J5S	C389176	06-17-02	100.0	99.6	99.7
SCHLUMBERGER	J5S	C389177	06-17-02	100.1	99.8	100.1
SCHLUMBERGER	J5S	C389178	06-17-02	100.0	100.3	100.3
SCHLUMBERGER	J5S	C389179	06-17-02	100.1	100.0	99.8
SCHLUMBERGER	J5S	C389180	06-17-02	100.0	99.8	99.7
SCHLUMBERGER	J5S	C389181	06-17-02	100.2	100.2	100.6
SCHLUMBERGER	J5S	C389182	06-17-02	100.2	100.0	100.2
SCHLUMBERGER	J5S	C389183	06-17-02	100.0	99.6	100.3
SCHLUMBERGER	J5S	C389184	06-17-02	100.0	99.7	99.7
SCHLUMBERGER	J5S	C389185	06-17-02	100.1	99.7	100.5
SCHLUMBERGER	J5S	C389186	06-17-02	99.8	99.8	100.4
SCHLUMBERGER	J5S	C389187	06-17-02	99.9	100.4	100.6
SCHLUMBERGER	J5S	C389188	06-17-02	100.1	99.8	100.2
SCHLUMBERGER	J5S	C389189	06-17-02	100.0	100.4	100.2
SCHLUMBERGER	J5S	C389190	06-17-02	100.1	99.9	100.4
SCHLUMBERGER	J5S	C389191	06-17-02	100.1	99.8	100.3

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

PAGE 108
 RUN DATE: 1/14/03
 RUN TIME: 13.26.53

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	J55	C389192	06-17-02	100.0	100.1	99.9
SCHLUMBERGER	J55	C389193	06-17-02	100.1	99.8	100.1
SCHLUMBERGER	J55	C389194	06-17-02	99.9	100.0	99.8
SCHLUMBERGER	J55	C389195	06-17-02	99.9	99.8	100.1
SCHLUMBERGER	J55	C389196	06-17-02	100.0	99.7	100.0
SCHLUMBERGER	J55	C389197	06-17-02	100.2	99.8	99.7
SCHLUMBERGER	J55	C389198	06-17-02	100.0	99.8	99.9
SCHLUMBERGER	J55	C389199	06-17-02	100.2	100.5	100.1
SCHLUMBERGER	J55	C389200	06-17-02	100.2	100.1	99.5
SCHLUMBERGER	J55	C389201	06-17-02	100.1	100.1	100.3
SCHLUMBERGER	J55	C389202	06-17-02	100.1	100.1	100.3
SCHLUMBERGER	J55	C389203	06-17-02	100.2	100.4	100.1
SCHLUMBERGER	J55	C389204	06-17-02	100.2	99.8	99.6
SCHLUMBERGER	J55	C389205	06-17-02	100.0	100.0	100.0
SCHLUMBERGER	J55	C389206	06-17-02	100.0	99.7	99.7
SCHLUMBERGER	J55	C389207	06-17-02	100.1	100.1	99.9
SCHLUMBERGER	J55	C389208	06-17-02	100.0	100.1	100.1
SCHLUMBERGER	J55	C389209	06-17-02	100.2	100.4	99.3
SCHLUMBERGER	J55	C389210	06-17-02	100.1	100.1	99.9
SCHLUMBERGER	J55	C389211	06-17-02	100.0	99.7	99.7
SCHLUMBERGER	J55	C389212	06-17-02	99.9	99.8	100.4
SCHLUMBERGER	J55	C389213	06-17-02	100.1	100.2	99.8
SCHLUMBERGER	J55	C389214	06-17-02	100.1	100.0	99.8
SCHLUMBERGER	J55	C389215	06-17-02	100.0	100.4	99.9
SCHLUMBERGER	J55	C389216	06-17-02	100.0	99.9	100.5
SCHLUMBERGER	J55	C389217	06-17-02	100.2	99.8	100.5
SCHLUMBERGER	J55	C389218	06-17-02	100.0	100.3	99.9
SCHLUMBERGER	J55	C389219	06-17-02	99.9	99.9	99.9
SCHLUMBERGER	J55	C389220	06-17-02	100.0	100.2	99.8
SCHLUMBERGER	J55	C389221	06-17-02	100.1	99.8	100.5
SCHLUMBERGER	J55	C389222	06-17-02	100.0	100.0	99.6
SCHLUMBERGER	J55	C389223	06-17-02	100.1	99.8	100.2
SCHLUMBERGER	J55	C389224	06-17-02	99.9	99.8	100.0
SCHLUMBERGER	J55	C389225	06-17-02	100.0	99.8	99.2
SCHLUMBERGER	J55	C389226	06-17-02	100.0	99.7	100.0
SCHLUMBERGER	J55	C389227	06-17-02	99.9	99.7	100.2
SCHLUMBERGER	J55	C389228	06-17-02	100.1	99.9	100.3
SCHLUMBERGER	J55	C389229	06-17-02	99.9	99.8	99.9
SCHLUMBERGER	J55	C389230	06-17-02	100.1	99.7	100.1
SCHLUMBERGER	J55	C389231	06-17-02	100.0	99.8	100.1
SCHLUMBERGER	J55	C389232	06-17-02	100.3	99.9	99.9
SCHLUMBERGER	J55	C389233	06-17-02	99.9	99.8	100.0
SCHLUMBERGER	J55	C389234	06-17-02	99.9	99.7	99.5
SCHLUMBERGER	J55	C389235	06-17-02	99.9	99.9	99.5
SCHLUMBERGER	J55	C389236	06-17-02	100.2	99.7	100.4
SCHLUMBERGER	J55	C389237	06-17-02	100.2	99.9	100.4
SCHLUMBERGER	J55	C389238	06-17-02	99.9	100.1	100.7
SCHLUMBERGER	J55	C389239	06-17-02	100.1	99.9	99.9
SCHLUMBERGER	J55	C389240	06-17-02	100.1	100.2	100.4
SCHLUMBERGER	J55	C389241	06-17-02	100.0	99.8	100.2
SCHLUMBERGER	J55	C389242	06-17-02	99.9	99.8	100.1
SCHLUMBERGER	J55	C389242	06-17-02	100.1	99.7	100.2

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

MANUFACTURER	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	C389243	06-17-02	100.1	100.0	100.3
SCHLUMBERGER	C389244	06-17-02	100.0	99.6	99.7
SCHLUMBERGER	C389245	06-17-02	100.0	99.6	100.0
SCHLUMBERGER	C389246	06-17-02	100.0	100.0	99.9
SCHLUMBERGER	C389247	06-17-02	100.0	100.0	99.6
SCHLUMBERGER	C389248	06-17-02	99.8	99.7	99.6
SCHLUMBERGER	C389249	06-17-02	100.2	100.0	100.0
SCHLUMBERGER	C389250	06-17-02	99.8	99.7	100.2
SCHLUMBERGER	C389251	06-17-02	100.1	99.9	100.0
SCHLUMBERGER	C389252	06-17-02	100.1	100.1	99.8
SCHLUMBERGER	C389253	06-17-02	99.9	99.9	100.1
SCHLUMBERGER	C389254	06-17-02	100.1	99.8	99.4
SCHLUMBERGER	C389255	06-17-02	99.9	99.8	100.1
SCHLUMBERGER	C389256	06-17-02	100.1	100.2	100.2
SCHLUMBERGER	C389257	06-17-02	99.9	99.8	100.0
SCHLUMBERGER	C389258	06-17-02	99.9	99.8	99.6
SCHLUMBERGER	C389259	06-17-02	100.1	100.0	100.2
SCHLUMBERGER	C389260	06-17-02	100.0	99.8	99.9
SCHLUMBERGER	C389261	06-17-02	99.9	99.8	100.3
SCHLUMBERGER	C389262	06-17-02	100.2	100.1	100.2
SCHLUMBERGER	C389263	06-17-02	100.2	100.1	100.3
SCHLUMBERGER	C389264	06-17-02	99.9	99.8	99.5
SCHLUMBERGER	C389265	06-17-02	100.0	99.8	99.9
SCHLUMBERGER	C389266	06-17-02	99.9	99.9	99.6
SCHLUMBERGER	C389267	06-17-02	100.1	99.6	99.8
SCHLUMBERGER	C389268	06-17-02	100.2	100.2	99.7
SCHLUMBERGER	C389269	06-17-02	100.1	99.8	100.0
SCHLUMBERGER	C389270	06-17-02	99.8	99.8	99.9
SCHLUMBERGER	C389271	06-17-02	99.9	99.9	99.8
SCHLUMBERGER	C389272	06-17-02	99.9	99.9	100.1
SCHLUMBERGER	C389273	06-17-02	100.0	99.7	99.9
SCHLUMBERGER	C389274	06-17-02	100.1	100.0	100.1
SCHLUMBERGER	C389275	06-17-02	100.0	99.8	100.1
SCHLUMBERGER	C389276	06-17-02	100.0	99.8	99.4
SCHLUMBERGER	C389277	06-17-02	100.0	100.0	99.7
SCHLUMBERGER	C389278	06-17-02	99.9	100.0	100.3
SCHLUMBERGER	C389279	06-17-02	100.3	100.5	100.1
SCHLUMBERGER	C389280	06-17-02	100.0	99.8	99.6
SCHLUMBERGER	C389281	06-17-02	100.2	99.8	99.8
SCHLUMBERGER	C389282	06-17-02	100.0	99.8	100.4
SCHLUMBERGER	C389283	06-17-02	100.0	99.8	99.5
SCHLUMBERGER	C389284	06-17-02	99.8	100.0	100.0
SCHLUMBERGER	C389285	06-17-02	100.0	99.9	100.1
SCHLUMBERGER	C389286	06-17-02	100.2	100.0	99.7
SCHLUMBERGER	C389287	06-17-02	99.9	99.8	99.6
SCHLUMBERGER	C389288	06-17-02	100.2	99.8	99.2
SCHLUMBERGER	C389289	06-17-02	99.9	100.0	100.1
SCHLUMBERGER	C389290	06-17-02	100.3	99.9	99.4
SCHLUMBERGER	C389291	06-17-02	100.2	99.8	99.9
SCHLUMBERGER	C389292	06-17-02	100.1	99.8	99.7
SCHLUMBERGER	C389293	06-17-02	99.8	99.9	99.6

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

PAGE 110
 RUN DATE: 1/14/03
 RUN TIME: 13.26.53

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	J55	C389294	06-17-02	100.0	99.8	100.7
SCHLUMBERGER	J55	C389295	06-17-02	100.0	99.9	100.1
SCHLUMBERGER	J55	C389296	06-17-02	100.3	100.1	100.2
SCHLUMBERGER	J55	C389297	06-17-02	100.1	99.7	99.9
SCHLUMBERGER	J55	C389298	06-17-02	100.0	100.0	99.5
SCHLUMBERGER	J55	C389299	06-17-02	100.1	99.9	99.7
SCHLUMBERGER	J55	C389300	06-17-02	100.2	100.0	100.3
SCHLUMBERGER	J55	C389301	06-17-02	100.1	99.8	100.8
SCHLUMBERGER	J55	C389302	06-17-02	100.0	99.7	99.6
SCHLUMBERGER	J55	C389303	06-17-02	100.0	99.7	99.9
SCHLUMBERGER	J55	C389304	06-17-02	99.9	99.9	100.0
SCHLUMBERGER	J55	C389305	06-17-02	100.0	99.6	100.2
SCHLUMBERGER	J55	C389306	06-17-02	100.0	100.0	99.8
SCHLUMBERGER	J55	C389307	06-17-02	100.1	99.5	99.5
SCHLUMBERGER	J55	C389308	06-17-02	100.1	99.6	100.1
SCHLUMBERGER	J55	C389309	06-17-02	100.1	99.8	99.6
SCHLUMBERGER	J55	C389310	06-17-02	100.0	99.7	100.0
SCHLUMBERGER	J55	C389311	06-17-02	100.0	100.0	99.7
SCHLUMBERGER	J55	C389312	06-17-02	100.3	99.9	100.1
SCHLUMBERGER	J55	C389313	06-17-02	100.0	99.6	100.0
SCHLUMBERGER	J55	C389314	06-17-02	99.8	99.8	100.7
SCHLUMBERGER	J55	C389315	06-17-02	100.3	100.4	100.4
SCHLUMBERGER	J55	C389316	06-17-02	100.0	99.6	100.0
SCHLUMBERGER	J55	C389317	06-17-02	100.0	99.9	99.8
SCHLUMBERGER	J55	C389318	06-17-02	100.2	99.8	99.9
SCHLUMBERGER	J55	C389319	06-17-02	100.2	99.8	99.7
SCHLUMBERGER	J55	C389321	06-17-02	99.9	99.9	99.9
SCHLUMBERGER	J55	C389322	06-17-02	99.9	99.9	100.3
SCHLUMBERGER	J55	C389323	06-17-02	100.1	100.0	100.4
SCHLUMBERGER	J55	C389324	06-17-02	100.1	100.1	100.2
SCHLUMBERGER	J55	C389325	06-17-02	100.1	100.1	99.8
SCHLUMBERGER	J55	C389326	06-17-02	100.2	99.8	100.1
SCHLUMBERGER	J55	C389327	06-17-02	100.2	100.1	99.5
SCHLUMBERGER	J55	C389328	06-17-02	100.2	100.0	100.0
SCHLUMBERGER	J55	C389329	06-17-02	100.2	100.0	100.5
SCHLUMBERGER	J55	C389330	06-17-02	99.8	100.0	99.8
SCHLUMBERGER	J55	C389331	06-17-02	100.1	100.0	100.5
SCHLUMBERGER	J55	C389332	06-17-02	100.0	99.7	100.0
SCHLUMBERGER	J55	C389333	06-17-02	100.2	99.8	100.2
SCHLUMBERGER	J55	C389334	06-17-02	100.0	100.0	100.0
SCHLUMBERGER	J55	C389335	06-17-02	100.1	99.6	99.6
SCHLUMBERGER	J55	C389336	06-17-02	99.9	100.0	100.2
SCHLUMBERGER	J55	C389337	06-17-02	100.1	100.0	99.8
SCHLUMBERGER	J55	C389338	06-17-02	100.0	100.0	100.1
SCHLUMBERGER	J55	C389339	06-17-02	99.9	100.3	100.2
SCHLUMBERGER	J55	C389340	06-17-02	100.0	100.2	99.3
SCHLUMBERGER	J55	C389341	06-17-02	99.9	99.9	99.9
SCHLUMBERGER	J55	C389342	06-17-02	99.8	99.9	99.3
SCHLUMBERGER	J55	C389343	06-17-02	99.8	100.0	99.2
SCHLUMBERGER	J55	C389344	06-17-02	99.9	100.0	99.8

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

PAGE 111
 RUN DATE: 1/14/03
 RUN TIME: 13.26.53

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	J55	C389345	06-17-02	99.9	99.6	99.7
SCHLUMBERGER	J55	C389346	06-17-02	100.0	99.6	100.1
SCHLUMBERGER	J55	C389347	06-17-02	100.2	100.4	99.9
SCHLUMBERGER	J55	C389348	06-17-02	100.0	100.1	100.3
SCHLUMBERGER	J55	C389349	06-17-02	100.0	99.9	100.2
SCHLUMBERGER	J55	C389350	06-17-02	100.1	99.9	100.0
SCHLUMBERGER	J55	C389351	06-17-02	100.0	99.6	99.6
SCHLUMBERGER	J55	C389352	06-17-02	100.0	99.8	99.4
SCHLUMBERGER	J55	C389353	06-17-02	100.0	100.0	100.6
SCHLUMBERGER	J55	C389354	06-17-02	100.2	100.0	99.9
SCHLUMBERGER	J55	C389355	06-17-02	100.0	99.9	99.9
SCHLUMBERGER	J55	C389356	06-17-02	100.3	99.8	100.0
SCHLUMBERGER	J55	C389357	06-17-02	100.3	99.8	100.1
SCHLUMBERGER	J55	C389358	06-17-02	100.1	99.8	100.1
SCHLUMBERGER	J55	C389359	06-17-02	99.8	100.1	99.7
SCHLUMBERGER	J55	C389360	06-17-02	100.1	100.1	99.8
SCHLUMBERGER	J55	C389361	06-17-02	100.0	100.0	100.3
SCHLUMBERGER	J55	C389362	06-17-02	100.0	99.8	99.3
SCHLUMBERGER	J55	C389363	06-17-02	100.0	99.7	99.7
SCHLUMBERGER	J55	C389364	06-17-02	99.9	100.2	99.9
SCHLUMBERGER	J55	C389365	06-17-02	100.2	100.3	100.1
SCHLUMBERGER	J55	C389366	06-17-02	100.3	100.1	100.3
SCHLUMBERGER	J55	C389367	06-17-02	99.8	100.3	99.3
SCHLUMBERGER	J55	C389368	06-17-02	100.2	99.7	100.2
SCHLUMBERGER	J55	C389369	06-17-02	100.1	100.1	99.9
SCHLUMBERGER	J55	C389370	06-17-02	100.0	99.8	99.8
SCHLUMBERGER	J55	C389371	06-17-02	100.0	99.7	100.1
SCHLUMBERGER	J55	C389372	06-17-02	100.1	99.7	100.1
SCHLUMBERGER	J55	C389373	06-17-02	100.0	99.7	99.6
SCHLUMBERGER	J55	C389374	06-17-02	99.9	100.2	99.9
SCHLUMBERGER	J55	C389375	06-17-02	99.8	99.8	99.9
SCHLUMBERGER	J55	C389376	06-17-02	100.3	99.8	100.1
SCHLUMBERGER	J55	C389377	06-17-02	100.0	99.7	99.8
SCHLUMBERGER	J55	C389378	06-17-02	100.2	99.9	100.2
SCHLUMBERGER	J55	C389379	06-17-02	100.2	99.7	100.2
SCHLUMBERGER	J55	C389380	06-17-02	100.0	100.2	99.8
SCHLUMBERGER	J55	C389381	06-17-02	100.1	99.8	100.2
SCHLUMBERGER	J55	C389382	06-17-02	99.9	100.0	99.6
SCHLUMBERGER	J55	C389383	06-17-02	99.9	100.2	100.1
SCHLUMBERGER	J55	C389384	06-17-02	100.1	99.9	100.2
SCHLUMBERGER	J55	C389385	06-17-02	100.2	99.9	100.2
SCHLUMBERGER	J55	C389386	06-17-02	100.0	100.0	99.7
SCHLUMBERGER	J55	C389387	06-17-02	99.9	99.6	100.0
SCHLUMBERGER	J55	C389388	06-17-02	100.1	99.9	99.8
SCHLUMBERGER	J55	C389389	06-17-02	100.0	100.1	100.0
SCHLUMBERGER	J55	C389390	06-17-02	99.9	99.7	99.6
SCHLUMBERGER	J55	C389391	06-17-02	99.9	100.2	100.0
SCHLUMBERGER	J55	C389392	06-17-02	100.0	99.7	100.1
SCHLUMBERGER	J55	C389393	06-17-02	100.0	99.8	99.8
SCHLUMBERGER	J55	C389394	06-17-02	100.0	99.6	100.1
SCHLUMBERGER	J55	C389395	06-17-02	100.1	99.9	99.9

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	J5S	C389396	06-17-02	100.0	100.2	99.3
SCHLUMBERGER	J5S	C389397	06-17-02	100.1	100.2	100.6
SCHLUMBERGER	J5S	C389398	06-17-02	99.9	99.6	100.1
SCHLUMBERGER	J5S	C389399	06-17-02	99.9	99.8	99.7
SCHLUMBERGER	J5S	C389400	06-17-02	100.2	100.1	100.6
SCHLUMBERGER	J5S	C389401	06-17-02	100.3	100.0	100.0
SCHLUMBERGER	J5S	C389402	06-17-02	100.2	100.0	100.1
SCHLUMBERGER	J5S	C389403	06-17-02	100.3	100.1	100.7
SCHLUMBERGER	J5S	C389404	06-17-02	100.2	100.1	100.4
SCHLUMBERGER	J5S	C389405	06-17-02	100.0	99.9	99.8
SCHLUMBERGER	J5S	C389406	06-17-02	100.0	100.0	99.8
SCHLUMBERGER	J5S	C389407	06-17-02	100.1	99.6	100.0
SCHLUMBERGER	J5S	C389408	06-17-02	100.1	99.8	100.0
SCHLUMBERGER	J5S	C389409	06-17-02	99.9	99.6	99.6
SCHLUMBERGER	J5S	C389410	06-17-02	100.1	99.8	99.7
SCHLUMBERGER	J5S	C389411	06-17-02	100.0	100.1	100.1
SCHLUMBERGER	J5S	C389412	06-17-02	100.2	100.2	100.3
SCHLUMBERGER	J5S	C389413	06-17-02	100.1	100.2	100.2
SCHLUMBERGER	J5S	C389414	06-17-02	100.2	100.1	100.5
SCHLUMBERGER	J5S	C389415	06-17-02	99.9	100.0	99.5
SCHLUMBERGER	J5S	C389416	06-17-02	100.2	100.0	100.0
SCHLUMBERGER	J5S	C389417	06-17-02	100.1	100.0	99.8
SCHLUMBERGER	J5S	C389418	06-17-02	100.0	99.8	99.9
SCHLUMBERGER	J5S	C389419	06-17-02	100.2	99.8	99.9
SCHLUMBERGER	J5S	C389420	06-17-02	100.2	99.7	99.6
SCHLUMBERGER	J5S	C389421	06-17-02	99.9	99.7	99.6
SCHLUMBERGER	J5S	C389422	06-17-02	100.1	99.7	100.1
SCHLUMBERGER	J5S	C389423	06-17-02	100.1	100.1	100.2
SCHLUMBERGER	J5S	C389424	06-17-02	100.1	99.9	99.8
SCHLUMBERGER	J5S	C389425	06-17-02	100.1	99.7	100.6
SCHLUMBERGER	J5S	C389426	06-17-02	100.1	99.7	99.7
SCHLUMBERGER	J5S	C389427	06-17-02	99.9	99.9	100.1
SCHLUMBERGER	J5S	C389428	06-17-02	100.0	100.1	100.4
SCHLUMBERGER	J5S	C389429	06-17-02	99.9	99.6	99.9
SCHLUMBERGER	J5S	C389430	06-17-02	100.1	100.1	99.7
SCHLUMBERGER	J5S	C389431	06-17-02	100.0	100.0	99.6
SCHLUMBERGER	J5S	C389432	06-17-02	100.2	99.9	99.9
SCHLUMBERGER	J5S	C389433	06-17-02	99.9	99.9	100.2
SCHLUMBERGER	J5S	C389434	06-17-02	100.0	99.9	100.0
SCHLUMBERGER	J5S	C389435	06-17-02	100.1	100.0	100.0
SCHLUMBERGER	J5S	C389436	06-17-02	100.1	100.1	100.4
SCHLUMBERGER	J5S	C389437	06-17-02	99.9	99.6	99.9
SCHLUMBERGER	J5S	C389438	06-17-02	99.9	99.7	100.4
SCHLUMBERGER	J5S	C389439	06-17-02	100.0	99.7	99.8
SCHLUMBERGER	J5S	C389440	06-17-02	100.0	99.7	99.9
SCHLUMBERGER	J5S	C389441	06-17-02	100.0	99.9	99.9
SCHLUMBERGER	J5S	C389442	06-17-02	99.9	99.6	99.9
SCHLUMBERGER	J5S	C389443	06-17-02	100.1	99.6	100.2
SCHLUMBERGER	J5S	C389444	06-17-02	100.0	99.7	100.1
SCHLUMBERGER	J5S	C389445	06-17-02	100.1	99.7	99.6
SCHLUMBERGER	J5S	C389446	06-17-02	100.1	99.9	100.4

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

PAGE 113
 RUN DATE: 1/14/03
 RUN TIME: 13.26.53

MANUFACTURER	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	C389447	06-17-02	99.9	100.2	99.8
SCHLUMBERGER	C389448	06-17-02	99.9	99.7	100.0
SCHLUMBERGER	C389449	06-17-02	100.1	100.2	100.2
SCHLUMBERGER	C389450	06-17-02	99.9	99.8	100.3
SCHLUMBERGER	C389451	06-17-02	100.3	99.6	100.0
SCHLUMBERGER	C389452	06-17-02	100.0	99.7	100.1
SCHLUMBERGER	C389453	06-17-02	100.0	99.9	100.3
SCHLUMBERGER	C389454	06-17-02	99.9	99.9	100.4
SCHLUMBERGER	C389455	06-18-02	99.9	99.9	100.3
SCHLUMBERGER	C389456	06-18-02	99.9	99.9	99.8
SCHLUMBERGER	C389457	06-18-02	99.9	99.9	100.5
SCHLUMBERGER	C389458	06-18-02	99.9	100.0	100.3
SCHLUMBERGER	C389459	06-18-02	100.0	99.9	100.0
SCHLUMBERGER	C389460	06-18-02	99.8	99.8	99.7
SCHLUMBERGER	C389461	06-18-02	99.9	99.9	100.0
SCHLUMBERGER	C389462	06-18-02	100.0	100.0	100.0
SCHLUMBERGER	C389463	06-18-02	100.1	100.2	99.5
SCHLUMBERGER	C389464	06-18-02	100.1	99.7	100.0
SCHLUMBERGER	C389465	06-18-02	100.0	100.0	99.8
SCHLUMBERGER	C389466	06-18-02	100.0	99.9	99.8
SCHLUMBERGER	C389467	06-18-02	99.9	99.9	99.5
SCHLUMBERGER	C389468	06-18-02	100.2	99.8	100.0
SCHLUMBERGER	C389469	06-18-02	100.1	100.3	100.0
SCHLUMBERGER	C389470	06-18-02	100.0	100.0	100.0
SCHLUMBERGER	C389471	06-18-02	100.0	100.2	99.9
SCHLUMBERGER	C389472	06-18-02	100.1	100.0	100.3
SCHLUMBERGER	C389473	06-18-02	99.9	99.6	99.6
SCHLUMBERGER	C389474	06-18-02	100.0	99.8	100.2
SCHLUMBERGER	C389475	06-18-02	100.1	100.1	100.4
SCHLUMBERGER	C389476	06-18-02	100.2	99.8	99.7
SCHLUMBERGER	C389477	06-18-02	99.9	99.8	100.5
SCHLUMBERGER	C389478	06-18-02	100.1	99.9	100.0
SCHLUMBERGER	C389479	06-18-02	99.9	99.7	100.1
SCHLUMBERGER	C389480	06-18-02	100.1	100.2	99.6
SCHLUMBERGER	C389481	06-18-02	99.9	100.0	100.2
SCHLUMBERGER	C389482	06-18-02	100.0	100.2	100.0
SCHLUMBERGER	C389483	06-18-02	100.0	99.8	100.0
SCHLUMBERGER	C389484	06-18-02	100.0	99.7	99.8
SCHLUMBERGER	C389485	06-18-02	100.0	99.7	99.5
SCHLUMBERGER	C389486	06-18-02	100.0	99.6	100.0
SCHLUMBERGER	C389487	06-18-02	100.2	100.0	100.2
SCHLUMBERGER	C389488	06-18-02	99.8	100.0	99.6
SCHLUMBERGER	C389489	06-18-02	100.0	99.9	99.6
SCHLUMBERGER	C389490	06-18-02	99.9	99.9	99.7
SCHLUMBERGER	C389491	06-18-02	100.0	99.7	99.7
SCHLUMBERGER	C389492	06-18-02	100.1	100.2	100.0
SCHLUMBERGER	C389493	06-18-02	100.0	99.8	99.4
SCHLUMBERGER	C389494	06-18-02	100.0	99.9	99.8
SCHLUMBERGER	C389495	06-18-02	100.1	99.9	100.5
SCHLUMBERGER	C389496	06-18-02	100.2	100.3	100.0
SCHLUMBERGER	C389497	06-18-02	100.1	99.7	100.2

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

PAGE 114
 RUN DATE: 1/14/03
 RUN TIME: 13.26.53

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	J55	C389498	06-18-02	100.0	99.7	99.6
SCHLUMBERGER	J55	C389499	06-18-02	100.0	99.6	99.8
SCHLUMBERGER	J55	C389500	06-18-02	100.1	100.2	100.1
SCHLUMBERGER	J55	C389501	06-18-02	99.9	100.0	99.7
SCHLUMBERGER	J55	C389502	06-18-02	99.9	100.1	99.8
SCHLUMBERGER	J55	C389503	06-18-02	100.1	100.1	100.0
SCHLUMBERGER	J55	C389504	06-18-02	99.8	99.6	99.5
SCHLUMBERGER	J55	C389505	06-18-02	100.2	99.8	100.3
SCHLUMBERGER	J55	C389506	06-18-02	99.9	100.2	100.2
SCHLUMBERGER	J55	C389507	06-18-02	99.9	99.8	99.9
SCHLUMBERGER	J55	C389508	06-18-02	100.1	99.7	100.0
SCHLUMBERGER	J55	C389509	06-18-02	100.0	99.8	100.0
SCHLUMBERGER	J55	C389510	06-18-02	99.9	99.8	99.7
SCHLUMBERGER	J55	C389511	06-18-02	100.1	99.7	99.9
SCHLUMBERGER	J55	C389512	06-18-02	100.2	100.2	100.0
SCHLUMBERGER	J55	C389513	06-18-02	99.9	100.0	99.3
SCHLUMBERGER	J55	C389514	06-18-02	100.1	99.8	100.1
SCHLUMBERGER	J55	C389515	06-18-02	100.1	100.1	100.1
SCHLUMBERGER	J55	C389516	06-18-02	100.3	99.8	100.1
SCHLUMBERGER	J55	C389517	06-18-02	99.9	100.0	100.4
SCHLUMBERGER	J55	C389518	06-18-02	99.9	100.2	99.8
SCHLUMBERGER	J55	C389519	06-18-02	100.1	99.6	99.7
SCHLUMBERGER	J55	C389520	06-18-02	99.9	100.1	99.6
SCHLUMBERGER	J55	C389521	06-18-02	100.1	100.1	100.6
SCHLUMBERGER	J55	C389522	06-18-02	99.9	99.9	99.6
SCHLUMBERGER	J55	C389523	06-18-02	99.9	99.7	100.7
SCHLUMBERGER	J55	C389524	06-18-02	100.0	99.7	99.9
SCHLUMBERGER	J55	C389525	06-18-02	100.0	100.2	100.2
SCHLUMBERGER	J55	C389526	06-18-02	100.1	100.0	100.3
SCHLUMBERGER	J55	C389527	06-18-02	100.0	100.2	99.7
SCHLUMBERGER	J55	C389528	06-18-02	100.1	99.6	99.8
SCHLUMBERGER	J55	C389529	06-18-02	99.9	99.6	100.0
SCHLUMBERGER	J55	C389530	06-18-02	99.9	100.0	99.9
SCHLUMBERGER	J55	C389531	06-18-02	100.1	99.7	99.9
SCHLUMBERGER	J55	C389532	06-18-02	100.0	100.0	99.6
SCHLUMBERGER	J55	C389533	06-18-02	100.0	99.7	100.4
SCHLUMBERGER	J55	C389534	06-18-02	100.0	99.7	100.0
SCHLUMBERGER	J55	C389535	06-18-02	100.0	99.7	100.1
SCHLUMBERGER	J55	C389536	06-18-02	100.0	99.8	99.9
SCHLUMBERGER	J55	C389537	06-18-02	99.9	99.9	99.5
SCHLUMBERGER	J55	C389538	06-18-02	99.9	99.6	99.5
SCHLUMBERGER	J55	C389539	06-18-02	100.0	99.8	99.6
SCHLUMBERGER	J55	C389540	06-18-02	100.1	99.8	99.8
SCHLUMBERGER	J55	C389541	06-18-02	100.1	100.0	99.7
SCHLUMBERGER	J55	C389542	06-18-02	100.1	100.3	100.0
SCHLUMBERGER	J55	C389543	06-18-02	100.1	99.7	100.0
SCHLUMBERGER	J55	C389544	06-18-02	99.9	100.3	100.0
SCHLUMBERGER	J55	C389545	06-18-02	100.1	100.0	100.0
SCHLUMBERGER	J55	C389546	06-18-02	100.1	99.8	100.1
SCHLUMBERGER	J55	C389547	06-18-02	99.9	99.7	100.1
SCHLUMBERGER	J55	C389548	06-18-02	99.9	100.0	99.8

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

PAGE 115
 RUN DATE: 1/14/03
 RUN TIME: 13.26.53

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	J5S	C389549	06-18-02	100.2	100.3	100.2
SCHLUMBERGER	J5S	C389550	06-18-02	100.0	99.7	99.9
SCHLUMBERGER	J5S	C389551	06-18-02	100.1	99.8	99.8
SCHLUMBERGER	J5S	C389552	06-18-02	100.0	99.8	100.5
SCHLUMBERGER	J5S	C389553	06-18-02	100.1	99.6	100.0
SCHLUMBERGER	J5S	C389554	06-18-02	99.9	99.8	99.6
SCHLUMBERGER	J5S	C389555	06-18-02	100.1	100.0	99.7
SCHLUMBERGER	J5S	C389556	06-18-02	100.2	99.7	99.9
SCHLUMBERGER	J5S	C389557	06-18-02	99.9	99.7	100.0
SCHLUMBERGER	J5S	C389558	06-18-02	100.1	99.6	99.7
SCHLUMBERGER	J5S	C389559	06-18-02	100.1	99.8	100.4
SCHLUMBERGER	J5S	C389560	06-18-02	100.0	99.9	99.7
SCHLUMBERGER	J5S	C389561	06-18-02	100.1	99.9	100.2
SCHLUMBERGER	J5S	C389562	06-18-02	100.1	99.7	100.2
SCHLUMBERGER	J5S	C389563	06-18-02	100.0	99.7	99.8
SCHLUMBERGER	J5S	C389564	06-18-02	100.1	100.0	100.3
SCHLUMBERGER	J5S	C389565	06-18-02	100.1	99.7	100.0
SCHLUMBERGER	J5S	C389566	06-18-02	100.0	99.8	99.6
SCHLUMBERGER	J5S	C389567	06-18-02	100.1	99.6	100.1
SCHLUMBERGER	J5S	C389568	06-18-02	100.1	100.1	100.1
SCHLUMBERGER	J5S	C389569	06-18-02	100.0	99.9	99.8
SCHLUMBERGER	J5S	C389570	06-18-02	99.9	100.0	99.8
SCHLUMBERGER	J5S	C389571	06-18-02	100.0	99.8	100.2
SCHLUMBERGER	J5S	C389572	06-18-02	99.9	99.8	99.8
SCHLUMBERGER	J5S	C389573	06-18-02	100.0	99.6	99.9
SCHLUMBERGER	J5S	C389574	06-18-02	100.1	99.9	100.1
SCHLUMBERGER	J5S	C389575	06-18-02	100.0	100.1	100.1
SCHLUMBERGER	J5S	C389576	06-18-02	100.0	99.8	99.7
SCHLUMBERGER	J5S	C389577	06-18-02	99.8	99.9	99.5
SCHLUMBERGER	J5S	C389578	06-18-02	100.0	99.7	99.8
SCHLUMBERGER	J5S	C389579	06-18-02	100.0	99.8	99.8
SCHLUMBERGER	J5S	C389580	06-18-02	100.0	99.6	99.9
SCHLUMBERGER	J5S	C389581	06-18-02	99.9	99.7	99.9
SCHLUMBERGER	J5S	C389582	06-18-02	100.0	99.8	100.0
SCHLUMBERGER	J5S	C389583	06-18-02	100.2	99.6	100.2
SCHLUMBERGER	J5S	C389584	06-18-02	100.1	99.7	100.2
SCHLUMBERGER	J5S	C389585	06-18-02	100.0	100.1	99.8
SCHLUMBERGER	J5S	C389586	06-18-02	99.9	99.9	99.8
SCHLUMBERGER	J5S	C389587	06-18-02	100.0	99.7	99.9
SCHLUMBERGER	J5S	C389588	06-18-02	99.9	99.8	99.9
SCHLUMBERGER	J5S	C389589	06-18-02	99.9	99.7	100.7
SCHLUMBERGER	J5S	C389590	06-18-02	100.1	99.7	100.0
SCHLUMBERGER	J5S	C389591	06-18-02	100.2	99.6	100.1
SCHLUMBERGER	J5S	C389592	06-18-02	100.1	99.7	100.0
SCHLUMBERGER	J5S	C389593	06-18-02	100.2	100.1	99.8
SCHLUMBERGER	J5S	C389594	06-18-02	100.2	99.7	100.0
SCHLUMBERGER	J5S	C389595	06-18-02	100.2	100.3	100.6
SCHLUMBERGER	J5S	C389596	06-18-02	100.1	100.0	100.0
SCHLUMBERGER	J5S	C389597	06-18-02	99.9	99.9	99.6
SCHLUMBERGER	J5S	C389598	06-18-02	100.0	99.7	100.1
SCHLUMBERGER	J5S	C389599	06-18-02	100.2	100.1	100.2

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

MANUFACTURER	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	C389600	06-18-02	100.0	99.8	100.1
SCHLUMBERGER	C389601	06-18-02	100.1	99.7	100.0
SCHLUMBERGER	C389602	06-18-02	100.0	99.9	100.1
SCHLUMBERGER	C389603	06-18-02	100.1	99.7	100.1
SCHLUMBERGER	C389604	06-18-02	100.0	100.0	100.2
SCHLUMBERGER	C389605	06-18-02	100.1	100.3	100.1
SCHLUMBERGER	C389606	06-18-02	100.0	99.8	99.9
SCHLUMBERGER	C389607	06-18-02	100.1	100.1	99.7
SCHLUMBERGER	C389608	06-18-02	99.9	100.1	99.6
SCHLUMBERGER	C389609	06-18-02	100.0	99.8	100.0
SCHLUMBERGER	C389610	06-18-02	100.1	99.9	100.2
SCHLUMBERGER	C389611	06-18-02	100.1	99.9	100.2
SCHLUMBERGER	C389612	06-18-02	100.2	100.2	100.4
SCHLUMBERGER	C389613	06-18-02	100.1	99.8	99.7
SCHLUMBERGER	C389614	06-18-02	100.0	99.6	99.4
SCHLUMBERGER	C389615	06-18-02	100.0	100.1	99.7
SCHLUMBERGER	C389616	06-18-02	100.1	100.0	100.1
SCHLUMBERGER	C389617	06-18-02	99.9	99.7	99.5
SCHLUMBERGER	C389618	06-18-02	100.2	99.8	100.3
SCHLUMBERGER	C389619	06-18-02	100.0	99.8	99.5
SCHLUMBERGER	C389620	06-18-02	99.9	100.1	99.8
SCHLUMBERGER	C389621	06-18-02	100.1	100.0	99.9
SCHLUMBERGER	C389622	06-18-02	100.1	99.6	100.1
SCHLUMBERGER	C389623	06-18-02	100.3	99.8	100.1
SCHLUMBERGER	C389624	06-18-02	99.8	100.0	99.8
SCHLUMBERGER	C389625	06-18-02	100.1	100.1	100.3
SCHLUMBERGER	C389626	06-18-02	100.0	99.8	100.0
SCHLUMBERGER	C389627	06-18-02	100.0	99.8	99.7
SCHLUMBERGER	C389628	06-18-02	99.9	100.2	99.7
SCHLUMBERGER	C389629	06-18-02	100.1	100.0	99.7
SCHLUMBERGER	C389630	06-18-02	100.1	99.9	99.8
SCHLUMBERGER	C389631	06-18-02	100.0	100.4	99.7
SCHLUMBERGER	C389632	06-18-02	99.9	99.8	99.7
SCHLUMBERGER	C389633	06-18-02	100.0	99.8	100.1
SCHLUMBERGER	C389634	06-18-02	100.1	99.9	99.9
SCHLUMBERGER	C389635	06-18-02	100.0	99.8	99.8
SCHLUMBERGER	C389636	06-18-02	99.9	99.7	100.0
SCHLUMBERGER	C389637	06-18-02	100.1	99.7	99.8
SCHLUMBERGER	C389638	06-18-02	100.0	99.9	99.6
SCHLUMBERGER	C389639	06-18-02	100.1	100.1	100.0
SCHLUMBERGER	C389640	06-18-02	100.0	99.7	100.0
SCHLUMBERGER	C389641	06-18-02	100.0	99.8	100.1
SCHLUMBERGER	C389642	06-18-02	100.1	99.7	99.5
SCHLUMBERGER	C389643	06-18-02	100.0	99.9	100.0
SCHLUMBERGER	C389644	06-18-02	100.0	99.7	99.6
SCHLUMBERGER	C389645	06-18-02	99.9	100.0	99.4
SCHLUMBERGER	C389646	06-18-02	100.0	100.4	99.9
SCHLUMBERGER	C389647	06-18-02	99.9	99.9	99.7
SCHLUMBERGER	C389648	06-26-02	100.0	100.0	100.1
SCHLUMBERGER	C389649	06-26-02	100.0	99.8	99.9
SCHLUMBERGER	C389650	06-26-02	100.1	99.9	100.0

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	J55	C389651	06-26-02	100.0	99.8	100.3
SCHLUMBERGER	J55	C389652	06-26-02	100.0	100.0	100.2
SCHLUMBERGER	J55	C389653	06-26-02	100.0	100.0	100.0
SCHLUMBERGER	J55	C389654	06-26-02	100.0	100.0	99.4
SCHLUMBERGER	J55	C389655	06-26-02	100.2	100.0	100.1
SCHLUMBERGER	J55	C389656	06-26-02	100.0	99.7	100.0
SCHLUMBERGER	J55	C389657	06-26-02	100.1	100.1	100.3
SCHLUMBERGER	J55	C389658	06-26-02	100.0	100.3	99.7
SCHLUMBERGER	J55	C389659	06-26-02	100.0	99.6	99.8
SCHLUMBERGER	J55	C389660	06-26-02	100.0	99.8	99.6
SCHLUMBERGER	J55	C389661	06-26-02	100.1	99.6	100.1
SCHLUMBERGER	J55	C389662	06-26-02	100.1	100.1	99.4
SCHLUMBERGER	J55	C389663	06-26-02	100.1	99.8	100.5
SCHLUMBERGER	J55	C389664	06-26-02	100.0	100.0	99.7
SCHLUMBERGER	J55	C389665	06-26-02	100.1	100.2	99.7
SCHLUMBERGER	J55	C389666	06-26-02	100.2	99.7	100.0
SCHLUMBERGER	J55	C389667	06-26-02	100.0	99.9	99.9
SCHLUMBERGER	J55	C389668	06-26-02	100.0	99.7	100.2
SCHLUMBERGER	J55	C389669	06-26-02	99.8	99.8	100.0
SCHLUMBERGER	J55	C389670	06-26-02	99.9	99.8	99.8
SCHLUMBERGER	J55	C389671	06-26-02	100.1	99.9	100.2
SCHLUMBERGER	J55	C389672	06-26-02	100.1	100.2	100.2
SCHLUMBERGER	J55	C389673	06-26-02	100.1	99.6	99.8
SCHLUMBERGER	J55	C389674	06-26-02	100.1	100.0	99.5
SCHLUMBERGER	J55	C389675	06-26-02	100.0	99.8	100.0
SCHLUMBERGER	J55	C389676	06-26-02	100.0	99.8	99.8
SCHLUMBERGER	J55	C389677	06-26-02	99.8	99.8	100.0
SCHLUMBERGER	J55	C389678	06-26-02	100.1	100.3	100.0
SCHLUMBERGER	J55	C389679	06-26-02	100.2	100.0	100.0
SCHLUMBERGER	J55	C389680	06-26-02	99.9	100.0	100.2
SCHLUMBERGER	J55	C389681	06-26-02	100.1	100.0	100.3
SCHLUMBERGER	J55	C389682	06-26-02	100.2	99.9	99.9
SCHLUMBERGER	J55	C389683	06-26-02	99.9	100.0	99.9
SCHLUMBERGER	J55	C389684	06-26-02	100.0	100.1	100.2
SCHLUMBERGER	J55	C389685	06-26-02	100.0	99.7	100.0
SCHLUMBERGER	J55	C389686	06-26-02	100.1	99.7	100.0
SCHLUMBERGER	J55	C389687	06-26-02	99.9	99.7	99.9
SCHLUMBERGER	J55	C389688	06-26-02	100.0	99.8	100.1
SCHLUMBERGER	J55	C389689	06-26-02	99.9	99.8	100.2
SCHLUMBERGER	J55	C389690	06-26-02	100.1	99.9	100.0
SCHLUMBERGER	J55	C389691	06-26-02	99.9	99.7	100.0
SCHLUMBERGER	J55	C389692	06-26-02	100.1	99.6	99.8
SCHLUMBERGER	J55	C389693	06-26-02	100.2	100.0	100.3
SCHLUMBERGER	J55	C389694	06-26-02	100.0	99.8	99.8
SCHLUMBERGER	J55	C389695	06-26-02	100.0	99.9	99.8
SCHLUMBERGER	J55	C389696	06-26-02	100.1	99.6	99.8
SCHLUMBERGER	J55	C389697	06-26-02	100.1	100.3	99.3
SCHLUMBERGER	J55	C389698	06-26-02	99.9	99.7	99.8
SCHLUMBERGER	J55	C389699	06-26-02	100.1	100.2	100.5
SCHLUMBERGER	J55	C389700	06-26-02	100.1	99.8	100.0
SCHLUMBERGER	J55	C389701	06-26-02	100.0	99.8	100.2

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	J55	C389702	06-26-02	99.9	100.2	100.3
SCHLUMBERGER	J55	C389703	06-26-02	100.0	99.6	100.1
SCHLUMBERGER	J55	C389704	06-26-02	100.1	100.0	100.1
SCHLUMBERGER	J55	C389705	06-26-02	100.0	99.7	99.6
SCHLUMBERGER	J55	C389706	06-26-02	100.3	99.7	100.2
SCHLUMBERGER	J55	C389707	06-26-02	100.2	100.1	100.4
SCHLUMBERGER	J55	C389708	06-26-02	100.2	99.7	99.8
SCHLUMBERGER	J55	C389709	06-26-02	100.0	99.7	100.0
SCHLUMBERGER	J55	C389710	06-26-02	100.1	100.4	100.3
SCHLUMBERGER	J55	C389711	06-26-02	100.0	100.1	99.7
SCHLUMBERGER	J55	C389712	06-26-02	100.0	100.3	100.1
SCHLUMBERGER	J55	C389713	06-26-02	100.1	100.1	100.5
SCHLUMBERGER	J55	C389714	06-26-02	100.1	100.1	100.0
SCHLUMBERGER	J55	C389715	06-26-02	100.0	100.3	100.7
SCHLUMBERGER	J55	C389716	06-26-02	100.1	99.7	100.0
SCHLUMBERGER	J55	C389717	06-26-02	99.8	99.8	99.5
SCHLUMBERGER	J55	C389718	06-26-02	100.1	99.8	100.1
SCHLUMBERGER	J55	C389719	06-26-02	100.1	100.3	100.1
SCHLUMBERGER	J55	C389720	06-26-02	100.1	99.8	99.8
SCHLUMBERGER	J55	C389721	06-26-02	100.1	100.1	100.6
SCHLUMBERGER	J55	C389722	06-26-02	100.2	100.1	99.9
SCHLUMBERGER	J55	C389723	06-26-02	100.1	99.9	100.5
SCHLUMBERGER	J55	C389724	06-26-02	100.1	99.7	100.3
SCHLUMBERGER	J55	C389725	06-26-02	100.1	99.9	99.9
SCHLUMBERGER	J55	C389726	06-26-02	100.0	99.8	100.2
SCHLUMBERGER	J55	C389727	06-26-02	100.0	100.1	100.3
SCHLUMBERGER	J55	C389728	06-26-02	100.0	99.9	99.8
SCHLUMBERGER	J55	C389729	06-26-02	100.0	100.0	100.1
SCHLUMBERGER	J55	C389730	06-26-02	100.0	99.7	99.6
SCHLUMBERGER	J55	C389731	06-26-02	100.1	99.9	100.1
SCHLUMBERGER	J55	C389732	06-26-02	100.0	99.8	99.9
SCHLUMBERGER	J55	C389733	06-26-02	100.3	99.8	100.0
SCHLUMBERGER	J55	C389734	06-26-02	100.1	100.2	99.8
SCHLUMBERGER	J55	C389735	06-26-02	100.1	100.1	99.7
SCHLUMBERGER	J55	C389736	06-26-02	100.0	99.8	100.0
SCHLUMBERGER	J55	C389737	06-26-02	100.0	99.9	99.7
SCHLUMBERGER	J55	C389738	06-26-02	100.0	100.0	100.2
SCHLUMBERGER	J55	C389739	06-26-02	100.1	99.7	99.5
SCHLUMBERGER	J55	C389740	06-26-02	100.1	99.8	99.4
SCHLUMBERGER	J55	C389741	06-26-02	100.0	100.4	99.8
SCHLUMBERGER	J55	C389742	06-26-02	100.2	99.6	100.0
SCHLUMBERGER	J55	C389743	06-26-02	100.0	99.8	99.8
SCHLUMBERGER	J55	C389744	06-26-02	100.0	100.3	100.0
SCHLUMBERGER	J55	C389745	06-26-02	99.9	100.1	99.5
SCHLUMBERGER	J55	C389746	06-26-02	100.2	100.3	100.3
SCHLUMBERGER	J55	C389747	06-26-02	100.0	99.8	100.2
SCHLUMBERGER	J55	C389748	06-26-02	100.2	99.9	100.3
SCHLUMBERGER	J55	C389749	06-26-02	100.0	99.8	99.5
SCHLUMBERGER	J55	C389750	06-26-02	100.1	100.1	100.0
SCHLUMBERGER	J55	C389751	06-26-02	100.1	100.1	99.2
SCHLUMBERGER	J55	C389752	06-26-02	99.9	100.0	99.9

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

PAGE 119
 RUN DATE: 1/14/03
 RUN TIME: 13.26.53

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	J55	C389753	06-26-02	100.0	99.7	99.9
SCHLUMBERGER	J55	C389754	06-26-02	100.2	100.1	99.9
SCHLUMBERGER	J55	C389755	06-26-02	100.1	100.3	100.0
SCHLUMBERGER	J55	C389756	06-26-02	100.2	100.2	99.8
SCHLUMBERGER	J55	C389757	06-26-02	100.0	100.2	100.0
SCHLUMBERGER	J55	C389758	06-26-02	100.1	100.1	99.7
SCHLUMBERGER	J55	C389759	06-26-02	100.1	100.1	99.7
SCHLUMBERGER	J55	C389760	06-26-02	100.2	99.6	100.2
SCHLUMBERGER	J55	C389761	06-26-02	99.9	99.7	99.6
SCHLUMBERGER	J55	C389762	06-26-02	100.2	99.7	100.0
SCHLUMBERGER	J55	C389763	06-26-02	100.1	99.7	100.1
SCHLUMBERGER	J55	C389764	06-26-02	100.0	100.0	99.9
SCHLUMBERGER	J55	C389765	06-26-02	100.1	99.9	99.8
SCHLUMBERGER	J55	C389766	06-26-02	100.0	100.2	99.9
SCHLUMBERGER	J55	C389767	06-26-02	100.0	99.9	100.0
SCHLUMBERGER	J55	C389768	06-26-02	99.9	99.6	99.7
SCHLUMBERGER	J55	C389769	06-26-02	100.0	99.8	99.4
SCHLUMBERGER	J55	C389770	06-26-02	100.1	99.7	100.0
SCHLUMBERGER	J55	C389771	06-26-02	99.9	99.9	99.8
SCHLUMBERGER	J55	C389772	06-26-02	100.2	99.9	100.3
SCHLUMBERGER	J55	C389773	06-26-02	100.1	99.7	99.9
SCHLUMBERGER	J55	C389774	06-26-02	100.1	99.7	99.7
SCHLUMBERGER	J55	C389775	06-26-02	100.2	99.9	99.3
SCHLUMBERGER	J55	C389776	06-26-02	100.1	100.0	100.0
SCHLUMBERGER	J55	C389777	06-26-02	99.8	99.6	99.6
SCHLUMBERGER	J55	C389778	06-26-02	100.1	100.0	99.5
SCHLUMBERGER	J55	C389779	06-26-02	100.1	99.7	99.7
SCHLUMBERGER	J55	C389780	06-26-02	100.0	99.8	100.1
SCHLUMBERGER	J55	C389781	06-26-02	100.1	100.1	100.0
SCHLUMBERGER	J55	C389782	06-26-02	100.1	99.9	100.0
SCHLUMBERGER	J55	C389783	06-26-02	100.1	100.0	100.3
SCHLUMBERGER	J55	C389784	06-26-02	100.0	99.8	99.8
SCHLUMBERGER	J55	C389785	06-26-02	99.9	99.7	100.0
SCHLUMBERGER	J55	C389786	06-26-02	100.2	100.1	99.9
SCHLUMBERGER	J55	C389787	06-26-02	100.1	99.9	100.2
SCHLUMBERGER	J55	C389788	06-26-02	100.1	100.4	100.1
SCHLUMBERGER	J55	C389789	06-26-02	100.1	99.8	99.8
SCHLUMBERGER	J55	C389790	06-26-02	100.2	100.2	100.4
SCHLUMBERGER	J55	C389791	06-26-02	100.2	99.8	100.0
SCHLUMBERGER	J55	C389792	06-26-02	99.8	99.7	100.0
SCHLUMBERGER	J55	C389793	06-26-02	100.1	99.7	100.0
SCHLUMBERGER	J55	C389794	06-26-02	100.1	99.8	100.4
SCHLUMBERGER	J55	C389795	06-26-02	100.1	99.8	100.1
SCHLUMBERGER	J55	C389796	06-26-02	100.1	100.0	99.9
SCHLUMBERGER	J55	C389797	06-26-02	100.0	99.9	99.9
SCHLUMBERGER	J55	C389798	06-26-02	100.0	99.8	100.0
SCHLUMBERGER	J55	C389799	06-26-02	100.1	99.8	100.1
SCHLUMBERGER	J55	C389800	06-26-02	100.0	99.9	99.7
SCHLUMBERGER	J55	C389801	06-26-02	100.1	99.6	100.3
SCHLUMBERGER	J55	C389802	06-26-02	100.1	99.8	100.1
SCHLUMBERGER	J55	C389803	06-26-02	100.1	99.8	100.1

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

PAGE 120
 RUN DATE: 1/14/03
 RUN TIME: 13.26.53

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	J5S	C389804	06-26-02	100.2	99.8	99.7
SCHLUMBERGER	J5S	C389805	06-26-02	100.2	100.0	100.1
SCHLUMBERGER	J5S	C389806	06-26-02	100.1	99.9	99.8
SCHLUMBERGER	J5S	C389807	06-26-02	100.0	100.0	99.9
SCHLUMBERGER	J5S	C389808	06-25-02	100.1	99.7	100.2
SCHLUMBERGER	J5S	C389809	06-25-02	100.1	99.8	99.9
SCHLUMBERGER	J5S	C389810	06-25-02	100.1	99.6	100.2
SCHLUMBERGER	J5S	C389811	06-25-02	100.1	99.9	100.4
SCHLUMBERGER	J5S	C389812	06-25-02	100.2	99.7	100.2
SCHLUMBERGER	J5S	C389813	06-25-02	100.0	99.7	100.1
SCHLUMBERGER	J5S	C389814	06-25-02	100.1	99.9	99.8
SCHLUMBERGER	J5S	C389815	06-25-02	100.1	99.6	99.4
SCHLUMBERGER	J5S	C389816	06-25-02	100.0	99.9	99.9
SCHLUMBERGER	J5S	C389817	06-25-02	100.2	99.7	100.2
SCHLUMBERGER	J5S	C389818	06-25-02	100.1	100.0	100.0
SCHLUMBERGER	J5S	C389819	06-25-02	100.3	99.6	100.0
SCHLUMBERGER	J5S	C389820	06-25-02	100.1	99.9	99.6
SCHLUMBERGER	J5S	C389821	06-25-02	100.0	99.7	99.5
SCHLUMBERGER	J5S	C389822	06-25-02	100.1	99.8	99.7
SCHLUMBERGER	J5S	C389823	06-25-02	100.0	99.7	99.5
SCHLUMBERGER	J5S	C389824	06-25-02	100.2	99.9	99.9
SCHLUMBERGER	J5S	C389825	06-25-02	100.1	100.1	99.9
SCHLUMBERGER	J5S	C389826	06-25-02	100.1	100.0	100.1
SCHLUMBERGER	J5S	C389827	06-25-02	100.0	99.7	99.9
SCHLUMBERGER	J5S	C389828	06-25-02	100.2	99.9	100.0
SCHLUMBERGER	J5S	C389829	06-25-02	100.0	99.7	100.1
SCHLUMBERGER	J5S	C389830	06-25-02	100.1	99.7	99.9
SCHLUMBERGER	J5S	C389831	06-25-02	100.2	99.7	100.3
SCHLUMBERGER	J5S	C389832	06-25-02	100.0	99.8	100.1
SCHLUMBERGER	J5S	C389833	06-25-02	99.9	99.9	99.7
SCHLUMBERGER	J5S	C389834	06-25-02	99.9	100.1	99.5
SCHLUMBERGER	J5S	C389835	06-25-02	100.1	99.9	100.1
SCHLUMBERGER	J5S	C389836	06-25-02	100.3	99.6	100.0
SCHLUMBERGER	J5S	C389837	06-25-02	100.1	99.7	99.9
SCHLUMBERGER	J5S	C389838	06-25-02	100.2	100.0	100.0
SCHLUMBERGER	J5S	C389839	06-25-02	100.1	99.8	99.7
SCHLUMBERGER	J5S	C389840	06-25-02	100.2	99.6	100.2
SCHLUMBERGER	J5S	C389841	06-25-02	100.0	99.9	99.6
SCHLUMBERGER	J5S	C389842	06-25-02	100.1	99.8	99.7
SCHLUMBERGER	J5S	C389843	06-25-02	100.0	99.9	100.2
SCHLUMBERGER	J5S	C389844	06-25-02	100.1	99.9	99.9
SCHLUMBERGER	J5S	C389845	06-25-02	99.8	99.9	99.3
SCHLUMBERGER	J5S	C389846	06-25-02	100.1	99.8	99.6
SCHLUMBERGER	J5S	C389847	06-25-02	100.1	99.8	99.8
SCHLUMBERGER	J5S	C389848	06-25-02	100.1	99.7	99.8
SCHLUMBERGER	J5S	C389849	06-25-02	99.9	99.7	100.0
SCHLUMBERGER	J5S	C389850	06-25-02	100.0	99.8	100.0
SCHLUMBERGER	J5S	C389851	06-25-02	100.0	99.8	100.1
SCHLUMBERGER	J5S	C389852	06-25-02	100.3	99.7	99.7
SCHLUMBERGER	J5S	C389853	06-25-02	100.1	99.8	100.3
SCHLUMBERGER	J5S	C389854	06-25-02	100.0	99.7	100.2

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

PAGE 121
 RUN DATE: 1/14/03
 RUN TIME: 13.26.53

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	J55	C389855	06-25-02	100.2	100.0	100.0
SCHLUMBERGER	J55	C389856	06-25-02	99.9	99.7	100.0
SCHLUMBERGER	J55	C389857	06-25-02	100.2	99.6	99.7
SCHLUMBERGER	J55	C389858	06-25-02	100.0	100.2	100.1
SCHLUMBERGER	J55	C389859	06-25-02	100.3	99.7	100.1
SCHLUMBERGER	J55	C389860	06-25-02	100.0	99.7	99.9
SCHLUMBERGER	J55	C389861	06-25-02	100.1	99.7	100.1
SCHLUMBERGER	J55	C389862	06-25-02	100.1	99.9	100.3
SCHLUMBERGER	J55	C389863	06-25-02	100.2	99.7	99.6
SCHLUMBERGER	J55	C389864	06-25-02	100.1	99.8	100.0
SCHLUMBERGER	J55	C389865	06-25-02	100.0	99.6	99.9
SCHLUMBERGER	J55	C389866	06-25-02	100.1	99.7	100.0
SCHLUMBERGER	J55	C389867	06-25-02	100.1	99.9	99.9
SCHLUMBERGER	J55	C389868	06-25-02	100.0	100.0	100.0
SCHLUMBERGER	J55	C389869	06-25-02	100.0	100.1	99.9
SCHLUMBERGER	J55	C389870	06-25-02	100.1	100.1	99.9
SCHLUMBERGER	J55	C389871	06-25-02	100.0	99.8	100.2
SCHLUMBERGER	J55	C389872	06-25-02	100.0	99.9	100.2
SCHLUMBERGER	J55	C389873	06-25-02	100.1	99.8	100.2
SCHLUMBERGER	J55	C389874	06-25-02	100.1	99.8	100.2
SCHLUMBERGER	J55	C389875	06-25-02	100.2	99.9	99.6
SCHLUMBERGER	J55	C389876	06-25-02	100.1	99.8	99.9
SCHLUMBERGER	J55	C389877	06-25-02	99.9	100.1	99.8
SCHLUMBERGER	J55	C389878	06-25-02	100.0	100.1	100.1
SCHLUMBERGER	J55	C389879	06-25-02	100.1	100.0	100.2
SCHLUMBERGER	J55	C389880	06-25-02	100.2	100.0	99.7
SCHLUMBERGER	J55	C389881	06-25-02	100.0	100.1	99.7
SCHLUMBERGER	J55	C389882	06-25-02	100.3	99.9	100.2
SCHLUMBERGER	J55	C389883	06-25-02	99.9	99.7	99.5
SCHLUMBERGER	J55	C389884	06-25-02	100.1	99.6	100.2
SCHLUMBERGER	J55	C389885	06-25-02	99.9	99.8	99.6
SCHLUMBERGER	J55	C389886	06-25-02	100.2	100.2	100.0
SCHLUMBERGER	J55	C389887	06-25-02	100.1	99.9	99.8
SCHLUMBERGER	J55	C389888	06-25-02	100.1	99.9	99.6
SCHLUMBERGER	J55	C389889	06-25-02	100.0	99.8	99.8
SCHLUMBERGER	J55	C389890	06-25-02	100.0	99.7	99.7
SCHLUMBERGER	J55	C389891	06-25-02	100.0	99.7	99.7
SCHLUMBERGER	J55	C389892	06-25-02	100.0	100.0	100.0
SCHLUMBERGER	J55	C389893	06-25-02	100.2	100.0	99.7
SCHLUMBERGER	J55	C389894	06-25-02	100.2	100.0	100.0
SCHLUMBERGER	J55	C389895	06-25-02	100.1	99.7	100.5
SCHLUMBERGER	J55	C389896	06-25-02	100.2	100.2	99.9
SCHLUMBERGER	J55	C389897	06-25-02	99.9	99.7	99.6
SCHLUMBERGER	J55	C389898	06-25-02	100.2	100.3	99.7
SCHLUMBERGER	J55	C389899	06-25-02	100.1	99.8	100.2
SCHLUMBERGER	J55	C389900	06-25-02	100.0	99.8	99.6
SCHLUMBERGER	J55	C389901	06-25-02	100.1	99.6	99.8
SCHLUMBERGER	J55	C389902	06-25-02	100.0	99.7	99.6
SCHLUMBERGER	J55	C389903	06-25-02	100.1	100.1	100.0
SCHLUMBERGER	J55	C389904	06-25-02	99.8	99.8	99.6
SCHLUMBERGER	J55	C389905	06-25-02	100.1	99.7	99.9

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

PAGE 122
 RUN DATE: 1/14/03
 RUN TIME: 13.26.53

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PF FACTOR
SCHLUMBERGER	J55	C389906	06-25-02	100.0	99.7	99.9
SCHLUMBERGER	J55	C389907	06-25-02	100.0	100.0	99.6
SCHLUMBERGER	J55	C389908	06-25-02	100.2	100.0	100.2
SCHLUMBERGER	J55	C389909	06-25-02	100.1	99.8	100.2
SCHLUMBERGER	J55	C389910	06-25-02	100.0	99.7	99.6
SCHLUMBERGER	J55	C389911	06-25-02	100.1	99.7	100.1
SCHLUMBERGER	J55	C389912	06-25-02	100.0	100.0	100.3
SCHLUMBERGER	J55	C389913	06-25-02	100.3	100.0	99.6
SCHLUMBERGER	J55	C389914	06-25-02	100.2	99.8	100.3
SCHLUMBERGER	J55	C389915	06-25-02	100.1	99.7	99.6
SCHLUMBERGER	J55	C389916	06-25-02	100.3	100.1	100.4
SCHLUMBERGER	J55	C389917	06-25-02	99.9	99.9	100.0
SCHLUMBERGER	J55	C389918	06-25-02	99.8	99.7	99.7
SCHLUMBERGER	J55	C389919	06-25-02	100.2	99.9	100.0
SCHLUMBERGER	J55	C389920	06-25-02	100.1	99.9	100.0
SCHLUMBERGER	J55	C389921	06-25-02	99.9	99.7	99.8
SCHLUMBERGER	J55	C389922	06-25-02	100.1	99.8	99.8
SCHLUMBERGER	J55	C389923	06-25-02	100.2	100.0	100.1
SCHLUMBERGER	J55	C389924	06-25-02	100.3	99.8	100.3
SCHLUMBERGER	J55	C389925	06-25-02	100.3	99.7	99.9
SCHLUMBERGER	J55	C389926	06-25-02	100.1	99.8	100.0
SCHLUMBERGER	J55	C389927	06-25-02	100.1	99.6	99.8
SCHLUMBERGER	J55	C389928	06-25-02	100.2	99.7	100.3
SCHLUMBERGER	J55	C389929	06-25-02	99.9	99.8	99.4
SCHLUMBERGER	J55	C389930	06-25-02	100.0	99.9	99.6
SCHLUMBERGER	J55	C389931	06-25-02	100.1	99.9	100.3
SCHLUMBERGER	J55	C389932	06-25-02	100.0	99.9	99.6
SCHLUMBERGER	J55	C389933	06-25-02	100.0	99.7	99.6
SCHLUMBERGER	J55	C389934	06-25-02	100.1	100.1	100.1
SCHLUMBERGER	J55	C389935	06-25-02	99.9	99.8	100.1
SCHLUMBERGER	J55	C389936	06-25-02	100.0	99.9	100.1
SCHLUMBERGER	J55	C389937	06-25-02	100.1	99.9	99.9
SCHLUMBERGER	J55	C389938	06-25-02	100.0	99.7	99.8
SCHLUMBERGER	J55	C389939	06-25-02	100.2	100.2	100.3
SCHLUMBERGER	J55	C389940	06-25-02	100.1	99.7	99.9
SCHLUMBERGER	J55	C389941	06-25-02	100.3	99.9	99.7
SCHLUMBERGER	J55	C389942	06-25-02	100.0	99.6	99.6
SCHLUMBERGER	J55	C389943	06-25-02	100.1	99.7	100.1
SCHLUMBERGER	J55	C389944	06-25-02	100.0	100.0	100.0
SCHLUMBERGER	J55	C389945	06-25-02	100.0	99.9	100.1
SCHLUMBERGER	J55	C389946	06-25-02	100.1	99.8	99.8
SCHLUMBERGER	J55	C389947	06-25-02	100.2	99.9	99.9
SCHLUMBERGER	J55	C389948	06-25-02	100.1	99.8	100.1
SCHLUMBERGER	J55	C389949	06-25-02	100.0	99.9	99.9
SCHLUMBERGER	J55	C389950	06-25-02	100.0	100.4	100.0
SCHLUMBERGER	J55	C389951	06-25-02	100.0	99.6	99.6
SCHLUMBERGER	J55	C389952	06-25-02	100.0	100.4	100.4
SCHLUMBERGER	J55	C389953	06-25-02	100.0	99.7	99.7
SCHLUMBERGER	J55	C389954	06-25-02	100.0	99.8	100.0
SCHLUMBERGER	J55	C389955	06-25-02	100.1	99.8	100.1
SCHLUMBERGER	J55	C389956	06-25-02	100.0	100.1	99.8

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

PAGE 123
 RUN DATE: 1/14/03
 RUN TIME: 13.26.53

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	J55	C389957	06-25-02	99.9	100.0	100.0
SCHLUMBERGER	J55	C389958	06-25-02	100.1	100.4	99.7
SCHLUMBERGER	J55	C389959	06-25-02	99.9	99.6	99.9
SCHLUMBERGER	J55	C389960	06-25-02	100.0	99.9	99.9
SCHLUMBERGER	J55	C389961	06-25-02	100.0	99.7	99.8
SCHLUMBERGER	J55	C389962	06-25-02	100.1	100.3	99.8
SCHLUMBERGER	J55	C389963	06-25-02	100.1	99.7	100.0
SCHLUMBERGER	J55	C389964	06-25-02	100.1	99.8	99.7
SCHLUMBERGER	J55	C389965	06-25-02	100.1	99.8	99.7
SCHLUMBERGER	J55	C389966	06-25-02	100.1	100.1	100.3
SCHLUMBERGER	J55	C389967	06-25-02	100.1	99.8	99.9
SCHLUMBERGER	J55	C389968	06-25-02	100.2	100.4	100.5
SCHLUMBERGER	J55	C389969	06-25-02	100.0	100.0	99.8
SCHLUMBERGER	J55	C389970	06-25-02	100.0	99.9	100.1
SCHLUMBERGER	J55	C389971	06-25-02	100.0	99.7	99.8
SCHLUMBERGER	J55	C389972	06-25-02	100.1	100.0	99.6
SCHLUMBERGER	J55	C389973	06-25-02	100.1	99.8	99.7
SCHLUMBERGER	J55	C389974	06-25-02	99.8	99.6	99.4
SCHLUMBERGER	J55	C389975	06-25-02	100.1	100.2	100.1
SCHLUMBERGER	J55	C389976	06-25-02	100.0	99.6	100.1
SCHLUMBERGER	J55	C389977	06-25-02	100.1	99.6	99.9
SCHLUMBERGER	J55	C389978	06-25-02	100.0	99.6	100.1
SCHLUMBERGER	J55	C389979	06-25-02	100.1	100.1	99.8
SCHLUMBERGER	J55	C389980	06-25-02	100.1	100.2	100.2
SCHLUMBERGER	J55	C389981	06-25-02	100.0	99.7	99.9
SCHLUMBERGER	J55	C389982	06-25-02	100.0	99.7	99.9
SCHLUMBERGER	J55	C389983	06-25-02	100.0	99.8	99.9
SCHLUMBERGER	J55	C389984	06-25-02	100.1	99.6	100.4
SCHLUMBERGER	J55	C389985	06-25-02	100.0	100.1	100.4
SCHLUMBERGER	J55	C389986	06-25-02	100.0	99.7	99.6
SCHLUMBERGER	J55	C389987	06-25-02	100.0	99.7	99.8
SCHLUMBERGER	J55	C389988	06-25-02	99.9	100.2	99.8
SCHLUMBERGER	J55	C389989	06-25-02	100.0	99.7	99.9
SCHLUMBERGER	J55	C389990	06-25-02	100.1	99.9	100.0
SCHLUMBERGER	J55	C389991	06-25-02	100.0	99.8	100.0
SCHLUMBERGER	J55	C389992	06-25-02	100.2	99.8	100.1
SCHLUMBERGER	J55	C389993	06-25-02	100.0	99.7	99.7
SCHLUMBERGER	J55	C389994	06-25-02	100.0	99.8	99.8
SCHLUMBERGER	J55	C389995	06-25-02	99.9	100.2	99.9
SCHLUMBERGER	J55	C389996	06-25-02	100.1	99.7	99.3
SCHLUMBERGER	J55	C389997	06-25-02	100.0	99.8	99.7
SCHLUMBERGER	J55	C389998	06-25-02	100.2	99.8	100.2
SCHLUMBERGER	J55	C389999	06-25-02	100.2	99.9	99.8
SCHLUMBERGER	J55	C390000	06-25-02	100.0	99.7	100.0
SCHLUMBERGER	J55	C390001	06-25-02	100.1	99.9	99.9
SCHLUMBERGER	J55	C390002	06-25-02	99.9	99.6	99.7
SCHLUMBERGER	J55	C390003	06-25-02	100.0	99.8	100.1
SCHLUMBERGER	J55	C390004	06-25-02	99.9	99.8	99.8
SCHLUMBERGER	J55	C390005	06-25-02	100.0	99.7	99.8
SCHLUMBERGER	J55	C390006	06-25-02	100.2	100.0	99.8
SCHLUMBERGER	J55	C390007	06-25-02	100.1	99.8	99.9

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

PAGE 124
 RUN DATE: 1/14/03
 RUN TIME: 13.26.53

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	J5S	C390008	06-25-02	100.0	99.8	99.8
SCHLUMBERGER	J5S	C390009	06-25-02	100.0	99.8	99.7
SCHLUMBERGER	J5S	C390010	06-25-02	100.1	100.4	99.9
SCHLUMBERGER	J5S	C390011	06-25-02	100.1	100.1	100.3
SCHLUMBERGER	J5S	C390012	06-25-02	100.1	100.0	99.9
SCHLUMBERGER	J5S	C390013	06-25-02	100.1	99.8	99.9
SCHLUMBERGER	J5S	C390014	06-25-02	100.0	100.1	99.8
SCHLUMBERGER	J5S	C390015	06-25-02	100.0	99.9	100.4
SCHLUMBERGER	J5S	C390016	06-25-02	100.1	99.7	99.7
SCHLUMBERGER	J5S	C390017	06-25-02	100.2	99.9	100.4
SCHLUMBERGER	J5S	C390018	06-25-02	100.0	99.8	100.0
SCHLUMBERGER	J5S	C390019	06-25-02	100.0	99.8	99.8
SCHLUMBERGER	J5S	C390020	06-25-02	99.9	99.8	99.7
SCHLUMBERGER	J5S	C390021	06-25-02	100.0	99.8	100.1
SCHLUMBERGER	J5S	C390022	06-25-02	99.9	99.9	100.1
SCHLUMBERGER	J5S	C390023	06-25-02	100.1	99.7	99.7
SCHLUMBERGER	J5S	C390024	06-25-02	99.9	99.9	100.1
SCHLUMBERGER	J5S	C390025	06-25-02	99.9	99.9	99.9
SCHLUMBERGER	J5S	C390026	06-25-02	99.8	100.5	99.7
SCHLUMBERGER	J5S	C390027	06-25-02	100.1	100.0	99.6
SCHLUMBERGER	J5S	C390028	06-25-02	100.1	99.7	99.9
SCHLUMBERGER	J5S	C390029	06-25-02	100.0	99.6	100.2
SCHLUMBERGER	J5S	C390030	06-25-02	100.1	99.7	100.1
SCHLUMBERGER	J5S	C390031	06-25-02	100.3	99.7	100.2
SCHLUMBERGER	J5S	C390032	06-25-02	100.1	99.9	100.1
SCHLUMBERGER	J5S	C390033	06-25-02	100.0	99.7	100.1
SCHLUMBERGER	J5S	C390034	06-25-02	99.9	99.6	99.9
SCHLUMBERGER	J5S	C390035	06-25-02	100.1	99.7	99.5
SCHLUMBERGER	J5S	C390036	06-25-02	99.9	99.7	100.1
SCHLUMBERGER	J5S	C390037	06-25-02	100.0	99.6	99.8
SCHLUMBERGER	J5S	C390038	06-25-02	100.2	99.9	99.9
SCHLUMBERGER	J5S	C390039	06-25-02	99.9	99.7	99.6
SCHLUMBERGER	J5S	C390040	06-25-02	99.9	99.8	99.7
SCHLUMBERGER	J5S	C390041	06-25-02	100.0	99.8	99.7
SCHLUMBERGER	J5S	C390042	06-25-02	100.1	99.8	100.0
SCHLUMBERGER	J5S	C390043	06-25-02	99.9	100.1	99.8
SCHLUMBERGER	J5S	C390044	06-25-02	100.0	99.8	99.9
SCHLUMBERGER	J5S	C390045	06-25-02	100.1	99.9	100.0
SCHLUMBERGER	J5S	C390046	06-25-02	99.9	99.8	99.9
SCHLUMBERGER	J5S	C390047	06-25-02	100.3	100.0	99.8
SCHLUMBERGER	J5S	C390048	06-25-02	100.2	99.7	100.2
SCHLUMBERGER	J5S	C390049	06-25-02	100.2	99.8	100.1
SCHLUMBERGER	J5S	C390050	06-25-02	100.0	100.2	100.2
SCHLUMBERGER	J5S	C390051	06-25-02	99.9	99.6	99.8
SCHLUMBERGER	J5S	C390052	06-25-02	100.0	99.8	99.9
SCHLUMBERGER	J5S	C390053	06-25-02	100.1	100.1	100.1
SCHLUMBERGER	J5S	C390054	06-25-02	100.1	99.7	99.8
SCHLUMBERGER	J5S	C390055	06-25-02	100.1	99.8	100.3
SCHLUMBERGER	J5S	C390056	06-25-02	100.0	100.0	100.0
SCHLUMBERGER	J5S	C390057	06-25-02	100.1	100.1	99.9
SCHLUMBERGER	J5S	C390058	06-25-02	100.0	99.9	99.5

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

PAGE 125
 RUN DATE: 1/14/03
 RUN TIME: 13.26.53

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	J5S	C390059	06-25-02	100.1	100.1	100.4
SCHLUMBERGER	J5S	C390060	05-25-02	100.1	99.7	100.1
SCHLUMBERGER	J5S	C390061	06-25-02	100.0	99.8	100.1
SCHLUMBERGER	J5S	C390062	06-25-02	100.0	100.0	100.0
SCHLUMBERGER	J5S	C390063	06-25-02	100.0	99.6	100.0
SCHLUMBERGER	J5S	C390064	06-25-02	100.0	99.7	99.8
SCHLUMBERGER	J5S	C390065	06-25-02	100.3	99.7	100.2
SCHLUMBERGER	J5S	C390066	06-25-02	100.1	100.2	100.0
SCHLUMBERGER	J5S	C390067	06-25-02	100.0	99.8	100.0
SCHLUMBERGER	J5S	C390068	06-25-02	100.1	100.0	99.7
SCHLUMBERGER	J5S	C390069	06-25-02	100.1	99.6	99.8
SCHLUMBERGER	J5S	C390070	06-25-02	100.0	99.7	99.8
SCHLUMBERGER	J5S	C390071	06-25-02	100.0	99.8	100.0
SCHLUMBERGER	J5S	C390072	06-25-02	99.9	99.7	100.1
SCHLUMBERGER	J5S	C390073	06-25-02	100.1	99.9	99.9
SCHLUMBERGER	J5S	C390074	06-25-02	100.1	99.8	100.2
SCHLUMBERGER	J5S	C390075	06-25-02	100.2	100.3	100.2
SCHLUMBERGER	J5S	C390076	06-25-02	100.1	100.4	100.3
SCHLUMBERGER	J5S	C390077	06-25-02	99.9	99.8	100.0
SCHLUMBERGER	J5S	C390078	06-25-02	100.1	99.7	99.5
SCHLUMBERGER	J5S	C390079	06-25-02	100.0	100.3	99.6
SCHLUMBERGER	J5S	C390080	06-25-02	100.1	99.8	99.8
SCHLUMBERGER	J5S	C390081	06-25-02	100.0	100.0	100.1
SCHLUMBERGER	J5S	C390082	06-25-02	100.1	99.8	99.9
SCHLUMBERGER	J5S	C390083	06-25-02	100.2	100.1	99.5
SCHLUMBERGER	J5S	C390084	06-25-02	100.1	100.1	100.1
SCHLUMBERGER	J5S	C390085	06-25-02	100.0	99.7	100.0
SCHLUMBERGER	J5S	C390086	06-25-02	99.9	99.6	99.8
SCHLUMBERGER	J5S	C390087	06-25-02	100.1	99.9	100.0
SCHLUMBERGER	J5S	C390088	06-25-02	99.9	99.8	99.4
SCHLUMBERGER	J5S	C390089	06-25-02	100.0	99.7	99.6
SCHLUMBERGER	J5S	C390090	06-25-02	100.0	99.8	100.1
SCHLUMBERGER	J5S	C390091	06-25-02	100.0	99.6	99.8
SCHLUMBERGER	J5S	C390092	06-25-02	100.1	100.2	99.8
SCHLUMBERGER	J5S	C390093	06-25-02	100.2	99.6	100.1
SCHLUMBERGER	J5S	C390094	06-25-02	100.0	100.0	99.9
SCHLUMBERGER	J5S	C390095	06-25-02	100.2	99.7	100.3
SCHLUMBERGER	J5S	C390096	06-25-02	100.1	99.7	99.8
SCHLUMBERGER	J5S	C390097	06-25-02	100.0	99.9	99.5
SCHLUMBERGER	J5S	C390098	06-25-02	99.9	99.8	100.2
SCHLUMBERGER	J5S	C390099	06-25-02	100.2	99.9	100.0
SCHLUMBERGER	J5S	C390100	06-25-02	100.1	99.7	99.8
SCHLUMBERGER	J5S	C390101	06-25-02	100.1	100.0	99.8
SCHLUMBERGER	J5S	C390102	06-25-02	100.1	100.0	100.3
SCHLUMBERGER	J5S	C390103	06-25-02	100.2	99.7	100.3
SCHLUMBERGER	J5S	C390104	06-25-02	100.1	100.0	100.3
SCHLUMBERGER	J5S	C390105	06-25-02	100.0	99.8	100.1
SCHLUMBERGER	J5S	C390106	06-25-02	100.1	100.2	100.1
SCHLUMBERGER	J5S	C390107	06-25-02	100.1	99.8	99.8
SCHLUMBERGER	J5S	C390108	06-25-02	100.1	99.7	100.0
SCHLUMBERGER	J5S	C390109	06-25-02	100.1	99.8	100.4

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

PAGE 126
 RUN DATE: 1/14/03
 RUN TIME: 13.26.53

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	J5S	C390110	06-25-02	100.2	100.4	100.4
SCHLUMBERGER	J5S	C390111	06-25-02	100.0	99.8	99.8
SCHLUMBERGER	J5S	C390112	06-25-02	100.0	99.9	99.6
SCHLUMBERGER	J5S	C390113	06-25-02	100.1	99.8	100.1
SCHLUMBERGER	J5S	C390114	06-25-02	99.9	100.0	100.0
SCHLUMBERGER	J5S	C390115	06-25-02	100.0	99.7	99.6
SCHLUMBERGER	J5S	C390116	06-25-02	100.0	100.1	99.8
SCHLUMBERGER	J5S	C390117	06-25-02	100.0	100.0	99.7
SCHLUMBERGER	J5S	C390118	06-25-02	100.1	99.9	99.9
SCHLUMBERGER	J5S	C390119	06-25-02	100.1	99.8	99.5
SCHLUMBERGER	J5S	C390120	06-25-02	99.9	100.0	100.0
SCHLUMBERGER	J5S	C390121	06-25-02	100.2	99.9	100.3
SCHLUMBERGER	J5S	C390122	06-25-02	100.3	99.7	100.4
SCHLUMBERGER	J5S	C390123	06-25-02	99.9	99.8	99.6
SCHLUMBERGER	J5S	C390124	06-25-02	100.0	99.6	99.8
SCHLUMBERGER	J5S	C390125	06-25-02	100.1	100.0	100.0
SCHLUMBERGER	J5S	C390126	06-25-02	100.1	99.7	99.8
SCHLUMBERGER	J5S	C390127	06-25-02	100.2	100.3	100.3
SCHLUMBERGER	J5S	C390128	06-25-02	100.2	100.1	100.2
SCHLUMBERGER	J5S	C390129	06-25-02	99.9	99.8	99.6
SCHLUMBERGER	J5S	C390130	06-25-02	100.1	99.8	99.9
SCHLUMBERGER	J5S	C390131	06-25-02	100.1	100.3	99.9
SCHLUMBERGER	J5S	C390132	06-25-02	100.1	99.8	99.8
SCHLUMBERGER	J5S	C390133	06-25-02	100.1	100.1	100.0
SCHLUMBERGER	J5S	C390134	06-25-02	100.1	99.9	100.5
SCHLUMBERGER	J5S	C390135	06-25-02	100.0	100.0	99.8
SCHLUMBERGER	J5S	C390136	06-25-02	100.1	100.2	99.8
SCHLUMBERGER	J5S	C390137	06-25-02	100.1	100.2	99.9
SCHLUMBERGER	J5S	C390138	06-25-02	100.2	99.8	99.8
SCHLUMBERGER	J5S	C390139	06-25-02	100.0	100.3	100.1
SCHLUMBERGER	J5S	C390140	06-25-02	100.2	100.2	100.2
SCHLUMBERGER	J5S	C390141	06-25-02	100.0	99.6	99.8
SCHLUMBERGER	J5S	C390142	06-25-02	100.2	99.6	99.8
SCHLUMBERGER	J5S	C390143	06-25-02	100.1	99.7	99.5
SCHLUMBERGER	J5S	C390144	06-25-02	100.2	99.9	99.9
SCHLUMBERGER	J5S	C390145	06-25-02	100.0	99.6	99.8
SCHLUMBERGER	J5S	C390146	06-25-02	100.0	99.6	100.3
SCHLUMBERGER	J5S	C390147	06-25-02	100.1	99.9	99.6
SCHLUMBERGER	J5S	C390148	06-25-02	100.1	99.8	100.0
SCHLUMBERGER	J5S	C390149	06-25-02	100.0	100.1	100.0
SCHLUMBERGER	J5S	C390150	06-25-02	100.0	99.8	99.5
SCHLUMBERGER	J5S	C390151	06-25-02	100.1	100.5	100.1
SCHLUMBERGER	J5S	C390152	06-25-02	100.0	99.6	99.8
SCHLUMBERGER	J5S	C390153	06-25-02	100.0	100.0	99.7
SCHLUMBERGER	J5S	C390154	06-25-02	100.0	100.3	99.9
SCHLUMBERGER	J5S	C390155	06-25-02	99.8	100.3	99.9
SCHLUMBERGER	J5S	C390156	06-25-02	99.9	99.6	99.6
SCHLUMBERGER	J5S	C390157	06-25-02	100.1	99.7	99.8
SCHLUMBERGER	J5S	C390158	06-25-02	100.1	99.6	100.1
SCHLUMBERGER	J5S	C390159	06-25-02	100.1	99.8	100.3
SCHLUMBERGER	J5S	C390160	06-25-02	100.0	99.6	99.6

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

PAGE 127
 RUN DATE: 1/14/03
 RUN TIME: 13.26.53

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	J5S	C390161	06-25-02	100.3	100.3	100.3
SCHLUMBERGER	J5S	C390162	06-25-02	100.0	99.9	99.8
SCHLUMBERGER	J5S	C390163	06-25-02	100.2	99.6	99.8
SCHLUMBERGER	J5S	C390164	06-25-02	100.1	100.1	99.9
SCHLUMBERGER	J5S	C390165	06-25-02	100.1	99.9	100.0
SCHLUMBERGER	J5S	C390166	06-25-02	100.0	100.3	99.9
SCHLUMBERGER	J5S	C390167	06-25-02	100.0	100.0	99.6
SCHLUMBERGER	J5S	C390168	06-25-02	100.0	99.6	99.7
SCHLUMBERGER	J5S	C390169	06-25-02	100.1	100.1	99.9
SCHLUMBERGER	J5S	C390170	06-25-02	100.0	99.8	99.5
SCHLUMBERGER	J5S	C390171	06-25-02	100.0	100.4	100.0
SCHLUMBERGER	J5S	C390172	06-25-02	100.0	99.6	100.3
SCHLUMBERGER	J5S	C390173	06-25-02	100.1	99.8	100.2
SCHLUMBERGER	J5S	C390174	06-25-02	100.1	100.2	100.5
SCHLUMBERGER	J5S	C390175	06-25-02	100.1	100.2	99.9
SCHLUMBERGER	J5S	C390176	06-25-02	100.0	100.4	99.9
SCHLUMBERGER	J5S	C390177	06-25-02	100.0	99.9	99.9
SCHLUMBERGER	J5S	C390178	06-25-02	100.1	100.0	99.8
SCHLUMBERGER	J5S	C390179	06-25-02	100.1	100.0	99.9
SCHLUMBERGER	J5S	C390180	06-25-02	99.9	100.3	99.9
SCHLUMBERGER	J5S	C390181	06-25-02	100.1	99.7	99.8
SCHLUMBERGER	J5S	C390182	06-25-02	100.1	100.0	99.9
SCHLUMBERGER	J5S	C390183	06-25-02	100.0	100.4	99.8
SCHLUMBERGER	J5S	C390184	06-25-02	100.2	100.1	100.1
SCHLUMBERGER	J5S	C390185	06-25-02	100.0	99.8	100.1
SCHLUMBERGER	J5S	C390186	06-25-02	100.0	99.8	99.9
SCHLUMBERGER	J5S	C390187	06-25-02	100.1	99.7	99.8
SCHLUMBERGER	J5S	C390188	06-25-02	99.8	99.7	100.0
SCHLUMBERGER	J5S	C390189	06-25-02	100.0	99.9	99.8
SCHLUMBERGER	J5S	C390190	06-25-02	99.9	99.9	99.8
SCHLUMBERGER	J5S	C390191	06-25-02	100.2	100.2	99.7
SCHLUMBERGER	J5S	C390192	06-25-02	100.0	99.6	99.6
SCHLUMBERGER	J5S	C390193	06-25-02	100.1	99.6	99.8
SCHLUMBERGER	J5S	C390194	06-25-02	100.1	100.2	99.9
SCHLUMBERGER	J5S	C390195	06-25-02	100.0	99.7	99.9
SCHLUMBERGER	J5S	C390196	06-25-02	100.0	100.2	99.7
SCHLUMBERGER	J5S	C390197	06-25-02	100.1	99.6	100.0
SCHLUMBERGER	J5S	C390198	06-25-02	100.0	99.7	100.0
SCHLUMBERGER	J5S	C390199	06-25-02	99.9	99.6	99.7
SCHLUMBERGER	J5S	C390200	06-25-02	100.0	99.8	100.2
SCHLUMBERGER	J5S	C390201	06-25-02	99.9	100.3	100.0
SCHLUMBERGER	J5S	C390202	06-25-02	100.1	100.0	100.0
SCHLUMBERGER	J5S	C390203	06-25-02	100.2	99.6	100.0
SCHLUMBERGER	J5S	C390204	06-25-02	100.0	99.7	100.2
SCHLUMBERGER	J5S	C390205	06-25-02	100.1	99.8	99.8
SCHLUMBERGER	J5S	C390206	06-25-02	100.0	99.7	99.7
SCHLUMBERGER	J5S	C390207	06-25-02	100.1	99.7	100.1
SCHLUMBERGER	J5S	C390208	06-25-02	100.3	100.0	100.3
SCHLUMBERGER	J5S	C390209	06-25-02	99.9	99.6	99.5
SCHLUMBERGER	J5S	C390210	06-25-02	99.9	99.9	99.6
SCHLUMBERGER	J5S	C390211	06-25-02	100.1	99.7	100.0

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

MANUFACTURER	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	C390212	06-25-02	100.0	99.6	99.9
SCHLUMBERGER	C390213	06-25-02	100.0	99.9	100.3
SCHLUMBERGER	C390214	06-25-02	100.0	99.9	99.8
SCHLUMBERGER	C390215	06-25-02	100.0	100.0	99.7
SCHLUMBERGER	C390216	06-25-02	99.9	99.8	99.8
SCHLUMBERGER	C390217	06-25-02	100.0	99.7	99.7
SCHLUMBERGER	C390218	06-25-02	99.8	100.0	99.8
SCHLUMBERGER	C390219	06-25-02	100.1	99.9	100.1
SCHLUMBERGER	C390220	06-25-02	100.1	99.7	99.7
SCHLUMBERGER	C390221	06-25-02	100.1	100.0	99.9
SCHLUMBERGER	C390222	06-25-02	100.0	99.8	100.1
SCHLUMBERGER	C390223	06-25-02	100.0	99.9	99.8
SCHLUMBERGER	C390224	06-25-02	100.0	99.7	99.9
SCHLUMBERGER	C390225	06-25-02	100.0	99.7	99.7
SCHLUMBERGER	C390226	06-25-02	100.0	99.6	100.0
SCHLUMBERGER	C390227	06-25-02	99.9	99.8	99.5
SCHLUMBERGER	C390228	06-25-02	100.2	100.0	99.8
SCHLUMBERGER	C390229	06-25-02	100.0	99.7	99.9
SCHLUMBERGER	C390230	06-25-02	100.0	100.4	100.1
SCHLUMBERGER	C390231	06-25-02	100.1	99.9	100.0
SCHLUMBERGER	C390232	06-25-02	100.0	100.4	100.2
SCHLUMBERGER	C390233	06-25-02	100.1	99.8	99.7
SCHLUMBERGER	C390234	06-25-02	100.2	99.7	100.3
SCHLUMBERGER	C390235	06-25-02	100.1	99.9	99.9
SCHLUMBERGER	C390236	06-25-02	100.2	99.8	100.3
SCHLUMBERGER	C390237	06-25-02	99.9	99.9	99.8
SCHLUMBERGER	C390238	06-25-02	99.9	99.7	99.8
SCHLUMBERGER	C390239	06-25-02	100.3	99.7	99.8
SCHLUMBERGER	C390240	06-25-02	100.1	99.7	100.2
SCHLUMBERGER	C390241	06-25-02	100.1	99.8	100.2
SCHLUMBERGER	C390242	06-25-02	100.2	100.0	99.9
SCHLUMBERGER	C390243	06-25-02	100.2	99.8	100.1
SCHLUMBERGER	C390244	06-25-02	100.0	99.6	99.9
SCHLUMBERGER	C390245	06-25-02	100.1	99.9	100.5
SCHLUMBERGER	C390246	06-25-02	100.1	99.8	99.9
SCHLUMBERGER	C390247	06-25-02	100.2	99.8	100.2
SCHLUMBERGER	C390248	06-25-02	100.0	100.0	100.1
SCHLUMBERGER	C390249	06-25-02	100.3	99.9	100.2
SCHLUMBERGER	C390250	06-25-02	100.2	99.9	99.6
SCHLUMBERGER	C390251	06-25-02	100.0	99.7	100.5
SCHLUMBERGER	C390252	06-25-02	99.8	100.1	100.0
SCHLUMBERGER	C390253	06-25-02	100.1	99.8	100.2
SCHLUMBERGER	C390254	06-25-02	99.9	99.9	99.8
SCHLUMBERGER	C390255	06-25-02	99.8	100.3	99.8
SCHLUMBERGER	C390256	06-25-02	100.1	100.1	100.3
SCHLUMBERGER	C390257	06-25-02	100.1	100.2	99.8
SCHLUMBERGER	C390258	06-25-02	100.0	99.7	99.7
SCHLUMBERGER	C390259	06-25-02	100.1	99.8	99.9
SCHLUMBERGER	C390260	06-25-02	100.0	99.9	100.2
SCHLUMBERGER	C390261	06-25-02	99.9	99.7	99.9
SCHLUMBERGER	C390262	06-25-02	100.1	100.1	100.0

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	J55	C390263	06-25-02	100.1	100.1	100.2
SCHLUMBERGER	J55	C390264	05-25-02	100.0	99.7	99.7
SCHLUMBERGER	J55	C390265	06-25-02	100.2	100.0	100.2
SCHLUMBERGER	J55	C390266	06-25-02	100.0	99.8	99.6
SCHLUMBERGER	J55	C390267	05-25-02	99.9	99.6	99.7
SCHLUMBERGER	J55	C390268	06-25-02	99.9	99.8	99.5
SCHLUMBERGER	J55	C390269	06-25-02	99.9	99.8	99.7
SCHLUMBERGER	J55	C390270	05-25-02	100.0	100.1	100.0
SCHLUMBERGER	J55	C390271	06-25-02	100.3	100.3	100.5
SCHLUMBERGER	J55	C390272	06-25-02	100.0	99.8	100.1
SCHLUMBERGER	J55	C390273	05-25-02	100.2	99.8	100.6
SCHLUMBERGER	J55	C390274	06-25-02	100.0	99.8	99.7
SCHLUMBERGER	J55	C390275	06-25-02	100.0	99.8	99.9
SCHLUMBERGER	J55	C390276	06-25-02	100.0	99.9	100.1
SCHLUMBERGER	J55	C390277	06-25-02	100.0	99.9	99.8
SCHLUMBERGER	J55	C390278	06-25-02	99.9	99.8	99.6
SCHLUMBERGER	J55	C390279	06-25-02	100.0	100.4	99.6
SCHLUMBERGER	J55	C390280	06-25-02	100.2	99.8	100.4
SCHLUMBERGER	J55	C390281	06-25-02	100.1	99.7	99.8
SCHLUMBERGER	J55	C390282	06-25-02	100.0	99.9	100.1
SCHLUMBERGER	J55	C390283	06-25-02	100.2	100.1	100.2
SCHLUMBERGER	J55	C390284	06-25-02	100.0	99.8	100.4
SCHLUMBERGER	J55	C390285	06-25-02	100.1	99.9	99.9
SCHLUMBERGER	J55	C390286	06-25-02	100.2	99.9	99.6
SCHLUMBERGER	J55	C390287	06-25-02	100.2	99.9	100.0
SCHLUMBERGER	J55	C390288	06-25-02	100.2	100.1	100.2
SCHLUMBERGER	J55	C390289	06-25-02	100.0	99.9	100.3
SCHLUMBERGER	J55	C390290	06-25-02	100.0	99.7	100.2
SCHLUMBERGER	J55	C390291	06-25-02	99.9	99.6	100.0
SCHLUMBERGER	J55	C390292	06-25-02	100.3	99.8	100.0
SCHLUMBERGER	J55	C390293	06-25-02	100.1	99.7	100.0
SCHLUMBERGER	J55	C390294	06-25-02	100.0	99.8	99.8
SCHLUMBERGER	J55	C390295	06-25-02	100.1	100.1	99.7
SCHLUMBERGER	J55	C390296	06-25-02	99.9	100.1	99.8
SCHLUMBERGER	J55	C390297	06-25-02	100.2	100.2	99.8
SCHLUMBERGER	J55	C390298	06-25-02	100.0	100.2	99.9
SCHLUMBERGER	J55	C390299	06-25-02	99.9	99.9	100.3
SCHLUMBERGER	J55	C390300	06-25-02	100.0	100.2	100.1
SCHLUMBERGER	J55	C390301	06-25-02	100.0	100.1	100.2
SCHLUMBERGER	J55	C390302	06-25-02	100.0	99.8	100.0
SCHLUMBERGER	J55	C390303	06-25-02	100.3	99.8	99.9
SCHLUMBERGER	J55	C390304	06-25-02	100.1	99.9	99.8
SCHLUMBERGER	J55	C390305	06-25-02	100.1	99.6	99.8
SCHLUMBERGER	J55	C390306	06-25-02	99.8	99.6	99.5
SCHLUMBERGER	J55	C390307	06-25-02	100.1	99.9	100.1
SCHLUMBERGER	J55	C390308	06-25-02	100.1	99.9	99.9
SCHLUMBERGER	J55	C390309	06-25-02	100.0	99.9	100.1
SCHLUMBERGER	J55	C390310	06-25-02	100.1	100.0	100.0
SCHLUMBERGER	J55	C390311	06-25-02	100.3	100.0	99.7
SCHLUMBERGER	J55	C390312	06-25-02	100.0	99.7	100.1
SCHLUMBERGER	J55	C390313	06-25-02	99.9	99.6	99.5

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

PAGE 130
 RUN DATE: 1/14/03
 RUN TIME: 13.26.53

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	J55	C390314	06-25-02	100.0	99.9	99.9
SCHLUMBERGER	J55	C390315	06-25-02	100.0	99.7	99.6
SCHLUMBERGER	J55	C390316	06-25-02	100.0	100.0	100.0
SCHLUMBERGER	J55	C390317	06-25-02	100.2	99.6	100.3
SCHLUMBERGER	J55	C390318	06-25-02	100.1	100.3	100.1
SCHLUMBERGER	J55	C390319	06-25-02	100.0	99.6	99.9
SCHLUMBERGER	J55	C390320	06-25-02	100.0	100.0	99.8
SCHLUMBERGER	J55	C390321	06-25-02	100.1	99.8	100.1
SCHLUMBERGER	J55	C390322	06-25-02	100.0	99.7	99.4
SCHLUMBERGER	J55	C390323	06-25-02	100.1	100.3	100.0
SCHLUMBERGER	J55	C390324	06-25-02	100.2	99.9	100.2
SCHLUMBERGER	J55	C390325	06-25-02	100.0	99.8	99.6
SCHLUMBERGER	J55	C390326	06-25-02	100.1	100.0	99.8
SCHLUMBERGER	J55	C390327	06-25-02	100.1	99.8	100.4
SCHLUMBERGER	J55	C390328	06-25-02	100.1	100.4	100.4
SCHLUMBERGER	J55	C390329	06-25-02	99.9	99.6	99.7
SCHLUMBERGER	J55	C390330	06-25-02	100.0	99.7	99.7
SCHLUMBERGER	J55	C390331	06-25-02	100.1	100.3	100.0
SCHLUMBERGER	J55	C390332	06-25-02	100.1	100.0	100.4
SCHLUMBERGER	J55	C390333	06-25-02	100.0	99.7	99.8
SCHLUMBERGER	J55	C390334	06-25-02	100.2	100.0	100.2
SCHLUMBERGER	J55	C390335	06-25-02	100.0	99.7	99.4
SCHLUMBERGER	J55	C390336	06-25-02	100.2	99.9	100.0
SCHLUMBERGER	J55	C390337	06-25-02	100.2	100.0	100.3
SCHLUMBERGER	J55	C390338	06-25-02	100.1	99.8	100.0
SCHLUMBERGER	J55	C390339	06-25-02	99.9	99.9	99.7
SCHLUMBERGER	J55	C390340	06-25-02	100.1	100.0	100.2
SCHLUMBERGER	J55	C390341	06-25-02	100.1	99.7	100.2
SCHLUMBERGER	J55	C390342	06-25-02	99.9	99.7	99.4
SCHLUMBERGER	J55	C390343	06-25-02	100.0	99.7	99.5
SCHLUMBERGER	J55	C390344	06-25-02	100.1	99.7	99.9
SCHLUMBERGER	J55	C390345	06-25-02	100.0	99.8	99.8
SCHLUMBERGER	J55	C390346	06-25-02	100.2	100.0	99.9
SCHLUMBERGER	J55	C390347	06-25-02	100.0	100.0	100.0
SCHLUMBERGER	J55	C390348	06-25-02	100.0	99.8	99.4
SCHLUMBERGER	J55	C390349	06-25-02	100.1	100.1	99.8
SCHLUMBERGER	J55	C390350	06-25-02	100.1	99.7	99.9
SCHLUMBERGER	J55	C390351	06-25-02	100.1	100.0	100.1
SCHLUMBERGER	J55	C390352	06-25-02	100.2	99.8	100.3
SCHLUMBERGER	J55	C390353	06-25-02	100.1	99.9	99.8
SCHLUMBERGER	J55	C390354	06-25-02	100.1	99.9	99.8
SCHLUMBERGER	J55	C390355	06-25-02	100.0	100.0	100.3
SCHLUMBERGER	J55	C390356	06-25-02	100.0	99.9	99.4
SCHLUMBERGER	J55	C390357	06-25-02	100.1	99.9	99.6
SCHLUMBERGER	J55	C390358	06-25-02	100.2	100.3	100.2
SCHLUMBERGER	J55	C390359	06-25-02	100.1	99.8	100.1
SCHLUMBERGER	J55	C390360	06-25-02	100.0	99.8	99.8
SCHLUMBERGER	J55	C390361	06-25-02	100.0	99.7	100.5
SCHLUMBERGER	J55	C390362	06-25-02	99.9	99.7	99.9
SCHLUMBERGER	J55	C390363	06-25-02	99.9	99.8	99.4
SCHLUMBERGER	J55	C390364	06-25-02	100.1	99.7	100.3

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

PAGE 131
 RUN DATE: 1/14/03
 RUN TIME: 13.26.53

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	J55	C390365	06-25-02	100.1	99.6	99.9
SCHLUMBERGER	J55	C390366	06-25-02	100.1	99.9	99.8
SCHLUMBERGER	J55	C390367	06-25-02	100.0	99.9	99.8
SCHLUMBERGER	J55	C390368	06-25-02	100.0	99.8	99.8
SCHLUMBERGER	J55	C390369	06-25-02	100.1	99.9	100.1
SCHLUMBERGER	J55	C390370	06-25-02	100.2	100.1	100.2
SCHLUMBERGER	J55	C390371	06-25-02	100.0	99.7	99.8
SCHLUMBERGER	J55	C390372	06-25-02	100.1	99.9	99.9
SCHLUMBERGER	J55	C390373	06-25-02	100.1	99.8	100.1
SCHLUMBERGER	J55	C390374	06-25-02	100.0	99.9	99.7
SCHLUMBERGER	J55	C390375	06-25-02	100.0	99.8	99.8
SCHLUMBERGER	J55	C390376	06-25-02	100.0	100.1	100.1
SCHLUMBERGER	J55	C390377	06-25-02	100.0	99.7	99.7
SCHLUMBERGER	J55	C390378	06-25-02	100.0	100.0	99.8
SCHLUMBERGER	J55	C390379	06-25-02	100.1	99.8	100.1
SCHLUMBERGER	J55	C390380	06-25-02	100.2	99.8	100.0
SCHLUMBERGER	J55	C390381	06-25-02	100.0	100.2	99.8
SCHLUMBERGER	J55	C390382	06-25-02	100.0	99.8	99.9
SCHLUMBERGER	J55	C390383	06-25-02	100.1	99.8	99.8
SCHLUMBERGER	J55	C390384	06-25-02	100.2	99.7	99.9
SCHLUMBERGER	J55	C390385	06-25-02	99.9	99.8	99.8
SCHLUMBERGER	J55	C390386	06-25-02	100.0	100.0	99.9
SCHLUMBERGER	J55	C390387	06-25-02	100.0	100.0	99.7
SCHLUMBERGER	J55	C390388	06-25-02	100.0	100.1	100.1
SCHLUMBERGER	J55	C390389	06-25-02	100.3	99.9	100.4
SCHLUMBERGER	J55	C390390	06-25-02	100.0	99.6	100.0
SCHLUMBERGER	J55	C390391	06-25-02	100.0	99.8	99.5
SCHLUMBERGER	J55	C390392	06-25-02	99.9	100.1	100.0
SCHLUMBERGER	J55	C390393	06-25-02	100.0	99.8	99.9
SCHLUMBERGER	J55	C390394	06-25-02	100.0	99.7	99.8
SCHLUMBERGER	J55	C390395	06-25-02	100.3	100.0	100.1
SCHLUMBERGER	J55	C390396	06-25-02	99.9	99.8	99.5
SCHLUMBERGER	J55	C390397	06-25-02	100.0	99.9	99.6
SCHLUMBERGER	J55	C390398	06-25-02	100.0	99.8	99.7
SCHLUMBERGER	J55	C390399	06-25-02	100.0	99.9	99.9
SCHLUMBERGER	J55	C390400	06-25-02	100.2	99.8	99.9
SCHLUMBERGER	J55	C390401	06-25-02	99.9	99.8	99.8
SCHLUMBERGER	J55	C390402	06-25-02	100.0	99.8	99.7
SCHLUMBERGER	J55	C390403	06-25-02	100.1	100.1	100.3
SCHLUMBERGER	J55	C390404	06-25-02	100.2	99.7	100.0
SCHLUMBERGER	J55	C390405	06-25-02	100.1	99.7	99.7
SCHLUMBERGER	J55	C390406	06-25-02	100.1	99.8	100.0
SCHLUMBERGER	J55	C390407	06-25-02	99.9	99.9	100.0
SCHLUMBERGER	J55	C390408	06-25-02	100.0	99.9	99.8
SCHLUMBERGER	J55	C390409	06-25-02	99.9	100.2	99.9
SCHLUMBERGER	J55	C390410	06-25-02	100.0	99.6	100.0
SCHLUMBERGER	J55	C390411	06-25-02	100.1	99.7	99.6
SCHLUMBERGER	J55	C390412	06-25-02	100.1	100.2	100.0
SCHLUMBERGER	J55	C390413	06-25-02	99.9	99.7	99.5
SCHLUMBERGER	J55	C390414	06-25-02	100.1	99.9	100.2
SCHLUMBERGER	J55	C390415	06-25-02	100.3	100.3	99.9

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

PAGE 132
 RUN DATE: 1/14/03
 RUN TIME: 13.26.53

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	J5S	C390416	06-25-02	100.1	99.9	100.2
SCHLUMBERGER	J5S	C390417	06-25-02	100.2	99.8	100.0
SCHLUMBERGER	J5S	C390418	06-25-02	100.0	99.9	100.0
SCHLUMBERGER	J5S	C390419	06-25-02	100.1	99.8	99.8
SCHLUMBERGER	J5S	C390420	06-25-02	100.1	100.2	100.0
SCHLUMBERGER	J5S	C390421	06-25-02	100.1	100.2	100.0
SCHLUMBERGER	J5S	C390422	06-25-02	100.1	99.6	99.7
SCHLUMBERGER	J5S	C390423	06-25-02	100.0	99.8	99.8
SCHLUMBERGER	J5S	C390424	06-25-02	100.0	100.1	99.7
SCHLUMBERGER	J5S	C390425	06-25-02	100.1	99.7	100.0
SCHLUMBERGER	J5S	C390426	06-25-02	100.3	100.0	99.7
SCHLUMBERGER	J5S	C390427	06-25-02	99.9	100.3	99.6
SCHLUMBERGER	J5S	C390428	06-25-02	100.0	99.8	100.0
SCHLUMBERGER	J5S	C390429	06-25-02	100.2	99.8	100.1
SCHLUMBERGER	J5S	C390430	06-25-02	100.0	100.0	100.1
SCHLUMBERGER	J5S	C390431	06-25-02	100.1	99.8	100.4
SCHLUMBERGER	J5S	C390432	06-25-02	100.1	99.9	99.9
SCHLUMBERGER	J5S	C390433	06-25-02	99.9	100.1	100.1
SCHLUMBERGER	J5S	C390434	06-25-02	100.0	100.2	99.9
SCHLUMBERGER	J5S	C390435	06-25-02	100.0	99.9	100.2
SCHLUMBERGER	J5S	C390436	06-25-02	100.1	100.0	100.3
SCHLUMBERGER	J5S	C390437	06-25-02	100.1	99.6	100.0
SCHLUMBERGER	J5S	C390438	06-25-02	100.0	100.2	99.8
SCHLUMBERGER	J5S	C390439	06-25-02	100.0	100.2	100.2
SCHLUMBERGER	J5S	C390440	06-25-02	100.0	99.8	100.1
SCHLUMBERGER	J5S	C390441	06-25-02	99.8	99.9	99.9
SCHLUMBERGER	J5S	C390442	06-25-02	99.9	100.2	99.7
SCHLUMBERGER	J5S	C390443	06-25-02	100.1	100.1	100.1
SCHLUMBERGER	J5S	C390444	06-25-02	100.0	100.1	100.3
SCHLUMBERGER	J5S	C390445	06-25-02	100.0	99.9	99.8
SCHLUMBERGER	J5S	C390446	06-25-02	100.0	99.7	99.7
SCHLUMBERGER	J5S	C390447	06-25-02	100.3	99.9	99.9
SCHLUMBERGER	J5S	C390448	06-25-02	100.0	99.6	99.9
SCHLUMBERGER	J5S	C390449	06-25-02	99.8	100.0	99.7
SCHLUMBERGER	J5S	C390450	06-25-02	100.3	100.3	100.0
SCHLUMBERGER	J5S	C390451	06-25-02	100.3	100.1	100.4
SCHLUMBERGER	J5S	C390452	06-25-02	99.8	100.4	99.8
SCHLUMBERGER	J5S	C390453	06-25-02	100.0	99.7	99.9
SCHLUMBERGER	J5S	C390454	06-25-02	100.0	100.0	99.9
SCHLUMBERGER	J5S	C390455	06-25-02	100.1	99.7	99.8
SCHLUMBERGER	J5S	C390456	06-25-02	100.0	99.7	100.1
SCHLUMBERGER	J5S	C390457	06-25-02	100.0	99.9	100.0
SCHLUMBERGER	J5S	C390458	06-25-02	100.0	100.1	100.2
SCHLUMBERGER	J5S	C390459	06-25-02	99.9	99.9	100.1
SCHLUMBERGER	J5S	C390460	06-25-02	100.0	99.8	100.1
SCHLUMBERGER	J5S	C390461	06-25-02	100.0	99.6	99.7
SCHLUMBERGER	J5S	C390462	06-25-02	100.1	100.1	100.1
SCHLUMBERGER	J5S	C390463	06-25-02	100.1	99.8	100.0
SCHLUMBERGER	J5S	C390464	06-25-02	100.3	99.8	100.1
SCHLUMBERGER	J5S	C390465	06-25-02	100.0	99.7	100.1
SCHLUMBERGER	J5S	C390466	06-25-02	100.1	99.9	100.4

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	J5S	C390467	06-25-02	100.2	99.8	100.2
SCHLUMBERGER	J5S	C390468	06-25-02	99.9	100.0	99.5
SCHLUMBERGER	J5S	C390469	06-25-02	100.1	100.3	100.1
SCHLUMBERGER	J5S	C390470	06-25-02	100.0	99.8	99.8
SCHLUMBERGER	J5S	C390471	06-25-02	100.0	99.7	99.8
SCHLUMBERGER	J5S	C390472	06-25-02	100.1	99.9	100.0
SCHLUMBERGER	J5S	C390473	06-25-02	100.0	100.1	99.8
SCHLUMBERGER	J5S	C390474	06-25-02	100.1	99.7	99.9
SCHLUMBERGER	J5S	C390475	06-25-02	100.1	99.8	100.3
SCHLUMBERGER	J5S	C390476	06-25-02	100.0	100.3	100.0
SCHLUMBERGER	J5S	C390477	06-25-02	99.9	99.8	100.2
SCHLUMBERGER	J5S	C390478	06-25-02	100.0	99.8	100.1
SCHLUMBERGER	J5S	C390479	06-25-02	100.0	99.6	100.1
SCHLUMBERGER	J5S	C390480	06-25-02	100.1	99.7	99.8
SCHLUMBERGER	J5S	C390481	06-25-02	100.1	100.0	100.0
SCHLUMBERGER	J5S	C390482	06-25-02	100.0	100.4	99.9
SCHLUMBERGER	J5S	C390483	06-25-02	100.1	99.9	99.9
SCHLUMBERGER	J5S	C390484	06-25-02	100.1	99.9	99.8
SCHLUMBERGER	J5S	C390485	06-25-02	100.0	100.2	100.2
SCHLUMBERGER	J5S	C390486	06-25-02	100.1	99.8	99.8
SCHLUMBERGER	J5S	C390487	06-25-02	100.2	99.8	99.9
SCHLUMBERGER	J5S	C390488	06-25-02	100.2	99.6	100.1
SCHLUMBERGER	J5S	C390489	06-25-02	100.0	100.1	100.1
SCHLUMBERGER	J5S	C390490	06-25-02	100.0	99.6	99.6
SCHLUMBERGER	J5S	C390491	06-25-02	100.0	99.6	99.7
SCHLUMBERGER	J5S	C390492	06-25-02	100.1	99.8	100.1
SCHLUMBERGER	J5S	C390493	06-25-02	100.0	99.8	100.2
SCHLUMBERGER	J5S	C390494	06-25-02	100.0	99.8	99.6
SCHLUMBERGER	J5S	C390495	06-25-02	100.0	99.7	99.8
SCHLUMBERGER	J5S	C390496	06-25-02	100.2	100.0	100.0
SCHLUMBERGER	J5S	C390497	06-25-02	100.0	100.0	99.5
SCHLUMBERGER	J5S	C390498	06-25-02	100.3	99.9	99.9
SCHLUMBERGER	J5S	C390499	06-25-02	100.1	100.1	100.4
SCHLUMBERGER	J5S	C390500	06-25-02	100.0	99.7	99.8
SCHLUMBERGER	J5S	C390501	06-25-02	100.0	99.9	100.1
SCHLUMBERGER	J5S	C390502	06-25-02	100.0	99.6	99.9
SCHLUMBERGER	J5S	C390503	06-25-02	100.1	100.0	100.0
SCHLUMBERGER	J5S	C390504	06-25-02	100.1	100.0	99.8
SCHLUMBERGER	J5S	C390505	06-25-02	100.1	100.2	100.3
SCHLUMBERGER	J5S	C390506	06-25-02	100.0	100.1	100.2
SCHLUMBERGER	J5S	C390507	06-25-02	100.1	99.9	100.3
SCHLUMBERGER	J5S	C390508	06-25-02	100.0	99.9	99.5
SCHLUMBERGER	J5S	C390509	06-25-02	100.1	99.8	99.7
SCHLUMBERGER	J5S	C390510	06-25-02	100.1	100.2	100.3
SCHLUMBERGER	J5S	C390511	06-25-02	99.8	99.7	99.7
SCHLUMBERGER	J5S	C390512	06-25-02	100.1	99.7	100.1
SCHLUMBERGER	J5S	C390513	06-25-02	100.2	99.7	99.7
SCHLUMBERGER	J5S	C390514	06-25-02	100.3	99.6	100.0
SCHLUMBERGER	J5S	C390515	06-25-02	99.9	99.6	99.4
SCHLUMBERGER	J5S	C390516	06-25-02	100.2	99.9	100.0
SCHLUMBERGER	J5S	C390517	06-25-02	100.0	99.9	99.5

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	J5S	C390518	06-25-02	100.0	99.9	99.6
SCHLUMBERGER	J5S	C390519	06-25-02	100.0	99.9	99.7
SCHLUMBERGER	J5S	C390520	06-25-02	100.0	99.8	99.8
SCHLUMBERGER	J5S	C390521	06-25-02	100.1	100.3	100.0
SCHLUMBERGER	J5S	C390522	06-25-02	100.1	99.7	99.8
SCHLUMBERGER	J5S	C390523	06-25-02	100.2	100.2	100.5
SCHLUMBERGER	J5S	C390524	06-25-02	100.1	99.9	99.8
SCHLUMBERGER	J5S	C390525	06-25-02	100.1	100.1	100.1
SCHLUMBERGER	J5S	C390526	06-25-02	100.1	99.8	99.9
SCHLUMBERGER	J5S	C390527	06-25-02	100.0	99.6	99.9
SCHLUMBERGER	J5S	C390528	06-25-02	99.9	99.9	99.8
SCHLUMBERGER	J5S	C390529	06-25-02	100.1	100.0	100.1
SCHLUMBERGER	J5S	C390530	06-25-02	100.0	99.7	99.8
SCHLUMBERGER	J5S	C390531	06-25-02	100.0	99.8	100.2
SCHLUMBERGER	J5S	C390532	06-25-02	100.1	99.7	100.1
SCHLUMBERGER	J5S	C390533	06-25-02	99.9	99.8	99.8
SCHLUMBERGER	J5S	C390534	06-25-02	100.0	100.1	100.2
SCHLUMBERGER	J5S	C390535	06-25-02	100.0	99.7	99.8
SCHLUMBERGER	J5S	C390536	06-25-02	100.0	99.7	99.8
SCHLUMBERGER	J5S	C390537	06-25-02	100.0	99.6	100.0
SCHLUMBERGER	J5S	C390538	06-25-02	100.0	99.9	99.7
SCHLUMBERGER	J5S	C390539	06-25-02	100.1	100.0	100.0
SCHLUMBERGER	J5S	C390540	06-25-02	100.2	99.7	100.1
SCHLUMBERGER	J5S	C390541	06-25-02	100.1	99.8	99.9
SCHLUMBERGER	J5S	C390542	06-25-02	100.0	99.7	99.9
SCHLUMBERGER	J5S	C390543	06-25-02	100.3	99.9	99.7
SCHLUMBERGER	J5S	C390544	06-25-02	100.0	99.9	99.9
SCHLUMBERGER	J5S	C390545	06-25-02	100.0	100.0	100.0
SCHLUMBERGER	J5S	C390546	06-25-02	100.1	99.7	99.8
SCHLUMBERGER	J5S	C390547	06-25-02	100.1	99.8	100.0
SCHLUMBERGER	J5S	C390548	06-25-02	100.0	99.6	99.9
SCHLUMBERGER	J5S	C390549	06-25-02	100.1	100.1	100.1
SCHLUMBERGER	J5S	C390550	06-25-02	100.2	100.0	100.0
SCHLUMBERGER	J5S	C390551	06-25-02	100.0	100.0	100.4
SCHLUMBERGER	J5S	C390552	06-25-02	100.2	99.6	99.8
SCHLUMBERGER	J5S	C390553	06-25-02	100.0	100.0	100.1
SCHLUMBERGER	J5S	C390554	06-25-02	100.1	99.6	100.3
SCHLUMBERGER	J5S	C390555	06-25-02	100.1	99.6	100.0
SCHLUMBERGER	J5S	C390556	06-25-02	100.1	100.0	100.2
SCHLUMBERGER	J5S	C390557	06-25-02	100.1	100.3	100.0
SCHLUMBERGER	J5S	C390558	06-25-02	100.1	99.9	100.1
SCHLUMBERGER	J5S	C390559	06-25-02	99.9	99.8	99.9
SCHLUMBERGER	J5S	C390560	06-25-02	100.0	99.9	100.3
SCHLUMBERGER	J5S	C390561	06-25-02	100.0	99.7	99.8
SCHLUMBERGER	J5S	C390562	06-25-02	100.0	99.7	100.1
SCHLUMBERGER	J5S	C390563	06-25-02	100.0	99.6	99.8
SCHLUMBERGER	J5S	C390564	06-25-02	100.0	99.9	99.7
SCHLUMBERGER	J5S	C390565	06-25-02	100.1	99.8	100.1
SCHLUMBERGER	J5S	C390566	06-25-02	100.0	99.6	100.1
SCHLUMBERGER	J5S	C390567	06-25-02	99.9	99.7	99.8
SCHLUMBERGER	J5S	C390568	06-25-02	100.3	99.8	99.9

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

PAGE 135
 RUN DATE: 1/14/03
 RUN TIME: 13.26.53

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	J55	C390569	06-25-02	100.0	99.8	100.3
SCHLUMBERGER	J55	C390570	06-25-02	99.9	99.7	99.8
SCHLUMBERGER	J55	C390571	06-25-02	100.1	100.0	99.9
SCHLUMBERGER	J55	C390572	06-25-02	100.1	100.0	100.2
SCHLUMBERGER	J55	C390573	06-25-02	100.1	99.9	100.0
SCHLUMBERGER	J55	C390574	06-25-02	100.0	99.7	100.0
SCHLUMBERGER	J55	C390575	06-25-02	99.9	99.9	100.0
SCHLUMBERGER	J55	C390576	06-25-02	100.1	99.8	100.0
SCHLUMBERGER	J55	C390577	06-25-02	100.0	100.0	99.7
SCHLUMBERGER	J55	C390578	06-25-02	100.3	99.9	99.8
SCHLUMBERGER	J55	C390579	06-25-02	100.1	99.8	100.1
SCHLUMBERGER	J55	C390580	06-25-02	100.2	99.9	99.9
SCHLUMBERGER	J55	C390581	06-25-02	100.0	99.9	99.8
SCHLUMBERGER	J55	C390582	06-25-02	100.0	99.8	100.1
SCHLUMBERGER	J55	C390583	06-25-02	100.1	100.2	100.1
SCHLUMBERGER	J55	C390584	06-25-02	100.2	100.2	100.1
SCHLUMBERGER	J55	C390585	06-25-02	99.8	99.8	99.8
SCHLUMBERGER	J55	C390586	06-25-02	100.1	100.0	100.1
SCHLUMBERGER	J55	C390587	06-25-02	99.9	99.9	99.6
SCHLUMBERGER	J55	C390588	06-25-02	100.1	99.7	99.8
SCHLUMBERGER	J55	C390589	06-25-02	100.1	99.8	99.7
SCHLUMBERGER	J55	C390590	06-25-02	100.0	99.8	100.1
SCHLUMBERGER	J55	C390591	06-25-02	99.9	100.0	100.0
SCHLUMBERGER	J55	C390592	06-25-02	100.1	100.1	99.9
SCHLUMBERGER	J55	C390593	06-25-02	100.3	100.3	100.3
SCHLUMBERGER	J55	C390594	06-25-02	99.9	99.8	99.7
SCHLUMBERGER	J55	C390595	06-25-02	100.0	99.8	100.0
SCHLUMBERGER	J55	C390596	06-25-02	100.1	100.1	100.3
SCHLUMBERGER	J55	C390597	06-25-02	99.9	99.9	99.9
SCHLUMBERGER	J55	C390598	06-25-02	100.1	99.8	100.2
SCHLUMBERGER	J55	C390599	06-25-02	100.2	100.1	100.3
SCHLUMBERGER	J55	C390600	06-25-02	100.1	99.8	99.6
SCHLUMBERGER	J55	C390601	06-25-02	100.2	100.0	100.0
SCHLUMBERGER	J55	C390602	06-25-02	100.1	100.1	99.9
SCHLUMBERGER	J55	C390603	06-25-02	100.1	99.7	100.2
SCHLUMBERGER	J55	C390604	06-25-02	100.1	99.9	100.1
SCHLUMBERGER	J55	C390605	06-25-02	100.2	100.4	100.0
SCHLUMBERGER	J55	C390606	06-25-02	100.0	99.7	99.8
SCHLUMBERGER	J55	C390607	06-25-02	100.0	99.6	100.2
SCHLUMBERGER	J55	C391708	08-01-02	100.1	100.2	100.1
SCHLUMBERGER	J55	C391709	08-01-02	100.1	99.7	99.8
SCHLUMBERGER	J55	C391710	08-01-02	100.0	99.7	99.8
SCHLUMBERGER	J55	C391711	08-01-02	100.0	99.9	100.0
SCHLUMBERGER	J55	C391712	08-01-02	99.9	99.7	99.7
SCHLUMBERGER	J55	C391713	08-01-02	100.1	99.9	99.7
SCHLUMBERGER	J55	C391714	08-01-02	99.9	100.2	99.7
SCHLUMBERGER	J55	C391715	08-01-02	100.0	99.6	99.9
SCHLUMBERGER	J55	C391716	08-01-02	100.1	100.0	99.6
SCHLUMBERGER	J55	C391717	08-01-02	100.0	99.8	100.3
SCHLUMBERGER	J55	C391718	08-01-02	99.9	100.0	99.3
SCHLUMBERGER	J55	C391719	08-01-02	99.9	99.9	100.1

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	J55	C391720	08-01-02	100.2	99.9	100.3
SCHLUMBERGER	J55	C391721	08-01-02	99.8	99.9	99.5
SCHLUMBERGER	J55	C391722	08-01-02	100.1	99.7	100.3
SCHLUMBERGER	J55	C391723	08-01-02	99.9	100.0	99.6
SCHLUMBERGER	J55	C391724	08-01-02	100.1	99.9	99.7
SCHLUMBERGER	J55	C391725	08-01-02	100.1	100.2	99.6
SCHLUMBERGER	J55	C391726	08-01-02	99.8	100.1	99.6
SCHLUMBERGER	J55	C391727	08-01-02	100.1	99.7	99.9
SCHLUMBERGER	J55	C391728	08-01-02	99.8	99.8	99.5
SCHLUMBERGER	J55	C391729	08-01-02	100.0	100.2	100.2
SCHLUMBERGER	J55	C391730	08-01-02	99.9	100.2	99.8
SCHLUMBERGER	J55	C391731	08-01-02	100.1	100.0	100.1
SCHLUMBERGER	J55	C391732	08-01-02	100.1	99.8	100.2
SCHLUMBERGER	J55	C391733	08-01-02	100.1	100.0	100.2
SCHLUMBERGER	J55	C391734	08-01-02	100.1	100.1	100.4
SCHLUMBERGER	J55	C391735	08-01-02	100.1	100.1	99.8
SCHLUMBERGER	J55	C391736	08-01-02	100.0	99.8	99.8
SCHLUMBERGER	J55	C391737	08-01-02	100.0	99.7	99.7
SCHLUMBERGER	J55	C391738	08-01-02	100.0	100.1	100.0
SCHLUMBERGER	J55	C391739	08-01-02	100.1	100.1	99.9
SCHLUMBERGER	J55	C391740	08-01-02	100.1	100.5	100.1
SCHLUMBERGER	J55	C391741	08-01-02	99.8	99.9	99.8
SCHLUMBERGER	J55	C391742	08-01-02	100.1	99.9	100.0
SCHLUMBERGER	J55	C391743	08-01-02	100.2	99.8	100.1
SCHLUMBERGER	J55	C391744	08-01-02	100.0	100.1	99.9
SCHLUMBERGER	J55	C391745	08-01-02	100.0	99.9	100.5
SCHLUMBERGER	J55	C391746	08-01-02	99.8	100.0	99.7
SCHLUMBERGER	J55	C391747	08-01-02	100.1	100.0	99.7
SCHLUMBERGER	J55	C391748	08-01-02	100.0	99.7	100.1
SCHLUMBERGER	J55	C391749	08-01-02	100.0	100.4	99.9
SCHLUMBERGER	J55	C391750	08-01-02	100.3	100.1	100.3
SCHLUMBERGER	J55	C391751	08-01-02	99.9	99.9	99.5
SCHLUMBERGER	J55	C391752	08-01-02	100.1	99.7	100.1
SCHLUMBERGER	J55	C391753	08-01-02	100.2	99.7	99.3
SCHLUMBERGER	J55	C391754	08-01-02	100.0	100.0	99.6
SCHLUMBERGER	J55	C391755	08-01-02	99.9	99.8	99.6
SCHLUMBERGER	J55	C391756	08-01-02	99.9	100.2	99.9
SCHLUMBERGER	J55	C391757	08-01-02	99.9	100.1	100.1
SCHLUMBERGER	J55	C391758	08-01-02	100.2	100.1	99.6
SCHLUMBERGER	J55	C391759	08-01-02	99.9	99.7	99.7
SCHLUMBERGER	J55	C391760	08-01-02	99.9	99.6	99.7
SCHLUMBERGER	J55	C391761	08-01-02	100.0	99.7	100.5
SCHLUMBERGER	J55	C391762	08-01-02	100.3	99.7	99.7
SCHLUMBERGER	J55	C391763	08-01-02	100.1	99.9	99.7
SCHLUMBERGER	J55	C391764	08-01-02	99.9	100.2	100.3
SCHLUMBERGER	J55	C391765	08-01-02	100.1	99.6	99.9
SCHLUMBERGER	J55	C391766	08-01-02	100.1	100.0	100.1
SCHLUMBERGER	J55	C391767	08-01-02	99.9	99.9	100.0
SCHLUMBERGER	J55	C391768	08-01-02	99.9	99.8	100.0
SCHLUMBERGER	J55	C391769	08-01-02	100.1	100.0	100.3
SCHLUMBERGER	J55	C391770	08-01-02	100.1	100.0	100.1

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	J55	C391771	08-01-02	100.2	100.1	99.7
SCHLUMBERGER	J55	C391772	08-01-02	100.1	100.1	99.9
SCHLUMBERGER	J55	C391773	08-01-02	100.0	99.9	99.5
SCHLUMBERGER	J55	C391774	08-01-02	100.3	100.2	100.0
SCHLUMBERGER	J55	C391775	08-01-02	100.3	100.0	100.1
SCHLUMBERGER	J55	C391776	08-01-02	100.1	99.9	99.8
SCHLUMBERGER	J55	C391777	08-01-02	100.1	100.0	99.6
SCHLUMBERGER	J55	C391778	08-01-02	100.1	100.4	100.1
SCHLUMBERGER	J55	C391779	08-01-02	100.1	99.7	99.9
SCHLUMBERGER	J55	C391780	08-01-02	100.1	100.2	99.9
SCHLUMBERGER	J55	C391781	08-01-02	100.3	99.8	100.3
SCHLUMBERGER	J55	C391782	08-01-02	100.3	100.0	99.9
SCHLUMBERGER	J55	C391783	08-01-02	99.9	99.8	99.9
SCHLUMBERGER	J55	C391784	08-01-02	99.9	99.9	100.1
SCHLUMBERGER	J55	C391785	08-01-02	99.9	99.9	100.1
SCHLUMBERGER	J55	C391786	08-01-02	100.0	99.6	99.9
SCHLUMBERGER	J55	C391787	08-01-02	100.1	99.7	99.7
SCHLUMBERGER	J55	C391788	08-01-02	100.3	100.3	100.2
SCHLUMBERGER	J55	C391789	08-01-02	100.1	100.1	100.0
SCHLUMBERGER	J55	C391790	08-01-02	100.0	99.9	100.0
SCHLUMBERGER	J55	C391791	08-01-02	100.0	99.8	99.8
SCHLUMBERGER	J55	C391792	08-01-02	100.0	99.8	99.7
SCHLUMBERGER	J55	C391793	08-01-02	100.2	99.7	99.7
SCHLUMBERGER	J55	C391794	08-01-02	100.0	99.9	100.4
SCHLUMBERGER	J55	C391795	08-01-02	100.0	99.9	99.5
SCHLUMBERGER	J55	C391796	08-01-02	99.8	99.9	100.1
SCHLUMBERGER	J55	C391797	08-01-02	99.9	99.7	100.7
SCHLUMBERGER	J55	C391798	08-01-02	100.0	100.0	99.4
SCHLUMBERGER	J55	C391799	08-01-02	99.8	99.8	99.5
SCHLUMBERGER	J55	C391800	08-01-02	100.2	99.7	100.3
SCHLUMBERGER	J55	C391801	08-01-02	100.2	100.4	100.1
SCHLUMBERGER	J55	C391802	08-01-02	100.0	99.8	100.2
SCHLUMBERGER	J55	C391803	08-01-02	100.0	99.8	99.6
SCHLUMBERGER	J55	C391804	08-01-02	100.0	100.2	100.1
SCHLUMBERGER	J55	C391805	08-01-02	100.0	99.7	100.0
SCHLUMBERGER	J55	C391806	08-01-02	99.8	99.7	99.4
SCHLUMBERGER	J55	C391807	08-01-02	100.1	100.1	100.1
SCHLUMBERGER	J55	C391808	08-01-02	100.2	99.9	100.1
SCHLUMBERGER	J55	C391809	08-01-02	100.1	99.9	99.9
SCHLUMBERGER	J55	C391810	08-01-02	100.0	99.7	99.8
SCHLUMBERGER	J55	C391811	08-01-02	100.0	99.7	99.6
SCHLUMBERGER	J55	C391812	08-01-02	100.2	100.0	100.2
SCHLUMBERGER	J55	C391813	08-01-02	100.0	99.5	99.5
SCHLUMBERGER	J55	C391814	08-01-02	100.0	99.7	99.3
SCHLUMBERGER	J55	C391815	08-01-02	100.1	100.4	99.8
SCHLUMBERGER	J55	C391816	08-01-02	100.1	100.2	99.8
SCHLUMBERGER	J55	C391817	08-01-02	100.1	100.0	100.0
SCHLUMBERGER	J55	C391818	08-01-02	100.1	99.8	99.6
SCHLUMBERGER	J55	C391819	08-01-02	99.9	99.7	99.6
SCHLUMBERGER	J55	C391820	08-01-02	99.9	100.0	99.6
SCHLUMBERGER	J55	C391821	08-01-02	100.0	100.3	100.5

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

PAGE 138
 RUN DATE: 1/14/03
 RUN TIME: 13.26.53

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	J5S	C391822	08-01-02	99.9	99.7	99.8
SCHLUMBERGER	J5S	C391823	08-01-02	100.2	99.9	99.6
SCHLUMBERGER	J5S	C391824	08-01-02	100.0	100.3	100.4
SCHLUMBERGER	J5S	C391825	08-01-02	100.2	99.7	100.3
SCHLUMBERGER	J5S	C391826	08-01-02	99.9	100.4	100.2
SCHLUMBERGER	J5S	C391827	08-01-02	99.9	99.7	100.1
SCHLUMBERGER	J5S	C391828	08-01-02	99.9	99.9	100.0
SCHLUMBERGER	J5S	C391829	08-01-02	100.1	100.0	99.5
SCHLUMBERGER	J5S	C391830	08-01-02	100.0	99.9	99.8
SCHLUMBERGER	J5S	C391831	08-01-02	100.2	99.8	100.5
SCHLUMBERGER	J5S	C391832	08-01-02	100.1	99.9	100.3
SCHLUMBERGER	J5S	C391833	08-01-02	100.3	99.8	100.1
SCHLUMBERGER	J5S	C391834	08-01-02	100.1	99.8	99.8
SCHLUMBERGER	J5S	C391835	08-01-02	99.9	99.7	99.8
SCHLUMBERGER	J5S	C391836	08-01-02	100.1	99.9	99.9
SCHLUMBERGER	J5S	C391837	08-01-02	100.2	100.3	99.8
SCHLUMBERGER	J5S	C391838	08-01-02	99.8	99.8	99.8
SCHLUMBERGER	J5S	C391839	08-01-02	100.2	99.9	99.9
SCHLUMBERGER	J5S	C391840	08-01-02	100.2	100.1	100.0
SCHLUMBERGER	J5S	C391841	08-01-02	100.1	99.8	100.1
SCHLUMBERGER	J5S	C391842	08-01-02	100.0	99.8	99.8
SCHLUMBERGER	J5S	C391843	08-01-02	99.9	99.9	100.1
SCHLUMBERGER	J5S	C391844	08-01-02	100.0	100.2	100.1
SCHLUMBERGER	J5S	C391845	08-01-02	99.9	99.8	100.2
SCHLUMBERGER	J5S	C391846	08-01-02	100.0	99.6	100.3
SCHLUMBERGER	J5S	C391847	08-01-02	100.1	100.4	100.0
SCHLUMBERGER	J5S	C391848	08-01-02	100.1	99.6	100.0
SCHLUMBERGER	J5S	C391849	08-01-02	100.1	99.7	99.3
SCHLUMBERGER	J5S	C391850	08-01-02	100.1	99.8	99.5
SCHLUMBERGER	J5S	C391851	08-01-02	99.9	99.6	99.9
SCHLUMBERGER	J5S	C391852	08-01-02	100.2	99.9	99.6
SCHLUMBERGER	J5S	C391853	08-01-02	100.0	99.7	100.0
SCHLUMBERGER	J5S	C391854	08-01-02	100.1	99.9	99.9
SCHLUMBERGER	J5S	C391855	08-01-02	99.9	100.3	99.9
SCHLUMBERGER	J5S	C391856	08-01-02	100.0	100.0	99.9
SCHLUMBERGER	J5S	C391857	08-01-02	100.1	99.7	100.0
SCHLUMBERGER	J5S	C391858	08-01-02	100.1	100.3	100.0
SCHLUMBERGER	J5S	C391859	08-01-02	99.8	99.8	99.8
SCHLUMBERGER	J5S	C391860	08-01-02	99.9	100.2	100.1
SCHLUMBERGER	J5S	C391861	08-01-02	100.3	99.9	99.8
SCHLUMBERGER	J5S	C391862	08-01-02	100.1	100.0	99.9
SCHLUMBERGER	J5S	C391863	08-01-02	99.9	99.7	99.6
SCHLUMBERGER	J5S	C391864	08-01-02	100.0	100.0	99.7
SCHLUMBERGER	J5S	C391865	08-01-02	99.9	100.1	99.8
SCHLUMBERGER	J5S	C391866	08-01-02	100.0	100.3	99.9
SCHLUMBERGER	J5S	C391867	08-01-02	100.2	100.5	99.7
SCHLUMBERGER	J5S	C391868	08-01-02	99.9	100.2	99.8
SCHLUMBERGER	J5S	C391869	08-01-02	99.8	100.2	100.0
SCHLUMBERGER	J5S	C391870	08-01-02	100.1	100.2	100.0
SCHLUMBERGER	J5S	C391871	08-01-02	100.1	99.9	99.5
SCHLUMBERGER	J5S	C391872	08-01-02	100.0	100.3	100.0

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

PAGE 139
 RUN DATE: 1/14/03
 RUN TIME: 13.26.53

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	J55	C391873	08-01-02	100.2	100.0	99.8
SCHLUMBERGER	J55	C391874	08-01-02	100.1	100.3	99.8
SCHLUMBERGER	J55	C391875	08-01-02	100.0	100.0	100.1
SCHLUMBERGER	J55	C391876	08-01-02	99.9	99.8	99.4
SCHLUMBERGER	J55	C391877	08-01-02	100.1	99.7	99.7
SCHLUMBERGER	J55	C391878	08-01-02	100.2	100.0	100.3
SCHLUMBERGER	J55	C391879	08-01-02	100.0	99.9	100.0
SCHLUMBERGER	J55	C391880	08-01-02	99.9	99.8	100.0
SCHLUMBERGER	J55	C391881	08-01-02	100.2	99.8	99.5
SCHLUMBERGER	J55	C391882	08-01-02	100.3	100.2	100.0
SCHLUMBERGER	J55	C391883	08-01-02	99.9	100.1	99.5
SCHLUMBERGER	J55	C391884	08-01-02	100.0	100.1	99.6
SCHLUMBERGER	J55	C391885	08-01-02	100.0	99.8	100.5
SCHLUMBERGER	J55	C391886	08-01-02	100.2	100.4	100.5
SCHLUMBERGER	J55	C391887	08-01-02	100.2	100.4	99.4
SCHLUMBERGER	J55	C391888	08-01-02	100.1	100.0	99.5
SCHLUMBERGER	J55	C391889	08-01-02	100.0	99.8	100.1
SCHLUMBERGER	J55	C391890	08-01-02	100.0	100.2	99.7
SCHLUMBERGER	J55	C391891	08-01-02	100.1	99.8	99.7
SCHLUMBERGER	J55	C391892	08-01-02	100.0	99.8	100.0
SCHLUMBERGER	J55	C391893	08-01-02	100.0	99.8	99.8
SCHLUMBERGER	J55	C391894	08-01-02	100.2	100.1	99.8
SCHLUMBERGER	J55	C391895	08-01-02	100.1	99.7	99.6
SCHLUMBERGER	J55	C391896	08-01-02	99.9	99.9	99.9
SCHLUMBERGER	J55	C391897	08-01-02	100.3	100.3	100.3
SCHLUMBERGER	J55	C391898	08-01-02	100.3	99.7	100.2
SCHLUMBERGER	J55	C391899	08-01-02	99.9	99.7	99.5
SCHLUMBERGER	J55	C391900	08-01-02	100.1	99.8	99.8
SCHLUMBERGER	J55	C391901	08-01-02	100.0	100.3	100.1
SCHLUMBERGER	J55	C391902	08-01-02	100.1	99.8	99.8
SCHLUMBERGER	J55	C391903	08-01-02	100.1	100.3	100.1
SCHLUMBERGER	J55	C391904	08-01-02	100.3	99.6	99.9
SCHLUMBERGER	J55	C391905	08-01-02	99.9	99.9	100.0
SCHLUMBERGER	J55	C391906	08-01-02	100.1	99.9	100.3
SCHLUMBERGER	J55	C391907	08-01-02	99.9	99.6	99.8
SCHLUMBERGER	J55	C391908	08-01-02	100.2	100.0	99.9
SCHLUMBERGER	J55	C391909	08-01-02	100.2	100.2	100.1
SCHLUMBERGER	J55	C391910	08-01-02	100.2	99.8	100.3
SCHLUMBERGER	J55	C391911	08-01-02	100.0	99.7	100.1
SCHLUMBERGER	J55	C391912	08-01-02	99.8	99.8	100.0
SCHLUMBERGER	J55	C391913	08-01-02	100.0	99.7	100.3
SCHLUMBERGER	J55	C391914	08-01-02	100.0	100.0	99.7
SCHLUMBERGER	J55	C391915	08-01-02	100.0	100.0	99.9
SCHLUMBERGER	J55	C391916	08-01-02	100.2	99.8	99.6
SCHLUMBERGER	J55	C391917	08-01-02	100.0	100.0	100.0
SCHLUMBERGER	J55	C391918	08-01-02	99.8	99.6	99.8
SCHLUMBERGER	J55	C391919	08-01-02	100.2	100.1	99.9
SCHLUMBERGER	J55	C391920	08-01-02	100.0	99.7	100.2
SCHLUMBERGER	J55	C391921	08-01-02	99.9	99.7	99.8
SCHLUMBERGER	J55	C391922	08-01-02	100.0	100.1	99.9
SCHLUMBERGER	J55	C391923	08-01-02	100.1	100.1	100.1

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	J55	C391924	08-01-02	100.0	99.9	100.1
SCHLUMBERGER	J55	C391925	08-01-02	100.1	99.9	99.8
SCHLUMBERGER	J55	C391926	08-01-02	99.9	99.7	99.8
SCHLUMBERGER	J55	C391927	08-01-02	99.9	99.8	99.6
SCHLUMBERGER	J55	C391928	08-01-02	100.2	99.6	99.9
SCHLUMBERGER	J55	C391929	08-01-02	100.1	100.0	99.7
SCHLUMBERGER	J55	C391930	08-01-02	100.0	100.5	99.9
SCHLUMBERGER	J55	C391931	08-01-02	100.0	99.8	99.5
SCHLUMBERGER	J55	C391932	08-01-02	99.9	99.8	100.1
SCHLUMBERGER	J55	C391933	08-01-02	100.1	99.9	99.8
SCHLUMBERGER	J55	C391934	08-01-02	100.1	99.8	99.8
SCHLUMBERGER	J55	C391935	08-01-02	100.2	99.9	99.8
SCHLUMBERGER	J55	C391936	08-01-02	100.0	100.0	100.2
SCHLUMBERGER	J55	C391937	08-01-02	99.9	99.8	100.1
SCHLUMBERGER	J55	C391938	08-01-02	100.1	100.0	100.0
SCHLUMBERGER	J55	C391939	08-01-02	100.2	100.1	100.0
SCHLUMBERGER	J55	C391940	08-01-02	99.9	99.7	99.3
SCHLUMBERGER	J55	C391941	08-01-02	100.0	100.3	99.9
SCHLUMBERGER	J55	C391942	08-01-02	100.0	99.7	100.0
SCHLUMBERGER	J55	C391943	08-01-02	100.1	99.9	99.5
SCHLUMBERGER	J55	C391944	08-01-02	100.3	100.1	100.2
SCHLUMBERGER	J55	C391945	08-01-02	99.9	100.0	99.7
SCHLUMBERGER	J55	C391946	08-01-02	100.2	99.9	99.9
SCHLUMBERGER	J55	C391947	08-01-02	100.1	100.1	100.0
SCHLUMBERGER	J55	C391948	08-01-02	100.0	100.3	99.8
SCHLUMBERGER	J55	C391949	08-01-02	100.2	100.0	99.6
SCHLUMBERGER	J55	C391950	08-01-02	100.0	99.9	99.8
SCHLUMBERGER	J55	C391951	08-01-02	99.8	99.6	99.9
SCHLUMBERGER	J55	C391952	08-01-02	100.2	100.0	100.1
SCHLUMBERGER	J55	C391953	08-01-02	99.9	100.1	99.7
SCHLUMBERGER	J55	C391954	08-01-02	100.3	99.9	99.8
SCHLUMBERGER	J55	C391955	08-01-02	99.9	100.2	99.7
SCHLUMBERGER	J55	C391956	08-01-02	100.0	99.9	100.3
SCHLUMBERGER	J55	C391957	08-01-02	100.1	99.6	99.9
SCHLUMBERGER	J55	C391958	08-01-02	100.1	99.8	99.9
SCHLUMBERGER	J55	C391959	08-01-02	100.2	99.8	99.9
SCHLUMBERGER	J55	C391960	08-01-02	100.1	100.0	99.8
SCHLUMBERGER	J55	C391961	08-01-02	100.2	100.0	100.1
SCHLUMBERGER	J55	C391962	08-01-02	100.1	100.2	100.1
SCHLUMBERGER	J55	C391963	08-01-02	99.9	99.7	99.7
SCHLUMBERGER	J55	C391964	08-01-02	100.0	99.7	99.6
SCHLUMBERGER	J55	C391965	08-01-02	100.2	100.2	99.8
SCHLUMBERGER	J55	C391966	08-01-02	100.1	100.2	100.2
SCHLUMBERGER	J55	C391967	08-01-02	100.0	99.7	100.4
SCHLUMBERGER	J55	C391968	08-01-02	100.0	99.8	99.9
SCHLUMBERGER	J55	C391969	08-01-02	99.9	99.9	99.6
SCHLUMBERGER	J55	C391970	08-01-02	100.0	100.0	100.5
SCHLUMBERGER	J55	C391971	08-01-02	99.9	99.7	99.5
SCHLUMBERGER	J55	C391972	08-01-02	99.9	100.0	100.1
SCHLUMBERGER	J55	C391973	08-01-02	99.9	99.6	99.9
SCHLUMBERGER	J55	C391974	08-01-02	100.1	100.1	99.8

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	J55	C391975	08-01-02	100.1	99.9	100.2
SCHLUMBERGER	J55	C391976	08-01-02	100.0	99.9	100.8
SCHLUMBERGER	J55	C391977	08-01-02	100.0	100.2	99.8
SCHLUMBERGER	J55	C391978	08-01-02	100.1	99.8	99.9
SCHLUMBERGER	J55	C391979	08-01-02	99.9	99.8	99.8
SCHLUMBERGER	J55	C391980	08-01-02	100.1	99.8	100.2
SCHLUMBERGER	J55	C391981	08-01-02	100.1	100.0	100.1
SCHLUMBERGER	J55	C391982	08-01-02	100.3	100.3	100.3
SCHLUMBERGER	J55	C391983	08-01-02	100.3	100.4	100.4
SCHLUMBERGER	J55	C391984	08-01-02	100.1	99.7	100.2
SCHLUMBERGER	J55	C391985	08-01-02	100.2	100.2	100.3
SCHLUMBERGER	J55	C391986	08-01-02	100.0	100.1	100.1
SCHLUMBERGER	J55	C391987	08-01-02	100.0	99.7	99.6
SCHLUMBERGER	J55	C391988	07-31-02	100.1	99.8	100.0
SCHLUMBERGER	J55	C391989	08-01-02	100.2	99.8	100.0
SCHLUMBERGER	J55	C391990	08-01-02	100.0	100.2	99.9
SCHLUMBERGER	J55	C391991	08-01-02	100.2	99.9	99.8
SCHLUMBERGER	J55	C391992	08-01-02	100.0	99.9	99.5
SCHLUMBERGER	J55	C391993	08-01-02	100.0	99.8	100.0
SCHLUMBERGER	J55	C391994	07-31-02	99.8	100.1	100.2
SCHLUMBERGER	J55	C391995	07-31-02	100.2	99.8	100.2
SCHLUMBERGER	J55	C391996	07-31-02	100.2	99.8	99.4
SCHLUMBERGER	J55	C391997	07-31-02	99.9	99.9	100.0
SCHLUMBERGER	J55	C391998	07-31-02	100.1	100.0	99.8
SCHLUMBERGER	J55	C391999	07-31-02	100.1	99.8	100.1
SCHLUMBERGER	J55	C392000	07-31-02	100.1	100.1	99.9
SCHLUMBERGER	J55	C392001	07-31-02	100.2	100.3	100.0
SCHLUMBERGER	J55	C392002	07-31-02	99.8	99.7	99.7
SCHLUMBERGER	J55	C392003	07-31-02	100.1	100.3	100.2
SCHLUMBERGER	J55	C392004	07-31-02	100.0	100.0	99.9
SCHLUMBERGER	J55	C392005	07-31-02	100.2	99.8	99.8
SCHLUMBERGER	J55	C392006	07-31-02	99.9	99.7	99.7
SCHLUMBERGER	J55	C392007	07-31-02	100.0	100.1	100.3
SCHLUMBERGER	J55	C392008	07-31-02	100.0	99.7	99.9
SCHLUMBERGER	J55	C392009	07-31-02	100.0	99.9	99.9
SCHLUMBERGER	J55	C392010	07-31-02	100.0	100.1	99.6
SCHLUMBERGER	J55	C392011	07-31-02	100.1	100.2	99.8
SCHLUMBERGER	J55	C392012	07-31-02	99.9	100.0	100.0
SCHLUMBERGER	J55	C392013	07-31-02	100.0	99.8	100.1
SCHLUMBERGER	J55	C392014	07-31-02	100.0	100.1	99.9
SCHLUMBERGER	J55	C392015	07-31-02	100.1	100.4	99.8
SCHLUMBERGER	J55	C392016	07-31-02	100.1	99.8	99.8
SCHLUMBERGER	J55	C392017	07-31-02	99.8	99.8	99.9
SCHLUMBERGER	J55	C392018	07-31-02	99.9	99.7	100.0
SCHLUMBERGER	J55	C392019	07-31-02	100.0	100.3	99.8
SCHLUMBERGER	J55	C392020	07-31-02	100.2	99.7	99.6
SCHLUMBERGER	J55	C392021	07-31-02	100.1	100.0	100.2
SCHLUMBERGER	J55	C392022	07-31-02	100.0	100.1	100.1
SCHLUMBERGER	J55	C392023	07-31-02	99.8	99.8	99.8
SCHLUMBERGER	J55	C392024	07-31-02	100.0	100.0	100.5
SCHLUMBERGER	J55	C392025	07-31-02	100.1	99.8	100.0

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

PAGE 142
 RUN DATE: 1/14/03
 RUN TIME: 13.26.53

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	J5S	C392026	07-31-02	99.9	99.6	99.9
SCHLUMBERGER	J5S	C392027	07-31-02	100.1	99.6	99.8
SCHLUMBERGER	J5S	C392028	07-31-02	100.3	100.0	100.2
SCHLUMBERGER	J5S	C392029	07-31-02	100.1	100.0	99.5
SCHLUMBERGER	J5S	C392030	07-31-02	100.2	99.7	99.4
SCHLUMBERGER	J5S	C392031	07-31-02	100.2	100.4	99.9
SCHLUMBERGER	J5S	C392032	07-31-02	100.2	99.9	100.3
SCHLUMBERGER	J5S	C392033	07-31-02	100.2	100.0	100.0
SCHLUMBERGER	J5S	C392034	07-31-02	99.9	100.0	100.1
SCHLUMBERGER	J5S	C392035	07-31-02	100.0	99.7	100.0
SCHLUMBERGER	J5S	C392036	07-31-02	99.9	100.0	100.1
SCHLUMBERGER	J5S	C392037	07-31-02	100.0	99.7	99.9
SCHLUMBERGER	J5S	C392038	07-31-02	99.8	100.3	100.3
SCHLUMBERGER	J5S	C392039	07-31-02	100.1	100.2	100.2
SCHLUMBERGER	J5S	C392040	07-31-02	100.2	100.1	100.4
SCHLUMBERGER	J5S	C392041	07-31-02	100.2	99.7	100.1
SCHLUMBERGER	J5S	C392042	07-31-02	100.0	100.0	99.4
SCHLUMBERGER	J5S	C392043	07-31-02	100.2	100.1	100.4
SCHLUMBERGER	J5S	C392044	07-31-02	100.0	100.1	100.0
SCHLUMBERGER	J5S	C392045	07-31-02	100.2	99.7	100.3
SCHLUMBERGER	J5S	C392046	07-31-02	99.9	100.1	99.9
SCHLUMBERGER	J5S	C392047	07-31-02	100.1	99.7	100.1
SCHLUMBERGER	J5S	C392048	07-31-02	99.8	99.8	99.7
SCHLUMBERGER	J5S	C392049	07-31-02	100.2	100.3	100.1
SCHLUMBERGER	J5S	C392050	07-31-02	100.3	99.9	100.1
SCHLUMBERGER	J5S	C392051	07-31-02	100.1	100.0	100.1
SCHLUMBERGER	J5S	C392052	07-31-02	100.1	100.0	100.1
SCHLUMBERGER	J5S	C392053	07-31-02	100.0	99.9	100.3
SCHLUMBERGER	J5S	C392054	07-31-02	100.1	100.1	99.8
SCHLUMBERGER	J5S	C392055	07-31-02	100.0	100.1	100.0
SCHLUMBERGER	J5S	C392056	07-31-02	100.2	99.9	100.2
SCHLUMBERGER	J5S	C392057	07-31-02	100.1	100.1	100.2
SCHLUMBERGER	J5S	C392058	07-31-02	100.2	99.7	99.8
SCHLUMBERGER	J5S	C392059	07-31-02	100.1	99.9	100.1
SCHLUMBERGER	J5S	C392060	07-31-02	100.2	100.0	100.4
SCHLUMBERGER	J5S	C392061	07-31-02	100.1	99.8	99.8
SCHLUMBERGER	J5S	C392062	07-31-02	100.1	100.4	100.6
SCHLUMBERGER	J5S	C392063	07-31-02	100.1	100.2	100.4
SCHLUMBERGER	J5S	C392064	07-31-02	100.2	99.8	100.5
SCHLUMBERGER	J5S	C392065	07-31-02	100.0	100.2	100.1
SCHLUMBERGER	J5S	C392066	07-31-02	100.1	100.3	100.7
SCHLUMBERGER	J5S	C392067	07-31-02	100.1	100.3	100.2
SCHLUMBERGER	J5S	C392068	07-31-02	100.1	100.0	99.8
SCHLUMBERGER	J5S	C392069	07-31-02	100.2	100.0	100.0
SCHLUMBERGER	J5S	C392070	07-31-02	99.9	99.9	99.9
SCHLUMBERGER	J5S	C392071	07-31-02	99.9	99.7	99.8
SCHLUMBERGER	J5S	C392072	07-31-02	100.1	99.8	99.8
SCHLUMBERGER	J5S	C392073	07-31-02	100.0	99.7	100.0
SCHLUMBERGER	J5S	C392074	07-31-02	100.0	99.8	99.9
SCHLUMBERGER	J5S	C392075	07-31-02	100.1	100.2	100.0
SCHLUMBERGER	J5S	C392076	07-31-02	100.1	100.3	100.2

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	J55	C392077	07-31-02	100.2	99.9	100.2
SCHLUMBERGER	J55	C392078	07-31-02	100.0	100.1	100.8
SCHLUMBERGER	J55	C392079	07-31-02	100.1	99.9	100.8
SCHLUMBERGER	J55	C392080	07-31-02	100.1	99.9	99.9
SCHLUMBERGER	J55	C392081	07-31-02	100.1	100.1	100.0
SCHLUMBERGER	J55	C392082	07-31-02	100.0	99.8	100.2
SCHLUMBERGER	J55	C392083	07-31-02	99.8	100.1	100.0
SCHLUMBERGER	J55	C392084	07-31-02	100.0	100.1	100.0
SCHLUMBERGER	J55	C392085	07-31-02	100.1	99.9	100.4
SCHLUMBERGER	J55	C392086	07-31-02	100.2	100.0	100.4
SCHLUMBERGER	J55	C392087	07-31-02	100.0	99.9	100.2
SCHLUMBERGER	J55	C392088	07-31-02	100.2	99.6	100.3
SCHLUMBERGER	J55	C392089	07-31-02	100.1	100.4	100.3
SCHLUMBERGER	J55	C392090	07-31-02	99.9	100.3	100.1
SCHLUMBERGER	J55	C392091	07-31-02	100.1	99.8	99.8
SCHLUMBERGER	J55	C392092	07-31-02	100.1	100.3	99.6
SCHLUMBERGER	J55	C392093	07-31-02	99.9	99.6	99.9
SCHLUMBERGER	J55	C392094	07-31-02	99.8	99.8	100.0
SCHLUMBERGER	J55	C392095	07-31-02	100.1	99.9	100.1
SCHLUMBERGER	J55	C392096	07-31-02	99.8	100.0	100.2
SCHLUMBERGER	J55	C392097	07-31-02	100.0	99.7	100.1
SCHLUMBERGER	J55	C392098	07-31-02	100.1	99.9	100.4
SCHLUMBERGER	J55	C392099	07-31-02	100.0	99.7	100.2
SCHLUMBERGER	J55	C392100	07-31-02	100.1	100.0	99.9
SCHLUMBERGER	J55	C392101	07-31-02	99.8	99.9	100.3
SCHLUMBERGER	J55	C392102	07-31-02	100.1	100.2	99.7
SCHLUMBERGER	J55	C392103	07-31-02	100.0	99.8	100.4
SCHLUMBERGER	J55	C392104	07-31-02	100.0	100.1	99.8
SCHLUMBERGER	J55	C392105	07-31-02	100.0	99.7	100.0
SCHLUMBERGER	J55	C392106	07-31-02	100.0	100.2	100.1
SCHLUMBERGER	J55	C392107	07-31-02	100.2	99.9	99.8
SCHLUMBERGER	J55	C392108	07-31-02	100.2	100.0	100.6
SCHLUMBERGER	J55	C392109	07-31-02	100.1	99.9	100.3
SCHLUMBERGER	J55	C392110	07-31-02	100.0	100.2	100.2
SCHLUMBERGER	J55	C392111	07-31-02	100.0	100.0	100.2
SCHLUMBERGER	J55	C392112	07-31-02	100.2	99.7	100.4
SCHLUMBERGER	J55	C392113	07-31-02	100.0	100.0	99.6
SCHLUMBERGER	J55	C392114	07-31-02	100.1	100.2	100.1
SCHLUMBERGER	J55	C392115	07-31-02	100.0	99.7	99.6
SCHLUMBERGER	J55	C392116	07-31-02	100.0	99.7	99.6
SCHLUMBERGER	J55	C392117	07-31-02	100.0	99.8	99.8
SCHLUMBERGER	J55	C392118	07-31-02	99.9	100.1	100.3
SCHLUMBERGER	J55	C392119	07-31-02	100.2	100.1	100.3
SCHLUMBERGER	J55	C392120	07-31-02	100.0	100.2	99.8
SCHLUMBERGER	J55	C392121	07-31-02	99.9	100.2	100.0
SCHLUMBERGER	J55	C392122	07-31-02	100.1	99.8	100.3
SCHLUMBERGER	J55	C392123	07-31-02	100.0	99.9	99.9
SCHLUMBERGER	J55	C392124	07-31-02	99.9	100.0	100.0
SCHLUMBERGER	J55	C392125	07-31-02	99.9	99.8	99.9
SCHLUMBERGER	J55	C392126	07-31-02	99.9	99.8	99.6
SCHLUMBERGER	J55	C392127	07-31-02	100.1	100.0	99.7
SCHLUMBERGER	J55	C392127	07-31-02	100.2	99.7	100.5

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

PAGE 144
 RUN DATE: 1/14/03
 RUN TIME: 13.26.53

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	J5S	C392128	07-31-02	100.0	99.9	100.0
SCHLUMBERGER	J5S	C392129	07-31-02	100.0	100.1	100.2
SCHLUMBERGER	J5S	C392130	07-31-02	100.1	100.2	100.2
SCHLUMBERGER	J5S	C392131	07-31-02	100.1	99.7	100.3
SCHLUMBERGER	J5S	C392132	07-31-02	100.1	99.7	100.5
SCHLUMBERGER	J5S	C392133	07-31-02	99.8	100.0	100.3
SCHLUMBERGER	J5S	C392134	07-31-02	99.9	99.8	99.9
SCHLUMBERGER	J5S	C392135	07-31-02	99.9	99.8	100.3
SCHLUMBERGER	J5S	C392136	07-31-02	99.9	99.8	99.6
SCHLUMBERGER	J5S	C392137	07-31-02	100.1	100.0	100.1
SCHLUMBERGER	J5S	C392138	07-31-02	100.1	99.9	99.9
SCHLUMBERGER	J5S	C392139	07-31-02	100.3	99.6	100.2
SCHLUMBERGER	J5S	C392140	07-31-02	99.9	100.2	99.9
SCHLUMBERGER	J5S	C392141	07-31-02	100.1	99.6	100.6
SCHLUMBERGER	J5S	C392142	07-31-02	99.8	99.6	100.1
SCHLUMBERGER	J5S	C392143	07-31-02	100.0	100.5	100.8
SCHLUMBERGER	J5S	C392144	07-31-02	100.0	99.8	99.9
SCHLUMBERGER	J5S	C392145	07-31-02	100.1	99.7	99.8
SCHLUMBERGER	J5S	C392146	07-31-02	100.1	99.7	99.8
SCHLUMBERGER	J5S	C392147	07-31-02	100.2	100.1	100.5
SCHLUMBERGER	J5S	C392148	07-31-02	99.9	99.9	100.5
SCHLUMBERGER	J5S	C392149	07-31-02	100.1	99.8	100.3
SCHLUMBERGER	J5S	C392150	07-31-02	100.0	99.7	100.4
SCHLUMBERGER	J5S	C392151	07-31-02	100.0	99.9	100.1
SCHLUMBERGER	J5S	C392152	07-31-02	99.9	99.8	100.2
SCHLUMBERGER	J5S	C392153	07-31-02	100.3	99.6	100.7
SCHLUMBERGER	J5S	C392154	07-31-02	100.0	99.7	100.0
SCHLUMBERGER	J5S	C392155	07-31-02	100.1	99.8	100.0
SCHLUMBERGER	J5S	C392156	07-31-02	100.2	100.0	100.2
SCHLUMBERGER	J5S	C392157	07-31-02	100.1	99.7	99.8
SCHLUMBERGER	J5S	C392158	07-31-02	99.9	99.7	100.5
SCHLUMBERGER	J5S	C392159	07-31-02	99.9	99.7	99.4
SCHLUMBERGER	J5S	C392160	07-31-02	100.1	100.4	100.1
SCHLUMBERGER	J5S	C392161	07-31-02	100.1	100.0	100.1
SCHLUMBERGER	J5S	C392162	07-31-02	99.9	99.9	100.5
SCHLUMBERGER	J5S	C392163	07-31-02	100.1	99.7	99.6
SCHLUMBERGER	J5S	C392164	07-31-02	100.0	99.9	100.2
SCHLUMBERGER	J5S	C392165	07-31-02	99.8	99.7	100.2
SCHLUMBERGER	J5S	C392166	07-31-02	99.9	100.1	99.7
SCHLUMBERGER	J5S	C392167	07-31-02	100.2	99.8	100.2
SCHLUMBERGER	J5S	C392168	07-31-02	99.9	99.9	100.0
SCHLUMBERGER	J5S	C392169	07-31-02	100.2	99.8	99.8
SCHLUMBERGER	J5S	C392170	07-31-02	100.1	100.1	100.4
SCHLUMBERGER	J5S	C392171	07-31-02	100.0	99.9	99.8
SCHLUMBERGER	J5S	C392172	07-31-02	100.1	99.9	100.1
SCHLUMBERGER	J5S	C392173	07-31-02	99.9	99.9	99.8
SCHLUMBERGER	J5S	C392174	07-31-02	100.1	99.9	100.3
SCHLUMBERGER	J5S	C392175	07-31-02	99.9	99.9	100.0
SCHLUMBERGER	J5S	C392176	07-31-02	99.9	100.0	100.0
SCHLUMBERGER	J5S	C392177	07-31-02	99.9	99.9	99.9
SCHLUMBERGER	J5S	C392178	07-31-02	100.2	99.7	100.3
SCHLUMBERGER	J5S	C392179	07-31-02	100.2	99.7	100.5

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	J55	C392179	07-31-02	100.1	100.1	100.1
SCHLUMBERGER	J55	C392180	07-31-02	99.8	100.0	100.2
SCHLUMBERGER	J55	C392181	07-31-02	100.1	100.2	100.2
SCHLUMBERGER	J55	C392182	07-31-02	100.2	99.7	99.9
SCHLUMBERGER	J55	C392183	07-31-02	100.0	99.8	99.8
SCHLUMBERGER	J55	C392184	07-31-02	100.0	100.1	99.6
SCHLUMBERGER	J55	C392185	07-31-02	99.8	99.9	99.7
SCHLUMBERGER	J55	C392186	07-31-02	100.0	99.6	99.7
SCHLUMBERGER	J55	C392187	07-31-02	100.2	100.1	100.3
SCHLUMBERGER	J55	C392188	07-31-02	99.9	100.0	100.1
SCHLUMBERGER	J55	C392189	07-31-02	100.0	100.1	100.1
SCHLUMBERGER	J55	C392190	07-31-02	99.9	99.6	99.6
SCHLUMBERGER	J55	C392191	07-31-02	100.0	99.7	100.1
SCHLUMBERGER	J55	C392192	07-31-02	100.1	100.2	100.2
SCHLUMBERGER	J55	C392193	07-31-02	99.8	100.0	100.1
SCHLUMBERGER	J55	C392194	07-31-02	100.2	100.0	100.8
SCHLUMBERGER	J55	C392195	07-31-02	100.0	100.0	100.1
SCHLUMBERGER	J55	C392196	07-31-02	99.9	100.1	99.9
SCHLUMBERGER	J55	C392197	07-31-02	100.0	99.8	99.9
SCHLUMBERGER	J55	C392198	07-31-02	100.1	100.6	100.6
SCHLUMBERGER	J55	C392199	07-31-02	100.0	99.7	100.1
SCHLUMBERGER	J55	C392200	07-31-02	100.0	99.7	100.2
SCHLUMBERGER	J55	C392201	07-31-02	100.1	100.5	100.8
SCHLUMBERGER	J55	C392202	07-31-02	100.2	100.1	99.6
SCHLUMBERGER	J55	C392203	07-31-02	100.2	99.7	100.3
SCHLUMBERGER	J55	C392204	07-31-02	100.1	99.7	100.4
SCHLUMBERGER	J55	C392205	07-31-02	100.0	99.8	99.9
SCHLUMBERGER	J55	C392206	07-31-02	100.1	99.9	100.0
SCHLUMBERGER	J55	C392207	07-31-02	99.9	99.7	99.8
SCHLUMBERGER	J55	C392208	07-31-02	100.0	99.9	100.3
SCHLUMBERGER	J55	C392209	07-31-02	100.0	99.9	100.0
SCHLUMBERGER	J55	C392210	07-31-02	100.0	99.6	100.6
SCHLUMBERGER	J55	C392211	07-31-02	100.1	99.6	99.5
SCHLUMBERGER	J55	C392212	07-31-02	100.0	100.0	99.9
SCHLUMBERGER	J55	C392213	07-31-02	100.2	99.8	100.2
SCHLUMBERGER	J55	C392214	07-31-02	100.0	99.9	100.7
SCHLUMBERGER	J55	C392215	07-31-02	100.2	99.9	100.7
SCHLUMBERGER	J55	C392216	07-31-02	100.1	100.3	99.8
SCHLUMBERGER	J55	C392217	07-31-02	100.0	100.2	99.6
SCHLUMBERGER	J55	C392218	07-31-02	100.2	99.8	100.2
SCHLUMBERGER	J55	C392219	07-31-02	99.9	99.6	99.7
SCHLUMBERGER	J55	C392220	07-31-02	100.0	100.4	100.0
SCHLUMBERGER	J55	C392221	07-31-02	100.0	99.7	100.3
SCHLUMBERGER	J55	C392222	07-31-02	100.1	100.1	100.0
SCHLUMBERGER	J55	C392223	07-31-02	100.1	99.6	99.7
SCHLUMBERGER	J55	C392224	07-31-02	100.3	100.0	99.9
SCHLUMBERGER	J55	C392225	07-31-02	100.1	100.2	100.7
SCHLUMBERGER	J55	C392226	07-31-02	100.1	99.6	100.3
SCHLUMBERGER	J55	C392227	07-31-02	100.0	100.3	99.3
SCHLUMBERGER	J55	C392228	07-31-02	100.1	100.0	100.3
SCHLUMBERGER	J55	C392229	07-31-02	100.0	100.0	100.0

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

PAGE 146
 RUN DATE: 1/14/03
 RUN TIME: 13.26.53

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	J55	C392230	07-31-02	100.2	99.8	100.2
SCHLUMBERGER	J55	C392231	07-31-02	100.1	100.3	100.6
SCHLUMBERGER	J55	C392232	07-31-02	100.2	100.0	100.0
SCHLUMBERGER	J55	C392233	07-31-02	99.9	99.9	99.7
SCHLUMBERGER	J55	C392234	07-31-02	100.2	99.7	100.4
SCHLUMBERGER	J55	C392235	07-31-02	100.0	99.8	99.9
SCHLUMBERGER	J55	C392236	07-31-02	100.0	99.6	99.9
SCHLUMBERGER	J55	C392237	07-31-02	100.2	100.1	100.5
SCHLUMBERGER	J55	C392238	07-31-02	100.3	99.9	100.1
SCHLUMBERGER	J55	C392239	07-31-02	100.2	100.1	100.0
SCHLUMBERGER	J55	C392240	07-31-02	100.0	99.6	100.4
SCHLUMBERGER	J55	C392241	07-31-02	100.1	99.9	100.4
SCHLUMBERGER	J55	C392242	07-31-02	100.0	99.8	100.3
SCHLUMBERGER	J55	C392243	07-31-02	99.9	99.7	100.4
SCHLUMBERGER	J55	C392244	07-31-02	100.2	99.7	100.4
SCHLUMBERGER	J55	C392245	07-31-02	99.9	99.7	100.1
SCHLUMBERGER	J55	C392246	07-31-02	100.2	99.9	100.0
SCHLUMBERGER	J55	C392247	07-31-02	100.0	99.7	100.0
SCHLUMBERGER	J55	C392248	07-31-02	100.2	99.6	99.7
SCHLUMBERGER	J55	C392249	07-31-02	100.2	99.6	100.1
SCHLUMBERGER	J55	C392250	07-31-02	100.1	99.9	100.3
SCHLUMBERGER	J55	C392251	07-31-02	100.1	100.0	100.7
SCHLUMBERGER	J55	C392252	07-31-02	99.8	99.6	100.0
SCHLUMBERGER	J55	C392253	07-31-02	100.1	99.8	99.9
SCHLUMBERGER	J55	C392254	07-31-02	100.0	99.8	99.5
SCHLUMBERGER	J55	C392255	07-31-02	100.0	99.8	100.0
SCHLUMBERGER	J55	C392256	07-31-02	99.9	100.2	99.8
SCHLUMBERGER	J55	C392257	07-31-02	100.1	99.9	100.2
SCHLUMBERGER	J55	C392258	07-31-02	99.9	99.9	100.1
SCHLUMBERGER	J55	C392259	07-31-02	100.1	99.9	100.1
SCHLUMBERGER	J55	C392260	07-31-02	99.9	99.9	100.0
SCHLUMBERGER	J55	C392261	07-31-02	100.1	99.9	100.2
SCHLUMBERGER	J55	C392262	07-31-02	100.2	99.9	100.2
SCHLUMBERGER	J55	C392263	07-31-02	100.0	100.0	100.2
SCHLUMBERGER	J55	C392264	07-31-02	100.0	100.2	100.4
SCHLUMBERGER	J55	C392265	07-31-02	99.9	100.2	100.4
SCHLUMBERGER	J55	C392266	07-31-02	100.0	99.8	99.7
SCHLUMBERGER	J55	C392267	07-31-02	100.0	100.0	99.6
SCHLUMBERGER	J55	C392268	07-31-02	100.1	99.8	100.0
SCHLUMBERGER	J55	C392269	07-31-02	100.0	99.8	100.3
SCHLUMBERGER	J55	C392270	07-31-02	100.1	99.9	100.3
SCHLUMBERGER	J55	C392271	07-31-02	99.9	100.1	100.3
SCHLUMBERGER	J55	C392272	07-31-02	99.9	99.7	100.1
SCHLUMBERGER	J55	C392273	07-31-02	100.1	99.9	100.1
SCHLUMBERGER	J55	C392274	07-31-02	100.1	100.0	100.3
SCHLUMBERGER	J55	C392275	07-31-02	100.1	100.0	100.0
SCHLUMBERGER	J55	C392276	07-31-02	100.1	99.8	100.3
SCHLUMBERGER	J55	C392277	07-31-02	100.1	99.9	100.0
SCHLUMBERGER	J55	C392278	07-31-02	100.0	99.8	100.0
SCHLUMBERGER	J55	C392279	07-31-02	100.2	100.2	100.1
SCHLUMBERGER	J55	C392280	07-31-02	100.3	99.7	100.4

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	J55	C392281	07-31-02	99.9	100.0	99.9
SCHLUMBERGER	J55	C392282	07-31-02	100.0	100.0	100.2
SCHLUMBERGER	J55	C392283	07-31-02	99.9	99.6	100.5
SCHLUMBERGER	J55	C392284	07-31-02	99.9	99.7	99.9
SCHLUMBERGER	J55	C392285	07-31-02	100.3	100.2	100.3
SCHLUMBERGER	J55	C392286	07-31-02	100.1	100.1	100.3
SCHLUMBERGER	J55	C392287	07-31-02	100.1	99.7	100.0
SCHLUMBERGER	J55	C392288	07-31-02	100.3	99.9	100.5
SCHLUMBERGER	J55	C392289	07-31-02	100.1	100.0	100.2
SCHLUMBERGER	J55	C392290	07-31-02	100.0	100.4	99.9
SCHLUMBERGER	J55	C392291	07-31-02	99.9	99.9	100.0
SCHLUMBERGER	J55	C392292	07-31-02	100.0	99.8	100.3
SCHLUMBERGER	J55	C392293	07-31-02	100.0	100.2	100.1
SCHLUMBERGER	J55	C392294	07-31-02	99.8	99.8	99.9
SCHLUMBERGER	J55	C392295	07-31-02	100.2	99.8	100.2
SCHLUMBERGER	J55	C392296	07-31-02	100.2	100.0	99.9
SCHLUMBERGER	J55	C392297	07-31-02	100.1	100.0	100.6
SCHLUMBERGER	J55	C392298	07-31-02	100.1	99.7	100.2
SCHLUMBERGER	J55	C392299	07-31-02	100.0	99.9	100.2
SCHLUMBERGER	J55	C392300	07-31-02	100.0	100.1	100.0
SCHLUMBERGER	J55	C392301	07-31-02	100.1	100.1	100.3
SCHLUMBERGER	J55	C392302	07-31-02	100.0	99.8	100.0
SCHLUMBERGER	J55	C392303	07-31-02	100.1	99.9	100.1
SCHLUMBERGER	J55	C392304	07-31-02	100.1	100.1	100.0
SCHLUMBERGER	J55	C392305	07-31-02	100.1	100.2	99.8
SCHLUMBERGER	J55	C392306	07-31-02	100.0	100.0	99.9
SCHLUMBERGER	J55	C392307	07-31-02	100.0	100.2	100.0
SCHLUMBERGER	J55	C392308	07-31-02	100.1	99.8	99.9
SCHLUMBERGER	J55	C392309	07-31-02	100.1	100.3	100.3
SCHLUMBERGER	J55	C392310	07-31-02	100.1	99.9	99.9
SCHLUMBERGER	J55	C392311	07-31-02	100.3	100.0	100.6
SCHLUMBERGER	J55	C392312	07-31-02	100.2	99.9	100.1
SCHLUMBERGER	J55	C392313	07-31-02	99.8	99.8	100.4
SCHLUMBERGER	J55	C392314	07-31-02	100.1	99.8	100.4
SCHLUMBERGER	J55	C392315	07-31-02	100.0	100.0	99.9
SCHLUMBERGER	J55	C392316	07-31-02	100.0	99.8	100.0
SCHLUMBERGER	J55	C392317	07-31-02	100.2	100.0	100.3
SCHLUMBERGER	J55	C392318	07-31-02	100.1	100.3	100.4
SCHLUMBERGER	J55	C392319	07-31-02	100.2	100.4	100.4
SCHLUMBERGER	J55	C392320	07-31-02	100.0	100.2	100.2
SCHLUMBERGER	J55	C392321	07-31-02	99.9	99.8	100.0
SCHLUMBERGER	J55	C392322	07-31-02	100.0	99.7	100.2
SCHLUMBERGER	J55	C392323	07-31-02	100.2	100.0	100.6
SCHLUMBERGER	J55	C392324	07-31-02	100.1	99.8	99.7
SCHLUMBERGER	J55	C392325	07-31-02	99.9	100.1	100.2
SCHLUMBERGER	J55	C392326	07-31-02	99.9	99.6	100.0
SCHLUMBERGER	J55	C392327	07-31-02	99.9	99.8	100.2
SCHLUMBERGER	J55	C392328	07-31-02	100.0	100.2	100.1
SCHLUMBERGER	J55	C392329	07-31-02	100.3	100.1	100.1
SCHLUMBERGER	J55	C392330	07-31-02	100.2	100.1	100.3
SCHLUMBERGER	J55	C392331	07-31-02	100.1	100.4	99.4

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

PAGE 148
 RUN DATE: 1/14/03
 RUN TIME: 13.26.53

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	J55	C392332	07-31-02	100.0	99.7	100.0
SCHLUMBERGER	J55	C392333	07-31-02	100.2	100.1	100.1
SCHLUMBERGER	J55	C392334	07-31-02	100.0	99.8	100.1
SCHLUMBERGER	J55	C392335	07-31-02	100.1	99.9	100.2
SCHLUMBERGER	J55	C392336	07-31-02	100.0	100.3	99.4
SCHLUMBERGER	J55	C392337	07-31-02	100.0	100.3	100.3
SCHLUMBERGER	J55	C392338	07-31-02	100.0	99.7	100.2
SCHLUMBERGER	J55	C392339	07-31-02	99.8	99.8	99.7
SCHLUMBERGER	J55	C392340	07-31-02	100.0	100.1	99.7
SCHLUMBERGER	J55	C392341	07-31-02	100.2	99.7	100.3
SCHLUMBERGER	J55	C392342	07-31-02	100.0	100.0	100.5
SCHLUMBERGER	J55	C392343	07-31-02	100.1	100.2	100.1
SCHLUMBERGER	J55	C392344	07-31-02	100.2	100.3	99.7
SCHLUMBERGER	J55	C392345	07-31-02	100.1	99.7	99.9
SCHLUMBERGER	J55	C392346	07-31-02	100.1	100.0	100.5
SCHLUMBERGER	J55	C392347	07-31-02	100.2	99.9	100.2
SCHLUMBERGER	J55	C392348	07-31-02	100.0	99.8	100.0
SCHLUMBERGER	J55	C392349	07-31-02	100.3	99.8	100.8
SCHLUMBERGER	J55	C392350	07-31-02	99.9	99.7	99.4
SCHLUMBERGER	J55	C392351	07-31-02	100.0	99.9	99.6
SCHLUMBERGER	J55	C392352	07-31-02	99.8	100.0	99.9
SCHLUMBERGER	J55	C392353	07-31-02	100.1	99.9	100.3
SCHLUMBERGER	J55	C392354	07-31-02	100.0	99.6	100.3
SCHLUMBERGER	J55	C392355	07-31-02	100.0	100.0	100.3
SCHLUMBERGER	J55	C392356	07-31-02	100.2	100.1	100.0
SCHLUMBERGER	J55	C392357	07-31-02	100.2	99.7	99.7
SCHLUMBERGER	J55	C392358	07-31-02	99.9	99.9	100.0
SCHLUMBERGER	J55	C392359	07-31-02	100.1	99.8	100.2
SCHLUMBERGER	J55	C392360	07-31-02	100.1	99.8	100.0
SCHLUMBERGER	J55	C392361	07-31-02	100.0	100.0	100.4
SCHLUMBERGER	J55	C392362	07-31-02	100.0	99.6	99.6
SCHLUMBERGER	J55	C392363	07-31-02	100.0	99.6	100.2
SCHLUMBERGER	J55	C392364	07-31-02	100.1	100.2	100.4
SCHLUMBERGER	J55	C392365	07-31-02	100.1	100.2	100.2
SCHLUMBERGER	J55	C392366	07-31-02	100.1	99.8	100.7
SCHLUMBERGER	J55	C392367	07-31-02	100.0	99.9	100.1
SCHLUMBERGER	J55	C392368	07-31-02	100.1	100.0	99.7
SCHLUMBERGER	J55	C392369	07-31-02	100.1	99.9	100.1
SCHLUMBERGER	J55	C392370	07-31-02	100.0	100.2	100.5
SCHLUMBERGER	J55	C392371	07-31-02	99.9	99.9	100.4
SCHLUMBERGER	J55	C392372	07-31-02	100.1	100.1	100.4
SCHLUMBERGER	J55	C392373	07-31-02	100.1	100.2	100.5
SCHLUMBERGER	J55	C392374	07-31-02	100.1	100.0	100.0
SCHLUMBERGER	J55	C392375	07-31-02	100.0	99.8	99.8
SCHLUMBERGER	J55	C392376	07-31-02	100.1	100.2	100.6
SCHLUMBERGER	J55	C392377	07-31-02	99.9	99.7	100.2
SCHLUMBERGER	J55	C392378	07-31-02	100.1	99.9	100.2
SCHLUMBERGER	J55	C392379	07-31-02	100.1	100.2	100.3
SCHLUMBERGER	J55	C392380	07-31-02	100.2	100.1	99.8
SCHLUMBERGER	J55	C392381	07-31-02	100.1	99.9	100.3
SCHLUMBERGER	J55	C392382	07-31-02	100.0	99.9	99.5

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

PAGE 149
 RUN DATE: 1/14/03
 RUN TIME: 13.26.53

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	J55	C392383	07-31-02	100.0	99.8	100.3
SCHLUMBERGER	J55	C392384	07-31-02	100.3	100.0	100.4
SCHLUMBERGER	J55	C392385	07-31-02	100.1	99.9	100.0
SCHLUMBERGER	J55	C392386	07-31-02	100.1	99.8	100.4
SCHLUMBERGER	J55	C392387	07-31-02	100.1	100.2	100.3
SCHLUMBERGER	J55	C392388	07-31-02	100.3	100.0	100.5
SCHLUMBERGER	J55	C392389	07-31-02	99.9	99.7	99.8
SCHLUMBERGER	J55	C392390	07-31-02	100.1	100.1	100.2
SCHLUMBERGER	J55	C392391	07-31-02	100.0	100.1	99.4
SCHLUMBERGER	J55	C392392	07-31-02	100.1	100.2	100.5
SCHLUMBERGER	J55	C392393	07-31-02	100.1	99.9	100.0
SCHLUMBERGER	J55	C392394	07-31-02	99.9	99.7	99.9
SCHLUMBERGER	J55	C392395	07-31-02	99.9	100.0	99.4
SCHLUMBERGER	J55	C392396	07-31-02	100.0	99.8	100.1
SCHLUMBERGER	J55	C392397	07-31-02	100.2	100.2	100.4
SCHLUMBERGER	J55	C392398	07-31-02	100.1	100.2	99.7
SCHLUMBERGER	J55	C392399	07-31-02	100.0	99.9	100.3
SCHLUMBERGER	J55	C392400	07-31-02	100.0	99.9	100.3
SCHLUMBERGER	J55	C392401	07-31-02	99.9	99.8	100.1
SCHLUMBERGER	J55	C392402	07-31-02	100.2	100.0	100.4
SCHLUMBERGER	J55	C392403	07-31-02	100.0	99.8	100.2
SCHLUMBERGER	J55	C392404	07-31-02	100.0	99.7	99.7
SCHLUMBERGER	J55	C392405	07-31-02	100.2	100.1	100.5
SCHLUMBERGER	J55	C392406	07-31-02	100.2	100.0	100.4
SCHLUMBERGER	J55	C392407	07-31-02	100.1	99.9	99.8
SCHLUMBERGER	J55	C392408	07-31-02	100.0	100.0	100.4
SCHLUMBERGER	J55	C392409	07-31-02	100.2	100.0	100.1
SCHLUMBERGER	J55	C392410	07-31-02	100.0	99.8	100.3
SCHLUMBERGER	J55	C392411	07-31-02	99.9	99.7	99.5
SCHLUMBERGER	J55	C392412	07-31-02	100.0	100.1	100.0
SCHLUMBERGER	J55	C392413	07-31-02	100.1	100.1	100.3
SCHLUMBERGER	J55	C392414	07-31-02	100.0	100.1	100.4
SCHLUMBERGER	J55	C392415	07-31-02	99.8	99.6	100.1
SCHLUMBERGER	J55	C392416	07-31-02	99.9	100.1	99.6
SCHLUMBERGER	J55	C392417	07-31-02	100.0	99.9	100.2
SCHLUMBERGER	J55	C392418	07-31-02	100.1	99.7	100.4
SCHLUMBERGER	J55	C392419	07-31-02	100.1	99.8	99.9
SCHLUMBERGER	J55	C392420	07-31-02	100.0	99.8	99.7
SCHLUMBERGER	J55	C392421	07-31-02	100.1	99.8	100.2
SCHLUMBERGER	J55	C392422	07-31-02	100.1	99.9	100.0
SCHLUMBERGER	J55	C392423	07-31-02	100.1	100.2	100.0
SCHLUMBERGER	J55	C392424	07-31-02	100.1	100.1	99.6
SCHLUMBERGER	J55	C392425	07-31-02	99.9	99.7	100.3
SCHLUMBERGER	J55	C392426	07-31-02	100.1	100.1	100.4
SCHLUMBERGER	J55	C392427	07-31-02	99.9	99.9	100.2
SCHLUMBERGER	J55	C392428	07-31-02	99.9	99.8	99.9
SCHLUMBERGER	J55	C392429	07-31-02	100.0	99.8	99.8
SCHLUMBERGER	J55	C392430	07-31-02	100.1	100.1	100.3
SCHLUMBERGER	J55	C392431	07-31-02	99.8	99.9	100.0
SCHLUMBERGER	J55	C392432	07-31-02	100.0	99.8	100.2
SCHLUMBERGER	J55	C392433	07-31-02	100.0	100.0	100.1

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

PAGE 150
 RUN DATE: 1/14/03
 RUN TIME: 13.26.53

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	J5S	C392434	07-31-02	100.1	99.9	99.8
SCHLUMBERGER	J5S	C392435	07-31-02	99.9	100.0	99.8
SCHLUMBERGER	J5S	C392436	07-31-02	100.0	100.1	100.5
SCHLUMBERGER	J5S	C392437	07-31-02	100.1	100.1	100.5
SCHLUMBERGER	J5S	C392438	07-31-02	100.2	100.0	100.2
SCHLUMBERGER	J5S	C392439	07-31-02	100.0	100.1	99.9
SCHLUMBERGER	J5S	C392440	07-31-02	100.1	100.2	100.3
SCHLUMBERGER	J5S	C392441	07-31-02	99.8	99.8	99.8
SCHLUMBERGER	J5S	C392442	07-31-02	100.0	99.7	100.3
SCHLUMBERGER	J5S	C392443	07-31-02	99.9	100.1	100.2
SCHLUMBERGER	J5S	C392444	07-31-02	100.1	100.0	100.3
SCHLUMBERGER	J5S	C392445	07-31-02	100.1	100.0	100.3
SCHLUMBERGER	J5S	C392446	07-31-02	100.0	99.9	100.4
SCHLUMBERGER	J5S	C392447	07-31-02	100.0	99.7	100.0
SCHLUMBERGER	J5S	C392448	07-31-02	100.0	99.9	99.9
SCHLUMBERGER	J5S	C392449	07-31-02	100.1	100.0	100.2
SCHLUMBERGER	J5S	C392450	07-31-02	99.9	100.0	100.1
SCHLUMBERGER	J5S	C392451	07-31-02	100.0	100.0	99.5
SCHLUMBERGER	J5S	C392452	07-31-02	100.1	100.1	100.3
SCHLUMBERGER	J5S	C392453	07-31-02	100.1	100.0	100.5
SCHLUMBERGER	J5S	C392454	07-31-02	100.0	100.0	100.5
SCHLUMBERGER	J5S	C392455	07-31-02	100.1	99.9	100.1
SCHLUMBERGER	J5S	C392456	07-31-02	100.0	100.2	100.0
SCHLUMBERGER	J5S	C392457	07-31-02	100.1	99.9	99.6
SCHLUMBERGER	J5S	C392458	07-31-02	100.1	100.2	99.9
SCHLUMBERGER	J5S	C392459	07-31-02	100.1	99.9	99.9
SCHLUMBERGER	J5S	C392460	07-31-02	100.1	99.9	99.8
SCHLUMBERGER	J5S	C392461	07-31-02	100.0	100.0	100.4
SCHLUMBERGER	J5S	C392462	07-31-02	99.8	99.8	100.2
SCHLUMBERGER	J5S	C392463	07-31-02	100.0	99.7	99.9
SCHLUMBERGER	J5S	C392464	07-31-02	99.8	99.6	100.3
SCHLUMBERGER	J5S	C392465	07-31-02	100.1	99.9	99.9
SCHLUMBERGER	J5S	C392466	07-31-02	100.2	100.1	100.2
SCHLUMBERGER	J5S	C392467	07-31-02	100.2	100.1	100.1
SCHLUMBERGER	J5S	C392468	07-31-02	100.1	99.7	100.6
SCHLUMBERGER	J5S	C392469	07-31-02	100.3	100.4	100.6
SCHLUMBERGER	J5S	C392470	07-31-02	100.1	100.2	99.6
SCHLUMBERGER	J5S	C392471	07-31-02	100.1	99.8	99.9
SCHLUMBERGER	J5S	C392472	07-31-02	100.1	99.7	100.2
SCHLUMBERGER	J5S	C392473	07-31-02	99.9	99.7	98.7
SCHLUMBERGER	J5S	C392474	07-31-02	100.1	99.8	100.5
SCHLUMBERGER	J5S	C392475	07-31-02	100.0	99.8	100.1
SCHLUMBERGER	J5S	C392476	07-31-02	99.9	100.2	99.9
SCHLUMBERGER	J5S	C392477	07-31-02	100.2	99.7	99.9
SCHLUMBERGER	J5S	C392478	07-31-02	100.1	100.3	99.9
SCHLUMBERGER	J5S	C392479	07-31-02	99.9	99.8	99.9
SCHLUMBERGER	J5S	C392480	07-31-02	100.0	100.0	100.0
SCHLUMBERGER	J5S	C392481	07-31-02	100.1	99.7	100.0
SCHLUMBERGER	J5S	C392482	07-31-02	100.0	100.2	100.3
SCHLUMBERGER	J5S	C392483	07-31-02	100.0	99.9	99.8
SCHLUMBERGER	J5S	C392484	07-31-02	100.1	100.2	100.0
SCHLUMBERGER	J5S			100.1	99.7	99.6

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	J5S	C392485	07-31-02	99.9	99.6	99.9
SCHLUMBERGER	J5S	C392486	07-31-02	100.1	99.9	99.9
SCHLUMBERGER	J5S	C392487	07-31-02	99.9	99.9	99.7
SCHLUMBERGER	J5S	C392488	07-31-02	100.0	99.9	100.1
SCHLUMBERGER	J5S	C392489	07-31-02	100.2	100.2	100.3
SCHLUMBERGER	J5S	C392490	07-31-02	100.0	100.0	99.7
SCHLUMBERGER	J5S	C392491	07-31-02	100.1	99.9	100.1
SCHLUMBERGER	J5S	C392492	07-31-02	99.9	100.2	100.4
SCHLUMBERGER	J5S	C392493	07-31-02	100.1	100.2	99.8
SCHLUMBERGER	J5S	C392494	07-31-02	100.0	100.2	99.6
SCHLUMBERGER	J5S	C392495	07-31-02	100.1	99.9	100.2
SCHLUMBERGER	J5S	C392496	07-31-02	100.1	99.9	100.4
SCHLUMBERGER	J5S	C392497	07-31-02	100.2	100.2	100.5
SCHLUMBERGER	J5S	C392498	07-31-02	100.0	100.0	100.0
SCHLUMBERGER	J5S	C392499	07-31-02	100.1	99.8	100.1
SCHLUMBERGER	J5S	C392500	07-31-02	100.2	100.0	100.5
SCHLUMBERGER	J5S	C392501	07-31-02	100.2	100.0	100.1
SCHLUMBERGER	J5S	C392502	07-31-02	100.0	100.0	100.2
SCHLUMBERGER	J5S	C392503	07-31-02	100.1	99.9	100.1
SCHLUMBERGER	J5S	C392504	07-31-02	100.1	100.3	100.1
SCHLUMBERGER	J5S	C392505	07-31-02	100.0	100.0	100.3
SCHLUMBERGER	J5S	C392506	07-31-02	100.2	99.9	100.1
SCHLUMBERGER	J5S	C392507	07-31-02	99.9	99.9	99.6
SCHLUMBERGER	J5S	C392508	07-31-02	100.2	99.8	100.4
SCHLUMBERGER	J5S	C392509	07-31-02	100.3	100.0	100.2
SCHLUMBERGER	J5S	C392510	07-31-02	100.1	100.0	99.8
SCHLUMBERGER	J5S	C392511	07-31-02	100.0	100.0	99.9
SCHLUMBERGER	J5S	C392512	07-31-02	100.2	99.9	99.9
SCHLUMBERGER	J5S	C392513	07-31-02	99.9	99.9	100.5
SCHLUMBERGER	J5S	C392514	07-31-02	99.9	99.9	99.5
SCHLUMBERGER	J5S	C392515	07-31-02	100.1	99.9	99.9
SCHLUMBERGER	J5S	C392516	07-31-02	100.1	100.0	99.9
SCHLUMBERGER	J5S	C392517	07-31-02	100.0	100.2	99.9
SCHLUMBERGER	J5S	C392518	07-31-02	100.0	99.8	100.1
SCHLUMBERGER	J5S	C392519	07-31-02	100.1	100.0	99.9
SCHLUMBERGER	J5S	C392520	07-31-02	99.8	99.9	99.6
SCHLUMBERGER	J5S	C392521	07-31-02	100.1	99.7	99.7
SCHLUMBERGER	J5S	C392522	07-31-02	100.1	99.6	99.9
SCHLUMBERGER	J5S	C392523	07-31-02	99.9	100.1	99.6
SCHLUMBERGER	J5S	C392524	07-31-02	100.1	100.4	99.9
SCHLUMBERGER	J5S	C392525	07-31-02	100.0	100.1	99.9
SCHLUMBERGER	J5S	C392526	07-31-02	100.0	100.0	99.8
SCHLUMBERGER	J5S	C392527	07-31-02	100.1	99.6	99.9
SCHLUMBERGER	J5S	C392528	07-31-02	100.0	99.8	100.2
SCHLUMBERGER	J5S	C392529	07-31-02	99.9	99.9	100.0
SCHLUMBERGER	J5S	C392530	07-31-02	100.2	100.2	100.3
SCHLUMBERGER	J5S	C392531	07-31-02	100.3	100.4	100.2
SCHLUMBERGER	J5S	C392532	07-31-02	100.0	99.9	99.8
SCHLUMBERGER	J5S	C392533	07-31-02	100.1	100.2	100.3
SCHLUMBERGER	J5S	C392534	07-31-02	100.1	99.6	99.9
SCHLUMBERGER	J5S	C392535	07-31-02	100.2	100.1	100.2

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

PAGE 152
 RUN DATE: 1/14/03
 RUN TIME: 13.26.53

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	J55	C392536	07-31-02	100.0	100.1	99.9
SCHLUMBERGER	J55	C392537	07-31-02	100.1	100.1	100.1
SCHLUMBERGER	J55	C392538	07-31-02	100.3	99.9	99.9
SCHLUMBERGER	J55	C392539	07-31-02	100.1	99.7	100.0
SCHLUMBERGER	J55	C392540	07-31-02	100.2	100.2	100.2
SCHLUMBERGER	J55	C392541	07-31-02	100.2	99.7	100.6
SCHLUMBERGER	J55	C392542	07-31-02	100.2	99.7	99.9
SCHLUMBERGER	J55	C392543	07-31-02	100.2	100.2	100.2
SCHLUMBERGER	J55	C392544	07-31-02	100.2	100.5	100.2
SCHLUMBERGER	J55	C392545	07-31-02	100.2	99.9	99.9
SCHLUMBERGER	J55	C392546	07-31-02	100.2	99.9	100.4
SCHLUMBERGER	J55	C392547	07-31-02	100.0	99.6	100.3
SCHLUMBERGER	J55	C392548	07-31-02	100.0	99.6	100.1
SCHLUMBERGER	J55	C392549	07-31-02	100.0	99.6	99.8
SCHLUMBERGER	J55	C392550	07-31-02	99.9	100.2	100.2
SCHLUMBERGER	J55	C392551	07-31-02	100.0	99.9	100.1
SCHLUMBERGER	J55	C392552	07-31-02	100.3	100.1	100.3
SCHLUMBERGER	J55	C392553	07-31-02	100.1	99.9	99.7
SCHLUMBERGER	J55	C392554	07-31-02	99.9	99.9	99.8
SCHLUMBERGER	J55	C392555	07-31-02	100.3	100.0	100.5
SCHLUMBERGER	J55	C392556	07-31-02	100.0	99.9	100.1
SCHLUMBERGER	J55	C392557	07-31-02	100.0	99.7	99.5
SCHLUMBERGER	J55	C392558	07-31-02	100.2	100.0	100.3
SCHLUMBERGER	J55	C392559	07-31-02	100.0	99.8	100.1
SCHLUMBERGER	J55	C392560	07-31-02	100.0	99.9	99.8
SCHLUMBERGER	J55	C392561	07-31-02	100.0	99.8	99.5
SCHLUMBERGER	J55	C392562	07-31-02	100.0	100.0	99.4
SCHLUMBERGER	J55	C392563	07-31-02	100.0	99.7	100.3
SCHLUMBERGER	J55	C392564	07-31-02	100.1	99.7	100.3
SCHLUMBERGER	J55	C392565	07-31-02	100.1	99.7	100.3
SCHLUMBERGER	J55	C392566	07-31-02	100.2	99.8	100.4
SCHLUMBERGER	J55	C392567	07-31-02	100.3	99.8	100.2
SCHLUMBERGER	J55	C392568	07-31-02	100.0	100.1	100.3
SCHLUMBERGER	J55	C392569	07-31-02	99.9	100.1	100.2
SCHLUMBERGER	J55	C392570	07-31-02	100.1	99.8	100.0
SCHLUMBERGER	J55	C392571	07-31-02	100.2	99.8	100.1
SCHLUMBERGER	J55	C392572	07-31-02	100.1	99.9	100.4
SCHLUMBERGER	J55	C392573	07-31-02	100.1	99.9	99.8
SCHLUMBERGER	J55	C392574	07-31-02	100.1	99.9	100.3
SCHLUMBERGER	J55	C392575	07-31-02	99.9	100.1	99.8
SCHLUMBERGER	J55	C392576	07-31-02	100.2	100.3	100.2
SCHLUMBERGER	J55	C392577	07-31-02	100.1	100.0	100.2
SCHLUMBERGER	J55	C392578	07-31-02	100.0	100.0	100.3
SCHLUMBERGER	J55	C392579	07-31-02	100.3	99.8	100.0
SCHLUMBERGER	J55	C392580	07-31-02	100.2	100.0	100.3
SCHLUMBERGER	J55	C392581	07-31-02	100.3	100.0	100.4
SCHLUMBERGER	J55	C392582	07-31-02	100.1	99.8	99.9
SCHLUMBERGER	J55	C392583	07-31-02	100.2	99.9	100.1
SCHLUMBERGER	J55	C392584	07-31-02	100.2	100.0	99.8
SCHLUMBERGER	J55	C392585	07-31-02	100.2	100.0	100.3
SCHLUMBERGER	J55	C392586	07-31-02	100.0	100.2	100.2

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD880

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	J55	C392587	07-31-02	100.0	99.9	99.7
SCHLUMBERGER	J55	C392588	07-31-02	99.9	100.1	100.2
SCHLUMBERGER	J55	C392589	07-31-02	100.1	99.7	100.2
SCHLUMBERGER	J55	C392590	07-31-02	99.9	99.7	99.7
SCHLUMBERGER	J55	C392591	07-31-02	100.0	100.4	99.8
SCHLUMBERGER	J55	C392592	07-31-02	100.2	100.0	100.1
SCHLUMBERGER	J55	C392593	07-31-02	100.0	99.8	99.8
SCHLUMBERGER	J55	C392594	07-31-02	100.1	99.7	99.8
SCHLUMBERGER	J55	C392595	07-31-02	100.0	99.9	99.5
SCHLUMBERGER	J55	C392596	07-31-02	100.1	100.1	100.4
SCHLUMBERGER	J55	C392597	07-31-02	99.9	100.0	99.8
SCHLUMBERGER	J55	C392598	07-31-02	100.2	100.3	100.2
SCHLUMBERGER	J55	C392599	07-31-02	100.1	99.9	99.8
SCHLUMBERGER	J55	C392600	07-31-02	100.1	100.1	100.1
SCHLUMBERGER	J55	C392601	07-31-02	99.9	100.1	100.1
SCHLUMBERGER	J55	C392602	07-31-02	100.0	99.6	99.7
SCHLUMBERGER	J55	C392603	07-31-02	99.9	100.1	99.9
SCHLUMBERGER	J55	C392604	07-31-02	100.0	99.8	99.8
SCHLUMBERGER	J55	C392605	07-31-02	100.2	99.8	100.2
SCHLUMBERGER	J55	C392606	07-31-02	100.3	99.9	100.3
SCHLUMBERGER	J55	C392607	07-31-02	100.0	99.6	99.9
SCHLUMBERGER	J55	C392608	07-31-02	100.0	100.0	100.0
SCHLUMBERGER	J55	C392609	07-31-02	100.0	99.8	100.3
SCHLUMBERGER	J55	C392610	07-31-02	100.0	99.7	100.0
SCHLUMBERGER	J55	C392611	07-31-02	100.1	99.7	100.2
SCHLUMBERGER	J55	C392612	07-31-02	100.1	100.2	100.2
SCHLUMBERGER	J55	C392613	07-31-02	99.9	100.1	100.4
SCHLUMBERGER	J55	C392614	07-31-02	100.1	99.8	99.9
SCHLUMBERGER	J55	C392615	07-31-02	100.0	100.2	99.8
SCHLUMBERGER	J55	C392616	07-31-02	100.3	100.1	100.2
SCHLUMBERGER	J55	C392617	07-31-02	100.1	100.0	100.3
SCHLUMBERGER	J55	C392618	07-31-02	100.1	99.9	100.3
SCHLUMBERGER	J55	C392619	07-31-02	99.9	100.0	99.4
SCHLUMBERGER	J55	C392620	07-31-02	100.1	99.8	99.7
SCHLUMBERGER	J55	C392621	07-31-02	99.8	99.8	99.7
SCHLUMBERGER	J55	C392622	07-31-02	100.0	100.0	100.1
SCHLUMBERGER	J55	C392623	07-31-02	100.0	99.9	100.2
SCHLUMBERGER	J55	C392624	07-31-02	99.9	100.0	99.5
SCHLUMBERGER	J55	C392625	07-31-02	100.0	99.7	100.3
SCHLUMBERGER	J55	C392626	07-31-02	99.9	100.2	100.1
SCHLUMBERGER	J55	C392627	07-31-02	100.1	100.0	100.4
SCHLUMBERGER	J55	C392628	07-31-02	100.3	100.1	100.4
SCHLUMBERGER	J55	C392629	07-31-02	100.1	100.3	100.3
SCHLUMBERGER	J55	C392630	07-31-02	100.1	99.9	99.7
SCHLUMBERGER	J55	C392631	07-31-02	99.9	99.8	100.2
SCHLUMBERGER	J55	C392632	07-31-02	100.1	99.8	99.6
SCHLUMBERGER	J55	C392633	07-31-02	100.2	99.8	100.2
SCHLUMBERGER	J55	C392634	07-31-02	100.1	99.8	100.4
SCHLUMBERGER	J55	C392635	07-31-02	100.1	99.7	99.9
SCHLUMBERGER	J55	C392636	07-31-02	100.1	100.2	100.5
SCHLUMBERGER	J55	C392637	07-31-02	100.2	99.8	100.3

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

PAGE 154
 RUN DATE: 1/14/03
 RUN TIME: 13.26.53

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	J55	C392638	07-31-02	100.0	100.2	99.8
SCHLUMBERGER	J55	C392639	07-31-02	100.1	100.0	100.4
SCHLUMBERGER	J55	C392640	07-31-02	99.9	99.7	100.5
SCHLUMBERGER	J55	C392641	07-31-02	100.1	100.2	100.3
SCHLUMBERGER	J55	C392642	07-31-02	100.1	100.0	100.1
SCHLUMBERGER	J55	C392643	07-31-02	99.9	100.1	99.5
SCHLUMBERGER	J55	C392644	07-31-02	100.2	99.8	100.2
SCHLUMBERGER	J55	C392645	07-31-02	100.1	99.8	100.1
SCHLUMBERGER	J55	C392646	07-31-02	99.9	99.8	100.5
SCHLUMBERGER	J55	C392647	07-31-02	99.9	100.0	100.8
SCHLUMBERGER	J55	C392648	07-31-02	99.9	99.9	99.7
SCHLUMBERGER	J55	C392649	07-31-02	100.0	99.8	99.9
SCHLUMBERGER	J55	C392650	07-31-02	100.2	100.0	100.1
SCHLUMBERGER	J55	C392651	07-31-02	100.0	99.7	100.0
SCHLUMBERGER	J55	C392652	07-31-02	100.1	100.0	99.8
SCHLUMBERGER	J55	C392653	07-31-02	100.1	99.7	99.6
SCHLUMBERGER	J55	C392654	07-31-02	99.9	99.8	100.1
SCHLUMBERGER	J55	C392655	07-31-02	100.1	100.0	99.9
SCHLUMBERGER	J55	C392656	07-31-02	100.2	99.9	100.1
SCHLUMBERGER	J55	C392657	07-31-02	99.9	99.6	99.8
SCHLUMBERGER	J55	C392658	07-31-02	99.9	99.6	99.8
SCHLUMBERGER	J55	C392659	07-31-02	100.2	100.2	100.3
SCHLUMBERGER	J55	C392660	07-31-02	100.0	100.2	100.0
SCHLUMBERGER	J55	C392661	07-31-02	100.2	100.0	100.2
SCHLUMBERGER	J55	C392662	07-31-02	100.1	99.8	100.1
SCHLUMBERGER	J55	C392663	07-31-02	100.1	99.7	100.2
SCHLUMBERGER	J55	C392664	07-31-02	100.1	99.8	100.2
SCHLUMBERGER	J55	C392665	07-31-02	100.1	99.8	100.4
SCHLUMBERGER	J55	C392666	07-31-02	100.2	99.8	99.6
SCHLUMBERGER	J55	C392667	07-31-02	100.1	100.0	100.1
SCHLUMBERGER	J55	C392668	08-15-02	99.9	99.7	99.9
SCHLUMBERGER	J55	C392669	08-15-02	100.1	100.0	100.3
SCHLUMBERGER	J55	C392670	08-15-02	100.1	99.8	100.7
SCHLUMBERGER	J55	C392671	08-15-02	100.0	100.1	100.3
SCHLUMBERGER	J55	C392672	08-15-02	100.3	100.1	100.0
SCHLUMBERGER	J55	C392673	08-15-02	100.1	99.7	100.0
SCHLUMBERGER	J55	C392674	08-15-02	100.0	99.7	100.0
SCHLUMBERGER	J55	C392675	08-15-02	100.0	100.4	100.0
SCHLUMBERGER	J55	C392676	08-15-02	100.0	100.1	100.1
SCHLUMBERGER	J55	C392677	08-15-02	100.0	99.6	100.1
SCHLUMBERGER	J55	C392678	08-15-02	100.0	99.8	100.1
SCHLUMBERGER	J55	C392679	08-15-02	100.0	100.0	100.2
SCHLUMBERGER	J55	C392680	08-15-02	100.0	100.0	99.8
SCHLUMBERGER	J55	C392681	08-15-02	100.2	99.9	99.9
SCHLUMBERGER	J55	C392682	08-15-02	100.0	100.1	100.1
SCHLUMBERGER	J55	C392683	08-15-02	100.0	99.6	99.9
SCHLUMBERGER	J55	C392684	08-15-02	100.0	100.0	100.2
SCHLUMBERGER	J55	C392685	08-15-02	100.1	99.7	100.0
SCHLUMBERGER	J55	C392686	08-15-02	100.1	99.6	100.3
SCHLUMBERGER	J55	C392687	08-15-02	100.0	99.8	100.3
SCHLUMBERGER	J55	C392688	08-15-02	99.8	99.7	99.9

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

PAGE 155
 RUN DATE: 1/14/03
 RUN TIME: 13.26.53

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	J55	C392689	08-15-02	100.0	99.8	99.7
SCHLUMBERGER	J55	C392690	08-15-02	100.0	99.9	100.6
SCHLUMBERGER	J55	C392691	08-15-02	100.0	100.0	100.0
SCHLUMBERGER	J55	C392692	08-15-02	100.0	99.7	99.8
SCHLUMBERGER	J55	C392693	08-15-02	100.2	99.9	100.2
SCHLUMBERGER	J55	C392694	08-15-02	99.9	99.7	99.8
SCHLUMBERGER	J55	C392695	08-15-02	100.1	100.1	100.0
SCHLUMBERGER	J55	C392696	08-15-02	100.2	99.7	100.3
SCHLUMBERGER	J55	C392697	08-15-02	100.1	100.1	100.2
SCHLUMBERGER	J55	C392698	08-15-02	99.9	100.0	99.8
SCHLUMBERGER	J55	C392699	08-15-02	100.1	100.1	100.0
SCHLUMBERGER	J55	C392700	08-15-02	100.0	99.7	100.3
SCHLUMBERGER	J55	C392701	08-15-02	100.3	100.1	99.7
SCHLUMBERGER	J55	C392702	08-15-02	100.2	99.7	100.2
SCHLUMBERGER	J55	C392703	08-15-02	100.2	100.3	99.9
SCHLUMBERGER	J55	C392704	08-15-02	99.9	99.7	100.1
SCHLUMBERGER	J55	C392705	08-15-02	100.2	100.0	99.9
SCHLUMBERGER	J55	C392706	08-15-02	100.1	99.8	100.1
SCHLUMBERGER	J55	C392707	08-15-02	100.1	100.1	99.6
SCHLUMBERGER	J55	C392708	08-15-02	100.1	99.7	100.2
SCHLUMBERGER	J55	C392709	08-15-02	100.3	99.6	100.0
SCHLUMBERGER	J55	C392710	08-15-02	100.2	100.3	100.3
SCHLUMBERGER	J55	C392711	08-15-02	99.9	99.9	100.1
SCHLUMBERGER	J55	C392712	08-15-02	100.0	99.9	100.2
SCHLUMBERGER	J55	C392713	08-15-02	100.2	99.9	100.1
SCHLUMBERGER	J55	C392714	08-15-02	100.3	100.1	100.8
SCHLUMBERGER	J55	C392715	08-15-02	100.3	100.1	100.3
SCHLUMBERGER	J55	C392716	08-15-02	100.1	100.2	100.1
SCHLUMBERGER	J55	C392717	08-15-02	100.0	100.1	100.0
SCHLUMBERGER	J55	C392718	08-15-02	100.2	99.8	100.5
SCHLUMBERGER	J55	C392719	08-15-02	100.0	100.0	100.3
SCHLUMBERGER	J55	C392720	08-15-02	99.9	99.9	100.6
SCHLUMBERGER	J55	C392721	08-15-02	100.2	99.8	100.5
SCHLUMBERGER	J55	C392722	08-15-02	99.9	99.7	100.3
SCHLUMBERGER	J55	C392723	08-15-02	100.1	99.9	100.3
SCHLUMBERGER	J55	C392724	08-15-02	99.9	100.0	99.7
SCHLUMBERGER	J55	C392725	08-15-02	100.0	100.1	100.7
SCHLUMBERGER	J55	C392726	08-15-02	99.9	99.7	100.0
SCHLUMBERGER	J55	C392727	08-15-02	100.1	100.1	100.4
SCHLUMBERGER	J55	C392728	08-15-02	99.9	99.8	100.6
SCHLUMBERGER	J55	C392729	08-15-02	100.0	99.9	99.9
SCHLUMBERGER	J55	C392730	08-15-02	100.1	99.7	100.1
SCHLUMBERGER	J55	C392731	08-15-02	100.1	99.7	99.8
SCHLUMBERGER	J55	C392732	08-15-02	100.1	100.0	100.2
SCHLUMBERGER	J55	C392733	08-15-02	100.1	99.9	99.9
SCHLUMBERGER	J55	C392734	08-15-02	100.0	100.1	100.5
SCHLUMBERGER	J55	C392735	08-15-02	100.0	100.0	100.0
SCHLUMBERGER	J55	C392736	08-15-02	100.0	100.3	100.2
SCHLUMBERGER	J55	C392737	08-15-02	99.8	99.7	100.2
SCHLUMBERGER	J55	C392738	08-15-02	99.9	99.7	99.7
SCHLUMBERGER	J55	C392739	08-15-02	100.1	99.9	100.1

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

PAGE 156
 RUN DATE: 1/14/03
 RUN TIME: 13.26.53

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	J55	C392740	08-15-02	100.3	100.1	100.2
SCHLUMBERGER	J55	C392741	08-15-02	100.0	99.8	99.9
SCHLUMBERGER	J55	C392742	08-15-02	100.3	100.4	100.7
SCHLUMBERGER	J55	C392743	08-15-02	100.1	99.6	99.7
SCHLUMBERGER	J55	C392744	08-15-02	100.0	100.0	99.7
SCHLUMBERGER	J55	C392745	08-15-02	99.9	99.7	99.9
SCHLUMBERGER	J55	C392746	08-15-02	100.2	100.2	100.5
SCHLUMBERGER	J55	C392747	08-15-02	100.0	99.8	100.4
SCHLUMBERGER	J55	C392748	08-15-02	100.1	99.9	100.2
SCHLUMBERGER	J55	C392749	08-15-02	100.1	99.9	99.8
SCHLUMBERGER	J55	C392750	08-15-02	100.1	100.1	100.0
SCHLUMBERGER	J55	C392751	08-15-02	100.0	99.9	99.9
SCHLUMBERGER	J55	C392752	08-15-02	99.9	99.9	99.7
SCHLUMBERGER	J55	C392753	08-15-02	100.1	99.8	100.0
SCHLUMBERGER	J55	C392754	08-15-02	100.1	99.7	100.7
SCHLUMBERGER	J55	C392755	08-15-02	100.2	99.9	100.0
SCHLUMBERGER	J55	C392756	08-15-02	100.2	100.1	100.3
SCHLUMBERGER	J55	C392757	08-15-02	100.2	100.1	99.7
SCHLUMBERGER	J55	C392758	08-15-02	100.1	100.1	100.4
SCHLUMBERGER	J55	C392759	08-15-02	100.1	100.0	99.8
SCHLUMBERGER	J55	C392760	08-15-02	100.2	100.0	100.6
SCHLUMBERGER	J55	C392761	08-15-02	100.2	100.2	99.8
SCHLUMBERGER	J55	C392762	08-15-02	100.3	99.9	99.6
SCHLUMBERGER	J55	C392763	08-15-02	99.9	99.7	100.7
SCHLUMBERGER	J55	C392764	08-15-02	100.2	100.2	100.5
SCHLUMBERGER	J55	C392765	08-15-02	100.3	100.0	100.0
SCHLUMBERGER	J55	C392766	08-15-02	100.1	100.5	100.6
SCHLUMBERGER	J55	C392767	08-15-02	100.2	100.1	100.3
SCHLUMBERGER	J55	C392768	08-15-02	100.0	100.0	100.2
SCHLUMBERGER	J55	C392769	08-15-02	100.0	100.0	100.3
SCHLUMBERGER	J55	C392770	08-15-02	100.1	100.0	99.8
SCHLUMBERGER	J55	C392771	08-15-02	100.1	100.3	100.2
SCHLUMBERGER	J55	C392772	08-15-02	99.9	99.8	99.9
SCHLUMBERGER	J55	C392773	08-15-02	100.1	100.1	100.1
SCHLUMBERGER	J55	C392774	08-15-02	100.0	100.1	100.3
SCHLUMBERGER	J55	C392775	08-15-02	99.9	100.0	100.0
SCHLUMBERGER	J55	C392776	08-15-02	100.1	100.0	100.0
SCHLUMBERGER	J55	C392777	08-15-02	100.0	99.9	100.1
SCHLUMBERGER	J55	C392778	08-15-02	100.0	100.0	99.9
SCHLUMBERGER	J55	C392779	08-15-02	100.0	99.7	99.7
SCHLUMBERGER	J55	C392780	08-15-02	100.1	99.6	100.4
SCHLUMBERGER	J55	C392781	08-15-02	100.1	99.8	100.1
SCHLUMBERGER	J55	C392782	08-15-02	100.2	100.3	100.4
SCHLUMBERGER	J55	C392783	08-15-02	100.0	99.8	100.2
SCHLUMBERGER	J55	C392784	08-15-02	99.9	99.8	100.4
SCHLUMBERGER	J55	C392785	08-15-02	100.2	100.1	100.2
SCHLUMBERGER	J55	C392786	08-15-02	100.3	100.2	100.5
SCHLUMBERGER	J55	C392787	08-15-02	100.1	99.8	99.6
SCHLUMBERGER	J55	C392788	08-15-02	100.1	100.1	99.7
SCHLUMBERGER	J55	C392789	08-15-02	100.0	99.7	100.2
SCHLUMBERGER	J55	C392790	08-15-02	100.1	100.2	100.0

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	J55	C392791	08-15-02	99.9	99.9	100.1
SCHLUMBERGER	J55	C392792	08-15-02	100.1	99.9	100.7
SCHLUMBERGER	J55	C392793	08-15-02	100.2	100.2	100.5
SCHLUMBERGER	J55	C392794	08-15-02	100.1	100.1	99.9
SCHLUMBERGER	J55	C392795	08-15-02	100.2	100.1	100.3
SCHLUMBERGER	J55	C392796	08-15-02	100.1	100.5	100.4
SCHLUMBERGER	J55	C392797	08-15-02	100.0	99.9	100.2
SCHLUMBERGER	J55	C392798	08-15-02	100.0	99.7	99.9
SCHLUMBERGER	J55	C392799	08-15-02	100.1	99.8	99.9
SCHLUMBERGER	J55	C392800	08-15-02	100.1	100.1	99.9
SCHLUMBERGER	J55	C392801	08-15-02	100.0	99.8	99.6
SCHLUMBERGER	J55	C392802	08-15-02	100.1	100.0	99.8
SCHLUMBERGER	J55	C392803	08-15-02	100.2	99.9	99.6
SCHLUMBERGER	J55	C392804	08-15-02	100.1	100.0	100.6
SCHLUMBERGER	J55	C392805	08-15-02	100.1	100.1	100.0
SCHLUMBERGER	J55	C392806	08-15-02	100.2	100.2	100.1
SCHLUMBERGER	J55	C392807	08-15-02	100.0	99.9	100.0
SCHLUMBERGER	J55	C392808	08-15-02	100.1	100.0	99.8
SCHLUMBERGER	J55	C392809	08-15-02	100.1	99.9	100.2
SCHLUMBERGER	J55	C392810	08-15-02	100.1	99.7	100.7
SCHLUMBERGER	J55	C392811	08-15-02	100.1	100.3	99.7
SCHLUMBERGER	J55	C392812	08-15-02	100.2	99.8	99.7
SCHLUMBERGER	J55	C392813	08-15-02	100.0	100.0	100.0
SCHLUMBERGER	J55	C392814	08-15-02	100.1	100.0	100.5
SCHLUMBERGER	J55	C392815	08-15-02	100.0	100.0	100.0
SCHLUMBERGER	J55	C392816	08-15-02	100.2	100.0	100.0
SCHLUMBERGER	J55	C392817	08-15-02	100.0	100.2	100.6
SCHLUMBERGER	J55	C392818	08-15-02	100.0	100.2	100.4
SCHLUMBERGER	J55	C392819	08-15-02	100.0	100.1	100.1
SCHLUMBERGER	J55	C392820	08-15-02	100.2	99.6	100.0
SCHLUMBERGER	J55	C392821	08-15-02	100.2	100.3	100.7
SCHLUMBERGER	J55	C392822	08-15-02	100.0	100.2	100.3
SCHLUMBERGER	J55	C392823	08-15-02	100.0	100.1	100.1
SCHLUMBERGER	J55	C392824	08-15-02	100.2	99.6	100.1
SCHLUMBERGER	J55	C392825	08-15-02	99.9	99.6	100.1
SCHLUMBERGER	J55	C392826	08-15-02	100.2	100.2	100.4
SCHLUMBERGER	J55	C392827	08-15-02	100.0	99.6	100.0
SCHLUMBERGER	J55	C392828	08-15-02	100.1	99.7	100.3
SCHLUMBERGER	J55	C392829	08-15-02	100.1	100.0	99.6
SCHLUMBERGER	J55	C392830	08-15-02	100.3	99.7	100.3
SCHLUMBERGER	J55	C392831	08-15-02	100.1	99.7	99.6
SCHLUMBERGER	J55	C392832	08-15-02	99.8	99.8	100.5
SCHLUMBERGER	J55	C392833	08-15-02	100.0	99.9	100.2
SCHLUMBERGER	J55	C392834	08-15-02	99.9	99.6	100.4
SCHLUMBERGER	J55	C392835	08-15-02	100.1	99.6	100.1
SCHLUMBERGER	J55	C392836	08-15-02	100.1	100.0	100.3
SCHLUMBERGER	J55	C392837	08-15-02	100.1	99.7	100.6
SCHLUMBERGER	J55	C392838	08-15-02	100.1	99.9	100.0
SCHLUMBERGER	J55	C392839	08-15-02	100.0	99.8	100.0
SCHLUMBERGER	J55	C392840	08-15-02	100.0	99.9	99.7
SCHLUMBERGER	J55	C392841	08-15-02	100.1	99.8	100.0

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

PAGE 158
 RUN DATE: 1/14/03
 RUN TIME: 13.26.53

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	J55	C392842	08-15-02	100.0	99.9	100.0
SCHLUMBERGER	J55	C392843	08-15-02	100.0	99.7	100.2
SCHLUMBERGER	J55	C392844	08-15-02	100.0	99.6	100.3
SCHLUMBERGER	J55	C392845	08-15-02	99.8	100.1	100.0
SCHLUMBERGER	J55	C392846	08-15-02	100.0	100.2	100.0
SCHLUMBERGER	J55	C392847	08-15-02	100.2	99.8	99.6
SCHLUMBERGER	J55	C392848	08-15-02	100.1	100.1	100.1
SCHLUMBERGER	J55	C392849	08-15-02	100.1	99.9	100.1
SCHLUMBERGER	J55	C392850	08-15-02	100.0	99.7	100.4
SCHLUMBERGER	J55	C392851	08-15-02	99.9	99.8	100.3
SCHLUMBERGER	J55	C392852	08-15-02	100.1	99.9	100.3
SCHLUMBERGER	J55	C392853	08-15-02	100.1	100.1	100.1
SCHLUMBERGER	J55	C392854	08-15-02	100.3	99.7	100.2
SCHLUMBERGER	J55	C392855	08-15-02	100.0	100.0	99.9
SCHLUMBERGER	J55	C392856	08-15-02	100.1	99.9	100.2
SCHLUMBERGER	J55	C392857	08-15-02	100.0	99.9	100.1
SCHLUMBERGER	J55	C392858	08-15-02	100.0	99.8	99.8
SCHLUMBERGER	J55	C392859	08-15-02	100.1	99.6	99.9
SCHLUMBERGER	J55	C392860	08-15-02	100.2	100.2	99.9
SCHLUMBERGER	J55	C392861	08-15-02	100.1	100.0	99.7
SCHLUMBERGER	J55	C392862	08-15-02	100.0	99.8	100.5
SCHLUMBERGER	J55	C392863	08-15-02	100.1	100.1	99.8
SCHLUMBERGER	J55	C392864	08-15-02	100.2	100.4	100.8
SCHLUMBERGER	J55	C392865	08-15-02	100.2	99.6	100.1
SCHLUMBERGER	J55	C392866	08-15-02	99.9	99.7	99.7
SCHLUMBERGER	J55	C392867	08-15-02	99.8	100.2	100.4
SCHLUMBERGER	J55	C392868	08-15-02	100.0	99.8	99.9
SCHLUMBERGER	J55	C392869	08-15-02	99.8	99.8	100.0
SCHLUMBERGER	J55	C392870	08-15-02	100.2	100.0	100.2
SCHLUMBERGER	J55	C392871	08-15-02	100.0	99.8	100.0
SCHLUMBERGER	J55	C392872	08-15-02	99.9	99.8	99.8
SCHLUMBERGER	J55	C392873	08-15-02	100.2	99.9	100.2
SCHLUMBERGER	J55	C392874	08-15-02	100.1	99.8	100.1
SCHLUMBERGER	J55	C392875	08-15-02	100.2	100.4	100.1
SCHLUMBERGER	J55	C392876	08-15-02	100.1	99.7	99.7
SCHLUMBERGER	J55	C392877	08-15-02	100.1	99.9	99.7
SCHLUMBERGER	J55	C392878	08-15-02	100.0	100.0	100.0
SCHLUMBERGER	J55	C392879	08-15-02	100.2	100.1	100.0
SCHLUMBERGER	J55	C392880	08-15-02	100.0	99.7	99.7
SCHLUMBERGER	J55	C392881	08-15-02	99.9	100.1	99.8
SCHLUMBERGER	J55	C392882	08-15-02	100.0	99.8	99.8
SCHLUMBERGER	J55	C392883	08-15-02	100.1	99.8	100.2
SCHLUMBERGER	J55	C392884	08-15-02	100.2	99.9	100.3
SCHLUMBERGER	J55	C392885	08-15-02	100.2	100.1	100.3
SCHLUMBERGER	J55	C392886	08-15-02	100.2	100.4	100.4
SCHLUMBERGER	J55	C392887	08-15-02	100.1	100.1	100.0
SCHLUMBERGER	J55	C392888	08-15-02	100.2	100.0	100.3
SCHLUMBERGER	J55	C392889	08-15-02	100.0	100.0	100.0
SCHLUMBERGER	J55	C392890	08-15-02	100.1	99.8	100.2
SCHLUMBERGER	J55	C392891	08-15-02	100.2	99.8	100.2
SCHLUMBERGER	J55	C392892	08-15-02	100.0	100.1	99.8

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	J55	C392893	08-15-02	100.3	100.1	100.3
SCHLUMBERGER	J55	C392894	08-15-02	100.1	100.0	100.1
SCHLUMBERGER	J55	C392895	08-15-02	99.9	100.0	99.8
SCHLUMBERGER	J55	C392896	08-15-02	100.0	100.0	100.1
SCHLUMBERGER	J55	C392897	08-15-02	99.8	99.7	100.3
SCHLUMBERGER	J55	C392898	08-15-02	100.0	99.8	99.7
SCHLUMBERGER	J55	C392899	08-15-02	100.1	100.0	100.1
SCHLUMBERGER	J55	C392900	08-15-02	100.1	100.4	100.6
SCHLUMBERGER	J55	C392901	08-15-02	100.0	100.0	100.6
SCHLUMBERGER	J55	C392902	08-15-02	100.1	99.3	99.3
SCHLUMBERGER	J55	C392903	08-15-02	100.3	100.1	100.1
SCHLUMBERGER	J55	C392904	08-15-02	100.2	100.2	100.0
SCHLUMBERGER	J55	C392905	08-15-02	100.3	100.0	100.1
SCHLUMBERGER	J55	C392906	08-15-02	100.0	100.1	100.2
SCHLUMBERGER	J55	C392907	08-15-02	100.2	99.9	100.4
SCHLUMBERGER	J55	C392908	08-15-02	100.2	99.8	99.9
SCHLUMBERGER	J55	C392909	08-15-02	100.1	100.1	99.9
SCHLUMBERGER	J55	C392910	08-15-02	100.2	99.8	100.1
SCHLUMBERGER	J55	C392911	08-15-02	100.1	99.7	99.9
SCHLUMBERGER	J55	C392912	08-15-02	99.8	100.2	100.2
SCHLUMBERGER	J55	C392913	08-15-02	100.3	100.1	100.1
SCHLUMBERGER	J55	C392914	08-15-02	100.2	100.3	99.9
SCHLUMBERGER	J55	C392915	08-15-02	100.2	99.8	100.3
SCHLUMBERGER	J55	C392916	08-15-02	99.9	99.9	100.0
SCHLUMBERGER	J55	C392917	08-15-02	100.1	100.1	100.0
SCHLUMBERGER	J55	C392918	08-15-02	100.1	100.0	100.3
SCHLUMBERGER	J55	C392919	08-15-02	100.0	100.0	100.3
SCHLUMBERGER	J55	C392920	08-15-02	100.2	100.3	99.8
SCHLUMBERGER	J55	C392921	08-15-02	99.9	99.9	99.9
SCHLUMBERGER	J55	C392922	08-15-02	100.1	99.9	100.3
SCHLUMBERGER	J55	C392923	08-15-02	100.0	100.1	99.9
SCHLUMBERGER	J55	C392924	08-15-02	100.2	100.4	100.3
SCHLUMBERGER	J55	C392925	08-15-02	100.0	99.8	100.1
SCHLUMBERGER	J55	C392926	08-15-02	100.1	99.7	100.1
SCHLUMBERGER	J55	C392927	08-15-02	100.1	100.4	100.3
SCHLUMBERGER	J55	C392928	08-15-02	100.1	99.8	99.8
SCHLUMBERGER	J55	C392929	08-15-02	100.1	99.9	100.0
SCHLUMBERGER	J55	C392930	08-15-02	100.1	100.1	100.2
SCHLUMBERGER	J55	C392931	08-15-02	100.1	99.8	100.5
SCHLUMBERGER	J55	C392932	08-15-02	100.2	99.7	100.6
SCHLUMBERGER	J55	C392933	08-15-02	100.3	100.3	100.2
SCHLUMBERGER	J55	C392934	08-15-02	100.3	99.9	100.2
SCHLUMBERGER	J55	C392935	08-15-02	100.1	100.3	100.1
SCHLUMBERGER	J55	C392936	08-15-02	100.0	100.0	100.0
SCHLUMBERGER	J55	C392937	08-15-02	99.9	100.2	100.1
SCHLUMBERGER	J55	C392938	08-15-02	100.1	100.1	100.1
SCHLUMBERGER	J55	C392939	08-15-02	100.0	99.7	99.9
SCHLUMBERGER	J55	C392940	08-15-02	100.1	99.8	100.1
SCHLUMBERGER	J55	C392941	08-15-02	100.0	99.8	99.5
SCHLUMBERGER	J55	C392942	08-15-02	100.0	99.8	100.5
SCHLUMBERGER	J55	C392943	08-15-02	99.9	99.7	100.5

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

PAGE 160
 RUN DATE: 1/14/03
 RUN TIME: 13.26.53

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	J5S	C392944	08-15-02	100.2	100.0	100.0
SCHLUMBERGER	J5S	C392945	08-15-02	100.2	100.3	99.9
SCHLUMBERGER	J5S	C392946	08-15-02	100.2	100.1	100.5
SCHLUMBERGER	J5S	C392947	08-15-02	100.1	99.9	100.1
SCHLUMBERGER	J5S	C392948	08-15-02	100.1	99.9	100.4
SCHLUMBERGER	J5S	C392949	08-15-02	100.0	100.0	100.0
SCHLUMBERGER	J5S	C392950	08-15-02	100.2	100.2	100.0
SCHLUMBERGER	J5S	C392951	08-15-02	100.2	100.1	99.6
SCHLUMBERGER	J5S	C392952	08-15-02	99.9	99.8	100.5
SCHLUMBERGER	J5S	C392953	08-15-02	99.8	100.0	99.7
SCHLUMBERGER	J5S	C392954	08-15-02	100.2	100.2	100.1
SCHLUMBERGER	J5S	C392955	08-15-02	100.1	99.9	99.8
SCHLUMBERGER	J5S	C392956	08-15-02	100.1	100.4	100.1
SCHLUMBERGER	J5S	C392957	08-15-02	100.0	99.7	100.1
SCHLUMBERGER	J5S	C392958	08-15-02	100.2	99.9	100.6
SCHLUMBERGER	J5S	C392959	08-15-02	100.0	99.6	100.2
SCHLUMBERGER	J5S	C392960	08-15-02	100.2	99.9	100.0
SCHLUMBERGER	J5S	C392961	08-15-02	100.2	99.7	99.9
SCHLUMBERGER	J5S	C392962	08-15-02	99.8	99.9	100.5
SCHLUMBERGER	J5S	C392963	08-15-02	100.0	99.7	99.4
SCHLUMBERGER	J5S	C392964	08-15-02	99.9	99.8	99.8
SCHLUMBERGER	J5S	C392965	08-15-02	100.2	100.1	100.1
SCHLUMBERGER	J5S	C392966	08-15-02	99.9	100.3	99.8
SCHLUMBERGER	J5S	C392967	08-15-02	100.0	100.0	100.5
SCHLUMBERGER	J5S	C392968	08-15-02	100.1	100.0	100.0
SCHLUMBERGER	J5S	C392969	08-15-02	100.1	99.7	100.2
SCHLUMBERGER	J5S	C392970	08-15-02	100.0	100.2	99.7
SCHLUMBERGER	J5S	C392971	08-15-02	100.0	99.7	99.8
SCHLUMBERGER	J5S	C392972	08-15-02	100.2	99.6	99.5
SCHLUMBERGER	J5S	C392973	08-15-02	100.1	100.1	100.2
SCHLUMBERGER	J5S	C392974	08-15-02	99.9	99.7	99.9
SCHLUMBERGER	J5S	C392975	08-15-02	100.0	100.0	99.9
SCHLUMBERGER	J5S	C392976	08-15-02	100.1	99.9	100.1
SCHLUMBERGER	J5S	C392977	08-15-02	100.1	99.8	100.5
SCHLUMBERGER	J5S	C392978	08-15-02	100.1	100.1	100.4
SCHLUMBERGER	J5S	C392979	08-15-02	100.3	99.7	100.4
SCHLUMBERGER	J5S	C392980	08-15-02	100.3	99.8	100.6
SCHLUMBERGER	J5S	C392981	08-15-02	100.2	99.9	100.2
SCHLUMBERGER	J5S	C392982	08-15-02	100.3	99.9	100.0
SCHLUMBERGER	J5S	C392983	08-15-02	100.3	99.2	100.4
SCHLUMBERGER	J5S	C392984	08-15-02	100.1	100.1	100.3
SCHLUMBERGER	J5S	C392985	08-15-02	100.1	99.6	100.4
SCHLUMBERGER	J5S	C392986	08-15-02	99.9	99.8	100.0
SCHLUMBERGER	J5S	C392987	08-15-02	100.0	100.0	99.6
SCHLUMBERGER	J5S	C392988	08-15-02	100.2	99.8	100.2
SCHLUMBERGER	J5S	C392989	08-15-02	100.0	99.8	100.0
SCHLUMBERGER	J5S	C392990	08-15-02	100.1	99.8	100.5
SCHLUMBERGER	J5S	C392991	08-15-02	100.2	100.0	100.0
SCHLUMBERGER	J5S	C392992	08-15-02	100.0	99.9	100.0
SCHLUMBERGER	J5S	C392993	08-15-02	100.0	99.9	99.8
SCHLUMBERGER	J5S	C392994	08-15-02	100.0	99.9	99.5

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	J55	C392995	08-15-02	100.1	99.8	100.3
SCHLUMBERGER	J55	C392996	08-15-02	100.0	99.6	100.6
SCHLUMBERGER	J55	C392997	08-15-02	100.0	99.7	100.4
SCHLUMBERGER	J55	C392998	08-15-02	100.0	99.7	100.1
SCHLUMBERGER	J55	C392999	08-15-02	100.0	100.3	100.2
SCHLUMBERGER	J55	C393000	08-15-02	100.1	99.9	99.6
SCHLUMBERGER	J55	C393001	08-15-02	100.0	99.7	100.5
SCHLUMBERGER	J55	C393002	08-15-02	100.0	99.7	100.2
SCHLUMBERGER	J55	C393003	08-15-02	100.0	99.8	100.1
SCHLUMBERGER	J55	C393004	08-15-02	100.2	100.0	100.1
SCHLUMBERGER	J55	C393005	08-15-02	99.9	99.8	99.9
SCHLUMBERGER	J55	C393006	08-15-02	100.2	100.0	100.4
SCHLUMBERGER	J55	C393007	08-15-02	100.2	100.1	100.3
SCHLUMBERGER	J55	C393008	08-15-02	100.2	99.7	99.8
SCHLUMBERGER	J55	C393009	08-15-02	100.0	100.2	99.9
SCHLUMBERGER	J55	C393010	08-15-02	100.1	99.9	100.5
SCHLUMBERGER	J55	C393011	08-15-02	99.9	99.8	100.4
SCHLUMBERGER	J55	C393012	08-15-02	99.9	99.7	99.9
SCHLUMBERGER	J55	C393013	08-15-02	100.3	100.3	100.4
SCHLUMBERGER	J55	C393014	08-15-02	100.1	99.9	99.8
SCHLUMBERGER	J55	C393015	08-15-02	100.0	100.1	100.4
SCHLUMBERGER	J55	C393016	08-15-02	100.1	99.9	100.6
SCHLUMBERGER	J55	C393017	08-15-02	100.1	100.1	100.1
SCHLUMBERGER	J55	C393018	08-15-02	100.1	100.1	100.1
SCHLUMBERGER	J55	C393019	08-15-02	100.3	100.1	100.4
SCHLUMBERGER	J55	C393020	08-15-02	100.0	99.9	100.0
SCHLUMBERGER	J55	C393021	08-15-02	100.1	99.8	100.2
SCHLUMBERGER	J55	C393022	08-15-02	99.9	100.2	100.0
SCHLUMBERGER	J55	C393023	08-15-02	99.8	99.7	99.8
SCHLUMBERGER	J55	C393024	08-15-02	100.2	99.8	100.3
SCHLUMBERGER	J55	C393025	08-15-02	100.2	100.0	100.0
SCHLUMBERGER	J55	C393026	08-15-02	100.1	99.9	100.2
SCHLUMBERGER	J55	C393027	08-15-02	99.9	99.9	100.3
SCHLUMBERGER	J55	C393028	08-15-02	100.1	100.0	100.1
SCHLUMBERGER	J55	C393029	08-15-02	100.0	99.6	100.0
SCHLUMBERGER	J55	C393030	08-15-02	100.1	100.0	100.2
SCHLUMBERGER	J55	C393031	08-15-02	100.1	100.2	100.2
SCHLUMBERGER	J55	C393032	08-15-02	100.2	99.7	100.5
SCHLUMBERGER	J55	C393033	08-15-02	100.0	99.7	99.6
SCHLUMBERGER	J55	C393034	08-15-02	100.2	99.9	100.2
SCHLUMBERGER	J55	C393035	08-15-02	100.1	100.0	100.3
SCHLUMBERGER	J55	C393036	08-15-02	99.9	99.8	100.0
SCHLUMBERGER	J55	C393037	08-15-02	100.1	99.7	99.8
SCHLUMBERGER	J55	C393038	08-15-02	100.1	99.7	100.1
SCHLUMBERGER	J55	C393039	08-15-02	100.2	99.7	100.3
SCHLUMBERGER	J55	C393040	08-15-02	100.3	99.7	100.1
SCHLUMBERGER	J55	C393041	08-15-02	99.9	99.9	99.9
SCHLUMBERGER	J55	C393042	08-15-02	100.3	99.8	100.2
SCHLUMBERGER	J55	C393043	08-15-02	99.9	100.0	100.2
SCHLUMBERGER	J55	C393044	08-15-02	100.3	100.3	99.9
SCHLUMBERGER	J55	C393045	08-15-02	99.9	100.2	100.2
SCHLUMBERGER	J55	C393045	08-15-02	100.1	100.0	100.2

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

PAGE 162
 RUN DATE: 1/14/03
 RUN TIME: 13.26.53

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	J5S	C393046	08-15-02	100.0	99.8	100.5
SCHLUMBERGER	J5S	C393047	08-15-02	100.0	100.1	99.5
SCHLUMBERGER	J5S	C393048	08-15-02	100.0	100.1	99.6
SCHLUMBERGER	J5S	C393049	08-15-02	100.0	99.9	100.1
SCHLUMBERGER	J5S	C393050	08-15-02	100.0	99.8	99.8
SCHLUMBERGER	J5S	C393051	08-15-02	100.0	100.0	99.9
SCHLUMBERGER	J5S	C393052	08-15-02	100.1	99.8	100.2
SCHLUMBERGER	J5S	C393053	08-15-02	100.2	100.1	100.0
SCHLUMBERGER	J5S	C393054	08-15-02	99.9	99.7	99.9
SCHLUMBERGER	J5S	C393055	08-15-02	100.1	99.6	100.2
SCHLUMBERGER	J5S	C393056	08-15-02	100.0	100.0	100.4
SCHLUMBERGER	J5S	C393057	08-15-02	99.9	99.8	99.6
SCHLUMBERGER	J5S	C393058	08-15-02	100.3	100.4	100.6
SCHLUMBERGER	J5S	C393059	08-15-02	100.1	99.6	100.2
SCHLUMBERGER	J5S	C393060	08-15-02	100.2	99.9	100.4
SCHLUMBERGER	J5S	C393061	08-15-02	100.3	100.2	100.4
SCHLUMBERGER	J5S	C393062	08-15-02	100.3	100.0	99.9
SCHLUMBERGER	J5S	C393063	08-15-02	100.1	100.1	100.4
SCHLUMBERGER	J5S	C393064	08-15-02	100.1	100.0	100.5
SCHLUMBERGER	J5S	C393065	08-15-02	100.1	100.3	100.1
SCHLUMBERGER	J5S	C393066	08-15-02	100.0	100.0	100.3
SCHLUMBERGER	J5S	C393067	08-15-02	100.2	99.8	99.5
SCHLUMBERGER	J5S	C393068	08-15-02	100.1	100.0	99.7
SCHLUMBERGER	J5S	C393069	08-15-02	100.2	99.9	100.5
SCHLUMBERGER	J5S	C393070	08-15-02	99.9	99.6	99.9
SCHLUMBERGER	J5S	C393071	08-15-02	100.2	100.0	99.7
SCHLUMBERGER	J5S	C393072	08-15-02	100.1	99.8	99.7
SCHLUMBERGER	J5S	C393073	08-15-02	100.1	99.8	100.3
SCHLUMBERGER	J5S	C393074	08-15-02	100.1	99.8	100.2
SCHLUMBERGER	J5S	C393075	08-15-02	100.1	100.0	100.3
SCHLUMBERGER	J5S	C393076	08-15-02	100.2	100.0	100.2
SCHLUMBERGER	J5S	C393077	08-15-02	100.1	99.8	100.3
SCHLUMBERGER	J5S	C393078	08-15-02	100.1	100.1	99.7
SCHLUMBERGER	J5S	C393079	08-15-02	100.1	100.1	100.1
SCHLUMBERGER	J5S	C393080	08-15-02	100.0	99.8	100.2
SCHLUMBERGER	J5S	C393081	08-15-02	100.0	99.8	100.0
SCHLUMBERGER	J5S	C393082	08-15-02	100.0	100.2	99.8
SCHLUMBERGER	J5S	C393083	08-15-02	100.1	100.0	100.1
SCHLUMBERGER	J5S	C393084	08-15-02	100.1	100.0	99.8
SCHLUMBERGER	J5S	C393085	08-15-02	100.3	99.9	100.1
SCHLUMBERGER	J5S	C393086	08-15-02	100.2	99.7	100.3
SCHLUMBERGER	J5S	C393087	08-15-02	100.0	99.8	100.5
SCHLUMBERGER	J5S	C393088	08-15-02	100.1	99.6	100.9
SCHLUMBERGER	J5S	C393089	08-15-02	100.1	100.2	100.2
SCHLUMBERGER	J5S	C393090	08-15-02	100.3	99.9	100.2
SCHLUMBERGER	J5S	C393091	08-15-02	99.8	99.8	100.1
SCHLUMBERGER	J5S	C393092	08-15-02	100.1	99.8	100.1
SCHLUMBERGER	J5S	C393093	08-15-02	100.2	99.7	100.1
SCHLUMBERGER	J5S	C393094	08-15-02	100.3	100.0	100.4
SCHLUMBERGER	J5S	C393095	08-15-02	100.1	99.7	100.1
SCHLUMBERGER	J5S	C393096	08-15-02	100.0	99.9	100.3
SCHLUMBERGER	J5S	C393096	08-15-02	100.1	99.6	99.9

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

PAGE 163
 RUN DATE: 1/14/03
 RUN TIME: 13.26.53

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	J55	C393097	08-15-02	100.0	99.8	99.8
SCHLUMBERGER	J55	C393098	08-15-02	100.2	100.4	100.4
SCHLUMBERGER	J55	C393099	08-15-02	100.0	99.8	100.0
SCHLUMBERGER	J55	C393100	08-15-02	100.1	100.1	100.0
SCHLUMBERGER	J55	C393101	08-15-02	100.0	99.7	100.3
SCHLUMBERGER	J55	C393102	08-15-02	100.2	100.3	100.1
SCHLUMBERGER	J55	C393103	08-15-02	100.0	100.1	100.3
SCHLUMBERGER	J55	C393104	08-15-02	100.2	99.7	100.3
SCHLUMBERGER	J55	C393105	08-15-02	100.1	100.2	100.2
SCHLUMBERGER	J55	C393106	08-15-02	100.0	99.7	100.4
SCHLUMBERGER	J55	C393107	08-15-02	100.2	100.2	100.2
SCHLUMBERGER	J55	C393108	08-15-02	100.0	99.7	100.2
SCHLUMBERGER	J55	C393109	08-15-02	100.2	100.0	100.0
SCHLUMBERGER	J55	C393110	08-15-02	100.1	99.8	100.1
SCHLUMBERGER	J55	C393111	08-15-02	100.1	100.0	100.2
SCHLUMBERGER	J55	C393112	08-15-02	100.0	99.8	100.1
SCHLUMBERGER	J55	C393113	08-15-02	100.0	99.9	100.5
SCHLUMBERGER	J55	C393114	08-15-02	100.2	100.2	100.0
SCHLUMBERGER	J55	C393115	08-15-02	100.1	99.8	100.0
SCHLUMBERGER	J55	C393116	08-15-02	100.0	99.7	100.0
SCHLUMBERGER	J55	C393117	08-15-02	100.1	99.8	100.0
SCHLUMBERGER	J55	C393118	08-15-02	100.2	99.8	100.1
SCHLUMBERGER	J55	C393119	08-15-02	100.0	100.1	100.2
SCHLUMBERGER	J55	C393120	08-15-02	100.2	99.7	100.2
SCHLUMBERGER	J55	C393121	08-15-02	100.1	99.7	100.3
SCHLUMBERGER	J55	C393122	08-15-02	100.2	99.6	100.1
SCHLUMBERGER	J55	C393123	08-15-02	99.9	99.9	100.1
SCHLUMBERGER	J55	C393124	08-15-02	100.0	99.7	99.5
SCHLUMBERGER	J55	C393125	08-15-02	100.2	100.0	100.0
SCHLUMBERGER	J55	C393126	08-15-02	100.0	100.1	100.0
SCHLUMBERGER	J55	C393127	08-15-02	100.2	99.9	100.2
SCHLUMBERGER	J55	C393128	08-15-02	99.9	100.0	100.0
SCHLUMBERGER	J55	C393129	08-15-02	100.0	100.1	100.0
SCHLUMBERGER	J55	C393130	08-15-02	99.8	99.8	99.6
SCHLUMBERGER	J55	C393131	08-15-02	99.9	99.7	100.0
SCHLUMBERGER	J55	C393132	08-15-02	99.9	99.8	100.0
SCHLUMBERGER	J55	C393133	08-15-02	100.0	99.9	99.5
SCHLUMBERGER	J55	C393134	08-15-02	100.0	100.0	100.1
SCHLUMBERGER	J55	C393135	08-15-02	100.2	99.9	99.8
SCHLUMBERGER	J55	C393136	08-15-02	99.9	100.0	99.8
SCHLUMBERGER	J55	C393137	08-15-02	100.2	99.7	100.3
SCHLUMBERGER	J55	C393138	08-15-02	99.9	99.8	100.2
SCHLUMBERGER	J55	C393139	08-15-02	100.3	100.2	100.3
SCHLUMBERGER	J55	C393140	08-15-02	100.1	99.9	99.8
SCHLUMBERGER	J55	C393141	08-15-02	100.2	100.0	99.7
SCHLUMBERGER	J55	C393142	08-15-02	99.9	99.8	99.9
SCHLUMBERGER	J55	C393143	08-15-02	100.1	99.7	100.2
SCHLUMBERGER	J55	C393144	08-15-02	100.1	100.0	100.4
SCHLUMBERGER	J55	C393145	08-15-02	100.1	99.8	100.2
SCHLUMBERGER	J55	C393146	08-15-02	100.1	100.0	99.8
SCHLUMBERGER	J55	C393147	08-15-02	100.1	100.1	100.4

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	J5S	C393148	08-15-02	100.2	99.8	100.0
SCHLUMBERGER	J5S	C393149	08-15-02	100.0	99.9	100.2
SCHLUMBERGER	J5S	C393150	08-15-02	100.1	99.8	100.0
SCHLUMBERGER	J5S	C393151	08-15-02	100.2	100.0	100.2
SCHLUMBERGER	J5S	C393152	08-15-02	99.9	100.4	100.0
SCHLUMBERGER	J5S	C393153	08-15-02	99.9	100.0	100.0
SCHLUMBERGER	J5S	C393154	08-15-02	99.9	99.7	99.9
SCHLUMBERGER	J5S	C393155	08-15-02	100.2	100.2	100.3
SCHLUMBERGER	J5S	C393156	08-15-02	100.1	100.1	99.8
SCHLUMBERGER	J5S	C393157	08-15-02	100.1	99.7	100.1
SCHLUMBERGER	J5S	C393158	08-15-02	100.0	99.8	99.9
SCHLUMBERGER	J5S	C393159	08-15-02	100.3	99.9	100.4
SCHLUMBERGER	J5S	C393160	08-15-02	99.9	100.1	99.7
SCHLUMBERGER	J5S	C393161	08-15-02	99.9	99.7	99.9
SCHLUMBERGER	J5S	C393162	08-15-02	99.9	99.9	100.1
SCHLUMBERGER	J5S	C393163	08-15-02	100.2	99.7	100.3
SCHLUMBERGER	J5S	C393164	08-15-02	100.1	99.9	100.4
SCHLUMBERGER	J5S	C393165	08-15-02	100.2	99.7	99.9
SCHLUMBERGER	J5S	C393166	08-15-02	100.1	100.1	100.5
SCHLUMBERGER	J5S	C393167	08-15-02	100.1	99.9	100.2
SCHLUMBERGER	J5S	C393168	08-15-02	100.3	100.1	100.1
SCHLUMBERGER	J5S	C393169	08-15-02	100.0	99.8	100.0
SCHLUMBERGER	J5S	C393170	08-15-02	100.1	99.8	100.2
SCHLUMBERGER	J5S	C393171	08-15-02	100.1	99.9	100.2
SCHLUMBERGER	J5S	C393172	08-15-02	100.0	99.9	100.2
SCHLUMBERGER	J5S	C393173	08-15-02	100.0	100.1	100.1
SCHLUMBERGER	J5S	C393174	08-15-02	100.3	100.1	100.4
SCHLUMBERGER	J5S	C393175	08-15-02	99.9	99.7	99.6
SCHLUMBERGER	J5S	C393176	08-15-02	100.1	100.0	100.5
SCHLUMBERGER	J5S	C393177	08-15-02	99.9	99.8	100.1
SCHLUMBERGER	J5S	C393178	08-15-02	100.1	99.6	99.8
SCHLUMBERGER	J5S	C393179	08-15-02	100.2	99.7	100.0
SCHLUMBERGER	J5S	C393180	08-15-02	100.0	99.9	99.9
SCHLUMBERGER	J5S	C393181	08-15-02	100.1	100.2	99.8
SCHLUMBERGER	J5S	C393182	08-15-02	100.1	99.6	99.7
SCHLUMBERGER	J5S	C393183	08-15-02	100.1	99.8	100.2
SCHLUMBERGER	J5S	C393184	08-15-02	100.3	99.6	100.4
SCHLUMBERGER	J5S	C393185	08-15-02	100.1	99.6	100.4
SCHLUMBERGER	J5S	C393186	08-15-02	100.0	100.1	100.0
SCHLUMBERGER	J5S	C393187	08-15-02	100.2	99.8	99.8
SCHLUMBERGER	J5S	C393188	08-15-02	99.9	99.7	100.4
SCHLUMBERGER	J5S	C393189	08-15-02	100.1	99.6	100.3
SCHLUMBERGER	J5S	C393190	08-15-02	100.1	99.7	99.7
SCHLUMBERGER	J5S	C393191	08-15-02	100.3	99.9	100.5
SCHLUMBERGER	J5S	C393192	08-15-02	99.8	99.9	99.8
SCHLUMBERGER	J5S	C393193	08-15-02	100.1	100.2	100.4
SCHLUMBERGER	J5S	C393194	08-15-02	99.9	100.3	99.6
SCHLUMBERGER	J5S	C393195	08-15-02	100.1	99.8	100.2
SCHLUMBERGER	J5S	C393196	08-15-02	100.3	99.8	100.4
SCHLUMBERGER	J5S	C393197	08-15-02	100.0	99.9	100.1
SCHLUMBERGER	J5S	C393198	08-15-02	100.1	99.6	100.1

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	J55	C393199	08-15-02	100.1	99.7	99.9
SCHLUMBERGER	J55	C393200	08-15-02	100.1	99.7	100.5
SCHLUMBERGER	J55	C393201	08-15-02	100.0	100.0	100.1
SCHLUMBERGER	J55	C393202	08-15-02	100.0	100.0	99.9
SCHLUMBERGER	J55	C393203	08-15-02	100.0	100.0	99.9
SCHLUMBERGER	J55	C393204	08-15-02	100.0	100.0	100.6
SCHLUMBERGER	J55	C393205	08-15-02	100.0	100.1	99.8
SCHLUMBERGER	J55	C393206	08-15-02	99.8	99.8	100.1
SCHLUMBERGER	J55	C393207	08-15-02	100.0	99.7	100.0
SCHLUMBERGER	J55	C393208	08-15-02	100.2	100.4	99.9
SCHLUMBERGER	J55	C393209	08-15-02	99.9	99.7	100.4
SCHLUMBERGER	J55	C393210	08-15-02	100.2	100.1	100.1
SCHLUMBERGER	J55	C393211	08-15-02	100.1	99.6	100.3
SCHLUMBERGER	J55	C393212	08-15-02	100.0	100.0	99.8
SCHLUMBERGER	J55	C393213	08-15-02	100.1	99.6	100.2
SCHLUMBERGER	J55	C393214	08-15-02	100.2	100.2	100.5
SCHLUMBERGER	J55	C393215	08-15-02	100.2	100.2	100.0
SCHLUMBERGER	J55	C393216	08-15-02	100.0	99.9	99.9
SCHLUMBERGER	J55	C393217	08-15-02	100.3	100.3	100.1
SCHLUMBERGER	J55	C393218	08-15-02	100.1	99.8	99.8
SCHLUMBERGER	J55	C393219	08-15-02	100.0	100.1	100.0
SCHLUMBERGER	J55	C393220	08-15-02	100.1	99.6	100.2
SCHLUMBERGER	J55	C393221	08-15-02	100.1	100.4	100.3
SCHLUMBERGER	J55	C393222	08-15-02	100.1	99.9	100.3
SCHLUMBERGER	J55	C393223	08-15-02	100.3	100.5	100.1
SCHLUMBERGER	J55	C393224	08-15-02	100.0	99.9	100.2
SCHLUMBERGER	J55	C393225	08-15-02	99.9	100.0	99.8
SCHLUMBERGER	J55	C393226	08-15-02	100.2	100.3	100.0
SCHLUMBERGER	J55	C393227	08-15-02	99.9	99.9	99.9
SCHLUMBERGER	J55	C393228	08-15-02	99.8	99.6	99.9
SCHLUMBERGER	J55	C393229	08-15-02	100.3	100.1	100.1
SCHLUMBERGER	J55	C393230	08-15-02	100.1	100.0	100.0
SCHLUMBERGER	J55	C393231	08-15-02	100.2	100.1	100.3
SCHLUMBERGER	J55	C393232	08-15-02	100.1	100.1	100.1
SCHLUMBERGER	J55	C393233	08-15-02	100.1	100.4	100.5
SCHLUMBERGER	J55	C393234	08-15-02	100.1	100.0	100.0
SCHLUMBERGER	J55	C393235	08-15-02	99.9	99.8	100.2
SCHLUMBERGER	J55	C393236	08-15-02	100.2	99.6	100.3
SCHLUMBERGER	J55	C393237	08-15-02	100.1	99.8	100.3
SCHLUMBERGER	J55	C393238	08-15-02	100.2	99.8	100.4
SCHLUMBERGER	J55	C393239	08-15-02	100.0	100.2	100.2
SCHLUMBERGER	J55	C393240	08-15-02	100.0	99.9	100.0
SCHLUMBERGER	J55	C393241	08-15-02	100.0	99.6	99.9
SCHLUMBERGER	J55	C393242	08-15-02	100.2	99.6	99.8
SCHLUMBERGER	J55	C393243	08-15-02	100.2	100.1	100.8
SCHLUMBERGER	J55	C393244	08-15-02	100.1	100.0	100.1
SCHLUMBERGER	J55	C393245	08-15-02	100.0	100.1	100.2
SCHLUMBERGER	J55	C393246	08-15-02	100.0	100.2	99.7
SCHLUMBERGER	J55	C393247	08-15-02	100.3	99.7	100.4
SCHLUMBERGER	J55	C393248	08-15-02	100.2	99.7	100.0
SCHLUMBERGER	J55	C393249	08-15-02	100.0	100.0	99.9

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	J55	C393250	08-15-02	100.2	100.2	100.4
SCHLUMBERGER	J55	C393251	08-15-02	100.2	99.9	99.8
SCHLUMBERGER	J55	C393252	08-15-02	100.1	100.3	99.8
SCHLUMBERGER	J55	C393253	08-15-02	100.1	100.3	100.2
SCHLUMBERGER	J55	C393254	08-15-02	100.1	99.9	100.2
SCHLUMBERGER	J55	C393255	08-15-02	100.0	100.1	99.9
SCHLUMBERGER	J55	C393256	08-15-02	100.1	100.3	100.2
SCHLUMBERGER	J55	C393257	08-15-02	100.1	99.7	99.9
SCHLUMBERGER	J55	C393258	08-15-02	100.2	99.8	100.1
SCHLUMBERGER	J55	C393259	08-15-02	100.2	100.4	100.0
SCHLUMBERGER	J55	C393260	08-15-02	100.1	100.3	100.0
SCHLUMBERGER	J55	C393261	08-15-02	100.1	99.8	100.0
SCHLUMBERGER	J55	C393262	08-15-02	100.2	100.1	99.9
SCHLUMBERGER	J55	C393263	08-15-02	100.0	99.9	100.2
SCHLUMBERGER	J55	C393264	08-15-02	100.0	100.1	99.7
SCHLUMBERGER	J55	C393265	08-15-02	100.0	100.4	100.1
SCHLUMBERGER	J55	C393266	08-15-02	100.2	100.2	100.0
SCHLUMBERGER	J55	C393267	08-15-02	100.1	100.3	100.1
SCHLUMBERGER	J55	C393268	08-15-02	99.8	99.9	99.8
SCHLUMBERGER	J55	C393269	08-15-02	100.0	99.7	99.9
SCHLUMBERGER	J55	C393270	08-15-02	100.0	99.6	99.9
SCHLUMBERGER	J55	C393271	08-15-02	99.8	99.8	99.7
SCHLUMBERGER	J55	C393272	08-15-02	99.8	99.7	99.7
SCHLUMBERGER	J55	C393273	08-15-02	100.1	100.2	100.3
SCHLUMBERGER	J55	C393274	08-15-02	100.0	99.9	100.1
SCHLUMBERGER	J55	C393275	08-15-02	100.1	100.7	99.7
SCHLUMBERGER	J55	C393276	08-15-02	100.2	99.7	100.2
SCHLUMBERGER	J55	C393277	08-15-02	100.1	99.9	99.9
SCHLUMBERGER	J55	C393278	08-15-02	100.1	99.8	99.9
SCHLUMBERGER	J55	C393279	08-15-02	100.2	99.8	99.6
SCHLUMBERGER	J55	C393280	08-15-02	100.0	99.7	99.6
SCHLUMBERGER	J55	C393281	08-15-02	100.1	99.9	99.9
SCHLUMBERGER	J55	C393282	08-15-02	100.1	99.9	99.9
SCHLUMBERGER	J55	C393283	08-15-02	100.2	99.7	99.6
SCHLUMBERGER	J55	C393284	08-15-02	100.1	99.9	99.9
SCHLUMBERGER	J55	C393285	08-15-02	100.0	99.9	100.1
SCHLUMBERGER	J55	C393286	08-15-02	99.9	100.0	100.2
SCHLUMBERGER	J55	C393287	08-15-02	99.9	99.6	99.7
SCHLUMBERGER	J55	C393288	08-15-02	100.0	99.8	99.6
SCHLUMBERGER	J55	C393289	08-15-02	100.1	99.8	100.0
SCHLUMBERGER	J55	C393290	08-15-02	100.2	99.8	100.1
SCHLUMBERGER	J55	C393291	08-15-02	99.9	100.3	100.0
SCHLUMBERGER	J55	C393292	08-15-02	100.0	99.9	99.8
SCHLUMBERGER	J55	C393293	08-15-02	100.1	99.7	99.6
SCHLUMBERGER	J55	C393294	08-15-02	100.1	99.8	100.0
SCHLUMBERGER	J55	C393295	08-15-02	99.9	99.8	100.3
SCHLUMBERGER	J55	C393296	08-15-02	100.1	99.9	100.3
SCHLUMBERGER	J55	C393297	08-15-02	100.0	99.8	99.9
SCHLUMBERGER	J55	C393298	08-15-02	100.0	100.0	100.0
SCHLUMBERGER	J55	C393299	08-15-02	100.0	99.8	99.9
SCHLUMBERGER	J55	C393300	08-15-02	100.1	100.3	100.4

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	J55	C393301	08-15-02	99.8	99.8	99.6
SCHLUMBERGER	J55	C393302	08-15-02	100.1	99.8	100.1
SCHLUMBERGER	J55	C393303	08-15-02	100.1	99.8	99.9
SCHLUMBERGER	J55	C393304	08-15-02	99.9	99.7	99.7
SCHLUMBERGER	J55	C393305	08-15-02	100.0	99.7	99.6
SCHLUMBERGER	J55	C393306	08-15-02	100.0	100.1	99.8
SCHLUMBERGER	J55	C393307	08-15-02	100.1	99.8	99.8
SCHLUMBERGER	J55	C393308	08-15-02	100.1	99.9	100.4
SCHLUMBERGER	J55	C393309	08-15-02	99.9	99.7	99.6
SCHLUMBERGER	J55	C393310	08-15-02	100.2	99.7	100.4
SCHLUMBERGER	J55	C393311	08-15-02	100.1	99.7	100.3
SCHLUMBERGER	J55	C393312	08-15-02	100.2	100.0	99.7
SCHLUMBERGER	J55	C393313	08-15-02	100.1	99.7	100.0
SCHLUMBERGER	J55	C393314	08-15-02	100.1	100.4	100.0
SCHLUMBERGER	J55	C393315	08-15-02	100.1	100.3	99.9
SCHLUMBERGER	J55	C393316	08-15-02	100.2	100.2	99.7
SCHLUMBERGER	J55	C393317	08-15-02	100.1	100.0	99.7
SCHLUMBERGER	J55	C393318	08-15-02	99.8	99.8	100.0
SCHLUMBERGER	J55	C393319	08-15-02	100.3	99.8	100.3
SCHLUMBERGER	J55	C393320	08-15-02	100.0	99.8	99.5
SCHLUMBERGER	J55	C393321	08-15-02	100.0	99.9	99.7
SCHLUMBERGER	J55	C393322	08-15-02	100.1	99.9	100.3
SCHLUMBERGER	J55	C393323	08-15-02	100.0	100.1	100.2
SCHLUMBERGER	J55	C393324	08-15-02	100.0	100.1	100.3
SCHLUMBERGER	J55	C393325	08-15-02	99.9	99.9	100.0
SCHLUMBERGER	J55	C393326	08-15-02	99.8	99.6	100.3
SCHLUMBERGER	J55	C393327	08-15-02	99.9	99.9	99.7
SCHLUMBERGER	J55	C393328	08-15-02	100.1	99.9	99.9
SCHLUMBERGER	J55	C393329	08-15-02	100.0	99.9	100.0
SCHLUMBERGER	J55	C393330	08-15-02	100.0	100.0	100.1
SCHLUMBERGER	J55	C393331	08-15-02	100.1	99.9	100.1
SCHLUMBERGER	J55	C393332	08-15-02	100.0	99.9	99.9
SCHLUMBERGER	J55	C393333	08-15-02	100.3	100.2	100.1
SCHLUMBERGER	J55	C393334	08-15-02	100.0	100.2	99.4
SCHLUMBERGER	J55	C393335	08-15-02	100.1	100.4	100.3
SCHLUMBERGER	J55	C393336	08-15-02	100.0	99.7	100.1
SCHLUMBERGER	J55	C393337	08-15-02	100.0	99.8	100.0
SCHLUMBERGER	J55	C393338	08-15-02	100.1	99.8	100.1
SCHLUMBERGER	J55	C393339	08-15-02	100.1	99.8	100.3
SCHLUMBERGER	J55	C393340	08-15-02	100.2	100.3	100.7
SCHLUMBERGER	J55	C393341	08-15-02	100.2	99.8	100.2
SCHLUMBERGER	J55	C393342	08-15-02	100.2	100.0	100.3
SCHLUMBERGER	J55	C393343	08-15-02	100.2	99.8	100.1
SCHLUMBERGER	J55	C393344	08-15-02	99.9	100.1	99.7
SCHLUMBERGER	J55	C393345	08-15-02	100.0	100.2	100.2
SCHLUMBERGER	J55	C393346	08-15-02	100.0	100.1	99.7
SCHLUMBERGER	J55	C393347	08-15-02	100.2	100.2	100.2
SCHLUMBERGER	J55	C393348	08-15-02	100.0	100.1	100.0
SCHLUMBERGER	J55	C393349	08-15-02	100.0	99.8	100.3
SCHLUMBERGER	J55	C393350	08-15-02	100.0	99.7	99.8
SCHLUMBERGER	J55	C393351	08-15-02	100.1	99.9	100.2

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

PAGE 168
 RUN DATE: 1/14/03
 RUN TIME: 13.26.53

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	J5S	C393352	08-15-02	100.1	99.7	100.4
SCHLUMBERGER	J5S	C393353	08-15-02	99.8	100.1	99.5
SCHLUMBERGER	J5S	C393354	08-15-02	100.1	100.0	100.0
SCHLUMBERGER	J5S	C393355	08-15-02	99.9	99.7	100.0
SCHLUMBERGER	J5S	C393356	08-15-02	100.2	100.2	100.1
SCHLUMBERGER	J5S	C393357	08-15-02	100.0	100.1	100.0
SCHLUMBERGER	J5S	C393358	08-15-02	99.9	100.1	99.7
SCHLUMBERGER	J5S	C393359	08-15-02	100.0	99.9	99.6
SCHLUMBERGER	J5S	C393360	08-15-02	99.9	99.7	99.9
SCHLUMBERGER	J5S	C393361	08-15-02	99.9	100.0	100.0
SCHLUMBERGER	J5S	C393362	08-15-02	100.0	100.1	100.1
SCHLUMBERGER	J5S	C393363	08-15-02	100.1	100.1	99.9
SCHLUMBERGER	J5S	C393364	08-15-02	100.0	99.9	99.9
SCHLUMBERGER	J5S	C393365	08-15-02	100.1	99.9	100.4
SCHLUMBERGER	J5S	C393366	08-15-02	100.1	100.1	99.9
SCHLUMBERGER	J5S	C393367	08-15-02	100.0	100.1	99.9
SCHLUMBERGER	J5S	C393368	08-15-02	100.1	99.7	100.1
SCHLUMBERGER	J5S	C393369	08-15-02	100.1	100.1	99.7
SCHLUMBERGER	J5S	C393370	08-15-02	100.0	99.8	100.0
SCHLUMBERGER	J5S	C393371	08-15-02	99.9	99.6	99.9
SCHLUMBERGER	J5S	C393372	08-15-02	100.1	99.7	100.3
SCHLUMBERGER	J5S	C393373	08-15-02	100.2	99.7	99.9
SCHLUMBERGER	J5S	C393374	08-15-02	100.2	99.8	100.5
SCHLUMBERGER	J5S	C393375	08-15-02	100.1	100.0	100.3
SCHLUMBERGER	J5S	C393376	08-15-02	100.0	99.7	99.9
SCHLUMBERGER	J5S	C393377	08-15-02	100.1	99.7	99.8
SCHLUMBERGER	J5S	C393378	08-15-02	100.0	100.1	100.1
SCHLUMBERGER	J5S	C393379	08-15-02	100.1	99.9	99.7
SCHLUMBERGER	J5S	C393380	08-15-02	100.2	99.9	100.0
SCHLUMBERGER	J5S	C393381	08-15-02	100.1	99.9	100.4
SCHLUMBERGER	J5S	C393382	08-15-02	100.1	99.7	100.6
SCHLUMBERGER	J5S	C393383	08-15-02	100.0	100.2	100.2
SCHLUMBERGER	J5S	C393384	08-15-02	100.1	100.1	100.1
SCHLUMBERGER	J5S	C393385	08-15-02	100.0	99.6	99.8
SCHLUMBERGER	J5S	C393386	08-15-02	100.0	99.7	100.1
SCHLUMBERGER	J5S	C393387	08-15-02	100.0	99.6	100.1
SCHLUMBERGER	J5S	C393388	08-15-02	100.0	99.9	100.4
SCHLUMBERGER	J5S	C393389	08-15-02	99.9	100.0	100.0
SCHLUMBERGER	J5S	C393390	08-15-02	100.1	99.8	100.2
SCHLUMBERGER	J5S	C393391	08-15-02	100.0	100.3	100.0
SCHLUMBERGER	J5S	C393392	08-15-02	100.1	99.9	100.2
SCHLUMBERGER	J5S	C393393	08-15-02	100.0	99.8	99.9
SCHLUMBERGER	J5S	C393394	08-15-02	100.1	99.9	100.2
SCHLUMBERGER	J5S	C393395	08-15-02	100.1	99.9	99.6
SCHLUMBERGER	J5S	C393396	08-15-02	100.1	100.3	100.3
SCHLUMBERGER	J5S	C393397	08-15-02	99.8	99.8	100.1
SCHLUMBERGER	J5S	C393398	08-15-02	100.1	99.9	100.1
SCHLUMBERGER	J5S	C393399	08-15-02	100.1	100.0	100.1
SCHLUMBERGER	J5S	C393400	08-15-02	99.8	99.7	99.9
SCHLUMBERGER	J5S	C393401	08-15-02	100.0	99.7	99.4
SCHLUMBERGER	J5S	C393402	08-15-02	100.1	99.8	99.4

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	J55	C393403	08-15-02	100.2	99.8	100.3
SCHLUMBERGER	J55	C393404	08-15-02	100.3	100.0	100.3
SCHLUMBERGER	J55	C393405	08-15-02	100.0	100.0	100.0
SCHLUMBERGER	J55	C393406	08-15-02	99.9	100.1	99.8
SCHLUMBERGER	J55	C393407	08-15-02	100.0	100.0	100.0
SCHLUMBERGER	J55	C393408	08-15-02	99.8	99.9	99.9
SCHLUMBERGER	J55	C393409	08-15-02	100.0	100.0	100.0
SCHLUMBERGER	J55	C393410	08-15-02	100.1	99.9	100.0
SCHLUMBERGER	J55	C393411	08-15-02	100.2	99.8	100.6
SCHLUMBERGER	J55	C393412	08-15-02	100.1	99.8	100.4
SCHLUMBERGER	J55	C393413	08-15-02	100.1	100.1	100.3
SCHLUMBERGER	J55	C393414	08-15-02	100.0	99.8	100.3
SCHLUMBERGER	J55	C393415	08-15-02	100.1	99.9	100.1
SCHLUMBERGER	J55	C393416	08-15-02	99.8	99.9	99.6
SCHLUMBERGER	J55	C393417	08-15-02	100.1	99.8	100.0
SCHLUMBERGER	J55	C393418	08-15-02	100.1	99.7	99.7
SCHLUMBERGER	J55	C393419	08-15-02	100.0	100.1	99.8
SCHLUMBERGER	J55	C393420	08-15-02	100.2	100.0	100.4
SCHLUMBERGER	J55	C393421	08-15-02	100.1	99.9	100.2
SCHLUMBERGER	J55	C393422	08-15-02	100.1	100.0	100.3
SCHLUMBERGER	J55	C393423	08-15-02	100.0	100.0	99.9
SCHLUMBERGER	J55	C393424	08-15-02	100.1	100.1	99.9
SCHLUMBERGER	J55	C393425	08-15-02	100.0	99.8	100.0
SCHLUMBERGER	J55	C393426	08-15-02	100.0	99.9	100.0
SCHLUMBERGER	J55	C393427	08-15-02	99.9	100.1	100.3
SCHLUMBERGER	J55	C393428	08-15-02	99.9	100.0	99.8
SCHLUMBERGER	J55	C393429	08-15-02	100.3	99.6	100.3
SCHLUMBERGER	J55	C393430	08-15-02	100.1	99.9	100.2
SCHLUMBERGER	J55	C393431	08-15-02	100.1	99.9	100.1
SCHLUMBERGER	J55	C393432	08-15-02	100.0	99.9	100.1
SCHLUMBERGER	J55	C393433	08-15-02	100.1	99.8	100.1
SCHLUMBERGER	J55	C393434	08-15-02	100.0	99.8	100.6
SCHLUMBERGER	J55	C393435	08-15-02	100.2	99.7	100.1
SCHLUMBERGER	J55	C393436	08-15-02	100.0	99.8	100.3
SCHLUMBERGER	J55	C393437	08-15-02	100.1	100.0	100.2
SCHLUMBERGER	J55	C393438	08-15-02	100.1	99.9	100.2
SCHLUMBERGER	J55	C393439	08-15-02	99.8	100.0	100.1
SCHLUMBERGER	J55	C393440	08-15-02	100.2	100.0	100.1
SCHLUMBERGER	J55	C393441	08-15-02	99.9	100.0	100.3
SCHLUMBERGER	J55	C393442	08-15-02	100.3	99.7	100.2
SCHLUMBERGER	J55	C393443	08-15-02	100.0	100.0	100.5
SCHLUMBERGER	J55	C393444	08-15-02	100.0	99.9	100.1
SCHLUMBERGER	J55	C393445	08-15-02	100.0	99.8	99.8
SCHLUMBERGER	J55	C393446	08-15-02	100.2	99.6	99.9
SCHLUMBERGER	J55	C393447	08-15-02	100.1	99.7	99.8
SCHLUMBERGER	J55	C393448	08-15-02	100.0	100.0	100.4
SCHLUMBERGER	J55	C393449	08-15-02	99.9	99.7	99.8
SCHLUMBERGER	J55	C393450	08-15-02	100.2	99.9	99.8
SCHLUMBERGER	J55	C393451	08-15-02	100.2	100.0	100.2
SCHLUMBERGER	J55	C393452	08-15-02	100.2	100.0	100.7
SCHLUMBERGER	J55	C393453	08-15-02	100.0	99.6	99.9

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD880

PAGE 170
 RUN DATE: 1/14/03
 RUN TIME: 13.26.53

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	J55	C393454	08-15-02	99.9	99.8	99.8
SCHLUMBERGER	J55	C393455	08-15-02	100.0	100.2	100.2
SCHLUMBERGER	J55	C393456	08-15-02	100.0	99.7	99.7
SCHLUMBERGER	J55	C393457	08-15-02	100.1	99.7	100.6
SCHLUMBERGER	J55	C393458	08-15-02	99.9	99.9	100.3
SCHLUMBERGER	J55	C393459	08-15-02	100.1	99.8	99.7
SCHLUMBERGER	J55	C393460	08-15-02	100.2	100.2	100.5
SCHLUMBERGER	J55	C393461	08-15-02	100.0	100.1	100.3
SCHLUMBERGER	J55	C393462	08-15-02	100.2	100.2	100.4
SCHLUMBERGER	J55	C393463	08-15-02	100.0	100.1	100.0
SCHLUMBERGER	J55	C393464	08-15-02	99.9	99.8	100.0
SCHLUMBERGER	J55	C393465	08-15-02	100.1	100.0	100.3
SCHLUMBERGER	J55	C393466	08-15-02	99.8	100.0	99.8
SCHLUMBERGER	J55	C393467	08-15-02	100.2	99.6	100.4
SCHLUMBERGER	J55	C393468	08-15-02	100.0	99.8	100.4
SCHLUMBERGER	J55	C393469	08-15-02	100.1	99.6	100.1
SCHLUMBERGER	J55	C393470	08-15-02	100.2	100.1	100.6
SCHLUMBERGER	J55	C393471	08-15-02	100.0	99.7	100.1
SCHLUMBERGER	J55	C393472	08-15-02	100.2	100.2	100.1
SCHLUMBERGER	J55	C393473	08-15-02	100.2	100.3	100.6
SCHLUMBERGER	J55	C393474	08-15-02	100.1	99.8	99.9
SCHLUMBERGER	J55	C393475	08-15-02	100.0	99.9	100.4
SCHLUMBERGER	J55	C393476	08-15-02	99.9	100.0	99.9
SCHLUMBERGER	J55	C393477	08-15-02	100.1	100.0	100.3
SCHLUMBERGER	J55	C393478	08-15-02	100.1	100.0	100.3
SCHLUMBERGER	J55	C393479	08-15-02	100.0	100.0	100.0
SCHLUMBERGER	J55	C393480	08-15-02	99.9	99.6	99.8
SCHLUMBERGER	J55	C393481	08-15-02	100.0	99.6	100.0
SCHLUMBERGER	J55	C393482	08-15-02	100.1	100.1	99.7
SCHLUMBERGER	J55	C393483	08-15-02	100.1	99.8	99.8
SCHLUMBERGER	J55	C393484	08-15-02	99.9	99.7	100.1
SCHLUMBERGER	J55	C393485	08-15-02	100.2	99.9	100.0
SCHLUMBERGER	J55	C393486	08-15-02	100.2	99.8	100.5
SCHLUMBERGER	J55	C393487	08-15-02	100.0	100.2	99.9
SCHLUMBERGER	J55	C393488	08-15-02	100.0	99.8	100.0
SCHLUMBERGER	J55	C393489	08-15-02	99.9	99.6	99.9
SCHLUMBERGER	J55	C393490	08-15-02	100.0	99.7	99.3
SCHLUMBERGER	J55	C393491	08-15-02	99.8	99.8	99.5
SCHLUMBERGER	J55	C393492	08-15-02	99.9	100.1	100.1
SCHLUMBERGER	J55	C393493	08-15-02	100.1	99.7	99.9
SCHLUMBERGER	J55	C393494	08-15-02	100.2	100.0	100.0
SCHLUMBERGER	J55	C393495	08-15-02	99.9	100.3	100.0
SCHLUMBERGER	J55	C393496	08-15-02	100.2	99.9	100.5
SCHLUMBERGER	J55	C393497	08-15-02	100.0	99.9	100.1
SCHLUMBERGER	J55	C393498	08-15-02	100.1	100.1	100.0
SCHLUMBERGER	J55	C393499	08-15-02	100.0	99.7	100.0
SCHLUMBERGER	J55	C393500	08-15-02	100.0	99.8	99.8
SCHLUMBERGER	J55	C393501	08-15-02	100.1	99.8	99.9
SCHLUMBERGER	J55	C393502	08-15-02	100.1	100.0	100.4
SCHLUMBERGER	J55	C393503	08-15-02	99.9	99.7	100.1
SCHLUMBERGER	J55	C393504	08-15-02	99.9	99.7	100.1

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

PAGE 171
 RUN DATE: 1/14/03
 RUN TIME: 13.26.53

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	J55	C3933505	08-15-02	100.0	100.1	99.9
SCHLUMBERGER	J55	C3933506	08-15-02	99.9	99.7	99.7
SCHLUMBERGER	J55	C3933507	08-15-02	99.9	100.0	100.0
SCHLUMBERGER	J55	C3933508	08-15-02	100.1	99.8	99.9
SCHLUMBERGER	J55	C3933509	08-15-02	100.0	99.8	99.7
SCHLUMBERGER	J55	C3933510	08-15-02	100.3	100.1	100.2
SCHLUMBERGER	J55	C3933511	08-15-02	99.8	99.6	99.8
SCHLUMBERGER	J55	C3933512	08-15-02	99.9	100.0	99.7
SCHLUMBERGER	J55	C3933513	08-15-02	100.1	99.6	100.1
SCHLUMBERGER	J55	C3933514	08-15-02	100.1	99.8	99.8
SCHLUMBERGER	J55	C3933515	08-15-02	99.9	99.7	100.0
SCHLUMBERGER	J55	C3933516	08-15-02	99.8	99.8	99.8
SCHLUMBERGER	J55	C3933517	08-15-02	100.1	100.0	100.0
SCHLUMBERGER	J55	C3933518	08-15-02	100.1	100.0	99.9
SCHLUMBERGER	J55	C3933519	08-15-02	100.1	99.8	100.1
SCHLUMBERGER	J55	C3933520	08-15-02	100.1	99.8	99.9
SCHLUMBERGER	J55	C3933521	08-15-02	100.1	99.9	100.1
SCHLUMBERGER	J55	C3933522	08-15-02	100.3	99.7	99.9
SCHLUMBERGER	J55	C3933523	08-15-02	100.2	99.8	100.1
SCHLUMBERGER	J55	C3933524	08-15-02	100.2	100.2	100.3
SCHLUMBERGER	J55	C3933525	08-15-02	100.2	99.7	100.1
SCHLUMBERGER	J55	C3933526	08-15-02	100.1	99.8	100.0
SCHLUMBERGER	J55	C3933527	08-15-02	100.2	99.7	99.9
SCHLUMBERGER	J55	C3933528	08-15-02	99.8	99.7	100.0
SCHLUMBERGER	J55	C3933529	08-15-02	100.1	99.9	100.4
SCHLUMBERGER	J55	C3933530	08-15-02	99.9	100.1	99.9
SCHLUMBERGER	J55	C3933531	08-15-02	100.0	99.7	99.8
SCHLUMBERGER	J55	C3933532	08-15-02	100.1	99.6	100.1
SCHLUMBERGER	J55	C3933533	08-15-02	100.0	100.3	100.2
SCHLUMBERGER	J55	C3933534	08-15-02	100.2	99.9	100.3
SCHLUMBERGER	J55	C3933535	08-15-02	100.1	99.7	99.9
SCHLUMBERGER	J55	C3933536	08-15-02	99.9	100.3	100.0
SCHLUMBERGER	J55	C3933537	08-15-02	100.1	99.7	100.3
SCHLUMBERGER	J55	C3933538	08-15-02	99.9	99.7	99.9
SCHLUMBERGER	J55	C3933539	08-15-02	100.0	99.7	99.9
SCHLUMBERGER	J55	C3933540	08-15-02	100.0	99.8	100.2
SCHLUMBERGER	J55	C3933541	08-15-02	100.0	100.0	100.0
SCHLUMBERGER	J55	C3933542	08-15-02	99.9	99.7	100.1
SCHLUMBERGER	J55	C3933543	08-15-02	100.0	99.8	100.1
SCHLUMBERGER	J55	C3933544	08-15-02	100.2	99.9	100.0
SCHLUMBERGER	J55	C3933545	08-15-02	100.0	100.1	100.0
SCHLUMBERGER	J55	C3933546	08-15-02	100.0	100.1	100.1
SCHLUMBERGER	J55	C3933547	08-15-02	100.1	100.0	99.9
SCHLUMBERGER	J55	C3933548	08-15-02	100.0	99.9	99.9
SCHLUMBERGER	J55	C3933549	08-15-02	100.2	99.9	100.2
SCHLUMBERGER	J55	C3933550	08-15-02	100.2	99.8	99.7
SCHLUMBERGER	J55	C3933551	08-15-02	100.0	100.3	100.3
SCHLUMBERGER	J55	C3933552	08-15-02	100.0	100.2	100.2
SCHLUMBERGER	J55	C3933553	08-15-02	99.9	99.8	99.8
SCHLUMBERGER	J55	C3933554	08-15-02	100.0	99.9	99.9
SCHLUMBERGER	J55	C3933555	08-15-02	100.1	99.9	100.0

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

PAGE 172
 RUN DATE: 1/14/03
 RUN TIME: 13.26.53

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	J5S	C393556	08-15-02	100.1	100.3	100.1
SCHLUMBERGER	J5S	C393557	08-15-02	100.2	99.9	100.1
SCHLUMBERGER	J5S	C393558	08-15-02	100.1	99.7	100.1
SCHLUMBERGER	J5S	C393559	08-15-02	100.2	99.7	100.3
SCHLUMBERGER	J5S	C393560	08-15-02	99.9	99.6	99.7
SCHLUMBERGER	J5S	C393561	08-15-02	99.8	100.1	99.7
SCHLUMBERGER	J5S	C393562	08-15-02	100.1	100.1	100.0
SCHLUMBERGER	J5S	C393563	08-15-02	100.0	100.0	100.0
SCHLUMBERGER	J5S	C393564	08-15-02	100.0	99.9	99.9
SCHLUMBERGER	J5S	C393565	08-15-02	100.1	99.7	99.8
SCHLUMBERGER	J5S	C393566	08-15-02	100.0	100.1	99.8
SCHLUMBERGER	J5S	C393567	08-15-02	100.0	99.9	99.9
SCHLUMBERGER	J5S	C393568	08-15-02	100.2	99.6	100.0
SCHLUMBERGER	J5S	C393569	08-15-02	99.9	100.1	100.1
SCHLUMBERGER	J5S	C393570	08-15-02	100.1	99.7	99.6
SCHLUMBERGER	J5S	C393571	08-15-02	100.1	100.1	99.8
SCHLUMBERGER	J5S	C393572	08-15-02	99.9	99.7	99.4
SCHLUMBERGER	J5S	C393573	08-15-02	100.0	100.1	99.9
SCHLUMBERGER	J5S	C393574	08-15-02	100.1	99.9	100.0
SCHLUMBERGER	J5S	C393575	08-15-02	100.0	99.9	99.9
SCHLUMBERGER	J5S	C393576	08-15-02	99.9	99.7	99.4
SCHLUMBERGER	J5S	C393577	08-15-02	100.0	99.6	100.1
SCHLUMBERGER	J5S	C393578	08-15-02	100.0	99.6	100.1
SCHLUMBERGER	J5S	C393579	08-15-02	100.2	99.8	99.9
SCHLUMBERGER	J5S	C393580	08-15-02	99.9	99.9	99.9
SCHLUMBERGER	J5S	C393581	08-15-02	100.1	99.8	100.1
SCHLUMBERGER	J5S	C393582	08-15-02	100.1	99.9	100.4
SCHLUMBERGER	J5S	C393583	08-15-02	100.3	99.0	100.2
SCHLUMBERGER	J5S	C393584	08-15-02	100.0	100.2	100.1
SCHLUMBERGER	J5S	C393585	08-15-02	100.0	100.0	100.3
SCHLUMBERGER	J5S	C393586	08-15-02	100.0	99.8	99.6
SCHLUMBERGER	J5S	C393587	08-15-02	100.1	100.2	99.5
SCHLUMBERGER	J5S	C393588	08-15-02	100.0	99.9	100.3
SCHLUMBERGER	J5S	C393589	08-15-02	99.8	99.7	99.5
SCHLUMBERGER	J5S	C393590	08-15-02	100.1	99.8	99.7
SCHLUMBERGER	J5S	C393591	08-15-02	100.2	100.2	100.7
SCHLUMBERGER	J5S	C393592	08-15-02	100.0	99.8	100.0
SCHLUMBERGER	J5S	C393593	08-15-02	100.1	100.1	100.1
SCHLUMBERGER	J5S	C393594	08-15-02	100.1	99.7	99.9
SCHLUMBERGER	J5S	C393595	08-15-02	99.9	99.8	99.9
SCHLUMBERGER	J5S	C393596	08-15-02	100.2	99.9	100.1
SCHLUMBERGER	J5S	C393597	08-15-02	100.2	100.0	99.6
SCHLUMBERGER	J5S	C393598	08-15-02	100.2	100.0	100.3
SCHLUMBERGER	J5S	C393599	08-15-02	100.0	99.8	100.0
SCHLUMBERGER	J5S	C393600	08-15-02	100.0	99.8	100.0
SCHLUMBERGER	J5S	C393601	08-15-02	100.1	99.9	100.5
SCHLUMBERGER	J5S	C393602	08-15-02	100.1	99.9	99.5
SCHLUMBERGER	J5S	C393603	08-15-02	100.1	99.9	100.0
SCHLUMBERGER	J5S	C393604	08-15-02	100.2	99.7	99.6
SCHLUMBERGER	J5S	C393605	08-15-02	100.3	100.1	100.1
SCHLUMBERGER	J5S	C393606	08-15-02	100.0	99.7	100.2

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

PAGE 173
 RUN DATE: 1/14/03
 RUN TIME: 13.26.53

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	J55	C393607	08-15-02	100.1	99.9	99.9
SCHLUMBERGER	J55	C393608	08-15-02	100.1	99.8	100.1
SCHLUMBERGER	J55	C393609	08-15-02	100.1	100.1	99.9
SCHLUMBERGER	J55	C393610	08-15-02	100.1	99.7	100.1
SCHLUMBERGER	J55	C393611	08-15-02	100.1	100.4	99.9
SCHLUMBERGER	J55	C393612	08-15-02	100.1	99.8	100.3
SCHLUMBERGER	J55	C393613	08-15-02	100.2	99.8	100.3
SCHLUMBERGER	J55	C393614	08-15-02	100.0	99.8	100.1
SCHLUMBERGER	J55	C393615	08-15-02	99.9	99.8	99.9
SCHLUMBERGER	J55	C393616	08-15-02	100.3	99.9	100.1
SCHLUMBERGER	J55	C393617	08-15-02	100.2	99.9	100.0
SCHLUMBERGER	J55	C393618	08-15-02	100.0	99.8	99.7
SCHLUMBERGER	J55	C393619	08-15-02	100.2	99.6	100.1
SCHLUMBERGER	J55	C393620	08-15-02	100.2	100.1	100.0
SCHLUMBERGER	J55	C393621	08-15-02	100.2	99.9	100.4
SCHLUMBERGER	J55	C393622	08-15-02	100.1	99.9	99.8
SCHLUMBERGER	J55	C393623	08-15-02	100.2	99.9	99.8
SCHLUMBERGER	J55	C393624	08-15-02	100.0	99.9	100.0
SCHLUMBERGER	J55	C393625	08-15-02	100.0	99.8	99.7
SCHLUMBERGER	J55	C393626	08-15-02	100.1	99.9	99.9
SCHLUMBERGER	J55	C393627	08-15-02	99.9	99.8	99.6
SCHLUMBERGER	J55	C393628	08-22-02	99.9	100.0	100.2
SCHLUMBERGER	J55	C393629	08-22-02	100.0	99.9	99.8
SCHLUMBERGER	J55	C393630	08-22-02	100.1	100.0	100.0
SCHLUMBERGER	J55	C393631	08-22-02	100.1	100.2	100.1
SCHLUMBERGER	J55	C393632	08-22-02	100.1	99.8	100.2
SCHLUMBERGER	J55	C393633	08-22-02	100.0	100.1	99.9
SCHLUMBERGER	J55	C393634	08-22-02	99.9	99.7	99.9
SCHLUMBERGER	J55	C393635	08-22-02	100.1	99.9	100.4
SCHLUMBERGER	J55	C393636	08-22-02	100.2	100.0	100.3
SCHLUMBERGER	J55	C393637	08-22-02	100.0	99.8	99.8
SCHLUMBERGER	J55	C393638	08-22-02	100.1	99.8	99.8
SCHLUMBERGER	J55	C393639	08-22-02	100.2	99.8	99.9
SCHLUMBERGER	J55	C393640	08-22-02	100.2	99.6	99.8
SCHLUMBERGER	J55	C393641	08-22-02	100.0	100.0	100.1
SCHLUMBERGER	J55	C393642	08-22-02	100.1	99.9	100.1
SCHLUMBERGER	J55	C393643	08-22-02	100.3	100.0	100.0
SCHLUMBERGER	J55	C393644	08-22-02	100.0	100.0	100.1
SCHLUMBERGER	J55	C393645	08-22-02	99.9	99.8	100.4
SCHLUMBERGER	J55	C393646	08-22-02	100.1	99.7	99.9
SCHLUMBERGER	J55	C393647	08-22-02	100.2	100.1	99.8
SCHLUMBERGER	J55	C393648	08-22-02	100.1	100.0	100.0
SCHLUMBERGER	J55	C393649	08-22-02	100.0	100.0	99.6
SCHLUMBERGER	J55	C393650	08-22-02	100.2	100.0	100.2
SCHLUMBERGER	J55	C393651	08-22-02	100.1	99.9	100.0
SCHLUMBERGER	J55	C393652	08-22-02	100.1	99.9	100.3
SCHLUMBERGER	J55	C393653	08-22-02	99.9	99.9	100.2
SCHLUMBERGER	J55	C393654	08-22-02	100.1	100.0	100.2
SCHLUMBERGER	J55	C393655	08-22-02	100.0	100.0	99.9
SCHLUMBERGER	J55	C393656	08-22-02	100.1	100.1	100.0
SCHLUMBERGER	J55	C393657	08-22-02	100.1	100.3	100.5

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	J5S	C393658	08-22-02	99.9	99.7	99.6
SCHLUMBERGER	J5S	C393659	08-22-02	99.9	99.7	99.5
SCHLUMBERGER	J5S	C393660	08-22-02	100.2	100.0	100.0
SCHLUMBERGER	J5S	C393661	08-22-02	100.1	100.0	100.2
SCHLUMBERGER	J5S	C393662	08-22-02	99.9	99.9	99.9
SCHLUMBERGER	J5S	C393663	08-22-02	100.0	99.8	100.2
SCHLUMBERGER	J5S	C393664	08-22-02	100.0	99.9	100.2
SCHLUMBERGER	J5S	C393665	08-22-02	100.0	100.0	100.1
SCHLUMBERGER	J5S	C393666	08-22-02	100.0	100.0	100.1
SCHLUMBERGER	J5S	C393667	08-22-02	100.1	99.8	100.1
SCHLUMBERGER	J5S	C393668	08-22-02	100.2	99.8	100.3
SCHLUMBERGER	J5S	C393669	08-22-02	100.2	100.0	100.3
SCHLUMBERGER	J5S	C393670	08-22-02	99.9	99.8	99.9
SCHLUMBERGER	J5S	C393671	08-22-02	100.0	99.9	100.0
SCHLUMBERGER	J5S	C393672	08-22-02	99.9	99.9	100.0
SCHLUMBERGER	J5S	C393673	08-22-02	100.0	100.1	99.9
SCHLUMBERGER	J5S	C393674	08-22-02	100.1	100.1	100.5
SCHLUMBERGER	J5S	C393675	08-22-02	100.1	100.1	99.8
SCHLUMBERGER	J5S	C393676	08-22-02	100.0	100.2	100.0
SCHLUMBERGER	J5S	C393677	08-22-02	100.2	100.0	100.2
SCHLUMBERGER	J5S	C393678	08-22-02	100.1	100.0	100.1
SCHLUMBERGER	J5S	C393679	08-22-02	100.0	99.9	99.9
SCHLUMBERGER	J5S	C393680	08-22-02	100.0	99.7	99.7
SCHLUMBERGER	J5S	C393681	08-22-02	100.0	99.8	99.8
SCHLUMBERGER	J5S	C393682	08-22-02	100.1	99.7	99.8
SCHLUMBERGER	J5S	C393683	08-22-02	100.1	99.8	100.1
SCHLUMBERGER	J5S	C393684	08-22-02	100.2	100.2	100.0
SCHLUMBERGER	J5S	C393685	08-22-02	100.0	100.1	100.0
SCHLUMBERGER	J5S	C393686	08-22-02	99.8	99.9	99.9
SCHLUMBERGER	J5S	C393687	08-22-02	100.1	100.0	99.9
SCHLUMBERGER	J5S	C393688	08-22-02	100.0	99.7	100.0
SCHLUMBERGER	J5S	C393689	08-22-02	99.9	99.9	99.6
SCHLUMBERGER	J5S	C393690	08-22-02	100.1	99.8	100.0
SCHLUMBERGER	J5S	C393691	08-22-02	99.9	99.8	100.0
SCHLUMBERGER	J5S	C393692	08-22-02	100.0	100.0	100.5
SCHLUMBERGER	J5S	C393693	08-22-02	100.0	100.0	100.3
SCHLUMBERGER	J5S	C393694	08-22-02	100.2	100.1	99.9
SCHLUMBERGER	J5S	C393695	08-22-02	100.1	99.8	100.4
SCHLUMBERGER	J5S	C393696	08-22-02	99.8	100.2	100.4
SCHLUMBERGER	J5S	C393697	08-22-02	99.8	100.0	100.5
SCHLUMBERGER	J5S	C393698	08-22-02	100.3	99.8	100.1
SCHLUMBERGER	J5S	C393699	08-22-02	100.1	99.7	100.0
SCHLUMBERGER	J5S	C393700	08-22-02	99.9	100.1	100.1
SCHLUMBERGER	J5S	C393701	08-22-02	99.9	100.0	100.1
SCHLUMBERGER	J5S	C393702	08-22-02	100.1	99.9	100.3
SCHLUMBERGER	J5S	C393703	08-22-02	100.1	100.2	100.4
SCHLUMBERGER	J5S	C393704	08-22-02	100.0	99.9	100.1
SCHLUMBERGER	J5S	C393705	08-22-02	100.2	100.0	100.3
SCHLUMBERGER	J5S	C393706	08-22-02	100.0	99.8	100.3
SCHLUMBERGER	J5S	C393707	08-22-02	100.0	100.2	100.0
SCHLUMBERGER	J5S	C393708	08-22-02	100.0	99.8	99.7
SCHLUMBERGER	J5S	C393708	08-22-02	100.0	100.0	100.1

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	J55	C393709	08-22-02	100.0	99.9	99.9
SCHLUMBERGER	J55	C393710	08-22-02	100.2	99.9	100.1
SCHLUMBERGER	J55	C393711	08-22-02	100.0	100.0	100.0
SCHLUMBERGER	J55	C393712	08-22-02	99.9	100.0	100.1
SCHLUMBERGER	J55	C393713	08-22-02	100.1	100.0	100.0
SCHLUMBERGER	J55	C393714	08-22-02	100.1	99.9	100.0
SCHLUMBERGER	J55	C393715	08-22-02	99.9	100.2	100.3
SCHLUMBERGER	J55	C393716	08-22-02	100.2	100.0	100.2
SCHLUMBERGER	J55	C393717	08-22-02	100.0	99.8	100.2
SCHLUMBERGER	J55	C393718	08-22-02	99.9	99.7	100.0
SCHLUMBERGER	J55	C393719	08-22-02	100.1	99.9	100.0
SCHLUMBERGER	J55	C393720	08-22-02	100.0	100.2	100.3
SCHLUMBERGER	J55	C393721	08-22-02	100.0	100.0	100.0
SCHLUMBERGER	J55	C393722	08-22-02	100.0	100.0	99.9
SCHLUMBERGER	J55	C393723	08-22-02	100.0	99.9	100.0
SCHLUMBERGER	J55	C393724	08-22-02	100.0	99.8	100.0
SCHLUMBERGER	J55	C393725	08-22-02	100.2	99.9	99.8
SCHLUMBERGER	J55	C393726	08-22-02	100.0	99.7	100.0
SCHLUMBERGER	J55	C393727	08-22-02	100.2	99.9	100.2
SCHLUMBERGER	J55	C393728	08-22-02	100.2	100.0	100.1
SCHLUMBERGER	J55	C393729	08-22-02	100.0	99.8	100.3
SCHLUMBERGER	J55	C393730	08-22-02	100.0	100.0	99.9
SCHLUMBERGER	J55	C393731	08-22-02	99.8	99.9	99.7
SCHLUMBERGER	J55	C393732	08-22-02	100.0	100.1	100.1
SCHLUMBERGER	J55	C393733	08-22-02	100.1	100.1	100.5
SCHLUMBERGER	J55	C393734	08-22-02	100.0	99.8	99.5
SCHLUMBERGER	J55	C393735	08-22-02	100.1	99.9	100.3
SCHLUMBERGER	J55	C393736	08-22-02	99.9	99.8	99.9
SCHLUMBERGER	J55	C393737	08-22-02	99.9	99.9	100.4
SCHLUMBERGER	J55	C393738	08-22-02	100.0	99.7	100.0
SCHLUMBERGER	J55	C393739	08-22-02	100.0	99.7	100.1
SCHLUMBERGER	J55	C393740	08-22-02	100.2	100.3	100.0
SCHLUMBERGER	J55	C393741	08-22-02	100.0	99.8	100.2
SCHLUMBERGER	J55	C393742	08-22-02	100.0	100.0	99.8
SCHLUMBERGER	J55	C393743	08-22-02	100.1	100.2	100.3
SCHLUMBERGER	J55	C393744	08-22-02	100.1	100.0	100.0
SCHLUMBERGER	J55	C393745	08-22-02	100.0	99.8	99.7
SCHLUMBERGER	J55	C393746	08-22-02	100.2	100.0	99.8
SCHLUMBERGER	J55	C393747	08-22-02	100.1	99.7	100.4
SCHLUMBERGER	J55	C393748	08-22-02	100.1	99.7	99.7
SCHLUMBERGER	J55	C393749	08-22-02	100.1	99.6	99.9
SCHLUMBERGER	J55	C393750	08-22-02	100.1	99.6	100.1
SCHLUMBERGER	J55	C393751	08-22-02	100.2	100.1	100.2
SCHLUMBERGER	J55	C393752	08-22-02	100.2	99.9	99.8
SCHLUMBERGER	J55	C393753	08-22-02	100.2	99.9	100.0
SCHLUMBERGER	J55	C393754	08-22-02	100.1	99.9	99.9
SCHLUMBERGER	J55	C393755	08-22-02	100.0	99.9	100.2
SCHLUMBERGER	J55	C393756	08-22-02	100.0	99.7	100.2
SCHLUMBERGER	J55	C393757	08-22-02	100.1	100.1	100.0
SCHLUMBERGER	J55	C393758	08-22-02	100.1	100.2	100.2
SCHLUMBERGER	J55	C393759	08-22-02	100.1	99.9	100.0

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

PAGE 176
 RUN DATE: 1/14/03
 RUN TIME: 13.26.53

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	J5S	C393760	08-22-02	100.1	99.9	100.3
SCHLUMBERGER	J5S	C393761	08-22-02	100.1	99.9	100.0
SCHLUMBERGER	J5S	C393762	08-22-02	100.0	99.6	100.3
SCHLUMBERGER	J5S	C393763	08-22-02	100.0	100.0	99.7
SCHLUMBERGER	J5S	C393764	08-22-02	100.1	99.8	100.0
SCHLUMBERGER	J5S	C393765	08-22-02	100.2	100.1	100.4
SCHLUMBERGER	J5S	C393766	08-22-02	100.1	99.6	100.2
SCHLUMBERGER	J5S	C393767	08-22-02	100.1	100.0	99.9
SCHLUMBERGER	J5S	C393768	08-22-02	100.0	99.6	100.3
SCHLUMBERGER	J5S	C393769	08-22-02	100.1	99.8	100.1
SCHLUMBERGER	J5S	C393770	08-22-02	100.2	100.2	100.2
SCHLUMBERGER	J5S	C393771	08-22-02	100.1	100.1	100.0
SCHLUMBERGER	J5S	C393772	08-22-02	100.0	100.1	99.9
SCHLUMBERGER	J5S	C393773	08-22-02	100.1	100.2	100.0
SCHLUMBERGER	J5S	C393774	08-22-02	100.1	99.8	100.1
SCHLUMBERGER	J5S	C393775	08-22-02	100.1	99.8	100.6
SCHLUMBERGER	J5S	C393776	08-22-02	99.9	99.8	99.8
SCHLUMBERGER	J5S	C393777	08-22-02	100.1	99.8	100.1
SCHLUMBERGER	J5S	C393778	08-22-02	100.3	100.1	100.3
SCHLUMBERGER	J5S	C393779	08-22-02	100.2	99.9	100.0
SCHLUMBERGER	J5S	C393780	08-22-02	100.0	100.1	99.9
SCHLUMBERGER	J5S	C393781	08-22-02	99.9	99.9	99.9
SCHLUMBERGER	J5S	C393782	08-22-02	100.2	100.4	100.6
SCHLUMBERGER	J5S	C393783	08-22-02	100.0	100.2	100.3
SCHLUMBERGER	J5S	C393784	08-22-02	100.0	99.9	99.9
SCHLUMBERGER	J5S	C393785	08-22-02	100.0	99.9	99.7
SCHLUMBERGER	J5S	C393786	08-22-02	100.1	100.0	100.5
SCHLUMBERGER	J5S	C393787	08-22-02	100.1	100.1	99.9
SCHLUMBERGER	J5S	C393788	08-22-02	100.2	99.7	100.0
SCHLUMBERGER	J5S	C393789	08-22-02	100.0	99.7	100.3
SCHLUMBERGER	J5S	C393790	08-22-02	100.1	99.8	100.4
SCHLUMBERGER	J5S	C393791	08-22-02	100.1	99.9	99.9
SCHLUMBERGER	J5S	C393792	08-22-02	100.3	99.8	100.1
SCHLUMBERGER	J5S	C393793	08-22-02	100.2	99.8	100.1
SCHLUMBERGER	J5S	C393794	08-22-02	100.1	100.0	100.4
SCHLUMBERGER	J5S	C393795	08-22-02	100.0	100.1	99.5
SCHLUMBERGER	J5S	C393796	08-22-02	100.1	100.0	100.6
SCHLUMBERGER	J5S	C393797	08-22-02	100.1	100.1	100.2
SCHLUMBERGER	J5S	C393798	08-22-02	100.0	99.8	100.2
SCHLUMBERGER	J5S	C393799	08-22-02	100.1	99.9	99.7
SCHLUMBERGER	J5S	C393800	08-22-02	100.0	99.9	99.8
SCHLUMBERGER	J5S	C393801	08-22-02	100.2	100.0	99.6
SCHLUMBERGER	J5S	C393802	08-22-02	100.2	100.2	100.3
SCHLUMBERGER	J5S	C393803	08-22-02	100.1	99.7	100.5
SCHLUMBERGER	J5S	C393804	08-22-02	100.0	99.9	99.8
SCHLUMBERGER	J5S	C393805	08-22-02	100.0	99.9	100.3
SCHLUMBERGER	J5S	C393806	08-22-02	100.2	99.8	100.0
SCHLUMBERGER	J5S	C393807	08-22-02	100.1	99.7	100.0
SCHLUMBERGER	J5S	C393808	08-22-02	100.0	99.6	99.7
SCHLUMBERGER	J5S	C393809	08-22-02	100.0	99.7	100.0
SCHLUMBERGER	J5S	C393810	08-22-02	100.1	100.2	100.2

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

PAGE 177
 RUN DATE: 1/14/03
 RUN TIME: 13.26.53

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	J55	C393811	08-22-02	100.0	100.3	100.3
SCHLUMBERGER	J55	C393812	08-22-02	100.0	99.8	99.8
SCHLUMBERGER	J55	C393813	08-22-02	100.0	100.0	99.9
SCHLUMBERGER	J55	C393814	08-22-02	100.0	100.2	99.9
SCHLUMBERGER	J55	C393815	08-22-02	100.0	100.1	100.3
SCHLUMBERGER	J55	C393816	08-22-02	100.1	99.8	100.2
SCHLUMBERGER	J55	C393817	08-22-02	100.1	100.2	100.2
SCHLUMBERGER	J55	C393818	08-22-02	100.0	100.1	99.8
SCHLUMBERGER	J55	C393819	08-22-02	100.0	99.8	99.9
SCHLUMBERGER	J55	C393820	08-22-02	100.1	99.7	100.2
SCHLUMBERGER	J55	C393821	08-22-02	100.0	99.6	99.8
SCHLUMBERGER	J55	C393822	08-22-02	100.0	99.8	99.8
SCHLUMBERGER	J55	C393823	08-22-02	100.1	100.1	99.9
SCHLUMBERGER	J55	C393824	08-22-02	99.9	99.6	99.9
SCHLUMBERGER	J55	C393825	08-22-02	100.1	99.7	100.0
SCHLUMBERGER	J55	C393826	08-22-02	100.0	100.0	100.0
SCHLUMBERGER	J55	C393827	08-22-02	99.9	100.0	100.0
SCHLUMBERGER	J55	C393828	08-22-02	100.0	99.9	99.7
SCHLUMBERGER	J55	C393829	08-22-02	100.0	100.1	99.8
SCHLUMBERGER	J55	C393830	08-22-02	100.1	99.9	99.9
SCHLUMBERGER	J55	C393831	08-22-02	100.1	100.0	99.9
SCHLUMBERGER	J55	C393832	08-22-02	100.1	100.0	99.9
SCHLUMBERGER	J55	C393833	08-22-02	100.0	100.0	99.7
SCHLUMBERGER	J55	C393834	08-22-02	100.2	99.8	99.9
SCHLUMBERGER	J55	C393835	08-22-02	99.9	99.9	99.9
SCHLUMBERGER	J55	C393836	08-22-02	100.1	100.1	100.3
SCHLUMBERGER	J55	C393837	08-22-02	100.3	99.8	100.1
SCHLUMBERGER	J55	C393838	08-22-02	100.1	99.8	100.0
SCHLUMBERGER	J55	C393839	08-22-02	100.1	99.7	100.2
SCHLUMBERGER	J55	C393840	08-22-02	99.9	99.7	99.6
SCHLUMBERGER	J55	C393841	08-22-02	100.0	100.0	100.1
SCHLUMBERGER	J55	C393842	08-22-02	99.9	99.6	99.6
SCHLUMBERGER	J55	C393843	08-22-02	100.1	99.9	99.8
SCHLUMBERGER	J55	C393844	08-22-02	100.1	99.8	99.8
SCHLUMBERGER	J55	C393845	08-22-02	100.0	99.6	100.3
SCHLUMBERGER	J55	C393846	08-22-02	100.0	99.6	99.8
SCHLUMBERGER	J55	C393847	08-22-02	100.0	99.7	100.0
SCHLUMBERGER	J55	C393848	08-22-02	100.1	100.0	99.9
SCHLUMBERGER	J55	C393849	08-22-02	100.1	100.1	99.9
SCHLUMBERGER	J55	C393850	08-22-02	100.0	99.9	100.1
SCHLUMBERGER	J55	C393851	08-22-02	100.1	100.1	99.6
SCHLUMBERGER	J55	C393852	08-22-02	100.0	99.6	100.1
SCHLUMBERGER	J55	C393853	08-22-02	99.8	99.8	99.7
SCHLUMBERGER	J55	C393854	08-22-02	100.0	100.0	99.8
SCHLUMBERGER	J55	C393855	08-22-02	100.1	100.4	99.9
SCHLUMBERGER	J55	C393856	08-22-02	100.1	99.9	100.0
SCHLUMBERGER	J55	C393857	08-22-02	99.8	99.8	100.1
SCHLUMBERGER	J55	C393858	08-22-02	99.8	100.0	99.9
SCHLUMBERGER	J55	C393859	08-22-02	100.2	100.0	99.9
SCHLUMBERGER	J55	C393860	08-22-02	99.9	99.8	100.4
SCHLUMBERGER	J55	C393861	08-22-02	100.0	99.7	99.8

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

PAGE 178
 RUN DATE: 1/14/03
 RUN TIME: 13.26.53

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	J55	C393862	08-22-02	100.1	99.7	100.1
SCHLUMBERGER	J55	C393863	08-22-02	100.2	100.0	100.2
SCHLUMBERGER	J55	C393864	08-22-02	100.0	100.3	99.9
SCHLUMBERGER	J55	C393865	08-22-02	100.1	99.7	100.0
SCHLUMBERGER	J55	C393866	08-22-02	100.1	99.9	99.7
SCHLUMBERGER	J55	C393867	08-22-02	99.8	99.9	99.8
SCHLUMBERGER	J55	C393868	08-22-02	100.0	99.8	100.0
SCHLUMBERGER	J55	C393869	08-22-02	100.1	100.3	99.8
SCHLUMBERGER	J55	C393870	08-22-02	100.1	100.4	100.1
SCHLUMBERGER	J55	C393871	08-22-02	100.0	99.8	99.7
SCHLUMBERGER	J55	C393872	08-22-02	100.0	99.9	100.1
SCHLUMBERGER	J55	C393873	08-22-02	100.0	99.8	100.0
SCHLUMBERGER	J55	C393874	08-22-02	100.1	99.8	100.1
SCHLUMBERGER	J55	C393875	08-22-02	100.1	99.8	100.3
SCHLUMBERGER	J55	C393876	08-22-02	100.0	99.7	99.8
SCHLUMBERGER	J55	C393877	08-22-02	100.1	100.1	100.0
SCHLUMBERGER	J55	C393878	08-22-02	100.1	100.1	100.1
SCHLUMBERGER	J55	C393879	08-22-02	99.9	99.7	99.8
SCHLUMBERGER	J55	C393880	08-22-02	100.1	99.8	99.8
SCHLUMBERGER	J55	C393881	08-22-02	100.1	99.8	100.3
SCHLUMBERGER	J55	C393882	08-22-02	99.9	99.7	99.8
SCHLUMBERGER	J55	C393883	08-22-02	100.1	100.2	99.9
SCHLUMBERGER	J55	C393884	08-22-02	100.0	99.8	99.7
SCHLUMBERGER	J55	C393885	08-22-02	100.0	100.2	100.0
SCHLUMBERGER	J55	C393886	08-22-02	100.0	100.0	99.9
SCHLUMBERGER	J55	C393887	08-22-02	100.1	100.0	99.9
SCHLUMBERGER	J55	C393888	08-22-02	100.2	100.0	100.3
SCHLUMBERGER	J55	C393889	08-22-02	100.1	100.3	99.7
SCHLUMBERGER	J55	C393890	08-22-02	99.9	99.8	99.6
SCHLUMBERGER	J55	C393891	08-22-02	100.1	99.8	100.1
SCHLUMBERGER	J55	C393892	08-22-02	100.0	100.0	99.7
SCHLUMBERGER	J55	C393893	08-22-02	100.1	100.1	100.0
SCHLUMBERGER	J55	C393894	08-22-02	100.1	100.1	99.8
SCHLUMBERGER	J55	C393895	08-22-02	100.1	100.0	100.1
SCHLUMBERGER	J55	C393896	08-22-02	100.1	99.9	99.9
SCHLUMBERGER	J55	C393897	08-22-02	100.1	99.6	99.8
SCHLUMBERGER	J55	C393898	08-22-02	100.0	100.0	99.8
SCHLUMBERGER	J55	C393899	08-22-02	100.0	100.0	99.7
SCHLUMBERGER	J55	C393900	08-22-02	100.1	100.3	100.0
SCHLUMBERGER	J55	C393901	08-22-02	99.9	99.7	99.6
SCHLUMBERGER	J55	C393902	08-22-02	100.1	99.8	99.8
SCHLUMBERGER	J55	C393903	08-22-02	100.2	99.9	99.9
SCHLUMBERGER	J55	C393904	08-22-02	100.1	99.8	99.8
SCHLUMBERGER	J55	C393905	08-22-02	100.2	100.5	100.3
SCHLUMBERGER	J55	C393906	08-22-02	100.2	99.8	99.9
SCHLUMBERGER	J55	C393907	08-22-02	100.0	99.8	99.7
SCHLUMBERGER	J55	C393908	08-22-02	99.9	100.1	99.6
SCHLUMBERGER	J55	C393909	08-22-02	100.1	100.0	99.6
SCHLUMBERGER	J55	C393910	08-22-02	100.0	100.0	99.8
SCHLUMBERGER	J55	C393911	08-22-02	100.0	99.6	99.6
SCHLUMBERGER	J55	C393912	08-22-02	100.1	100.1	99.8

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

PAGE 179
 RUN DATE: 1/14/03
 RUN TIME: 13.26.53

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	J55	C393913	08-22-02	99.9	99.8	99.9
SCHLUMBERGER	J55	C393914	08-22-02	99.9	100.0	99.8
SCHLUMBERGER	J55	C393915	08-22-02	100.1	100.2	100.2
SCHLUMBERGER	J55	C393916	08-22-02	100.2	100.0	100.0
SCHLUMBERGER	J55	C393917	08-22-02	100.1	99.8	100.0
SCHLUMBERGER	J55	C393918	08-22-02	100.2	100.1	100.2
SCHLUMBERGER	J55	C393919	08-22-02	100.1	99.8	99.9
SCHLUMBERGER	J55	C393920	08-22-02	100.0	100.0	99.8
SCHLUMBERGER	J55	C393921	08-22-02	100.1	99.6	99.9
SCHLUMBERGER	J55	C393922	08-22-02	100.1	100.0	100.1
SCHLUMBERGER	J55	C393923	08-22-02	100.2	100.1	99.6
SCHLUMBERGER	J55	C393924	08-22-02	100.0	99.6	100.1
SCHLUMBERGER	J55	C393925	08-22-02	100.2	99.8	99.7
SCHLUMBERGER	J55	C393926	08-22-02	100.0	99.7	100.0
SCHLUMBERGER	J55	C393927	08-22-02	100.0	100.0	99.6
SCHLUMBERGER	J55	C393928	08-22-02	100.1	100.0	100.4
SCHLUMBERGER	J55	C393929	08-22-02	99.9	100.0	99.8
SCHLUMBERGER	J55	C393930	08-22-02	99.9	100.0	99.9
SCHLUMBERGER	J55	C393931	08-22-02	100.1	100.0	99.8
SCHLUMBERGER	J55	C393932	08-22-02	100.2	99.8	99.8
SCHLUMBERGER	J55	C393933	08-22-02	100.2	100.0	100.0
SCHLUMBERGER	J55	C393934	08-22-02	100.0	100.4	100.0
SCHLUMBERGER	J55	C393935	08-22-02	100.0	100.1	100.1
SCHLUMBERGER	J55	C393936	08-22-02	100.1	99.7	100.2
SCHLUMBERGER	J55	C393937	08-22-02	100.1	99.9	99.9
SCHLUMBERGER	J55	C393938	08-22-02	100.1	99.9	99.9
SCHLUMBERGER	J55	C393939	08-22-02	100.0	99.7	100.3
SCHLUMBERGER	J55	C393940	08-22-02	100.2	99.8	99.9
SCHLUMBERGER	J55	C393941	08-22-02	100.0	99.9	100.2
SCHLUMBERGER	J55	C393942	08-22-02	100.0	99.7	99.7
SCHLUMBERGER	J55	C393943	08-22-02	100.1	100.2	100.2
SCHLUMBERGER	J55	C393944	08-22-02	100.1	99.6	99.5
SCHLUMBERGER	J55	C393945	08-22-02	100.0	99.6	100.0
SCHLUMBERGER	J55	C393946	08-22-02	100.1	99.9	100.4
SCHLUMBERGER	J55	C393947	08-22-02	100.1	99.7	100.0
SCHLUMBERGER	J55	C393948	08-22-02	100.2	100.3	100.2
SCHLUMBERGER	J55	C393949	08-22-02	100.0	100.1	100.3
SCHLUMBERGER	J55	C393950	08-22-02	99.9	100.0	99.6
SCHLUMBERGER	J55	C393951	08-22-02	100.1	100.2	100.0
SCHLUMBERGER	J55	C393952	08-22-02	100.0	99.8	99.8
SCHLUMBERGER	J55	C393953	08-22-02	100.0	99.7	99.8
SCHLUMBERGER	J55	C393954	08-22-02	100.1	100.2	100.0
SCHLUMBERGER	J55	C393955	08-22-02	100.3	99.6	100.0
SCHLUMBERGER	J55	C393956	08-22-02	100.2	100.4	100.1
SCHLUMBERGER	J55	C393957	08-22-02	100.1	100.1	99.7
SCHLUMBERGER	J55	C393958	08-22-02	100.0	99.8	99.7
SCHLUMBERGER	J55	C393959	08-22-02	100.1	100.1	99.8
SCHLUMBERGER	J55	C393960	08-22-02	100.2	100.4	100.4
SCHLUMBERGER	J55	C393961	08-22-02	99.7	99.9	99.6
SCHLUMBERGER	J55	C393962	08-22-02	99.9	99.7	100.0
SCHLUMBERGER	J55	C393963	08-22-02	100.1	99.7	100.0

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

PAGE 180
 RUN DATE: 1/14/03
 RUN TIME: 13.26.53

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	J5S	C393964	08-22-02	99.9	99.9	99.7
SCHLUMBERGER	J5S	C393965	08-22-02	100.0	99.7	100.2
SCHLUMBERGER	J5S	C393966	08-22-02	99.9	99.9	100.1
SCHLUMBERGER	J5S	C393967	08-22-02	99.9	99.7	99.9
SCHLUMBERGER	J5S	C393968	08-22-02	100.0	99.9	99.8
SCHLUMBERGER	J5S	C393969	08-22-02	100.1	100.2	99.8
SCHLUMBERGER	J5S	C393970	08-22-02	100.3	99.9	99.8
SCHLUMBERGER	J5S	C393971	08-22-02	99.9	100.0	100.3
SCHLUMBERGER	J5S	C393972	08-22-02	99.8	99.8	99.7
SCHLUMBERGER	J5S	C393973	08-22-02	100.0	100.0	99.8
SCHLUMBERGER	J5S	C393974	08-22-02	100.2	99.6	99.9
SCHLUMBERGER	J5S	C393975	08-22-02	99.8	99.7	99.8
SCHLUMBERGER	J5S	C393976	08-22-02	99.9	100.2	99.7
SCHLUMBERGER	J5S	C393977	08-22-02	100.1	99.7	100.1
SCHLUMBERGER	J5S	C393978	08-22-02	100.0	99.8	99.5
SCHLUMBERGER	J5S	C393979	08-22-02	100.2	100.2	99.9
SCHLUMBERGER	J5S	C393980	08-22-02	99.8	99.8	100.0
SCHLUMBERGER	J5S	C393981	08-22-02	100.0	99.8	99.6
SCHLUMBERGER	J5S	C393982	08-22-02	100.0	100.2	99.8
SCHLUMBERGER	J5S	C393983	08-22-02	100.0	100.0	99.5
SCHLUMBERGER	J5S	C393984	08-22-02	100.1	99.8	99.9
SCHLUMBERGER	J5S	C393985	08-22-02	100.1	99.8	100.1
SCHLUMBERGER	J5S	C393986	08-22-02	100.1	100.3	99.9
SCHLUMBERGER	J5S	C393987	08-22-02	100.0	100.3	99.9
SCHLUMBERGER	J5S	C393988	08-22-02	100.0	99.9	99.8
SCHLUMBERGER	J5S	C393989	08-22-02	100.2	99.7	100.2
SCHLUMBERGER	J5S	C393990	08-22-02	100.0	99.9	99.8
SCHLUMBERGER	J5S	C393991	08-22-02	100.0	99.9	99.8
SCHLUMBERGER	J5S	C393992	08-22-02	100.0	100.2	100.5
SCHLUMBERGER	J5S	C393993	08-22-02	100.1	100.1	99.9
SCHLUMBERGER	J5S	C393994	08-22-02	99.9	99.7	99.7
SCHLUMBERGER	J5S	C393995	08-22-02	100.0	100.1	100.0
SCHLUMBERGER	J5S	C393996	08-22-02	100.3	99.8	99.8
SCHLUMBERGER	J5S	C393997	08-22-02	100.3	100.0	100.3
SCHLUMBERGER	J5S	C393998	08-22-02	100.1	100.0	100.1
SCHLUMBERGER	J5S	C393999	08-22-02	100.0	99.7	99.7
SCHLUMBERGER	J5S	C394000	08-22-02	100.1	99.7	100.0
SCHLUMBERGER	J5S	C394001	08-22-02	99.9	99.9	99.5
SCHLUMBERGER	J5S	C394002	08-22-02	100.0	99.9	99.4
SCHLUMBERGER	J5S	C394003	08-22-02	99.9	99.7	100.0
SCHLUMBERGER	J5S	C394004	08-22-02	100.0	100.0	100.1
SCHLUMBERGER	J5S	C394005	08-22-02	100.1	99.7	99.8
SCHLUMBERGER	J5S	C394006	08-22-02	100.0	100.1	99.7
SCHLUMBERGER	J5S	C394007	08-22-02	100.0	100.0	99.8
SCHLUMBERGER	J5S	C394008	08-22-02	100.2	99.7	100.0
SCHLUMBERGER	J5S	C394009	08-22-02	100.1	100.3	100.1
SCHLUMBERGER	J5S	C394010	08-22-02	100.1	100.0	99.8
SCHLUMBERGER	J5S	C394011	08-22-02	100.0	100.0	99.8
SCHLUMBERGER	J5S	C394012	08-22-02	99.9	99.9	99.7
SCHLUMBERGER	J5S	C394013	08-22-02	100.2	100.1	99.9
SCHLUMBERGER	J5S	C394014	08-22-02	100.0	100.0	99.7

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

PAGE 181
 RUN DATE: 1/14/03
 RUN TIME: 13.26.53

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	J55	C394015	08-22-02	100.0	99.8	99.7
SCHLUMBERGER	J55	C394016	08-22-02	100.0	99.9	99.7
SCHLUMBERGER	J55	C394017	08-22-02	100.1	99.6	100.0
SCHLUMBERGER	J55	C394018	08-22-02	100.1	99.7	100.1
SCHLUMBERGER	J55	C394019	08-22-02	100.0	100.0	99.8
SCHLUMBERGER	J55	C394020	08-22-02	99.9	99.7	99.5
SCHLUMBERGER	J55	C394021	08-22-02	100.1	99.8	99.6
SCHLUMBERGER	J55	C394022	08-22-02	100.1	100.0	100.4
SCHLUMBERGER	J55	C394023	08-22-02	100.0	99.9	99.6
SCHLUMBERGER	J55	C394024	08-22-02	100.1	99.8	99.7
SCHLUMBERGER	J55	C394025	08-22-02	99.9	99.9	100.0
SCHLUMBERGER	J55	C394026	08-22-02	100.3	99.7	99.7
SCHLUMBERGER	J55	C394027	08-22-02	100.0	99.9	99.6
SCHLUMBERGER	J55	C394028	08-22-02	100.0	100.1	100.0
SCHLUMBERGER	J55	C394029	08-22-02	99.9	99.8	99.8
SCHLUMBERGER	J55	C394030	08-22-02	99.9	99.9	99.8
SCHLUMBERGER	J55	C394031	08-22-02	100.0	99.9	99.7
SCHLUMBERGER	J55	C394032	08-22-02	100.0	99.9	99.9
SCHLUMBERGER	J55	C394033	08-22-02	100.1	100.0	100.1
SCHLUMBERGER	J55	C394034	08-22-02	99.9	100.2	99.8
SCHLUMBERGER	J55	C394035	08-22-02	99.9	100.0	99.8
SCHLUMBERGER	J55	C394036	08-22-02	100.0	100.0	100.0
SCHLUMBERGER	J55	C394037	08-22-02	100.0	100.2	100.1
SCHLUMBERGER	J55	C394038	08-22-02	100.1	99.8	100.0
SCHLUMBERGER	J55	C394039	08-22-02	100.1	99.6	99.8
SCHLUMBERGER	J55	C394040	08-22-02	100.3	100.3	99.9
SCHLUMBERGER	J55	C394041	08-22-02	100.1	99.8	99.9
SCHLUMBERGER	J55	C394042	08-22-02	100.0	99.8	99.8
SCHLUMBERGER	J55	C394043	08-22-02	100.0	100.1	99.9
SCHLUMBERGER	J55	C394044	08-22-02	100.0	100.0	99.7
SCHLUMBERGER	J55	C394045	08-22-02	100.1	99.7	99.7
SCHLUMBERGER	J55	C394046	08-22-02	100.0	99.9	99.7
SCHLUMBERGER	J55	C394047	08-22-02	100.1	99.9	100.1
SCHLUMBERGER	J55	C394048	08-22-02	100.0	99.9	99.6
SCHLUMBERGER	J55	C394049	08-22-02	100.0	99.8	99.6
SCHLUMBERGER	J55	C394050	08-22-02	100.0	99.8	99.7
SCHLUMBERGER	J55	C394051	08-22-02	100.1	99.9	100.0
SCHLUMBERGER	J55	C394052	08-22-02	100.1	99.9	99.4
SCHLUMBERGER	J55	C394053	08-22-02	100.0	99.8	100.1
SCHLUMBERGER	J55	C394054	08-22-02	99.9	99.8	99.9
SCHLUMBERGER	J55	C394055	08-22-02	99.8	99.9	100.0
SCHLUMBERGER	J55	C394056	08-22-02	100.0	99.9	99.4
SCHLUMBERGER	J55	C394057	08-22-02	100.0	99.6	99.9
SCHLUMBERGER	J55	C394058	08-22-02	100.1	99.8	99.9
SCHLUMBERGER	J55	C394059	08-22-02	99.9	100.0	99.9
SCHLUMBERGER	J55	C394060	08-22-02	100.1	100.0	100.0
SCHLUMBERGER	J55	C394061	08-22-02	100.2	100.0	100.5
SCHLUMBERGER	J55	C394062	08-22-02	100.1	100.0	100.4
SCHLUMBERGER	J55	C394063	08-22-02	100.2	99.9	99.9
SCHLUMBERGER	J55	C394064	08-22-02	100.1	100.1	99.9
SCHLUMBERGER	J55	C394065	08-22-02	100.0	99.8	99.3

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

PAGE 182
 RUN DATE: 1/14/03
 RUN TIME: 13.26.53

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	J5S	C394066	08-22-02	100.3	99.7	99.9
SCHLUMBERGER	J5S	C394067	08-22-02	100.1	100.1	99.9
SCHLUMBERGER	J5S	C394068	08-22-02	100.0	99.8	100.1
SCHLUMBERGER	J5S	C394069	08-22-02	99.9	99.8	99.6
SCHLUMBERGER	J5S	C394070	08-22-02	100.0	99.8	100.1
SCHLUMBERGER	J5S	C394071	08-22-02	100.0	99.9	99.7
SCHLUMBERGER	J5S	C394072	08-22-02	100.3	99.8	99.6
SCHLUMBERGER	J5S	C394073	08-22-02	100.2	99.9	99.7
SCHLUMBERGER	J5S	C394074	08-22-02	100.1	99.6	99.6
SCHLUMBERGER	J5S	C394075	08-22-02	100.1	99.8	100.1
SCHLUMBERGER	J5S	C394076	08-22-02	100.1	99.8	100.2
SCHLUMBERGER	J5S	C394077	08-21-02	99.9	100.1	99.8
SCHLUMBERGER	J5S	C394078	08-21-02	100.0	99.6	100.0
SCHLUMBERGER	J5S	C394079	08-21-02	100.1	99.7	99.8
SCHLUMBERGER	J5S	C394080	08-21-02	100.2	99.7	100.0
SCHLUMBERGER	J5S	C394081	08-21-02	99.9	99.7	99.6
SCHLUMBERGER	J5S	C394082	08-21-02	100.1	100.3	100.2
SCHLUMBERGER	J5S	C394083	08-21-02	100.3	99.8	99.9
SCHLUMBERGER	J5S	C394084	08-21-02	100.2	99.9	100.2
SCHLUMBERGER	J5S	C394085	08-21-02	100.0	99.8	99.6
SCHLUMBERGER	J5S	C394086	08-21-02	99.9	99.8	99.8
SCHLUMBERGER	J5S	C394087	08-21-02	100.0	99.7	99.8
SCHLUMBERGER	J5S	C394088	08-21-02	100.0	100.1	99.8
SCHLUMBERGER	J5S	C394089	08-21-02	99.8	99.7	99.7
SCHLUMBERGER	J5S	C394090	08-21-02	99.9	99.9	99.8
SCHLUMBERGER	J5S	C394091	08-21-02	100.1	99.6	100.1
SCHLUMBERGER	J5S	C394092	08-21-02	100.0	100.0	99.3
SCHLUMBERGER	J5S	C394093	08-21-02	100.1	99.8	100.3
SCHLUMBERGER	J5S	C394094	08-21-02	100.1	100.0	100.6
SCHLUMBERGER	J5S	C394095	08-21-02	100.1	99.8	99.8
SCHLUMBERGER	J5S	C394096	08-21-02	100.0	100.0	100.0
SCHLUMBERGER	J5S	C394097	08-21-02	100.0	99.8	99.7
SCHLUMBERGER	J5S	C394098	08-21-02	100.1	99.7	100.0
SCHLUMBERGER	J5S	C394099	08-21-02	100.1	99.9	100.2
SCHLUMBERGER	J5S	C394100	08-21-02	100.2	100.2	100.2
SCHLUMBERGER	J5S	C394101	08-21-02	100.1	99.8	99.9
SCHLUMBERGER	J5S	C394102	08-21-02	100.1	100.1	100.0
SCHLUMBERGER	J5S	C394103	08-21-02	100.0	99.8	100.6
SCHLUMBERGER	J5S	C394104	08-21-02	100.0	99.6	99.8
SCHLUMBERGER	J5S	C394105	08-21-02	100.0	99.9	100.4
SCHLUMBERGER	J5S	C394106	08-21-02	100.2	99.8	100.2
SCHLUMBERGER	J5S	C394107	08-21-02	99.9	99.7	99.9
SCHLUMBERGER	J5S	C394108	08-21-02	99.9	99.7	99.7
SCHLUMBERGER	J5S	C394109	08-21-02	100.1	100.3	99.4
SCHLUMBERGER	J5S	C394110	08-21-02	100.2	100.2	100.4
SCHLUMBERGER	J5S	C394111	08-21-02	100.0	99.9	99.9
SCHLUMBERGER	J5S	C394112	08-21-02	99.9	99.7	99.8
SCHLUMBERGER	J5S	C394113	08-21-02	100.2	99.6	100.0
SCHLUMBERGER	J5S	C394114	08-21-02	100.2	100.0	99.8
SCHLUMBERGER	J5S	C394115	08-21-02	99.9	100.3	100.1
SCHLUMBERGER	J5S	C394116	08-21-02	100.1	99.8	99.9

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

PAGE 183
 RUN DATE: 1/14/03
 RUN TIME: 13.26.53

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	J55	C394117	08-21-02	99.9	99.6	100.0
SCHLUMBERGER	J55	C394118	08-21-02	100.3	99.8	99.8
SCHLUMBERGER	J55	C394119	08-21-02	100.0	100.0	100.3
SCHLUMBERGER	J55	C394120	08-21-02	100.0	100.0	99.7
SCHLUMBERGER	J55	C394121	08-21-02	100.0	99.8	99.4
SCHLUMBERGER	J55	C394122	08-21-02	99.8	99.6	99.9
SCHLUMBERGER	J55	C394123	08-21-02	100.1	100.2	99.4
SCHLUMBERGER	J55	C394124	08-21-02	100.1	99.6	99.8
SCHLUMBERGER	J55	C394125	08-21-02	100.1	100.0	100.3
SCHLUMBERGER	J55	C394126	08-21-02	99.9	99.7	99.7
SCHLUMBERGER	J55	C394127	08-21-02	99.9	99.8	100.2
SCHLUMBERGER	J55	C394128	08-21-02	100.0	99.7	100.3
SCHLUMBERGER	J55	C394129	08-21-02	100.3	100.2	99.9
SCHLUMBERGER	J55	C394130	08-21-02	100.0	99.7	99.6
SCHLUMBERGER	J55	C394131	08-21-02	100.0	99.9	100.1
SCHLUMBERGER	J55	C394132	08-21-02	100.1	99.7	99.9
SCHLUMBERGER	J55	C394133	08-21-02	100.1	99.9	99.9
SCHLUMBERGER	J55	C394134	08-21-02	100.1	99.8	99.8
SCHLUMBERGER	J55	C394135	08-21-02	100.3	100.0	100.3
SCHLUMBERGER	J55	C394136	08-21-02	100.1	99.7	100.0
SCHLUMBERGER	J55	C394137	08-21-02	100.1	99.8	100.3
SCHLUMBERGER	J55	C394138	08-21-02	100.1	99.7	99.8
SCHLUMBERGER	J55	C394139	08-21-02	100.2	99.9	100.2
SCHLUMBERGER	J55	C394140	08-21-02	99.9	99.7	99.7
SCHLUMBERGER	J55	C394141	08-21-02	100.0	99.9	99.4
SCHLUMBERGER	J55	C394142	08-21-02	99.9	99.8	99.9
SCHLUMBERGER	J55	C394143	08-21-02	100.1	99.8	100.6
SCHLUMBERGER	J55	C394144	08-21-02	100.0	100.0	99.8
SCHLUMBERGER	J55	C394145	08-21-02	100.0	100.0	100.1
SCHLUMBERGER	J55	C394146	08-21-02	100.0	99.9	100.3
SCHLUMBERGER	J55	C394147	08-21-02	99.9	99.9	100.3
SCHLUMBERGER	J55	C394148	08-21-02	100.0	99.9	100.3
SCHLUMBERGER	J55	C394149	08-21-02	100.1	100.0	100.0
SCHLUMBERGER	J55	C394150	08-21-02	99.9	99.7	100.0
SCHLUMBERGER	J55	C394151	08-21-02	100.1	99.6	100.3
SCHLUMBERGER	J55	C394152	08-21-02	100.2	100.0	100.6
SCHLUMBERGER	J55	C394153	08-21-02	99.9	99.8	100.4
SCHLUMBERGER	J55	C394154	08-21-02	100.1	99.9	99.7
SCHLUMBERGER	J55	C394155	08-21-02	99.9	100.0	100.2
SCHLUMBERGER	J55	C394156	08-21-02	100.0	99.8	99.9
SCHLUMBERGER	J55	C394157	08-21-02	100.1	99.8	100.3
SCHLUMBERGER	J55	C394158	08-21-02	100.0	99.7	100.0
SCHLUMBERGER	J55	C394159	08-21-02	100.1	100.0	100.1
SCHLUMBERGER	J55	C394160	08-21-02	100.1	100.0	100.4
SCHLUMBERGER	J55	C394161	08-21-02	100.1	100.1	99.7
SCHLUMBERGER	J55	C394162	08-21-02	100.1	100.0	100.0
SCHLUMBERGER	J55	C394163	08-21-02	100.1	100.1	100.5
SCHLUMBERGER	J55	C394164	08-21-02	100.0	99.6	100.0
SCHLUMBERGER	J55	C394165	08-21-02	100.2	99.8	100.6
SCHLUMBERGER	J55	C394166	08-21-02	100.1	99.8	100.1
SCHLUMBERGER	J55	C394167	08-21-02	100.3	100.2	100.2

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

PAGE 184
 RUN DATE: 1/14/03
 RUN TIME: 13.26.53

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	J5S	C394168	08-21-02	100.0	99.8	99.8
SCHLUMBERGER	J5S	C394169	08-21-02	100.3	100.4	100.1
SCHLUMBERGER	J5S	C394170	08-21-02	100.2	100.3	100.2
SCHLUMBERGER	J5S	C394171	08-21-02	100.0	100.3	100.3
SCHLUMBERGER	J5S	C394172	08-21-02	100.1	99.8	100.6
SCHLUMBERGER	J5S	C394173	08-21-02	100.0	99.9	100.2
SCHLUMBERGER	J5S	C394174	08-21-02	100.0	99.7	99.8
SCHLUMBERGER	J5S	C394175	08-21-02	99.9	100.2	99.9
SCHLUMBERGER	J5S	C394176	08-21-02	100.2	99.9	99.9
SCHLUMBERGER	J5S	C394177	08-21-02	100.0	99.9	100.2
SCHLUMBERGER	J5S	C394178	08-21-02	100.1	100.1	99.9
SCHLUMBERGER	J5S	C394179	08-21-02	100.1	100.3	99.4
SCHLUMBERGER	J5S	C394180	08-21-02	99.9	99.8	100.1
SCHLUMBERGER	J5S	C394181	08-21-02	100.3	99.9	100.4
SCHLUMBERGER	J5S	C394182	08-21-02	100.1	99.9	100.3
SCHLUMBERGER	J5S	C394183	08-21-02	100.0	99.7	99.6
SCHLUMBERGER	J5S	C394184	08-21-02	100.1	100.2	100.0
SCHLUMBERGER	J5S	C394185	08-21-02	100.1	99.6	100.2
SCHLUMBERGER	J5S	C394186	08-21-02	100.1	99.7	100.1
SCHLUMBERGER	J5S	C394187	08-21-02	100.1	99.9	100.0
SCHLUMBERGER	J5S	C394188	08-21-02	100.1	99.8	99.7
SCHLUMBERGER	J5S	C394189	08-21-02	100.2	100.2	100.8
SCHLUMBERGER	J5S	C394190	08-21-02	100.3	100.3	100.1
SCHLUMBERGER	J5S	C394191	08-21-02	100.0	100.0	100.2
SCHLUMBERGER	J5S	C394192	08-21-02	100.2	99.6	100.6
SCHLUMBERGER	J5S	C394193	08-21-02	100.0	99.8	99.9
SCHLUMBERGER	J5S	C394194	08-21-02	100.0	100.2	100.1
SCHLUMBERGER	J5S	C394195	08-21-02	100.0	100.0	99.6
SCHLUMBERGER	J5S	C394196	08-21-02	100.0	100.2	99.8
SCHLUMBERGER	J5S	C394197	08-21-02	100.3	99.9	100.2
SCHLUMBERGER	J5S	C394198	08-21-02	100.1	100.1	99.9
SCHLUMBERGER	J5S	C394199	08-21-02	100.1	100.1	100.1
SCHLUMBERGER	J5S	C394200	08-21-02	100.1	99.7	100.1
SCHLUMBERGER	J5S	C394201	08-21-02	99.9	100.0	100.0
SCHLUMBERGER	J5S	C394202	08-21-02	99.9	99.9	100.5
SCHLUMBERGER	J5S	C394203	08-21-02	100.1	99.7	100.1
SCHLUMBERGER	J5S	C394204	08-21-02	100.1	99.9	100.4
SCHLUMBERGER	J5S	C394205	08-21-02	99.8	99.7	99.9
SCHLUMBERGER	J5S	C394206	08-21-02	100.1	100.2	100.1
SCHLUMBERGER	J5S	C394207	08-21-02	100.1	100.2	99.6
SCHLUMBERGER	J5S	C394208	08-21-02	100.0	99.7	99.7
SCHLUMBERGER	J5S	C394209	08-21-02	99.9	99.6	100.2
SCHLUMBERGER	J5S	C394210	08-21-02	100.1	99.9	99.6
SCHLUMBERGER	J5S	C394211	08-21-02	100.1	99.9	100.3
SCHLUMBERGER	J5S	C394212	08-21-02	99.9	100.0	99.8
SCHLUMBERGER	J5S	C394213	08-21-02	100.0	99.9	99.9
SCHLUMBERGER	J5S	C394214	08-21-02	100.0	99.8	100.2
SCHLUMBERGER	J5S	C394215	08-21-02	100.2	99.8	100.1
SCHLUMBERGER	J5S	C394216	08-21-02	100.0	100.0	99.9
SCHLUMBERGER	J5S	C394217	08-21-02	99.9	100.0	99.7
SCHLUMBERGER	J5S	C394218	08-21-02	100.1	99.6	99.8

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

PAGE 185
 RUN DATE: 1/14/03
 RUN TIME: 13.26.53

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	J55	C394219	08-21-02	100.0	99.7	100.4
SCHLUMBERGER	J55	C394220	08-21-02	99.9	99.7	99.7
SCHLUMBERGER	J55	C394221	08-21-02	100.0	99.7	100.4
SCHLUMBERGER	J55	C394222	08-21-02	100.2	100.2	100.0
SCHLUMBERGER	J55	C394223	08-21-02	100.1	99.7	100.0
SCHLUMBERGER	J55	C394224	08-21-02	100.1	100.2	99.7
SCHLUMBERGER	J55	C394225	08-21-02	100.0	99.7	99.9
SCHLUMBERGER	J55	C394226	08-21-02	100.0	99.8	100.4
SCHLUMBERGER	J55	C394227	08-21-02	100.2	100.0	99.9
SCHLUMBERGER	J55	C394228	08-21-02	100.1	99.8	100.4
SCHLUMBERGER	J55	C394229	08-21-02	100.1	99.6	99.8
SCHLUMBERGER	J55	C394230	08-21-02	100.1	99.8	99.6
SCHLUMBERGER	J55	C394231	08-21-02	100.1	99.9	99.9
SCHLUMBERGER	J55	C394232	08-21-02	100.2	100.1	100.2
SCHLUMBERGER	J55	C394233	08-21-02	100.1	99.9	100.4
SCHLUMBERGER	J55	C394234	08-21-02	99.9	99.8	99.9
SCHLUMBERGER	J55	C394235	08-21-02	100.1	100.1	99.8
SCHLUMBERGER	J55	C394236	08-21-02	100.0	99.7	99.7
SCHLUMBERGER	J55	C394237	08-21-02	100.3	100.0	100.0
SCHLUMBERGER	J55	C394238	08-21-02	100.1	99.9	100.1
SCHLUMBERGER	J55	C394239	08-21-02	100.2	100.1	100.6
SCHLUMBERGER	J55	C394240	08-21-02	100.0	100.0	100.2
SCHLUMBERGER	J55	C394241	08-21-02	100.1	99.8	99.8
SCHLUMBERGER	J55	C394242	08-21-02	100.1	99.6	100.1
SCHLUMBERGER	J55	C394243	08-21-02	100.0	100.0	100.0
SCHLUMBERGER	J55	C394244	08-21-02	100.2	99.8	99.9
SCHLUMBERGER	J55	C394245	08-21-02	100.2	100.0	100.1
SCHLUMBERGER	J55	C394246	08-21-02	100.0	99.9	99.9
SCHLUMBERGER	J55	C394247	08-21-02	100.2	99.9	100.0
SCHLUMBERGER	J55	C394248	08-21-02	100.2	99.8	100.2
SCHLUMBERGER	J55	C394249	08-21-02	100.2	99.8	100.4
SCHLUMBERGER	J55	C394250	08-21-02	100.0	99.8	99.9
SCHLUMBERGER	J55	C394251	08-21-02	100.2	99.8	100.0
SCHLUMBERGER	J55	C394252	08-21-02	100.0	99.8	99.7
SCHLUMBERGER	J55	C394253	08-21-02	100.0	100.2	99.6
SCHLUMBERGER	J55	C394254	08-21-02	100.1	99.9	99.8
SCHLUMBERGER	J55	C394255	08-21-02	100.0	100.0	100.0
SCHLUMBERGER	J55	C394256	08-21-02	100.0	99.8	99.8
SCHLUMBERGER	J55	C394257	08-21-02	100.0	99.9	99.7
SCHLUMBERGER	J55	C394258	08-21-02	100.1	100.1	99.3
SCHLUMBERGER	J55	C394259	08-21-02	100.1	99.7	100.0
SCHLUMBERGER	J55	C394260	08-21-02	99.9	100.4	100.0
SCHLUMBERGER	J55	C394261	08-21-02	100.3	99.6	99.7
SCHLUMBERGER	J55	C394262	08-21-02	99.9	100.0	100.2
SCHLUMBERGER	J55	C394263	08-21-02	100.0	99.8	99.9
SCHLUMBERGER	J55	C394264	08-21-02	100.1	100.0	100.1
SCHLUMBERGER	J55	C394265	08-21-02	100.1	100.0	100.0
SCHLUMBERGER	J55	C394266	08-21-02	100.1	99.8	100.0
SCHLUMBERGER	J55	C394267	08-21-02	100.1	99.8	99.6
SCHLUMBERGER	J55	C394268	08-21-02	100.1	99.9	100.0
SCHLUMBERGER	J55	C394269	08-21-02	100.2	99.8	100.0

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

PAGE 186
 RUN DATE: 1/14/03
 RUN TIME: 13.26.53

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	J5S	C394270	08-21-02	100.1	100.2	100.1
SCHLUMBERGER	J5S	C394271	08-21-02	99.9	99.9	99.5
SCHLUMBERGER	J5S	C394272	08-21-02	100.0	99.9	99.9
SCHLUMBERGER	J5S	C394273	08-21-02	100.0	99.8	99.8
SCHLUMBERGER	J5S	C394274	08-21-02	100.0	100.0	100.2
SCHLUMBERGER	J5S	C394275	08-21-02	100.1	99.6	99.8
SCHLUMBERGER	J5S	C394276	08-21-02	100.0	99.8	99.5
SCHLUMBERGER	J5S	C394277	08-21-02	100.0	99.9	99.9
SCHLUMBERGER	J5S	C394278	08-21-02	99.9	99.7	99.8
SCHLUMBERGER	J5S	C394279	08-21-02	99.9	99.8	99.7
SCHLUMBERGER	J5S	C394280	08-21-02	99.9	99.9	99.9
SCHLUMBERGER	J5S	C394281	08-21-02	100.0	99.9	99.9
SCHLUMBERGER	J5S	C394282	08-21-02	100.0	100.0	100.3
SCHLUMBERGER	J5S	C394283	08-21-02	100.1	100.1	99.9
SCHLUMBERGER	J5S	C394284	08-21-02	100.2	99.9	99.6
SCHLUMBERGER	J5S	C394285	08-21-02	99.9	100.0	99.7
SCHLUMBERGER	J5S	C394286	08-21-02	100.0	99.9	100.2
SCHLUMBERGER	J5S	C394287	08-21-02	100.0	99.8	99.9
SCHLUMBERGER	J5S	C394288	08-21-02	99.8	99.8	99.5
SCHLUMBERGER	J5S	C394289	08-21-02	99.9	99.8	99.8
SCHLUMBERGER	J5S	C394290	08-21-02	99.9	99.8	99.8
SCHLUMBERGER	J5S	C394291	08-21-02	100.0	100.1	99.8
SCHLUMBERGER	J5S	C394292	08-21-02	100.1	100.2	99.8
SCHLUMBERGER	J5S	C394293	08-21-02	100.2	100.3	100.0
SCHLUMBERGER	J5S	C394294	08-21-02	100.1	100.1	100.0
SCHLUMBERGER	J5S	C394295	08-21-02	100.1	100.2	99.8
SCHLUMBERGER	J5S	C394296	08-21-02	100.0	100.0	99.9
SCHLUMBERGER	J5S	C394297	08-21-02	100.0	99.7	99.7
SCHLUMBERGER	J5S	C394298	08-21-02	100.2	100.3	100.0
SCHLUMBERGER	J5S	C394299	08-21-02	100.1	100.2	100.2
SCHLUMBERGER	J5S	C394300	08-21-02	100.0	100.2	99.8
SCHLUMBERGER	J5S	C394301	08-21-02	100.0	99.9	99.9
SCHLUMBERGER	J5S	C394302	08-21-02	100.0	100.0	99.9
SCHLUMBERGER	J5S	C394303	08-21-02	100.0	99.9	100.1
SCHLUMBERGER	J5S	C394304	08-21-02	100.0	99.8	100.1
SCHLUMBERGER	J5S	C394305	08-21-02	100.1	99.8	100.0
SCHLUMBERGER	J5S	C394306	08-21-02	100.2	100.0	100.4
SCHLUMBERGER	J5S	C394307	08-21-02	100.1	100.0	99.9
SCHLUMBERGER	J5S	C394308	08-21-02	100.1	99.9	99.6
SCHLUMBERGER	J5S	C394309	08-21-02	100.2	99.9	99.8
SCHLUMBERGER	J5S	C394310	08-21-02	100.0	99.9	100.1
SCHLUMBERGER	J5S	C394311	08-21-02	100.1	99.7	100.1
SCHLUMBERGER	J5S	C394312	08-21-02	99.9	99.7	99.7
SCHLUMBERGER	J5S	C394313	08-21-02	100.1	99.9	100.2
SCHLUMBERGER	J5S	C394314	08-21-02	99.9	99.6	99.6
SCHLUMBERGER	J5S	C394315	08-21-02	100.0	99.8	100.2
SCHLUMBERGER	J5S	C394316	08-21-02	100.2	99.9	100.1
SCHLUMBERGER	J5S	C394317	08-21-02	100.2	100.1	99.9
SCHLUMBERGER	J5S	C394318	08-21-02	99.9	99.8	99.8
SCHLUMBERGER	J5S	C394319	08-21-02	100.3	100.1	100.6
SCHLUMBERGER	J5S	C394320	08-21-02	100.1	99.8	100.1
SCHLUMBERGER	J5S	C394320	08-21-02	100.2	100.0	100.4

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

PAGE 187
 RUN DATE: 1/14/03
 RUN TIME: 13.26.53

MANUFACTURER	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	C394321	08-21-02	99.9	100.0	99.9
SCHLUMBERGER	C394322	08-21-02	100.1	99.9	100.3
SCHLUMBERGER	C394323	08-21-02	100.0	99.8	99.9
SCHLUMBERGER	C394324	08-21-02	100.1	100.1	100.0
SCHLUMBERGER	C394325	08-21-02	99.9	99.6	99.6
SCHLUMBERGER	C394326	08-21-02	100.0	99.9	99.7
SCHLUMBERGER	C394327	08-21-02	99.9	99.9	100.4
SCHLUMBERGER	C394328	08-21-02	100.2	99.9	99.9
SCHLUMBERGER	C394329	08-21-02	100.1	100.0	100.2
SCHLUMBERGER	C394330	08-21-02	100.1	100.2	100.4
SCHLUMBERGER	C394331	08-21-02	99.9	99.9	100.4
SCHLUMBERGER	C394332	08-21-02	100.0	99.9	100.2
SCHLUMBERGER	C394333	08-21-02	100.3	100.0	100.1
SCHLUMBERGER	C394334	08-21-02	99.9	99.8	99.9
SCHLUMBERGER	C394335	08-21-02	100.1	99.7	99.9
SCHLUMBERGER	C394336	08-21-02	100.0	99.9	99.8
SCHLUMBERGER	C394337	08-21-02	100.1	99.7	99.9
SCHLUMBERGER	C394338	08-21-02	99.9	99.8	99.9
SCHLUMBERGER	C394339	08-21-02	100.1	99.8	99.6
SCHLUMBERGER	C394340	08-21-02	100.1	100.0	100.3
SCHLUMBERGER	C394341	08-21-02	100.1	99.8	100.0
SCHLUMBERGER	C394342	08-21-02	100.0	100.1	99.8
SCHLUMBERGER	C394343	08-21-02	100.1	100.0	100.2
SCHLUMBERGER	C394344	08-21-02	100.1	99.6	100.4
SCHLUMBERGER	C394345	08-21-02	99.9	99.6	99.9
SCHLUMBERGER	C394346	08-21-02	100.1	99.9	100.1
SCHLUMBERGER	C394347	08-21-02	100.2	100.0	100.0
SCHLUMBERGER	C394348	08-21-02	100.1	99.7	100.2
SCHLUMBERGER	C394349	08-21-02	100.0	99.8	99.4
SCHLUMBERGER	C394350	08-21-02	99.9	99.7	99.6
SCHLUMBERGER	C394351	08-21-02	100.2	99.6	100.1
SCHLUMBERGER	C394352	08-21-02	100.0	99.7	100.4
SCHLUMBERGER	C394353	08-21-02	99.9	99.7	100.2
SCHLUMBERGER	C394354	08-21-02	100.0	99.9	99.8
SCHLUMBERGER	C394355	08-21-02	100.0	99.7	100.1
SCHLUMBERGER	C394356	08-21-02	100.0	99.8	100.1
SCHLUMBERGER	C394357	08-21-02	100.1	99.9	100.1
SCHLUMBERGER	C394358	08-21-02	100.1	100.2	99.7
SCHLUMBERGER	C394359	08-21-02	100.0	100.1	100.6
SCHLUMBERGER	C394360	08-21-02	100.2	99.7	99.7
SCHLUMBERGER	C394361	08-21-02	100.1	99.9	100.1
SCHLUMBERGER	C394362	08-21-02	100.2	99.9	100.2
SCHLUMBERGER	C394363	08-21-02	99.8	99.7	99.7
SCHLUMBERGER	C394364	08-21-02	100.1	99.7	100.2
SCHLUMBERGER	C394365	08-21-02	100.1	100.0	99.6
SCHLUMBERGER	C394366	08-21-02	100.0	99.9	99.6
SCHLUMBERGER	C394367	08-21-02	100.0	100.1	99.9
SCHLUMBERGER	C394368	08-21-02	100.0	99.7	99.7
SCHLUMBERGER	C394369	08-21-02	100.1	99.9	100.1
SCHLUMBERGER	C394370	08-21-02	100.0	99.6	99.7
SCHLUMBERGER	C394371	08-21-02	99.9	99.8	99.3

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

PAGE 188
 RUN DATE: 1/14/03
 RUN TIME: 13.26.53

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	J5S	C394372	08-21-02	100.1	100.0	100.0
SCHLUMBERGER	J5S	C394373	08-21-02	100.0	99.8	100.2
SCHLUMBERGER	J5S	C394374	08-21-02	100.1	100.0	99.8
SCHLUMBERGER	J5S	C394375	08-21-02	100.1	99.8	99.6
SCHLUMBERGER	J5S	C394376	08-21-02	100.3	100.0	100.2
SCHLUMBERGER	J5S	C394377	08-21-02	100.0	99.9	99.8
SCHLUMBERGER	J5S	C394378	08-21-02	100.0	99.9	100.3
SCHLUMBERGER	J5S	C394379	08-21-02	100.0	99.9	99.6
SCHLUMBERGER	J5S	C394380	08-21-02	100.1	99.9	100.0
SCHLUMBERGER	J5S	C394381	08-21-02	100.1	99.9	100.0
SCHLUMBERGER	J5S	C394382	08-21-02	100.1	99.9	100.0
SCHLUMBERGER	J5S	C394383	08-21-02	100.0	99.8	100.4
SCHLUMBERGER	J5S	C394384	08-21-02	100.0	99.8	99.8
SCHLUMBERGER	J5S	C394385	08-21-02	100.0	100.1	99.7
SCHLUMBERGER	J5S	C394386	08-21-02	100.0	99.9	100.2
SCHLUMBERGER	J5S	C394387	08-21-02	100.2	100.0	100.1
SCHLUMBERGER	J5S	C394388	08-21-02	100.1	99.9	99.8
SCHLUMBERGER	J5S	C394389	08-21-02	99.9	99.9	99.7
SCHLUMBERGER	J5S	C394390	08-21-02	100.0	100.0	99.8
SCHLUMBERGER	J5S	C394391	08-21-02	100.0	99.9	99.9
SCHLUMBERGER	J5S	C394392	08-21-02	100.0	100.0	100.1
SCHLUMBERGER	J5S	C394393	08-21-02	100.3	99.9	100.1
SCHLUMBERGER	J5S	C394394	08-21-02	100.1	99.7	99.8
SCHLUMBERGER	J5S	C394395	08-21-02	100.1	100.1	99.9
SCHLUMBERGER	J5S	C394396	08-21-02	100.1	100.1	100.3
SCHLUMBERGER	J5S	C394397	08-21-02	100.1	99.9	100.0
SCHLUMBERGER	J5S	C394398	08-21-02	100.1	100.0	99.7
SCHLUMBERGER	J5S	C394399	08-21-02	100.0	99.7	99.7
SCHLUMBERGER	J5S	C394400	08-21-02	100.1	99.8	99.9
SCHLUMBERGER	J5S	C394401	08-21-02	100.3	100.1	100.3
SCHLUMBERGER	J5S	C394402	08-21-02	99.9	99.9	100.2
SCHLUMBERGER	J5S	C394403	08-21-02	100.0	100.0	100.1
SCHLUMBERGER	J5S	C394404	08-21-02	100.1	100.2	99.8
SCHLUMBERGER	J5S	C394405	08-21-02	100.0	100.0	99.8
SCHLUMBERGER	J5S	C394406	08-21-02	100.1	99.8	100.2
SCHLUMBERGER	J5S	C394407	08-21-02	100.1	100.1	100.3
SCHLUMBERGER	J5S	C394408	08-21-02	100.1	100.1	99.8
SCHLUMBERGER	J5S	C394409	08-21-02	100.1	100.0	100.1
SCHLUMBERGER	J5S	C394410	08-21-02	100.1	99.9	100.3
SCHLUMBERGER	J5S	C394411	08-21-02	100.3	100.0	100.3
SCHLUMBERGER	J5S	C394412	08-21-02	100.2	100.1	100.0
SCHLUMBERGER	J5S	C394413	08-21-02	100.2	100.0	100.3
SCHLUMBERGER	J5S	C394414	08-21-02	100.2	99.8	100.1
SCHLUMBERGER	J5S	C394415	08-21-02	100.0	99.6	100.4
SCHLUMBERGER	J5S	C394416	08-21-02	100.0	99.6	99.6
SCHLUMBERGER	J5S	C394417	08-21-02	100.0	100.3	100.1
SCHLUMBERGER	J5S	C394418	08-21-02	100.3	99.9	100.2
SCHLUMBERGER	J5S	C394419	08-21-02	100.2	99.7	99.6
SCHLUMBERGER	J5S	C394420	08-21-02	100.2	100.1	99.8
SCHLUMBERGER	J5S	C394421	08-21-02	100.0	99.8	100.1
SCHLUMBERGER	J5S	C394422	08-21-02	99.9	99.7	100.4
SCHLUMBERGER	J5S	C394423	08-21-02	100.0	99.9	99.9

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	J55	C394423	08-21-02	100.2	100.2	100.2
SCHLUMBERGER	J55	C394424	08-21-02	100.1	99.8	99.9
SCHLUMBERGER	J55	C394425	08-21-02	100.1	100.0	100.3
SCHLUMBERGER	J55	C394426	08-21-02	100.1	100.1	99.9
SCHLUMBERGER	J55	C394427	08-21-02	100.2	100.0	100.0
SCHLUMBERGER	J55	C394428	08-21-02	100.1	99.9	100.5
SCHLUMBERGER	J55	C394429	08-21-02	100.1	99.7	99.8
SCHLUMBERGER	J55	C394430	08-21-02	100.2	100.0	100.5
SCHLUMBERGER	J55	C394431	08-21-02	100.1	99.6	100.1
SCHLUMBERGER	J55	C394432	08-21-02	100.0	99.6	99.6
SCHLUMBERGER	J55	C394433	08-21-02	100.2	99.9	99.7
SCHLUMBERGER	J55	C394434	08-21-02	100.1	100.2	100.3
SCHLUMBERGER	J55	C394435	08-21-02	100.2	99.9	100.0
SCHLUMBERGER	J55	C394436	08-21-02	100.0	100.2	100.2
SCHLUMBERGER	J55	C394437	08-21-02	100.0	99.9	100.1
SCHLUMBERGER	J55	C394438	08-21-02	100.0	100.0	99.9
SCHLUMBERGER	J55	C394439	08-21-02	100.1	99.8	99.7
SCHLUMBERGER	J55	C394440	08-21-02	100.2	99.7	100.4
SCHLUMBERGER	J55	C394441	08-21-02	100.2	100.2	100.1
SCHLUMBERGER	J55	C394442	08-21-02	100.1	100.2	100.2
SCHLUMBERGER	J55	C394443	08-21-02	99.9	99.9	99.7
SCHLUMBERGER	J55	C394444	08-21-02	99.9	100.0	99.6
SCHLUMBERGER	J55	C394445	08-21-02	100.1	100.1	100.0
SCHLUMBERGER	J55	C394446	08-21-02	100.0	100.0	100.2
SCHLUMBERGER	J55	C394447	08-21-02	100.0	99.9	100.3
SCHLUMBERGER	J55	C394448	08-21-02	99.9	99.6	100.2
SCHLUMBERGER	J55	C394449	08-21-02	100.3	99.8	100.3
SCHLUMBERGER	J55	C394450	08-21-02	99.9	99.7	100.3
SCHLUMBERGER	J55	C394451	08-21-02	100.2	100.0	99.9
SCHLUMBERGER	J55	C394452	08-21-02	100.1	100.0	99.9
SCHLUMBERGER	J55	C394453	08-21-02	99.8	100.0	99.7
SCHLUMBERGER	J55	C394454	08-21-02	100.1	99.8	99.6
SCHLUMBERGER	J55	C394455	08-21-02	100.0	99.8	100.1
SCHLUMBERGER	J55	C394456	08-21-02	100.0	99.9	100.2
SCHLUMBERGER	J55	C394457	08-21-02	100.1	100.1	100.0
SCHLUMBERGER	J55	C394458	08-21-02	100.1	99.7	100.1
SCHLUMBERGER	J55	C394459	08-21-02	100.2	100.4	100.7
SCHLUMBERGER	J55	C394460	08-21-02	100.0	99.9	100.3
SCHLUMBERGER	J55	C394461	08-21-02	100.1	100.1	100.5
SCHLUMBERGER	J55	C394462	08-21-02	100.2	99.9	100.3
SCHLUMBERGER	J55	C394463	08-21-02	100.1	100.1	100.3
SCHLUMBERGER	J55	C394464	08-21-02	100.0	100.5	100.2
SCHLUMBERGER	J55	C394465	08-21-02	99.9	99.8	99.9
SCHLUMBERGER	J55	C394466	08-21-02	100.3	100.1	99.9
SCHLUMBERGER	J55	C394467	08-21-02	100.1	99.9	100.1
SCHLUMBERGER	J55	C394468	08-21-02	100.0	99.7	100.0
SCHLUMBERGER	J55	C394469	08-21-02	100.1	100.1	100.1
SCHLUMBERGER	J55	C394470	08-21-02	100.1	99.8	99.5
SCHLUMBERGER	J55	C394471	08-21-02	100.1	99.9	99.8
SCHLUMBERGER	J55	C394472	08-21-02	100.0	100.0	100.2
SCHLUMBERGER	J55	C394473	08-21-02	100.1	100.3	100.3

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

MANUFACTURER	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	C394474	08-21-02	100.3	100.0	99.9
SCHLUMBERGER	C394475	08-21-02	100.0	99.7	99.7
SCHLUMBERGER	C394476	08-21-02	100.1	100.0	100.3
SCHLUMBERGER	C394477	08-21-02	99.9	99.8	100.5
SCHLUMBERGER	C394478	08-21-02	100.2	100.2	100.6
SCHLUMBERGER	C394479	08-21-02	100.2	100.2	100.3
SCHLUMBERGER	C394480	08-21-02	100.1	99.8	99.6
SCHLUMBERGER	C394481	08-21-02	100.0	100.1	99.9
SCHLUMBERGER	C394482	08-21-02	100.2	99.8	100.0
SCHLUMBERGER	C394483	08-21-02	100.2	99.8	100.0
SCHLUMBERGER	C394484	08-21-02	100.2	100.1	100.3
SCHLUMBERGER	C394485	08-21-02	100.2	99.9	100.0
SCHLUMBERGER	C394486	08-21-02	100.2	100.1	100.0
SCHLUMBERGER	C394487	08-21-02	99.9	100.1	100.2
SCHLUMBERGER	C394488	08-21-02	100.0	99.8	100.0
SCHLUMBERGER	C394489	08-21-02	99.9	100.1	100.0
SCHLUMBERGER	C394490	08-21-02	99.9	100.4	99.8
SCHLUMBERGER	C394491	08-21-02	100.1	99.9	100.0
SCHLUMBERGER	C394492	08-21-02	100.1	99.8	100.6
SCHLUMBERGER	C394493	08-21-02	100.1	99.7	100.1
SCHLUMBERGER	C394494	08-21-02	100.1	99.8	99.9
SCHLUMBERGER	C394495	08-21-02	100.1	99.8	99.8
SCHLUMBERGER	C394496	08-21-02	100.1	99.7	99.7
SCHLUMBERGER	C394497	08-21-02	100.1	100.1	99.9
SCHLUMBERGER	C394498	08-21-02	100.1	100.2	99.9
SCHLUMBERGER	C394499	08-21-02	100.0	100.1	100.2
SCHLUMBERGER	C394500	08-21-02	99.9	99.9	100.2
SCHLUMBERGER	C394501	08-21-02	100.1	99.7	99.9
SCHLUMBERGER	C394502	08-21-02	100.1	99.6	100.1
SCHLUMBERGER	C394503	08-21-02	100.0	99.8	100.1
SCHLUMBERGER	C394504	08-21-02	99.9	99.9	99.4
SCHLUMBERGER	C394505	08-21-02	100.2	100.0	99.6
SCHLUMBERGER	C394506	08-21-02	100.2	100.0	99.8
SCHLUMBERGER	C394507	08-21-02	100.2	100.1	100.1
SCHLUMBERGER	C394508	08-21-02	100.3	99.9	99.9
SCHLUMBERGER	C394509	08-21-02	100.1	99.8	100.3
SCHLUMBERGER	C394510	08-21-02	100.2	100.0	100.3
SCHLUMBERGER	C394511	08-21-02	100.0	99.7	100.4
SCHLUMBERGER	C394512	08-21-02	100.1	99.8	100.3
SCHLUMBERGER	C394513	08-21-02	100.1	99.9	100.1
SCHLUMBERGER	C394514	08-21-02	100.1	99.9	100.0
SCHLUMBERGER	C394515	08-21-02	100.3	100.0	100.3
SCHLUMBERGER	C394516	08-21-02	99.9	99.6	100.0
SCHLUMBERGER	C394517	08-21-02	100.0	99.9	100.0
SCHLUMBERGER	C394518	08-21-02	100.0	100.1	100.5
SCHLUMBERGER	C394519	08-21-02	100.1	99.8	100.4
SCHLUMBERGER	C394520	08-21-02	100.1	99.8	100.3
SCHLUMBERGER	C394521	08-21-02	99.9	99.9	100.1
SCHLUMBERGER	C394522	08-21-02	100.0	99.8	99.7
SCHLUMBERGER	C394523	08-21-02	100.1	100.0	100.4
SCHLUMBERGER	C394524	08-21-02	100.0	100.0	99.8

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

PAGE 191
 RUN DATE: 1/14/03
 RUN TIME: 13.26.53

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	J55	C394525	08-21-02	100.0	100.0	100.3
SCHLUMBERGER	J55	C394526	08-21-02	100.3	100.2	99.8
SCHLUMBERGER	J55	C394527	08-21-02	100.0	99.7	99.5
SCHLUMBERGER	J55	C394528	08-21-02	100.1	100.0	100.0
SCHLUMBERGER	J55	C394529	08-21-02	100.1	100.2	100.6
SCHLUMBERGER	J55	C394530	08-21-02	100.0	99.8	100.0
SCHLUMBERGER	J55	C394531	08-21-02	100.2	99.6	100.2
SCHLUMBERGER	J55	C394532	08-21-02	100.1	99.8	100.4
SCHLUMBERGER	J55	C394533	08-21-02	100.1	99.9	100.1
SCHLUMBERGER	J55	C394534	08-21-02	100.2	99.8	100.2
SCHLUMBERGER	J55	C394535	08-21-02	100.0	99.9	100.6
SCHLUMBERGER	J55	C394536	08-21-02	100.0	99.7	99.7
SCHLUMBERGER	J55	C394537	08-21-02	100.0	99.7	100.0
SCHLUMBERGER	J55	C394538	08-21-02	100.2	99.9	100.2
SCHLUMBERGER	J55	C394539	08-21-02	100.1	100.0	100.0
SCHLUMBERGER	J55	C394540	08-21-02	100.1	99.7	99.9
SCHLUMBERGER	J55	C394541	08-21-02	100.0	99.8	100.0
SCHLUMBERGER	J55	C394542	08-21-02	100.0	99.7	100.3
SCHLUMBERGER	J55	C394543	08-21-02	100.1	100.0	100.1
SCHLUMBERGER	J55	C394544	08-21-02	100.2	100.1	100.0
SCHLUMBERGER	J55	C394545	08-21-02	100.2	99.8	100.2
SCHLUMBERGER	J55	C394546	08-21-02	100.0	100.0	100.2
SCHLUMBERGER	J55	C394547	08-21-02	100.0	99.6	100.0
SCHLUMBERGER	J55	C394548	08-21-02	100.1	99.9	100.1
SCHLUMBERGER	J55	C394549	08-21-02	100.0	99.9	100.0
SCHLUMBERGER	J55	C394550	08-21-02	100.3	100.4	100.6
SCHLUMBERGER	J55	C394551	08-21-02	100.0	100.0	99.3
SCHLUMBERGER	J55	C394552	08-21-02	100.3	99.6	100.1
SCHLUMBERGER	J55	C394553	08-21-02	100.0	99.9	99.5
SCHLUMBERGER	J55	C394554	08-21-02	100.0	100.1	99.5
SCHLUMBERGER	J55	C394555	08-21-02	100.1	99.7	100.3
SCHLUMBERGER	J55	C394556	08-21-02	100.3	100.1	100.1
SCHLUMBERGER	J55	C394557	08-21-02	100.2	99.7	99.8
SCHLUMBERGER	J55	C394558	08-21-02	100.1	100.2	99.7
SCHLUMBERGER	J55	C394559	08-21-02	100.2	99.9	100.0
SCHLUMBERGER	J55	C394560	08-21-02	100.3	100.4	100.3
SCHLUMBERGER	J55	C394561	08-21-02	100.0	100.0	100.4
SCHLUMBERGER	J55	C394562	08-21-02	100.2	99.8	99.9
SCHLUMBERGER	J55	C394563	08-21-02	100.1	100.0	99.8
SCHLUMBERGER	J55	C394564	08-21-02	100.0	100.0	99.9
SCHLUMBERGER	J55	C394565	08-21-02	99.9	99.7	99.8
SCHLUMBERGER	J55	C394566	08-21-02	100.1	99.8	99.8
SCHLUMBERGER	J55	C394567	08-21-02	100.1	100.0	100.2
SCHLUMBERGER	J55	C394568	08-21-02	100.1	99.7	100.0
SCHLUMBERGER	J55	C394569	08-21-02	100.2	99.9	100.0
SCHLUMBERGER	J55	C394570	08-21-02	100.2	100.2	99.9
SCHLUMBERGER	J55	C394571	08-21-02	100.1	99.6	100.0
SCHLUMBERGER	J55	C394572	08-21-02	100.0	99.6	99.5
SCHLUMBERGER	J55	C394573	08-21-02	100.2	99.9	100.4
SCHLUMBERGER	J55	C394574	08-21-02	100.2	100.0	100.4
SCHLUMBERGER	J55	C394575	08-21-02	100.1	100.0	100.5

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	J5S	C394576	08-21-02	100.1	99.6	99.7
SCHLUMBERGER	J5S	C394577	08-21-02	100.0	99.6	100.5
SCHLUMBERGER	J5S	C394578	08-21-02	100.1	99.8	100.2
SCHLUMBERGER	J5S	C394579	08-21-02	100.1	100.0	100.0
SCHLUMBERGER	J5S	C394580	08-21-02	99.9	99.7	100.3
SCHLUMBERGER	J5S	C394581	08-21-02	100.0	100.0	100.4
SCHLUMBERGER	J5S	C394582	08-21-02	100.0	100.3	100.4
SCHLUMBERGER	J5S	C394583	08-21-02	99.9	99.7	100.2
SCHLUMBERGER	J5S	C394584	08-21-02	100.1	99.6	99.9
SCHLUMBERGER	J5S	C394585	08-21-02	100.1	100.1	99.9
SCHLUMBERGER	J5S	C394586	08-21-02	99.8	99.8	99.4
SCHLUMBERGER	J5S	C394587	08-21-02	100.1	100.1	100.1
SCHLUMBERGER	J5S	C394588	09-18-02	99.9	99.9	99.9
SCHLUMBERGER	J5S	C394589	09-18-02	100.1	99.8	100.1
SCHLUMBERGER	J5S	C394590	09-18-02	100.1	100.2	100.1
SCHLUMBERGER	J5S	C394591	09-18-02	100.0	100.2	100.3
SCHLUMBERGER	J5S	C394592	09-18-02	100.0	100.0	99.9
SCHLUMBERGER	J5S	C394593	09-18-02	100.0	100.4	100.0
SCHLUMBERGER	J5S	C394594	09-18-02	100.1	99.7	100.1
SCHLUMBERGER	J5S	C394595	09-18-02	100.2	99.7	99.8
SCHLUMBERGER	J5S	C394596	09-18-02	100.2	99.8	100.0
SCHLUMBERGER	J5S	C394597	09-18-02	100.1	99.9	100.2
SCHLUMBERGER	J5S	C394598	09-18-02	100.1	99.9	99.5
SCHLUMBERGER	J5S	C394599	09-18-02	100.1	99.9	99.7
SCHLUMBERGER	J5S	C394600	09-18-02	100.0	100.0	99.7
SCHLUMBERGER	J5S	C394601	09-18-02	100.1	99.8	100.1
SCHLUMBERGER	J5S	C394602	09-18-02	100.1	99.8	100.1
SCHLUMBERGER	J5S	C394603	09-18-02	100.1	99.8	100.1
SCHLUMBERGER	J5S	C394604	09-18-02	99.9	100.0	99.4
SCHLUMBERGER	J5S	C394605	09-18-02	100.0	99.9	100.0
SCHLUMBERGER	J5S	C394606	09-18-02	100.1	99.8	99.8
SCHLUMBERGER	J5S	C394607	09-18-02	100.1	99.9	100.3
SCHLUMBERGER	J5S	C394608	09-18-02	100.2	99.8	99.6
SCHLUMBERGER	J5S	C394609	09-18-02	100.2	99.8	100.2
SCHLUMBERGER	J5S	C394610	09-18-02	100.1	99.8	99.7
SCHLUMBERGER	J5S	C394611	09-18-02	100.0	99.8	100.2
SCHLUMBERGER	J5S	C394612	09-18-02	100.1	99.9	100.3
SCHLUMBERGER	J5S	C394613	09-18-02	100.0	99.9	100.2
SCHLUMBERGER	J5S	C394614	09-18-02	100.1	99.9	100.4
SCHLUMBERGER	J5S	C394615	09-18-02	100.0	99.6	99.7
SCHLUMBERGER	J5S	C394616	09-18-02	100.1	99.7	100.0
SCHLUMBERGER	J5S	C394617	09-18-02	100.0	99.7	100.2
SCHLUMBERGER	J5S	C394618	09-18-02	100.1	100.0	100.2
SCHLUMBERGER	J5S	C394619	09-18-02	100.1	99.8	99.8
SCHLUMBERGER	J5S	C394620	09-18-02	100.1	99.7	100.1
SCHLUMBERGER	J5S	C394621	09-18-02	100.0	99.7	99.9
SCHLUMBERGER	J5S	C394622	09-18-02	100.2	100.0	99.6
SCHLUMBERGER	J5S	C394623	09-18-02	100.0	99.7	100.3
SCHLUMBERGER	J5S	C394624	09-18-02	100.0	99.7	99.9
SCHLUMBERGER	J5S	C394625	09-18-02	100.1	100.1	100.1
SCHLUMBERGER	J5S	C394626	09-18-02	100.1	99.7	99.7
SCHLUMBERGER	J5S	C394626	09-18-02	100.2	100.0	100.0

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	J55	C394627	09-18-02	100.2	99.8	100.3
SCHLUMBERGER	J55	C394628	09-18-02	100.1	99.7	100.1
SCHLUMBERGER	J55	C394629	09-18-02	99.9	99.7	99.9
SCHLUMBERGER	J55	C394630	09-18-02	100.0	99.6	100.1
SCHLUMBERGER	J55	C394631	09-18-02	100.1	99.6	100.0
SCHLUMBERGER	J55	C394632	09-18-02	100.0	99.7	99.7
SCHLUMBERGER	J55	C394633	09-18-02	100.0	99.6	99.6
SCHLUMBERGER	J55	C394634	09-18-02	99.9	99.6	99.7
SCHLUMBERGER	J55	C394635	09-18-02	100.1	99.6	99.8
SCHLUMBERGER	J55	C394636	09-18-02	100.0	100.3	100.1
SCHLUMBERGER	J55	C394637	09-18-02	100.0	100.2	100.0
SCHLUMBERGER	J55	C394638	09-18-02	100.0	99.9	99.9
SCHLUMBERGER	J55	C394639	09-18-02	100.1	100.4	100.0
SCHLUMBERGER	J55	C394640	09-18-02	100.1	99.7	99.5
SCHLUMBERGER	J55	C394641	09-18-02	99.9	100.3	100.1
SCHLUMBERGER	J55	C394642	09-18-02	100.1	99.6	99.8
SCHLUMBERGER	J55	C394643	09-18-02	100.1	99.7	99.9
SCHLUMBERGER	J55	C394644	09-18-02	100.0	99.7	99.8
SCHLUMBERGER	J55	C394645	09-18-02	100.0	99.6	99.5
SCHLUMBERGER	J55	C394646	09-18-02	100.0	99.7	100.0
SCHLUMBERGER	J55	C394647	09-18-02	99.9	100.2	100.0
SCHLUMBERGER	J55	C394648	09-18-02	100.0	99.7	99.5
SCHLUMBERGER	J55	C394649	09-18-02	100.1	99.8	99.8
SCHLUMBERGER	J55	C394650	09-18-02	100.1	99.6	100.1
SCHLUMBERGER	J55	C394651	09-18-02	100.1	99.9	99.8
SCHLUMBERGER	J55	C394652	09-18-02	100.1	99.7	99.7
SCHLUMBERGER	J55	C394653	09-18-02	100.1	99.6	99.6
SCHLUMBERGER	J55	C394654	09-18-02	100.0	99.7	100.1
SCHLUMBERGER	J55	C394655	09-18-02	100.0	99.6	99.8
SCHLUMBERGER	J55	C394656	09-18-02	100.0	100.1	100.2
SCHLUMBERGER	J55	C394657	09-18-02	99.8	99.7	99.7
SCHLUMBERGER	J55	C394658	09-18-02	100.1	100.1	100.2
SCHLUMBERGER	J55	C394659	09-18-02	100.1	99.7	99.8
SCHLUMBERGER	J55	C394660	09-18-02	100.1	99.8	99.9
SCHLUMBERGER	J55	C394661	09-18-02	100.0	100.0	99.9
SCHLUMBERGER	J55	C394662	09-18-02	100.1	99.8	100.1
SCHLUMBERGER	J55	C394663	09-18-02	100.0	99.6	99.6
SCHLUMBERGER	J55	C394664	09-18-02	100.1	99.7	100.0
SCHLUMBERGER	J55	C394665	09-18-02	100.1	99.7	99.4
SCHLUMBERGER	J55	C394666	09-18-02	100.1	99.7	99.8
SCHLUMBERGER	J55	C394667	09-18-02	100.3	99.8	100.1
SCHLUMBERGER	J55	C394668	09-18-02	100.1	99.9	100.1
SCHLUMBERGER	J55	C394669	09-18-02	100.0	100.0	99.9
SCHLUMBERGER	J55	C394670	09-18-02	100.0	99.9	99.7
SCHLUMBERGER	J55	C394671	09-18-02	100.0	99.7	99.7
SCHLUMBERGER	J55	C394672	09-18-02	100.1	99.7	100.1
SCHLUMBERGER	J55	C394673	09-18-02	100.1	99.8	99.8
SCHLUMBERGER	J55	C394674	09-18-02	100.1	99.8	100.1
SCHLUMBERGER	J55	C394675	09-18-02	100.1	99.8	100.3
SCHLUMBERGER	J55	C394676	09-18-02	100.1	99.8	99.5
SCHLUMBERGER	J55	C394677	09-18-02	99.9	99.9	99.9

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	J5S	C394678	09-18-02	100.0	100.2	99.8
SCHLUMBERGER	J5S	C394679	09-18-02	100.1	100.0	100.2
SCHLUMBERGER	J5S	C394680	09-18-02	100.3	100.1	100.0
SCHLUMBERGER	J5S	C394681	09-18-02	100.0	100.2	99.8
SCHLUMBERGER	J5S	C394682	09-18-02	100.0	99.8	99.8
SCHLUMBERGER	J5S	C394683	09-18-02	99.9	99.7	99.6
SCHLUMBERGER	J5S	C394684	09-18-02	100.0	99.6	99.8
SCHLUMBERGER	J5S	C394685	09-18-02	100.0	99.7	99.9
SCHLUMBERGER	J5S	C394686	09-18-02	100.1	99.7	100.0
SCHLUMBERGER	J5S	C394687	09-18-02	100.0	99.7	99.8
SCHLUMBERGER	J5S	C394688	09-18-02	99.9	99.7	99.7
SCHLUMBERGER	J5S	C394689	09-18-02	100.1	99.8	100.1
SCHLUMBERGER	J5S	C394690	09-18-02	99.9	99.7	99.9
SCHLUMBERGER	J5S	C394691	09-18-02	100.1	100.0	100.1
SCHLUMBERGER	J5S	C394692	09-18-02	99.9	100.1	99.7
SCHLUMBERGER	J5S	C394693	09-18-02	100.2	99.7	100.0
SCHLUMBERGER	J5S	C394694	09-18-02	100.1	99.9	100.1
SCHLUMBERGER	J5S	C394695	09-18-02	100.0	100.2	100.2
SCHLUMBERGER	J5S	C394696	09-18-02	100.1	100.0	99.5
SCHLUMBERGER	J5S	C394697	09-18-02	100.3	99.8	100.3
SCHLUMBERGER	J5S	C394698	09-18-02	100.0	99.9	100.1
SCHLUMBERGER	J5S	C394699	09-18-02	100.2	99.7	100.1
SCHLUMBERGER	J5S	C394700	09-18-02	100.1	99.9	99.9
SCHLUMBERGER	J5S	C394701	09-18-02	100.0	99.9	100.2
SCHLUMBERGER	J5S	C394702	09-18-02	100.0	99.7	99.9
SCHLUMBERGER	J5S	C394703	09-18-02	100.0	100.1	100.0
SCHLUMBERGER	J5S	C394704	09-18-02	99.9	100.4	99.8
SCHLUMBERGER	J5S	C394705	09-18-02	100.2	99.7	100.2
SCHLUMBERGER	J5S	C394706	09-18-02	100.1	99.7	100.2
SCHLUMBERGER	J5S	C394707	09-18-02	100.1	100.0	100.1
SCHLUMBERGER	J5S	C394708	09-18-02	100.0	100.2	100.3
SCHLUMBERGER	J5S	C394709	09-18-02	100.0	99.9	99.9
SCHLUMBERGER	J5S	C394710	09-18-02	100.0	99.9	100.0
SCHLUMBERGER	J5S	C394711	09-18-02	100.0	99.8	99.9
SCHLUMBERGER	J5S	C394712	09-18-02	100.2	100.0	99.9
SCHLUMBERGER	J5S	C394713	09-18-02	100.1	99.7	100.0
SCHLUMBERGER	J5S	C394714	09-18-02	100.1	99.7	100.0
SCHLUMBERGER	J5S	C394715	09-18-02	100.1	99.8	99.9
SCHLUMBERGER	J5S	C394716	09-18-02	100.0	100.3	100.2
SCHLUMBERGER	J5S	C394717	09-18-02	100.1	100.1	100.4
SCHLUMBERGER	J5S	C394718	09-18-02	100.0	100.0	100.2
SCHLUMBERGER	J5S	C394719	09-18-02	100.1	99.7	100.0
SCHLUMBERGER	J5S	C394720	09-18-02	100.0	99.6	99.9
SCHLUMBERGER	J5S	C394721	09-18-02	99.9	99.7	100.0
SCHLUMBERGER	J5S	C394722	09-18-02	100.1	99.7	100.0
SCHLUMBERGER	J5S	C394723	09-18-02	100.0	99.8	99.7
SCHLUMBERGER	J5S	C394724	09-18-02	100.1	100.1	100.1
SCHLUMBERGER	J5S	C394725	09-18-02	100.1	99.9	99.7
SCHLUMBERGER	J5S	C394726	09-18-02	100.1	99.9	100.1
SCHLUMBERGER	J5S	C394727	09-18-02	100.2	100.1	99.9
SCHLUMBERGER	J5S	C394728	09-18-02	100.0	99.9	100.2

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	J55	C394729	09-18-02	100.1	99.7	99.6
SCHLUMBERGER	J55	C394730	09-18-02	100.1	99.9	99.8
SCHLUMBERGER	J55	C394731	09-18-02	100.1	100.3	99.8
SCHLUMBERGER	J55	C394732	09-18-02	100.1	99.6	99.9
SCHLUMBERGER	J55	C394733	09-18-02	100.0	99.7	100.0
SCHLUMBERGER	J55	C394734	09-18-02	99.9	99.7	99.5
SCHLUMBERGER	J55	C394735	09-18-02	100.0	99.9	99.7
SCHLUMBERGER	J55	C394736	09-18-02	100.1	99.9	99.9
SCHLUMBERGER	J55	C394737	09-18-02	100.1	99.7	99.6
SCHLUMBERGER	J55	C394738	09-18-02	100.2	99.9	99.9
SCHLUMBERGER	J55	C394739	09-18-02	100.0	99.8	99.9
SCHLUMBERGER	J55	C394740	09-18-02	100.2	99.8	100.3
SCHLUMBERGER	J55	C394741	09-18-02	100.0	99.8	100.0
SCHLUMBERGER	J55	C394742	09-18-02	100.0	99.8	99.6
SCHLUMBERGER	J55	C394743	09-18-02	100.1	99.7	99.9
SCHLUMBERGER	J55	C394744	09-18-02	100.0	99.8	100.0
SCHLUMBERGER	J55	C394745	09-18-02	100.1	100.0	100.0
SCHLUMBERGER	J55	C394746	09-18-02	100.1	99.6	99.6
SCHLUMBERGER	J55	C394747	09-18-02	99.8	100.0	99.8
SCHLUMBERGER	J55	C394748	09-18-02	100.2	99.7	100.1
SCHLUMBERGER	J55	C394749	09-18-02	100.1	99.8	99.8
SCHLUMBERGER	J55	C394750	09-18-02	100.2	100.2	100.1
SCHLUMBERGER	J55	C394751	09-18-02	100.0	99.9	100.4
SCHLUMBERGER	J55	C394752	09-18-02	100.2	99.7	100.2
SCHLUMBERGER	J55	C394753	09-18-02	100.0	99.9	100.0
SCHLUMBERGER	J55	C394754	09-18-02	100.1	99.4	99.4
SCHLUMBERGER	J55	C394755	09-18-02	100.2	99.9	100.0
SCHLUMBERGER	J55	C394756	09-18-02	100.1	99.8	99.4
SCHLUMBERGER	J55	C394757	09-18-02	100.1	99.8	100.3
SCHLUMBERGER	J55	C394758	09-18-02	100.1	100.1	100.2
SCHLUMBERGER	J55	C394759	09-18-02	100.0	99.9	100.0
SCHLUMBERGER	J55	C394760	09-18-02	100.0	99.7	99.7
SCHLUMBERGER	J55	C394761	09-18-02	100.1	99.9	100.1
SCHLUMBERGER	J55	C394762	09-18-02	100.1	99.7	99.8
SCHLUMBERGER	J55	C394763	09-18-02	100.1	99.7	99.8
SCHLUMBERGER	J55	C394764	09-18-02	100.0	99.8	100.0
SCHLUMBERGER	J55	C394765	09-18-02	100.1	99.8	100.0
SCHLUMBERGER	J55	C394766	09-18-02	100.1	99.7	99.8
SCHLUMBERGER	J55	C394767	09-18-02	100.2	99.7	100.2
SCHLUMBERGER	J55	C394768	09-18-02	100.2	99.7	99.9
SCHLUMBERGER	J55	C394769	09-18-02	100.2	99.7	100.0
SCHLUMBERGER	J55	C394770	09-18-02	99.8	99.6	99.4
SCHLUMBERGER	J55	C394771	09-18-02	100.0	100.4	99.9
SCHLUMBERGER	J55	C394772	09-18-02	100.0	99.7	99.8
SCHLUMBERGER	J55	C394773	09-18-02	100.2	99.9	99.8
SCHLUMBERGER	J55	C394774	09-18-02	100.1	99.9	100.0
SCHLUMBERGER	J55	C394775	09-18-02	100.2	99.7	99.9
SCHLUMBERGER	J55	C394776	09-18-02	100.1	100.1	100.0
SCHLUMBERGER	J55	C394777	09-18-02	100.2	100.1	100.1
SCHLUMBERGER	J55	C394778	09-18-02	100.2	100.0	100.2
SCHLUMBERGER	J55	C394779	09-18-02	100.1	99.7	99.9

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

PAGE 196
 RUN DATE: 1/14/03
 RUN TIME: 13.26.53

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	J5S	C394780	09-18-02	100.2	100.0	100.1
SCHLUMBERGER	J5S	C394781	09-18-02	100.1	99.8	99.8
SCHLUMBERGER	J5S	C394782	09-18-02	99.8	99.9	99.9
SCHLUMBERGER	J5S	C394783	09-18-02	100.0	99.6	100.0
SCHLUMBERGER	J5S	C394784	09-18-02	100.1	99.9	99.6
SCHLUMBERGER	J5S	C394785	09-18-02	100.2	100.2	100.2
SCHLUMBERGER	J5S	C394786	09-18-02	100.2	99.8	100.0
SCHLUMBERGER	J5S	C394787	09-18-02	99.9	99.6	99.9
SCHLUMBERGER	J5S	C394788	09-18-02	100.0	99.6	99.6
SCHLUMBERGER	J5S	C394789	09-18-02	100.3	100.1	99.7
SCHLUMBERGER	J5S	C394790	09-18-02	100.1	100.1	100.0
SCHLUMBERGER	J5S	C394791	09-18-02	100.0	100.2	99.8
SCHLUMBERGER	J5S	C394792	09-18-02	100.0	99.7	99.8
SCHLUMBERGER	J5S	C394793	09-18-02	100.1	99.6	99.6
SCHLUMBERGER	J5S	C394794	09-18-02	100.1	100.0	100.1
SCHLUMBERGER	J5S	C394795	09-18-02	100.0	100.2	99.8
SCHLUMBERGER	J5S	C394796	09-18-02	100.1	99.7	99.8
SCHLUMBERGER	J5S	C394797	09-18-02	100.2	99.9	100.0
SCHLUMBERGER	J5S	C394798	09-18-02	100.1	99.9	99.6
SCHLUMBERGER	J5S	C394799	09-18-02	100.0	99.9	99.9
SCHLUMBERGER	J5S	C394800	09-18-02	100.0	100.1	100.2
SCHLUMBERGER	J5S	C394801	09-18-02	100.1	99.9	99.7
SCHLUMBERGER	J5S	C394802	09-18-02	100.0	99.7	99.9
SCHLUMBERGER	J5S	C394803	09-18-02	100.0	99.7	99.9
SCHLUMBERGER	J5S	C394804	09-18-02	100.0	99.7	100.2
SCHLUMBERGER	J5S	C394805	09-18-02	100.0	99.6	99.5
SCHLUMBERGER	J5S	C394806	09-18-02	100.1	99.7	100.2
SCHLUMBERGER	J5S	C394807	09-18-02	100.1	99.8	100.0
SCHLUMBERGER	J5S	C394808	09-18-02	100.1	99.8	99.8
SCHLUMBERGER	J5S	C394809	09-18-02	100.0	99.9	99.9
SCHLUMBERGER	J5S	C394810	09-18-02	100.0	99.9	99.9
SCHLUMBERGER	J5S	C394811	09-18-02	100.3	100.1	100.3
SCHLUMBERGER	J5S	C394812	09-18-02	100.0	99.9	99.8
SCHLUMBERGER	J5S	C394813	09-18-02	100.0	99.9	99.8
SCHLUMBERGER	J5S	C394814	09-18-02	100.1	99.8	100.1
SCHLUMBERGER	J5S	C394815	09-18-02	100.0	99.6	99.8
SCHLUMBERGER	J5S	C394816	09-18-02	100.1	99.9	99.4
SCHLUMBERGER	J5S	C394817	09-18-02	100.0	99.9	100.3
SCHLUMBERGER	J5S	C394818	09-18-02	100.2	99.9	100.2
SCHLUMBERGER	J5S	C394819	09-18-02	100.0	100.1	99.8
SCHLUMBERGER	J5S	C394820	09-18-02	100.1	99.8	99.9
SCHLUMBERGER	J5S	C394821	09-18-02	99.9	99.8	99.9
SCHLUMBERGER	J5S	C394822	09-18-02	100.1	100.1	99.8
SCHLUMBERGER	J5S	C394823	09-18-02	100.0	99.8	99.7
SCHLUMBERGER	J5S	C394824	09-18-02	99.9	99.6	99.6
SCHLUMBERGER	J5S	C394825	09-18-02	100.0	100.0	99.9
SCHLUMBERGER	J5S	C394826	09-18-02	100.1	99.8	99.6
SCHLUMBERGER	J5S	C394827	09-18-02	100.1	99.9	99.8
SCHLUMBERGER	J5S	C394828	09-18-02	100.1	99.8	100.0
SCHLUMBERGER	J5S	C394829	09-18-02	100.2	100.1	99.8
SCHLUMBERGER	J5S	C394830	09-18-02	99.9	99.8	100.4
SCHLUMBERGER	J5S					100.0

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

PAGE 197
 RUN DATE: 1/14/03
 RUN TIME: 13.26.53

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	J5S	C394831	09-18-02	100.0	99.7	99.5
SCHLUMBERGER	J5S	C394832	09-18-02	99.9	99.9	99.6
SCHLUMBERGER	J5S	C394833	09-18-02	100.1	99.8	99.9
SCHLUMBERGER	J5S	C394834	09-18-02	100.2	99.8	100.1
SCHLUMBERGER	J5S	C394835	09-18-02	100.2	99.8	100.4
SCHLUMBERGER	J5S	C394836	09-18-02	100.1	99.9	99.6
SCHLUMBERGER	J5S	C394837	09-18-02	100.1	99.9	100.0
SCHLUMBERGER	J5S	C394838	09-18-02	99.9	99.9	99.9
SCHLUMBERGER	J5S	C394839	09-18-02	100.1	99.9	99.9
SCHLUMBERGER	J5S	C394840	09-18-02	100.1	99.9	100.1
SCHLUMBERGER	J5S	C394841	09-18-02	100.1	99.7	99.9
SCHLUMBERGER	J5S	C394842	09-18-02	100.1	99.9	99.9
SCHLUMBERGER	J5S	C394843	09-18-02	100.2	99.9	100.0
SCHLUMBERGER	J5S	C394844	09-18-02	99.8	99.8	99.8
SCHLUMBERGER	J5S	C394845	09-18-02	100.0	99.8	99.7
SCHLUMBERGER	J5S	C394846	09-18-02	100.3	99.8	99.8
SCHLUMBERGER	J5S	C394847	09-18-02	100.1	99.8	99.7
SCHLUMBERGER	J5S	C394848	09-18-02	100.1	99.8	99.7
SCHLUMBERGER	J5S	C394849	09-18-02	100.1	99.8	99.7
SCHLUMBERGER	J5S	C394850	09-18-02	99.9	99.7	99.8
SCHLUMBERGER	J5S	C394851	09-18-02	100.1	100.1	100.0
SCHLUMBERGER	J5S	C394852	09-18-02	100.0	100.1	99.9
SCHLUMBERGER	J5S	C394853	09-18-02	100.1	99.6	99.8
SCHLUMBERGER	J5S	C394854	09-18-02	100.0	99.6	99.7
SCHLUMBERGER	J5S	C394855	09-18-02	100.1	99.9	99.7
SCHLUMBERGER	J5S	C394856	09-18-02	100.0	99.9	99.6
SCHLUMBERGER	J5S	C394857	09-18-02	100.0	99.7	99.9
SCHLUMBERGER	J5S	C394858	09-18-02	99.9	99.9	99.9
SCHLUMBERGER	J5S	C394859	09-18-02	100.2	99.8	99.8
SCHLUMBERGER	J5S	C394860	09-18-02	99.9	99.6	99.4
SCHLUMBERGER	J5S	C394861	09-18-02	100.1	99.8	100.1
SCHLUMBERGER	J5S	C394862	09-18-02	100.0	99.7	100.2
SCHLUMBERGER	J5S	C394863	09-18-02	100.2	99.8	100.1
SCHLUMBERGER	J5S	C394864	09-18-02	100.2	99.7	100.3
SCHLUMBERGER	J5S	C394865	09-18-02	100.1	99.8	99.9
SCHLUMBERGER	J5S	C394866	09-18-02	100.1	99.7	100.1
SCHLUMBERGER	J5S	C394867	09-18-02	100.1	100.0	99.7
SCHLUMBERGER	J5S	C394868	09-18-02	100.0	99.8	99.8
SCHLUMBERGER	J5S	C394869	09-18-02	100.2	99.6	100.0
SCHLUMBERGER	J5S	C394870	09-18-02	100.0	99.7	99.7
SCHLUMBERGER	J5S	C394871	09-18-02	99.9	99.7	99.5
SCHLUMBERGER	J5S	C394872	09-18-02	100.1	99.9	99.8
SCHLUMBERGER	J5S	C394873	09-18-02	99.9	99.9	99.4
SCHLUMBERGER	J5S	C394874	09-18-02	100.1	99.8	99.8
SCHLUMBERGER	J5S	C394875	09-18-02	100.0	99.7	100.3
SCHLUMBERGER	J5S	C394876	09-18-02	100.1	99.8	99.8
SCHLUMBERGER	J5S	C394877	09-18-02	100.0	99.9	99.7
SCHLUMBERGER	J5S	C394878	09-18-02	100.1	99.9	100.1
SCHLUMBERGER	J5S	C394879	09-18-02	100.0	99.6	100.0
SCHLUMBERGER	J5S	C394880	09-18-02	99.9	99.9	99.6
SCHLUMBERGER	J5S	C394881	09-18-02	100.0	99.7	100.2

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

PAGE 198
 RUN DATE: 1/14/03
 RUN TIME: 13.26.53

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	J55	C394882	09-18-02	100.0	99.8	99.6
SCHLUMBERGER	J55	C394883	09-18-02	100.0	99.8	100.2
SCHLUMBERGER	J55	C394884	09-18-02	100.0	99.6	99.9
SCHLUMBERGER	J55	C394885	09-18-02	100.1	100.3	99.5
SCHLUMBERGER	J55	C394886	09-18-02	100.1	99.8	99.8
SCHLUMBERGER	J55	C394887	09-18-02	100.0	99.7	99.8
SCHLUMBERGER	J55	C394888	09-18-02	100.0	99.9	99.7
SCHLUMBERGER	J55	C394889	09-18-02	100.1	100.2	99.9
SCHLUMBERGER	J55	C394890	09-18-02	100.2	99.8	100.0
SCHLUMBERGER	J55	C394891	09-18-02	100.1	99.9	100.2
SCHLUMBERGER	J55	C394892	09-18-02	100.1	99.9	100.3
SCHLUMBERGER	J55	C394893	09-18-02	100.0	99.8	99.9
SCHLUMBERGER	J55	C394894	09-18-02	100.2	99.8	99.9
SCHLUMBERGER	J55	C394895	09-18-02	100.3	99.7	99.9
SCHLUMBERGER	J55	C394896	09-18-02	100.3	99.7	100.1
SCHLUMBERGER	J55	C394897	09-18-02	100.0	99.7	100.0
SCHLUMBERGER	J55	C394898	09-18-02	100.0	99.8	99.9
SCHLUMBERGER	J55	C394899	09-18-02	100.1	99.7	100.3
SCHLUMBERGER	J55	C394900	09-18-02	99.8	99.6	99.7
SCHLUMBERGER	J55	C394901	09-18-02	100.0	99.7	100.0
SCHLUMBERGER	J55	C394902	09-18-02	99.9	99.7	99.7
SCHLUMBERGER	J55	C394903	09-18-02	99.9	99.9	99.5
SCHLUMBERGER	J55	C394904	09-18-02	100.1	99.8	100.0
SCHLUMBERGER	J55	C394905	09-18-02	100.0	99.8	100.0
SCHLUMBERGER	J55	C394906	09-18-02	100.1	99.8	100.2
SCHLUMBERGER	J55	C394907	09-18-02	100.0	100.2	99.7
SCHLUMBERGER	J55	C394908	09-18-02	100.1	99.7	99.7
SCHLUMBERGER	J55	C394909	09-18-02	100.0	99.7	99.7
SCHLUMBERGER	J55	C394910	09-18-02	100.0	99.8	99.7
SCHLUMBERGER	J55	C394911	09-18-02	100.0	99.8	99.5
SCHLUMBERGER	J55	C394912	09-18-02	100.1	99.9	100.0
SCHLUMBERGER	J55	C394913	09-18-02	100.1	99.6	100.0
SCHLUMBERGER	J55	C394914	09-18-02	99.9	99.7	99.9
SCHLUMBERGER	J55	C394915	09-18-02	100.0	99.7	99.9
SCHLUMBERGER	J55	C394916	09-18-02	100.1	99.9	100.0
SCHLUMBERGER	J55	C394917	09-18-02	99.9	99.8	99.8
SCHLUMBERGER	J55	C394918	09-18-02	100.1	99.8	100.2
SCHLUMBERGER	J55	C394919	09-18-02	100.0	99.7	99.5
SCHLUMBERGER	J55	C394920	09-18-02	100.1	100.0	100.0
SCHLUMBERGER	J55	C394921	09-18-02	100.2	100.0	100.0
SCHLUMBERGER	J55	C394922	09-18-02	100.0	100.0	99.9
SCHLUMBERGER	J55	C394923	09-18-02	100.1	100.1	100.3
SCHLUMBERGER	J55	C394924	09-18-02	99.9	99.6	100.0
SCHLUMBERGER	J55	C394925	09-18-02	100.1	99.7	99.9
SCHLUMBERGER	J55	C394926	09-18-02	100.2	100.0	100.2
SCHLUMBERGER	J55	C394927	09-18-02	100.0	99.7	100.0
SCHLUMBERGER	J55	C394928	09-18-02	100.1	100.0	99.9
SCHLUMBERGER	J55	C394929	09-18-02	100.1	99.9	99.9
SCHLUMBERGER	J55	C394930	09-18-02	99.9	99.6	99.7
SCHLUMBERGER	J55	C394931	09-18-02	100.0	99.8	100.1
SCHLUMBERGER	J55	C394932	09-18-02	100.0	99.8	99.7

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

PAGE 199
 RUN DATE: 1/14/03
 RUN TIME: 13.26.53

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	J5S	C394933	09-18-02	100.0	99.7	100.2
SCHLUMBERGER	J5S	C394934	09-18-02	100.1	100.3	100.1
SCHLUMBERGER	J5S	C394935	09-18-02	100.3	99.8	100.5
SCHLUMBERGER	J5S	C394936	09-18-02	100.2	99.8	100.1
SCHLUMBERGER	J5S	C394937	09-18-02	100.1	99.7	99.9
SCHLUMBERGER	J5S	C394938	09-18-02	100.1	99.9	99.3
SCHLUMBERGER	J5S	C394939	09-18-02	99.9	99.7	99.5
SCHLUMBERGER	J5S	C394940	09-18-02	100.0	99.7	100.1
SCHLUMBERGER	J5S	C394941	09-18-02	100.0	99.9	99.9
SCHLUMBERGER	J5S	C394942	09-18-02	100.1	99.7	99.9
SCHLUMBERGER	J5S	C394943	09-18-02	100.0	99.6	100.0
SCHLUMBERGER	J5S	C394944	09-18-02	100.1	99.9	99.9
SCHLUMBERGER	J5S	C394945	09-18-02	100.0	99.7	99.7
SCHLUMBERGER	J5S	C394946	09-18-02	100.1	99.8	99.9
SCHLUMBERGER	J5S	C394947	09-18-02	100.1	99.9	100.0
SCHLUMBERGER	J5S	C394948	09-18-02	99.9	99.9	100.2
SCHLUMBERGER	J5S	C394949	09-18-02	100.0	99.8	99.9
SCHLUMBERGER	J5S	C394950	09-18-02	100.0	99.6	99.4
SCHLUMBERGER	J5S	C394951	09-18-02	100.0	99.6	100.1
SCHLUMBERGER	J5S	C394952	09-18-02	100.1	100.1	99.9
SCHLUMBERGER	J5S	C394953	09-18-02	100.0	100.2	99.8
SCHLUMBERGER	J5S	C394954	09-18-02	100.3	100.1	100.3
SCHLUMBERGER	J5S	C394955	09-18-02	100.1	100.1	100.2
SCHLUMBERGER	J5S	C394956	09-18-02	100.0	100.0	100.1
SCHLUMBERGER	J5S	C394957	09-18-02	100.0	99.9	100.1
SCHLUMBERGER	J5S	C394958	09-18-02	100.0	99.6	100.1
SCHLUMBERGER	J5S	C394959	09-18-02	100.1	99.8	100.1
SCHLUMBERGER	J5S	C394960	09-18-02	100.0	99.9	100.2
SCHLUMBERGER	J5S	C394961	09-18-02	100.1	100.0	100.1
SCHLUMBERGER	J5S	C394962	09-18-02	100.1	99.7	99.8
SCHLUMBERGER	J5S	C394963	09-18-02	100.0	99.7	99.7
SCHLUMBERGER	J5S	C394964	09-18-02	99.9	99.6	99.7
SCHLUMBERGER	J5S	C394965	09-18-02	100.0	99.8	99.8
SCHLUMBERGER	J5S	C394966	09-18-02	100.0	99.8	99.9
SCHLUMBERGER	J5S	C394967	09-18-02	100.1	99.9	100.1
SCHLUMBERGER	J5S	C394968	09-18-02	100.0	99.8	100.0
SCHLUMBERGER	J5S	C394969	09-18-02	100.0	99.9	99.7
SCHLUMBERGER	J5S	C394970	09-18-02	99.9	100.1	99.5
SCHLUMBERGER	J5S	C394971	09-18-02	100.1	99.7	99.7
SCHLUMBERGER	J5S	C394972	09-18-02	100.1	99.7	99.4
SCHLUMBERGER	J5S	C394973	09-18-02	100.3	100.0	100.1
SCHLUMBERGER	J5S	C394974	09-18-02	100.0	99.8	99.5
SCHLUMBERGER	J5S	C394975	09-18-02	100.0	100.1	99.9
SCHLUMBERGER	J5S	C394976	09-18-02	100.1	99.7	100.0
SCHLUMBERGER	J5S	C394977	09-18-02	100.0	99.9	99.8
SCHLUMBERGER	J5S	C394978	09-18-02	100.0	100.0	99.8
SCHLUMBERGER	J5S	C394979	09-18-02	100.0	99.7	99.9
SCHLUMBERGER	J5S	C394980	09-18-02	100.0	99.8	100.1
SCHLUMBERGER	J5S	C394981	09-18-02	100.1	99.8	99.9
SCHLUMBERGER	J5S	C394982	09-18-02	100.0	100.1	99.8
SCHLUMBERGER	J5S	C394983	09-18-02	100.0	99.8	99.9

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD880

PAGE 200
 RUN DATE: 1/14/03
 RUN TIME: 13.26.53

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	J55	C394984	09-18-02	100.0	99.8	99.9
SCHLUMBERGER	J55	C394985	09-18-02	99.9	99.7	99.6
SCHLUMBERGER	J55	C394986	09-18-02	100.0	99.8	99.8
SCHLUMBERGER	J55	C394987	09-18-02	99.8	99.7	99.6
SCHLUMBERGER	J55	C394988	09-18-02	100.0	99.8	99.8
SCHLUMBERGER	J55	C394989	09-18-02	100.1	99.9	99.4
SCHLUMBERGER	J55	C394990	09-18-02	100.0	99.8	99.6
SCHLUMBERGER	J55	C394991	09-18-02	100.0	100.3	99.8
SCHLUMBERGER	J55	C394992	09-18-02	99.9	99.7	100.1
SCHLUMBERGER	J55	C394993	09-18-02	100.0	99.7	100.1
SCHLUMBERGER	J55	C394994	09-18-02	100.1	100.2	100.2
SCHLUMBERGER	J55	C394995	09-18-02	100.3	100.3	99.7
SCHLUMBERGER	J55	C394996	09-18-02	100.2	99.8	99.8
SCHLUMBERGER	J55	C394997	09-18-02	100.0	99.8	100.0
SCHLUMBERGER	J55	C394998	09-18-02	100.0	100.0	99.6
SCHLUMBERGER	J55	C394999	09-18-02	100.1	100.1	99.9
SCHLUMBERGER	J55	C395000	09-18-02	100.1	100.1	100.3
SCHLUMBERGER	J55	C395001	09-18-02	100.0	99.6	100.1
SCHLUMBERGER	J55	C395002	09-18-02	100.1	100.1	100.0
SCHLUMBERGER	J55	C395003	09-18-02	100.0	99.9	99.6
SCHLUMBERGER	J55	C395004	09-18-02	100.0	99.6	100.3
SCHLUMBERGER	J55	C395005	09-18-02	100.1	99.7	100.0
SCHLUMBERGER	J55	C395006	09-18-02	100.1	99.9	99.5
SCHLUMBERGER	J55	C395007	09-18-02	100.0	100.0	99.8
SCHLUMBERGER	J55	C395008	09-18-02	100.0	99.7	99.6
SCHLUMBERGER	J55	C395009	09-18-02	100.3	100.0	100.2
SCHLUMBERGER	J55	C395010	09-18-02	99.9	100.0	99.7
SCHLUMBERGER	J55	C395011	09-18-02	100.2	100.4	99.4
SCHLUMBERGER	J55	C395012	09-18-02	100.0	99.8	99.6
SCHLUMBERGER	J55	C395013	09-18-02	100.0	100.0	99.9
SCHLUMBERGER	J55	C395014	09-18-02	99.9	99.8	99.6
SCHLUMBERGER	J55	C395015	09-18-02	100.1	99.9	99.7
SCHLUMBERGER	J55	C395016	09-18-02	100.1	99.7	99.8
SCHLUMBERGER	J55	C395017	09-18-02	99.9	99.6	99.4
SCHLUMBERGER	J55	C395018	09-18-02	100.0	100.1	99.9
SCHLUMBERGER	J55	C395019	09-18-02	100.1	100.0	99.9
SCHLUMBERGER	J55	C395020	09-18-02	100.0	99.9	99.3
SCHLUMBERGER	J55	C395021	09-18-02	100.2	99.8	99.9
SCHLUMBERGER	J55	C395022	09-18-02	100.0	99.7	100.0
SCHLUMBERGER	J55	C395023	09-18-02	100.0	99.7	100.3
SCHLUMBERGER	J55	C395024	09-18-02	100.0	99.6	100.1
SCHLUMBERGER	J55	C395025	09-18-02	100.1	100.0	100.1
SCHLUMBERGER	J55	C395026	09-18-02	100.0	100.2	100.2
SCHLUMBERGER	J55	C395027	09-18-02	100.1	99.7	100.0
SCHLUMBERGER	J55	C395028	09-18-02	100.0	100.1	99.9
SCHLUMBERGER	J55	C395029	09-18-02	100.2	99.8	99.7
SCHLUMBERGER	J55	C395030	09-18-02	100.1	99.9	100.0
SCHLUMBERGER	J55	C395031	09-18-02	99.9	100.0	99.8
SCHLUMBERGER	J55	C395032	09-18-02	100.0	99.6	99.7
SCHLUMBERGER	J55	C395033	09-18-02	100.0	99.9	99.6
SCHLUMBERGER	J55	C395034	09-18-02	100.1	99.9	99.8

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	J55	C395035	09-18-02	100.0	99.7	99.8
SCHLUMBERGER	J55	C395036	09-18-02	100.1	100.0	100.2
SCHLUMBERGER	J55	C395037	09-18-02	100.0	99.9	99.8
SCHLUMBERGER	J55	C395038	09-18-02	100.1	99.8	99.7
SCHLUMBERGER	J55	C395039	09-18-02	100.0	99.8	99.5
SCHLUMBERGER	J55	C395040	09-18-02	100.0	99.9	100.1
SCHLUMBERGER	J55	C395041	09-18-02	100.3	99.9	100.1
SCHLUMBERGER	J55	C395042	09-18-02	100.1	99.7	100.0
SCHLUMBERGER	J55	C395043	09-18-02	100.1	100.1	100.0
SCHLUMBERGER	J55	C395044	09-18-02	100.0	99.7	99.6
SCHLUMBERGER	J55	C395045	09-18-02	100.0	99.9	99.7
SCHLUMBERGER	J55	C395046	09-18-02	100.1	99.9	100.0
SCHLUMBERGER	J55	C395047	09-18-02	100.3	100.4	99.4
SCHLUMBERGER	J55	C395048	09-18-02	100.1	99.6	99.8
SCHLUMBERGER	J55	C395049	09-18-02	100.1	99.6	99.9
SCHLUMBERGER	J55	C395050	09-18-02	100.1	100.0	99.6
SCHLUMBERGER	J55	C395051	09-18-02	100.1	99.8	99.9
SCHLUMBERGER	J55	C395052	09-18-02	100.0	99.9	100.1
SCHLUMBERGER	J55	C395053	09-18-02	100.0	99.7	99.4
SCHLUMBERGER	J55	C395054	09-18-02	100.0	99.9	99.9
SCHLUMBERGER	J55	C395055	09-18-02	100.1	99.7	99.5
SCHLUMBERGER	J55	C395056	09-18-02	99.9	100.4	100.0
SCHLUMBERGER	J55	C395057	09-18-02	100.1	99.9	100.0
SCHLUMBERGER	J55	C395058	09-18-02	100.0	99.8	99.3
SCHLUMBERGER	J55	C395059	09-18-02	99.9	99.8	99.3
SCHLUMBERGER	J55	C395060	09-18-02	99.9	99.8	99.5
SCHLUMBERGER	J55	C395061	09-18-02	100.3	100.5	99.3
SCHLUMBERGER	J55	C395062	09-18-02	100.0	99.9	100.0
SCHLUMBERGER	J55	C395063	09-18-02	100.0	99.8	99.7
SCHLUMBERGER	J55	C395064	09-18-02	100.3	99.9	99.6
SCHLUMBERGER	J55	C395065	09-18-02	100.1	99.8	99.9
SCHLUMBERGER	J55	C395066	09-18-02	100.1	99.7	99.8
SCHLUMBERGER	J55	C395067	09-18-02	100.1	99.8	99.8
SCHLUMBERGER	J55	C395068	09-18-02	100.2	100.0	100.0
SCHLUMBERGER	J55	C395069	09-18-02	100.0	99.8	99.4
SCHLUMBERGER	J55	C395070	09-18-02	100.0	99.8	100.3
SCHLUMBERGER	J55	C395071	09-18-02	100.0	99.9	100.1
SCHLUMBERGER	J55	C395072	09-18-02	100.0	99.7	99.6
SCHLUMBERGER	J55	C395073	09-18-02	99.9	99.7	99.8
SCHLUMBERGER	J55	C395074	09-18-02	100.1	99.8	99.9
SCHLUMBERGER	J55	C395075	09-18-02	100.0	100.0	99.8
SCHLUMBERGER	J55	C395076	09-18-02	100.1	99.8	99.8
SCHLUMBERGER	J55	C395077	09-18-02	100.1	99.9	99.9
SCHLUMBERGER	J55	C395078	09-18-02	100.0	99.7	99.4
SCHLUMBERGER	J55	C395079	09-18-02	100.0	99.7	99.7
SCHLUMBERGER	J55	C395080	09-18-02	100.1	99.7	100.0
SCHLUMBERGER	J55	C395081	09-18-02	100.0	99.7	99.7
SCHLUMBERGER	J55	C395082	09-18-02	99.9	99.9	100.0
SCHLUMBERGER	J55	C395083	09-18-02	100.0	99.9	99.5
SCHLUMBERGER	J55	C395084	09-18-02	100.0	100.2	99.7
SCHLUMBERGER	J55	C395085	09-18-02	100.1	100.0	99.5

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

PAGE 202
 RUN DATE: 1/14/03
 RUN TIME: 13.26.53

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	J55	C395086	09-18-02	100.1	99.8	99.6
SCHLUMBERGER	J55	C395087	09-18-02	100.2	99.9	100.3
SCHLUMBERGER	J55	C395088	09-18-02	100.2	100.2	99.5
SCHLUMBERGER	J55	C395089	09-18-02	100.0	99.9	99.8
SCHLUMBERGER	J55	C395090	09-18-02	100.0	99.6	99.5
SCHLUMBERGER	J55	C395091	09-18-02	100.1	99.8	100.1
SCHLUMBERGER	J55	C395092	09-18-02	100.3	100.4	99.4
SCHLUMBERGER	J55	C395093	09-18-02	100.1	99.8	100.1
SCHLUMBERGER	J55	C395094	09-18-02	100.0	99.7	99.3
SCHLUMBERGER	J55	C395095	09-18-02	99.9	99.7	99.5
SCHLUMBERGER	J55	C395096	09-18-02	99.9	99.6	99.5
SCHLUMBERGER	J55	C395097	09-18-02	99.9	99.7	99.5
SCHLUMBERGER	J55	C395098	09-18-02	100.1	100.1	99.4
SCHLUMBERGER	J55	C395099	09-18-02	100.0	99.8	99.5
SCHLUMBERGER	J55	C395100	09-18-02	100.1	99.8	99.9
SCHLUMBERGER	J55	C395101	09-18-02	100.0	100.0	99.6
SCHLUMBERGER	J55	C395102	09-18-02	99.9	99.6	99.6
SCHLUMBERGER	J55	C395103	09-18-02	100.0	100.3	99.5
SCHLUMBERGER	J55	C395104	09-18-02	100.0	99.7	99.4
SCHLUMBERGER	J55	C395105	09-18-02	99.9	100.0	99.7
SCHLUMBERGER	J55	C395106	09-18-02	100.1	100.3	99.7
SCHLUMBERGER	J55	C395107	09-18-02	100.1	99.9	99.5
SCHLUMBERGER	J55	C395108	09-18-02	100.0	100.0	99.7
SCHLUMBERGER	J55	C395109	09-18-02	100.0	100.2	99.6
SCHLUMBERGER	J55	C395110	09-18-02	99.9	100.0	99.4
SCHLUMBERGER	J55	C395111	09-18-02	100.0	99.8	99.6
SCHLUMBERGER	J55	C395112	09-18-02	100.0	100.0	100.0
SCHLUMBERGER	J55	C395113	09-18-02	100.0	99.9	100.2
SCHLUMBERGER	J55	C395114	09-18-02	100.0	99.7	100.1
SCHLUMBERGER	J55	C395115	09-18-02	100.1	99.9	100.0
SCHLUMBERGER	J55	C395116	09-18-02	100.0	99.8	99.8
SCHLUMBERGER	J55	C395117	09-18-02	100.0	99.8	99.8
SCHLUMBERGER	J55	C395118	09-18-02	100.0	99.7	100.0
SCHLUMBERGER	J55	C395119	09-18-02	100.1	100.0	100.6
SCHLUMBERGER	J55	C395120	09-18-02	100.0	99.8	99.3
SCHLUMBERGER	J55	C395121	09-18-02	100.0	100.0	99.9
SCHLUMBERGER	J55	C395122	09-18-02	100.0	99.9	99.5
SCHLUMBERGER	J55	C395123	09-18-02	100.0	99.7	99.5
SCHLUMBERGER	J55	C395124	09-18-02	100.2	100.0	99.6
SCHLUMBERGER	J55	C395125	09-18-02	100.1	99.8	99.8
SCHLUMBERGER	J55	C395126	09-18-02	100.1	99.7	99.7
SCHLUMBERGER	J55	C395127	09-18-02	100.2	99.7	100.1
SCHLUMBERGER	J55	C395128	09-18-02	100.0	99.8	99.8
SCHLUMBERGER	J55	C395129	09-18-02	100.1	100.0	99.3
SCHLUMBERGER	J55	C395130	09-18-02	100.1	100.1	100.0
SCHLUMBERGER	J55	C395131	09-18-02	100.1	99.9	100.2
SCHLUMBERGER	J55	C395132	09-18-02	100.1	99.7	99.4
SCHLUMBERGER	J55	C395133	09-18-02	100.0	100.1	99.9
SCHLUMBERGER	J55	C395134	09-18-02	100.1	99.9	99.9
SCHLUMBERGER	J55	C395135	09-18-02	100.3	100.0	100.2
SCHLUMBERGER	J55	C395136	09-18-02	100.0	99.8	99.8

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	J55	C3951137	09-18-02	100.0	99.7	99.6
SCHLUMBERGER	J55	C3951138	09-18-02	99.9	99.9	99.7
SCHLUMBERGER	J55	C3951139	09-18-02	100.0	99.9	99.6
SCHLUMBERGER	J55	C3951140	09-18-02	100.0	100.1	100.1
SCHLUMBERGER	J55	C3951141	09-18-02	100.1	100.1	99.4
SCHLUMBERGER	J55	C3951142	09-18-02	100.0	100.0	99.4
SCHLUMBERGER	J55	C3951143	09-18-02	100.0	99.7	99.3
SCHLUMBERGER	J55	C3951144	09-18-02	100.0	99.9	100.0
SCHLUMBERGER	J55	C3951145	09-18-02	100.0	99.7	100.3
SCHLUMBERGER	J55	C3951146	09-18-02	100.1	99.9	99.6
SCHLUMBERGER	J55	C3951147	09-18-02	99.9	99.8	99.9
SCHLUMBERGER	J55	C3951148	09-18-02	100.1	99.7	99.5
SCHLUMBERGER	J55	C3951149	09-18-02	100.1	99.8	99.8
SCHLUMBERGER	J55	C3951150	09-18-02	100.0	99.8	100.0
SCHLUMBERGER	J55	C3951151	09-18-02	100.1	99.8	99.8
SCHLUMBERGER	J55	C3951152	09-18-02	100.1	100.2	99.9
SCHLUMBERGER	J55	C3951153	09-18-02	100.2	100.5	99.4
SCHLUMBERGER	J55	C3951154	09-18-02	99.9	99.7	100.1
SCHLUMBERGER	J55	C3951155	09-18-02	100.0	99.8	99.3
SCHLUMBERGER	J55	C3951156	09-18-02	100.0	100.0	99.9
SCHLUMBERGER	J55	C3951157	09-18-02	100.0	99.7	99.7
SCHLUMBERGER	J55	C3951158	09-18-02	99.9	99.8	100.1
SCHLUMBERGER	J55	C3951159	09-18-02	99.9	99.8	99.8
SCHLUMBERGER	J55	C3951160	09-18-02	100.2	99.8	99.7
SCHLUMBERGER	J55	C3951161	09-18-02	100.1	100.0	100.2
SCHLUMBERGER	J55	C3951162	09-18-02	100.0	99.9	99.9
SCHLUMBERGER	J55	C3951163	09-18-02	100.0	100.4	99.3
SCHLUMBERGER	J55	C3951164	09-18-02	100.1	99.8	99.7
SCHLUMBERGER	J55	C3951165	09-18-02	100.1	99.9	99.9
SCHLUMBERGER	J55	C3951166	09-18-02	100.2	99.9	100.2
SCHLUMBERGER	J55	C3951167	09-18-02	100.3	100.1	99.4
SCHLUMBERGER	J55	C3951168	09-18-02	100.0	100.1	99.8
SCHLUMBERGER	J55	C3951169	09-18-02	100.0	99.7	100.0
SCHLUMBERGER	J55	C3951170	09-18-02	100.1	99.8	100.2
SCHLUMBERGER	J55	C3951171	09-18-02	100.0	99.6	99.5
SCHLUMBERGER	J55	C3951172	09-18-02	100.0	99.7	99.8
SCHLUMBERGER	J55	C3951173	09-18-02	100.2	99.7	99.5
SCHLUMBERGER	J55	C3951174	09-18-02	100.0	100.2	100.1
SCHLUMBERGER	J55	C3951175	09-18-02	100.0	99.8	99.6
SCHLUMBERGER	J55	C3951176	09-18-02	100.1	100.1	100.1
SCHLUMBERGER	J55	C3951177	09-18-02	100.0	100.0	99.8
SCHLUMBERGER	J55	C3951178	09-18-02	100.1	99.6	99.9
SCHLUMBERGER	J55	C3951179	09-18-02	100.0	99.8	100.3
SCHLUMBERGER	J55	C3951180	09-18-02	100.1	100.0	100.0
SCHLUMBERGER	J55	C3951181	09-18-02	100.1	100.0	100.0
SCHLUMBERGER	J55	C3951182	09-18-02	100.2	100.3	99.3
SCHLUMBERGER	J55	C3951183	09-18-02	100.0	99.7	99.5
SCHLUMBERGER	J55	C3951184	09-18-02	100.0	100.3	99.3
SCHLUMBERGER	J55	C3951185	09-18-02	100.2	100.0	99.9
SCHLUMBERGER	J55	C3951186	09-18-02	100.1	99.8	100.0
SCHLUMBERGER	J55	C3951187	09-18-02	100.2	99.7	99.5

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

PAGE 204
 RUN DATE: 1/14/03
 RUN TIME: 13.26.53

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	J5S	C395188	09-18-02	100.2	99.9	99.9
SCHLUMBERGER	J5S	C395189	09-18-02	100.0	99.9	99.7
SCHLUMBERGER	J5S	C395190	09-18-02	100.1	99.8	99.6
SCHLUMBERGER	J5S	C395191	09-18-02	99.9	99.8	99.7
SCHLUMBERGER	J5S	C395192	09-18-02	100.0	100.3	99.3
SCHLUMBERGER	J5S	C395193	09-18-02	100.0	100.3	99.4
SCHLUMBERGER	J5S	C395194	09-18-02	100.2	100.0	99.7
SCHLUMBERGER	J5S	C395195	09-18-02	100.0	99.9	100.1
SCHLUMBERGER	J5S	C395196	09-18-02	100.1	99.6	100.0
SCHLUMBERGER	J5S	C395197	09-18-02	99.8	99.9	99.5
SCHLUMBERGER	J5S	C395198	09-18-02	100.0	99.7	99.9
SCHLUMBERGER	J5S	C395199	09-18-02	99.9	99.6	99.6
SCHLUMBERGER	J5S	C395200	09-18-02	100.1	100.0	99.5
SCHLUMBERGER	J5S	C395201	09-18-02	100.0	99.9	99.9
SCHLUMBERGER	J5S	C395202	09-18-02	100.1	100.0	100.2
SCHLUMBERGER	J5S	C395203	09-18-02	100.0	99.9	99.9
SCHLUMBERGER	J5S	C395204	09-18-02	100.0	99.9	99.6
SCHLUMBERGER	J5S	C395205	09-18-02	100.2	100.0	100.3
SCHLUMBERGER	J5S	C395206	09-18-02	100.0	100.0	99.9
SCHLUMBERGER	J5S	C395207	09-18-02	99.9	99.7	99.8
SCHLUMBERGER	J5S	C395208	09-18-02	100.2	100.1	99.8
SCHLUMBERGER	J5S	C395209	09-18-02	100.0	100.1	100.4
SCHLUMBERGER	J5S	C395210	09-18-02	100.0	100.0	100.1
SCHLUMBERGER	J5S	C395211	09-18-02	100.1	100.0	100.1
SCHLUMBERGER	J5S	C395212	09-18-02	99.9	99.8	99.8
SCHLUMBERGER	J5S	C395213	09-18-02	100.1	100.1	99.4
SCHLUMBERGER	J5S	C395214	09-18-02	100.1	99.6	100.0
SCHLUMBERGER	J5S	C395215	09-18-02	100.0	100.4	100.3
SCHLUMBERGER	J5S	C395216	09-18-02	100.2	99.7	100.2
SCHLUMBERGER	J5S	C395217	09-18-02	100.2	99.6	99.7
SCHLUMBERGER	J5S	C395218	09-18-02	100.1	100.0	99.8
SCHLUMBERGER	J5S	C395219	09-18-02	100.1	99.9	99.9
SCHLUMBERGER	J5S	C395220	09-18-02	100.0	100.1	99.5
SCHLUMBERGER	J5S	C395221	09-18-02	100.1	99.9	99.8
SCHLUMBERGER	J5S	C395222	09-18-02	100.0	99.7	100.4
SCHLUMBERGER	J5S	C395223	09-18-02	100.3	100.1	100.1
SCHLUMBERGER	J5S	C395224	09-18-02	100.2	99.9	100.2
SCHLUMBERGER	J5S	C395225	09-18-02	100.0	100.0	99.5
SCHLUMBERGER	J5S	C395226	09-18-02	100.1	99.9	100.0
SCHLUMBERGER	J5S	C395227	09-18-02	100.2	100.2	100.0
SCHLUMBERGER	J5S	C395228	09-18-02	100.1	99.8	99.4
SCHLUMBERGER	J5S	C395229	09-18-02	99.9	100.0	100.2
SCHLUMBERGER	J5S	C395230	09-18-02	100.1	100.2	100.1
SCHLUMBERGER	J5S	C395231	09-18-02	100.1	99.7	100.0
SCHLUMBERGER	J5S	C395232	09-18-02	100.1	100.0	99.5
SCHLUMBERGER	J5S	C395233	09-18-02	100.0	99.6	100.1
SCHLUMBERGER	J5S	C395234	09-18-02	100.0	99.6	100.1
SCHLUMBERGER	J5S	C395235	09-18-02	99.9	99.7	99.3
SCHLUMBERGER	J5S	C395236	09-18-02	100.1	99.9	99.3
SCHLUMBERGER	J5S	C395237	09-18-02	100.0	99.6	100.1
SCHLUMBERGER	J5S	C395238	09-18-02	100.0	99.7	100.1

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

PAGE 205
 RUN DATE: 1/14/03
 RUN TIME: 13.26.53

MANUFACTURER	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	C395239	09-18-02	100.1	99.7	100.1
SCHLUMBERGER	C395240	09-18-02	100.0	100.0	99.9
SCHLUMBERGER	C395241	09-18-02	100.2	100.0	100.6
SCHLUMBERGER	C395242	09-18-02	100.0	100.1	100.0
SCHLUMBERGER	C395243	09-18-02	100.0	99.7	99.5
SCHLUMBERGER	C395244	09-18-02	100.0	99.7	100.1
SCHLUMBERGER	C395245	09-18-02	100.0	99.8	99.6
SCHLUMBERGER	C395246	09-18-02	100.1	99.7	99.4
SCHLUMBERGER	C395247	09-18-02	100.0	100.0	99.7
SCHLUMBERGER	C395248	09-18-02	99.9	100.0	99.7
SCHLUMBERGER	C395249	09-18-02	100.1	99.8	99.9
SCHLUMBERGER	C395250	09-18-02	100.2	99.7	100.3
SCHLUMBERGER	C395251	09-18-02	100.0	100.4	99.8
SCHLUMBERGER	C395252	09-18-02	100.1	99.9	100.1
SCHLUMBERGER	C395253	09-18-02	100.1	99.8	99.5
SCHLUMBERGER	C395254	09-18-02	100.0	100.0	99.6
SCHLUMBERGER	C395255	09-18-02	100.1	99.8	99.7
SCHLUMBERGER	C395256	09-18-02	100.0	100.0	99.7
SCHLUMBERGER	C395257	09-18-02	100.1	99.9	99.9
SCHLUMBERGER	C395258	09-18-02	100.0	99.9	99.9
SCHLUMBERGER	C395259	09-18-02	100.0	99.7	100.1
SCHLUMBERGER	C395260	09-18-02	100.2	99.9	99.5
SCHLUMBERGER	C395261	09-18-02	100.1	99.7	99.5
SCHLUMBERGER	C395262	09-18-02	99.9	99.9	99.7
SCHLUMBERGER	C395263	09-18-02	100.2	99.8	100.2
SCHLUMBERGER	C395264	09-18-02	100.2	99.9	100.2
SCHLUMBERGER	C395265	09-18-02	100.1	99.6	100.5
SCHLUMBERGER	C395266	09-18-02	100.2	100.1	100.5
SCHLUMBERGER	C395267	09-18-02	100.2	100.1	100.2
SCHLUMBERGER	C395268	09-18-02	100.1	99.7	100.1
SCHLUMBERGER	C395269	09-18-02	100.0	99.7	99.8
SCHLUMBERGER	C395270	09-18-02	100.1	100.0	99.8
SCHLUMBERGER	C395271	09-18-02	100.0	99.8	99.4
SCHLUMBERGER	C395272	09-18-02	100.0	99.7	99.8
SCHLUMBERGER	C395273	09-18-02	100.2	100.4	99.3
SCHLUMBERGER	C395274	09-18-02	100.0	99.6	99.8
SCHLUMBERGER	C395275	09-18-02	100.1	99.6	99.3
SCHLUMBERGER	C395276	09-18-02	100.1	99.7	99.9
SCHLUMBERGER	C395277	09-18-02	100.1	99.9	100.3
SCHLUMBERGER	C395278	09-18-02	100.3	100.1	100.2
SCHLUMBERGER	C395279	09-18-02	99.8	99.7	100.2
SCHLUMBERGER	C395280	09-18-02	100.0	99.7	99.6
SCHLUMBERGER	C395281	09-18-02	100.0	99.9	99.6
SCHLUMBERGER	C395282	09-18-02	100.2	99.9	99.8
SCHLUMBERGER	C395283	09-18-02	100.0	99.7	99.7
SCHLUMBERGER	C395284	09-18-02	100.0	99.9	99.9
SCHLUMBERGER	C395285	09-18-02	100.0	99.9	100.0
SCHLUMBERGER	C395286	09-18-02	100.1	100.1	100.1
SCHLUMBERGER	C395287	09-18-02	100.0	99.7	99.6
SCHLUMBERGER	C395288	09-18-02	99.9	99.8	99.4
SCHLUMBERGER	C395289	09-18-02	100.1	99.8	100.1

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	J55	C395290	09-18-02	100.0	100.2	99.8
SCHLUMBERGER	J55	C395291	09-18-02	100.0	99.7	100.0
SCHLUMBERGER	J55	C395292	09-18-02	99.9	99.8	100.1
SCHLUMBERGER	J55	C395293	09-18-02	99.9	99.7	99.5
SCHLUMBERGER	J55	C395294	09-18-02	99.9	99.7	99.3
SCHLUMBERGER	J55	C395295	09-18-02	100.1	99.6	100.5
SCHLUMBERGER	J55	C395296	09-18-02	100.0	100.2	99.4
SCHLUMBERGER	J55	C395297	09-18-02	100.0	99.6	99.7
SCHLUMBERGER	J55	C395298	09-18-02	100.0	100.3	100.2
SCHLUMBERGER	J55	C395299	09-18-02	100.0	100.2	99.7
SCHLUMBERGER	J55	C395300	09-18-02	100.1	99.9	99.9
SCHLUMBERGER	J55	C395301	09-18-02	100.1	99.7	99.3
SCHLUMBERGER	J55	C395302	09-18-02	100.0	100.2	99.7
SCHLUMBERGER	J55	C395303	09-18-02	100.1	100.0	99.3
SCHLUMBERGER	J55	C395304	09-18-02	100.1	99.7	99.7
SCHLUMBERGER	J55	C395305	09-18-02	100.1	99.9	99.9
SCHLUMBERGER	J55	C395306	09-18-02	100.0	99.8	99.8
SCHLUMBERGER	J55	C395307	09-18-02	100.1	100.0	99.8
SCHLUMBERGER	J55	C395308	09-18-02	100.1	99.8	99.9
SCHLUMBERGER	J55	C395309	09-18-02	100.0	100.0	99.8
SCHLUMBERGER	J55	C395310	09-18-02	100.1	99.7	99.6
SCHLUMBERGER	J55	C395311	09-18-02	100.0	100.1	99.9
SCHLUMBERGER	J55	C395312	09-18-02	100.2	99.6	99.6
SCHLUMBERGER	J55	C395313	09-18-02	100.3	100.4	100.4
SCHLUMBERGER	J55	C395314	09-18-02	100.0	99.5	99.5
SCHLUMBERGER	J55	C395315	09-18-02	100.0	99.7	99.7
SCHLUMBERGER	J55	C395316	09-18-02	100.0	99.6	99.7
SCHLUMBERGER	J55	C395317	09-18-02	100.0	99.7	99.4
SCHLUMBERGER	J55	C395318	09-18-02	100.3	99.8	99.8
SCHLUMBERGER	J55	C395319	09-18-02	99.8	99.7	99.6
SCHLUMBERGER	J55	C395320	09-18-02	99.9	99.6	99.9
SCHLUMBERGER	J55	C395321	09-18-02	100.1	99.8	100.2
SCHLUMBERGER	J55	C395322	09-18-02	100.1	99.8	99.8
SCHLUMBERGER	J55	C395323	09-18-02	100.1	99.8	100.1
SCHLUMBERGER	J55	C395324	09-18-02	100.0	100.0	99.5
SCHLUMBERGER	J55	C395325	09-18-02	100.1	99.9	99.7
SCHLUMBERGER	J55	C395326	09-18-02	100.0	99.8	99.7
SCHLUMBERGER	J55	C395327	09-18-02	100.1	99.6	99.6
SCHLUMBERGER	J55	C395328	09-18-02	100.1	99.6	100.0
SCHLUMBERGER	J55	C395329	09-18-02	100.0	99.7	100.0
SCHLUMBERGER	J55	C395330	09-18-02	100.0	99.4	99.4
SCHLUMBERGER	J55	C395331	09-18-02	100.1	99.8	100.1
SCHLUMBERGER	J55	C395332	09-18-02	100.3	100.5	99.3
SCHLUMBERGER	J55	C395333	09-18-02	100.1	99.9	100.0
SCHLUMBERGER	J55	C395334	09-18-02	100.0	99.8	99.6
SCHLUMBERGER	J55	C395335	09-18-02	99.9	99.8	99.5
SCHLUMBERGER	J55	C395336	09-18-02	100.1	99.9	99.4
SCHLUMBERGER	J55	C395337	09-18-02	100.0	99.9	99.7
SCHLUMBERGER	J55	C395338	09-18-02	99.8	99.6	99.6
SCHLUMBERGER	J55	C395339	09-18-02	100.1	99.7	100.2
SCHLUMBERGER	J55	C395340	09-18-02	100.2	99.9	100.3

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	J55	C395341	09-18-02	100.1	100.1	99.9
SCHLUMBERGER	J55	C395342	09-18-02	100.1	100.1	99.6
SCHLUMBERGER	J55	C395343	09-18-02	100.1	99.8	99.3
SCHLUMBERGER	J55	C395344	09-18-02	100.3	100.1	100.0
SCHLUMBERGER	J55	C395345	09-18-02	100.1	99.9	99.7
SCHLUMBERGER	J55	C395346	09-18-02	100.0	99.7	99.4
SCHLUMBERGER	J55	C395347	09-18-02	100.1	99.7	99.7
SCHLUMBERGER	J55	C395348	09-18-02	99.9	99.6	99.7
SCHLUMBERGER	J55	C395349	09-18-02	100.0	100.0	100.2
SCHLUMBERGER	J55	C395350	09-18-02	100.1	99.9	99.8
SCHLUMBERGER	J55	C395351	09-18-02	99.9	99.9	99.6
SCHLUMBERGER	J55	C395352	09-18-02	100.2	100.0	99.4
SCHLUMBERGER	J55	C395353	09-18-02	100.0	99.9	99.8
SCHLUMBERGER	J55	C395354	09-18-02	100.0	100.0	99.4
SCHLUMBERGER	J55	C395355	09-18-02	100.0	99.8	99.5
SCHLUMBERGER	J55	C395356	09-18-02	100.0	99.6	100.1
SCHLUMBERGER	J55	C395357	09-17-02	100.1	99.9	99.7
SCHLUMBERGER	J55	C395358	09-18-02	99.9	99.9	99.7
SCHLUMBERGER	J55	C395359	09-17-02	100.0	99.8	99.8
SCHLUMBERGER	J55	C395360	09-17-02	100.0	99.6	100.2
SCHLUMBERGER	J55	C395361	09-17-02	100.1	100.0	99.6
SCHLUMBERGER	J55	C395362	09-17-02	100.0	99.9	99.8
SCHLUMBERGER	J55	C395363	09-17-02	99.9	100.3	99.3
SCHLUMBERGER	J55	C395364	09-17-02	99.9	99.6	99.4
SCHLUMBERGER	J55	C395365	09-17-02	100.0	99.9	99.9
SCHLUMBERGER	J55	C395366	09-17-02	100.0	99.7	99.5
SCHLUMBERGER	J55	C395367	09-17-02	100.1	99.7	99.9
SCHLUMBERGER	J55	C395368	09-17-02	100.1	99.6	99.4
SCHLUMBERGER	J55	C395369	09-17-02	100.1	100.0	99.8
SCHLUMBERGER	J55	C395370	09-17-02	100.0	99.9	99.4
SCHLUMBERGER	J55	C395371	09-17-02	99.8	99.8	99.5
SCHLUMBERGER	J55	C395372	09-17-02	99.9	99.9	99.6
SCHLUMBERGER	J55	C395373	09-17-02	100.0	99.8	99.9
SCHLUMBERGER	J55	C395374	09-17-02	100.1	100.5	99.2
SCHLUMBERGER	J55	C395375	09-17-02	99.9	99.8	99.3
SCHLUMBERGER	J55	C395376	09-17-02	100.0	99.8	99.6
SCHLUMBERGER	J55	C395377	09-17-02	100.0	99.7	99.6
SCHLUMBERGER	J55	C395378	09-17-02	100.0	99.8	100.0
SCHLUMBERGER	J55	C395379	09-17-02	100.1	99.6	99.8
SCHLUMBERGER	J55	C395380	09-17-02	100.0	100.3	100.1
SCHLUMBERGER	J55	C395381	09-17-02	100.1	99.7	99.6
SCHLUMBERGER	J55	C395382	09-17-02	100.2	100.1	99.5
SCHLUMBERGER	J55	C395383	09-17-02	99.9	99.6	99.8
SCHLUMBERGER	J55	C395384	09-17-02	100.1	99.9	99.7
SCHLUMBERGER	J55	C395385	09-17-02	99.9	99.9	100.5
SCHLUMBERGER	J55	C395386	09-17-02	100.3	99.9	99.6
SCHLUMBERGER	J55	C395387	09-17-02	99.9	99.7	99.8
SCHLUMBERGER	J55	C395388	09-17-02	100.0	100.1	99.9
SCHLUMBERGER	J55	C395389	09-17-02	100.1	99.7	100.0
SCHLUMBERGER	J55	C395390	09-17-02	100.2	99.7	100.4
SCHLUMBERGER	J55	C395391	09-17-02	100.1	99.8	99.8

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD880

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	J55	C395392	09-17-02	100.0	99.9	99.7
SCHLUMBERGER	J55	C395393	09-17-02	100.1	99.9	100.2
SCHLUMBERGER	J55	C395394	09-17-02	100.1	99.9	100.0
SCHLUMBERGER	J55	C395395	09-17-02	100.1	99.9	99.8
SCHLUMBERGER	J55	C395396	09-17-02	100.0	99.9	99.8
SCHLUMBERGER	J55	C395397	09-17-02	100.0	99.7	99.5
SCHLUMBERGER	J55	C395398	09-17-02	99.9	99.8	99.7
SCHLUMBERGER	J55	C395399	09-17-02	99.8	99.6	99.5
SCHLUMBERGER	J55	C395400	09-17-02	100.1	100.1	99.3
SCHLUMBERGER	J55	C395401	09-17-02	100.2	100.4	99.3
SCHLUMBERGER	J55	C395402	09-17-02	99.8	99.8	99.6
SCHLUMBERGER	J55	C395403	09-17-02	100.2	99.9	99.7
SCHLUMBERGER	J55	C395404	09-17-02	100.1	100.2	100.3
SCHLUMBERGER	J55	C395405	09-17-02	100.0	99.8	99.9
SCHLUMBERGER	J55	C395406	09-17-02	100.0	99.8	99.3
SCHLUMBERGER	J55	C395407	09-17-02	100.1	100.0	100.0
SCHLUMBERGER	J55	C395408	09-17-02	100.0	100.0	100.2
SCHLUMBERGER	J55	C395409	09-17-02	100.1	100.4	99.2
SCHLUMBERGER	J55	C395410	09-17-02	100.0	100.0	100.0
SCHLUMBERGER	J55	C395411	09-17-02	100.3	99.9	99.4
SCHLUMBERGER	J55	C395412	09-17-02	100.0	99.9	99.7
SCHLUMBERGER	J55	C395413	09-17-02	100.0	99.8	99.3
SCHLUMBERGER	J55	C395414	09-17-02	100.1	99.7	100.0
SCHLUMBERGER	J55	C395415	09-17-02	100.2	99.7	99.9
SCHLUMBERGER	J55	C395416	09-17-02	100.1	100.1	99.7
SCHLUMBERGER	J55	C395417	09-17-02	100.2	99.9	100.3
SCHLUMBERGER	J55	C395418	09-17-02	100.2	100.4	99.4
SCHLUMBERGER	J55	C395419	09-17-02	100.0	100.0	100.0
SCHLUMBERGER	J55	C395420	09-17-02	100.2	100.1	100.2
SCHLUMBERGER	J55	C395421	09-17-02	100.1	100.0	99.6
SCHLUMBERGER	J55	C395422	09-17-02	99.8	100.0	100.1
SCHLUMBERGER	J55	C395423	09-17-02	100.1	99.8	100.4
SCHLUMBERGER	J55	C395424	09-17-02	99.8	100.0	99.5
SCHLUMBERGER	J55	C395425	09-17-02	100.0	100.3	99.3
SCHLUMBERGER	J55	C395426	09-17-02	100.0	100.3	99.5
SCHLUMBERGER	J55	C395427	09-17-02	100.1	100.7	100.0
SCHLUMBERGER	J55	C395428	09-17-02	100.1	99.7	100.0
SCHLUMBERGER	J55	C395429	09-17-02	100.0	99.7	100.0
SCHLUMBERGER	J55	C395430	09-17-02	99.9	99.9	99.7
SCHLUMBERGER	J55	C395431	09-17-02	100.1	99.8	99.4
SCHLUMBERGER	J55	C395432	09-17-02	100.3	99.6	100.0
SCHLUMBERGER	J55	C395433	09-17-02	100.0	99.9	99.5
SCHLUMBERGER	J55	C395434	09-17-02	99.9	99.8	99.6
SCHLUMBERGER	J55	C395435	09-17-02	100.3	99.9	100.3
SCHLUMBERGER	J55	C395436	09-17-02	100.0	100.2	99.3
SCHLUMBERGER	J55	C395437	09-17-02	100.0	100.0	100.2
SCHLUMBERGER	J55	C395438	09-17-02	100.2	99.8	100.2
SCHLUMBERGER	J55	C395439	09-17-02	100.0	99.6	99.9
SCHLUMBERGER	J55	C395440	09-17-02	100.0	99.8	100.1
SCHLUMBERGER	J55	C395441	09-17-02	100.0	100.3	99.8
SCHLUMBERGER	J55	C395442	09-17-02	100.0	99.9	100.0

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	J5S	C395443	09-17-02	100.0	99.8	99.7
SCHLUMBERGER	J5S	C395444	09-17-02	100.1	99.8	100.2
SCHLUMBERGER	J5S	C395445	09-17-02	100.1	99.8	99.8
SCHLUMBERGER	J5S	C395446	09-17-02	100.2	99.9	99.5
SCHLUMBERGER	J5S	C395447	09-17-02	100.2	99.9	100.2
SCHLUMBERGER	J5S	C395448	09-17-02	100.0	99.9	99.4
SCHLUMBERGER	J5S	C395449	09-17-02	100.0	99.9	99.6
SCHLUMBERGER	J5S	C395450	09-17-02	100.1	100.4	99.3
SCHLUMBERGER	J5S	C395451	09-17-02	100.0	99.8	99.7
SCHLUMBERGER	J5S	C395452	09-17-02	100.1	100.0	99.8
SCHLUMBERGER	J5S	C395453	09-17-02	100.1	100.0	99.8
SCHLUMBERGER	J5S	C395454	09-17-02	100.0	99.9	99.7
SCHLUMBERGER	J5S	C395455	09-17-02	100.2	100.0	99.9
SCHLUMBERGER	J5S	C395456	09-17-02	100.0	99.7	99.5
SCHLUMBERGER	J5S	C395457	09-17-02	100.0	99.7	100.0
SCHLUMBERGER	J5S	C395458	09-17-02	100.3	100.1	100.1
SCHLUMBERGER	J5S	C395459	09-17-02	99.9	99.9	99.9
SCHLUMBERGER	J5S	C395460	09-17-02	100.2	100.2	100.7
SCHLUMBERGER	J5S	C395461	09-17-02	100.1	99.6	100.1
SCHLUMBERGER	J5S	C395462	09-17-02	100.1	99.8	99.6
SCHLUMBERGER	J5S	C395463	09-17-02	100.0	99.9	99.8
SCHLUMBERGER	J5S	C395464	09-17-02	100.1	99.7	99.4
SCHLUMBERGER	J5S	C395465	09-17-02	100.0	99.9	99.3
SCHLUMBERGER	J5S	C395466	09-17-02	100.0	99.8	99.7
SCHLUMBERGER	J5S	C395467	09-17-02	100.0	99.6	99.3
SCHLUMBERGER	J5S	C395468	09-17-02	100.0	99.7	99.6
SCHLUMBERGER	J5S	C395469	09-17-02	100.0	100.0	100.0
SCHLUMBERGER	J5S	C395470	09-17-02	100.3	100.4	99.3
SCHLUMBERGER	J5S	C395471	09-17-02	100.0	99.8	100.1
SCHLUMBERGER	J5S	C395472	09-17-02	100.1	99.6	99.7
SCHLUMBERGER	J5S	C395473	09-17-02	99.9	99.7	99.9
SCHLUMBERGER	J5S	C395474	09-17-02	100.2	99.7	99.4
SCHLUMBERGER	J5S	C395475	09-17-02	100.2	99.9	99.6
SCHLUMBERGER	J5S	C395476	09-17-02	100.1	100.2	99.4
SCHLUMBERGER	J5S	C395477	09-17-02	100.1	99.8	100.2
SCHLUMBERGER	J5S	C395478	09-17-02	100.1	99.9	99.8
SCHLUMBERGER	J5S	C395479	09-17-02	100.0	100.2	100.7
SCHLUMBERGER	J5S	C395480	09-17-02	100.1	99.6	99.4
SCHLUMBERGER	J5S	C395481	09-17-02	100.1	99.7	99.4
SCHLUMBERGER	J5S	C395482	09-17-02	99.9	99.8	100.0
SCHLUMBERGER	J5S	C395483	09-17-02	100.1	99.8	99.8
SCHLUMBERGER	J5S	C395484	09-17-02	100.0	99.8	99.8
SCHLUMBERGER	J5S	C395485	09-17-02	100.1	99.6	99.8
SCHLUMBERGER	J5S	C395486	09-17-02	100.1	99.8	99.8
SCHLUMBERGER	J5S	C395487	09-17-02	100.0	99.7	99.7
SCHLUMBERGER	J5S	C395488	09-17-02	100.1	99.8	100.0
SCHLUMBERGER	J5S	C395489	09-17-02	100.1	99.6	99.8
SCHLUMBERGER	J5S	C395490	09-17-02	100.0	99.8	99.3
SCHLUMBERGER	J5S	C395491	09-17-02	99.8	99.7	100.8
SCHLUMBERGER	J5S	C395492	09-17-02	100.0	99.6	100.8
SCHLUMBERGER	J5S	C395493	09-17-02	99.9	99.6	99.3

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

PAGE 210
 RUN DATE: 1/14/03
 RUN TIME: 13.26.53

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	J5S	C395494	09-17-02	100.0	99.8	99.6
SCHLUMBERGER	J5S	C395495	09-17-02	99.9	99.9	99.6
SCHLUMBERGER	J5S	C395496	09-17-02	100.0	99.8	99.4
SCHLUMBERGER	J5S	C395497	09-17-02	99.9	99.8	100.0
SCHLUMBERGER	J5S	C395498	09-17-02	100.0	100.0	100.0
SCHLUMBERGER	J5S	C395499	09-17-02	100.0	99.7	99.8
SCHLUMBERGER	J5S	C395500	09-17-02	100.0	100.0	99.6
SCHLUMBERGER	J5S	C395501	09-17-02	100.0	99.9	100.0
SCHLUMBERGER	J5S	C395502	09-17-02	99.9	99.8	99.5
SCHLUMBERGER	J5S	C395503	09-17-02	100.1	99.6	100.4
SCHLUMBERGER	J5S	C395504	09-17-02	100.0	99.7	99.8
SCHLUMBERGER	J5S	C395505	09-17-02	100.3	100.2	100.1
SCHLUMBERGER	J5S	C395506	09-17-02	100.0	99.8	100.1
SCHLUMBERGER	J5S	C395507	09-17-02	99.9	99.8	99.8
SCHLUMBERGER	J5S	C395508	09-17-02	100.0	99.6	100.2
SCHLUMBERGER	J5S	C395509	09-17-02	100.2	99.8	99.8
SCHLUMBERGER	J5S	C395510	09-17-02	100.1	99.9	99.7
SCHLUMBERGER	J5S	C395511	09-17-02	100.0	100.0	100.1
SCHLUMBERGER	J5S	C395512	09-17-02	100.0	99.8	100.2
SCHLUMBERGER	J5S	C395513	09-17-02	100.2	100.1	99.3
SCHLUMBERGER	J5S	C395514	09-17-02	100.3	99.7	99.7
SCHLUMBERGER	J5S	C395515	09-17-02	99.9	100.1	99.8
SCHLUMBERGER	J5S	C395516	09-17-02	99.9	99.6	99.4
SCHLUMBERGER	J5S	C395517	09-17-02	100.0	100.0	99.5
SCHLUMBERGER	J5S	C395518	09-17-02	99.9	100.2	100.0
SCHLUMBERGER	J5S	C395519	09-17-02	100.2	99.8	99.8
SCHLUMBERGER	J5S	C395520	09-17-02	100.0	100.0	99.4
SCHLUMBERGER	J5S	C395521	09-17-02	99.8	99.9	100.1
SCHLUMBERGER	J5S	C395522	09-17-02	100.0	99.9	99.7
SCHLUMBERGER	J5S	C395523	09-17-02	100.0	99.9	99.8
SCHLUMBERGER	J5S	C395524	09-17-02	100.0	99.8	99.8
SCHLUMBERGER	J5S	C395525	09-17-02	100.0	99.9	99.8
SCHLUMBERGER	J5S	C395526	09-17-02	100.0	99.8	100.1
SCHLUMBERGER	J5S	C395527	09-17-02	100.0	99.7	100.0
SCHLUMBERGER	J5S	C395528	09-17-02	100.1	99.6	99.5
SCHLUMBERGER	J5S	C395529	09-17-02	100.0	99.7	99.6
SCHLUMBERGER	J5S	C395530	09-17-02	100.0	99.8	100.0
SCHLUMBERGER	J5S	C395531	09-17-02	99.9	99.7	100.0
SCHLUMBERGER	J5S	C395532	09-17-02	100.1	100.5	99.4
SCHLUMBERGER	J5S	C395533	09-17-02	99.9	99.8	99.9
SCHLUMBERGER	J5S	C395534	09-17-02	100.1	100.1	100.3
SCHLUMBERGER	J5S	C395535	09-17-02	100.1	100.1	100.0
SCHLUMBERGER	J5S	C395536	09-17-02	100.2	100.2	100.1
SCHLUMBERGER	J5S	C395537	09-17-02	100.3	100.3	99.4
SCHLUMBERGER	J5S	C395538	09-17-02	100.0	99.6	100.1
SCHLUMBERGER	J5S	C395539	09-17-02	100.1	99.9	99.5
SCHLUMBERGER	J5S	C395540	09-17-02	100.0	99.6	99.4
SCHLUMBERGER	J5S	C395541	09-17-02	100.1	99.6	99.6
SCHLUMBERGER	J5S	C395542	09-17-02	100.0	100.0	99.4
SCHLUMBERGER	J5S	C395543	09-17-02	100.1	99.9	100.5
SCHLUMBERGER	J5S	C395544	09-17-02	100.2	99.7	100.1

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	J55	C3955545	09-17-02	100.0	100.1	99.3
SCHLUMBERGER	J55	C3955546	09-17-02	99.9	99.7	99.6
SCHLUMBERGER	J55	C3955547	09-17-02	99.9	99.8	100.2
SCHLUMBERGER	J55	C3955548	09-27-02	100.0	99.8	99.9
SCHLUMBERGER	J55	C3955549	09-27-02	100.1	100.0	100.6
SCHLUMBERGER	J55	C3955550	09-27-02	99.9	100.3	99.9
SCHLUMBERGER	J55	C3955551	09-27-02	100.3	99.8	100.2
SCHLUMBERGER	J55	C3955552	09-27-02	100.0	99.9	99.8
SCHLUMBERGER	J55	C3955553	09-27-02	100.0	99.9	99.8
SCHLUMBERGER	J55	C3955554	09-27-02	100.0	100.0	99.8
SCHLUMBERGER	J55	C3955555	09-27-02	100.0	99.7	99.7
SCHLUMBERGER	J55	C3955556	09-27-02	100.0	99.7	99.9
SCHLUMBERGER	J55	C3955557	09-27-02	100.0	100.4	100.0
SCHLUMBERGER	J55	C3955558	09-27-02	99.9	100.1	100.2
SCHLUMBERGER	J55	C3955559	09-27-02	100.2	99.7	100.2
SCHLUMBERGER	J55	C3955560	09-27-02	99.9	100.0	99.9
SCHLUMBERGER	J55	C3955561	09-27-02	99.9	99.9	99.9
SCHLUMBERGER	J55	C3955562	09-27-02	99.9	99.9	99.8
SCHLUMBERGER	J55	C3955563	09-27-02	100.1	99.9	99.9
SCHLUMBERGER	J55	C3955564	09-27-02	99.8	99.9	99.8
SCHLUMBERGER	J55	C3955565	09-27-02	100.1	100.3	100.2
SCHLUMBERGER	J55	C3955566	09-27-02	100.0	100.0	99.7
SCHLUMBERGER	J55	C3955567	09-27-02	99.9	100.3	100.4
SCHLUMBERGER	J55	C3955568	09-27-02	100.2	100.0	99.8
SCHLUMBERGER	J55	C3955569	09-27-02	99.9	100.2	99.8
SCHLUMBERGER	J55	C3955570	09-27-02	100.3	99.8	100.1
SCHLUMBERGER	J55	C3955571	09-27-02	100.2	100.1	100.2
SCHLUMBERGER	J55	C3955572	09-27-02	100.1	100.1	100.0
SCHLUMBERGER	J55	C3955573	09-27-02	100.1	100.1	99.8
SCHLUMBERGER	J55	C3955574	09-27-02	100.3	100.5	99.9
SCHLUMBERGER	J55	C3955575	09-27-02	100.0	100.0	99.9
SCHLUMBERGER	J55	C3955576	09-27-02	99.9	100.0	100.1
SCHLUMBERGER	J55	C3955577	09-27-02	100.0	100.3	99.9
SCHLUMBERGER	J55	C3955578	09-27-02	99.9	100.0	99.7
SCHLUMBERGER	J55	C3955579	09-27-02	100.0	100.1	99.9
SCHLUMBERGER	J55	C3955580	09-27-02	99.9	99.9	100.0
SCHLUMBERGER	J55	C395581	09-27-02	100.3	100.1	100.1
SCHLUMBERGER	J55	C395582	09-27-02	100.0	100.3	100.4
SCHLUMBERGER	J55	C395583	09-27-02	100.1	100.2	99.9
SCHLUMBERGER	J55	C395584	09-27-02	100.1	100.3	100.4
SCHLUMBERGER	J55	C395585	09-27-02	100.0	99.8	100.3
SCHLUMBERGER	J55	C395586	09-27-02	99.9	99.7	100.0
SCHLUMBERGER	J55	C395587	09-27-02	100.1	100.2	100.0
SCHLUMBERGER	J55	C395588	09-27-02	100.0	100.2	100.0
SCHLUMBERGER	J55	C395589	09-27-02	100.0	99.9	100.1
SCHLUMBERGER	J55	C395590	09-27-02	100.0	99.9	100.2
SCHLUMBERGER	J55	C395591	09-27-02	100.1	99.8	100.0
SCHLUMBERGER	J55	C395592	09-27-02	100.0	99.7	99.9
SCHLUMBERGER	J55	C395593	09-27-02	100.2	99.8	99.8
SCHLUMBERGER	J55	C395594	09-27-02	100.3	100.3	100.5
SCHLUMBERGER	J55	C395595	09-27-02	100.0	100.0	100.2

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

PAGE 212
 RUN DATE: 1/14/03
 RUN TIME: 13.26.53

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	J5S	C395596	09-27-02	100.0	99.7	100.2
SCHLUMBERGER	J5S	C395597	09-27-02	100.0	100.0	100.0
SCHLUMBERGER	J5S	C395598	09-27-02	100.1	100.1	99.9
SCHLUMBERGER	J5S	C395599	09-27-02	100.0	100.0	100.1
SCHLUMBERGER	J5S	C395600	09-27-02	100.1	99.8	100.2
SCHLUMBERGER	J5S	C395601	09-27-02	100.2	100.2	100.1
SCHLUMBERGER	J5S	C395602	09-27-02	100.2	100.0	99.8
SCHLUMBERGER	J5S	C395603	09-27-02	99.9	99.9	100.1
SCHLUMBERGER	J5S	C395604	09-27-02	100.1	100.3	100.3
SCHLUMBERGER	J5S	C395605	09-27-02	100.2	99.7	100.1
SCHLUMBERGER	J5S	C395606	09-27-02	100.0	99.8	100.2
SCHLUMBERGER	J5S	C395607	09-27-02	100.1	100.1	100.2
SCHLUMBERGER	J5S	C395608	09-27-02	99.9	100.0	100.2
SCHLUMBERGER	J5S	C395609	09-27-02	100.0	99.9	99.9
SCHLUMBERGER	J5S	C395610	09-27-02	99.9	100.1	100.0
SCHLUMBERGER	J5S	C395611	09-27-02	100.0	100.0	100.2
SCHLUMBERGER	J5S	C395612	09-27-02	99.9	99.8	99.5
SCHLUMBERGER	J5S	C395613	09-27-02	100.2	99.9	100.2
SCHLUMBERGER	J5S	C395614	09-27-02	100.2	100.2	99.8
SCHLUMBERGER	J5S	C395615	09-27-02	99.9	100.1	99.8
SCHLUMBERGER	J5S	C395616	09-27-02	99.9	99.7	99.6
SCHLUMBERGER	J5S	C395617	09-27-02	100.3	100.0	99.8
SCHLUMBERGER	J5S	C395618	09-27-02	100.1	100.4	100.0
SCHLUMBERGER	J5S	C395619	09-27-02	100.0	100.0	100.1
SCHLUMBERGER	J5S	C395620	09-27-02	100.3	99.7	100.4
SCHLUMBERGER	J5S	C395621	09-27-02	100.3	99.9	100.2
SCHLUMBERGER	J5S	C395622	09-27-02	100.2	100.1	100.1
SCHLUMBERGER	J5S	C395623	09-27-02	99.8	99.7	100.2
SCHLUMBERGER	J5S	C395624	09-27-02	100.3	99.6	99.9
SCHLUMBERGER	J5S	C395625	09-27-02	100.0	99.7	99.7
SCHLUMBERGER	J5S	C395626	09-27-02	100.2	99.7	100.0
SCHLUMBERGER	J5S	C395627	09-27-02	100.0	99.7	100.5
SCHLUMBERGER	J5S	C395628	09-27-02	100.3	100.0	99.8
SCHLUMBERGER	J5S	C395629	09-27-02	100.0	99.9	100.0
SCHLUMBERGER	J5S	C395630	09-27-02	100.0	100.0	99.9
SCHLUMBERGER	J5S	C395631	09-27-02	100.1	99.9	100.4
SCHLUMBERGER	J5S	C395632	09-27-02	100.1	100.0	100.4
SCHLUMBERGER	J5S	C395633	09-27-02	99.8	99.9	100.4
SCHLUMBERGER	J5S	C395634	09-27-02	100.0	99.8	100.0
SCHLUMBERGER	J5S	C395635	09-27-02	99.9	99.9	99.9
SCHLUMBERGER	J5S	C395636	09-27-02	100.0	99.8	100.1
SCHLUMBERGER	J5S	C395637	09-27-02	100.0	99.7	100.0
SCHLUMBERGER	J5S	C395638	09-27-02	99.9	99.7	100.0
SCHLUMBERGER	J5S	C395639	09-27-02	100.0	100.0	99.7
SCHLUMBERGER	J5S	C395640	09-27-02	100.1	99.7	99.5
SCHLUMBERGER	J5S	C395641	09-27-02	100.1	100.3	100.1
SCHLUMBERGER	J5S	C395642	09-27-02	99.9	99.9	99.9
SCHLUMBERGER	J5S	C395643	09-27-02	99.8	100.0	99.4
SCHLUMBERGER	J5S	C395644	09-27-02	100.0	99.8	100.2
SCHLUMBERGER	J5S	C395645	09-27-02	99.9	99.8	99.8
SCHLUMBERGER	J5S	C395646	09-27-02	100.2	100.0	100.0

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

PAGE 213
 RUN DATE: 1/14/03
 RUN TIME: 13.26.53

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	J55	C395647	09-27-02	100.0	99.9	99.9
SCHLUMBERGER	J55	C395648	09-27-02	100.1	100.0	100.2
SCHLUMBERGER	J55	C395649	09-27-02	100.1	99.9	99.7
SCHLUMBERGER	J55	C395650	09-27-02	99.8	99.9	99.8
SCHLUMBERGER	J55	C395651	09-27-02	100.3	100.2	100.1
SCHLUMBERGER	J55	C395652	09-27-02	100.0	99.8	100.5
SCHLUMBERGER	J55	C395653	09-27-02	100.2	100.0	100.1
SCHLUMBERGER	J55	C395654	09-27-02	100.3	100.0	100.3
SCHLUMBERGER	J55	C395655	09-27-02	99.9	99.9	100.1
SCHLUMBERGER	J55	C395656	09-27-02	99.9	99.7	99.9
SCHLUMBERGER	J55	C395657	09-27-02	99.9	100.1	100.2
SCHLUMBERGER	J55	C395658	09-27-02	100.1	100.0	100.0
SCHLUMBERGER	J55	C395659	09-27-02	100.2	100.0	99.9
SCHLUMBERGER	J55	C395660	09-27-02	100.2	100.4	100.0
SCHLUMBERGER	J55	C395661	09-27-02	100.2	99.6	100.0
SCHLUMBERGER	J55	C395662	09-27-02	100.0	99.9	100.4
SCHLUMBERGER	J55	C395663	09-27-02	100.1	99.7	99.7
SCHLUMBERGER	J55	C395664	09-27-02	100.1	100.0	100.1
SCHLUMBERGER	J55	C395665	09-27-02	100.1	100.3	100.2
SCHLUMBERGER	J55	C395666	09-27-02	100.1	100.1	100.3
SCHLUMBERGER	J55	C395667	09-27-02	99.9	99.8	99.8
SCHLUMBERGER	J55	C395668	09-27-02	100.2	100.0	100.0
SCHLUMBERGER	J55	C395669	09-27-02	99.9	99.8	100.0
SCHLUMBERGER	J55	C395670	09-27-02	100.1	100.2	100.2
SCHLUMBERGER	J55	C395671	09-27-02	100.0	99.8	99.9
SCHLUMBERGER	J55	C395672	09-27-02	100.0	100.2	100.2
SCHLUMBERGER	J55	C395673	09-27-02	100.0	100.1	99.8
SCHLUMBERGER	J55	C395674	09-27-02	100.0	99.8	100.4
SCHLUMBERGER	J55	C395675	09-27-02	100.2	99.8	99.8
SCHLUMBERGER	J55	C395676	09-27-02	100.2	100.0	100.5
SCHLUMBERGER	J55	C395677	09-27-02	100.0	100.1	100.3
SCHLUMBERGER	J55	C395678	09-27-02	100.1	99.8	100.2
SCHLUMBERGER	J55	C395679	09-27-02	100.0	99.9	100.2
SCHLUMBERGER	J55	C395680	09-27-02	100.0	99.8	100.1
SCHLUMBERGER	J55	C395681	09-27-02	99.9	99.8	100.1
SCHLUMBERGER	J55	C395682	09-27-02	100.0	100.0	100.1
SCHLUMBERGER	J55	C395683	09-27-02	99.9	99.8	100.0
SCHLUMBERGER	J55	C395684	09-27-02	100.1	99.9	99.9
SCHLUMBERGER	J55	C395685	09-27-02	100.1	99.6	99.9
SCHLUMBERGER	J55	C395686	09-27-02	100.0	100.0	100.1
SCHLUMBERGER	J55	C395687	09-27-02	100.1	99.9	100.2
SCHLUMBERGER	J55	C395688	09-27-02	100.0	99.7	100.0
SCHLUMBERGER	J55	C395689	09-27-02	100.0	99.7	99.8
SCHLUMBERGER	J55	C395690	09-27-02	99.9	99.7	99.7
SCHLUMBERGER	J55	C395691	09-27-02	99.9	99.8	99.8
SCHLUMBERGER	J55	C395692	09-27-02	100.3	99.8	100.0
SCHLUMBERGER	J55	C395693	09-27-02	100.1	100.0	100.2
SCHLUMBERGER	J55	C395694	09-27-02	99.9	99.9	100.2
SCHLUMBERGER	J55	C395695	09-27-02	100.0	99.8	100.1
SCHLUMBERGER	J55	C395696	09-27-02	100.0	99.9	99.9
SCHLUMBERGER	J55	C395697	09-27-02	100.0	99.8	99.4

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	J55	C395698	09-27-02	100.0	100.2	99.8
SCHLUMBERGER	J55	C395699	09-27-02	99.9	99.6	99.7
SCHLUMBERGER	J55	C395700	09-27-02	99.9	100.2	99.9
SCHLUMBERGER	J55	C395701	09-27-02	100.0	100.0	99.7
SCHLUMBERGER	J55	C395702	09-27-02	100.0	99.8	99.7
SCHLUMBERGER	J55	C395703	09-27-02	100.1	100.1	99.9
SCHLUMBERGER	J55	C395704	09-27-02	99.9	99.7	100.2
SCHLUMBERGER	J55	C395705	09-27-02	100.3	100.0	99.9
SCHLUMBERGER	J55	C395706	09-27-02	100.1	99.8	99.9
SCHLUMBERGER	J55	C395707	09-27-02	100.0	99.8	99.7
SCHLUMBERGER	J55	C395708	09-27-02	100.1	99.9	100.0
SCHLUMBERGER	J55	C395709	09-27-02	99.9	99.9	99.6
SCHLUMBERGER	J55	C395710	09-27-02	100.0	99.7	100.1
SCHLUMBERGER	J55	C395711	09-27-02	100.3	100.2	100.3
SCHLUMBERGER	J55	C395712	09-27-02	100.3	99.8	100.2
SCHLUMBERGER	J55	C395713	09-27-02	100.2	99.7	100.2
SCHLUMBERGER	J55	C395714	09-27-02	99.9	99.9	99.9
SCHLUMBERGER	J55	C395715	09-27-02	99.9	99.8	99.7
SCHLUMBERGER	J55	C395716	09-27-02	100.0	99.8	100.2
SCHLUMBERGER	J55	C395717	09-27-02	100.0	99.7	99.9
SCHLUMBERGER	J55	C395718	09-27-02	100.1	100.0	99.9
SCHLUMBERGER	J55	C395719	09-27-02	99.9	99.8	99.9
SCHLUMBERGER	J55	C395720	09-27-02	99.9	100.1	99.8
SCHLUMBERGER	J55	C395721	09-27-02	100.0	99.7	99.8
SCHLUMBERGER	J55	C395722	09-27-02	100.0	99.7	100.3
SCHLUMBERGER	J55	C395723	09-27-02	100.0	99.8	99.8
SCHLUMBERGER	J55	C395724	09-27-02	99.9	99.7	100.0
SCHLUMBERGER	J55	C395725	09-27-02	100.2	99.8	99.9
SCHLUMBERGER	J55	C395726	09-27-02	99.9	99.6	100.0
SCHLUMBERGER	J55	C395727	09-27-02	100.2	99.6	99.9
SCHLUMBERGER	J55	C395728	09-27-02	100.1	99.7	100.2
SCHLUMBERGER	J55	C395729	09-27-02	99.9	99.9	99.8
SCHLUMBERGER	J55	C395730	09-27-02	100.3	99.7	100.2
SCHLUMBERGER	J55	C395731	09-27-02	99.9	99.9	99.8
SCHLUMBERGER	J55	C395732	09-27-02	99.8	100.1	99.7
SCHLUMBERGER	J55	C395733	09-27-02	99.9	100.0	100.2
SCHLUMBERGER	J55	C395734	09-27-02	100.1	100.0	99.9
SCHLUMBERGER	J55	C395735	09-27-02	100.0	99.7	100.3
SCHLUMBERGER	J55	C395736	09-27-02	100.2	99.8	100.0
SCHLUMBERGER	J55	C395737	09-27-02	100.1	99.9	99.9
SCHLUMBERGER	J55	C395738	09-27-02	100.1	100.1	99.9
SCHLUMBERGER	J55	C395739	09-27-02	100.0	99.7	99.8
SCHLUMBERGER	J55	C395740	09-27-02	100.0	99.7	100.0
SCHLUMBERGER	J55	C395741	09-27-02	100.2	99.7	99.8
SCHLUMBERGER	J55	C395742	09-27-02	100.1	99.7	99.9
SCHLUMBERGER	J55	C395743	09-27-02	100.1	99.9	99.7
SCHLUMBERGER	J55	C395744	09-27-02	99.9	99.9	100.1
SCHLUMBERGER	J55	C395745	09-27-02	99.9	99.9	100.2
SCHLUMBERGER	J55	C395746	09-27-02	100.1	99.9	99.8
SCHLUMBERGER	J55	C395747	09-27-02	99.9	99.8	100.3
SCHLUMBERGER	J55	C395748	09-27-02	100.1	99.8	99.9

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

PAGE 215
 RUN DATE: 1/14/03
 RUN TIME: 13.26.53

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	J55	C395749	09-27-02	100.1	99.8	100.5
SCHLUMBERGER	J55	C395750	09-27-02	100.0	100.0	100.0
SCHLUMBERGER	J55	C395751	09-27-02	100.1	99.9	100.0
SCHLUMBERGER	J55	C395752	09-27-02	100.0	99.9	100.0
SCHLUMBERGER	J55	C395753	09-27-02	100.0	99.8	100.1
SCHLUMBERGER	J55	C395754	09-27-02	100.0	99.7	100.4
SCHLUMBERGER	J55	C395755	09-27-02	100.0	99.7	100.4
SCHLUMBERGER	J55	C395756	09-27-02	100.0	99.7	99.8
SCHLUMBERGER	J55	C395757	09-27-02	100.3	100.0	99.9
SCHLUMBERGER	J55	C395758	09-27-02	100.1	99.7	99.9
SCHLUMBERGER	J55	C395759	09-27-02	100.1	99.8	100.2
SCHLUMBERGER	J55	C395760	09-27-02	99.9	100.2	99.9
SCHLUMBERGER	J55	C395761	09-27-02	100.0	99.8	99.6
SCHLUMBERGER	J55	C395762	09-27-02	99.8	99.8	99.8
SCHLUMBERGER	J55	C395763	09-27-02	99.8	100.0	99.7
SCHLUMBERGER	J55	C395764	09-27-02	100.0	100.0	99.9
SCHLUMBERGER	J55	C395765	09-27-02	100.0	100.0	100.1
SCHLUMBERGER	J55	C395766	09-27-02	100.0	100.0	99.8
SCHLUMBERGER	J55	C395767	09-27-02	100.0	100.0	99.7
SCHLUMBERGER	J55	C395768	09-27-02	100.1	100.2	99.8
SCHLUMBERGER	J55	C395769	09-27-02	100.1	99.9	99.9
SCHLUMBERGER	J55	C395770	09-27-02	100.0	100.0	100.0
SCHLUMBERGER	J55	C395771	09-27-02	99.9	100.2	100.0
SCHLUMBERGER	J55	C395772	09-27-02	100.1	99.7	100.1
SCHLUMBERGER	J55	C395773	09-27-02	100.1	100.0	99.9
SCHLUMBERGER	J55	C395774	09-27-02	100.0	100.3	100.0
SCHLUMBERGER	J55	C395775	09-27-02	99.8	99.7	99.9
SCHLUMBERGER	J55	C395776	09-27-02	100.0	100.0	99.9
SCHLUMBERGER	J55	C395777	09-27-02	100.2	100.2	100.2
SCHLUMBERGER	J55	C395778	09-27-02	100.1	99.9	100.0
SCHLUMBERGER	J55	C395779	09-27-02	99.9	99.6	99.8
SCHLUMBERGER	J55	C395780	09-27-02	100.0	99.8	100.7
SCHLUMBERGER	J55	C395781	09-27-02	99.9	99.9	100.0
SCHLUMBERGER	J55	C395782	09-27-02	100.0	99.7	100.1
SCHLUMBERGER	J55	C395783	09-27-02	99.9	99.9	99.5
SCHLUMBERGER	J55	C395784	09-27-02	100.1	99.7	100.2
SCHLUMBERGER	J55	C395785	09-27-02	100.0	99.9	99.9
SCHLUMBERGER	J55	C395786	09-27-02	100.0	99.7	100.3
SCHLUMBERGER	J55	C395787	09-27-02	100.0	99.7	100.6
SCHLUMBERGER	J55	C395788	09-27-02	100.2	99.9	100.1
SCHLUMBERGER	J55	C395789	09-26-02	100.0	99.9	100.2
SCHLUMBERGER	J55	C395790	09-26-02	100.0	99.7	99.9
SCHLUMBERGER	J55	C395791	09-26-02	100.0	99.7	99.8
SCHLUMBERGER	J55	C395792	09-26-02	100.1	100.2	99.6
SCHLUMBERGER	J55	C395793	09-26-02	100.0	99.9	100.4
SCHLUMBERGER	J55	C395794	09-26-02	99.8	100.1	99.4
SCHLUMBERGER	J55	C395795	09-26-02	100.1	100.0	100.1
SCHLUMBERGER	J55	C395796	09-26-02	100.1	100.2	100.2
SCHLUMBERGER	J55	C395797	09-26-02	100.0	99.7	99.8
SCHLUMBERGER	J55	C395798	09-26-02	100.0	99.9	99.9
SCHLUMBERGER	J55	C395799	09-26-02	100.1	99.8	100.3

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

PAGE 216
 RUN DATE: 1/14/03
 RUN TIME: 13.26.53

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	J55	C395800	09-26-02	100.1	99.9	99.9
SCHLUMBERGER	J55	C395801	09-26-02	100.2	99.7	99.6
SCHLUMBERGER	J55	C395802	09-26-02	100.0	100.0	100.0
SCHLUMBERGER	J55	C395803	09-26-02	100.0	99.7	100.0
SCHLUMBERGER	J55	C395804	09-26-02	100.1	99.9	100.0
SCHLUMBERGER	J55	C395805	09-26-02	99.9	100.2	99.7
SCHLUMBERGER	J55	C395806	09-26-02	100.0	99.9	99.6
SCHLUMBERGER	J55	C395807	09-26-02	100.3	99.6	99.7
SCHLUMBERGER	J55	C395808	09-26-02	100.0	99.8	100.1
SCHLUMBERGER	J55	C395809	09-26-02	100.1	99.2	100.1
SCHLUMBERGER	J55	C395810	09-26-02	100.0	99.8	100.1
SCHLUMBERGER	J55	C395811	09-26-02	100.1	99.9	99.9
SCHLUMBERGER	J55	C395812	09-27-02	100.0	99.9	100.3
SCHLUMBERGER	J55	C395813	09-26-02	100.1	99.7	99.2
SCHLUMBERGER	J55	C395814	09-26-02	100.1	99.7	99.8
SCHLUMBERGER	J55	C395815	09-26-02	99.9	99.6	99.7
SCHLUMBERGER	J55	C395816	09-26-02	100.1	99.3	99.3
SCHLUMBERGER	J55	C395817	09-26-02	100.1	100.1	100.3
SCHLUMBERGER	J55	C395818	09-26-02	100.2	100.2	100.2
SCHLUMBERGER	J55	C395819	09-26-02	100.2	100.1	100.0
SCHLUMBERGER	J55	C395820	09-26-02	99.9	99.8	99.8
SCHLUMBERGER	J55	C395821	09-26-02	100.1	99.8	100.0
SCHLUMBERGER	J55	C395822	09-26-02	99.8	99.8	99.6
SCHLUMBERGER	J55	C395823	09-26-02	100.0	99.9	100.0
SCHLUMBERGER	J55	C395824	09-26-02	100.1	99.7	99.7
SCHLUMBERGER	J55	C395825	09-26-02	99.9	99.9	99.8
SCHLUMBERGER	J55	C395826	09-26-02	100.0	99.9	100.2
SCHLUMBERGER	J55	C395827	09-26-02	100.0	100.0	100.4
SCHLUMBERGER	J55	C395828	09-26-02	100.0	99.8	100.7
SCHLUMBERGER	J55	C395829	09-26-02	100.1	100.1	99.8
SCHLUMBERGER	J55	C395830	09-26-02	100.1	100.3	100.4
SCHLUMBERGER	J55	C395831	09-26-02	99.9	99.8	99.8
SCHLUMBERGER	J55	C395832	09-26-02	100.0	99.9	99.6
SCHLUMBERGER	J55	C395833	09-26-02	99.9	99.7	99.6
SCHLUMBERGER	J55	C395834	09-26-02	100.0	99.9	100.0
SCHLUMBERGER	J55	C395835	09-26-02	100.1	100.2	100.0
SCHLUMBERGER	J55	C395836	09-26-02	100.1	99.8	100.2
SCHLUMBERGER	J55	C395837	09-26-02	100.3	100.1	100.6
SCHLUMBERGER	J55	C395838	09-26-02	100.1	99.7	100.0
SCHLUMBERGER	J55	C395839	09-26-02	100.1	99.8	100.0
SCHLUMBERGER	J55	C395840	09-26-02	99.9	99.6	100.2
SCHLUMBERGER	J55	C395841	09-26-02	100.1	100.3	99.7
SCHLUMBERGER	J55	C395842	09-26-02	100.0	100.1	100.1
SCHLUMBERGER	J55	C395843	09-26-02	100.1	100.4	100.1
SCHLUMBERGER	J55	C395844	09-26-02	100.0	99.7	100.0
SCHLUMBERGER	J55	C395845	09-26-02	100.0	99.7	100.5
SCHLUMBERGER	J55	C395846	09-26-02	100.1	99.8	100.0
SCHLUMBERGER	J55	C395847	09-26-02	100.1	99.9	99.9
SCHLUMBERGER	J55	C395848	09-26-02	100.0	99.9	99.7
SCHLUMBERGER	J55	C395849	09-26-02	100.2	99.9	99.9
SCHLUMBERGER	J55	C395850	09-26-02	100.0	99.8	99.9

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	J55	C395851	09-26-02	99.8	99.7	99.9
SCHLUMBERGER	J55	C395852	09-26-02	100.1	100.2	100.2
SCHLUMBERGER	J55	C395853	09-26-02	99.9	99.8	99.7
SCHLUMBERGER	J55	C395854	09-26-02	100.2	99.7	100.0
SCHLUMBERGER	J55	C395855	09-26-02	100.0	99.9	99.8
SCHLUMBERGER	J55	C395856	09-26-02	99.8	99.7	99.7
SCHLUMBERGER	J55	C395857	09-26-02	100.1	99.7	99.6
SCHLUMBERGER	J55	C395858	09-26-02	99.8	99.7	99.5
SCHLUMBERGER	J55	C395859	09-26-02	100.0	100.1	99.5
SCHLUMBERGER	J55	C395860	09-26-02	100.0	99.8	100.3
SCHLUMBERGER	J55	C395861	09-26-02	100.0	99.8	99.9
SCHLUMBERGER	J55	C395862	09-26-02	99.9	99.8	100.1
SCHLUMBERGER	J55	C395863	09-26-02	100.0	99.8	100.1
SCHLUMBERGER	J55	C395864	09-26-02	100.0	99.8	100.0
SCHLUMBERGER	J55	C395865	09-26-02	100.0	99.8	100.2
SCHLUMBERGER	J55	C395866	09-26-02	100.0	99.7	99.8
SCHLUMBERGER	J55	C395867	09-26-02	100.0	99.7	99.5
SCHLUMBERGER	J55	C395868	09-26-02	100.0	99.9	99.5
SCHLUMBERGER	J55	C395869	09-26-02	100.0	99.7	100.1
SCHLUMBERGER	J55	C395870	09-26-02	100.0	99.9	100.0
SCHLUMBERGER	J55	C395871	09-26-02	99.9	99.7	99.9
SCHLUMBERGER	J55	C395872	09-26-02	100.0	99.7	99.5
SCHLUMBERGER	J55	C395873	09-26-02	100.1	100.0	100.1
SCHLUMBERGER	J55	C395874	09-26-02	100.1	99.6	100.0
SCHLUMBERGER	J55	C395875	09-26-02	100.1	99.7	100.0
SCHLUMBERGER	J55	C395876	09-26-02	100.0	99.9	99.7
SCHLUMBERGER	J55	C395877	09-26-02	100.0	99.6	100.3
SCHLUMBERGER	J55	C395878	09-26-02	100.0	99.9	99.9
SCHLUMBERGER	J55	C395879	09-26-02	100.1	99.9	99.9
SCHLUMBERGER	J55	C395880	09-26-02	99.9	99.7	99.9
SCHLUMBERGER	J55	C395881	09-26-02	100.1	100.0	99.9
SCHLUMBERGER	J55	C395882	09-26-02	100.1	100.0	99.8
SCHLUMBERGER	J55	C395883	09-26-02	100.0	99.8	99.7
SCHLUMBERGER	J55	C395884	09-26-02	100.2	99.9	99.7
SCHLUMBERGER	J55	C395885	09-26-02	100.1	100.0	100.0
SCHLUMBERGER	J55	C395886	09-26-02	100.1	99.7	99.9
SCHLUMBERGER	J55	C395887	09-26-02	99.9	99.9	100.0
SCHLUMBERGER	J55	C395888	09-26-02	100.2	99.8	100.1
SCHLUMBERGER	J55	C395889	09-26-02	100.0	99.9	99.9
SCHLUMBERGER	J55	C395890	09-26-02	100.2	99.8	100.0
SCHLUMBERGER	J55	C395891	09-26-02	100.1	99.7	100.2
SCHLUMBERGER	J55	C395892	09-26-02	100.0	99.8	100.0
SCHLUMBERGER	J55	C395893	09-26-02	100.1	99.9	100.0
SCHLUMBERGER	J55	C395894	09-26-02	100.1	99.6	100.0
SCHLUMBERGER	J55	C395895	09-26-02	100.1	100.1	100.1
SCHLUMBERGER	J55	C395896	09-26-02	100.0	99.7	99.7
SCHLUMBERGER	J55	C395897	09-26-02	100.0	99.8	99.9
SCHLUMBERGER	J55	C395898	09-26-02	100.0	99.8	99.9
SCHLUMBERGER	J55	C395899	09-26-02	100.0	99.8	100.0
SCHLUMBERGER	J55	C395900	09-26-02	99.9	99.8	99.6
SCHLUMBERGER	J55	C395901	09-26-02	100.0	99.7	99.5

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

PAGE 218
 RUN DATE: 1/14/03
 RUN TIME: 13.26.53

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	J5S	C395902	09-26-02	100.0	99.9	100.0
SCHLUMBERGER	J5S	C395903	09-26-02	100.0	99.7	99.7
SCHLUMBERGER	J5S	C395904	09-26-02	100.0	100.5	100.0
SCHLUMBERGER	J5S	C395905	09-26-02	100.0	99.7	99.8
SCHLUMBERGER	J5S	C395906	09-26-02	100.0	99.6	99.7
SCHLUMBERGER	J5S	C395907	09-26-02	100.1	100.3	100.2
SCHLUMBERGER	J5S	C395908	09-26-02	99.9	100.3	99.9
SCHLUMBERGER	J5S	C395909	09-26-02	100.1	99.7	100.0
SCHLUMBERGER	J5S	C395910	09-26-02	100.2	99.9	99.6
SCHLUMBERGER	J5S	C395911	09-26-02	100.0	99.9	100.2
SCHLUMBERGER	J5S	C395912	09-26-02	100.0	99.9	99.4
SCHLUMBERGER	J5S	C395913	09-26-02	100.0	99.9	99.7
SCHLUMBERGER	J5S	C395914	09-26-02	100.0	99.9	99.8
SCHLUMBERGER	J5S	C395915	09-26-02	100.0	99.7	100.1
SCHLUMBERGER	J5S	C395916	09-26-02	99.7	100.3	99.7
SCHLUMBERGER	J5S	C395917	09-26-02	100.1	99.9	100.0
SCHLUMBERGER	J5S	C395918	09-26-02	100.2	99.8	100.0
SCHLUMBERGER	J5S	C395919	09-26-02	100.0	99.8	99.9
SCHLUMBERGER	J5S	C395920	09-26-02	100.1	100.4	100.2
SCHLUMBERGER	J5S	C395921	09-26-02	100.1	99.9	100.1
SCHLUMBERGER	J5S	C395922	09-26-02	100.1	100.3	100.1
SCHLUMBERGER	J5S	C395923	09-26-02	100.1	99.8	99.9
SCHLUMBERGER	J5S	C395924	09-26-02	100.1	100.5	99.9
SCHLUMBERGER	J5S	C395925	09-26-02	100.1	99.6	100.3
SCHLUMBERGER	J5S	C395926	09-26-02	100.1	99.8	100.3
SCHLUMBERGER	J5S	C395927	09-26-02	100.0	99.7	99.9
SCHLUMBERGER	J5S	C395928	09-26-02	100.0	99.7	99.6
SCHLUMBERGER	J5S	C395929	09-26-02	100.1	100.3	100.0
SCHLUMBERGER	J5S	C395930	09-26-02	99.9	100.2	99.7
SCHLUMBERGER	J5S	C395931	09-26-02	100.1	99.8	100.3
SCHLUMBERGER	J5S	C395932	09-26-02	100.0	99.8	99.7
SCHLUMBERGER	J5S	C395933	09-26-02	100.1	99.9	100.1
SCHLUMBERGER	J5S	C395934	09-26-02	100.2	99.9	99.7
SCHLUMBERGER	J5S	C395935	09-26-02	100.1	99.6	100.0
SCHLUMBERGER	J5S	C395936	09-27-02	99.9	99.7	99.7
SCHLUMBERGER	J5S	C395937	09-26-02	99.9	100.3	100.3
SCHLUMBERGER	J5S	C395938	09-26-02	99.9	99.9	99.9
SCHLUMBERGER	J5S	C395939	09-26-02	100.1	99.7	99.8
SCHLUMBERGER	J5S	C395940	09-26-02	100.0	100.0	100.0
SCHLUMBERGER	J5S	C395941	09-26-02	100.2	99.7	99.8
SCHLUMBERGER	J5S	C395942	09-26-02	100.1	99.9	100.0
SCHLUMBERGER	J5S	C395943	09-26-02	100.2	100.0	100.1
SCHLUMBERGER	J5S	C395944	09-26-02	100.0	99.9	99.6
SCHLUMBERGER	J5S	C395945	09-26-02	100.0	99.9	100.2
SCHLUMBERGER	J5S	C395946	09-26-02	100.1	99.7	100.0
SCHLUMBERGER	J5S	C395947	09-26-02	100.1	99.9	99.8
SCHLUMBERGER	J5S	C395948	09-26-02	100.0	99.6	99.7
SCHLUMBERGER	J5S	C395949	09-26-02	100.0	99.6	99.9
SCHLUMBERGER	J5S	C395950	09-26-02	100.0	100.3	100.2
SCHLUMBERGER	J5S	C395951	09-26-02	100.0	99.9	99.9
SCHLUMBERGER	J5S	C395952	09-26-02	100.1	99.8	100.0

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	J55	C395953	09-26-02	100.0	99.8	99.5
SCHLUMBERGER	J55	C395954	09-26-02	100.0	100.2	100.0
SCHLUMBERGER	J55	C395955	09-26-02	100.0	100.2	100.3
SCHLUMBERGER	J55	C395956	09-26-02	100.1	100.0	100.3
SCHLUMBERGER	J55	C395957	09-26-02	99.9	99.8	99.8
SCHLUMBERGER	J55	C395958	09-26-02	100.1	100.0	100.1
SCHLUMBERGER	J55	C395959	09-26-02	100.1	100.4	99.7
SCHLUMBERGER	J55	C395960	09-26-02	99.9	99.7	99.7
SCHLUMBERGER	J55	C395961	09-26-02	100.0	99.7	100.3
SCHLUMBERGER	J55	C395962	09-26-02	100.1	100.1	100.0
SCHLUMBERGER	J55	C395963	09-26-02	100.1	99.7	100.0
SCHLUMBERGER	J55	C395964	09-26-02	100.0	99.8	100.2
SCHLUMBERGER	J55	C395965	09-26-02	100.1	99.8	100.2
SCHLUMBERGER	J55	C395966	09-26-02	100.0	100.0	100.2
SCHLUMBERGER	J55	C395967	09-26-02	100.0	99.7	99.6
SCHLUMBERGER	J55	C395968	09-26-02	100.0	99.8	99.7
SCHLUMBERGER	J55	C395969	09-26-02	100.2	100.1	100.1
SCHLUMBERGER	J55	C395970	09-26-02	100.1	100.0	99.8
SCHLUMBERGER	J55	C395971	09-26-02	100.2	99.7	100.3
SCHLUMBERGER	J55	C395972	09-26-02	100.1	99.7	100.2
SCHLUMBERGER	J55	C395973	09-26-02	100.1	99.7	100.0
SCHLUMBERGER	J55	C395974	09-26-02	100.1	99.8	99.7
SCHLUMBERGER	J55	C395975	09-26-02	100.1	99.7	100.1
SCHLUMBERGER	J55	C395976	09-26-02	99.9	100.2	99.4
SCHLUMBERGER	J55	C395977	09-26-02	99.9	99.8	99.9
SCHLUMBERGER	J55	C395978	09-26-02	100.1	99.9	100.1
SCHLUMBERGER	J55	C395979	09-26-02	100.1	99.7	100.2
SCHLUMBERGER	J55	C395980	09-26-02	100.0	100.3	99.7
SCHLUMBERGER	J55	C395981	09-26-02	100.0	100.4	100.0
SCHLUMBERGER	J55	C395982	09-26-02	99.8	100.3	99.7
SCHLUMBERGER	J55	C395983	09-26-02	100.1	100.0	99.8
SCHLUMBERGER	J55	C395984	09-26-02	100.1	100.3	99.8
SCHLUMBERGER	J55	C395985	09-26-02	100.1	100.0	99.8
SCHLUMBERGER	J55	C395986	09-26-02	100.2	99.8	99.8
SCHLUMBERGER	J55	C395987	09-26-02	100.0	99.6	99.8
SCHLUMBERGER	J55	C395988	09-26-02	100.3	99.4	100.1
SCHLUMBERGER	J55	C395989	09-26-02	99.9	99.8	99.5
SCHLUMBERGER	J55	C395990	09-26-02	100.0	99.7	100.0
SCHLUMBERGER	J55	C395991	09-26-02	100.1	99.8	100.0
SCHLUMBERGER	J55	C395992	09-26-02	100.2	99.8	99.8
SCHLUMBERGER	J55	C395993	09-26-02	100.1	99.8	99.8
SCHLUMBERGER	J55	C395994	09-26-02	100.2	99.8	99.9
SCHLUMBERGER	J55	C395995	09-26-02	100.3	99.9	100.0
SCHLUMBERGER	J55	C395996	09-26-02	100.1	99.6	99.8
SCHLUMBERGER	J55	C395997	09-26-02	100.0	99.8	99.8
SCHLUMBERGER	J55	C395998	09-26-02	100.0	100.3	100.0
SCHLUMBERGER	J55	C395999	09-26-02	100.3	99.6	100.1
SCHLUMBERGER	J55	C396000	09-26-02	100.1	100.1	100.2
SCHLUMBERGER	J55	C396001	09-26-02	100.1	99.8	100.1
SCHLUMBERGER	J55	C396002	09-26-02	100.0	99.6	99.7
SCHLUMBERGER	J55	C396003	09-26-02	100.2	99.9	99.9

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	J55	C396004	09-26-02	99.9	99.9	99.7
SCHLUMBERGER	J55	C396005	09-26-02	100.0	99.8	100.1
SCHLUMBERGER	J55	C396006	09-26-02	100.0	99.7	99.8
SCHLUMBERGER	J55	C396007	09-26-02	100.0	99.9	99.9
SCHLUMBERGER	J55	C396008	09-26-02	100.1	100.2	100.1
SCHLUMBERGER	J55	C396009	09-26-02	100.0	99.7	99.9
SCHLUMBERGER	J55	C396010	09-26-02	100.1	99.8	99.8
SCHLUMBERGER	J55	C396011	09-26-02	100.2	100.0	99.9
SCHLUMBERGER	J55	C396012	09-26-02	100.0	100.4	100.1
SCHLUMBERGER	J55	C396013	09-26-02	100.0	99.9	99.9
SCHLUMBERGER	J55	C396014	09-26-02	100.1	99.9	100.0
SCHLUMBERGER	J55	C396015	09-26-02	100.1	100.0	100.0
SCHLUMBERGER	J55	C396016	09-26-02	100.0	99.8	100.1
SCHLUMBERGER	J55	C396017	09-26-02	100.3	100.0	100.0
SCHLUMBERGER	J55	C396018	09-26-02	100.1	100.3	100.5
SCHLUMBERGER	J55	C396019	09-26-02	100.1	99.9	99.9
SCHLUMBERGER	J55	C396020	09-26-02	100.2	99.8	99.8
SCHLUMBERGER	J55	C396021	09-26-02	99.8	99.7	99.6
SCHLUMBERGER	J55	C396022	09-26-02	100.0	99.8	99.4
SCHLUMBERGER	J55	C396023	09-26-02	100.1	99.7	99.4
SCHLUMBERGER	J55	C396024	09-26-02	99.8	99.7	99.4
SCHLUMBERGER	J55	C396025	09-26-02	100.1	99.7	99.7
SCHLUMBERGER	J55	C396026	09-26-02	99.9	100.5	99.8
SCHLUMBERGER	J55	C396027	09-26-02	100.3	99.6	100.1
SCHLUMBERGER	J55	C396028	09-26-02	99.9	99.6	99.7
SCHLUMBERGER	J55	C396029	09-26-02	99.8	99.6	99.6
SCHLUMBERGER	J55	C396030	09-26-02	100.0	99.8	99.4
SCHLUMBERGER	J55	C396031	09-26-02	100.0	99.6	99.8
SCHLUMBERGER	J55	C396032	09-26-02	100.1	99.9	99.7
SCHLUMBERGER	J55	C396033	09-26-02	100.1	99.9	100.0
SCHLUMBERGER	J55	C396034	09-26-02	100.3	100.5	100.1
SCHLUMBERGER	J55	C396035	09-26-02	100.1	99.8	100.2
SCHLUMBERGER	J55	C396036	09-26-02	100.2	99.7	100.2
SCHLUMBERGER	J55	C396037	09-26-02	100.2	99.7	99.9
SCHLUMBERGER	J55	C396038	09-26-02	100.1	99.9	99.9
SCHLUMBERGER	J55	C396039	09-26-02	100.0	99.7	100.1
SCHLUMBERGER	J55	C396040	09-26-02	100.0	99.7	99.5
SCHLUMBERGER	J55	C396041	09-26-02	100.0	100.0	100.0
SCHLUMBERGER	J55	C396042	09-26-02	100.1	99.6	99.8
SCHLUMBERGER	J55	C396043	09-26-02	100.1	99.8	100.0
SCHLUMBERGER	J55	C396044	09-26-02	100.1	99.7	100.0
SCHLUMBERGER	J55	C396045	09-26-02	100.0	99.7	100.0
SCHLUMBERGER	J55	C396046	09-26-02	99.9	99.7	99.4
SCHLUMBERGER	J55	C396047	09-26-02	100.2	100.1	99.5
SCHLUMBERGER	J55	C396048	09-26-02	100.0	100.2	100.2
SCHLUMBERGER	J55	C396049	09-26-02	100.0	100.2	99.8
SCHLUMBERGER	J55	C396050	09-26-02	100.1	99.9	99.9
SCHLUMBERGER	J55	C396051	09-26-02	100.2	100.2	99.8
SCHLUMBERGER	J55	C396052	09-26-02	100.1	100.1	100.0
SCHLUMBERGER	J55	C396053	09-26-02	99.9	99.8	99.7
SCHLUMBERGER	J55	C396054	09-26-02	100.0	100.2	99.8

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	J55	C396055	09-26-02	100.1	100.2	100.4
SCHLUMBERGER	J55	C396056	09-26-02	100.2	99.8	99.6
SCHLUMBERGER	J55	C396057	09-26-02	100.1	99.7	99.0
SCHLUMBERGER	J55	C396058	09-26-02	100.2	100.0	100.0
SCHLUMBERGER	J55	C396059	09-26-02	100.1	100.3	99.8
SCHLUMBERGER	J55	C396060	09-26-02	100.0	100.4	100.2
SCHLUMBERGER	J55	C396061	09-26-02	100.0	100.3	99.7
SCHLUMBERGER	J55	C396062	09-26-02	100.1	100.0	99.8
SCHLUMBERGER	J55	C396063	09-26-02	100.2	100.3	100.2
SCHLUMBERGER	J55	C396064	09-26-02	100.0	99.9	99.7
SCHLUMBERGER	J55	C396065	09-26-02	100.1	100.3	99.4
SCHLUMBERGER	J55	C396066	09-26-02	100.0	100.0	100.0
SCHLUMBERGER	J55	C396067	09-26-02	100.3	100.1	99.5
SCHLUMBERGER	J55	C396068	09-26-02	100.2	100.1	99.7
SCHLUMBERGER	J55	C396069	09-26-02	100.1	100.0	99.9
SCHLUMBERGER	J55	C396070	09-26-02	99.9	99.6	99.9
SCHLUMBERGER	J55	C396071	09-26-02	100.1	99.8	100.0
SCHLUMBERGER	J55	C396072	09-26-02	100.1	99.7	99.8
SCHLUMBERGER	J55	C396073	09-26-02	100.1	99.8	100.1
SCHLUMBERGER	J55	C396074	09-26-02	100.0	99.9	100.0
SCHLUMBERGER	J55	C396075	09-26-02	100.0	100.0	99.6
SCHLUMBERGER	J55	C396076	09-26-02	100.3	100.1	99.8
SCHLUMBERGER	J55	C396077	09-26-02	99.8	99.8	100.2
SCHLUMBERGER	J55	C396078	09-26-02	100.1	100.2	99.6
SCHLUMBERGER	J55	C396079	09-26-02	100.1	100.0	100.2
SCHLUMBERGER	J55	C396080	09-26-02	100.0	100.0	99.8
SCHLUMBERGER	J55	C396081	09-26-02	100.0	99.9	100.3
SCHLUMBERGER	J55	C396082	09-26-02	99.9	100.3	100.2
SCHLUMBERGER	J55	C396083	09-26-02	100.1	100.4	99.5
SCHLUMBERGER	J55	C396084	09-26-02	100.2	100.0	100.2
SCHLUMBERGER	J55	C396085	09-26-02	99.9	99.9	99.7
SCHLUMBERGER	J55	C396086	09-26-02	100.1	99.9	99.9
SCHLUMBERGER	J55	C396087	09-26-02	100.2	100.1	99.9
SCHLUMBERGER	J55	C396088	09-26-02	100.1	99.8	100.2
SCHLUMBERGER	J55	C396089	09-26-02	99.9	99.9	99.7
SCHLUMBERGER	J55	C396090	09-26-02	100.1	100.1	100.0
SCHLUMBERGER	J55	C396091	09-26-02	100.2	100.0	100.0
SCHLUMBERGER	J55	C396092	09-26-02	100.0	99.6	100.4
SCHLUMBERGER	J55	C396093	09-26-02	100.1	99.8	100.0
SCHLUMBERGER	J55	C396094	09-26-02	100.0	99.9	99.7
SCHLUMBERGER	J55	C396095	09-26-02	100.1	99.9	99.8
SCHLUMBERGER	J55	C396096	09-26-02	100.0	99.9	100.2
SCHLUMBERGER	J55	C396097	09-26-02	100.0	99.9	99.4
SCHLUMBERGER	J55	C396098	09-26-02	100.0	100.0	99.7
SCHLUMBERGER	J55	C396099	09-26-02	100.1	99.8	99.8
SCHLUMBERGER	J55	C396100	09-26-02	100.1	99.7	99.8
SCHLUMBERGER	J55	C396101	09-26-02	99.9	99.6	99.9
SCHLUMBERGER	J55	C396102	09-26-02	100.1	99.8	99.3
SCHLUMBERGER	J55	C396103	09-26-02	100.0	99.9	100.1
SCHLUMBERGER	J55	C396104	09-26-02	100.2	99.8	100.1
SCHLUMBERGER	J55	C396105	09-26-02	100.2	99.8	100.3

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

PAGE 222
 RUN DATE: 1/14/03
 RUN TIME: 13.26.53

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	J55	C396106	09-26-02	100.1	99.8	99.7
SCHLUMBERGER	J55	C396107	09-26-02	100.1	99.8	100.0
SCHLUMBERGER	J55	C396108	09-26-02	100.3	100.3	100.2
SCHLUMBERGER	J55	C396109	09-26-02	100.0	100.1	100.1
SCHLUMBERGER	J55	C396110	09-26-02	100.3	99.9	99.9
SCHLUMBERGER	J55	C396111	09-26-02	100.3	99.9	99.8
SCHLUMBERGER	J55	C396112	09-26-02	99.9	99.7	99.7
SCHLUMBERGER	J55	C396113	09-26-02	100.1	99.8	99.8
SCHLUMBERGER	J55	C396114	09-26-02	100.1	99.8	99.8
SCHLUMBERGER	J55	C396115	09-26-02	100.1	100.0	99.8
SCHLUMBERGER	J55	C396116	09-26-02	100.0	99.8	99.9
SCHLUMBERGER	J55	C396117	09-26-02	100.1	100.5	99.6
SCHLUMBERGER	J55	C396118	09-26-02	100.1	100.0	99.7
SCHLUMBERGER	J55	C396119	09-26-02	100.0	100.0	100.0
SCHLUMBERGER	J55	C396120	09-26-02	100.1	99.8	99.8
SCHLUMBERGER	J55	C396121	09-26-02	100.1	100.0	100.2
SCHLUMBERGER	J55	C396122	09-26-02	100.1	99.8	100.0
SCHLUMBERGER	J55	C396123	09-26-02	100.1	99.8	100.0
SCHLUMBERGER	J55	C396124	09-26-02	100.0	100.0	99.7
SCHLUMBERGER	J55	C396125	09-26-02	100.2	99.8	99.9
SCHLUMBERGER	J55	C396126	09-26-02	100.1	100.1	99.9
SCHLUMBERGER	J55	C396127	09-26-02	100.0	99.9	99.9
SCHLUMBERGER	J55	C396128	09-26-02	100.1	100.2	100.0
SCHLUMBERGER	J55	C396129	09-26-02	100.1	100.0	99.9
SCHLUMBERGER	J55	C396130	09-26-02	100.1	100.0	100.0
SCHLUMBERGER	J55	C396131	09-26-02	100.0	99.8	100.0
SCHLUMBERGER	J55	C396132	09-26-02	100.0	99.8	100.0
SCHLUMBERGER	J55	C396133	09-26-02	99.8	100.0	99.9
SCHLUMBERGER	J55	C396134	09-26-02	100.0	99.8	99.8
SCHLUMBERGER	J55	C396135	09-26-02	99.9	99.8	99.9
SCHLUMBERGER	J55	C396136	09-26-02	100.1	99.8	99.9
SCHLUMBERGER	J55	C396137	09-26-02	100.0	99.8	99.9
SCHLUMBERGER	J55	C396138	09-26-02	100.1	100.0	100.1
SCHLUMBERGER	J55	C396139	09-26-02	100.0	99.7	99.8
SCHLUMBERGER	J55	C396140	09-26-02	100.1	99.9	99.7
SCHLUMBERGER	J55	C396141	09-26-02	100.1	100.1	99.8
SCHLUMBERGER	J55	C396142	09-26-02	100.0	100.0	99.4
SCHLUMBERGER	J55	C396143	09-26-02	100.0	99.6	99.9
SCHLUMBERGER	J55	C396144	09-26-02	100.3	99.6	100.3
SCHLUMBERGER	J55	C396145	09-26-02	99.8	99.6	99.2
SCHLUMBERGER	J55	C396146	09-26-02	100.3	99.6	100.1
SCHLUMBERGER	J55	C396147	09-26-02	100.2	99.9	100.3
SCHLUMBERGER	J55	C396148	09-26-02	100.0	99.7	100.0
SCHLUMBERGER	J55	C396149	09-26-02	100.3	99.7	100.0
SCHLUMBERGER	J55	C396150	09-26-02	99.9	99.7	99.9
SCHLUMBERGER	J55	C396151	09-26-02	100.2	100.2	100.0
SCHLUMBERGER	J55	C396152	09-26-02	100.1	99.9	100.1
SCHLUMBERGER	J55	C396153	09-26-02	100.1	100.3	100.1
SCHLUMBERGER	J55	C396154	09-26-02	99.9	99.9	100.1
SCHLUMBERGER	J55	C396155	09-26-02	100.2	100.0	99.6
SCHLUMBERGER	J55	C396156	09-26-02	100.1	100.0	100.1

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

PAGE 223
 RUN DATE: 1/14/03
 RUN TIME: 13.26.53

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	J5S	C396157	09-26-02	99.9	100.0	100.1
SCHLUMBERGER	J5S	C396158	09-26-02	100.2	100.1	99.9
SCHLUMBERGER	J5S	C396159	09-26-02	100.0	99.8	99.3
SCHLUMBERGER	J5S	C396160	09-26-02	100.2	100.0	100.2
SCHLUMBERGER	J5S	C396161	09-26-02	100.3	100.0	100.3
SCHLUMBERGER	J5S	C396162	09-26-02	100.0	99.6	99.9
SCHLUMBERGER	J5S	C396163	09-26-02	100.0	99.8	99.7
SCHLUMBERGER	J5S	C396164	09-26-02	100.2	100.1	99.9
SCHLUMBERGER	J5S	C396165	09-26-02	100.1	100.1	100.2
SCHLUMBERGER	J5S	C396166	09-26-02	100.2	100.1	100.2
SCHLUMBERGER	J5S	C396167	09-26-02	99.9	99.7	99.5
SCHLUMBERGER	J5S	C396168	09-26-02	100.0	100.1	100.0
SCHLUMBERGER	J5S	C396169	09-26-02	100.0	99.9	99.7
SCHLUMBERGER	J5S	C396170	09-26-02	100.1	100.0	100.5
SCHLUMBERGER	J5S	C396171	09-26-02	100.1	99.8	100.0
SCHLUMBERGER	J5S	C396172	09-26-02	100.1	100.0	99.5
SCHLUMBERGER	J5S	C396173	09-26-02	100.1	99.7	99.5
SCHLUMBERGER	J5S	C396174	09-26-02	100.0	99.7	100.1
SCHLUMBERGER	J5S	C396175	09-26-02	100.1	99.7	99.7
SCHLUMBERGER	J5S	C396176	09-26-02	100.0	99.6	99.9
SCHLUMBERGER	J5S	C396177	09-26-02	99.9	99.8	99.9
SCHLUMBERGER	J5S	C396178	09-26-02	99.9	99.9	100.0
SCHLUMBERGER	J5S	C396179	09-26-02	100.2	100.3	100.2
SCHLUMBERGER	J5S	C396180	09-26-02	100.0	99.6	100.0
SCHLUMBERGER	J5S	C396181	09-26-02	99.9	100.0	99.7
SCHLUMBERGER	J5S	C396182	09-26-02	100.1	100.2	100.2
SCHLUMBERGER	J5S	C396183	09-26-02	100.1	100.0	100.1
SCHLUMBERGER	J5S	C396184	09-26-02	100.3	100.0	100.2
SCHLUMBERGER	J5S	C396185	09-26-02	100.0	99.8	100.2
SCHLUMBERGER	J5S	C396186	09-26-02	100.1	99.9	99.9
SCHLUMBERGER	J5S	C396187	09-26-02	100.1	100.0	100.5
SCHLUMBERGER	J5S	C396188	09-26-02	99.8	100.5	100.5
SCHLUMBERGER	J5S	C396189	09-26-02	100.2	99.7	100.0
SCHLUMBERGER	J5S	C396190	09-26-02	100.1	100.2	100.5
SCHLUMBERGER	J5S	C396191	09-26-02	99.9	99.6	99.5
SCHLUMBERGER	J5S	C396192	09-26-02	100.2	99.8	100.2
SCHLUMBERGER	J5S	C396193	09-26-02	100.1	99.8	99.9
SCHLUMBERGER	J5S	C396194	09-26-02	100.0	100.1	100.3
SCHLUMBERGER	J5S	C396195	09-26-02	100.0	99.7	99.8
SCHLUMBERGER	J5S	C396196	09-26-02	100.2	100.1	100.1
SCHLUMBERGER	J5S	C396197	09-26-02	100.1	100.0	100.0
SCHLUMBERGER	J5S	C396198	09-26-02	100.0	100.1	99.5
SCHLUMBERGER	J5S	C396199	09-26-02	100.1	99.6	99.7
SCHLUMBERGER	J5S	C396200	09-26-02	100.0	99.9	99.8
SCHLUMBERGER	J5S	C396201	09-26-02	100.0	99.8	99.6
SCHLUMBERGER	J5S	C396202	09-26-02	100.1	100.0	100.2
SCHLUMBERGER	J5S	C396203	09-26-02	100.1	99.8	99.8
SCHLUMBERGER	J5S	C396204	09-26-02	99.9	100.1	99.5
SCHLUMBERGER	J5S	C396205	09-26-02	100.1	100.0	99.9
SCHLUMBERGER	J5S	C396206	09-26-02	100.0	100.4	99.5
SCHLUMBERGER	J5S	C396207	09-26-02	100.1	99.9	99.4

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

MANUFACTURER	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	C396208	09-26-02	100.0	100.3	99.4
SCHLUMBERGER	C396209	09-26-02	100.2	100.4	100.4
SCHLUMBERGER	C396210	09-26-02	100.1	99.8	99.8
SCHLUMBERGER	C396211	09-26-02	99.9	99.8	100.3
SCHLUMBERGER	C396212	09-26-02	100.0	99.7	99.9
SCHLUMBERGER	C396213	09-26-02	99.8	100.0	100.1
SCHLUMBERGER	C396214	09-26-02	100.0	100.2	99.9
SCHLUMBERGER	C396215	09-26-02	100.1	99.7	99.9
SCHLUMBERGER	C396216	09-26-02	100.3	100.1	100.1
SCHLUMBERGER	C396217	09-26-02	99.9	99.7	99.9
SCHLUMBERGER	C396218	09-26-02	99.9	99.8	99.6
SCHLUMBERGER	C396219	09-26-02	100.1	100.1	100.3
SCHLUMBERGER	C396220	09-26-02	100.1	100.3	99.3
SCHLUMBERGER	C396221	09-26-02	100.2	100.4	100.2
SCHLUMBERGER	C396222	09-26-02	100.1	99.9	100.1
SCHLUMBERGER	C396223	09-26-02	100.0	99.7	99.4
SCHLUMBERGER	C396224	09-26-02	100.1	99.9	99.8
SCHLUMBERGER	C396225	09-26-02	100.0	100.0	100.0
SCHLUMBERGER	C396226	09-26-02	99.9	99.8	99.7
SCHLUMBERGER	C396227	09-26-02	100.2	99.8	99.7
SCHLUMBERGER	C396228	09-26-02	100.1	99.7	100.1
SCHLUMBERGER	C396229	09-26-02	100.0	99.9	99.7
SCHLUMBERGER	C396230	09-26-02	100.1	99.8	100.1
SCHLUMBERGER	C396231	09-26-02	99.9	99.7	99.7
SCHLUMBERGER	C396232	09-26-02	99.9	100.1	99.6
SCHLUMBERGER	C396233	09-26-02	100.0	99.8	99.5
SCHLUMBERGER	C396234	09-26-02	100.0	99.9	99.8
SCHLUMBERGER	C396235	09-26-02	100.0	99.9	100.1
SCHLUMBERGER	C396236	09-26-02	100.0	99.8	100.1
SCHLUMBERGER	C396237	09-26-02	99.9	100.0	99.7
SCHLUMBERGER	C396238	09-26-02	100.1	99.7	99.7
SCHLUMBERGER	C396239	09-26-02	99.9	100.1	99.9
SCHLUMBERGER	C396240	09-26-02	99.9	99.9	99.8
SCHLUMBERGER	C396241	09-26-02	100.3	100.0	100.0
SCHLUMBERGER	C396242	09-26-02	100.0	99.8	99.8
SCHLUMBERGER	C396243	09-26-02	100.0	100.0	99.7
SCHLUMBERGER	C396244	09-26-02	100.0	99.8	100.0
SCHLUMBERGER	C396245	09-26-02	100.1	100.1	100.4
SCHLUMBERGER	C396246	09-26-02	100.0	99.9	100.1
SCHLUMBERGER	C396247	09-26-02	99.9	99.8	100.3
SCHLUMBERGER	C396248	09-26-02	100.2	99.7	99.8
SCHLUMBERGER	C396249	09-26-02	100.1	99.8	100.0
SCHLUMBERGER	C396250	09-26-02	100.2	100.0	99.8
SCHLUMBERGER	C396251	09-26-02	100.0	99.7	100.1
SCHLUMBERGER	C396252	09-26-02	99.9	99.9	99.3
SCHLUMBERGER	C396253	09-26-02	99.9	99.9	99.8
SCHLUMBERGER	C396254	09-26-02	100.0	99.8	99.6
SCHLUMBERGER	C396255	09-26-02	100.2	100.2	100.3
SCHLUMBERGER	C396256	09-26-02	100.2	99.8	100.0
SCHLUMBERGER	C396257	09-26-02	100.0	99.9	99.8
SCHLUMBERGER	C396258	09-26-02	100.1	99.7	100.5

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

PAGE 225
 RUN DATE: 1/14/03
 RUN TIME: 13.26.53

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	J55	C396259	09-26-02	100.0	99.9	100.0
SCHLUMBERGER	J55	C396260	09-26-02	100.3	99.8	100.0
SCHLUMBERGER	J55	C396261	09-26-02	99.9	100.2	99.9
SCHLUMBERGER	J55	C396262	09-26-02	100.1	100.0	100.4
SCHLUMBERGER	J55	C396263	09-26-02	100.1	99.8	100.5
SCHLUMBERGER	J55	C396264	09-26-02	100.0	99.8	99.7
SCHLUMBERGER	J55	C396265	09-26-02	100.0	100.0	99.6
SCHLUMBERGER	J55	C396266	09-26-02	100.0	100.0	99.8
SCHLUMBERGER	J55	C396267	09-26-02	100.0	100.2	100.3
SCHLUMBERGER	J55	C396268	09-26-02	100.1	99.8	99.9
SCHLUMBERGER	J55	C396269	09-26-02	100.0	99.7	99.6
SCHLUMBERGER	J55	C396270	09-26-02	100.1	99.8	100.0
SCHLUMBERGER	J55	C396271	09-26-02	100.3	99.9	100.1
SCHLUMBERGER	J55	C396272	09-26-02	100.0	99.8	99.8
SCHLUMBERGER	J55	C396273	09-26-02	100.3	100.1	99.9
SCHLUMBERGER	J55	C396274	09-26-02	99.9	100.2	99.9
SCHLUMBERGER	J55	C396275	09-26-02	99.9	99.8	99.5
SCHLUMBERGER	J55	C396276	09-26-02	100.2	99.9	99.8
SCHLUMBERGER	J55	C396277	09-26-02	100.0	100.4	100.1
SCHLUMBERGER	J55	C396278	09-26-02	100.1	100.0	100.4
SCHLUMBERGER	J55	C396279	09-26-02	100.1	99.7	100.0
SCHLUMBERGER	J55	C396280	09-26-02	100.0	99.9	100.3
SCHLUMBERGER	J55	C396281	09-26-02	100.1	99.8	100.0
SCHLUMBERGER	J55	C396282	09-26-02	100.2	99.6	100.0
SCHLUMBERGER	J55	C396283	09-26-02	99.9	99.8	99.7
SCHLUMBERGER	J55	C396284	09-26-02	99.9	100.0	99.9
SCHLUMBERGER	J55	C396285	09-26-02	100.0	99.8	100.0
SCHLUMBERGER	J55	C396286	09-26-02	100.0	99.9	100.0
SCHLUMBERGER	J55	C396287	09-26-02	100.0	100.0	99.9
SCHLUMBERGER	J55	C396288	09-26-02	100.1	99.9	100.1
SCHLUMBERGER	J55	C396289	09-26-02	99.9	99.6	99.5
SCHLUMBERGER	J55	C396290	09-26-02	100.1	99.9	100.2
SCHLUMBERGER	J55	C396291	09-26-02	100.0	99.8	99.9
SCHLUMBERGER	J55	C396292	09-26-02	100.1	100.1	100.0
SCHLUMBERGER	J55	C396293	09-26-02	100.1	99.8	100.0
SCHLUMBERGER	J55	C396294	09-26-02	100.3	100.0	99.8
SCHLUMBERGER	J55	C396295	09-26-02	100.1	100.0	99.7
SCHLUMBERGER	J55	C396296	09-26-02	100.0	99.6	99.9
SCHLUMBERGER	J55	C396297	09-26-02	100.3	100.0	100.1
SCHLUMBERGER	J55	C396298	09-26-02	100.1	99.8	99.7
SCHLUMBERGER	J55	C396299	09-26-02	100.0	99.9	99.9
SCHLUMBERGER	J55	C396300	09-26-02	100.2	100.1	100.1
SCHLUMBERGER	J55	C396301	09-26-02	100.1	99.9	99.8
SCHLUMBERGER	J55	C396302	09-26-02	100.2	99.7	100.3
SCHLUMBERGER	J55	C396303	09-26-02	100.0	99.8	99.9
SCHLUMBERGER	J55	C396304	09-26-02	100.2	99.8	100.0
SCHLUMBERGER	J55	C396305	09-26-02	100.0	99.8	99.8
SCHLUMBERGER	J55	C396306	09-26-02	100.1	100.0	99.7
SCHLUMBERGER	J55	C396307	09-26-02	100.0	99.8	99.8
SCHLUMBERGER	J55	C396308	09-26-02	100.2	100.0	99.9
SCHLUMBERGER	J55	C396309	09-26-02	100.1	99.8	99.9

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

PAGE 226
 RUN DATE: 1/14/03
 RUN TIME: 13.26.53

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	J5S	C396310	09-26-02	100.3	99.9	99.9
SCHLUMBERGER	J5S	C396311	09-26-02	100.1	100.0	99.8
SCHLUMBERGER	J5S	C396312	09-26-02	100.1	99.8	100.1
SCHLUMBERGER	J5S	C396313	09-26-02	99.9	99.6	99.7
SCHLUMBERGER	J5S	C396314	09-26-02	100.0	99.6	99.6
SCHLUMBERGER	J5S	C396315	09-26-02	100.1	100.3	100.3
SCHLUMBERGER	J5S	C396316	09-26-02	100.2	99.9	99.9
SCHLUMBERGER	J5S	C396317	09-26-02	100.1	100.3	100.2
SCHLUMBERGER	J5S	C396318	09-26-02	100.0	99.7	99.7
SCHLUMBERGER	J5S	C396319	09-26-02	100.1	100.4	99.8
SCHLUMBERGER	J5S	C396320	09-26-02	100.1	99.7	100.2
SCHLUMBERGER	J5S	C396321	09-26-02	99.9	100.0	99.8
SCHLUMBERGER	J5S	C396322	09-26-02	100.1	99.6	100.0
SCHLUMBERGER	J5S	C396323	09-26-02	100.1	99.8	100.0
SCHLUMBERGER	J5S	C396324	09-26-02	100.0	100.1	100.3
SCHLUMBERGER	J5S	C396325	09-26-02	100.3	99.7	99.3
SCHLUMBERGER	J5S	C396326	09-26-02	100.1	99.9	99.5
SCHLUMBERGER	J5S	C396327	09-26-02	99.9	100.1	99.8
SCHLUMBERGER	J5S	C396328	09-26-02	100.1	100.0	99.8
SCHLUMBERGER	J5S	C396329	09-26-02	100.0	99.6	99.9
SCHLUMBERGER	J5S	C396330	09-26-02	99.9	100.3	99.9
SCHLUMBERGER	J5S	C396331	09-26-02	100.2	99.8	100.1
SCHLUMBERGER	J5S	C396332	09-26-02	100.3	99.9	100.4
SCHLUMBERGER	J5S	C396333	09-26-02	100.2	99.7	100.2
SCHLUMBERGER	J5S	C396334	09-26-02	100.1	99.6	99.6
SCHLUMBERGER	J5S	C396335	09-26-02	100.1	99.9	100.1
SCHLUMBERGER	J5S	C396336	09-26-02	100.0	99.9	100.2
SCHLUMBERGER	J5S	C396337	09-26-02	100.1	99.7	100.0
SCHLUMBERGER	J5S	C396338	09-26-02	100.1	99.7	100.0
SCHLUMBERGER	J5S	C396339	09-26-02	100.0	100.1	99.8
SCHLUMBERGER	J5S	C396340	09-26-02	100.1	99.8	100.0
SCHLUMBERGER	J5S	C396341	09-26-02	100.0	100.3	99.6
SCHLUMBERGER	J5S	C396342	09-26-02	100.1	99.6	99.9
SCHLUMBERGER	J5S	C396343	09-26-02	100.2	100.0	100.1
SCHLUMBERGER	J5S	C396344	09-26-02	99.9	99.7	99.7
SCHLUMBERGER	J5S	C396345	09-26-02	100.0	100.2	100.0
SCHLUMBERGER	J5S	C396346	09-26-02	100.1	99.9	99.9
SCHLUMBERGER	J5S	C396347	09-26-02	100.0	99.7	100.2
SCHLUMBERGER	J5S	C396348	09-26-02	99.9	99.9	99.8
SCHLUMBERGER	J5S	C396349	09-26-02	100.3	99.9	100.3
SCHLUMBERGER	J5S	C396350	09-26-02	100.1	99.7	99.7
SCHLUMBERGER	J5S	C396351	09-26-02	100.0	99.7	99.7
SCHLUMBERGER	J5S	C396352	09-26-02	99.9	99.7	100.2
SCHLUMBERGER	J5S	C396353	09-26-02	100.0	100.1	100.7
SCHLUMBERGER	J5S	C396354	09-26-02	100.1	99.8	100.1
SCHLUMBERGER	J5S	C396355	09-26-02	99.9	99.7	99.8
SCHLUMBERGER	J5S	C396356	09-26-02	100.0	99.8	99.7
SCHLUMBERGER	J5S	C396357	09-26-02	100.3	99.7	100.0
SCHLUMBERGER	J5S	C396358	09-26-02	100.0	100.2	100.3
SCHLUMBERGER	J5S	C396359	09-26-02	100.1	99.7	100.0
SCHLUMBERGER	J5S	C396360	09-26-02	100.0	99.9	99.5

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	J55	C396361	09-26-02	100.1	99.7	100.3
SCHLUMBERGER	J55	C396362	09-26-02	100.0	99.7	100.3
SCHLUMBERGER	J55	C396363	09-26-02	100.0	99.9	99.9
SCHLUMBERGER	J55	C396364	09-26-02	99.9	100.3	99.9
SCHLUMBERGER	J55	C396365	09-26-02	100.1	99.9	99.6
SCHLUMBERGER	J55	C396366	09-26-02	100.0	100.0	100.1
SCHLUMBERGER	J55	C396367	09-26-02	100.1	99.9	99.9
SCHLUMBERGER	J55	C396368	09-26-02	100.2	99.8	99.7
SCHLUMBERGER	J55	C396369	09-26-02	100.1	100.0	100.3
SCHLUMBERGER	J55	C396370	09-26-02	100.1	99.7	100.2
SCHLUMBERGER	J55	C396371	09-26-02	100.0	99.6	100.1
SCHLUMBERGER	J55	C396372	09-26-02	100.0	99.8	100.1
SCHLUMBERGER	J55	C396373	09-26-02	100.2	99.7	100.0
SCHLUMBERGER	J55	C396374	09-26-02	100.0	99.6	99.8
SCHLUMBERGER	J55	C396375	09-26-02	100.0	100.0	99.7
SCHLUMBERGER	J55	C396376	09-26-02	100.0	100.1	99.7
SCHLUMBERGER	J55	C396377	09-26-02	100.1	99.7	100.1
SCHLUMBERGER	J55	C396378	09-26-02	100.0	99.8	99.8
SCHLUMBERGER	J55	C396379	09-26-02	100.1	99.8	99.8
SCHLUMBERGER	J55	C396380	09-26-02	100.2	99.8	100.1
SCHLUMBERGER	J55	C396381	09-26-02	100.0	99.7	100.0
SCHLUMBERGER	J55	C396382	09-26-02	100.1	99.8	99.5
SCHLUMBERGER	J55	C396383	09-26-02	100.1	99.8	100.1
SCHLUMBERGER	J55	C396384	09-26-02	100.1	99.8	100.3
SCHLUMBERGER	J55	C396385	09-26-02	100.1	99.8	100.3
SCHLUMBERGER	J55	C396386	09-26-02	100.2	100.0	100.3
SCHLUMBERGER	J55	C396387	09-26-02	100.0	100.0	99.6
SCHLUMBERGER	J55	C396388	09-26-02	99.9	99.6	99.8
SCHLUMBERGER	J55	C396389	09-26-02	100.3	99.7	99.8
SCHLUMBERGER	J55	C396390	09-26-02	99.9	99.6	99.9
SCHLUMBERGER	J55	C396391	09-26-02	100.0	99.6	99.7
SCHLUMBERGER	J55	C396392	09-26-02	99.9	99.8	99.9
SCHLUMBERGER	J55	C396393	09-26-02	100.1	99.8	100.2
SCHLUMBERGER	J55	C396394	09-26-02	100.3	100.4	100.7
SCHLUMBERGER	J55	C396395	09-26-02	100.0	99.7	100.0
SCHLUMBERGER	J55	C396396	09-26-02	100.0	99.7	99.9
SCHLUMBERGER	J55	C396397	09-26-02	99.8	99.6	99.5
SCHLUMBERGER	J55	C396398	09-26-02	100.2	99.7	99.5
SCHLUMBERGER	J55	C396399	09-26-02	100.1	100.2	100.3
SCHLUMBERGER	J55	C396400	09-26-02	100.0	99.9	100.0
SCHLUMBERGER	J55	C396401	09-26-02	100.0	99.8	99.9
SCHLUMBERGER	J55	C396402	09-26-02	100.0	99.8	99.8
SCHLUMBERGER	J55	C396403	09-26-02	100.0	99.8	99.8
SCHLUMBERGER	J55	C396404	09-26-02	100.0	99.9	100.0
SCHLUMBERGER	J55	C396405	09-26-02	99.9	100.0	99.6
SCHLUMBERGER	J55	C396406	09-26-02	99.8	99.7	100.1
SCHLUMBERGER	J55	C396407	09-26-02	100.1	99.7	99.5
SCHLUMBERGER	J55	C396408	09-26-02	100.3	99.7	100.1
SCHLUMBERGER	J55	C396409	09-26-02	100.1	99.8	100.4
SCHLUMBERGER	J55	C396410	09-26-02	100.1	99.8	100.1
SCHLUMBERGER	J55	C396411	09-26-02	100.0	99.6	99.8

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

PAGE 228
 RUN DATE: 1/14/03
 RUN TIME: 13.26.53

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	J55	C396412	09-26-02	100.1	99.8	100.0
SCHLUMBERGER	J55	C396413	09-26-02	100.1	99.8	99.9
SCHLUMBERGER	J55	C396414	09-26-02	100.2	99.9	100.1
SCHLUMBERGER	J55	C396415	09-26-02	100.0	99.6	99.9
SCHLUMBERGER	J55	C396416	09-26-02	100.1	99.6	100.0
SCHLUMBERGER	J55	C396417	09-26-02	100.0	100.2	99.7
SCHLUMBERGER	J55	C396418	09-26-02	100.1	99.9	100.1
SCHLUMBERGER	J55	C396419	09-26-02	100.0	99.7	99.8
SCHLUMBERGER	J55	C396420	09-26-02	100.2	99.9	100.4
SCHLUMBERGER	J55	C396421	09-26-02	100.1	99.9	99.7
SCHLUMBERGER	J55	C396422	09-26-02	100.1	100.1	99.8
SCHLUMBERGER	J55	C396423	09-26-02	100.1	99.7	99.9
SCHLUMBERGER	J55	C396424	09-26-02	100.0	99.8	100.2
SCHLUMBERGER	J55	C396425	09-26-02	100.1	100.2	99.9
SCHLUMBERGER	J55	C396426	09-26-02	100.1	100.0	100.1
SCHLUMBERGER	J55	C396427	09-26-02	100.0	99.9	99.6
SCHLUMBERGER	J55	C396428	09-26-02	100.0	99.8	99.8
SCHLUMBERGER	J55	C396429	09-26-02	100.1	99.7	100.0
SCHLUMBERGER	J55	C396430	09-26-02	100.0	99.8	100.2
SCHLUMBERGER	J55	C396431	09-26-02	100.1	100.3	99.9
SCHLUMBERGER	J55	C396432	09-26-02	99.9	100.0	100.0
SCHLUMBERGER	J55	C396433	09-26-02	100.1	99.9	100.0
SCHLUMBERGER	J55	C396434	09-26-02	100.2	100.1	100.0
SCHLUMBERGER	J55	C396435	09-26-02	100.1	100.0	99.9
SCHLUMBERGER	J55	C396436	09-26-02	99.8	99.6	99.7
SCHLUMBERGER	J55	C396437	09-26-02	100.0	99.8	100.2
SCHLUMBERGER	J55	C396438	09-26-02	100.0	99.7	99.6
SCHLUMBERGER	J55	C396439	09-26-02	100.0	99.9	100.0
SCHLUMBERGER	J55	C396440	09-26-02	99.8	99.7	99.7
SCHLUMBERGER	J55	C396441	09-26-02	100.1	99.7	100.0
SCHLUMBERGER	J55	C396442	09-26-02	100.1	99.7	100.3
SCHLUMBERGER	J55	C396443	09-26-02	99.9	100.1	99.6
SCHLUMBERGER	J55	C396444	09-26-02	100.1	100.1	100.1
SCHLUMBERGER	J55	C396445	09-26-02	100.1	100.4	100.0
SCHLUMBERGER	J55	C396446	09-26-02	100.2	100.1	100.4
SCHLUMBERGER	J55	C396447	09-26-02	100.1	99.7	100.0
SCHLUMBERGER	J55	C396448	09-26-02	100.0	99.7	100.2
SCHLUMBERGER	J55	C396449	09-26-02	100.0	99.8	99.6
SCHLUMBERGER	J55	C396450	09-26-02	100.0	100.2	100.1
SCHLUMBERGER	J55	C396451	09-26-02	100.0	100.3	100.3
SCHLUMBERGER	J55	C396452	09-26-02	99.9	99.6	99.6
SCHLUMBERGER	J55	C396453	09-26-02	100.1	99.8	100.0
SCHLUMBERGER	J55	C396454	09-26-02	100.2	99.7	100.1
SCHLUMBERGER	J55	C396455	09-26-02	100.0	99.9	100.0
SCHLUMBERGER	J55	C396456	09-26-02	100.2	99.7	100.0
SCHLUMBERGER	J55	C396457	09-26-02	100.0	99.3	100.1
SCHLUMBERGER	J55	C396458	09-26-02	100.0	99.8	99.9
SCHLUMBERGER	J55	C396459	09-26-02	100.1	99.8	100.2
SCHLUMBERGER	J55	C396460	09-26-02	100.1	100.2	100.3
SCHLUMBERGER	J55	C396461	09-26-02	100.2	100.5	99.6
SCHLUMBERGER	J55	C396462	09-26-02	100.0	99.9	99.9

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	J55	C396463	09-26-02	99.9	100.2	99.9
SCHLUMBERGER	J55	C396464	09-26-02	100.1	99.8	99.8
SCHLUMBERGER	J55	C396465	09-26-02	100.0	100.3	100.5
SCHLUMBERGER	J55	C396466	09-26-02	100.0	100.3	99.8
SCHLUMBERGER	J55	C396467	09-26-02	100.0	99.6	99.8
SCHLUMBERGER	J55	C396468	09-26-02	100.2	100.3	100.2
SCHLUMBERGER	J55	C396469	09-26-02	100.0	99.8	99.6
SCHLUMBERGER	J55	C396470	09-26-02	100.1	99.7	99.8
SCHLUMBERGER	J55	C396471	09-26-02	100.1	99.8	100.1
SCHLUMBERGER	J55	C396472	09-26-02	100.0	99.6	99.7
SCHLUMBERGER	J55	C396473	09-26-02	100.2	99.8	100.0
SCHLUMBERGER	J55	C396474	09-26-02	100.2	99.8	99.8
SCHLUMBERGER	J55	C396475	09-26-02	100.0	99.8	100.0
SCHLUMBERGER	J55	C396476	09-26-02	99.9	100.3	99.6
SCHLUMBERGER	J55	C396477	09-26-02	100.1	100.0	99.7
SCHLUMBERGER	J55	C396478	09-26-02	100.0	99.8	99.9
SCHLUMBERGER	J55	C396479	09-26-02	100.1	99.8	99.8
SCHLUMBERGER	J55	C396480	09-26-02	100.3	99.9	99.7
SCHLUMBERGER	J55	C396481	09-26-02	100.1	99.6	100.0
SCHLUMBERGER	J55	C396482	09-26-02	100.1	99.8	99.9
SCHLUMBERGER	J55	C396483	09-26-02	100.1	99.8	99.8
SCHLUMBERGER	J55	C396484	09-26-02	100.0	99.8	100.0
SCHLUMBERGER	J55	C396485	09-26-02	100.0	99.6	99.8
SCHLUMBERGER	J55	C396486	09-26-02	100.0	99.7	99.9
SCHLUMBERGER	J55	C396487	09-26-02	99.9	100.2	100.0
SCHLUMBERGER	J55	C396488	09-26-02	100.1	99.9	100.1
SCHLUMBERGER	J55	C396489	09-26-02	100.0	100.1	99.8
SCHLUMBERGER	J55	C396490	09-26-02	100.0	100.1	99.9
SCHLUMBERGER	J55	C396491	09-26-02	100.0	99.7	99.9
SCHLUMBERGER	J55	C396492	09-26-02	100.1	99.8	100.3
SCHLUMBERGER	J55	C396493	09-26-02	100.1	99.8	99.8
SCHLUMBERGER	J55	C396494	09-26-02	100.0	99.8	100.0
SCHLUMBERGER	J55	C396495	09-26-02	100.0	99.9	99.5
SCHLUMBERGER	J55	C396496	09-26-02	100.0	99.7	100.0
SCHLUMBERGER	J55	C396497	09-26-02	100.1	99.7	99.9
SCHLUMBERGER	J55	C396498	09-26-02	100.0	99.8	99.6
SCHLUMBERGER	J55	C396499	09-26-02	100.0	100.3	99.7
SCHLUMBERGER	J55	C396500	09-26-02	99.9	99.8	99.7
SCHLUMBERGER	J55	C396501	09-26-02	100.0	100.3	99.9
SCHLUMBERGER	J55	C396502	09-26-02	100.0	99.5	99.9
SCHLUMBERGER	J55	C396503	09-26-02	100.0	100.5	100.0
SCHLUMBERGER	J55	C396504	09-26-02	100.0	99.7	99.9
SCHLUMBERGER	J55	C396505	09-26-02	100.0	99.6	99.8
SCHLUMBERGER	J55	C396506	09-26-02	100.2	99.6	99.8
SCHLUMBERGER	J55	C396507	09-26-02	100.1	99.9	99.9
SCHLUMBERGER	J55	C396508	10-14-02	100.0	99.9	99.7
SCHLUMBERGER	J55	C396509	10-14-02	100.0	99.7	99.8
SCHLUMBERGER	J55	C396510	10-14-02	100.1	99.7	99.5
SCHLUMBERGER	J55	C396511	10-14-02	99.9	99.7	99.4
SCHLUMBERGER	J55	C396512	10-14-02	99.8	99.8	99.4
SCHLUMBERGER	J55	C396513	10-14-02	100.0	99.8	99.8

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

PAGE 230
 RUN DATE: 1/14/03
 RUN TIME: 13.26.53

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	J55	C396514	10-14-02	100.0	99.7	99.4
SCHLUMBERGER	J55	C396515	10-14-02	100.1	100.0	99.8
SCHLUMBERGER	J55	C396516	10-14-02	100.1	99.8	99.6
SCHLUMBERGER	J55	C396517	10-14-02	100.1	99.7	99.5
SCHLUMBERGER	J55	C396518	10-14-02	99.9	100.0	99.3
SCHLUMBERGER	J55	C396519	10-14-02	100.0	100.3	99.4
SCHLUMBERGER	J55	C396520	10-14-02	99.9	100.2	99.7
SCHLUMBERGER	J55	C396521	10-14-02	100.1	100.0	100.0
SCHLUMBERGER	J55	C396522	10-14-02	100.1	99.7	99.6
SCHLUMBERGER	J55	C396523	10-14-02	100.1	100.1	100.1
SCHLUMBERGER	J55	C396524	10-14-02	99.9	100.3	99.4
SCHLUMBERGER	J55	C396525	10-14-02	100.1	99.8	99.8
SCHLUMBERGER	J55	C396526	10-14-02	100.2	99.7	100.0
SCHLUMBERGER	J55	C396527	10-14-02	99.9	99.8	100.1
SCHLUMBERGER	J55	C396528	10-14-02	100.3	99.9	99.8
SCHLUMBERGER	J55	C396529	10-14-02	100.1	100.1	100.1
SCHLUMBERGER	J55	C396530	10-14-02	100.1	99.9	99.7
SCHLUMBERGER	J55	C396531	10-14-02	99.9	100.0	99.8
SCHLUMBERGER	J55	C396532	10-14-02	100.0	99.8	99.5
SCHLUMBERGER	J55	C396533	10-14-02	100.0	99.8	99.5
SCHLUMBERGER	J55	C396534	10-14-02	100.1	99.9	99.8
SCHLUMBERGER	J55	C396535	10-14-02	99.9	100.1	99.7
SCHLUMBERGER	J55	C396536	10-14-02	99.9	99.6	99.6
SCHLUMBERGER	J55	C396537	10-14-02	100.0	100.0	99.4
SCHLUMBERGER	J55	C396538	10-14-02	100.0	99.9	99.9
SCHLUMBERGER	J55	C396539	10-14-02	99.9	99.8	100.3
SCHLUMBERGER	J55	C396540	10-14-02	100.3	99.8	99.3
SCHLUMBERGER	J55	C396541	10-14-02	100.1	100.0	100.3
SCHLUMBERGER	J55	C396542	10-14-02	100.0	99.7	99.8
SCHLUMBERGER	J55	C396543	10-14-02	100.0	99.8	99.5
SCHLUMBERGER	J55	C396544	10-14-02	99.9	99.8	100.2
SCHLUMBERGER	J55	C396545	10-14-02	100.0	99.7	99.6
SCHLUMBERGER	J55	C396546	10-14-02	100.1	99.7	100.0
SCHLUMBERGER	J55	C396547	10-14-02	100.0	99.9	99.3
SCHLUMBERGER	J55	C396548	10-14-02	100.0	100.1	100.0
SCHLUMBERGER	J55	C396549	10-14-02	99.8	99.6	99.9
SCHLUMBERGER	J55	C396550	10-14-02	100.0	100.0	99.6
SCHLUMBERGER	J55	C396551	10-14-02	100.0	100.0	99.8
SCHLUMBERGER	J55	C396552	10-14-02	100.1	99.7	99.5
SCHLUMBERGER	J55	C396553	10-14-02	100.0	100.0	100.2
SCHLUMBERGER	J55	C396554	10-14-02	100.0	99.7	100.1
SCHLUMBERGER	J55	C396555	10-14-02	99.9	99.7	99.9
SCHLUMBERGER	J55	C396556	10-14-02	100.1	99.7	99.3
SCHLUMBERGER	J55	C396557	10-14-02	100.0	99.8	100.3
SCHLUMBERGER	J55	C396558	10-14-02	100.3	99.7	99.7
SCHLUMBERGER	J55	C396559	10-14-02	100.2	100.2	99.9
SCHLUMBERGER	J55	C396560	10-14-02	100.1	99.8	99.8
SCHLUMBERGER	J55	C396561	10-14-02	100.1	99.7	99.7
SCHLUMBERGER	J55	C396562	10-14-02	100.2	100.0	99.5
SCHLUMBERGER	J55	C396563	10-14-02	100.1	99.7	99.6
SCHLUMBERGER	J55	C396564	10-14-02	99.9	99.8	99.4

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	J55	C396565	10-14-02	100.3	100.2	99.9
SCHLUMBERGER	J55	C396566	10-14-02	99.9	99.8	100.0
SCHLUMBERGER	J55	C396567	10-14-02	100.0	100.3	100.5
SCHLUMBERGER	J55	C396568	10-14-02	100.1	99.9	99.6
SCHLUMBERGER	J55	C396569	10-14-02	99.9	99.9	99.9
SCHLUMBERGER	J55	C396570	10-14-02	100.0	99.7	99.5
SCHLUMBERGER	J55	C396571	10-14-02	100.0	99.9	99.5
SCHLUMBERGER	J55	C396572	10-14-02	100.1	100.0	99.8
SCHLUMBERGER	J55	C396573	10-14-02	100.2	100.0	99.9
SCHLUMBERGER	J55	C396574	10-14-02	100.0	99.6	99.8
SCHLUMBERGER	J55	C396575	10-14-02	100.0	99.9	99.8
SCHLUMBERGER	J55	C396576	10-14-02	100.1	99.9	99.7
SCHLUMBERGER	J55	C396577	10-14-02	100.1	99.9	99.8
SCHLUMBERGER	J55	C396578	10-14-02	99.8	99.8	100.1
SCHLUMBERGER	J55	C396579	10-14-02	100.0	99.7	99.5
SCHLUMBERGER	J55	C396580	10-14-02	99.8	99.8	99.7
SCHLUMBERGER	J55	C396581	10-14-02	100.0	99.7	99.3
SCHLUMBERGER	J55	C396582	10-14-02	100.1	99.8	99.8
SCHLUMBERGER	J55	C396583	10-14-02	100.2	100.0	100.4
SCHLUMBERGER	J55	C396584	10-14-02	100.1	99.9	99.5
SCHLUMBERGER	J55	C396585	10-14-02	100.1	99.6	99.6
SCHLUMBERGER	J55	C396586	10-14-02	100.0	99.7	99.6
SCHLUMBERGER	J55	C396587	10-14-02	99.9	99.6	99.3
SCHLUMBERGER	J55	C396588	10-14-02	99.9	99.6	99.7
SCHLUMBERGER	J55	C396589	10-14-02	100.2	100.2	99.7
SCHLUMBERGER	J55	C396590	10-14-02	100.1	100.0	99.7
SCHLUMBERGER	J55	C396591	10-14-02	100.1	100.0	100.1
SCHLUMBERGER	J55	C396592	10-14-02	99.9	99.9	100.1
SCHLUMBERGER	J55	C396593	10-14-02	100.0	100.2	99.3
SCHLUMBERGER	J55	C396594	10-14-02	100.1	99.8	99.7
SCHLUMBERGER	J55	C396595	10-14-02	100.1	100.0	99.4
SCHLUMBERGER	J55	C396596	10-14-02	100.1	99.9	99.7
SCHLUMBERGER	J55	C396597	10-14-02	100.2	100.1	99.6
SCHLUMBERGER	J55	C396598	10-14-02	99.9	99.8	99.8
SCHLUMBERGER	J55	C396599	10-14-02	100.0	99.8	99.8
SCHLUMBERGER	J55	C396600	10-14-02	100.0	99.9	99.4
SCHLUMBERGER	J55	C396601	10-14-02	100.3	99.8	99.4
SCHLUMBERGER	J55	C396602	10-14-02	100.3	99.8	100.1
SCHLUMBERGER	J55	C396603	10-14-02	100.3	99.8	100.2
SCHLUMBERGER	J55	C396604	10-14-02	100.1	100.2	99.9
SCHLUMBERGER	J55	C396605	10-14-02	100.0	99.8	99.7
SCHLUMBERGER	J55	C396606	10-14-02	100.0	99.8	99.7
SCHLUMBERGER	J55	C396607	10-14-02	100.1	99.6	99.4
SCHLUMBERGER	J55	C396608	10-14-02	100.0	99.6	99.8
SCHLUMBERGER	J55	C396609	10-14-02	100.0	99.6	100.1
SCHLUMBERGER	J55	C396610	10-14-02	100.2	100.4	99.9
SCHLUMBERGER	J55	C396611	10-14-02	100.2	100.2	100.2
SCHLUMBERGER	J55	C396612	10-14-02	100.0	99.9	99.6
SCHLUMBERGER	J55	C396613	10-14-02	99.9	99.8	99.4
SCHLUMBERGER	J55	C396614	10-14-02	100.2	99.8	100.0
SCHLUMBERGER	J55	C396615	10-14-02	100.0	99.8	99.5
SCHLUMBERGER	J55	C396616	10-14-02	99.9	100.1	100.0
SCHLUMBERGER	J55	C396617	10-14-02	99.9	99.7	99.7

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

PAGE 232
 RUN DATE: 1/14/03
 RUN TIME: 13.26.53

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	J5S	C396616	10-14-02	100.0	99.7	99.5
SCHLUMBERGER	J5S	C396617	10-14-02	100.2	99.8	99.9
SCHLUMBERGER	J5S	C396618	10-14-02	100.2	100.0	99.3
SCHLUMBERGER	J5S	C396619	10-14-02	100.0	99.8	99.7
SCHLUMBERGER	J5S	C396620	10-14-02	100.2	99.9	99.7
SCHLUMBERGER	J5S	C396621	10-14-02	100.0	99.8	100.2
SCHLUMBERGER	J5S	C396622	10-14-02	99.9	99.6	99.4
SCHLUMBERGER	J5S	C396623	10-14-02	100.0	100.0	99.7
SCHLUMBERGER	J5S	C396624	10-14-02	100.1	100.1	100.3
SCHLUMBERGER	J5S	C396625	10-14-02	100.1	99.7	99.5
SCHLUMBERGER	J5S	C396626	10-14-02	100.1	99.7	99.6
SCHLUMBERGER	J5S	C396627	10-14-02	99.9	99.7	99.7
SCHLUMBERGER	J5S	C396628	10-14-02	100.1	99.6	99.8
SCHLUMBERGER	J5S	C396629	10-14-02	99.9	100.0	99.9
SCHLUMBERGER	J5S	C396630	10-14-02	100.1	100.0	99.5
SCHLUMBERGER	J5S	C396631	10-14-02	100.1	99.6	99.7
SCHLUMBERGER	J5S	C396632	10-14-02	100.0	99.6	99.5
SCHLUMBERGER	J5S	C396633	10-14-02	99.8	99.9	99.5
SCHLUMBERGER	J5S	C396634	10-14-02	100.0	99.8	100.0
SCHLUMBERGER	J5S	C396635	10-14-02	100.0	99.8	99.6
SCHLUMBERGER	J5S	C396636	10-14-02	99.9	99.7	99.5
SCHLUMBERGER	J5S	C396637	10-14-02	100.0	100.0	99.8
SCHLUMBERGER	J5S	C396638	10-14-02	99.9	99.7	99.5
SCHLUMBERGER	J5S	C396639	10-14-02	100.1	99.9	99.9
SCHLUMBERGER	J5S	C396640	10-14-02	100.0	99.7	99.4
SCHLUMBERGER	J5S	C396641	10-14-02	100.1	100.2	99.4
SCHLUMBERGER	J5S	C396642	10-14-02	100.1	99.9	100.2
SCHLUMBERGER	J5S	C396643	10-14-02	100.1	99.6	99.9
SCHLUMBERGER	J5S	C396644	10-14-02	100.0	99.8	99.6
SCHLUMBERGER	J5S	C396645	10-14-02	100.0	99.9	99.9
SCHLUMBERGER	J5S	C396646	10-14-02	100.1	100.1	99.7
SCHLUMBERGER	J5S	C396647	10-14-02	100.1	100.1	99.3
SCHLUMBERGER	J5S	C396648	10-14-02	100.0	99.6	99.3
SCHLUMBERGER	J5S	C396649	10-14-02	100.1	99.8	99.6
SCHLUMBERGER	J5S	C396650	10-14-02	100.0	99.9	99.5
SCHLUMBERGER	J5S	C396651	10-14-02	100.0	100.0	100.2
SCHLUMBERGER	J5S	C396652	10-14-02	100.1	100.2	99.3
SCHLUMBERGER	J5S	C396653	10-14-02	100.1	99.7	100.3
SCHLUMBERGER	J5S	C396654	10-14-02	100.1	100.1	99.5
SCHLUMBERGER	J5S	C396655	10-14-02	100.1	99.6	99.4
SCHLUMBERGER	J5S	C396656	10-14-02	99.9	100.0	99.4
SCHLUMBERGER	J5S	C396657	10-14-02	100.0	100.0	100.0
SCHLUMBERGER	J5S	C396658	10-14-02	99.9	99.7	99.4
SCHLUMBERGER	J5S	C396659	10-14-02	99.9	100.0	99.3
SCHLUMBERGER	J5S	C396660	10-14-02	99.9	99.9	99.8
SCHLUMBERGER	J5S	C396661	10-14-02	100.1	99.9	100.2
SCHLUMBERGER	J5S	C396662	10-14-02	100.0	99.8	99.6
SCHLUMBERGER	J5S	C396663	10-14-02	99.9	99.8	99.2
SCHLUMBERGER	J5S	C396664	10-14-02	100.1	99.9	99.9
SCHLUMBERGER	J5S	C396665	10-14-02	100.1	100.3	99.8
SCHLUMBERGER	J5S	C396666	10-14-02	99.8	99.8	99.5

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	J55	C396667	10-14-02	100.1	99.8	99.8
SCHLUMBERGER	J55	C396668	10-14-02	100.2	100.0	99.4
SCHLUMBERGER	J55	C396669	10-14-02	100.0	100.0	99.4
SCHLUMBERGER	J55	C396670	10-14-02	100.0	99.8	99.9
SCHLUMBERGER	J55	C396671	10-14-02	99.9	100.1	99.7
SCHLUMBERGER	J55	C396672	10-14-02	100.0	100.0	99.6
SCHLUMBERGER	J55	C396673	10-14-02	100.0	100.0	99.5
SCHLUMBERGER	J55	C396674	10-14-02	100.1	99.7	99.5
SCHLUMBERGER	J55	C396675	10-14-02	100.1	99.8	99.5
SCHLUMBERGER	J55	C396676	10-14-02	100.0	99.9	99.5
SCHLUMBERGER	J55	C396677	10-14-02	100.1	100.0	100.1
SCHLUMBERGER	J55	C396678	10-14-02	100.2	100.4	99.5
SCHLUMBERGER	J55	C396679	10-14-02	100.2	100.3	99.3
SCHLUMBERGER	J55	C396680	10-14-02	100.3	100.0	99.9
SCHLUMBERGER	J55	C396681	10-14-02	100.1	100.2	99.3
SCHLUMBERGER	J55	C396682	10-14-02	99.9	100.1	99.6
SCHLUMBERGER	J55	C396683	10-14-02	100.0	100.0	100.0
SCHLUMBERGER	J55	C396684	10-14-02	100.0	99.6	99.5
SCHLUMBERGER	J55	C396685	10-14-02	100.2	100.1	99.7
SCHLUMBERGER	J55	C396686	10-14-02	100.0	99.8	99.7
SCHLUMBERGER	J55	C396687	10-14-02	100.1	99.8	100.1
SCHLUMBERGER	J55	C396688	10-14-02	100.1	100.1	99.9
SCHLUMBERGER	J55	C396689	10-14-02	100.2	99.8	99.5
SCHLUMBERGER	J55	C396690	10-14-02	100.0	99.8	100.2
SCHLUMBERGER	J55	C396691	10-14-02	99.9	99.9	99.9
SCHLUMBERGER	J55	C396692	10-14-02	100.3	99.7	99.7
SCHLUMBERGER	J55	C396693	10-14-02	100.2	99.7	99.7
SCHLUMBERGER	J55	C396694	10-14-02	100.1	99.7	99.9
SCHLUMBERGER	J55	C396695	10-14-02	100.1	99.8	99.4
SCHLUMBERGER	J55	C396696	10-14-02	100.0	99.9	99.7
SCHLUMBERGER	J55	C396697	10-14-02	100.1	100.0	99.8
SCHLUMBERGER	J55	C396698	10-14-02	100.2	100.4	100.0
SCHLUMBERGER	J55	C396699	10-14-02	100.1	99.8	100.4
SCHLUMBERGER	J55	C396700	10-14-02	100.1	100.2	100.0
SCHLUMBERGER	J55	C396701	10-14-02	100.2	100.2	99.6
SCHLUMBERGER	J55	C396702	10-14-02	100.0	100.2	100.3
SCHLUMBERGER	J55	C396703	10-14-02	100.0	99.7	100.0
SCHLUMBERGER	J55	C396704	10-14-02	100.1	99.6	99.4
SCHLUMBERGER	J55	C396705	10-14-02	100.1	99.6	99.8
SCHLUMBERGER	J55	C396706	10-14-02	100.3	100.0	99.6
SCHLUMBERGER	J55	C396707	10-14-02	100.2	100.1	100.1
SCHLUMBERGER	J55	C396708	10-14-02	100.2	100.1	99.6
SCHLUMBERGER	J55	C396709	10-14-02	99.9	99.9	99.6
SCHLUMBERGER	J55	C396710	10-14-02	100.1	99.8	99.4
SCHLUMBERGER	J55	C396711	10-14-02	100.3	100.1	99.9
SCHLUMBERGER	J55	C396712	10-14-02	100.0	99.8	99.6
SCHLUMBERGER	J55	C396713	10-14-02	100.0	99.9	99.3
SCHLUMBERGER	J55	C396714	10-14-02	100.0	99.8	99.3
SCHLUMBERGER	J55	C396715	10-14-02	100.0	100.0	99.8
SCHLUMBERGER	J55	C396716	10-14-02	100.0	99.7	99.5
SCHLUMBERGER	J55	C396717	10-14-02	100.2	99.9	99.6

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

PAGE 234
 RUN DATE: 1/14/03
 RUN TIME: 13.26.53

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	J5S	C396718	10-14-02	100.1	99.8	99.3
SCHLUMBERGER	J5S	C396719	10-14-02	100.0	99.9	99.7
SCHLUMBERGER	J5S	C396720	10-14-02	100.0	99.6	99.6
SCHLUMBERGER	J5S	C396721	10-14-02	100.1	99.6	99.9
SCHLUMBERGER	J5S	C396722	10-14-02	100.1	100.1	99.3
SCHLUMBERGER	J5S	C396723	10-14-02	100.0	99.8	99.8
SCHLUMBERGER	J5S	C396724	10-14-02	100.2	99.8	99.6
SCHLUMBERGER	J5S	C396725	10-14-02	100.0	99.9	99.8
SCHLUMBERGER	J5S	C396726	10-14-02	100.2	99.8	99.4
SCHLUMBERGER	J5S	C396727	10-14-02	100.1	99.7	99.7
SCHLUMBERGER	J5S	C396728	10-14-02	100.1	99.7	100.1
SCHLUMBERGER	J5S	C396729	10-14-02	100.0	100.2	99.4
SCHLUMBERGER	J5S	C396730	10-14-02	100.1	100.2	99.6
SCHLUMBERGER	J5S	C396731	10-14-02	99.8	99.9	99.3
SCHLUMBERGER	J5S	C396732	10-14-02	100.0	99.9	99.9
SCHLUMBERGER	J5S	C396733	10-14-02	100.0	99.6	99.3
SCHLUMBERGER	J5S	C396734	10-14-02	100.0	99.8	99.7
SCHLUMBERGER	J5S	C396735	10-14-02	100.0	99.8	99.4
SCHLUMBERGER	J5S	C396736	10-14-02	100.1	99.9	99.8
SCHLUMBERGER	J5S	C396737	10-14-02	100.3	100.2	99.7
SCHLUMBERGER	J5S	C396738	10-14-02	100.1	99.9	100.0
SCHLUMBERGER	J5S	C396739	10-14-02	100.1	100.5	99.5
SCHLUMBERGER	J5S	C396740	10-14-02	100.0	99.8	99.5
SCHLUMBERGER	J5S	C396741	10-14-02	100.1	100.2	99.7
SCHLUMBERGER	J5S	C396742	10-14-02	100.1	99.8	99.6
SCHLUMBERGER	J5S	C396743	10-14-02	100.1	99.7	99.7
SCHLUMBERGER	J5S	C396744	10-14-02	100.0	100.1	99.6
SCHLUMBERGER	J5S	C396745	10-14-02	100.1	99.9	99.6
SCHLUMBERGER	J5S	C396746	10-14-02	100.1	99.9	99.5
SCHLUMBERGER	J5S	C396747	10-14-02	100.1	100.0	99.8
SCHLUMBERGER	J5S	C396748	10-14-02	100.1	100.3	99.6
SCHLUMBERGER	J5S	C396749	10-14-02	100.0	100.0	99.4
SCHLUMBERGER	J5S	C396750	10-14-02	100.1	99.8	99.7
SCHLUMBERGER	J5S	C396751	10-14-02	100.0	99.8	100.0
SCHLUMBERGER	J5S	C396752	10-14-02	100.1	99.9	99.4
SCHLUMBERGER	J5S	C396753	10-14-02	100.3	100.3	99.4
SCHLUMBERGER	J5S	C396754	10-14-02	100.1	99.7	99.7
SCHLUMBERGER	J5S	C396755	10-14-02	100.2	99.9	99.9
SCHLUMBERGER	J5S	C396756	10-14-02	100.0	99.8	99.5
SCHLUMBERGER	J5S	C396757	10-14-02	100.0	100.1	99.5
SCHLUMBERGER	J5S	C396758	10-14-02	100.0	99.9	99.6
SCHLUMBERGER	J5S	C396759	10-14-02	99.9	99.9	99.8
SCHLUMBERGER	J5S	C396760	10-14-02	99.9	99.9	99.6
SCHLUMBERGER	J5S	C396761	10-14-02	100.2	99.7	99.5
SCHLUMBERGER	J5S	C396762	10-14-02	100.3	100.5	99.6
SCHLUMBERGER	J5S	C396763	10-14-02	99.9	100.0	100.2
SCHLUMBERGER	J5S	C396764	10-14-02	100.0	99.9	100.4
SCHLUMBERGER	J5S	C396765	10-14-02	100.0	99.8	100.3
SCHLUMBERGER	J5S	C396766	10-14-02	100.3	99.8	99.7
SCHLUMBERGER	J5S	C396767	10-14-02	100.0	99.9	99.6
SCHLUMBERGER	J5S	C396768	10-14-02	100.1	100.2	99.4

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

PAGE 235
 RUN DATE: 1/14/03
 RUN TIME: 13.26.53

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	J5S	C396769	10-14-02	100.1	99.7	99.4
SCHLUMBERGER	J5S	C396770	10-14-02	100.2	100.1	100.3
SCHLUMBERGER	J5S	C396771	10-14-02	99.9	99.8	99.7
SCHLUMBERGER	J5S	C396772	10-14-02	100.1	99.8	99.4
SCHLUMBERGER	J5S	C396773	10-14-02	100.1	100.0	99.4
SCHLUMBERGER	J5S	C396774	10-14-02	100.0	100.0	99.4
SCHLUMBERGER	J5S	C396775	10-14-02	100.0	100.1	99.7
SCHLUMBERGER	J5S	C396776	10-14-02	100.0	99.8	99.9
SCHLUMBERGER	J5S	C396777	10-14-02	100.3	99.9	99.9
SCHLUMBERGER	J5S	C396778	10-14-02	99.8	100.3	99.4
SCHLUMBERGER	J5S	C396779	10-14-02	100.1	99.8	99.9
SCHLUMBERGER	J5S	C396780	10-14-02	100.1	99.6	99.9
SCHLUMBERGER	J5S	C396781	10-14-02	100.3	100.4	100.4
SCHLUMBERGER	J5S	C396782	10-14-02	100.0	100.0	99.5
SCHLUMBERGER	J5S	C396783	10-14-02	100.0	99.7	99.4
SCHLUMBERGER	J5S	C396784	10-14-02	100.3	100.2	99.8
SCHLUMBERGER	J5S	C396785	10-14-02	100.0	99.8	99.6
SCHLUMBERGER	J5S	C396786	10-14-02	99.9	100.0	99.4
SCHLUMBERGER	J5S	C396787	10-14-02	100.1	99.9	100.0
SCHLUMBERGER	J5S	C396788	10-14-02	100.1	99.8	99.6
SCHLUMBERGER	J5S	C396789	10-14-02	100.0	99.7	99.4
SCHLUMBERGER	J5S	C396791	10-14-02	99.9	99.9	99.4
SCHLUMBERGER	J5S	C396792	10-14-02	100.1	100.2	100.1
SCHLUMBERGER	J5S	C396793	10-14-02	100.2	99.7	100.0
SCHLUMBERGER	J5S	C396794	10-14-02	100.1	99.8	99.3
SCHLUMBERGER	J5S	C396795	10-14-02	100.3	99.9	100.0
SCHLUMBERGER	J5S	C396796	10-14-02	100.0	100.1	99.7
SCHLUMBERGER	J5S	C396797	10-14-02	100.0	100.0	99.5
SCHLUMBERGER	J5S	C396798	10-14-02	100.2	99.7	99.8
SCHLUMBERGER	J5S	C396799	10-14-02	100.0	99.7	99.3
SCHLUMBERGER	J5S	C396800	10-14-02	100.1	99.6	100.1
SCHLUMBERGER	J5S	C396801	10-14-02	100.3	99.8	99.7
SCHLUMBERGER	J5S	C396802	10-14-02	100.1	99.9	100.3
SCHLUMBERGER	J5S	C396803	10-14-02	100.0	99.9	100.0
SCHLUMBERGER	J5S	C396804	10-14-02	100.1	100.0	1
SCHLUMBERGER	J5S	C396805	10-14-02	100.1	99.8	99.5
SCHLUMBERGER	J5S	C396806	10-14-02	100.0	99.9	99.6
SCHLUMBERGER	J5S	C396807	10-14-02	100.1	100.0	99.5
SCHLUMBERGER	J5S	C396808	10-14-02	100.0	99.8	99.5
SCHLUMBERGER	J5S	C396809	10-14-02	100.3	99.8	99.5
SCHLUMBERGER	J5S	C396810	10-14-02	100.0	100.1	100.1
SCHLUMBERGER	J5S	C396811	10-14-02	100.3	99.7	100.0
SCHLUMBERGER	J5S	C396812	10-14-02	100.1	99.7	100.0
SCHLUMBERGER	J5S	C396813	10-14-02	100.1	99.6	99.6
SCHLUMBERGER	J5S	C396814	10-14-02	100.2	99.8	99.8
SCHLUMBERGER	J5S	C396815	10-14-02	100.1	99.9	100.4
SCHLUMBERGER	J5S	C396816	10-14-02	100.1	99.8	99.3
SCHLUMBERGER	J5S	C396817	10-14-02	100.2	99.8	99.8
SCHLUMBERGER	J5S	C396818	10-14-02	100.0	99.9	100.3
SCHLUMBERGER	J5S	C396819	10-14-02	100.1	99.8	99.5
SCHLUMBERGER	J5S	C396819	10-14-02	100.1	100.1	99.8

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

PAGE 236
 RUN DATE: 1/14/03
 RUN TIME: 13.26.53

MANUFACTURER	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	C396820	10-14-02	100.1	99.7	99.7
SCHLUMBERGER	C396821	10-14-02	99.9	99.7	99.5
SCHLUMBERGER	C396822	10-14-02	100.3	100.3	100.0
SCHLUMBERGER	C396823	10-14-02	100.3	99.7	99.9
SCHLUMBERGER	C396824	10-14-02	100.1	99.6	99.6
SCHLUMBERGER	C396825	10-14-02	100.0	99.9	99.8
SCHLUMBERGER	C396826	10-14-02	100.0	99.7	99.9
SCHLUMBERGER	C396827	10-14-02	100.2	99.6	100.2
SCHLUMBERGER	C396828	10-14-02	100.0	99.7	99.7
SCHLUMBERGER	C396829	10-14-02	100.2	99.7	99.6
SCHLUMBERGER	C396830	10-14-02	100.2	99.8	99.7
SCHLUMBERGER	C396831	10-14-02	99.9	99.9	99.7
SCHLUMBERGER	C396832	10-14-02	99.8	99.6	99.3
SCHLUMBERGER	C396833	10-14-02	100.2	100.5	100.5
SCHLUMBERGER	C396834	10-14-02	100.3	99.7	100.1
SCHLUMBERGER	C396835	10-14-02	100.3	99.9	100.5
SCHLUMBERGER	C396836	10-14-02	100.1	100.0	100.1
SCHLUMBERGER	C396837	10-14-02	100.1	99.7	99.9
SCHLUMBERGER	C396838	10-14-02	100.1	99.8	99.5
SCHLUMBERGER	C396839	10-14-02	100.1	99.8	100.1
SCHLUMBERGER	C396840	10-14-02	99.9	99.6	99.5
SCHLUMBERGER	C396841	10-14-02	100.0	99.9	99.7
SCHLUMBERGER	C396842	10-14-02	100.0	100.0	99.7
SCHLUMBERGER	C396843	10-14-02	100.0	100.2	99.5
SCHLUMBERGER	C396844	10-14-02	100.0	100.0	99.3
SCHLUMBERGER	C396845	10-14-02	100.0	99.6	99.5
SCHLUMBERGER	C396846	10-14-02	100.2	99.9	99.9
SCHLUMBERGER	C396847	10-14-02	100.1	99.7	100.1
SCHLUMBERGER	C396848	10-14-02	100.0	99.7	99.4
SCHLUMBERGER	C396849	10-14-02	100.0	100.2	99.8
SCHLUMBERGER	C396850	10-14-02	100.0	99.6	99.8
SCHLUMBERGER	C396851	10-14-02	100.0	99.7	99.8
SCHLUMBERGER	C396852	10-14-02	100.1	99.7	99.8
SCHLUMBERGER	C396853	10-14-02	100.1	99.8	99.7
SCHLUMBERGER	C396854	10-14-02	99.9	99.9	99.8
SCHLUMBERGER	C396855	10-14-02	100.3	99.7	100.4
SCHLUMBERGER	C396856	10-14-02	100.3	99.7	99.8
SCHLUMBERGER	C396857	10-14-02	100.2	99.9	100.3
SCHLUMBERGER	C396858	10-14-02	100.1	99.8	99.7
SCHLUMBERGER	C396859	10-14-02	99.9	99.6	99.7
SCHLUMBERGER	C396860	10-14-02	100.0	99.9	99.5
SCHLUMBERGER	C396861	10-14-02	100.0	99.8	99.9
SCHLUMBERGER	C396862	10-14-02	100.3	99.8	99.9
SCHLUMBERGER	C396863	10-14-02	100.1	100.0	99.4
SCHLUMBERGER	C396864	10-14-02	100.1	99.7	99.8
SCHLUMBERGER	C396865	10-14-02	99.9	99.7	100.1
SCHLUMBERGER	C396866	10-14-02	100.2	99.9	99.9
SCHLUMBERGER	C396867	10-14-02	99.9	99.7	100.0
SCHLUMBERGER	C396868	10-14-02	100.1	99.8	99.7
SCHLUMBERGER	C396869	10-14-02	100.2	99.8	99.8
SCHLUMBERGER	C396870	10-14-02	100.3	99.9	100.1
SCHLUMBERGER					99.9

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	J55	C396871	10-14-02	100.1	99.9	99.8
SCHLUMBERGER	J55	C396872	10-14-02	99.8	99.8	99.5
SCHLUMBERGER	J55	C396873	10-14-02	100.1	99.7	100.0
SCHLUMBERGER	J55	C396874	10-14-02	100.3	100.2	99.9
SCHLUMBERGER	J55	C396875	10-14-02	100.1	99.9	99.5
SCHLUMBERGER	J55	C396876	10-14-02	99.9	99.6	99.7
SCHLUMBERGER	J55	C396877	10-14-02	100.2	99.8	100.1
SCHLUMBERGER	J55	C396878	10-14-02	100.3	100.1	100.1
SCHLUMBERGER	J55	C396879	10-14-02	100.0	99.9	99.8
SCHLUMBERGER	J55	C396880	10-14-02	100.1	99.8	99.6
SCHLUMBERGER	J55	C396881	10-14-02	100.0	99.9	99.6
SCHLUMBERGER	J55	C396882	10-14-02	99.9	99.6	100.1
SCHLUMBERGER	J55	C396883	10-14-02	100.1	99.7	99.6
SCHLUMBERGER	J55	C396884	10-14-02	99.7	99.6	99.3
SCHLUMBERGER	J55	C396885	10-14-02	100.1	99.9	99.8
SCHLUMBERGER	J55	C396886	10-14-02	100.0	100.0	99.8
SCHLUMBERGER	J55	C396887	10-14-02	100.3	99.9	100.2
SCHLUMBERGER	J55	C396888	10-14-02	100.3	100.2	99.8
SCHLUMBERGER	J55	C396889	10-14-02	100.3	99.6	100.1
SCHLUMBERGER	J55	C396890	10-14-02	99.9	99.8	99.6
SCHLUMBERGER	J55	C396891	10-14-02	100.0	99.6	99.6
SCHLUMBERGER	J55	C396892	10-14-02	100.0	99.7	99.6
SCHLUMBERGER	J55	C396893	10-14-02	1	99.6	99.6
SCHLUMBERGER	J55	C396894	10-14-02	100.0	99.7	99.5
SCHLUMBERGER	J55	C396895	10-14-02	99.9	99.7	99.8
SCHLUMBERGER	J55	C396896	10-14-02	100.1	100.0	99.7
SCHLUMBERGER	J55	C396897	10-14-02	100.1	99.8	99.3
SCHLUMBERGER	J55	C396898	10-14-02	100.3	100.0	99.9
SCHLUMBERGER	J55	C396899	10-14-02	99.9	99.7	99.5
SCHLUMBERGER	J55	C396900	10-14-02	100.0	99.8	100.0
SCHLUMBERGER	J55	C396901	10-14-02	100.0	99.7	99.6
SCHLUMBERGER	J55	C396902	10-14-02	100.0	99.7	99.7
SCHLUMBERGER	J55	C396903	10-14-02	100.1	99.7	99.9
SCHLUMBERGER	J55	C396904	10-14-02	100.1	100.1	99.9
SCHLUMBERGER	J55	C396905	10-14-02	100.1	100.2	100.2
SCHLUMBERGER	J55	C396906	10-14-02	99.9	100.1	99.7
SCHLUMBERGER	J55	C396907	10-14-02	100.0	99.8	99.6
SCHLUMBERGER	J55	C396908	10-14-02	100.0	99.8	99.6
SCHLUMBERGER	J55	C396909	10-14-02	100.0	100.0	99.6
SCHLUMBERGER	J55	C396910	10-14-02	100.0	99.8	100.0
SCHLUMBERGER	J55	C396911	10-14-02	100.0	99.7	99.8
SCHLUMBERGER	J55	C396912	10-14-02	100.3	99.8	100.0
SCHLUMBERGER	J55	C396913	10-14-02	100.2	99.8	100.0
SCHLUMBERGER	J55	C396914	10-14-02	100.1	100.0	99.8
SCHLUMBERGER	J55	C396915	10-14-02	100.0	99.9	99.6
SCHLUMBERGER	J55	C396916	10-14-02	100.0	99.6	99.7
SCHLUMBERGER	J55	C396917	10-14-02	100.0	100.1	99.5
SCHLUMBERGER	J55	C396918	10-14-02	99.9	99.9	99.3
SCHLUMBERGER	J55	C396919	10-14-02	100.1	99.9	99.8
SCHLUMBERGER	J55	C396920	10-14-02	100.1	99.9	99.8
SCHLUMBERGER	J55	C396921	10-14-02	100.0	99.7	100.1
SCHLUMBERGER	J55	C396922	10-14-02	100.0	99.7	99.7

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

PAGE 238
 RUN DATE: 1/14/03
 RUN TIME: 13.26.53

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	J5S	C396922	10-14-02	100.3	100.0	100.0
SCHLUMBERGER	J5S	C396923	10-14-02	100.1	99.8	99.8
SCHLUMBERGER	J5S	C396924	10-14-02	100.0	99.7	99.8
SCHLUMBERGER	J5S	C396925	10-14-02	100.1	99.6	99.7
SCHLUMBERGER	J5S	C396926	10-14-02	99.8	99.9	99.6
SCHLUMBERGER	J5S	C396927	10-14-02	100.0	99.6	99.8
SCHLUMBERGER	J5S	C396928	10-14-02	99.9	99.9	99.5
SCHLUMBERGER	J5S	C396929	10-14-02	100.1	99.9	99.6
SCHLUMBERGER	J5S	C396930	10-14-02	100.1	99.9	100.2
SCHLUMBERGER	J5S	C396931	10-14-02	99.9	99.9	99.7
SCHLUMBERGER	J5S	C396932	10-14-02	99.9	99.9	99.4
SCHLUMBERGER	J5S	C396933	10-14-02	100.1	99.7	99.3
SCHLUMBERGER	J5S	C396934	10-14-02	99.9	99.8	99.5
SCHLUMBERGER	J5S	C396935	10-14-02	100.1	99.7	100.2
SCHLUMBERGER	J5S	C396936	10-14-02	100.1	99.8	99.9
SCHLUMBERGER	J5S	C396937	10-14-02	100.1	99.6	99.6
SCHLUMBERGER	J5S	C396938	10-14-02	100.1	99.7	100.0
SCHLUMBERGER	J5S	C396939	10-14-02	100.3	100.2	99.9
SCHLUMBERGER	J5S	C396940	10-14-02	100.3	100.1	100.3
SCHLUMBERGER	J5S	C396941	10-14-02	100.2	99.9	100.3
SCHLUMBERGER	J5S	C396942	10-14-02	100.0	99.6	99.4
SCHLUMBERGER	J5S	C396943	10-14-02	100.1	99.7	100.0
SCHLUMBERGER	J5S	C396944	10-14-02	100.0	99.9	99.7
SCHLUMBERGER	J5S	C396945	10-14-02	99.9	99.7	99.8
SCHLUMBERGER	J5S	C396946	10-14-02	100.0	99.8	100.2
SCHLUMBERGER	J5S	C396947	10-14-02	100.1	99.8	100.1
SCHLUMBERGER	J5S	C396948	10-14-02	100.0	99.7	100.0
SCHLUMBERGER	J5S	C396949	10-14-02	100.1	99.9	99.7
SCHLUMBERGER	J5S	C396950	10-14-02	100.1	99.8	99.9
SCHLUMBERGER	J5S	C396951	10-14-02	100.0	99.7	99.9
SCHLUMBERGER	J5S	C396952	10-14-02	100.0	99.8	99.8
SCHLUMBERGER	J5S	C396953	10-14-02	100.2	99.7	99.5
SCHLUMBERGER	J5S	C396954	10-14-02	100.0	99.9	99.8
SCHLUMBERGER	J5S	C396955	10-14-02	100.1	99.9	100.0
SCHLUMBERGER	J5S	C396956	10-14-02	100.2	99.7	99.9
SCHLUMBERGER	J5S	C396957	10-14-02	100.2	99.7	99.8
SCHLUMBERGER	J5S	C396958	10-14-02	100.1	99.7	99.7
SCHLUMBERGER	J5S	C396959	10-14-02	100.1	100.0	99.7
SCHLUMBERGER	J5S	C396960	10-14-02	100.3	100.3	100.1
SCHLUMBERGER	J5S	C396961	10-14-02	99.8	100.2	99.6
SCHLUMBERGER	J5S	C396962	10-14-02	99.9	99.6	99.7
SCHLUMBERGER	J5S	C396963	10-14-02	100.0	100.2	99.3
SCHLUMBERGER	J5S	C396964	10-14-02	99.9	99.7	100.1
SCHLUMBERGER	J5S	C396965	10-14-02	100.1	99.8	99.8
SCHLUMBERGER	J5S	C396966	10-14-02	100.2	100.0	100.1
SCHLUMBERGER	J5S	C396967	10-14-02	100.1	99.6	99.9
SCHLUMBERGER	J5S	C396968	10-14-02	100.0	100.0	99.9
SCHLUMBERGER	J5S	C396969	10-14-02	99.9	99.7	99.4
SCHLUMBERGER	J5S	C396970	10-14-02	100.2	99.8	100.2
SCHLUMBERGER	J5S	C396971	10-14-02	100.1	99.7	100.3
SCHLUMBERGER	J5S	C396972	10-14-02	100.2	100.1	99.8

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	J5S	C396973	10-14-02	100.0	99.6	99.7
SCHLUMBERGER	J5S	C396974	10-14-02	100.0	99.9	99.8
SCHLUMBERGER	J5S	C396975	10-14-02	100.0	100.0	100.3
SCHLUMBERGER	J5S	C396976	10-14-02	99.8	99.8	99.6
SCHLUMBERGER	J5S	C396977	10-14-02	100.0	99.8	100.2
SCHLUMBERGER	J5S	C396978	10-14-02	100.1	99.8	100.3
SCHLUMBERGER	J5S	C396979	10-14-02	100.1	99.7	99.7
SCHLUMBERGER	J5S	C396980	10-14-02	100.0	99.8	100.0
SCHLUMBERGER	J5S	C396981	10-14-02	100.2	99.8	99.5
SCHLUMBERGER	J5S	C396982	10-14-02	100.1	99.7	99.3
SCHLUMBERGER	J5S	C396983	10-14-02	100.1	99.8	99.6
SCHLUMBERGER	J5S	C396984	10-14-02	100.1	99.9	99.6
SCHLUMBERGER	J5S	C396985	10-14-02	100.1	99.7	100.4
SCHLUMBERGER	J5S	C396986	10-14-02	100.1	99.7	99.6
SCHLUMBERGER	J5S	C396987	10-14-02	99.9	99.8	100.2
SCHLUMBERGER	J5S	C396988	10-14-02	99.9	99.8	99.8
SCHLUMBERGER	J5S	C396989	10-14-02	99.9	99.7	99.4
SCHLUMBERGER	J5S	C396990	10-14-02	100.2	99.8	100.0
SCHLUMBERGER	J5S	C396991	10-14-02	99.8	99.6	99.7
SCHLUMBERGER	J5S	C396992	10-14-02	100.0	99.6	99.7
SCHLUMBERGER	J5S	C396993	10-14-02	100.1	99.8	100.2
SCHLUMBERGER	J5S	C396994	10-14-02	100.0	100.4	99.3
SCHLUMBERGER	J5S	C396995	10-14-02	99.9	99.9	99.8
SCHLUMBERGER	J5S	C396996	10-14-02	100.0	99.9	99.7
SCHLUMBERGER	J5S	C396997	10-14-02	100.1	100.4	99.5
SCHLUMBERGER	J5S	C396998	10-14-02	100.1	100.0	99.7
SCHLUMBERGER	J5S	C396999	10-14-02	100.2	100.0	100.3
SCHLUMBERGER	J5S	C397000	10-14-02	100.0	99.9	100.0
SCHLUMBERGER	J5S	C397001	10-14-02	100.0	99.8	99.4
SCHLUMBERGER	J5S	C397002	10-14-02	99.9	99.8	99.9
SCHLUMBERGER	J5S	C397003	10-14-02	100.2	99.9	100.2
SCHLUMBERGER	J5S	C397004	10-14-02	100.0	99.9	100.0
SCHLUMBERGER	J5S	C397005	10-14-02	100.0	100.1	100.1
SCHLUMBERGER	J5S	C397006	10-14-02	100.1	99.9	100.0
SCHLUMBERGER	J5S	C397007	10-14-02	100.0	99.8	99.8
SCHLUMBERGER	J5S	C397008	10-14-02	100.1	99.7	99.7
SCHLUMBERGER	J5S	C397009	10-14-02	99.9	99.7	99.7
SCHLUMBERGER	J5S	C397010	10-14-02	100.0	99.8	99.8
SCHLUMBERGER	J5S	C397011	10-14-02	100.0	99.7	99.6
SCHLUMBERGER	J5S	C397012	10-14-02	100.1	100.1	100.0
SCHLUMBERGER	J5S	C397013	10-14-02	100.2	99.7	100.0
SCHLUMBERGER	J5S	C397014	10-14-02	99.9	99.7	100.0
SCHLUMBERGER	J5S	C397015	10-14-02	100.2	99.8	100.0
SCHLUMBERGER	J5S	C397016	10-14-02	100.0	99.7	100.0
SCHLUMBERGER	J5S	C397017	10-14-02	100.0	99.7	99.8
SCHLUMBERGER	J5S	C397018	10-14-02	100.3	100.1	100.3
SCHLUMBERGER	J5S	C397019	10-14-02	100.1	99.7	100.2
SCHLUMBERGER	J5S	C397020	10-14-02	100.0	99.9	99.9
SCHLUMBERGER	J5S	C397021	10-14-02	100.2	100.1	99.9
SCHLUMBERGER	J5S	C397022	10-14-02	100.0	100.2	99.8
SCHLUMBERGER	J5S	C397023	10-14-02	100.1	99.7	99.6

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

PAGE 240
 RUN DATE: 1/14/03
 RUN TIME: 13.26.53

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	J55	C397024	10-14-02	100.0	99.9	100.0
SCHLUMBERGER	J55	C397025	10-14-02	100.2	100.2	100.1
SCHLUMBERGER	J55	C397026	10-14-02	99.9	99.6	99.6
SCHLUMBERGER	J55	C397027	10-14-02	100.0	100.0	99.7
SCHLUMBERGER	J55	C397028	10-14-02	100.0	99.7	99.9
SCHLUMBERGER	J55	C397029	10-14-02	100.1	99.7	100.3
SCHLUMBERGER	J55	C397030	10-14-02	100.0	99.9	100.2
SCHLUMBERGER	J55	C397031	10-14-02	100.0	99.9	100.0
SCHLUMBERGER	J55	C397032	10-14-02	100.2	100.0	100.1
SCHLUMBERGER	J55	C397033	10-14-02	100.1	99.7	100.0
SCHLUMBERGER	J55	C397034	10-14-02	100.2	99.9	99.9
SCHLUMBERGER	J55	C397035	10-14-02	100.2	100.0	100.0
SCHLUMBERGER	J55	C397036	10-14-02	100.1	99.7	100.0
SCHLUMBERGER	J55	C397037	10-14-02	100.2	99.9	100.4
SCHLUMBERGER	J55	C397038	10-14-02	100.1	99.7	100.1
SCHLUMBERGER	J55	C397039	10-14-02	99.9	100.0	100.0
SCHLUMBERGER	J55	C397040	10-14-02	100.1	100.0	99.7
SCHLUMBERGER	J55	C397041	10-14-02	100.0	100.0	100.0
SCHLUMBERGER	J55	C397042	10-14-02	100.0	99.7	99.7
SCHLUMBERGER	J55	C397043	10-14-02	99.9	99.6	99.8
SCHLUMBERGER	J55	C397044	10-14-02	99.9	99.7	99.8
SCHLUMBERGER	J55	C397045	10-14-02	99.8	99.7	99.6
SCHLUMBERGER	J55	C397046	10-14-02	99.8	99.6	99.8
SCHLUMBERGER	J55	C397047	10-14-02	100.2	99.8	100.0
SCHLUMBERGER	J55	C397048	10-14-02	99.9	99.7	99.7
SCHLUMBERGER	J55	C397049	10-14-02	100.1	99.9	100.1
SCHLUMBERGER	J55	C397050	10-14-02	100.1	99.9	100.3
SCHLUMBERGER	J55	C397051	10-14-02	100.0	100.0	99.8
SCHLUMBERGER	J55	C397052	10-14-02	100.1	100.1	100.2
SCHLUMBERGER	J55	C397053	10-14-02	100.1	99.7	99.8
SCHLUMBERGER	J55	C397054	10-14-02	100.1	99.6	99.5
SCHLUMBERGER	J55	C397055	10-14-02	100.1	99.7	99.6
SCHLUMBERGER	J55	C397056	10-14-02	100.0	99.8	99.6
SCHLUMBERGER	J55	C397057	10-14-02	100.0	99.8	99.8
SCHLUMBERGER	J55	C397058	10-14-02	100.0	99.7	100.0
SCHLUMBERGER	J55	C397059	10-14-02	100.0	99.8	99.8
SCHLUMBERGER	J55	C397060	10-14-02	100.0	99.8	100.0
SCHLUMBERGER	J55	C397061	10-14-02	100.1	100.2	99.5
SCHLUMBERGER	J55	C397062	10-14-02	100.0	99.7	100.0
SCHLUMBERGER	J55	C397063	10-14-02	99.9	99.8	99.6
SCHLUMBERGER	J55	C397064	10-14-02	100.0	99.7	99.5
SCHLUMBERGER	J55	C397065	10-14-02	100.2	99.8	99.9
SCHLUMBERGER	J55	C397066	10-14-02	99.8	99.8	99.3
SCHLUMBERGER	J55	C397067	10-14-02	99.9	99.7	99.8
SCHLUMBERGER	J55	C397068	10-14-02	100.0	99.7	100.3
SCHLUMBERGER	J55	C397069	10-14-02	100.1	99.8	99.8
SCHLUMBERGER	J55	C397070	10-14-02	100.2	100.3	100.2
SCHLUMBERGER	J55	C397071	10-14-02	100.2	100.3	99.6
SCHLUMBERGER	J55	C397072	10-14-02	100.1	100.3	100.4
SCHLUMBERGER	J55	C397073	10-14-02	99.9	99.8	99.8
SCHLUMBERGER	J55	C397074	10-14-02	100.1	99.7	99.6

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	J55	C397075	10-14-02	100.1	99.6	100.0
SCHLUMBERGER	J55	C397076	10-14-02	100.1	99.9	100.3
SCHLUMBERGER	J55	C397077	10-14-02	99.9	99.7	99.5
SCHLUMBERGER	J55	C397078	10-14-02	100.0	99.9	99.6
SCHLUMBERGER	J55	C397079	10-14-02	100.0	99.8	99.9
SCHLUMBERGER	J55	C397080	10-14-02	100.1	99.8	100.2
SCHLUMBERGER	J55	C397081	10-14-02	99.9	99.7	100.0
SCHLUMBERGER	J55	C397082	10-14-02	99.8	99.9	99.7
SCHLUMBERGER	J55	C397083	10-14-02	100.1	99.8	100.2
SCHLUMBERGER	J55	C397084	10-14-02	100.2	99.7	100.2
SCHLUMBERGER	J55	C397085	10-14-02	100.1	100.2	100.0
SCHLUMBERGER	J55	C397086	10-14-02	100.0	100.0	100.0
SCHLUMBERGER	J55	C397087	10-14-02	100.0	99.9	99.9
SCHLUMBERGER	J55	C397088	10-14-02	100.0	99.7	100.2
SCHLUMBERGER	J55	C397089	10-14-02	100.1	99.9	99.5
SCHLUMBERGER	J55	C397090	10-14-02	100.0	99.8	99.4
SCHLUMBERGER	J55	C397091	10-14-02	100.1	99.6	99.9
SCHLUMBERGER	J55	C397092	10-14-02	99.9	99.9	100.0
SCHLUMBERGER	J55	C397093	10-14-02	100.3	100.1	100.0
SCHLUMBERGER	J55	C397094	10-14-02	100.1	99.8	100.0
SCHLUMBERGER	J55	C397095	10-14-02	100.0	99.7	100.2
SCHLUMBERGER	J55	C397096	10-14-02	100.0	99.9	99.7
SCHLUMBERGER	J55	C397097	10-14-02	99.9	99.7	99.8
SCHLUMBERGER	J55	C397098	10-14-02	100.3	99.8	99.7
SCHLUMBERGER	J55	C397099	10-14-02	100.1	99.8	99.7
SCHLUMBERGER	J55	C397100	10-14-02	100.2	99.7	99.7
SCHLUMBERGER	J55	C397101	10-14-02	100.0	99.7	100.0
SCHLUMBERGER	J55	C397102	10-14-02	100.0	99.7	99.6
SCHLUMBERGER	J55	C397103	10-14-02	100.1	99.9	100.1
SCHLUMBERGER	J55	C397104	10-14-02	100.2	99.7	100.2
SCHLUMBERGER	J55	C397105	10-14-02	100.1	99.9	100.0
SCHLUMBERGER	J55	C397106	10-14-02	100.0	99.8	99.6
SCHLUMBERGER	J55	C397107	10-14-02	100.0	99.8	99.6
SCHLUMBERGER	J55	C397108	10-14-02	100.1	99.8	100.0
SCHLUMBERGER	J55	C397109	10-14-02	100.0	99.8	100.1
SCHLUMBERGER	J55	C397110	10-14-02	100.2	99.9	100.0
SCHLUMBERGER	J55	C397111	10-14-02	100.1	99.9	100.1
SCHLUMBERGER	J55	C397112	10-14-02	99.9	99.7	99.5
SCHLUMBERGER	J55	C397113	10-14-02	99.9	99.7	99.9
SCHLUMBERGER	J55	C397114	10-14-02	100.1	99.9	100.1
SCHLUMBERGER	J55	C397115	10-14-02	100.0	99.9	99.9
SCHLUMBERGER	J55	C397116	10-14-02	100.1	99.9	100.0
SCHLUMBERGER	J55	C397117	10-14-02	100.1	99.8	100.1
SCHLUMBERGER	J55	C397118	10-14-02	99.8	99.7	99.4
SCHLUMBERGER	J55	C397119	10-14-02	100.3	99.9	99.9
SCHLUMBERGER	J55	C397120	10-14-02	100.0	99.7	99.8
SCHLUMBERGER	J55	C397121	10-14-02	100.1	99.8	99.5
SCHLUMBERGER	J55	C397122	10-14-02	100.0	100.2	99.7
SCHLUMBERGER	J55	C397123	10-14-02	100.0	100.0	99.8
SCHLUMBERGER	J55	C397124	10-14-02	100.1	99.9	100.0
SCHLUMBERGER	J55	C397125	10-14-02	100.1	100.2	100.0

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

PAGE 242
 RUN DATE: 1/14/03
 RUN TIME: 13.26.53

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	J5S	C397126	10-10-02	99.8	99.9	99.5
SCHLUMBERGER	J5S	C397127	10-10-02	100.2	99.7	99.7
SCHLUMBERGER	J5S	C397128	10-10-02	100.0	100.5	100.1
SCHLUMBERGER	J5S	C397129	10-10-02	100.0	99.6	99.8
SCHLUMBERGER	J5S	C397130	10-10-02	100.1	100.0	99.9
SCHLUMBERGER	J5S	C397131	10-10-02	100.2	99.8	100.1
SCHLUMBERGER	J5S	C397132	10-10-02	100.2	100.0	100.2
SCHLUMBERGER	J5S	C397133	10-10-02	99.9	100.2	99.6
SCHLUMBERGER	J5S	C397134	10-10-02	100.1	99.8	100.0
SCHLUMBERGER	J5S	C397135	10-10-02	100.1	100.1	100.3
SCHLUMBERGER	J5S	C397136	10-10-02	100.1	99.9	100.1
SCHLUMBERGER	J5S	C397137	10-10-02	100.1	100.4	99.8
SCHLUMBERGER	J5S	C397138	10-10-02	100.1	99.7	99.9
SCHLUMBERGER	J5S	C397139	10-10-02	100.0	100.1	100.2
SCHLUMBERGER	J5S	C397140	10-10-02	100.2	100.1	100.0
SCHLUMBERGER	J5S	C397141	10-10-02	100.1	99.8	99.8
SCHLUMBERGER	J5S	C397142	10-10-02	100.2	99.9	99.9
SCHLUMBERGER	J5S	C397143	10-10-02	100.1	99.7	99.7
SCHLUMBERGER	J5S	C397144	10-10-02	100.2	99.8	100.0
SCHLUMBERGER	J5S	C397145	10-10-02	100.3	99.7	99.7
SCHLUMBERGER	J5S	C397146	10-10-02	99.8	99.7	99.7
SCHLUMBERGER	J5S	C397147	10-10-02	99.9	99.8	99.8
SCHLUMBERGER	J5S	C397148	10-10-02	100.1	100.1	100.1
SCHLUMBERGER	J5S	C397149	10-10-02	100.0	99.7	99.7
SCHLUMBERGER	J5S	C397150	10-10-02	100.0	99.7	99.8
SCHLUMBERGER	J5S	C397151	10-10-02	100.0	99.6	99.8
SCHLUMBERGER	J5S	C397152	10-10-02	99.9	100.0	99.5
SCHLUMBERGER	J5S	C397153	10-10-02	100.3	99.9	99.9
SCHLUMBERGER	J5S	C397154	10-10-02	100.1	99.9	100.3
SCHLUMBERGER	J5S	C397155	10-10-02	100.1	100.0	99.7
SCHLUMBERGER	J5S	C397156	10-10-02	100.0	99.9	99.9
SCHLUMBERGER	J5S	C397157	10-10-02	100.0	99.7	99.8
SCHLUMBERGER	J5S	C397158	10-10-02	100.3	100.0	100.2
SCHLUMBERGER	J5S	C397159	10-10-02	100.2	99.8	99.7
SCHLUMBERGER	J5S	C397160	10-10-02	100.1	99.7	100.2
SCHLUMBERGER	J5S	C397161	10-10-02	100.1	99.7	99.6
SCHLUMBERGER	J5S	C397162	10-10-02	100.1	99.9	100.1
SCHLUMBERGER	J5S	C397163	10-10-02	100.3	100.0	100.0
SCHLUMBERGER	J5S	C397164	10-10-02	100.0	99.7	99.8
SCHLUMBERGER	J5S	C397165	10-10-02	100.0	99.7	99.7
SCHLUMBERGER	J5S	C397166	10-10-02	99.9	99.7	99.8
SCHLUMBERGER	J5S	C397167	10-10-02	100.1	99.8	99.8
SCHLUMBERGER	J5S	C397168	10-10-02	100.0	99.8	100.0
SCHLUMBERGER	J5S	C397169	10-10-02	100.2	100.3	99.4
SCHLUMBERGER	J5S	C397170	10-10-02	100.0	99.6	99.4
SCHLUMBERGER	J5S	C397171	10-10-02	100.0	99.8	100.0
SCHLUMBERGER	J5S	C397172	10-10-02	100.0	99.6	99.9
SCHLUMBERGER	J5S	C397173	10-10-02	100.1	99.7	99.9
SCHLUMBERGER	J5S	C397174	10-10-02	100.0	99.7	99.9
SCHLUMBERGER	J5S	C397175	10-10-02	100.2	99.9	99.8
SCHLUMBERGER	J5S	C397176	10-10-02	100.2	99.9	100.0

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	J55	C397177	10-10-02	100.3	99.8	100.0
SCHLUMBERGER	J55	C397178	10-10-02	99.9	99.6	99.6
SCHLUMBERGER	J55	C397179	10-10-02	100.0	99.9	100.0
SCHLUMBERGER	J55	C397180	10-10-02	100.2	99.9	100.0
SCHLUMBERGER	J55	C397181	10-10-02	100.0	100.0	99.9
SCHLUMBERGER	J55	C397182	10-10-02	100.1	99.8	100.1
SCHLUMBERGER	J55	C397183	10-10-02	100.1	99.9	99.8
SCHLUMBERGER	J55	C397184	10-10-02	100.2	99.7	100.0
SCHLUMBERGER	J55	C397185	10-10-02	100.1	99.6	99.6
SCHLUMBERGER	J55	C397186	10-10-02	100.1	99.8	99.6
SCHLUMBERGER	J55	C397187	10-10-02	99.9	99.7	99.8
SCHLUMBERGER	J55	C397188	10-10-02	100.0	100.0	100.2
SCHLUMBERGER	J55	C397189	10-10-02	100.0	100.0	100.0
SCHLUMBERGER	J55	C397190	10-10-02	99.9	100.0	99.8
SCHLUMBERGER	J55	C397191	10-10-02	100.1	99.8	99.8
SCHLUMBERGER	J55	C397192	10-10-02	99.7	100.0	99.5
SCHLUMBERGER	J55	C397193	10-10-02	100.2	99.6	100.0
SCHLUMBERGER	J55	C397194	10-10-02	100.0	99.8	99.6
SCHLUMBERGER	J55	C397195	10-10-02	100.1	99.9	99.8
SCHLUMBERGER	J55	C397196	10-10-02	100.0	99.6	99.5
SCHLUMBERGER	J55	C397197	10-10-02	100.0	99.8	99.5
SCHLUMBERGER	J55	C397198	10-10-02	100.0	99.7	99.6
SCHLUMBERGER	J55	C397199	10-10-02	100.1	99.9	99.7
SCHLUMBERGER	J55	C397200	10-10-02	100.0	99.6	100.0
SCHLUMBERGER	J55	C397201	10-10-02	100.1	100.2	100.0
SCHLUMBERGER	J55	C397202	10-10-02	100.0	100.0	100.1
SCHLUMBERGER	J55	C397203	10-10-02	100.2	99.8	100.0
SCHLUMBERGER	J55	C397204	10-10-02	100.1	99.8	100.0
SCHLUMBERGER	J55	C397205	10-10-02	100.0	100.1	100.1
SCHLUMBERGER	J55	C397206	10-10-02	100.0	99.8	99.8
SCHLUMBERGER	J55	C397207	10-10-02	99.8	99.6	99.8
SCHLUMBERGER	J55	C397208	10-10-02	100.3	99.8	100.0
SCHLUMBERGER	J55	C397209	10-10-02	100.2	99.7	100.1
SCHLUMBERGER	J55	C397210	10-10-02	100.1	99.6	99.9
SCHLUMBERGER	J55	C397211	10-10-02	100.0	99.9	99.7
SCHLUMBERGER	J55	C397212	10-10-02	100.1	99.9	99.5
SCHLUMBERGER	J55	C397213	10-10-02	100.1	99.8	99.8
SCHLUMBERGER	J55	C397214	10-10-02	100.1	99.8	99.8
SCHLUMBERGER	J55	C397215	10-10-02	100.2	100.0	99.8
SCHLUMBERGER	J55	C397216	10-10-02	99.9	100.0	99.9
SCHLUMBERGER	J55	C397217	10-10-02	100.1	99.7	99.7
SCHLUMBERGER	J55	C397218	10-10-02	100.0	99.9	99.6
SCHLUMBERGER	J55	C397219	10-10-02	100.0	99.7	99.7
SCHLUMBERGER	J55	C397220	10-10-02	100.0	99.6	99.9
SCHLUMBERGER	J55	C397221	10-10-02	100.0	99.7	99.4
SCHLUMBERGER	J55	C397222	10-10-02	100.0	99.7	99.8
SCHLUMBERGER	J55	C397223	10-10-02	100.2	99.7	99.5
SCHLUMBERGER	J55	C397224	10-10-02	100.0	99.9	99.8
SCHLUMBERGER	J55	C397225	10-10-02	100.2	100.1	100.0
SCHLUMBERGER	J55	C397226	10-10-02	99.9	99.9	99.6
SCHLUMBERGER	J55	C397227	10-10-02	100.1	99.9	100.2

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

PAGE 244
 RUN DATE: 1/14/03
 RUN TIME: 13.26.53

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	J5S	C397228	10-10-02	100.1	99.6	100.3
SCHLUMBERGER	J5S	C397229	10-10-02	100.0	99.7	100.0
SCHLUMBERGER	J5S	C397230	10-10-02	100.1	100.2	100.0
SCHLUMBERGER	J5S	C397231	10-10-02	99.9	100.0	99.9
SCHLUMBERGER	J5S	C397232	10-10-02	100.2	99.9	100.0
SCHLUMBERGER	J5S	C397233	10-10-02	99.8	99.7	99.8
SCHLUMBERGER	J5S	C397234	10-10-02	100.0	99.9	99.9
SCHLUMBERGER	J5S	C397235	10-10-02	100.1	99.7	99.9
SCHLUMBERGER	J5S	C397236	10-10-02	100.0	99.6	100.0
SCHLUMBERGER	J5S	C397237	10-10-02	100.1	99.7	100.1
SCHLUMBERGER	J5S	C397238	10-10-02	100.0	99.6	100.0
SCHLUMBERGER	J5S	C397239	10-10-02	100.0	99.6	99.7
SCHLUMBERGER	J5S	C397240	10-10-02	100.1	99.9	99.8
SCHLUMBERGER	J5S	C397241	10-10-02	100.0	99.7	99.8
SCHLUMBERGER	J5S	C397242	10-10-02	100.0	99.8	99.5
SCHLUMBERGER	J5S	C397243	10-10-02	100.0	99.8	99.5
SCHLUMBERGER	J5S	C397244	10-10-02	100.0	99.7	99.9
SCHLUMBERGER	J5S	C397245	10-10-02	100.1	99.7	100.0
SCHLUMBERGER	J5S	C397246	10-10-02	100.2	100.0	99.7
SCHLUMBERGER	J5S	C397247	10-10-02	100.1	99.8	99.9
SCHLUMBERGER	J5S	C397248	10-10-02	100.3	100.1	99.9
SCHLUMBERGER	J5S	C397249	10-10-02	99.9	99.6	99.7
SCHLUMBERGER	J5S	C397250	10-10-02	100.0	99.6	99.7
SCHLUMBERGER	J5S	C397251	10-10-02	100.2	100.4	100.0
SCHLUMBERGER	J5S	C397252	10-10-02	100.3	100.4	100.2
SCHLUMBERGER	J5S	C397253	10-10-02	100.1	99.8	100.1
SCHLUMBERGER	J5S	C397254	10-10-02	100.1	100.1	100.1
SCHLUMBERGER	J5S	C397255	10-10-02	100.2	99.8	99.6
SCHLUMBERGER	J5S	C397256	10-10-02	100.0	100.1	100.1
SCHLUMBERGER	J5S	C397257	10-10-02	100.2	100.1	100.0
SCHLUMBERGER	J5S	C397258	10-10-02	100.3	100.1	99.4
SCHLUMBERGER	J5S	C397259	10-10-02	100.0	99.8	99.8
SCHLUMBERGER	J5S	C397260	10-10-02	100.2	100.2	99.9
SCHLUMBERGER	J5S	C397261	10-10-02	100.1	99.7	100.0
SCHLUMBERGER	J5S	C397262	10-10-02	100.1	99.9	99.8
SCHLUMBERGER	J5S	C397263	10-10-02	100.1	100.0	100.1
SCHLUMBERGER	J5S	C397264	10-10-02	100.2	100.0	100.0
SCHLUMBERGER	J5S	C397265	10-10-02	100.0	99.9	100.1
SCHLUMBERGER	J5S	C397266	10-10-02	100.0	99.7	99.8
SCHLUMBERGER	J5S	C397267	10-10-02	100.0	100.2	100.0
SCHLUMBERGER	J5S	C397268	10-10-02	100.1	99.9	99.9
SCHLUMBERGER	J5S	C397269	10-10-02	100.1	99.6	99.9
SCHLUMBERGER	J5S	C397270	10-10-02	99.8	100.0	99.6
SCHLUMBERGER	J5S	C397271	10-10-02	100.0	99.9	99.7
SCHLUMBERGER	J5S	C397272	10-10-02	100.1	99.8	100.3
SCHLUMBERGER	J5S	C397273	10-10-02	100.0	99.9	100.3
SCHLUMBERGER	J5S	C397274	10-10-02	100.0	99.7	100.2
SCHLUMBERGER	J5S	C397275	10-10-02	100.2	100.0	100.1
SCHLUMBERGER	J5S	C397276	10-10-02	100.3	100.2	100.2
SCHLUMBERGER	J5S	C397277	10-10-02	100.1	99.7	99.6
SCHLUMBERGER	J5S	C397278	10-10-02	100.0	99.6	99.4

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

PAGE 245
 RUN DATE: 1/14/03
 RUN TIME: 13.26.53

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	J5S	C397279	10-10-02	100.3	99.6	99.8
SCHLUMBERGER	J5S	C397280	10-10-02	100.1	99.9	99.8
SCHLUMBERGER	J5S	C397281	10-10-02	99.9	100.0	99.7
SCHLUMBERGER	J5S	C397282	10-10-02	100.0	99.7	99.3
SCHLUMBERGER	J5S	C397283	10-10-02	100.1	99.8	100.2
SCHLUMBERGER	J5S	C397284	10-10-02	100.1	99.8	99.9
SCHLUMBERGER	J5S	C397285	10-10-02	100.1	99.7	99.9
SCHLUMBERGER	J5S	C397286	10-10-02	100.2	100.2	100.6
SCHLUMBERGER	J5S	C397287	10-10-02	100.3	99.8	100.2
SCHLUMBERGER	J5S	C397288	10-10-02	100.0	99.6	99.4
SCHLUMBERGER	J5S	C397289	10-10-02	100.0	99.9	99.3
SCHLUMBERGER	J5S	C397290	10-10-02	100.0	99.7	99.3
SCHLUMBERGER	J5S	C397291	10-10-02	100.0	99.7	99.8
SCHLUMBERGER	J5S	C397292	10-10-02	99.9	99.7	100.0
SCHLUMBERGER	J5S	C397293	10-10-02	100.1	100.1	99.6
SCHLUMBERGER	J5S	C397294	10-10-02	100.3	99.9	99.8
SCHLUMBERGER	J5S	C397295	10-10-02	100.0	99.8	99.4
SCHLUMBERGER	J5S	C397296	10-10-02	100.1	99.8	100.3
SCHLUMBERGER	J5S	C397297	10-10-02	100.2	99.9	100.3
SCHLUMBERGER	J5S	C397298	10-10-02	100.0	99.7	99.9
SCHLUMBERGER	J5S	C397299	10-10-02	100.1	100.1	99.6
SCHLUMBERGER	J5S	C397300	10-10-02	100.0	99.8	99.8
SCHLUMBERGER	J5S	C397301	10-10-02	100.0	99.8	100.0
SCHLUMBERGER	J5S	C397302	10-10-02	100.3	100.0	99.4
SCHLUMBERGER	J5S	C397303	10-10-02	100.1	100.0	100.5
SCHLUMBERGER	J5S	C397304	10-10-02	99.9	100.0	99.7
SCHLUMBERGER	J5S	C397305	10-10-02	100.3	99.7	100.0
SCHLUMBERGER	J5S	C397306	10-10-02	100.0	100.0	99.7
SCHLUMBERGER	J5S	C397307	10-10-02	100.0	99.6	99.7
SCHLUMBERGER	J5S	C397308	10-10-02	100.2	99.7	100.0
SCHLUMBERGER	J5S	C397309	10-10-02	100.3	99.9	99.7
SCHLUMBERGER	J5S	C397310	10-10-02	100.1	100.1	100.1
SCHLUMBERGER	J5S	C397311	10-10-02	99.9	99.8	99.4
SCHLUMBERGER	J5S	C397312	10-10-02	100.1	100.0	100.1
SCHLUMBERGER	J5S	C397313	10-10-02	100.2	99.7	100.0
SCHLUMBERGER	J5S	C397314	10-10-02	100.2	100.1	100.0
SCHLUMBERGER	J5S	C397315	10-10-02	100.3	100.0	99.7
SCHLUMBERGER	J5S	C397316	10-10-02	100.0	100.3	99.3
SCHLUMBERGER	J5S	C397317	10-10-02	99.9	99.7	99.7
SCHLUMBERGER	J5S	C397318	10-10-02	100.0	99.7	99.8
SCHLUMBERGER	J5S	C397319	10-10-02	100.0	99.8	99.8
SCHLUMBERGER	J5S	C397320	10-10-02	100.1	99.8	100.2
SCHLUMBERGER	J5S	C397321	10-10-02	100.1	99.7	100.2
SCHLUMBERGER	J5S	C397322	10-10-02	100.1	99.7	99.7
SCHLUMBERGER	J5S	C397323	10-10-02	100.0	99.8	100.1
SCHLUMBERGER	J5S	C397324	10-10-02	100.1	99.9	99.8
SCHLUMBERGER	J5S	C397325	10-10-02	100.0	99.6	99.6
SCHLUMBERGER	J5S	C397326	10-10-02	100.0	99.6	99.9
SCHLUMBERGER	J5S	C397327	10-10-02	100.3	99.7	100.0
SCHLUMBERGER	J5S	C397328	10-10-02	99.9	99.9	100.1
SCHLUMBERGER	J5S	C397329	10-10-02	100.1	99.8	100.0

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

PAGE 246
 RUN DATE: 1/14/03
 RUN TIME: 13.26.53

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	J5S	C397330	10-10-02	100.0	99.8	100.0
SCHLUMBERGER	J5S	C397331	10-10-02	100.2	99.8	100.1
SCHLUMBERGER	J5S	C397332	10-10-02	99.9	99.8	99.9
SCHLUMBERGER	J5S	C397333	10-10-02	100.1	99.8	100.0
SCHLUMBERGER	J5S	C397334	10-10-02	100.0	99.9	99.9
SCHLUMBERGER	J5S	C397335	10-10-02	99.8	99.6	99.7
SCHLUMBERGER	J5S	C397336	10-10-02	100.1	99.8	99.8
SCHLUMBERGER	J5S	C397337	10-10-02	100.1	100.1	100.4
SCHLUMBERGER	J5S	C397338	10-10-02	100.1	99.7	100.0
SCHLUMBERGER	J5S	C397339	10-10-02	100.0	99.6	99.5
SCHLUMBERGER	J5S	C397340	10-10-02	100.0	99.6	99.8
SCHLUMBERGER	J5S	C397341	10-10-02	100.0	99.6	100.0
SCHLUMBERGER	J5S	C397342	10-10-02	99.8	99.8	99.5
SCHLUMBERGER	J5S	C397343	10-10-02	100.1	99.7	99.7
SCHLUMBERGER	J5S	C397344	10-10-02	100.0	99.8	99.6
SCHLUMBERGER	J5S	C397345	10-10-02	100.0	99.7	99.9
SCHLUMBERGER	J5S	C397346	10-10-02	100.1	99.6	100.2
SCHLUMBERGER	J5S	C397347	10-10-02	100.1	99.9	99.7
SCHLUMBERGER	J5S	C397348	10-10-02	100.2	99.7	100.0
SCHLUMBERGER	J5S	C397349	10-10-02	100.0	100.0	99.9
SCHLUMBERGER	J5S	C397350	10-10-02	100.2	99.8	99.8
SCHLUMBERGER	J5S	C397351	10-10-02	100.2	99.9	99.6
SCHLUMBERGER	J5S	C397352	10-10-02	100.1	99.8	99.9
SCHLUMBERGER	J5S	C397353	10-10-02	100.2	99.8	99.9
SCHLUMBERGER	J5S	C397354	10-10-02	100.1	100.2	100.0
SCHLUMBERGER	J5S	C397355	10-10-02	99.9	99.8	99.4
SCHLUMBERGER	J5S	C397356	10-10-02	100.1	99.8	99.8
SCHLUMBERGER	J5S	C397357	10-10-02	100.1	99.8	100.1
SCHLUMBERGER	J5S	C397358	10-10-02	100.1	99.8	99.7
SCHLUMBERGER	J5S	C397359	10-10-02	100.0	99.7	99.7
SCHLUMBERGER	J5S	C397360	10-10-02	100.2	99.8	99.9
SCHLUMBERGER	J5S	C397361	10-10-02	100.2	100.2	99.9
SCHLUMBERGER	J5S	C397362	10-10-02	100.1	99.6	100.1
SCHLUMBERGER	J5S	C397363	10-10-02	99.8	99.7	100.2
SCHLUMBERGER	J5S	C397364	10-10-02	100.1	99.6	100.2
SCHLUMBERGER	J5S	C397365	10-10-02	100.1	99.7	100.3
SCHLUMBERGER	J5S	C397366	10-10-02	100.1	99.9	100.0
SCHLUMBERGER	J5S	C397367	10-10-02	99.9	100.0	99.3
SCHLUMBERGER	J5S	C397368	10-10-02	100.0	99.6	99.6
SCHLUMBERGER	J5S	C397369	10-10-02	100.0	99.8	100.2
SCHLUMBERGER	J5S	C397370	10-10-02	100.1	99.6	100.2
SCHLUMBERGER	J5S	C397371	10-10-02	100.0	99.9	99.6
SCHLUMBERGER	J5S	C397372	10-10-02	100.1	99.8	99.4
SCHLUMBERGER	J5S	C397373	10-10-02	99.8	99.9	99.6
SCHLUMBERGER	J5S	C397374	10-10-02	100.0	99.8	99.8
SCHLUMBERGER	J5S	C397375	10-10-02	100.1	100.2	100.1
SCHLUMBERGER	J5S	C397376	10-10-02	100.1	99.7	99.9
SCHLUMBERGER	J5S	C397377	10-10-02	100.0	99.9	99.7
SCHLUMBERGER	J5S	C397378	10-10-02	100.2	99.8	99.9
SCHLUMBERGER	J5S	C397379	10-10-02	100.0	99.9	100.1
SCHLUMBERGER	J5S	C397380	10-10-02	100.0	100.1	99.5

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

PAGE 247
 RUN DATE: 1/14/03
 RUN TIME: 13.26.53

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	J55	C397381	10-10-02	100.1	99.9	99.9
SCHLUMBERGER	J55	C397382	10-10-02	99.9	99.9	99.3
SCHLUMBERGER	J55	C397383	10-10-02	100.0	99.9	99.6
SCHLUMBERGER	J55	C397384	10-10-02	100.1	99.9	100.1
SCHLUMBERGER	J55	C397385	10-10-02	100.0	99.9	99.7
SCHLUMBERGER	J55	C397386	10-10-02	100.1	100.3	100.0
SCHLUMBERGER	J55	C397387	10-10-02	100.1	99.9	99.7
SCHLUMBERGER	J55	C397388	10-10-02	100.0	100.0	100.0
SCHLUMBERGER	J55	C397389	10-10-02	100.1	99.9	100.2
SCHLUMBERGER	J55	C397390	10-10-02	100.3	99.6	99.8
SCHLUMBERGER	J55	C397391	10-10-02	100.1	99.7	100.1
SCHLUMBERGER	J55	C397392	10-10-02	100.0	99.8	100.0
SCHLUMBERGER	J55	C397393	10-10-02	100.1	99.9	100.2
SCHLUMBERGER	J55	C397394	10-10-02	100.1	99.7	100.2
SCHLUMBERGER	J55	C397395	10-10-02	99.9	100.2	99.5
SCHLUMBERGER	J55	C397396	10-10-02	100.0	99.6	99.8
SCHLUMBERGER	J55	C397397	10-10-02	99.9	100.0	99.8
SCHLUMBERGER	J55	C397398	10-10-02	100.2	99.9	100.2
SCHLUMBERGER	J55	C397399	10-10-02	99.9	99.8	99.7
SCHLUMBERGER	J55	C397400	10-10-02	100.2	100.1	99.7
SCHLUMBERGER	J55	C397401	10-10-02	99.9	100.0	99.8
SCHLUMBERGER	J55	C397402	10-10-02	100.0	99.7	99.8
SCHLUMBERGER	J55	C397403	10-10-02	100.0	99.8	99.6
SCHLUMBERGER	J55	C397404	10-10-02	100.0	99.8	100.2
SCHLUMBERGER	J55	C397405	10-10-02	100.2	100.0	100.1
SCHLUMBERGER	J55	C397406	10-10-02	99.9	99.7	99.6
SCHLUMBERGER	J55	C397407	10-10-02	100.0	99.8	99.9
SCHLUMBERGER	J55	C397408	10-10-02	100.0	99.7	99.6
SCHLUMBERGER	J55	C397409	10-10-02	100.1	99.8	99.9
SCHLUMBERGER	J55	C397410	10-10-02	100.1	99.9	100.2
SCHLUMBERGER	J55	C397411	10-10-02	100.2	100.0	100.1
SCHLUMBERGER	J55	C397412	10-10-02	99.9	99.9	99.9
SCHLUMBERGER	J55	C397413	10-10-02	99.9	99.9	99.7
SCHLUMBERGER	J55	C397414	10-10-02	100.0	99.9	99.9
SCHLUMBERGER	J55	C397415	10-10-02	100.3	99.9	99.8
SCHLUMBERGER	J55	C397416	10-10-02	100.0	99.8	100.3
SCHLUMBERGER	J55	C397417	10-10-02	100.0	99.7	99.8
SCHLUMBERGER	J55	C397418	10-10-02	99.8	99.6	99.7
SCHLUMBERGER	J55	C397419	10-10-02	100.2	100.0	100.4
SCHLUMBERGER	J55	C397420	10-10-02	100.0	99.7	99.9
SCHLUMBERGER	J55	C397421	10-10-02	100.2	99.8	100.1
SCHLUMBERGER	J55	C397422	10-10-02	100.1	100.0	99.9
SCHLUMBERGER	J55	C397423	10-10-02	100.0	99.7	99.5
SCHLUMBERGER	J55	C397424	10-10-02	100.0	100.0	99.4
SCHLUMBERGER	J55	C397425	10-10-02	100.0	99.9	100.0
SCHLUMBERGER	J55	C397426	10-10-02	100.0	99.7	99.5
SCHLUMBERGER	J55	C397427	10-10-02	100.0	100.0	99.9
SCHLUMBERGER	J55	C397428	10-10-02	100.0	99.7	100.0
SCHLUMBERGER	J55	C397429	10-10-02	99.9	99.7	99.5
SCHLUMBERGER	J55	C397430	10-10-02	100.3	99.7	100.2
SCHLUMBERGER	J55	C397431	10-10-02	100.1	100.2	99.5

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

MANUFACTURER	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	C397432	10-10-02	100.2	99.6	99.8
SCHLUMBERGER	C397433	10-10-02	100.1	99.7	100.1
SCHLUMBERGER	C397434	10-10-02	100.1	99.7	99.6
SCHLUMBERGER	C397435	10-10-02	100.1	99.9	99.9
SCHLUMBERGER	C397436	10-10-02	100.2	99.7	99.5
SCHLUMBERGER	C397437	10-10-02	100.2	99.7	99.6
SCHLUMBERGER	C397438	10-10-02	100.1	99.9	99.7
SCHLUMBERGER	C397439	10-10-02	100.1	99.7	99.7
SCHLUMBERGER	C397440	10-10-02	99.9	99.7	99.5
SCHLUMBERGER	C397441	10-10-02	100.1	99.8	100.1
SCHLUMBERGER	C397442	10-10-02	100.0	99.8	99.4
SCHLUMBERGER	C397443	10-10-02	100.0	100.3	99.4
SCHLUMBERGER	C397444	10-10-02	100.0	99.8	100.1
SCHLUMBERGER	C397445	10-10-02	100.1	99.7	99.6
SCHLUMBERGER	C397446	10-10-02	100.0	100.1	99.4
SCHLUMBERGER	C397447	10-10-02	100.0	99.9	99.7
SCHLUMBERGER	C397448	10-10-02	100.0	99.7	99.8
SCHLUMBERGER	C397449	10-10-02	100.1	99.8	99.7
SCHLUMBERGER	C397450	10-10-02	100.3	100.3	100.2
SCHLUMBERGER	C397451	10-10-02	100.1	99.8	99.4
SCHLUMBERGER	C397452	10-10-02	100.1	99.9	100.1
SCHLUMBERGER	C397453	10-10-02	100.0	99.6	99.3
SCHLUMBERGER	C397454	10-10-02	100.1	99.9	100.0
SCHLUMBERGER	C397455	10-10-02	100.0	99.9	100.0
SCHLUMBERGER	C397456	10-10-02	100.1	99.6	100.4
SCHLUMBERGER	C397457	10-10-02	99.9	99.9	100.0
SCHLUMBERGER	C397458	10-10-02	99.8	100.2	99.5
SCHLUMBERGER	C397459	10-10-02	100.1	99.7	100.1
SCHLUMBERGER	C397460	10-10-02	100.2	99.8	100.0
SCHLUMBERGER	C397461	10-10-02	100.0	99.8	99.4
SCHLUMBERGER	C397462	10-10-02	99.9	99.7	99.5
SCHLUMBERGER	C397463	10-10-02	100.1	99.8	100.0
SCHLUMBERGER	C397464	10-10-02	100.0	99.9	99.9
SCHLUMBERGER	C397465	10-10-02	99.9	99.6	100.0
SCHLUMBERGER	C397466	10-10-02	100.2	100.0	99.7
SCHLUMBERGER	C397467	10-10-02	100.0	99.8	100.1
SCHLUMBERGER	C397468	10-24-02	100.2	100.0	100.0
SCHLUMBERGER	C397469	10-24-02	100.2	100.2	99.8
SCHLUMBERGER	C397470	10-24-02	100.1	99.8	99.7
SCHLUMBERGER	C397471	10-24-02	100.1	99.8	99.9
SCHLUMBERGER	C397472	10-24-02	100.2	99.9	100.1
SCHLUMBERGER	C397473	10-24-02	100.1	100.0	100.0
SCHLUMBERGER	C397474	10-24-02	100.0	100.0	99.7
SCHLUMBERGER	C397475	10-24-02	100.0	99.7	99.9
SCHLUMBERGER	C397476	10-24-02	100.1	100.1	100.5
SCHLUMBERGER	C397477	10-24-02	100.1	100.0	100.3
SCHLUMBERGER	C397478	10-24-02	100.2	100.1	100.2
SCHLUMBERGER	C397479	10-24-02	100.2	99.6	99.9
SCHLUMBERGER	C397480	10-24-02	100.2	100.4	100.1
SCHLUMBERGER	C397481	10-24-02	100.3	99.8	99.9
SCHLUMBERGER	C397482	10-24-02	100.2	99.9	100.2

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	J55	C397483	10-24-02	100.0	100.0	100.2
SCHLUMBERGER	J55	C397484	10-24-02	100.2	99.9	100.2
SCHLUMBERGER	J55	C397485	10-24-02	100.1	100.2	99.8
SCHLUMBERGER	J55	C397486	10-24-02	100.2	100.1	100.1
SCHLUMBERGER	J55	C397487	10-24-02	100.1	100.2	99.5
SCHLUMBERGER	J55	C397488	10-24-02	100.1	100.2	100.2
SCHLUMBERGER	J55	C397489	10-24-02	100.2	100.1	100.0
SCHLUMBERGER	J55	C397490	10-24-02	100.3	99.7	100.4
SCHLUMBERGER	J55	C397491	10-24-02	100.2	100.0	100.2
SCHLUMBERGER	J55	C397492	10-24-02	100.2	99.9	100.3
SCHLUMBERGER	J55	C397493	10-24-02	100.2	99.8	99.9
SCHLUMBERGER	J55	C397494	10-24-02	100.1	100.2	100.0
SCHLUMBERGER	J55	C397495	10-24-02	100.0	100.1	99.7
SCHLUMBERGER	J55	C397496	10-24-02	100.1	99.9	99.9
SCHLUMBERGER	J55	C397497	10-24-02	100.2	99.9	100.2
SCHLUMBERGER	J55	C397498	10-24-02	100.1	99.8	100.1
SCHLUMBERGER	J55	C397499	10-24-02	99.8	99.7	99.9
SCHLUMBERGER	J55	C397500	10-24-02	100.2	100.1	99.8
SCHLUMBERGER	J55	C397501	10-24-02	100.2	99.8	100.1
SCHLUMBERGER	J55	C397502	10-24-02	100.1	99.7	99.8
SCHLUMBERGER	J55	C397503	10-24-02	100.1	100.3	99.6
SCHLUMBERGER	J55	C397504	10-24-02	100.1	100.0	100.1
SCHLUMBERGER	J55	C397505	10-24-02	99.8	99.7	99.8
SCHLUMBERGER	J55	C397506	10-24-02	100.1	99.9	100.1
SCHLUMBERGER	J55	C397507	10-24-02	100.2	100.1	100.7
SCHLUMBERGER	J55	C397508	10-24-02	100.1	100.0	100.1
SCHLUMBERGER	J55	C397509	10-24-02	100.1	100.0	100.3
SCHLUMBERGER	J55	C397510	10-24-02	100.0	100.1	99.9
SCHLUMBERGER	J55	C397511	10-24-02	100.1	99.6	100.1
SCHLUMBERGER	J55	C397512	10-24-02	100.1	99.6	100.3
SCHLUMBERGER	J55	C397513	10-24-02	100.1	99.7	100.2
SCHLUMBERGER	J55	C397514	10-24-02	100.2	100.5	100.2
SCHLUMBERGER	J55	C397515	10-24-02	100.1	99.8	99.9
SCHLUMBERGER	J55	C397516	10-24-02	100.3	100.2	99.9
SCHLUMBERGER	J55	C397517	10-24-02	100.1	100.0	99.8
SCHLUMBERGER	J55	C397518	10-24-02	100.1	100.1	100.3
SCHLUMBERGER	J55	C397519	10-24-02	100.2	99.7	99.6
SCHLUMBERGER	J55	C397520	10-24-02	100.2	100.0	100.3
SCHLUMBERGER	J55	C397521	10-24-02	100.2	99.8	99.7
SCHLUMBERGER	J55	C397522	10-24-02	100.1	100.2	99.7
SCHLUMBERGER	J55	C397523	10-24-02	99.9	100.0	100.0
SCHLUMBERGER	J55	C397524	10-24-02	100.2	100.0	99.7
SCHLUMBERGER	J55	C397525	10-24-02	100.2	100.3	100.4
SCHLUMBERGER	J55	C397526	10-24-02	99.8	99.6	99.3
SCHLUMBERGER	J55	C397527	10-24-02	100.2	99.6	100.0
SCHLUMBERGER	J55	C397528	10-24-02	100.1	99.9	100.1
SCHLUMBERGER	J55	C397529	10-24-02	100.2	99.7	100.0
SCHLUMBERGER	J55	C397530	10-24-02	100.1	99.9	100.4
SCHLUMBERGER	J55	C397531	10-24-02	100.2	100.0	100.3
SCHLUMBERGER	J55	C397532	10-24-02	100.2	99.6	99.7
SCHLUMBERGER	J55	C397533	10-24-02	100.1	100.0	99.7

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

PAGE 250
 RUN DATE: 1/14/03
 RUN TIME: 13.26.53

MANUFACTURER	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	C397534	10-24-02	100.1	99.9	100.0
SCHLUMBERGER	C397535	10-24-02	100.3	100.2	100.3
SCHLUMBERGER	C397536	10-24-02	100.0	99.7	99.8
SCHLUMBERGER	C397537	10-24-02	100.2	99.9	100.2
SCHLUMBERGER	C397538	10-24-02	100.2	100.4	100.2
SCHLUMBERGER	C397539	10-24-02	100.1	100.0	100.3
SCHLUMBERGER	C397540	10-24-02	99.8	100.3	99.7
SCHLUMBERGER	C397541	10-24-02	100.1	99.8	99.8
SCHLUMBERGER	C397542	10-24-02	100.1	100.1	100.1
SCHLUMBERGER	C397543	10-24-02	100.2	100.2	99.9
SCHLUMBERGER	C397544	10-24-02	100.0	99.9	100.1
SCHLUMBERGER	C397545	10-24-02	100.2	99.6	100.3
SCHLUMBERGER	C397546	10-24-02	100.1	99.9	100.0
SCHLUMBERGER	C397547	10-24-02	100.1	99.7	100.0
SCHLUMBERGER	C397548	10-24-02	100.1	100.0	99.8
SCHLUMBERGER	C397549	10-24-02	100.1	100.1	100.0
SCHLUMBERGER	C397550	10-24-02	100.0	99.8	99.9
SCHLUMBERGER	C397551	10-24-02	100.1	99.6	99.6
SCHLUMBERGER	C397552	10-24-02	100.2	99.9	100.0
SCHLUMBERGER	C397553	10-24-02	100.0	99.9	99.8
SCHLUMBERGER	C397554	10-24-02	100.2	99.7	99.9
SCHLUMBERGER	C397555	10-24-02	99.9	99.9	99.8
SCHLUMBERGER	C397556	10-24-02	100.2	100.2	100.3
SCHLUMBERGER	C397557	10-24-02	100.1	99.7	99.7
SCHLUMBERGER	C397558	10-24-02	100.0	99.8	99.8
SCHLUMBERGER	C397559	10-24-02	100.1	99.7	100.3
SCHLUMBERGER	C397560	10-24-02	100.2	99.9	100.2
SCHLUMBERGER	C397561	10-24-02	100.3	99.8	100.0
SCHLUMBERGER	C397562	10-24-02	100.1	99.9	100.4
SCHLUMBERGER	C397563	10-24-02	100.1	99.8	99.9
SCHLUMBERGER	C397564	10-24-02	100.1	99.7	100.2
SCHLUMBERGER	C397565	10-24-02	100.1	99.9	99.8
SCHLUMBERGER	C397566	10-24-02	100.1	99.9	100.2
SCHLUMBERGER	C397567	10-24-02	100.2	100.1	99.8
SCHLUMBERGER	C397568	10-24-02	100.3	100.3	100.4
SCHLUMBERGER	C397569	10-24-02	100.2	99.8	99.9
SCHLUMBERGER	C397570	10-24-02	100.1	100.0	100.1
SCHLUMBERGER	C397571	10-24-02	100.3	100.0	100.1
SCHLUMBERGER	C397572	10-24-02	100.1	100.1	100.2
SCHLUMBERGER	C397573	10-24-02	100.0	99.8	99.8
SCHLUMBERGER	C397574	10-24-02	100.2	100.1	100.1
SCHLUMBERGER	C397575	10-24-02	100.1	99.6	100.0
SCHLUMBERGER	C397576	10-24-02	100.0	99.9	99.7
SCHLUMBERGER	C397577	10-24-02	100.2	99.7	100.1
SCHLUMBERGER	C397578	10-24-02	100.2	99.8	100.1
SCHLUMBERGER	C397579	10-24-02	100.3	99.7	99.7
SCHLUMBERGER	C397580	10-24-02	100.2	100.2	100.2
SCHLUMBERGER	C397581	10-24-02	100.1	99.6	100.0
SCHLUMBERGER	C397582	10-24-02	100.1	99.8	100.1
SCHLUMBERGER	C397583	10-24-02	99.9	100.0	100.0
SCHLUMBERGER	C397584	10-24-02	100.2	100.0	99.9

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

PAGE 251
 RUN DATE: 1/14/03
 RUN TIME: 13.26.53

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	J55	C397585	10-24-02	100.2	100.1	100.1
SCHLUMBERGER	J55	C397586	10-24-02	100.0	99.6	100.3
SCHLUMBERGER	J55	C397587	10-24-02	100.0	99.7	99.5
SCHLUMBERGER	J55	C397588	10-24-02	100.2	100.0	99.9
SCHLUMBERGER	J55	C397589	10-24-02	100.0	99.8	99.7
SCHLUMBERGER	J55	C397590	10-24-02	100.1	99.8	100.0
SCHLUMBERGER	J55	C397591	10-24-02	99.9	99.8	99.8
SCHLUMBERGER	J55	C397592	10-24-02	100.0	99.8	100.0
SCHLUMBERGER	J55	C397593	10-24-02	100.0	99.8	100.0
SCHLUMBERGER	J55	C397594	10-24-02	100.3	99.8	100.3
SCHLUMBERGER	J55	C397595	10-24-02	100.3	100.4	99.9
SCHLUMBERGER	J55	C397596	10-24-02	100.0	100.0	99.6
SCHLUMBERGER	J55	C397597	10-24-02	100.0	99.9	100.3
SCHLUMBERGER	J55	C397598	10-24-02	100.2	100.2	100.0
SCHLUMBERGER	J55	C397599	10-24-02	100.1	100.0	99.8
SCHLUMBERGER	J55	C397600	10-24-02	100.0	99.8	100.1
SCHLUMBERGER	J55	C397601	10-24-02	99.9	99.7	100.1
SCHLUMBERGER	J55	C397602	10-24-02	100.3	99.8	99.7
SCHLUMBERGER	J55	C397603	10-24-02	100.0	100.1	99.7
SCHLUMBERGER	J55	C397604	10-24-02	100.0	99.9	100.1
SCHLUMBERGER	J55	C397605	10-24-02	100.3	100.0	100.1
SCHLUMBERGER	J55	C397606	10-24-02	100.0	99.9	99.7
SCHLUMBERGER	J55	C397607	10-24-02	100.2	100.1	99.9
SCHLUMBERGER	J55	C397608	10-24-02	99.9	99.9	99.6
SCHLUMBERGER	J55	C397609	10-24-02	100.0	100.1	99.9
SCHLUMBERGER	J55	C397610	10-24-02	100.0	99.6	100.0
SCHLUMBERGER	J55	C397611	10-24-02	100.0	100.0	100.2
SCHLUMBERGER	J55	C397612	10-24-02	100.3	99.8	100.1
SCHLUMBERGER	J55	C397613	10-24-02	100.2	100.1	100.0
SCHLUMBERGER	J55	C397614	10-24-02	100.1	100.2	100.5
SCHLUMBERGER	J55	C397615	10-24-02	100.0	99.8	100.2
SCHLUMBERGER	J55	C397616	10-24-02	100.1	100.2	100.1
SCHLUMBERGER	J55	C397617	10-24-02	100.3	100.0	100.1
SCHLUMBERGER	J55	C397618	10-24-02	100.1	99.7	99.7
SCHLUMBERGER	J55	C397619	10-24-02	100.1	99.6	100.2
SCHLUMBERGER	J55	C397620	10-24-02	100.1	99.7	99.8
SCHLUMBERGER	J55	C397621	10-24-02	100.0	100.1	99.8
SCHLUMBERGER	J55	C397622	10-24-02	100.1	99.7	100.0
SCHLUMBERGER	J55	C397623	10-24-02	100.1	99.7	100.0
SCHLUMBERGER	J55	C397624	10-24-02	100.1	99.8	99.9
SCHLUMBERGER	J55	C397625	10-24-02	100.0	99.9	100.1
SCHLUMBERGER	J55	C397626	10-24-02	100.1	99.9	100.0
SCHLUMBERGER	J55	C397627	10-24-02	100.0	100.0	100.0
SCHLUMBERGER	J55	C397628	10-24-02	100.1	99.9	100.5
SCHLUMBERGER	J55	C397629	10-24-02	100.0	99.7	99.8
SCHLUMBERGER	J55	C397630	10-24-02	99.9	99.7	99.8
SCHLUMBERGER	J55	C397631	10-24-02	100.0	99.9	100.1
SCHLUMBERGER	J55	C397632	10-24-02	100.0	99.8	99.8
SCHLUMBERGER	J55	C397633	10-24-02	100.3	100.0	100.8
SCHLUMBERGER	J55	C397634	10-24-02	100.1	99.7	100.2
SCHLUMBERGER	J55	C397635	10-24-02	100.1	99.9	100.0

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

PAGE 252
 RUN DATE: 1/14/03
 RUN TIME: 13.26.53

MANUFACTURER	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PF FACTOR
SCHLUMBERGER	C397636	10-24-02	100.0	99.9	99.9
SCHLUMBERGER	C397637	10-24-02	100.2	99.9	100.2
SCHLUMBERGER	C397638	10-24-02	100.0	99.9	99.9
SCHLUMBERGER	C397639	10-24-02	100.3	99.8	100.6
SCHLUMBERGER	C397640	10-24-02	100.1	100.3	100.0
SCHLUMBERGER	C397641	10-24-02	100.1	99.9	100.4
SCHLUMBERGER	C397642	10-24-02	100.0	99.7	99.8
SCHLUMBERGER	C397643	10-24-02	100.1	99.8	100.2
SCHLUMBERGER	C397644	10-24-02	100.2	99.8	99.5
SCHLUMBERGER	C397645	10-24-02	100.1	100.1	99.6
SCHLUMBERGER	C397646	10-24-02	100.0	100.1	100.1
SCHLUMBERGER	C397647	10-24-02	100.0	99.8	99.7
SCHLUMBERGER	C397648	10-24-02	100.1	99.9	100.1
SCHLUMBERGER	C397649	10-24-02	100.1	99.7	100.2
SCHLUMBERGER	C397650	10-24-02	100.0	99.9	100.2
SCHLUMBERGER	C397651	10-24-02	100.0	99.8	99.6
SCHLUMBERGER	C397652	10-24-02	100.1	99.9	100.1
SCHLUMBERGER	C397653	10-24-02	100.1	99.8	99.8
SCHLUMBERGER	C397654	10-24-02	99.9	100.1	99.8
SCHLUMBERGER	C397655	10-24-02	100.1	99.9	99.6
SCHLUMBERGER	C397656	10-24-02	100.2	100.0	99.9
SCHLUMBERGER	C397657	10-24-02	100.1	99.7	100.1
SCHLUMBERGER	C397658	10-24-02	100.1	100.0	100.2
SCHLUMBERGER	C397659	10-24-02	100.1	99.8	99.7
SCHLUMBERGER	C397660	10-24-02	100.1	99.9	99.9
SCHLUMBERGER	C397661	10-24-02	100.0	100.0	100.0
SCHLUMBERGER	C397662	10-24-02	100.1	100.0	99.7
SCHLUMBERGER	C397663	10-24-02	100.3	99.9	99.7
SCHLUMBERGER	C397664	10-24-02	100.1	100.0	100.1
SCHLUMBERGER	C397665	10-24-02	100.3	99.9	99.6
SCHLUMBERGER	C397666	10-24-02	99.9	100.2	100.4
SCHLUMBERGER	C397667	10-24-02	100.2	99.6	100.0
SCHLUMBERGER	C397668	10-24-02	100.0	100.2	100.0
SCHLUMBERGER	C397669	10-24-02	100.0	99.8	99.8
SCHLUMBERGER	C397670	10-24-02	100.3	100.1	100.3
SCHLUMBERGER	C397671	10-24-02	100.0	100.2	100.3
SCHLUMBERGER	C397672	10-24-02	100.2	99.8	100.2
SCHLUMBERGER	C397673	10-24-02	100.3	99.8	100.2
SCHLUMBERGER	C397674	10-24-02	100.1	99.8	100.1
SCHLUMBERGER	C397675	10-24-02	100.0	99.8	99.8
SCHLUMBERGER	C397676	10-24-02	100.0	99.7	100.0
SCHLUMBERGER	C397677	10-24-02	99.9	100.2	100.2
SCHLUMBERGER	C397678	10-24-02	100.0	99.8	99.9
SCHLUMBERGER	C397679	10-24-02	100.0	100.1	99.9
SCHLUMBERGER	C397680	10-24-02	100.2	100.1	99.6
SCHLUMBERGER	C397681	10-24-02	100.2	99.7	99.9
SCHLUMBERGER	C397682	10-24-02	100.2	99.7	100.0
SCHLUMBERGER	C397683	10-24-02	100.1	99.9	100.1
SCHLUMBERGER	C397684	10-24-02	100.1	99.8	100.2
SCHLUMBERGER	C397685	10-24-02	100.1	99.8	99.9
SCHLUMBERGER	C397686	10-24-02	100.3	99.6	100.2

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	J55	C397687	10-24-02	100.1	99.8	100.1
SCHLUMBERGER	J55	C397688	10-24-02	100.2	99.7	100.2
SCHLUMBERGER	J55	C397689	10-24-02	100.2	100.4	100.4
SCHLUMBERGER	J55	C397690	10-24-02	100.0	100.0	100.0
SCHLUMBERGER	J55	C397691	10-24-02	100.0	100.0	100.2
SCHLUMBERGER	J55	C397692	10-24-02	100.1	100.3	100.2
SCHLUMBERGER	J55	C397693	10-24-02	100.2	99.8	100.0
SCHLUMBERGER	J55	C397694	10-24-02	100.3	99.9	100.0
SCHLUMBERGER	J55	C397695	10-24-02	100.1	100.1	100.3
SCHLUMBERGER	J55	C397696	10-24-02	100.2	100.0	100.0
SCHLUMBERGER	J55	C397697	10-24-02	100.2	100.2	100.3
SCHLUMBERGER	J55	C397698	10-24-02	100.1	99.9	100.0
SCHLUMBERGER	J55	C397699	10-24-02	100.2	99.9	100.0
SCHLUMBERGER	J55	C397700	10-24-02	100.2	99.9	100.1
SCHLUMBERGER	J55	C397701	10-24-02	99.9	99.8	100.2
SCHLUMBERGER	J55	C397702	10-24-02	100.1	99.8	100.1
SCHLUMBERGER	J55	C397703	10-24-02	100.2	100.0	100.1
SCHLUMBERGER	J55	C397704	10-24-02	100.3	99.8	100.3
SCHLUMBERGER	J55	C397705	10-24-02	100.0	100.2	99.3
SCHLUMBERGER	J55	C397706	10-24-02	100.1	100.1	100.1
SCHLUMBERGER	J55	C397707	10-24-02	100.2	99.9	100.1
SCHLUMBERGER	J55	C397708	10-24-02	100.3	99.8	100.3
SCHLUMBERGER	J55	C397709	10-24-02	100.0	99.8	100.0
SCHLUMBERGER	J55	C397710	10-24-02	99.9	99.8	100.0
SCHLUMBERGER	J55	C397711	10-24-02	100.2	100.0	99.9
SCHLUMBERGER	J55	C397712	10-24-02	100.2	99.8	100.1
SCHLUMBERGER	J55	C397713	10-24-02	100.1	100.0	100.2
SCHLUMBERGER	J55	C397714	10-24-02	100.1	100.0	100.3
SCHLUMBERGER	J55	C397715	10-24-02	99.9	99.8	100.1
SCHLUMBERGER	J55	C397716	10-24-02	99.9	99.7	99.7
SCHLUMBERGER	J55	C397717	10-24-02	100.1	99.6	100.2
SCHLUMBERGER	J55	C397718	10-24-02	100.3	100.4	100.0
SCHLUMBERGER	J55	C397719	10-24-02	100.1	100.1	100.1
SCHLUMBERGER	J55	C397720	10-24-02	100.2	99.8	100.1
SCHLUMBERGER	J55	C397721	10-24-02	100.0	99.9	99.7
SCHLUMBERGER	J55	C397722	10-24-02	100.1	99.8	99.9
SCHLUMBERGER	J55	C397723	10-24-02	100.1	99.8	100.1
SCHLUMBERGER	J55	C397724	10-24-02	100.0	99.7	99.7
SCHLUMBERGER	J55	C397725	10-24-02	99.9	99.6	99.9
SCHLUMBERGER	J55	C397726	10-24-02	100.1	99.9	99.7
SCHLUMBERGER	J55	C397727	10-24-02	100.0	99.7	99.6
SCHLUMBERGER	J55	C397728	10-24-02	100.1	100.3	99.7
SCHLUMBERGER	J55	C397729	10-24-02	99.8	99.9	100.6
SCHLUMBERGER	J55	C397730	10-24-02	100.0	99.8	100.0
SCHLUMBERGER	J55	C397731	10-24-02	100.2	99.8	100.0
SCHLUMBERGER	J55	C397732	10-24-02	100.1	99.9	100.4
SCHLUMBERGER	J55	C397733	10-24-02	100.2	99.9	100.2
SCHLUMBERGER	J55	C397734	10-24-02	100.2	99.7	100.0
SCHLUMBERGER	J55	C397735	10-24-02	100.3	99.8	99.8
SCHLUMBERGER	J55	C397736	10-24-02	100.2	100.0	100.4
SCHLUMBERGER	J55	C397737	10-24-02	100.0	99.8	100.0
SCHLUMBERGER	J55	C397737	10-24-02	100.0	99.8	99.7

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	J55	C397738	10-24-02	100.1	99.9	100.2
SCHLUMBERGER	J55	C397739	10-24-02	100.2	100.0	100.0
SCHLUMBERGER	J55	C397740	10-24-02	100.1	99.8	100.0
SCHLUMBERGER	J55	C397741	10-24-02	100.1	99.6	99.7
SCHLUMBERGER	J55	C397742	10-24-02	100.2	99.9	100.2
SCHLUMBERGER	J55	C397743	10-24-02	100.2	100.0	100.6
SCHLUMBERGER	J55	C397744	10-24-02	100.3	100.2	100.0
SCHLUMBERGER	J55	C397745	10-24-02	100.1	99.9	100.1
SCHLUMBERGER	J55	C397746	10-24-02	100.1	99.8	100.2
SCHLUMBERGER	J55	C397747	10-24-02	100.3	99.9	99.9
SCHLUMBERGER	J55	C397748	10-24-02	100.2	99.9	100.4
SCHLUMBERGER	J55	C397749	10-24-02	100.1	100.3	99.7
SCHLUMBERGER	J55	C397750	10-24-02	99.9	100.0	99.9
SCHLUMBERGER	J55	C397751	10-24-02	100.2	100.0	100.2
SCHLUMBERGER	J55	C397752	10-24-02	100.2	99.6	99.9
SCHLUMBERGER	J55	C397753	10-24-02	100.1	99.7	100.2
SCHLUMBERGER	J55	C397754	10-24-02	100.1	99.8	100.3
SCHLUMBERGER	J55	C397755	10-24-02	100.0	99.8	100.3
SCHLUMBERGER	J55	C397756	10-24-02	100.2	99.7	99.8
SCHLUMBERGER	J55	C397757	10-24-02	100.1	100.3	100.5
SCHLUMBERGER	J55	C397758	10-24-02	100.2	99.8	99.7
SCHLUMBERGER	J55	C397759	10-24-02	100.1	99.9	99.8
SCHLUMBERGER	J55	C397760	10-24-02	100.1	99.7	100.5
SCHLUMBERGER	J55	C397761	10-24-02	99.9	99.8	100.5
SCHLUMBERGER	J55	C397762	10-24-02	100.0	99.8	100.3
SCHLUMBERGER	J55	C397763	10-24-02	100.2	99.8	100.0
SCHLUMBERGER	J55	C397764	10-24-02	100.1	99.8	100.4
SCHLUMBERGER	J55	C397765	10-24-02	100.1	99.6	100.5
SCHLUMBERGER	J55	C397766	10-24-02	99.9	100.1	100.0
SCHLUMBERGER	J55	C397767	10-24-02	100.1	100.0	100.4
SCHLUMBERGER	J55	C397768	10-24-02	100.0	99.9	99.3
SCHLUMBERGER	J55	C397769	10-24-02	100.2	99.7	99.7
SCHLUMBERGER	J55	C397770	10-24-02	100.1	100.0	99.8
SCHLUMBERGER	J55	C397771	10-24-02	100.1	100.1	99.8
SCHLUMBERGER	J55	C397772	10-24-02	100.1	100.0	100.5
SCHLUMBERGER	J55	C397773	10-24-02	100.3	99.9	100.3
SCHLUMBERGER	J55	C397774	10-24-02	100.2	100.1	99.8
SCHLUMBERGER	J55	C397775	10-24-02	100.1	100.2	99.9
SCHLUMBERGER	J55	C397776	10-24-02	100.3	99.9	100.3
SCHLUMBERGER	J55	C397777	10-24-02	100.0	99.9	99.9
SCHLUMBERGER	J55	C397778	10-24-02	100.1	99.7	100.0
SCHLUMBERGER	J55	C397779	10-24-02	99.9	100.1	99.9
SCHLUMBERGER	J55	C397780	10-24-02	100.3	99.9	100.8
SCHLUMBERGER	J55	C397781	10-24-02	100.3	99.8	100.3
SCHLUMBERGER	J55	C397782	10-24-02	100.2	99.8	100.3
SCHLUMBERGER	J55	C397783	10-24-02	99.9	99.9	100.3
SCHLUMBERGER	J55	C397784	10-24-02	100.1	99.7	99.8
SCHLUMBERGER	J55	C397785	10-24-02	100.0	100.0	99.8
SCHLUMBERGER	J55	C397786	10-24-02	100.3	99.8	100.5
SCHLUMBERGER	J55	C397787	10-24-02	100.1	99.6	100.0
SCHLUMBERGER	J55	C397788	10-24-02	99.9	99.9	100.2

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

PAGE 255
 RUN DATE: 1/14/03
 RUN TIME: 13.26.53

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	J55	C397789	10-24-02	100.1	100.4	100.1
SCHLUMBERGER	J55	C397790	10-24-02	99.8	99.8	100.3
SCHLUMBERGER	J55	C397791	10-24-02	100.0	99.7	100.0
SCHLUMBERGER	J55	C397792	10-24-02	100.0	99.9	99.8
SCHLUMBERGER	J55	C397793	10-24-02	100.2	99.7	100.2
SCHLUMBERGER	J55	C397794	10-24-02	100.1	99.9	99.8
SCHLUMBERGER	J55	C397795	10-24-02	100.0	100.1	100.4
SCHLUMBERGER	J55	C397796	10-24-02	100.0	99.8	100.2
SCHLUMBERGER	J55	C397797	10-24-02	100.2	99.9	100.0
SCHLUMBERGER	J55	C397798	10-24-02	100.2	100.0	100.1
SCHLUMBERGER	J55	C397799	10-24-02	100.2	99.8	100.1
SCHLUMBERGER	J55	C397800	10-24-02	100.2	99.9	100.1
SCHLUMBERGER	J55	C397801	10-24-02	100.1	100.0	100.2
SCHLUMBERGER	J55	C397802	10-24-02	100.0	100.1	100.3
SCHLUMBERGER	J55	C397803	10-24-02	100.2	99.6	100.5
SCHLUMBERGER	J55	C397804	10-24-02	100.1	99.9	100.4
SCHLUMBERGER	J55	C397805	10-24-02	100.1	99.8	100.2
SCHLUMBERGER	J55	C397806	10-24-02	100.0	99.6	100.1
SCHLUMBERGER	J55	C397807	10-24-02	99.9	100.1	100.2
SCHLUMBERGER	J55	C397808	10-24-02	100.2	99.9	99.9
SCHLUMBERGER	J55	C397809	10-24-02	100.2	99.8	99.9
SCHLUMBERGER	J55	C397810	10-24-02	100.1	100.0	100.0
SCHLUMBERGER	J55	C397811	10-24-02	100.0	100.0	99.3
SCHLUMBERGER	J55	C397812	10-24-02	100.0	99.9	99.8
SCHLUMBERGER	J55	C397813	10-24-02	100.2	99.8	100.2
SCHLUMBERGER	J55	C397814	10-24-02	100.3	100.2	100.4
SCHLUMBERGER	J55	C397815	10-24-02	100.2	100.1	100.8
SCHLUMBERGER	J55	C397816	10-24-02	100.1	100.0	100.1
SCHLUMBERGER	J55	C397817	10-24-02	100.0	99.8	99.9
SCHLUMBERGER	J55	C397818	10-24-02	100.0	100.0	100.3
SCHLUMBERGER	J55	C397819	10-24-02	100.0	99.9	99.5
SCHLUMBERGER	J55	C397820	10-24-02	100.0	99.9	99.8
SCHLUMBERGER	J55	C397821	10-24-02	100.3	99.6	100.1
SCHLUMBERGER	J55	C397822	10-24-02	100.0	99.9	100.0
SCHLUMBERGER	J55	C397823	10-24-02	100.3	99.6	100.4
SCHLUMBERGER	J55	C397824	10-24-02	100.1	100.1	100.1
SCHLUMBERGER	J55	C397825	10-24-02	100.0	100.4	99.8
SCHLUMBERGER	J55	C397826	10-24-02	100.1	100.0	99.9
SCHLUMBERGER	J55	C397827	10-24-02	100.1	100.1	99.9
SCHLUMBERGER	J55	C397828	10-24-02	100.1	100.0	100.0
SCHLUMBERGER	J55	C397829	10-24-02	100.2	99.7	100.2
SCHLUMBERGER	J55	C397830	10-24-02	100.0	99.6	99.5
SCHLUMBERGER	J55	C397831	10-24-02	100.1	99.9	99.6
SCHLUMBERGER	J55	C397832	10-24-02	100.1	99.9	99.6
SCHLUMBERGER	J55	C397833	10-24-02	100.2	100.0	100.6
SCHLUMBERGER	J55	C397834	10-24-02	100.0	99.7	99.8
SCHLUMBERGER	J55	C397835	10-24-02	100.1	100.2	100.2
SCHLUMBERGER	J55	C397836	10-24-02	100.0	100.2	100.5
SCHLUMBERGER	J55	C397837	10-24-02	100.3	99.9	99.9
SCHLUMBERGER	J55	C397838	10-24-02	100.0	99.8	100.2
SCHLUMBERGER	J55	C397839	10-24-02	100.2	100.1	100.0

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

PAGE 256
 RUN DATE: 1/14/03
 RUN TIME: 13.26.53

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	J5S	C397840	10-24-02	100.0	99.9	100.3
SCHLUMBERGER	J5S	C397841	10-24-02	100.1	99.7	99.7
SCHLUMBERGER	J5S	C397842	10-24-02	100.2	99.6	100.3
SCHLUMBERGER	J5S	C397843	10-24-02	100.3	100.0	100.2
SCHLUMBERGER	J5S	C397844	10-24-02	100.0	100.0	100.4
SCHLUMBERGER	J5S	C397845	10-24-02	100.0	99.7	99.7
SCHLUMBERGER	J5S	C397846	10-24-02	100.0	99.9	99.5
SCHLUMBERGER	J5S	C397847	10-24-02	100.1	99.9	99.9
SCHLUMBERGER	J5S	C397848	10-24-02	100.2	99.7	99.9
SCHLUMBERGER	J5S	C397849	10-24-02	100.2	100.0	99.8
SCHLUMBERGER	J5S	C397850	10-24-02	100.1	99.9	100.3
SCHLUMBERGER	J5S	C397851	10-24-02	100.1	99.9	100.2
SCHLUMBERGER	J5S	C397852	10-24-02	100.1	99.9	100.3
SCHLUMBERGER	J5S	C397853	10-24-02	100.3	99.8	99.9
SCHLUMBERGER	J5S	C397854	10-24-02	100.3	99.9	99.8
SCHLUMBERGER	J5S	C397855	10-24-02	100.1	99.6	100.3
SCHLUMBERGER	J5S	C397856	10-24-02	100.0	100.1	100.3
SCHLUMBERGER	J5S	C397857	10-24-02	100.2	99.9	100.0
SCHLUMBERGER	J5S	C397858	10-24-02	99.8	100.3	99.6
SCHLUMBERGER	J5S	C397859	10-24-02	100.2	99.8	100.1
SCHLUMBERGER	J5S	C397860	10-24-02	100.3	100.0	100.0
SCHLUMBERGER	J5S	C397861	10-24-02	99.9	99.7	100.1
SCHLUMBERGER	J5S	C397862	10-24-02	100.2	100.1	100.3
SCHLUMBERGER	J5S	C397863	10-24-02	100.3	100.0	99.9
SCHLUMBERGER	J5S	C397864	10-24-02	100.1	99.9	100.2
SCHLUMBERGER	J5S	C397865	10-24-02	100.0	100.3	100.0
SCHLUMBERGER	J5S	C397866	10-24-02	100.0	99.9	100.0
SCHLUMBERGER	J5S	C397867	10-24-02	100.2	100.0	100.1
SCHLUMBERGER	J5S	C397868	10-24-02	99.8	99.9	100.1
SCHLUMBERGER	J5S	C397869	10-24-02	99.8	99.9	99.9
SCHLUMBERGER	J5S	C397870	10-24-02	100.1	99.9	100.4
SCHLUMBERGER	J5S	C397871	10-24-02	100.1	100.1	99.9
SCHLUMBERGER	J5S	C397872	10-24-02	100.1	99.9	99.8
SCHLUMBERGER	J5S	C397873	10-24-02	100.3	100.1	100.0
SCHLUMBERGER	J5S	C397874	10-24-02	99.9	99.8	99.6
SCHLUMBERGER	J5S	C397875	10-24-02	100.2	100.1	100.4
SCHLUMBERGER	J5S	C397876	10-24-02	100.1	99.9	100.2
SCHLUMBERGER	J5S	C397877	10-24-02	100.2	100.3	100.1
SCHLUMBERGER	J5S	C397878	10-24-02	100.2	100.1	100.1
SCHLUMBERGER	J5S	C397879	10-24-02	100.2	99.9	100.3
SCHLUMBERGER	J5S	C397880	10-24-02	99.9	100.0	100.4
SCHLUMBERGER	J5S	C397881	10-24-02	100.2	99.9	99.8
SCHLUMBERGER	J5S	C397882	10-24-02	100.1	99.7	100.0
SCHLUMBERGER	J5S	C397883	10-23-02	100.2	100.2	100.0
SCHLUMBERGER	J5S	C397884	10-23-02	100.3	100.0	100.1
SCHLUMBERGER	J5S	C397885	10-23-02	100.2	99.9	100.2
SCHLUMBERGER	J5S	C397886	10-23-02	100.0	99.7	99.8
SCHLUMBERGER	J5S	C397887	10-23-02	100.1	99.9	100.2
SCHLUMBERGER	J5S	C397888	10-23-02	99.9	99.9	99.9
SCHLUMBERGER	J5S	C397889	10-23-02	100.1	99.8	100.0
SCHLUMBERGER	J5S	C397890	10-23-02	99.8	99.9	99.8

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

PAGE 257
 RUN DATE: 1/14/03
 RUN TIME: 13.26.53

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	J55	C397891	10-23-02	100.2	100.0	100.1
SCHLUMBERGER	J55	C397892	10-23-02	100.0	99.9	100.3
SCHLUMBERGER	J55	C397893	10-23-02	100.1	100.2	100.1
SCHLUMBERGER	J55	C397894	10-23-02	100.1	99.7	100.0
SCHLUMBERGER	J55	C397895	10-23-02	99.9	100.2	100.1
SCHLUMBERGER	J55	C397896	10-23-02	100.2	99.8	100.0
SCHLUMBERGER	J55	C397897	10-23-02	100.3	100.1	100.1
SCHLUMBERGER	J55	C397898	10-23-02	100.1	99.7	100.2
SCHLUMBERGER	J55	C397899	10-23-02	100.1	100.2	100.2
SCHLUMBERGER	J55	C397900	10-23-02	100.0	99.8	100.1
SCHLUMBERGER	J55	C397901	10-23-02	100.2	100.0	100.1
SCHLUMBERGER	J55	C397902	10-23-02	100.0	100.2	99.9
SCHLUMBERGER	J55	C397903	10-23-02	100.2	99.9	100.2
SCHLUMBERGER	J55	C397904	10-23-02	100.0	100.2	100.4
SCHLUMBERGER	J55	C397905	10-23-02	100.2	99.8	100.2
SCHLUMBERGER	J55	C397906	10-23-02	100.0	99.7	99.6
SCHLUMBERGER	J55	C397907	10-23-02	100.0	100.0	99.7
SCHLUMBERGER	J55	C397908	10-23-02	100.2	99.9	100.1
SCHLUMBERGER	J55	C397909	10-23-02	100.1	99.9	100.0
SCHLUMBERGER	J55	C397910	10-23-02	100.3	100.0	100.3
SCHLUMBERGER	J55	C397911	10-23-02	99.9	99.9	99.4
SCHLUMBERGER	J55	C397912	10-23-02	100.2	100.1	100.1
SCHLUMBERGER	J55	C397913	10-23-02	100.3	100.1	100.0
SCHLUMBERGER	J55	C397914	10-23-02	100.0	99.9	99.8
SCHLUMBERGER	J55	C397915	10-23-02	100.3	99.9	100.0
SCHLUMBERGER	J55	C397916	10-23-02	100.0	99.7	99.9
SCHLUMBERGER	J55	C397917	10-23-02	100.1	99.6	99.8
SCHLUMBERGER	J55	C397918	10-23-02	100.0	99.8	100.4
SCHLUMBERGER	J55	C397919	10-23-02	100.2	99.7	100.0
SCHLUMBERGER	J55	C397920	10-23-02	100.0	99.6	100.0
SCHLUMBERGER	J55	C397921	10-23-02	100.1	100.1	100.1
SCHLUMBERGER	J55	C397922	10-23-02	100.2	100.3	100.3
SCHLUMBERGER	J55	C397923	10-23-02	100.1	99.9	99.9
SCHLUMBERGER	J55	C397924	10-23-02	100.1	100.1	99.9
SCHLUMBERGER	J55	C397925	10-23-02	100.3	100.2	99.9
SCHLUMBERGER	J55	C397926	10-23-02	100.0	99.8	100.0
SCHLUMBERGER	J55	C397927	10-23-02	100.2	99.6	100.0
SCHLUMBERGER	J55	C397928	10-23-02	100.1	100.2	100.0
SCHLUMBERGER	J55	C397929	10-23-02	100.3	100.1	100.1
SCHLUMBERGER	J55	C397930	10-23-02	100.1	99.9	100.5
SCHLUMBERGER	J55	C397931	10-23-02	99.9	100.1	100.2
SCHLUMBERGER	J55	C397932	10-23-02	100.2	99.9	100.4
SCHLUMBERGER	J55	C397933	10-23-02	100.2	100.1	100.1
SCHLUMBERGER	J55	C397934	10-23-02	100.0	99.9	100.0
SCHLUMBERGER	J55	C397935	10-23-02	100.3	100.2	100.2
SCHLUMBERGER	J55	C397936	10-23-02	100.1	99.9	99.9
SCHLUMBERGER	J55	C397937	10-23-02	99.9	100.0	99.9
SCHLUMBERGER	J55	C397938	10-23-02	100.0	100.0	100.4
SCHLUMBERGER	J55	C397939	10-23-02	100.0	99.8	99.7
SCHLUMBERGER	J55	C397940	10-23-02	100.3	100.1	100.3
SCHLUMBERGER	J55	C397941	10-23-02	100.3	99.7	100.7

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

PAGE 258
 RUN DATE: 1/14/03
 RUN TIME: 13.26.53

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	J5S	C397942	10-23-02	100.0	100.0	99.8
SCHLUMBERGER	J5S	C397943	10-23-02	100.1	100.0	100.2
SCHLUMBERGER	J5S	C397944	10-23-02	100.0	99.8	99.8
SCHLUMBERGER	J5S	C397945	10-23-02	100.3	99.8	100.4
SCHLUMBERGER	J5S	C397946	10-23-02	100.2	99.8	100.2
SCHLUMBERGER	J5S	C397947	10-23-02	100.1	100.1	100.0
SCHLUMBERGER	J5S	C397948	10-23-02	100.0	99.9	100.0
SCHLUMBERGER	J5S	C397949	10-23-02	100.2	100.1	100.2
SCHLUMBERGER	J5S	C397950	10-23-02	100.3	100.0	100.0
SCHLUMBERGER	J5S	C397951	10-23-02	100.2	100.0	99.8
SCHLUMBERGER	J5S	C397952	10-23-02	100.1	99.8	100.0
SCHLUMBERGER	J5S	C397953	10-23-02	100.2	100.1	100.2
SCHLUMBERGER	J5S	C397954	10-23-02	100.1	99.7	99.8
SCHLUMBERGER	J5S	C397955	10-23-02	100.0	100.3	99.5
SCHLUMBERGER	J5S	C397956	10-23-02	100.1	100.0	100.1
SCHLUMBERGER	J5S	C397957	10-23-02	100.2	100.0	100.0
SCHLUMBERGER	J5S	C397958	10-23-02	100.1	100.0	100.2
SCHLUMBERGER	J5S	C397959	10-23-02	100.1	99.9	100.1
SCHLUMBERGER	J5S	C397960	10-23-02	100.0	99.8	100.1
SCHLUMBERGER	J5S	C397961	10-23-02	100.2	100.2	99.8
SCHLUMBERGER	J5S	C397962	10-23-02	100.1	100.0	99.9
SCHLUMBERGER	J5S	C397963	10-23-02	99.8	99.9	99.7
SCHLUMBERGER	J5S	C397964	10-23-02	100.1	99.9	100.2
SCHLUMBERGER	J5S	C397965	10-23-02	100.2	100.0	99.9
SCHLUMBERGER	J5S	C397966	10-23-02	99.8	99.9	99.9
SCHLUMBERGER	J5S	C397967	10-23-02	100.3	100.4	100.3
SCHLUMBERGER	J5S	C397968	10-23-02	100.1	99.9	100.0
SCHLUMBERGER	J5S	C397969	10-23-02	100.2	99.8	99.5
SCHLUMBERGER	J5S	C397970	10-23-02	100.1	100.1	100.3
SCHLUMBERGER	J5S	C397971	10-23-02	100.2	100.0	100.2
SCHLUMBERGER	J5S	C397972	10-23-02	99.9	99.8	100.1
SCHLUMBERGER	J5S	C397973	10-23-02	100.1	100.0	100.0
SCHLUMBERGER	J5S	C397974	10-23-02	100.1	99.8	99.9
SCHLUMBERGER	J5S	C397975	10-23-02	100.1	100.2	99.9
SCHLUMBERGER	J5S	C397976	10-23-02	100.3	100.2	99.9
SCHLUMBERGER	J5S	C397977	10-23-02	100.0	100.0	99.6
SCHLUMBERGER	J5S	C397978	10-23-02	99.9	99.7	99.5
SCHLUMBERGER	J5S	C397979	10-23-02	100.2	100.0	100.0
SCHLUMBERGER	J5S	C397980	10-23-02	100.2	99.9	99.8
SCHLUMBERGER	J5S	C397981	10-23-02	100.0	99.9	100.0
SCHLUMBERGER	J5S	C397982	10-23-02	100.1	99.9	99.9
SCHLUMBERGER	J5S	C397983	10-23-02	100.1	99.8	99.5
SCHLUMBERGER	J5S	C397984	10-23-02	100.1	99.9	99.6
SCHLUMBERGER	J5S	C397985	10-23-02	100.1	99.9	99.8
SCHLUMBERGER	J5S	C397986	10-23-02	100.3	99.7	100.1
SCHLUMBERGER	J5S	C397987	10-23-02	100.3	99.7	100.4
SCHLUMBERGER	J5S	C397988	10-23-02	100.1	99.8	99.7
SCHLUMBERGER	J5S	C397989	10-23-02	100.2	100.0	100.3
SCHLUMBERGER	J5S	C397990	10-23-02	100.0	99.6	99.4
SCHLUMBERGER	J5S	C397991	10-23-02	100.2	99.9	100.0
SCHLUMBERGER	J5S	C397992	10-23-02	99.9	100.3	99.5

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	J55	C397993	10-23-02	100.2	99.9	100.1
SCHLUMBERGER	J55	C397994	10-23-02	100.1	99.7	100.2
SCHLUMBERGER	J55	C397995	10-23-02	100.0	99.8	100.0
SCHLUMBERGER	J55	C397996	10-23-02	100.2	100.0	100.2
SCHLUMBERGER	J55	C397997	10-23-02	100.1	99.8	100.2
SCHLUMBERGER	J55	C397998	10-23-02	100.2	100.0	100.2
SCHLUMBERGER	J55	C397999	10-23-02	100.2	100.3	100.1
SCHLUMBERGER	J55	C398000	10-23-02	100.1	99.6	100.1
SCHLUMBERGER	J55	C398001	10-23-02	100.2	99.7	100.4
SCHLUMBERGER	J55	C398002	10-23-02	100.0	99.6	100.2
SCHLUMBERGER	J55	C398003	10-23-02	100.3	99.7	100.2
SCHLUMBERGER	J55	C398004	10-23-02	100.2	100.2	100.5
SCHLUMBERGER	J55	C398005	10-23-02	100.2	100.0	100.0
SCHLUMBERGER	J55	C398006	10-23-02	100.2	99.8	100.3
SCHLUMBERGER	J55	C398007	10-23-02	100.0	100.1	100.2
SCHLUMBERGER	J55	C398008	10-23-02	100.1	100.2	100.3
SCHLUMBERGER	J55	C398009	10-23-02	100.0	100.1	100.4
SCHLUMBERGER	J55	C398010	10-23-02	100.2	99.8	99.6
SCHLUMBERGER	J55	C398011	10-23-02	100.0	100.1	99.5
SCHLUMBERGER	J55	C398012	10-23-02	100.2	100.0	99.9
SCHLUMBERGER	J55	C398013	10-23-02	100.0	100.0	100.1
SCHLUMBERGER	J55	C398014	10-23-02	100.2	99.8	100.0
SCHLUMBERGER	J55	C398015	10-23-02	100.1	100.2	100.1
SCHLUMBERGER	J55	C398016	10-23-02	100.0	99.8	99.9
SCHLUMBERGER	J55	C398017	10-23-02	100.1	99.6	100.1
SCHLUMBERGER	J55	C398018	10-23-02	100.1	100.1	100.0
SCHLUMBERGER	J55	C398019	10-23-02	99.9	100.1	99.8
SCHLUMBERGER	J55	C398020	10-23-02	100.2	100.1	100.2
SCHLUMBERGER	J55	C398021	10-23-02	99.9	100.0	99.6
SCHLUMBERGER	J55	C398022	10-23-02	100.1	99.6	99.8
SCHLUMBERGER	J55	C398023	10-23-02	100.1	100.2	100.3
SCHLUMBERGER	J55	C398024	10-23-02	100.3	100.1	100.1
SCHLUMBERGER	J55	C398025	10-23-02	100.1	100.0	100.2
SCHLUMBERGER	J55	C398026	10-23-02	100.2	100.0	100.4
SCHLUMBERGER	J55	C398027	10-23-02	100.1	99.7	100.0
SCHLUMBERGER	J55	C398028	10-23-02	100.1	100.2	100.0
SCHLUMBERGER	J55	C398029	10-23-02	100.1	100.1	100.2
SCHLUMBERGER	J55	C398030	10-23-02	100.0	99.9	100.2
SCHLUMBERGER	J55	C398031	10-23-02	99.8	99.8	99.9
SCHLUMBERGER	J55	C398032	10-23-02	99.9	99.8	99.6
SCHLUMBERGER	J55	C398033	10-23-02	100.2	100.4	100.4
SCHLUMBERGER	J55	C398034	10-23-02	100.1	100.1	99.9
SCHLUMBERGER	J55	C398035	10-23-02	100.0	100.1	100.1
SCHLUMBERGER	J55	C398036	10-23-02	100.1	100.0	100.3
SCHLUMBERGER	J55	C398037	10-23-02	100.1	99.8	100.0
SCHLUMBERGER	J55	C398038	10-23-02	100.1	99.7	100.0
SCHLUMBERGER	J55	C398039	10-23-02	100.0	100.2	100.0
SCHLUMBERGER	J55	C398040	10-23-02	99.9	100.0	100.0
SCHLUMBERGER	J55	C398041	10-23-02	100.3	99.7	100.4
SCHLUMBERGER	J55	C398042	10-23-02	99.9	99.8	99.9
SCHLUMBERGER	J55	C398043	10-23-02	100.2	99.9	100.3

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

PAGE 260
 RUN DATE: 1/14/03
 RUN TIME: 13.26.53

MANUFACTURER	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	C398044	10-23-02	100.3	100.2	100.1
SCHLUMBERGER	C398045	10-23-02	100.2	99.9	99.8
SCHLUMBERGER	C398046	10-23-02	100.2	100.0	99.9
SCHLUMBERGER	C398047	10-23-02	100.1	100.4	100.7
SCHLUMBERGER	C398048	10-23-02	100.0	100.1	100.1
SCHLUMBERGER	C398049	10-23-02	100.2	100.1	100.2
SCHLUMBERGER	C398050	10-23-02	100.1	100.1	100.1
SCHLUMBERGER	C398051	10-23-02	100.1	99.9	99.8
SCHLUMBERGER	C398052	10-23-02	100.2	99.8	99.8
SCHLUMBERGER	C398053	10-23-02	100.2	100.2	100.1
SCHLUMBERGER	C398054	10-23-02	100.0	99.8	99.9
SCHLUMBERGER	C398055	10-23-02	100.2	100.2	100.4
SCHLUMBERGER	C398056	10-23-02	100.1	100.0	100.0
SCHLUMBERGER	C398057	10-23-02	100.2	100.0	100.0
SCHLUMBERGER	C398058	10-23-02	100.3	100.1	100.4
SCHLUMBERGER	C398059	10-23-02	100.1	99.9	99.9
SCHLUMBERGER	C398060	10-23-02	99.8	100.0	99.6
SCHLUMBERGER	C398061	10-23-02	100.2	99.7	99.7
SCHLUMBERGER	C398062	10-23-02	100.1	100.0	100.3
SCHLUMBERGER	C398063	10-23-02	99.7	99.9	99.9
SCHLUMBERGER	C398064	10-23-02	100.1	99.9	99.7
SCHLUMBERGER	C398065	10-23-02	100.1	100.0	100.0
SCHLUMBERGER	C398066	10-23-02	100.1	100.1	100.4
SCHLUMBERGER	C398067	10-23-02	100.2	99.9	99.8
SCHLUMBERGER	C398068	10-23-02	100.1	100.1	100.0
SCHLUMBERGER	C398069	10-23-02	100.2	99.7	100.0
SCHLUMBERGER	C398070	10-23-02	100.3	99.9	100.4
SCHLUMBERGER	C398071	10-23-02	100.1	100.3	100.5
SCHLUMBERGER	C398072	10-23-02	100.1	99.9	100.0
SCHLUMBERGER	C398073	10-23-02	100.1	99.9	100.1
SCHLUMBERGER	C398074	10-23-02	100.1	99.7	100.2
SCHLUMBERGER	C398075	10-23-02	100.0	99.8	100.0
SCHLUMBERGER	C398076	10-23-02	100.1	99.9	99.6
SCHLUMBERGER	C398077	10-23-02	100.2	99.9	100.0
SCHLUMBERGER	C398078	10-23-02	100.1	100.1	100.2
SCHLUMBERGER	C398079	10-23-02	100.0	99.7	100.0
SCHLUMBERGER	C398080	10-23-02	99.9	99.8	100.0
SCHLUMBERGER	C398081	10-23-02	100.2	100.0	100.3
SCHLUMBERGER	C398082	10-23-02	100.1	99.8	100.1
SCHLUMBERGER	C398083	10-23-02	100.1	99.7	100.4
SCHLUMBERGER	C398084	10-23-02	100.1	99.8	100.2
SCHLUMBERGER	C398085	10-23-02	100.0	99.9	100.5
SCHLUMBERGER	C398086	10-23-02	100.2	100.0	99.7
SCHLUMBERGER	C398087	10-23-02	100.0	100.1	100.1
SCHLUMBERGER	C398088	10-23-02	100.1	99.7	100.3
SCHLUMBERGER	C398089	10-23-02	100.2	99.8	100.1
SCHLUMBERGER	C398090	10-23-02	100.1	100.1	100.1
SCHLUMBERGER	C398091	10-23-02	100.1	100.2	100.0
SCHLUMBERGER	C398092	10-23-02	100.2	100.2	100.3
SCHLUMBERGER	C398093	10-23-02	100.2	100.0	100.1
SCHLUMBERGER	C398094	10-23-02	100.2	99.7	99.7

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

PAGE 261
 RUN DATE: 1/14/03
 RUN TIME: 13.26.53

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	J5S	C398095	10-23-02	100.1	99.9	100.1
SCHLUMBERGER	J5S	C398096	10-23-02	100.2	100.0	100.1
SCHLUMBERGER	J5S	C398097	10-23-02	100.0	99.8	100.3
SCHLUMBERGER	J5S	C398098	10-23-02	100.3	99.9	100.4
SCHLUMBERGER	J5S	C398099	10-23-02	99.9	99.9	100.0
SCHLUMBERGER	J5S	C398100	10-23-02	100.1	99.7	99.9
SCHLUMBERGER	J5S	C398101	10-23-02	100.1	99.7	100.0
SCHLUMBERGER	J5S	C398102	10-23-02	100.3	100.2	99.8
SCHLUMBERGER	J5S	C398103	10-23-02	100.0	99.8	99.9
SCHLUMBERGER	J5S	C398104	10-23-02	100.0	99.7	100.3
SCHLUMBERGER	J5S	C398105	10-23-02	100.1	99.8	99.8
SCHLUMBERGER	J5S	C398106	10-23-02	100.1	99.7	100.0
SCHLUMBERGER	J5S	C398107	10-23-02	100.0	99.9	100.3
SCHLUMBERGER	J5S	C398108	10-23-02	100.1	100.2	100.5
SCHLUMBERGER	J5S	C398109	10-23-02	100.2	100.3	100.1
SCHLUMBERGER	J5S	C398110	10-23-02	100.3	100.0	100.5
SCHLUMBERGER	J5S	C398111	10-23-02	100.0	99.8	99.9
SCHLUMBERGER	J5S	C398112	10-23-02	99.9	99.9	100.3
SCHLUMBERGER	J5S	C398113	10-23-02	100.1	99.8	100.1
SCHLUMBERGER	J5S	C398114	10-23-02	100.0	100.2	100.3
SCHLUMBERGER	J5S	C398115	10-23-02	99.8	99.7	99.4
SCHLUMBERGER	J5S	C398116	10-23-02	100.1	99.9	99.9
SCHLUMBERGER	J5S	C398117	10-23-02	100.3	99.6	100.4
SCHLUMBERGER	J5S	C398118	10-23-02	100.1	100.0	100.3
SCHLUMBERGER	J5S	C398119	10-23-02	100.3	100.2	100.2
SCHLUMBERGER	J5S	C398120	10-23-02	100.1	99.9	99.8
SCHLUMBERGER	J5S	C398121	10-23-02	100.3	99.9	100.5
SCHLUMBERGER	J5S	C398122	10-23-02	100.0	99.7	100.5
SCHLUMBERGER	J5S	C398123	10-23-02	100.2	99.8	100.1
SCHLUMBERGER	J5S	C398124	10-23-02	99.9	99.9	99.8
SCHLUMBERGER	J5S	C398125	10-23-02	100.0	100.0	100.1
SCHLUMBERGER	J5S	C398126	10-23-02	100.3	100.3	100.1
SCHLUMBERGER	J5S	C398127	10-23-02	100.0	99.8	100.2
SCHLUMBERGER	J5S	C398128	10-23-02	100.0	99.7	99.9
SCHLUMBERGER	J5S	C398129	10-23-02	100.1	100.2	100.1
SCHLUMBERGER	J5S	C398130	10-23-02	100.1	100.0	100.0
SCHLUMBERGER	J5S	C398131	10-23-02	100.1	99.9	100.1
SCHLUMBERGER	J5S	C398132	10-23-02	100.1	99.8	99.8
SCHLUMBERGER	J5S	C398133	10-23-02	99.8	100.2	100.0
SCHLUMBERGER	J5S	C398134	10-23-02	100.0	100.0	99.6
SCHLUMBERGER	J5S	C398135	10-23-02	99.8	100.0	99.6
SCHLUMBERGER	J5S	C398136	10-23-02	100.1	100.0	100.1
SCHLUMBERGER	J5S	C398137	10-23-02	100.3	99.8	100.2
SCHLUMBERGER	J5S	C398138	10-23-02	99.9	100.1	99.7
SCHLUMBERGER	J5S	C398139	10-23-02	100.2	100.2	100.2
SCHLUMBERGER	J5S	C398140	10-23-02	100.1	99.7	100.1
SCHLUMBERGER	J5S	C398141	10-23-02	100.3	99.7	100.1
SCHLUMBERGER	J5S	C398142	10-23-02	100.3	99.8	99.9
SCHLUMBERGER	J5S	C398143	10-23-02	100.2	99.8	99.9
SCHLUMBERGER	J5S	C398144	10-23-02	99.8	100.2	99.4
SCHLUMBERGER	J5S	C398145	10-23-02	100.1	100.2	99.7
SCHLUMBERGER	J5S	C398145	10-23-02	100.1	99.7	100.7

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

PAGE 262
 RUN DATE: 1/14/03
 RUN TIME: 13.26.53

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	J5S	C398146	10-23-02	100.2	99.8	100.0
SCHLUMBERGER	J5S	C398147	10-23-02	100.0	100.1	100.0
SCHLUMBERGER	J5S	C398148	10-23-02	100.0	100.0	100.0
SCHLUMBERGER	J5S	C398149	10-23-02	99.9	99.6	100.1
SCHLUMBERGER	J5S	C398150	10-23-02	100.2	99.9	100.0
SCHLUMBERGER	J5S	C398151	10-23-02	100.2	99.6	100.2
SCHLUMBERGER	J5S	C398152	10-23-02	100.2	99.7	100.2
SCHLUMBERGER	J5S	C398153	10-23-02	100.0	100.1	100.4
SCHLUMBERGER	J5S	C398154	10-23-02	100.1	99.9	100.2
SCHLUMBERGER	J5S	C398155	10-23-02	100.1	99.8	100.1
SCHLUMBERGER	J5S	C398156	10-23-02	99.9	99.7	99.5
SCHLUMBERGER	J5S	C398157	10-23-02	99.8	100.0	99.6
SCHLUMBERGER	J5S	C398158	10-23-02	100.2	99.8	100.2
SCHLUMBERGER	J5S	C398159	10-23-02	100.3	99.8	100.2
SCHLUMBERGER	J5S	C398160	10-23-02	99.9	99.9	99.5
SCHLUMBERGER	J5S	C398161	10-23-02	99.8	99.8	99.9
SCHLUMBERGER	J5S	C398162	10-23-02	100.1	100.4	99.9
SCHLUMBERGER	J5S	C398163	10-23-02	99.9	99.8	99.6
SCHLUMBERGER	J5S	C398164	10-23-02	100.1	99.7	99.6
SCHLUMBERGER	J5S	C398165	10-23-02	100.1	99.8	99.7
SCHLUMBERGER	J5S	C398166	10-23-02	100.0	99.8	100.0
SCHLUMBERGER	J5S	C398167	10-23-02	100.2	99.8	100.2
SCHLUMBERGER	J5S	C398168	10-23-02	100.1	99.7	99.9
SCHLUMBERGER	J5S	C398169	10-23-02	100.1	100.1	100.1
SCHLUMBERGER	J5S	C398170	10-23-02	100.2	99.6	99.9
SCHLUMBERGER	J5S	C398171	10-23-02	100.2	99.9	100.1
SCHLUMBERGER	J5S	C398172	10-23-02	100.1	99.7	100.2
SCHLUMBERGER	J5S	C398173	10-23-02	100.2	100.1	99.9
SCHLUMBERGER	J5S	C398174	10-23-02	100.1	99.9	99.9
SCHLUMBERGER	J5S	C398175	10-23-02	100.0	99.6	99.6
SCHLUMBERGER	J5S	C398176	10-23-02	100.1	99.6	100.1
SCHLUMBERGER	J5S	C398177	10-23-02	100.3	99.7	99.7
SCHLUMBERGER	J5S	C398178	10-23-02	100.1	99.8	100.0
SCHLUMBERGER	J5S	C398179	10-23-02	100.2	99.6	100.2
SCHLUMBERGER	J5S	C398180	10-23-02	100.0	99.8	99.7
SCHLUMBERGER	J5S	C398181	10-23-02	100.2	99.6	100.2
SCHLUMBERGER	J5S	C398182	10-23-02	100.0	99.8	99.6
SCHLUMBERGER	J5S	C398183	10-23-02	99.9	99.9	99.6
SCHLUMBERGER	J5S	C398184	10-23-02	100.1	99.7	100.4
SCHLUMBERGER	J5S	C398185	10-23-02	100.1	99.7	99.9
SCHLUMBERGER	J5S	C398186	10-23-02	100.1	100.1	99.9
SCHLUMBERGER	J5S	C398187	10-23-02	100.1	100.1	100.3
SCHLUMBERGER	J5S	C398188	10-23-02	100.1	99.9	99.9
SCHLUMBERGER	J5S	C398189	10-23-02	99.9	99.7	99.9
SCHLUMBERGER	J5S	C398190	10-23-02	100.0	99.7	99.7
SCHLUMBERGER	J5S	C398191	10-23-02	100.0	99.9	100.0
SCHLUMBERGER	J5S	C398192	10-23-02	100.1	100.0	100.2
SCHLUMBERGER	J5S	C398193	10-23-02	100.0	99.9	99.9
SCHLUMBERGER	J5S	C398194	10-23-02	100.0	99.9	99.6
SCHLUMBERGER	J5S	C398195	10-23-02	100.0	99.7	99.7
SCHLUMBERGER	J5S	C398196	10-23-02	100.2	99.9	100.2

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	J55	C398197	10-23-02	100.0	99.7	99.7
SCHLUMBERGER	J55	C398198	10-23-02	100.1	99.8	99.8
SCHLUMBERGER	J55	C398199	10-23-02	100.2	99.9	99.8
SCHLUMBERGER	J55	C398200	10-23-02	100.1	99.8	100.4
SCHLUMBERGER	J55	C398201	10-23-02	99.8	99.6	100.2
SCHLUMBERGER	J55	C398202	10-23-02	100.0	99.6	100.1
SCHLUMBERGER	J55	C398203	10-23-02	100.1	100.0	99.9
SCHLUMBERGER	J55	C398204	10-23-02	100.3	100.0	99.9
SCHLUMBERGER	J55	C398205	10-23-02	100.0	99.8	100.0
SCHLUMBERGER	J55	C398206	10-23-02	99.9	99.8	99.9
SCHLUMBERGER	J55	C398207	10-23-02	100.0	100.0	99.9
SCHLUMBERGER	J55	C398208	10-23-02	100.1	99.6	99.9
SCHLUMBERGER	J55	C398209	10-23-02	100.3	99.9	99.8
SCHLUMBERGER	J55	C398210	10-23-02	100.2	100.0	99.6
SCHLUMBERGER	J55	C398211	10-23-02	100.1	99.8	99.9
SCHLUMBERGER	J55	C398212	10-23-02	99.9	99.7	100.2
SCHLUMBERGER	J55	C398213	10-23-02	100.1	99.8	99.8
SCHLUMBERGER	J55	C398214	10-23-02	99.9	99.9	100.1
SCHLUMBERGER	J55	C398215	10-23-02	100.1	100.0	99.9
SCHLUMBERGER	J55	C398216	10-23-02	99.8	99.7	99.7
SCHLUMBERGER	J55	C398217	10-23-02	99.9	99.8	99.6
SCHLUMBERGER	J55	C398218	10-23-02	100.1	99.8	99.7
SCHLUMBERGER	J55	C398219	10-23-02	100.2	99.9	99.8
SCHLUMBERGER	J55	C398220	10-23-02	100.2	99.7	99.7
SCHLUMBERGER	J55	C398221	10-23-02	100.1	99.9	99.6
SCHLUMBERGER	J55	C398222	10-23-02	100.0	99.8	100.1
SCHLUMBERGER	J55	C398223	10-23-02	100.3	99.9	99.8
SCHLUMBERGER	J55	C398224	10-23-02	100.0	99.7	100.0
SCHLUMBERGER	J55	C398225	10-23-02	100.3	100.0	100.6
SCHLUMBERGER	J55	C398226	10-23-02	100.3	99.8	100.2
SCHLUMBERGER	J55	C398227	10-23-02	99.9	99.7	99.9
SCHLUMBERGER	J55	C398228	10-23-02	100.1	99.9	99.6
SCHLUMBERGER	J55	C398229	10-23-02	100.3	99.7	99.6
SCHLUMBERGER	J55	C398230	10-23-02	100.1	100.0	100.1
SCHLUMBERGER	J55	C398231	10-23-02	99.9	99.9	99.9
SCHLUMBERGER	J55	C398232	10-23-02	100.3	100.0	99.7
SCHLUMBERGER	J55	C398233	10-23-02	100.1	99.8	100.1
SCHLUMBERGER	J55	C398234	10-23-02	100.2	99.8	99.9
SCHLUMBERGER	J55	C398235	10-23-02	100.0	100.0	100.0
SCHLUMBERGER	J55	C398236	10-23-02	100.0	100.0	99.9
SCHLUMBERGER	J55	C398237	10-23-02	100.3	100.0	99.9
SCHLUMBERGER	J55	C398238	10-23-02	100.2	99.9	100.3
SCHLUMBERGER	J55	C398239	10-23-02	99.8	99.9	99.7
SCHLUMBERGER	J55	C398240	10-23-02	100.2	100.0	100.2
SCHLUMBERGER	J55	C398241	10-23-02	100.3	99.9	100.3
SCHLUMBERGER	J55	C398242	10-23-02	99.9	99.7	99.7
SCHLUMBERGER	J55	C398243	10-23-02	100.1	100.2	100.1
SCHLUMBERGER	J55	C398244	10-23-02	100.0	99.8	99.9
SCHLUMBERGER	J55	C398245	10-23-02	99.9	99.8	100.4
SCHLUMBERGER	J55	C398246	10-23-02	100.2	99.9	99.5
SCHLUMBERGER	J55	C398247	10-23-02	100.1	99.7	100.0
SCHLUMBERGER	J55	C398248	10-23-02	100.1	99.7	100.4

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

PAGE 264
 RUN DATE: 1/14/03
 RUN TIME: 13.26.53

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	J55	C398248	10-23-02	100.1	100.0	99.9
SCHLUMBERGER	J55	C398249	10-23-02	99.7	99.7	99.6
SCHLUMBERGER	J55	C398250	10-23-02	100.1	100.0	99.9
SCHLUMBERGER	J55	C398251	10-23-02	100.1	99.8	99.9
SCHLUMBERGER	J55	C398252	10-23-02	100.0	99.9	100.1
SCHLUMBERGER	J55	C398253	10-23-02	100.2	99.8	99.9
SCHLUMBERGER	J55	C398254	10-23-02	100.3	99.8	100.4
SCHLUMBERGER	J55	C398255	10-23-02	100.1	99.9	100.1
SCHLUMBERGER	J55	C398256	10-23-02	100.1	100.0	100.1
SCHLUMBERGER	J55	C398257	10-23-02	99.9	99.8	99.7
SCHLUMBERGER	J55	C398258	10-23-02	100.2	100.0	100.0
SCHLUMBERGER	J55	C398259	10-23-02	99.9	100.1	99.6
SCHLUMBERGER	J55	C398260	10-23-02	100.1	99.9	100.4
SCHLUMBERGER	J55	C398261	10-23-02	99.8	99.6	99.8
SCHLUMBERGER	J55	C398262	10-23-02	100.1	99.9	100.2
SCHLUMBERGER	J55	C398263	10-23-02	99.9	99.7	100.0
SCHLUMBERGER	J55	C398264	10-23-02	100.1	100.1	100.5
SCHLUMBERGER	J55	C398265	10-23-02	100.1	100.2	100.0
SCHLUMBERGER	J55	C398266	10-23-02	99.8	99.7	100.0
SCHLUMBERGER	J55	C398267	10-23-02	100.1	99.7	99.8
SCHLUMBERGER	J55	C398268	10-23-02	99.9	99.8	99.9
SCHLUMBERGER	J55	C398269	10-23-02	100.0	100.2	99.7
SCHLUMBERGER	J55	C398270	10-23-02	100.3	99.9	100.5
SCHLUMBERGER	J55	C398271	10-23-02	100.1	100.0	100.0
SCHLUMBERGER	J55	C398272	10-23-02	100.0	99.9	99.8
SCHLUMBERGER	J55	C398273	10-23-02	99.9	99.7	100.0
SCHLUMBERGER	J55	C398274	10-23-02	100.3	100.1	100.4
SCHLUMBERGER	J55	C398275	10-23-02	99.8	99.7	99.8
SCHLUMBERGER	J55	C398276	10-23-02	100.1	99.9	100.3
SCHLUMBERGER	J55	C398277	10-23-02	100.0	99.9	99.9
SCHLUMBERGER	J55	C398278	10-23-02	100.2	100.0	99.9
SCHLUMBERGER	J55	C398279	10-23-02	100.2	100.1	99.9
SCHLUMBERGER	J55	C398280	10-23-02	100.1	100.1	100.2
SCHLUMBERGER	J55	C398281	10-23-02	100.3	99.8	100.0
SCHLUMBERGER	J55	C398282	10-23-02	99.8	99.7	99.4
SCHLUMBERGER	J55	C398283	10-23-02	100.2	100.1	100.0
SCHLUMBERGER	J55	C398284	10-23-02	100.1	99.8	99.8
SCHLUMBERGER	J55	C398285	10-23-02	100.2	100.0	100.1
SCHLUMBERGER	J55	C398286	10-23-02	99.9	100.0	100.0
SCHLUMBERGER	J55	C398287	10-23-02	100.2	99.8	100.1
SCHLUMBERGER	J55	C398288	10-23-02	100.1	100.0	100.1
SCHLUMBERGER	J55	C398289	10-23-02	100.0	99.6	99.6
SCHLUMBERGER	J55	C398290	10-23-02	99.8	100.0	100.0
SCHLUMBERGER	J55	C398291	10-23-02	99.9	100.1	100.0
SCHLUMBERGER	J55	C398292	10-23-02	100.0	99.7	100.2
SCHLUMBERGER	J55	C398293	10-23-02	100.2	99.8	100.1
SCHLUMBERGER	J55	C398294	10-23-02	99.8	100.1	99.8
SCHLUMBERGER	J55	C398295	10-23-02	100.2	100.0	100.2
SCHLUMBERGER	J55	C398296	10-23-02	100.2	99.7	100.1
SCHLUMBERGER	J55	C398297	10-23-02	100.1	99.8	100.1
SCHLUMBERGER	J55	C398298	10-23-02	100.1	100.2	100.2

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	J5S	C398299	10-23-02	100.1	99.9	100.0
SCHLUMBERGER	J5S	C398300	10-23-02	100.1	99.9	99.7
SCHLUMBERGER	J5S	C398301	10-23-02	99.9	99.9	100.0
SCHLUMBERGER	J5S	C398302	10-23-02	100.0	100.1	99.9
SCHLUMBERGER	J5S	C398303	10-23-02	100.2	99.9	100.2
SCHLUMBERGER	J5S	C398304	10-23-02	99.8	99.8	100.2
SCHLUMBERGER	J5S	C398305	10-23-02	100.1	99.8	100.0
SCHLUMBERGER	J5S	C398306	10-23-02	100.2	100.2	100.2
SCHLUMBERGER	J5S	C398307	10-23-02	100.1	99.8	100.2
SCHLUMBERGER	J5S	C398308	10-23-02	100.0	100.2	99.8
SCHLUMBERGER	J5S	C398309	10-23-02	99.8	99.7	99.5
SCHLUMBERGER	J5S	C398310	10-23-02	100.0	99.9	100.1
SCHLUMBERGER	J5S	C398311	10-23-02	100.0	99.8	100.0
SCHLUMBERGER	J5S	C398312	10-23-02	100.1	99.9	100.2
SCHLUMBERGER	J5S	C398313	10-23-02	100.3	99.9	100.2
SCHLUMBERGER	J5S	C398314	10-23-02	100.1	99.9	100.5
SCHLUMBERGER	J5S	C398315	10-23-02	100.0	99.9	99.8
SCHLUMBERGER	J5S	C398316	10-23-02	100.1	99.9	100.0
SCHLUMBERGER	J5S	C398317	10-23-02	100.1	99.8	99.9
SCHLUMBERGER	J5S	C398318	10-23-02	100.0	100.0	100.2
SCHLUMBERGER	J5S	C398319	10-23-02	100.1	99.8	100.0
SCHLUMBERGER	J5S	C398320	10-23-02	100.0	99.7	99.8
SCHLUMBERGER	J5S	C398321	10-23-02	100.0	99.8	100.2
SCHLUMBERGER	J5S	C398322	10-23-02	100.1	100.4	100.0
SCHLUMBERGER	J5S	C398323	10-23-02	100.1	99.6	100.1
SCHLUMBERGER	J5S	C398324	10-23-02	100.2	99.7	99.8
SCHLUMBERGER	J5S	C398325	10-23-02	100.3	99.9	100.1
SCHLUMBERGER	J5S	C398326	10-23-02	100.1	99.8	99.8
SCHLUMBERGER	J5S	C398327	10-23-02	100.2	99.8	99.6
SCHLUMBERGER	J5S	C398328	10-23-02	100.2	99.7	100.4
SCHLUMBERGER	J5S	C398329	10-23-02	100.0	99.8	99.9
SCHLUMBERGER	J5S	C398330	10-23-02	99.9	99.9	100.1
SCHLUMBERGER	J5S	C398331	10-23-02	99.9	99.9	100.1
SCHLUMBERGER	J5S	C398332	10-23-02	100.3	100.1	100.3
SCHLUMBERGER	J5S	C398333	10-23-02	100.0	99.8	99.8
SCHLUMBERGER	J5S	C398334	10-23-02	100.1	100.0	100.0
SCHLUMBERGER	J5S	C398335	10-23-02	99.9	99.7	100.1
SCHLUMBERGER	J5S	C398336	10-23-02	100.0	99.9	99.7
SCHLUMBERGER	J5S	C398337	10-23-02	100.1	99.9	99.8
SCHLUMBERGER	J5S	C398338	10-23-02	100.2	100.4	100.4
SCHLUMBERGER	J5S	C398339	10-23-02	99.8	99.9	99.4
SCHLUMBERGER	J5S	C398340	10-23-02	100.3	100.4	99.7
SCHLUMBERGER	J5S	C398341	10-23-02	100.1	99.8	100.1
SCHLUMBERGER	J5S	C398342	10-23-02	100.2	100.2	99.8
SCHLUMBERGER	J5S	C398343	10-23-02	100.2	99.9	100.0
SCHLUMBERGER	J5S	C398344	10-23-02	100.2	99.7	100.1
SCHLUMBERGER	J5S	C398345	10-23-02	99.9	100.2	100.0
SCHLUMBERGER	J5S	C398346	10-23-02	100.1	100.0	99.7
SCHLUMBERGER	J5S	C398347	10-23-02	100.0	100.0	99.8
SCHLUMBERGER	J5S	C398348	10-23-02	100.1	100.0	100.0
SCHLUMBERGER	J5S	C398349	10-23-02	100.2	100.0	100.0

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

PAGE 266
 RUN DATE: 1/14/03
 RUN TIME: 13.26.53

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	J55	C398350	10-23-02	99.9	99.6	100.3
SCHLUMBERGER	J55	C398351	10-23-02	100.2	100.0	100.0
SCHLUMBERGER	J55	C398352	10-23-02	99.9	99.7	99.9
SCHLUMBERGER	J55	C398353	10-23-02	100.1	99.9	100.0
SCHLUMBERGER	J55	C398354	10-23-02	100.2	99.9	100.4
SCHLUMBERGER	J55	C398355	10-23-02	100.0	99.7	99.9
SCHLUMBERGER	J55	C398356	10-23-02	100.2	99.7	100.3
SCHLUMBERGER	J55	C398357	10-23-02	100.3	99.8	100.4
SCHLUMBERGER	J55	C398358	10-23-02	100.0	99.6	99.9
SCHLUMBERGER	J55	C398359	10-23-02	100.0	100.1	99.8
SCHLUMBERGER	J55	C398360	10-23-02	100.0	100.2	100.0
SCHLUMBERGER	J55	C398361	10-23-02	100.0	99.6	99.5
SCHLUMBERGER	J55	C398362	10-23-02	100.1	99.7	100.0
SCHLUMBERGER	J55	C398363	10-23-02	100.0	99.7	99.8
SCHLUMBERGER	J55	C398364	10-23-02	100.3	99.8	100.3
SCHLUMBERGER	J55	C398365	10-23-02	100.1	99.8	100.5
SCHLUMBERGER	J55	C398366	10-23-02	100.2	100.2	100.4
SCHLUMBERGER	J55	C398367	10-23-02	100.0	99.7	99.9
SCHLUMBERGER	J55	C398368	10-23-02	100.0	100.0	99.7
SCHLUMBERGER	J55	C398369	10-23-02	99.9	100.0	100.0
SCHLUMBERGER	J55	C398370	10-23-02	100.0	100.0	100.0
SCHLUMBERGER	J55	C398371	10-23-02	100.2	100.2	100.3
SCHLUMBERGER	J55	C398372	10-23-02	99.9	99.9	99.8
SCHLUMBERGER	J55	C398373	10-23-02	100.1	99.9	100.0
SCHLUMBERGER	J55	C398374	10-23-02	100.3	99.9	99.9
SCHLUMBERGER	J55	C398375	10-23-02	100.3	99.7	100.5
SCHLUMBERGER	J55	C398376	10-23-02	99.9	99.7	99.5
SCHLUMBERGER	J55	C398377	10-23-02	100.2	100.2	100.1
SCHLUMBERGER	J55	C398378	10-23-02	100.1	100.2	99.7
SCHLUMBERGER	J55	C398379	10-23-02	100.0	99.9	100.0
SCHLUMBERGER	J55	C398380	10-23-02	100.2	100.2	100.8
SCHLUMBERGER	J55	C398381	10-23-02	100.0	99.9	100.0
SCHLUMBERGER	J55	C398382	10-23-02	99.9	99.9	99.8
SCHLUMBERGER	J55	C398383	10-23-02	100.0	99.7	99.7
SCHLUMBERGER	J55	C398384	10-23-02	100.0	99.7	99.7
SCHLUMBERGER	J55	C398385	10-23-02	100.2	100.3	100.1
SCHLUMBERGER	J55	C398386	10-23-02	99.9	99.8	99.9
SCHLUMBERGER	J55	C398387	10-23-02	100.0	100.0	99.8
SCHLUMBERGER	J55	C398388	10-23-02	100.1	99.9	99.9
SCHLUMBERGER	J55	C398389	10-23-02	100.2	99.8	100.0
SCHLUMBERGER	J55	C398390	10-23-02	100.2	99.7	100.1
SCHLUMBERGER	J55	C398391	10-23-02	100.1	99.6	100.0
SCHLUMBERGER	J55	C398392	10-23-02	100.2	99.7	99.7
SCHLUMBERGER	J55	C398393	10-23-02	100.1	100.1	99.9
SCHLUMBERGER	J55	C398394	10-23-02	100.1	99.9	100.3
SCHLUMBERGER	J55	C398395	10-23-02	100.1	99.7	99.9
SCHLUMBERGER	J55	C398396	10-23-02	100.2	99.9	100.3
SCHLUMBERGER	J55	C398397	10-23-02	100.0	99.9	100.2
SCHLUMBERGER	J55	C398398	10-23-02	100.1	100.1	100.3
SCHLUMBERGER	J55	C398399	10-23-02	99.9	100.0	99.5
SCHLUMBERGER	J55	C398400	10-23-02	99.9	99.8	100.2

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

PAGE 267
 RUN DATE: 1/14/03
 RUN TIME: 13.26.53

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	J55	C398401	10-23-02	100.2	99.8	100.5
SCHLUMBERGER	J55	C398402	10-23-02	100.0	99.9	99.7
SCHLUMBERGER	J55	C398403	10-23-02	100.2	99.7	99.9
SCHLUMBERGER	J55	C398404	10-23-02	99.8	99.6	100.2
SCHLUMBERGER	J55	C398405	10-23-02	99.9	99.8	99.7
SCHLUMBERGER	J55	C398406	10-23-02	100.0	100.0	100.1
SCHLUMBERGER	J55	C398407	10-23-02	100.3	100.0	100.1
SCHLUMBERGER	J55	C398408	10-23-02	100.2	100.0	100.1
SCHLUMBERGER	J55	C398409	10-23-02	100.0	99.8	99.4
SCHLUMBERGER	J55	C398410	10-23-02	100.2	99.8	99.8
SCHLUMBERGER	J55	C398411	10-23-02	100.1	99.8	100.0
SCHLUMBERGER	J55	C398412	10-23-02	100.1	99.7	99.7
SCHLUMBERGER	J55	C398413	10-23-02	99.9	100.1	100.0
SCHLUMBERGER	J55	C398414	10-23-02	99.9	99.7	99.6
SCHLUMBERGER	J55	C398415	10-23-02	100.1	99.9	100.3
SCHLUMBERGER	J55	C398416	10-23-02	100.0	100.1	100.0
SCHLUMBERGER	J55	C398417	10-23-02	100.3	99.9	100.0
SCHLUMBERGER	J55	C398418	10-23-02	100.0	99.7	99.9
SCHLUMBERGER	J55	C398419	10-23-02	100.2	99.7	100.2
SCHLUMBERGER	J55	C398420	10-23-02	100.1	99.8	100.2
SCHLUMBERGER	J55	C398421	10-23-02	100.1	100.0	99.8
SCHLUMBERGER	J55	C398422	10-23-02	100.1	100.0	100.2
SCHLUMBERGER	J55	C398423	10-23-02	99.9	99.6	99.6
SCHLUMBERGER	J55	C398424	10-23-02	99.9	99.9	100.4
SCHLUMBERGER	J55	C398425	10-23-02	100.3	99.6	100.3
SCHLUMBERGER	J55	C398426	10-23-02	100.1	99.9	100.0
SCHLUMBERGER	J55	C398427	10-23-02	100.1	99.6	99.6
SCHLUMBERGER	J55	C398428	11-11-02	100.2	99.6	100.1
SCHLUMBERGER	J55	C398429	11-11-02	99.8	100.2	99.8
SCHLUMBERGER	J55	C398430	11-11-02	100.0	99.6	100.2
SCHLUMBERGER	J55	C398431	11-11-02	99.9	99.8	99.9
SCHLUMBERGER	J55	C398432	11-11-02	99.9	99.9	99.8
SCHLUMBERGER	J55	C398433	11-11-02	100.0	99.9	100.2
SCHLUMBERGER	J55	C398434	11-11-02	100.1	99.7	99.5
SCHLUMBERGER	J55	C398435	11-11-02	100.1	99.8	99.9
SCHLUMBERGER	J55	C398436	11-11-02	100.2	99.6	99.9
SCHLUMBERGER	J55	C398437	11-11-02	100.1	99.8	99.8
SCHLUMBERGER	J55	C398438	11-11-02	100.0	100.4	100.1
SCHLUMBERGER	J55	C398439	11-11-02	100.3	100.0	99.5
SCHLUMBERGER	J55	C398440	11-11-02	100.1	99.7	100.4
SCHLUMBERGER	J55	C398441	11-11-02	100.0	99.7	99.9
SCHLUMBERGER	J55	C398442	11-11-02	100.1	99.7	99.9
SCHLUMBERGER	J55	C398443	11-11-02	100.1	99.7	99.5
SCHLUMBERGER	J55	C398444	11-11-02	100.1	99.6	100.2
SCHLUMBERGER	J55	C398445	11-11-02	100.2	99.9	99.6
SCHLUMBERGER	J55	C398446	11-11-02	100.0	99.7	99.9
SCHLUMBERGER	J55	C398447	11-11-02	100.0	99.8	99.9
SCHLUMBERGER	J55	C398448	11-11-02	99.8	100.0	100.0
SCHLUMBERGER	J55	C398449	11-11-02	100.0	99.9	99.8
SCHLUMBERGER	J55	C398450	11-11-02	100.1	99.8	100.0
SCHLUMBERGER	J55	C398451	11-11-02	99.9	99.6	99.8

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

PAGE 268
 RUN DATE: 1/14/03
 RUN TIME: 13.26.53

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	J55	C398452	11-11-02	100.1	99.8	99.5
SCHLUMBERGER	J55	C398453	11-11-02	100.1	99.8	99.9
SCHLUMBERGER	J55	C398454	11-11-02	100.0	99.9	100.2
SCHLUMBERGER	J55	C398455	11-11-02	100.1	99.8	100.0
SCHLUMBERGER	J55	C398456	11-11-02	100.0	99.9	100.3
SCHLUMBERGER	J55	C398457	11-11-02	100.0	99.9	99.7
SCHLUMBERGER	J55	C398458	11-11-02	100.1	100.1	100.0
SCHLUMBERGER	J55	C398459	11-11-02	100.0	100.1	100.2
SCHLUMBERGER	J55	C398460	11-11-02	100.0	100.1	100.0
SCHLUMBERGER	J55	C398461	11-11-02	100.1	100.1	99.9
SCHLUMBERGER	J55	C398462	11-11-02	100.1	99.8	100.0
SCHLUMBERGER	J55	C398463	11-11-02	99.9	99.8	99.8
SCHLUMBERGER	J55	C398464	11-11-02	100.0	99.7	100.3
SCHLUMBERGER	J55	C398465	11-11-02	100.1	100.1	99.6
SCHLUMBERGER	J55	C398466	11-11-02	100.0	99.8	99.9
SCHLUMBERGER	J55	C398467	11-11-02	100.1	99.7	100.2
SCHLUMBERGER	J55	C398468	11-11-02	100.1	99.8	100.0
SCHLUMBERGER	J55	C398469	11-11-02	100.1	99.8	99.9
SCHLUMBERGER	J55	C398470	11-11-02	99.9	99.7	99.8
SCHLUMBERGER	J55	C398471	11-11-02	100.0	99.7	99.8
SCHLUMBERGER	J55	C398472	11-11-02	100.0	99.8	99.8
SCHLUMBERGER	J55	C398473	11-11-02	100.0	99.8	99.8
SCHLUMBERGER	J55	C398474	11-11-02	100.1	100.2	100.2
SCHLUMBERGER	J55	C398475	11-11-02	99.9	99.6	99.4
SCHLUMBERGER	J55	C398476	11-11-02	100.0	99.6	99.4
SCHLUMBERGER	J55	C398477	11-11-02	99.9	99.8	99.8
SCHLUMBERGER	J55	C398478	11-11-02	100.1	99.7	99.7
SCHLUMBERGER	J55	C398479	11-11-02	100.1	99.7	100.0
SCHLUMBERGER	J55	C398480	11-11-02	100.2	99.8	99.9
SCHLUMBERGER	J55	C398481	11-11-02	100.0	99.8	99.7
SCHLUMBERGER	J55	C398482	11-11-02	100.0	99.8	99.6
SCHLUMBERGER	J55	C398483	11-11-02	100.1	99.7	99.9
SCHLUMBERGER	J55	C398484	11-11-02	100.0	99.9	100.0
SCHLUMBERGER	J55	C398485	11-11-02	100.0	99.6	99.3
SCHLUMBERGER	J55	C398486	11-11-02	100.0	100.0	99.8
SCHLUMBERGER	J55	C398487	11-11-02	100.0	99.8	100.3
SCHLUMBERGER	J55	C398488	11-11-02	100.0	99.8	99.8
SCHLUMBERGER	J55	C398489	11-11-02	100.1	99.7	100.0
SCHLUMBERGER	J55	C398490	11-11-02	100.0	99.7	99.6
SCHLUMBERGER	J55	C398491	11-11-02	99.9	99.8	99.7
SCHLUMBERGER	J55	C398492	11-11-02	99.9	99.6	99.6
SCHLUMBERGER	J55	C398493	11-11-02	100.1	99.8	100.3
SCHLUMBERGER	J55	C398494	11-11-02	100.0	99.8	100.0
SCHLUMBERGER	J55	C398495	11-11-02	100.0	100.1	100.1
SCHLUMBERGER	J55	C398496	11-11-02	99.9	99.7	99.9
SCHLUMBERGER	J55	C398497	11-11-02	99.9	99.7	99.8
SCHLUMBERGER	J55	C398498	11-11-02	100.2	99.9	99.5
SCHLUMBERGER	J55	C398499	11-11-02	100.2	99.8	100.1
SCHLUMBERGER	J55	C398500	11-11-02	100.1	99.6	99.9
SCHLUMBERGER	J55	C398501	11-11-02	99.9	99.7	99.4
SCHLUMBERGER	J55	C398502	11-11-02	100.1	99.9	100.1

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	J55	C398503	11-11-02	100.0	99.9	99.7
SCHLUMBERGER	J55	C398504	11-11-02	100.0	100.0	100.1
SCHLUMBERGER	J55	C398505	11-11-02	100.1	100.0	100.0
SCHLUMBERGER	J55	C398506	11-11-02	99.8	99.7	99.6
SCHLUMBERGER	J55	C398507	11-11-02	100.2	99.9	100.3
SCHLUMBERGER	J55	C398508	11-11-02	100.0	99.7	99.8
SCHLUMBERGER	J55	C398509	11-11-02	99.8	99.7	99.4
SCHLUMBERGER	J55	C398510	11-11-02	100.0	100.0	100.0
SCHLUMBERGER	J55	C398511	11-11-02	100.1	100.1	99.7
SCHLUMBERGER	J55	C398512	11-11-02	100.0	99.7	100.1
SCHLUMBERGER	J55	C398513	11-11-02	100.1	100.0	100.2
SCHLUMBERGER	J55	C398514	11-11-02	100.0	99.6	99.8
SCHLUMBERGER	J55	C398515	11-11-02	100.2	100.0	99.7
SCHLUMBERGER	J55	C398516	11-11-02	100.1	100.0	100.1
SCHLUMBERGER	J55	C398517	11-11-02	100.0	99.9	100.0
SCHLUMBERGER	J55	C398518	11-11-02	99.9	99.6	99.9
SCHLUMBERGER	J55	C398519	11-11-02	100.0	99.9	99.9
SCHLUMBERGER	J55	C398520	11-11-02	100.1	99.9	99.8
SCHLUMBERGER	J55	C398521	11-11-02	100.1	99.9	100.0
SCHLUMBERGER	J55	C398522	11-11-02	100.1	100.1	100.2
SCHLUMBERGER	J55	C398523	11-11-02	100.0	99.7	99.9
SCHLUMBERGER	J55	C398524	11-11-02	100.0	99.7	100.3
SCHLUMBERGER	J55	C398525	11-11-02	100.0	99.8	99.8
SCHLUMBERGER	J55	C398526	11-11-02	100.1	99.8	99.5
SCHLUMBERGER	J55	C398527	11-11-02	100.0	100.0	99.8
SCHLUMBERGER	J55	C398528	11-11-02	100.1	99.7	100.0
SCHLUMBERGER	J55	C398529	11-11-02	100.1	99.9	100.0
SCHLUMBERGER	J55	C398530	11-11-02	100.0	99.6	99.5
SCHLUMBERGER	J55	C398531	11-11-02	100.1	100.2	100.3
SCHLUMBERGER	J55	C398532	11-11-02	99.9	99.8	99.9
SCHLUMBERGER	J55	C398533	11-11-02	100.2	99.8	99.8
SCHLUMBERGER	J55	C398534	11-11-02	100.3	99.8	99.8
SCHLUMBERGER	J55	C398535	11-11-02	100.0	99.9	99.3
SCHLUMBERGER	J55	C398536	11-11-02	99.9	99.9	99.9
SCHLUMBERGER	J55	C398537	11-11-02	99.8	99.7	100.0
SCHLUMBERGER	J55	C398538	11-11-02	100.0	99.7	100.1
SCHLUMBERGER	J55	C398539	11-11-02	100.0	99.6	99.6
SCHLUMBERGER	J55	C398540	11-11-02	99.9	99.7	99.9
SCHLUMBERGER	J55	C398541	11-11-02	100.2	99.7	99.6
SCHLUMBERGER	J55	C398542	11-11-02	100.1	99.9	99.8
SCHLUMBERGER	J55	C398543	11-11-02	100.0	99.8	99.9
SCHLUMBERGER	J55	C398544	11-11-02	100.1	100.0	99.8
SCHLUMBERGER	J55	C398545	11-11-02	100.0	99.9	99.9
SCHLUMBERGER	J55	C398546	11-11-02	100.1	100.0	100.1
SCHLUMBERGER	J55	C398547	11-11-02	100.0	99.7	100.0
SCHLUMBERGER	J55	C398548	11-11-02	100.2	99.9	100.0
SCHLUMBERGER	J55	C398549	11-11-02	100.0	99.8	99.7
SCHLUMBERGER	J55	C398550	11-11-02	99.9	99.9	99.7
SCHLUMBERGER	J55	C398551	11-11-02	100.1	100.3	100.3
SCHLUMBERGER	J55	C398552	11-11-02	100.0	99.7	99.7
SCHLUMBERGER	J55	C398553	11-11-02	100.1	99.9	99.7

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

PAGE 270
 RUN DATE: 1/14/03
 RUN TIME: 13.26.53

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	J55	C398554	11-11-02	100.0	99.8	99.8
SCHLUMBERGER	J55	C398555	11-11-02	100.0	100.0	99.6
SCHLUMBERGER	J55	C398556	11-11-02	100.0	99.8	99.9
SCHLUMBERGER	J55	C398557	11-11-02	100.3	100.0	100.0
SCHLUMBERGER	J55	C398558	11-11-02	99.9	99.6	99.7
SCHLUMBERGER	J55	C398559	11-11-02	100.0	99.7	99.8
SCHLUMBERGER	J55	C398560	11-11-02	100.1	99.8	99.8
SCHLUMBERGER	J55	C398561	11-11-02	100.0	99.7	99.5
SCHLUMBERGER	J55	C398562	11-11-02	100.0	99.7	100.0
SCHLUMBERGER	J55	C398563	11-11-02	100.0	99.8	99.9
SCHLUMBERGER	J55	C398564	11-11-02	100.2	99.7	99.7
SCHLUMBERGER	J55	C398565	11-11-02	100.1	99.9	99.6
SCHLUMBERGER	J55	C398566	11-11-02	100.1	99.8	100.0
SCHLUMBERGER	J55	C398567	11-11-02	100.1	99.8	100.0
SCHLUMBERGER	J55	C398568	11-11-02	100.0	100.1	99.9
SCHLUMBERGER	J55	C398569	11-11-02	100.0	99.9	99.8
SCHLUMBERGER	J55	C398570	11-11-02	99.9	99.9	99.9
SCHLUMBERGER	J55	C398571	11-11-02	100.1	99.9	99.9
SCHLUMBERGER	J55	C398572	11-11-02	100.0	99.8	99.7
SCHLUMBERGER	J55	C398573	11-11-02	100.1	99.8	99.7
SCHLUMBERGER	J55	C398574	11-11-02	99.9	99.7	100.3
SCHLUMBERGER	J55	C398575	11-11-02	99.8	99.6	99.6
SCHLUMBERGER	J55	C398576	11-11-02	99.9	99.6	99.7
SCHLUMBERGER	J55	C398577	11-11-02	100.1	100.2	100.2
SCHLUMBERGER	J55	C398578	11-11-02	100.2	99.8	100.2
SCHLUMBERGER	J55	C398579	11-11-02	100.1	99.7	99.9
SCHLUMBERGER	J55	C398580	11-11-02	99.9	99.6	99.4
SCHLUMBERGER	J55	C398581	11-11-02	99.9	99.7	100.0
SCHLUMBERGER	J55	C398582	11-11-02	100.0	100.0	100.1
SCHLUMBERGER	J55	C398583	11-11-02	100.2	100.3	99.9
SCHLUMBERGER	J55	C398584	11-11-02	100.2	100.1	100.1
SCHLUMBERGER	J55	C398585	11-11-02	100.0	99.7	99.9
SCHLUMBERGER	J55	C398586	11-11-02	100.0	99.6	100.3
SCHLUMBERGER	J55	C398587	11-11-02	100.0	99.7	99.7
SCHLUMBERGER	J55	C398588	11-11-02	99.9	100.0	99.9
SCHLUMBERGER	J55	C398589	11-11-02	100.0	99.9	100.2
SCHLUMBERGER	J55	C398590	11-11-02	100.0	99.7	99.9
SCHLUMBERGER	J55	C398591	11-11-02	100.1	99.9	100.0
SCHLUMBERGER	J55	C398592	11-11-02	99.9	99.9	99.6
SCHLUMBERGER	J55	C398593	11-11-02	99.8	99.6	99.9
SCHLUMBERGER	J55	C398594	11-11-02	100.0	99.8	100.3
SCHLUMBERGER	J55	C398595	11-11-02	100.0	99.7	100.1
SCHLUMBERGER	J55	C398596	11-11-02	99.9	100.3	100.0
SCHLUMBERGER	J55	C398597	11-11-02	100.1	99.8	99.8
SCHLUMBERGER	J55	C398598	11-11-02	100.2	99.8	100.2
SCHLUMBERGER	J55	C398599	11-11-02	99.9	99.6	99.4
SCHLUMBERGER	J55	C398600	11-11-02	100.1	99.8	99.9
SCHLUMBERGER	J55	C398601	11-11-02	100.2	99.9	100.1
SCHLUMBERGER	J55	C398602	11-11-02	100.1	100.0	99.9
SCHLUMBERGER	J55	C398603	11-11-02	100.1	99.8	99.9
SCHLUMBERGER	J55	C398604	11-11-02	100.0	99.8	100.1

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	J55	C398605	11-11-02	100.0	100.0	100.2
SCHLUMBERGER	J55	C398606	11-11-02	100.0	99.9	99.3
SCHLUMBERGER	J55	C398607	11-11-02	100.1	99.8	99.7
SCHLUMBERGER	J55	C398608	11-11-02	99.9	99.8	99.9
SCHLUMBERGER	J55	C398609	11-11-02	100.0	99.8	99.5
SCHLUMBERGER	J55	C398610	11-11-02	100.0	99.7	100.1
SCHLUMBERGER	J55	C398611	11-11-02	100.0	99.8	100.0
SCHLUMBERGER	J55	C398612	11-11-02	100.1	100.1	99.8
SCHLUMBERGER	J55	C398613	11-11-02	100.0	99.8	99.7
SCHLUMBERGER	J55	C398614	11-11-02	100.1	99.6	100.0
SCHLUMBERGER	J55	C398615	11-11-02	100.1	99.9	100.1
SCHLUMBERGER	J55	C398616	11-11-02	99.9	99.7	99.6
SCHLUMBERGER	J55	C398617	11-11-02	100.3	100.1	99.8
SCHLUMBERGER	J55	C398618	11-11-02	100.0	100.1	100.7
SCHLUMBERGER	J55	C398619	11-11-02	100.3	100.1	100.2
SCHLUMBERGER	J55	C398620	11-11-02	100.1	99.6	99.5
SCHLUMBERGER	J55	C398621	11-11-02	99.8	99.7	99.9
SCHLUMBERGER	J55	C398622	11-11-02	99.9	100.3	99.9
SCHLUMBERGER	J55	C398623	11-11-02	100.0	99.8	99.6
SCHLUMBERGER	J55	C398624	11-11-02	100.0	99.7	99.6
SCHLUMBERGER	J55	C398625	11-11-02	99.8	99.6	99.4
SCHLUMBERGER	J55	C398626	11-11-02	100.2	99.6	99.7
SCHLUMBERGER	J55	C398627	11-11-02	100.0	99.9	99.8
SCHLUMBERGER	J55	C398628	11-11-02	100.0	99.7	100.0
SCHLUMBERGER	J55	C398629	11-11-02	99.9	99.7	99.6
SCHLUMBERGER	J55	C398630	11-11-02	100.0	99.7	99.9
SCHLUMBERGER	J55	C398631	11-11-02	100.2	99.8	100.3
SCHLUMBERGER	J55	C398632	11-11-02	100.0	99.9	99.8
SCHLUMBERGER	J55	C398633	11-11-02	100.0	99.7	99.5
SCHLUMBERGER	J55	C398634	11-11-02	100.1	99.7	99.5
SCHLUMBERGER	J55	C398635	11-11-02	100.0	99.9	100.1
SCHLUMBERGER	J55	C398636	11-11-02	100.0	99.7	100.0
SCHLUMBERGER	J55	C398637	11-11-02	100.1	99.8	99.9
SCHLUMBERGER	J55	C398638	11-11-02	100.1	99.7	100.0
SCHLUMBERGER	J55	C398639	11-11-02	100.3	100.1	100.0
SCHLUMBERGER	J55	C398640	11-11-02	99.9	99.8	99.9
SCHLUMBERGER	J55	C398641	11-11-02	100.0	99.8	99.5
SCHLUMBERGER	J55	C398642	11-11-02	100.1	99.8	99.8
SCHLUMBERGER	J55	C398643	11-11-02	100.2	99.7	100.1
SCHLUMBERGER	J55	C398644	11-11-02	100.1	99.8	99.8
SCHLUMBERGER	J55	C398645	11-11-02	100.2	99.8	100.0
SCHLUMBERGER	J55	C398646	11-11-02	100.0	99.9	99.8
SCHLUMBERGER	J55	C398647	11-11-02	100.1	100.1	99.8
SCHLUMBERGER	J55	C398648	11-11-02	99.9	99.7	99.9
SCHLUMBERGER	J55	C398649	11-11-02	100.0	99.7	99.4
SCHLUMBERGER	J55	C398650	11-11-02	100.0	99.6	99.6
SCHLUMBERGER	J55	C398651	11-11-02	100.0	99.9	99.6
SCHLUMBERGER	J55	C398652	11-11-02	99.9	99.9	99.5
SCHLUMBERGER	J55	C398653	11-11-02	100.0	100.0	100.1
SCHLUMBERGER	J55	C398654	11-11-02	100.0	100.0	99.6
SCHLUMBERGER	J55	C398655	11-11-02	100.0	99.6	99.6

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

PAGE 272
 RUN DATE: 1/14/03
 RUN TIME: 13.26.53

MANUFACTURER	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	C398656	11-11-02	100.0	99.7	99.9
SCHLUMBERGER	C398657	11-11-02	100.0	100.0	100.0
SCHLUMBERGER	C398658	11-11-02	99.9	99.6	100.3
SCHLUMBERGER	C398659	11-11-02	100.2	100.0	100.0
SCHLUMBERGER	C398660	11-11-02	100.0	99.8	99.5
SCHLUMBERGER	C398661	11-11-02	100.0	99.9	99.9
SCHLUMBERGER	C398662	11-11-02	99.9	100.4	99.9
SCHLUMBERGER	C398663	11-11-02	100.0	99.6	99.7
SCHLUMBERGER	C398664	11-11-02	99.8	99.6	99.3
SCHLUMBERGER	C398665	11-11-02	100.1	99.6	99.4
SCHLUMBERGER	C398666	11-11-02	100.0	100.0	100.0
SCHLUMBERGER	C398667	11-11-02	100.0	100.0	99.4
SCHLUMBERGER	C398668	11-11-02	99.9	99.6	100.2
SCHLUMBERGER	C398669	11-11-02	99.9	100.3	100.0
SCHLUMBERGER	C398670	11-11-02	100.0	99.7	100.0
SCHLUMBERGER	C398671	11-11-02	100.1	100.0	100.3
SCHLUMBERGER	C398672	11-11-02	100.1	100.0	100.0
SCHLUMBERGER	C398673	11-11-02	100.0	100.0	100.0
SCHLUMBERGER	C398674	11-11-02	100.1	99.6	99.6
SCHLUMBERGER	C398675	11-11-02	100.2	100.4	100.0
SCHLUMBERGER	C398676	11-11-02	100.2	99.8	99.6
SCHLUMBERGER	C398677	11-11-02	100.2	100.0	100.1
SCHLUMBERGER	C398678	11-11-02	100.1	99.9	99.8
SCHLUMBERGER	C398679	11-11-02	100.3	100.0	100.1
SCHLUMBERGER	C398680	11-11-02	100.0	99.9	99.5
SCHLUMBERGER	C398681	11-11-02	100.2	99.9	99.8
SCHLUMBERGER	C398682	11-11-02	99.8	100.0	100.1
SCHLUMBERGER	C398683	11-11-02	100.1	99.8	99.9
SCHLUMBERGER	C398684	11-11-02	100.1	99.6	99.9
SCHLUMBERGER	C398685	11-11-02	99.9	99.6	99.6
SCHLUMBERGER	C398686	11-11-02	99.9	99.8	99.5
SCHLUMBERGER	C398687	11-11-02	100.2	99.8	99.5
SCHLUMBERGER	C398688	11-11-02	100.1	100.1	100.0
SCHLUMBERGER	C398689	11-11-02	100.1	100.0	99.7
SCHLUMBERGER	C398690	11-11-02	100.2	100.0	99.5
SCHLUMBERGER	C398691	11-11-02	100.1	100.1	99.6
SCHLUMBERGER	C398692	11-11-02	100.0	99.8	100.0
SCHLUMBERGER	C398693	11-11-02	100.0	99.6	99.9
SCHLUMBERGER	C398694	11-11-02	100.1	99.7	100.1
SCHLUMBERGER	C398695	11-11-02	100.2	99.8	99.7
SCHLUMBERGER	C398696	11-11-02	100.1	99.8	99.9
SCHLUMBERGER	C398697	11-11-02	100.1	100.3	100.3
SCHLUMBERGER	C398698	11-11-02	99.9	99.7	99.8
SCHLUMBERGER	C398699	11-11-02	99.9	99.6	99.8
SCHLUMBERGER	C398700	11-11-02	99.9	99.9	99.5
SCHLUMBERGER	C398701	11-11-02	100.1	100.2	99.7
SCHLUMBERGER	C398702	11-11-02	100.0	99.7	100.0
SCHLUMBERGER	C398703	11-11-02	100.2	100.2	100.1
SCHLUMBERGER	C398704	11-11-02	99.9	99.9	99.6
SCHLUMBERGER	C398705	11-11-02	100.0	99.7	99.9
SCHLUMBERGER	C398706	11-11-02	100.2	100.0	100.0

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	J55	C398707	11-11-02	100.0	100.3	99.7
SCHLUMBERGER	J55	C398708	11-11-02	100.1	99.7	99.9
SCHLUMBERGER	J55	C398709	11-11-02	100.1	100.1	99.8
SCHLUMBERGER	J55	C398710	11-11-02	100.0	99.7	99.6
SCHLUMBERGER	J55	C398711	11-11-02	100.0	99.8	99.4
SCHLUMBERGER	J55	C398712	11-11-02	99.9	100.3	99.5
SCHLUMBERGER	J55	C398713	11-11-02	100.0	99.8	99.7
SCHLUMBERGER	J55	C398714	11-11-02	100.2	100.0	100.0
SCHLUMBERGER	J55	C398715	11-11-02	99.9	100.2	99.7
SCHLUMBERGER	J55	C398716	11-11-02	100.0	99.8	99.3
SCHLUMBERGER	J55	C398717	11-11-02	100.1	99.7	99.5
SCHLUMBERGER	J55	C398718	11-11-02	100.1	99.9	100.1
SCHLUMBERGER	J55	C398719	11-11-02	100.1	99.9	100.2
SCHLUMBERGER	J55	C398720	11-11-02	100.2	100.5	100.3
SCHLUMBERGER	J55	C398721	11-11-02	100.2	99.8	100.0
SCHLUMBERGER	J55	C398722	11-11-02	100.2	99.9	100.1
SCHLUMBERGER	J55	C398723	11-11-02	100.2	99.8	99.6
SCHLUMBERGER	J55	C398724	11-11-02	100.2	99.9	99.6
SCHLUMBERGER	J55	C398725	11-11-02	99.9	99.7	100.0
SCHLUMBERGER	J55	C398726	11-11-02	100.2	99.7	99.8
SCHLUMBERGER	J55	C398727	11-11-02	100.0	99.6	99.5
SCHLUMBERGER	J55	C398728	11-11-02	100.1	99.9	99.8
SCHLUMBERGER	J55	C398729	11-11-02	100.2	99.7	99.6
SCHLUMBERGER	J55	C398730	11-11-02	100.2	99.8	100.2
SCHLUMBERGER	J55	C398731	11-11-02	100.1	99.8	99.5
SCHLUMBERGER	J55	C398732	11-11-02	100.0	99.9	99.9
SCHLUMBERGER	J55	C398733	11-11-02	99.9	100.1	99.9
SCHLUMBERGER	J55	C398734	11-11-02	99.9	99.8	99.8
SCHLUMBERGER	J55	C398735	11-11-02	99.9	100.0	99.9
SCHLUMBERGER	J55	C398736	11-11-02	100.2	99.8	99.9
SCHLUMBERGER	J55	C398737	11-11-02	99.8	99.8	99.5
SCHLUMBERGER	J55	C398738	11-11-02	100.0	99.9	99.4
SCHLUMBERGER	J55	C398739	11-11-02	100.2	100.2	100.0
SCHLUMBERGER	J55	C398740	11-11-02	100.2	99.9	100.1
SCHLUMBERGER	J55	C398741	11-11-02	100.3	99.9	100.2
SCHLUMBERGER	J55	C398742	11-11-02	100.1	99.9	100.1
SCHLUMBERGER	J55	C398743	11-11-02	100.2	100.1	100.3
SCHLUMBERGER	J55	C398744	11-11-02	100.0	100.4	99.5
SCHLUMBERGER	J55	C398745	11-11-02	100.1	100.0	99.8
SCHLUMBERGER	J55	C398746	11-11-02	100.0	99.7	99.6
SCHLUMBERGER	J55	C398747	11-11-02	99.9	99.9	99.7
SCHLUMBERGER	J55	C398748	11-11-02	100.0	99.6	99.6
SCHLUMBERGER	J55	C398749	11-11-02	100.0	99.7	99.6
SCHLUMBERGER	J55	C398750	11-11-02	100.0	99.8	99.4
SCHLUMBERGER	J55	C398751	11-11-02	100.0	99.7	100.0
SCHLUMBERGER	J55	C398752	11-11-02	100.2	99.7	100.2
SCHLUMBERGER	J55	C398753	11-11-02	100.1	99.9	99.8
SCHLUMBERGER	J55	C398754	11-11-02	100.1	99.9	100.0
SCHLUMBERGER	J55	C398755	11-11-02	100.0	100.0	100.0
SCHLUMBERGER	J55	C398756	11-11-02	99.8	99.9	99.9
SCHLUMBERGER	J55	C398757	11-11-02	100.1	100.0	100.2

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

PAGE 274
 RUN DATE: 1/14/03
 RUN TIME: 13.26.53

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	J5S	C398758	11-11-02	99.9	100.2	100.0
SCHLUMBERGER	J5S	C398759	11-11-02	100.3	99.9	100.3
SCHLUMBERGER	J5S	C398760	11-11-02	100.1	99.9	99.6
SCHLUMBERGER	J5S	C398761	11-11-02	100.1	99.8	99.8
SCHLUMBERGER	J5S	C398762	11-11-02	100.3	99.8	99.6
SCHLUMBERGER	J5S	C398763	11-11-02	100.3	99.9	100.1
SCHLUMBERGER	J5S	C398764	11-11-02	100.1	99.6	99.6
SCHLUMBERGER	J5S	C398765	11-11-02	99.9	99.8	99.6
SCHLUMBERGER	J5S	C398766	11-11-02	99.9	100.3	99.8
SCHLUMBERGER	J5S	C398767	11-11-02	99.9	99.7	100.2
SCHLUMBERGER	J5S	C398768	11-11-02	100.3	100.0	100.1
SCHLUMBERGER	J5S	C398769	11-11-02	100.0	100.3	99.6
SCHLUMBERGER	J5S	C398770	11-11-02	99.9	99.8	99.6
SCHLUMBERGER	J5S	C398771	11-11-02	100.1	99.9	100.0
SCHLUMBERGER	J5S	C398772	11-11-02	99.9	99.6	99.7
SCHLUMBERGER	J5S	C398773	11-11-02	100.2	99.9	100.2
SCHLUMBERGER	J5S	C398774	11-11-02	100.3	99.9	100.2
SCHLUMBERGER	J5S	C398775	11-11-02	100.3	100.0	99.9
SCHLUMBERGER	J5S	C398776	11-11-02	99.9	99.8	99.7
SCHLUMBERGER	J5S	C398777	11-11-02	100.1	99.9	100.1
SCHLUMBERGER	J5S	C398778	11-11-02	99.9	99.9	99.7
SCHLUMBERGER	J5S	C398779	11-11-02	99.9	99.6	99.9
SCHLUMBERGER	J5S	C398780	11-11-02	100.0	100.0	100.1
SCHLUMBERGER	J5S	C398781	11-11-02	100.0	99.7	100.0
SCHLUMBERGER	J5S	C398782	11-11-02	100.0	100.0	99.8
SCHLUMBERGER	J5S	C398783	11-11-02	99.9	99.8	99.5
SCHLUMBERGER	J5S	C398784	11-11-02	100.2	99.7	99.7
SCHLUMBERGER	J5S	C398785	11-11-02	100.2	100.0	99.3
SCHLUMBERGER	J5S	C398786	11-11-02	99.9	100.1	99.6
SCHLUMBERGER	J5S	C398787	11-11-02	100.1	100.5	99.8
SCHLUMBERGER	J5S	C398788	11-11-02	100.0	100.0	99.4
SCHLUMBERGER	J5S	C398789	11-11-02	99.9	99.7	99.5
SCHLUMBERGER	J5S	C398790	11-11-02	99.8	99.7	99.4
SCHLUMBERGER	J5S	C398791	11-11-02	100.1	100.1	99.4
SCHLUMBERGER	J5S	C398792	11-11-02	100.0	99.7	99.6
SCHLUMBERGER	J5S	C398793	11-11-02	99.8	100.4	99.9
SCHLUMBERGER	J5S	C398794	11-11-02	100.0	99.8	100.1
SCHLUMBERGER	J5S	C398795	11-11-02	99.8	99.7	100.0
SCHLUMBERGER	J5S	C398796	11-11-02	100.2	100.0	99.8
SCHLUMBERGER	J5S	C398797	11-11-02	100.1	99.8	99.9
SCHLUMBERGER	J5S	C398798	11-11-02	99.9	99.7	99.6
SCHLUMBERGER	J5S	C398799	11-11-02	100.0	99.8	99.6
SCHLUMBERGER	J5S	C398800	11-11-02	99.9	99.7	99.6
SCHLUMBERGER	J5S	C398801	11-11-02	100.0	99.9	99.8
SCHLUMBERGER	J5S	C398802	11-11-02	100.0	99.9	99.9
SCHLUMBERGER	J5S	C398803	11-11-02	99.9	99.7	99.6
SCHLUMBERGER	J5S	C398804	11-11-02	100.2	99.6	100.3
SCHLUMBERGER	J5S	C398805	11-11-02	100.1	99.8	100.0
SCHLUMBERGER	J5S	C398806	11-11-02	100.2	99.8	99.7
SCHLUMBERGER	J5S	C398807	11-11-02	100.0	99.8	99.8
SCHLUMBERGER	J5S	C398808	11-11-02	100.1	99.9	99.9

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

PAGE 275
 RUN DATE: 1/14/03
 RUN TIME: 13.26.53

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	J5S	C398809	11-11-02	100.3	99.9	100.1
SCHLUMBERGER	J5S	C398810	11-11-02	99.9	99.6	99.8
SCHLUMBERGER	J5S	C398811	11-11-02	100.0	99.9	100.2
SCHLUMBERGER	J5S	C398812	11-11-02	100.2	99.8	100.1
SCHLUMBERGER	J5S	C398813	11-11-02	99.9	99.9	99.6
SCHLUMBERGER	J5S	C398814	11-11-02	99.9	100.3	99.6
SCHLUMBERGER	J5S	C398815	11-11-02	100.1	100.3	100.2
SCHLUMBERGER	J5S	C398816	11-11-02	100.0	100.2	100.2
SCHLUMBERGER	J5S	C398817	11-11-02	100.2	99.7	100.3
SCHLUMBERGER	J5S	C398818	11-11-02	100.1	99.7	100.1
SCHLUMBERGER	J5S	C398819	11-11-02	100.0	99.7	100.1
SCHLUMBERGER	J5S	C398820	11-11-02	100.0	99.8	99.9
SCHLUMBERGER	J5S	C398821	11-11-02	99.8	100.0	100.3
SCHLUMBERGER	J5S	C398822	11-11-02	100.1	99.9	100.3
SCHLUMBERGER	J5S	C398823	11-11-02	100.3	99.9	100.1
SCHLUMBERGER	J5S	C398824	11-11-02	100.1	99.7	100.0
SCHLUMBERGER	J5S	C398825	11-11-02	100.1	99.8	100.0
SCHLUMBERGER	J5S	C398826	11-11-02	99.9	99.7	99.5
SCHLUMBERGER	J5S	C398827	11-11-02	100.1	100.0	100.4
SCHLUMBERGER	J5S	C398828	11-11-02	100.1	99.7	99.6
SCHLUMBERGER	J5S	C398829	11-11-02	100.0	100.0	100.2
SCHLUMBERGER	J5S	C398830	11-11-02	100.1	99.7	100.1
SCHLUMBERGER	J5S	C398831	11-11-02	99.9	99.7	99.9
SCHLUMBERGER	J5S	C398832	11-11-02	100.2	99.8	100.4
SCHLUMBERGER	J5S	C398833	11-11-02	100.0	99.7	100.1
SCHLUMBERGER	J5S	C398834	11-11-02	100.2	100.3	100.7
SCHLUMBERGER	J5S	C398835	11-11-02	100.1	99.6	100.1
SCHLUMBERGER	J5S	C398836	11-11-02	99.8	99.7	99.8
SCHLUMBERGER	J5S	C398837	11-11-02	100.0	99.6	99.8
SCHLUMBERGER	J5S	C398838	11-11-02	100.0	99.9	99.7
SCHLUMBERGER	J5S	C398839	11-11-02	100.2	100.2	100.1
SCHLUMBERGER	J5S	C398840	11-11-02	100.1	100.3	99.4
SCHLUMBERGER	J5S	C398841	11-11-02	100.1	100.0	99.9
SCHLUMBERGER	J5S	C398842	11-11-02	100.1	99.9	100.1
SCHLUMBERGER	J5S	C398843	11-11-02	100.1	99.6	100.0
SCHLUMBERGER	J5S	C398844	11-11-02	100.2	99.7	100.2
SCHLUMBERGER	J5S	C398845	11-11-02	100.2	99.7	100.0
SCHLUMBERGER	J5S	C398846	11-11-02	100.1	99.6	100.3
SCHLUMBERGER	J5S	C398847	11-11-02	100.0	99.9	100.2
SCHLUMBERGER	J5S	C398848	11-11-02	100.0	99.6	100.2
SCHLUMBERGER	J5S	C398849	11-11-02	100.3	100.0	100.0
SCHLUMBERGER	J5S	C398850	11-11-02	100.0	100.1	100.3
SCHLUMBERGER	J5S	C398851	11-11-02	99.9	100.1	99.9
SCHLUMBERGER	J5S	C398852	11-11-02	100.0	100.0	99.8
SCHLUMBERGER	J5S	C398853	11-11-02	100.0	99.7	100.0
SCHLUMBERGER	J5S	C398854	11-11-02	100.2	99.8	99.8
SCHLUMBERGER	J5S	C398855	11-11-02	100.1	99.8	100.0
SCHLUMBERGER	J5S	C398856	11-11-02	100.1	99.7	100.5
SCHLUMBERGER	J5S	C398857	11-11-02	99.8	100.0	99.7
SCHLUMBERGER	J5S	C398858	11-11-02	100.2	99.7	100.0
SCHLUMBERGER	J5S	C398859	11-11-02	100.0	99.7	99.8

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

PAGE 276
 RUN DATE: 1/14/03
 RUN TIME: 13.26.53

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	J5S	C398860	11-11-02	99.9	99.6	99.5
SCHLUMBERGER	J5S	C398861	11-11-02	99.9	99.6	100.0
SCHLUMBERGER	J5S	C398862	11-11-02	99.8	100.1	99.9
SCHLUMBERGER	J5S	C398863	11-11-02	100.2	99.8	100.2
SCHLUMBERGER	J5S	C398864	11-11-02	100.2	99.9	99.9
SCHLUMBERGER	J5S	C398865	11-11-02	100.1	99.7	99.8
SCHLUMBERGER	J5S	C398866	11-11-02	100.1	100.0	100.0
SCHLUMBERGER	J5S	C398867	11-11-02	100.2	99.6	99.9
SCHLUMBERGER	J5S	C398868	11-11-02	100.0	99.7	99.9
SCHLUMBERGER	J5S	C398869	11-11-02	100.0	99.8	100.1
SCHLUMBERGER	J5S	C398870	11-11-02	100.1	99.7	99.9
SCHLUMBERGER	J5S	C398871	11-11-02	100.1	99.7	100.0
SCHLUMBERGER	J5S	C398872	11-11-02	100.0	99.6	99.7
SCHLUMBERGER	J5S	C398873	11-11-02	99.8	100.1	99.4
SCHLUMBERGER	J5S	C398874	11-11-02	100.2	100.0	100.4
SCHLUMBERGER	J5S	C398875	11-11-02	100.0	99.7	100.1
SCHLUMBERGER	J5S	C398876	11-11-02	99.9	99.9	99.8
SCHLUMBERGER	J5S	C398877	11-11-02	99.8	100.1	100.1
SCHLUMBERGER	J5S	C398878	11-11-02	100.1	99.8	100.3
SCHLUMBERGER	J5S	C398879	11-11-02	99.9	99.8	100.2
SCHLUMBERGER	J5S	C398880	11-11-02	100.2	100.1	100.0
SCHLUMBERGER	J5S	C398881	11-11-02	100.0	99.7	99.8
SCHLUMBERGER	J5S	C398882	11-11-02	100.1	99.7	100.3
SCHLUMBERGER	J5S	C398883	11-11-02	100.0	100.2	100.2
SCHLUMBERGER	J5S	C398884	11-11-02	100.1	100.0	99.9
SCHLUMBERGER	J5S	C398885	11-11-02	100.2	100.0	100.3
SCHLUMBERGER	J5S	C398886	11-11-02	100.1	100.1	100.2
SCHLUMBERGER	J5S	C398887	11-11-02	100.3	99.8	100.0
SCHLUMBERGER	J5S	C398888	11-11-02	99.7	99.9	99.7
SCHLUMBERGER	J5S	C398889	11-11-02	100.1	100.5	100.0
SCHLUMBERGER	J5S	C398890	11-11-02	100.0	99.6	100.0
SCHLUMBERGER	J5S	C398891	11-11-02	100.0	100.0	100.1
SCHLUMBERGER	J5S	C398892	11-11-02	100.1	99.9	100.0
SCHLUMBERGER	J5S	C398893	11-11-02	100.3	100.0	100.0
SCHLUMBERGER	J5S	C398894	11-11-02	100.2	100.0	100.4
SCHLUMBERGER	J5S	C398895	11-11-02	100.1	99.9	99.8
SCHLUMBERGER	J5S	C398896	11-11-02	100.1	99.7	99.5
SCHLUMBERGER	J5S	C398897	11-11-02	100.2	99.6	99.8
SCHLUMBERGER	J5S	C398898	11-11-02	99.8	99.7	100.0
SCHLUMBERGER	J5S	C398899	11-11-02	100.0	99.6	100.1
SCHLUMBERGER	J5S	C398900	11-11-02	100.1	99.9	100.3
SCHLUMBERGER	J5S	C398901	11-11-02	100.0	99.7	100.2
SCHLUMBERGER	J5S	C398902	11-11-02	100.0	99.6	100.2
SCHLUMBERGER	J5S	C398903	11-11-02	100.1	99.8	100.1
SCHLUMBERGER	J5S	C398904	11-11-02	100.0	100.1	99.8
SCHLUMBERGER	J5S	C398905	11-11-02	100.2	99.7	99.8
SCHLUMBERGER	J5S	C398906	11-11-02	100.0	99.7	100.1
SCHLUMBERGER	J5S	C398907	11-11-02	100.0	99.7	99.8
SCHLUMBERGER	J5S	C398908	11-11-02	100.3	99.9	100.5
SCHLUMBERGER	J5S	C398909	11-11-02	100.2	100.0	100.3
SCHLUMBERGER	J5S	C398910	11-11-02	100.1	99.8	100.0

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	J55	C398911	11-11-02	100.1	99.8	100.3
SCHLUMBERGER	J55	C398912	11-11-02	100.0	99.9	100.0
SCHLUMBERGER	J55	C398913	11-11-02	99.9	99.7	99.6
SCHLUMBERGER	J55	C398914	11-11-02	100.2	99.8	99.8
SCHLUMBERGER	J55	C398915	11-11-02	100.1	100.1	100.1
SCHLUMBERGER	J55	C398916	11-11-02	99.9	100.2	99.7
SCHLUMBERGER	J55	C398917	11-11-02	100.2	99.9	100.0
SCHLUMBERGER	J55	C398918	11-11-02	100.2	99.8	99.9
SCHLUMBERGER	J55	C398919	11-11-02	100.0	100.1	100.1
SCHLUMBERGER	J55	C398920	11-11-02	100.2	99.8	100.1
SCHLUMBERGER	J55	C398921	11-11-02	100.1	99.8	100.4
SCHLUMBERGER	J55	C398922	11-11-02	100.2	99.9	100.3
SCHLUMBERGER	J55	C398923	11-11-02	100.0	99.9	99.6
SCHLUMBERGER	J55	C398924	11-11-02	100.1	99.8	100.1
SCHLUMBERGER	J55	C398925	11-11-02	100.0	99.7	99.6
SCHLUMBERGER	J55	C398926	11-11-02	100.0	99.9	99.8
SCHLUMBERGER	J55	C398927	11-11-02	100.0	100.2	99.8
SCHLUMBERGER	J55	C398928	11-11-02	100.0	99.6	99.6
SCHLUMBERGER	J55	C398929	11-11-02	100.0	99.7	99.8
SCHLUMBERGER	J55	C398930	11-11-02	100.0	100.0	100.0
SCHLUMBERGER	J55	C398931	11-11-02	100.1	99.7	100.3
SCHLUMBERGER	J55	C398932	11-11-02	100.1	99.9	100.4
SCHLUMBERGER	J55	C398933	11-11-02	100.1	99.9	100.2
SCHLUMBERGER	J55	C398934	11-11-02	100.0	99.8	100.3
SCHLUMBERGER	J55	C398935	11-11-02	100.0	99.7	99.6
SCHLUMBERGER	J55	C398936	11-11-02	100.1	99.9	100.0
SCHLUMBERGER	J55	C398937	11-11-02	99.9	100.0	100.1
SCHLUMBERGER	J55	C398938	11-11-02	100.0	99.6	99.8
SCHLUMBERGER	J55	C398939	11-11-02	100.0	99.6	99.7
SCHLUMBERGER	J55	C398940	11-11-02	100.1	100.0	99.8
SCHLUMBERGER	J55	C398941	11-11-02	100.2	99.9	100.5
SCHLUMBERGER	J55	C398942	11-11-02	99.9	99.6	99.8
SCHLUMBERGER	J55	C398943	11-11-02	99.9	100.2	100.1
SCHLUMBERGER	J55	C398944	11-11-02	100.0	100.3	100.0
SCHLUMBERGER	J55	C398945	11-11-02	100.0	99.7	100.2
SCHLUMBERGER	J55	C398946	11-11-02	99.8	100.1	99.9
SCHLUMBERGER	J55	C398947	11-11-02	100.0	100.3	100.0
SCHLUMBERGER	J55	C398948	11-11-02	99.9	100.3	99.9
SCHLUMBERGER	J55	C398949	11-11-02	100.2	100.0	100.2
SCHLUMBERGER	J55	C398950	11-11-02	100.0	100.0	100.3
SCHLUMBERGER	J55	C398951	11-11-02	100.0	99.9	100.0
SCHLUMBERGER	J55	C398952	11-11-02	99.8	99.6	99.4
SCHLUMBERGER	J55	C398953	11-11-02	99.9	99.7	100.0
SCHLUMBERGER	J55	C398954	11-11-02	100.1	100.3	100.3
SCHLUMBERGER	J55	C398955	11-11-02	100.1	99.9	100.0
SCHLUMBERGER	J55	C398956	11-11-02	100.1	99.9	100.0
SCHLUMBERGER	J55	C398957	11-11-02	100.0	99.6	99.5
SCHLUMBERGER	J55	C398958	11-11-02	100.0	99.8	99.6
SCHLUMBERGER	J55	C398959	11-11-02	100.3	100.0	100.1
SCHLUMBERGER	J55	C398960	11-11-02	100.0	99.7	99.8
SCHLUMBERGER	J55	C398961	11-11-02	99.9	99.9	99.4

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

MANUFACTURER	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	C398962	11-11-02	100.1	100.0	99.8
SCHLUMBERGER	C398963	11-11-02	100.1	100.4	100.0
SCHLUMBERGER	C398964	11-11-02	100.1	99.8	100.0
SCHLUMBERGER	C398965	11-11-02	100.2	100.1	100.0
SCHLUMBERGER	C398966	11-11-02	100.0	99.7	100.0
SCHLUMBERGER	C398967	11-11-02	100.2	100.0	100.3
SCHLUMBERGER	C398968	11-11-02	99.8	100.3	100.0
SCHLUMBERGER	C398969	11-11-02	100.1	99.6	100.1
SCHLUMBERGER	C398970	11-11-02	100.0	99.9	99.4
SCHLUMBERGER	C398971	11-11-02	99.9	100.1	100.2
SCHLUMBERGER	C398972	11-11-02	100.0	100.3	99.7
SCHLUMBERGER	C398973	11-11-02	100.2	100.2	99.7
SCHLUMBERGER	C398974	11-11-02	100.0	99.9	99.9
SCHLUMBERGER	C398975	11-11-02	99.9	99.7	99.7
SCHLUMBERGER	C398976	11-11-02	100.1	99.9	99.7
SCHLUMBERGER	C398977	11-11-02	100.0	99.7	100.3
SCHLUMBERGER	C398978	11-11-02	99.8	99.7	99.4
SCHLUMBERGER	C398979	11-11-02	100.1	100.0	100.2
SCHLUMBERGER	C398980	11-11-02	100.1	100.3	100.3
SCHLUMBERGER	C398981	11-11-02	100.1	99.8	99.8
SCHLUMBERGER	C398982	11-11-02	99.9	99.7	99.7
SCHLUMBERGER	C398983	11-11-02	100.0	100.1	100.1
SCHLUMBERGER	C398984	11-11-02	99.8	99.7	99.5
SCHLUMBERGER	C398985	11-11-02	100.2	100.4	100.0
SCHLUMBERGER	C398986	11-11-02	100.1	99.7	100.2
SCHLUMBERGER	C398987	11-11-02	99.9	99.7	99.6
SCHLUMBERGER	C398988	11-11-02	99.9	99.6	99.9
SCHLUMBERGER	C398989	11-11-02	100.1	99.9	100.0
SCHLUMBERGER	C398990	11-11-02	100.0	99.6	100.0
SCHLUMBERGER	C398991	11-11-02	100.0	99.9	100.0
SCHLUMBERGER	C398992	11-11-02	100.0	99.9	100.2
SCHLUMBERGER	C398993	11-11-02	99.8	100.3	99.7
SCHLUMBERGER	C398994	11-11-02	99.9	100.1	100.1
SCHLUMBERGER	C398995	11-11-02	99.9	100.2	100.1
SCHLUMBERGER	C398996	11-11-02	100.0	100.1	100.1
SCHLUMBERGER	C398997	11-11-02	99.9	99.8	99.7
SCHLUMBERGER	C398998	11-11-02	100.2	100.3	100.2
SCHLUMBERGER	C398999	11-11-02	100.0	100.1	100.2
SCHLUMBERGER	C399000	11-11-02	100.0	100.4	99.7
SCHLUMBERGER	C399001	11-11-02	100.1	99.9	100.0
SCHLUMBERGER	C399002	11-11-02	100.0	99.8	100.6
SCHLUMBERGER	C399003	11-11-02	100.0	99.8	100.0
SCHLUMBERGER	C399004	11-11-02	100.2	100.1	100.1
SCHLUMBERGER	C399005	11-11-02	100.2	99.8	100.0
SCHLUMBERGER	C399006	11-11-02	100.1	100.0	100.3
SCHLUMBERGER	C399007	11-11-02	100.3	99.9	100.3
SCHLUMBERGER	C399008	11-11-02	100.1	99.7	99.8
SCHLUMBERGER	C399009	11-11-02	100.0	99.8	99.6
SCHLUMBERGER	C399010	11-11-02	100.0	99.7	99.5
SCHLUMBERGER	C399011	11-11-02	100.0	99.9	99.7
SCHLUMBERGER	C399012	11-11-02	100.0	100.0	100.2

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

PAGE 279
 RUN DATE: 1/14/03
 RUN TIME: 13.26.53

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	J55	C399013	11-11-02	100.1	99.7	100.1
SCHLUMBERGER	J55	C399014	11-11-02	99.8	99.7	99.8
SCHLUMBERGER	J55	C399015	11-11-02	100.0	99.7	99.6
SCHLUMBERGER	J55	C399016	11-11-02	100.0	99.7	100.3
SCHLUMBERGER	J55	C399017	11-11-02	100.2	99.9	99.7
SCHLUMBERGER	J55	C399018	11-11-02	100.2	99.6	99.6
SCHLUMBERGER	J55	C399019	11-11-02	100.1	99.7	100.2
SCHLUMBERGER	J55	C399020	11-11-02	99.8	99.8	99.9
SCHLUMBERGER	J55	C399021	11-11-02	100.0	99.7	99.7
SCHLUMBERGER	J55	C399022	11-11-02	100.0	99.6	99.9
SCHLUMBERGER	J55	C399023	11-11-02	99.9	99.7	99.6
SCHLUMBERGER	J55	C399024	11-11-02	100.1	99.8	100.1
SCHLUMBERGER	J55	C399025	11-11-02	100.0	100.1	99.7
SCHLUMBERGER	J55	C399026	11-11-02	100.1	99.8	100.1
SCHLUMBERGER	J55	C399027	11-11-02	99.8	100.5	100.0
SCHLUMBERGER	J55	C399028	11-11-02	100.1	99.6	100.0
SCHLUMBERGER	J55	C399029	11-11-02	99.8	99.8	99.8
SCHLUMBERGER	J55	C399030	11-11-02	100.1	100.0	100.1
SCHLUMBERGER	J55	C399031	11-11-02	99.9	100.2	100.2
SCHLUMBERGER	J55	C399032	11-11-02	100.0	100.0	100.0
SCHLUMBERGER	J55	C399033	11-11-02	100.1	99.9	100.4
SCHLUMBERGER	J55	C399034	11-11-02	100.2	99.7	100.1
SCHLUMBERGER	J55	C399035	11-11-02	100.2	99.8	100.1
SCHLUMBERGER	J55	C399036	11-11-02	100.0	99.6	99.7
SCHLUMBERGER	J55	C399037	11-11-02	100.1	100.1	100.2
SCHLUMBERGER	J55	C399038	11-11-02	100.1	100.0	100.0
SCHLUMBERGER	J55	C399039	11-11-02	100.1	99.8	99.5
SCHLUMBERGER	J55	C399040	11-11-02	99.9	100.3	99.6
SCHLUMBERGER	J55	C399041	11-11-02	100.1	99.7	99.9
SCHLUMBERGER	J55	C399042	11-11-02	100.3	100.1	100.4
SCHLUMBERGER	J55	C399043	11-11-02	100.1	100.0	99.9
SCHLUMBERGER	J55	C399044	11-11-02	100.0	99.7	99.5
SCHLUMBERGER	J55	C399045	11-11-02	100.2	100.1	100.0
SCHLUMBERGER	J55	C399046	11-11-02	100.1	99.7	100.0
SCHLUMBERGER	J55	C399047	11-11-02	99.8	100.1	100.1
SCHLUMBERGER	J55	C399048	11-11-02	100.2	99.6	99.9
SCHLUMBERGER	J55	C399049	11-11-02	99.8	99.8	99.8
SCHLUMBERGER	J55	C399050	11-11-02	100.0	99.8	100.0
SCHLUMBERGER	J55	C399051	11-11-02	100.0	99.8	99.8
SCHLUMBERGER	J55	C399052	11-11-02	100.3	99.8	100.6
SCHLUMBERGER	J55	C399053	11-11-02	100.1	99.6	99.6
SCHLUMBERGER	J55	C399054	11-11-02	99.9	99.8	99.8
SCHLUMBERGER	J55	C399055	11-11-02	100.0	99.6	100.0
SCHLUMBERGER	J55	C399056	11-11-02	100.3	100.0	100.0
SCHLUMBERGER	J55	C399057	11-11-02	99.9	100.1	100.0
SCHLUMBERGER	J55	C399058	11-11-02	99.8	99.7	99.7
SCHLUMBERGER	J55	C399059	11-11-02	100.2	100.1	100.2
SCHLUMBERGER	J55	C399060	11-11-02	100.0	99.7	99.6
SCHLUMBERGER	J55	C399061	11-11-02	100.0	99.8	99.8
SCHLUMBERGER	J55	C399062	11-11-02	99.9	99.7	99.3
SCHLUMBERGER	J55	C399063	11-11-02	99.9	100.2	100.0

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

PAGE 280
 RUN DATE: 1/14/03
 RUN TIME: 13.26.53

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	J5S	C399064	11-11-02	100.1	99.8	100.3
SCHLUMBERGER	J5S	C399065	11-11-02	100.1	99.6	99.9
SCHLUMBERGER	J5S	C399066	11-11-02	100.1	100.2	100.6
SCHLUMBERGER	J5S	C399067	11-11-02	100.1	100.0	99.3
SCHLUMBERGER	J5S	C399068	11-11-02	100.1	99.6	100.5
SCHLUMBERGER	J5S	C399069	11-11-02	100.1	100.0	100.2
SCHLUMBERGER	J5S	C399070	11-11-02	99.9	99.9	99.3
SCHLUMBERGER	J5S	C399071	11-11-02	100.0	99.7	100.1
SCHLUMBERGER	J5S	C399072	11-11-02	100.0	99.7	99.9
SCHLUMBERGER	J5S	C399073	11-11-02	100.1	99.7	100.1
SCHLUMBERGER	J5S	C399074	11-11-02	99.8	99.7	99.3
SCHLUMBERGER	J5S	C399075	11-11-02	99.9	99.6	100.0
SCHLUMBERGER	J5S	C399076	11-11-02	100.1	99.8	100.2
SCHLUMBERGER	J5S	C399077	11-11-02	100.1	99.7	99.7
SCHLUMBERGER	J5S	C399078	11-11-02	99.9	99.7	100.0
SCHLUMBERGER	J5S	C399079	11-11-02	100.2	99.8	100.0
SCHLUMBERGER	J5S	C399080	11-11-02	100.3	99.8	100.1
SCHLUMBERGER	J5S	C399081	11-11-02	99.9	99.8	99.6
SCHLUMBERGER	J5S	C399082	11-11-02	99.8	99.9	99.9
SCHLUMBERGER	J5S	C399083	11-11-02	100.2	100.0	100.5
SCHLUMBERGER	J5S	C399084	11-11-02	100.0	99.8	100.0
SCHLUMBERGER	J5S	C399085	11-11-02	100.3	99.9	100.3
SCHLUMBERGER	J5S	C399086	11-11-02	100.2	100.5	99.3
SCHLUMBERGER	J5S	C399087	11-11-02	100.1	100.0	99.8
SCHLUMBERGER	J5S	C399088	11-11-02	100.1	99.7	100.5
SCHLUMBERGER	J5S	C399089	11-11-02	100.1	99.7	100.5
SCHLUMBERGER	J5S	C399090	11-11-02	100.2	100.0	100.3
SCHLUMBERGER	J5S	C399091	11-11-02	100.1	99.9	100.2
SCHLUMBERGER	J5S	C399092	11-11-02	100.3	100.0	99.9
SCHLUMBERGER	J5S	C399093	11-11-02	99.9	99.6	100.1
SCHLUMBERGER	J5S	C399094	11-11-02	100.2	99.7	100.3
SCHLUMBERGER	J5S	C399095	11-11-02	100.2	99.6	100.3
SCHLUMBERGER	J5S	C399096	11-11-02	99.9	99.8	100.4
SCHLUMBERGER	J5S	C399097	11-11-02	100.0	99.9	99.7
SCHLUMBERGER	J5S	C399098	11-11-02	99.8	99.8	99.6
SCHLUMBERGER	J5S	C399099	11-11-02	99.9	99.9	99.5
SCHLUMBERGER	J5S	C399100	11-11-02	100.0	99.7	99.9
SCHLUMBERGER	J5S	C399101	11-11-02	100.1	99.7	99.9
SCHLUMBERGER	J5S	C399102	11-11-02	100.0	99.6	99.4
SCHLUMBERGER	J5S	C399103	11-11-02	100.0	100.0	99.7
SCHLUMBERGER	J5S	C399104	11-11-02	100.2	99.7	100.5
SCHLUMBERGER	J5S	C399105	11-11-02	100.2	99.7	99.7
SCHLUMBERGER	J5S	C399106	11-11-02	100.0	99.8	100.0
SCHLUMBERGER	J5S	C399107	11-11-02	100.2	99.8	100.5
SCHLUMBERGER	J5S	C399108	11-11-02	100.2	99.8	100.5
SCHLUMBERGER	J5S	C399109	11-11-02	100.0	100.2	100.4
SCHLUMBERGER	J5S	C399110	11-11-02	99.8	99.9	100.2
SCHLUMBERGER	J5S	C399111	11-11-02	99.8	99.9	99.3
SCHLUMBERGER	J5S	C399112	11-11-02	100.0	100.0	99.9
SCHLUMBERGER	J5S	C399113	11-11-02	99.9	99.7	100.1
SCHLUMBERGER	J5S	C399114	11-11-02	100.3	99.6	100.4
SCHLUMBERGER	J5S	C399115	11-11-02	100.1	99.9	100.8

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

PAGE 281
 RUN DATE: 1/14/03
 RUN TIME: 13.26.53

MANUFACTURER	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	C399115	11-11-02	99.9	99.9	100.1
SCHLUMBERGER	C399116	11-11-02	100.0	99.8	100.0
SCHLUMBERGER	C399117	11-11-02	100.1	99.8	100.1
SCHLUMBERGER	C399118	11-11-02	100.0	99.7	99.8
SCHLUMBERGER	C399119	11-11-02	100.2	99.7	100.1
SCHLUMBERGER	C399120	11-11-02	100.3	100.0	100.3
SCHLUMBERGER	C399121	11-11-02	100.3	100.0	100.4
SCHLUMBERGER	C399122	11-11-02	99.9	100.2	99.3
SCHLUMBERGER	C399123	11-11-02	100.2	99.8	100.1
SCHLUMBERGER	C399124	11-11-02	100.3	99.9	100.2
SCHLUMBERGER	C399125	11-11-02	100.2	99.8	100.3
SCHLUMBERGER	C399126	11-11-02	100.2	99.9	100.1
SCHLUMBERGER	C399127	11-11-02	100.1	99.9	100.2
SCHLUMBERGER	C399128	11-11-02	100.3	100.2	100.3
SCHLUMBERGER	C399129	11-11-02	100.2	99.9	100.2
SCHLUMBERGER	C399130	11-11-02	100.2	100.0	100.1
SCHLUMBERGER	C399131	11-11-02	100.1	99.7	99.9
SCHLUMBERGER	C399132	11-11-02	99.9	99.7	100.1
SCHLUMBERGER	C399133	11-11-02	100.2	100.2	100.3
SCHLUMBERGER	C399134	11-11-02	100.1	99.9	100.0
SCHLUMBERGER	C399135	11-11-02	100.1	99.7	99.9
SCHLUMBERGER	C399136	11-11-02	100.1	99.8	100.4
SCHLUMBERGER	C399137	11-11-02	100.1	99.8	100.2
SCHLUMBERGER	C399138	11-11-02	100.0	99.9	99.7
SCHLUMBERGER	C399139	11-11-02	100.3	100.2	100.1
SCHLUMBERGER	C399140	11-11-02	99.9	99.8	100.2
SCHLUMBERGER	C399141	11-11-02	99.9	99.9	99.6
SCHLUMBERGER	C399142	11-11-02	99.9	100.2	100.1
SCHLUMBERGER	C399143	11-11-02	100.1	99.8	100.3
SCHLUMBERGER	C399144	11-11-02	99.9	99.8	99.9
SCHLUMBERGER	C399145	11-11-02	100.2	100.0	100.2
SCHLUMBERGER	C399146	11-11-02	100.2	99.7	100.1
SCHLUMBERGER	C399147	11-11-02	100.3	99.8	100.4
SCHLUMBERGER	C399148	11-11-02	100.3	100.2	100.2
SCHLUMBERGER	C399149	11-11-02	100.1	99.7	99.9
SCHLUMBERGER	C399150	11-11-02	99.9	99.8	99.7
SCHLUMBERGER	C399151	11-11-02	100.1	100.1	99.6
SCHLUMBERGER	C399152	11-11-02	100.2	100.0	100.1
SCHLUMBERGER	C399153	11-11-02	100.2	99.8	100.5
SCHLUMBERGER	C399154	11-11-02	100.1	100.0	99.3
SCHLUMBERGER	C399155	11-11-02	100.1	99.8	100.1
SCHLUMBERGER	C399156	11-11-02	100.0	99.7	100.0
SCHLUMBERGER	C399157	11-11-02	100.0	100.4	100.3
SCHLUMBERGER	C399158	11-11-02	100.2	99.9	99.8
SCHLUMBERGER	C399159	11-11-02	100.0	100.0	100.0
SCHLUMBERGER	C399160	11-11-02	100.0	100.0	100.1
SCHLUMBERGER	C399161	11-11-02	100.1	100.0	99.6
SCHLUMBERGER	C399162	11-11-02	99.8	99.6	99.5
SCHLUMBERGER	C399163	11-11-02	100.1	100.1	100.3
SCHLUMBERGER	C399164	11-11-02	100.1	100.1	99.8
SCHLUMBERGER	C399165	11-11-02	99.9	99.6	100.0

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

PAGE 282
 RUN DATE: 1/14/03
 RUN TIME: 13.26.53

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	J5S	C399166	11-11-02	100.0	99.7	100.1
SCHLUMBERGER	J5S	C399167	11-11-02	100.0	99.9	99.6
SCHLUMBERGER	J5S	C399168	11-11-02	100.1	99.6	100.0
SCHLUMBERGER	J5S	C399169	11-11-02	100.2	100.1	100.5
SCHLUMBERGER	J5S	C399170	11-11-02	100.1	100.0	100.2
SCHLUMBERGER	J5S	C399171	11-11-02	100.0	99.7	99.8
SCHLUMBERGER	J5S	C399172	11-11-02	100.3	99.7	100.3
SCHLUMBERGER	J5S	C399173	11-11-02	99.9	100.0	99.9
SCHLUMBERGER	J5S	C399174	11-11-02	100.0	100.0	99.9
SCHLUMBERGER	J5S	C399175	11-11-02	100.0	99.8	99.4
SCHLUMBERGER	J5S	C399176	11-11-02	99.8	100.1	99.7
SCHLUMBERGER	J5S	C399177	11-11-02	100.0	99.7	99.7
SCHLUMBERGER	J5S	C399178	11-11-02	99.9	100.1	99.5
SCHLUMBERGER	J5S	C399179	11-11-02	100.1	99.8	100.1
SCHLUMBERGER	J5S	C399180	11-11-02	100.1	99.9	100.1
SCHLUMBERGER	J5S	C399181	11-11-02	100.2	100.0	100.2
SCHLUMBERGER	J5S	C399182	11-11-02	100.0	99.7	100.1
SCHLUMBERGER	J5S	C399183	11-11-02	99.9	99.9	99.9
SCHLUMBERGER	J5S	C399184	11-11-02	100.1	100.1	100.0
SCHLUMBERGER	J5S	C399185	11-11-02	100.2	99.6	99.9
SCHLUMBERGER	J5S	C399186	11-11-02	100.0	100.0	100.0
SCHLUMBERGER	J5S	C399187	11-11-02	100.2	99.8	100.6
SCHLUMBERGER	J5S	C399188	11-11-02	99.9	99.8	100.0
SCHLUMBERGER	J5S	C399189	11-11-02	100.2	99.8	100.0
SCHLUMBERGER	J5S	C399190	11-11-02	100.0	99.9	100.6
SCHLUMBERGER	J5S	C399191	11-11-02	100.2	99.9	100.0
SCHLUMBERGER	J5S	C399192	11-11-02	100.1	99.7	100.1
SCHLUMBERGER	J5S	C399193	11-11-02	99.9	99.7	99.9
SCHLUMBERGER	J5S	C399194	11-11-02	100.2	100.0	100.0
SCHLUMBERGER	J5S	C399195	11-11-02	100.3	100.1	100.4
SCHLUMBERGER	J5S	C399196	11-11-02	100.1	100.0	100.2
SCHLUMBERGER	J5S	C399197	11-11-02	99.9	99.8	99.7
SCHLUMBERGER	J5S	C399198	11-11-02	99.9	100.2	100.0
SCHLUMBERGER	J5S	C399199	11-11-02	100.0	99.8	99.8
SCHLUMBERGER	J5S	C399200	11-11-02	100.1	100.1	100.0
SCHLUMBERGER	J5S	C399201	11-11-02	100.0	100.1	99.3
SCHLUMBERGER	J5S	C399202	11-11-02	100.0	100.3	99.3
SCHLUMBERGER	J5S	C399203	11-11-02	99.9	99.9	99.7
SCHLUMBERGER	J5S	C399204	11-11-02	99.9	99.7	99.7
SCHLUMBERGER	J5S	C399205	11-11-02	100.0	99.8	99.9
SCHLUMBERGER	J5S	C399206	11-11-02	100.1	99.8	99.9
SCHLUMBERGER	J5S	C399207	11-11-02	100.1	100.2	100.0
SCHLUMBERGER	J5S	C399208	11-11-02	100.2	100.2	100.0
SCHLUMBERGER	J5S	C399209	11-11-02	100.2	100.0	99.9
SCHLUMBERGER	J5S	C399210	11-11-02	100.1	99.7	99.6
SCHLUMBERGER	J5S	C399211	11-11-02	100.0	99.8	99.7
SCHLUMBERGER	J5S	C399212	11-11-02	100.1	99.8	100.7
SCHLUMBERGER	J5S	C399213	11-11-02	99.9	100.1	99.6
SCHLUMBERGER	J5S	C399214	11-11-02	99.9	100.1	99.6
SCHLUMBERGER	J5S	C399215	11-11-02	100.0	99.6	99.6
SCHLUMBERGER	J5S	C399216	11-11-02	100.3	99.8	99.7

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	J55	C399217	11-11-02	100.2	100.1	99.3
SCHLUMBERGER	J55	C399218	11-11-02	99.9	99.8	100.0
SCHLUMBERGER	J55	C399219	11-11-02	99.9	99.6	99.6
SCHLUMBERGER	J55	C399220	11-11-02	100.2	99.9	100.0
SCHLUMBERGER	J55	C399221	11-11-02	100.3	99.9	100.0
SCHLUMBERGER	J55	C399222	11-11-02	100.3	99.8	99.9
SCHLUMBERGER	J55	C399223	11-11-02	100.2	99.9	100.1
SCHLUMBERGER	J55	C399224	11-11-02	100.0	99.7	99.9
SCHLUMBERGER	J55	C399225	11-11-02	99.9	99.7	99.4
SCHLUMBERGER	J55	C399226	11-11-02	99.9	99.6	99.9
SCHLUMBERGER	J55	C399227	11-11-02	99.9	99.7	99.9
SCHLUMBERGER	J55	C399228	11-11-02	100.0	99.8	99.9
SCHLUMBERGER	J55	C399229	11-11-02	99.9	99.8	100.2
SCHLUMBERGER	J55	C399230	11-11-02	100.2	100.4	100.3
SCHLUMBERGER	J55	C399231	11-11-02	100.1	100.0	100.1
SCHLUMBERGER	J55	C399232	11-11-02	100.0	100.4	99.3
SCHLUMBERGER	J55	C399233	11-11-02	100.1	99.8	100.2
SCHLUMBERGER	J55	C399234	11-11-02	100.0	100.0	99.9
SCHLUMBERGER	J55	C399235	11-11-02	100.2	100.1	100.0
SCHLUMBERGER	J55	C399236	11-11-02	100.0	99.9	99.9
SCHLUMBERGER	J55	C399237	11-11-02	100.1	99.9	100.1
SCHLUMBERGER	J55	C399238	11-11-02	99.8	99.6	99.7
SCHLUMBERGER	J55	C399239	11-11-02	99.9	99.9	99.9
SCHLUMBERGER	J55	C399240	11-11-02	100.1	99.6	100.3
SCHLUMBERGER	J55	C399241	11-11-02	100.0	100.0	99.9
SCHLUMBERGER	J55	C399242	11-11-02	100.0	99.8	99.7
SCHLUMBERGER	J55	C399243	11-11-02	100.1	100.3	100.1
SCHLUMBERGER	J55	C399244	11-11-02	100.0	100.0	99.9
SCHLUMBERGER	J55	C399245	11-11-02	100.2	99.6	100.7
SCHLUMBERGER	J55	C399246	11-11-02	100.0	99.7	99.7
SCHLUMBERGER	J55	C399247	11-11-02	100.0	100.1	100.2
SCHLUMBERGER	J55	C399248	11-11-02	100.1	99.7	99.9
SCHLUMBERGER	J55	C399249	11-11-02	100.2	99.9	100.5
SCHLUMBERGER	J55	C399250	11-11-02	100.0	100.0	100.3
SCHLUMBERGER	J55	C399251	11-11-02	100.2	100.4	100.4
SCHLUMBERGER	J55	C399252	11-11-02	99.8	100.2	99.7
SCHLUMBERGER	J55	C399253	11-11-02	100.1	99.8	99.7
SCHLUMBERGER	J55	C399254	11-11-02	99.8	100.0	100.0
SCHLUMBERGER	J55	C399255	11-11-02	100.1	100.1	100.0
SCHLUMBERGER	J55	C399256	11-11-02	100.1	99.8	100.0
SCHLUMBERGER	J55	C399257	11-11-02	99.8	100.1	100.1
SCHLUMBERGER	J55	C399258	11-11-02	100.1	99.8	100.3
SCHLUMBERGER	J55	C399259	11-11-02	99.8	100.3	99.9
SCHLUMBERGER	J55	C399260	11-11-02	100.1	99.8	99.9
SCHLUMBERGER	J55	C399261	11-11-02	99.9	100.1	100.0
SCHLUMBERGER	J55	C399262	11-11-02	100.0	99.8	100.0
SCHLUMBERGER	J55	C399263	11-11-02	100.0	99.6	99.4
SCHLUMBERGER	J55	C399264	11-11-02	100.0	99.8	100.1
SCHLUMBERGER	J55	C399265	11-11-02	100.0	99.7	99.8
SCHLUMBERGER	J55	C399266	11-11-02	100.1	100.1	99.8
SCHLUMBERGER	J55	C399267	11-11-02	100.1	99.7	100.2

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

PAGE 284
 RUN DATE: 1/14/03
 RUN TIME: 13.26.53

MANUFACTURER	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	C399268	11-11-02	99.9	100.0	99.9
SCHLUMBERGER	C399269	11-11-02	100.1	99.8	100.0
SCHLUMBERGER	C399270	11-11-02	100.0	99.8	99.9
SCHLUMBERGER	C399271	11-11-02	100.1	99.7	99.7
SCHLUMBERGER	C399272	11-11-02	100.1	99.9	100.3
SCHLUMBERGER	C399273	11-11-02	100.0	99.8	99.8
SCHLUMBERGER	C399274	11-11-02	99.8	99.9	99.4
SCHLUMBERGER	C399275	11-11-02	100.1	99.9	100.3
SCHLUMBERGER	C399276	11-11-02	100.0	99.8	99.7
SCHLUMBERGER	C399277	11-11-02	100.0	99.7	100.1
SCHLUMBERGER	C399278	11-11-02	100.1	100.3	99.7
SCHLUMBERGER	C399279	11-11-02	100.3	99.9	99.8
SCHLUMBERGER	C399280	11-11-02	100.2	100.3	100.5
SCHLUMBERGER	C399281	11-11-02	99.9	100.3	100.0
SCHLUMBERGER	C399282	11-11-02	100.0	99.7	99.9
SCHLUMBERGER	C399283	11-11-02	100.0	99.8	100.3
SCHLUMBERGER	C399284	11-11-02	99.9	100.0	99.8
SCHLUMBERGER	C399285	11-11-02	99.9	99.7	99.7
SCHLUMBERGER	C399286	11-11-02	99.9	99.6	100.1
SCHLUMBERGER	C399287	11-11-02	100.0	99.9	100.1
SCHLUMBERGER	C399288	11-11-02	100.0	99.9	99.5
SCHLUMBERGER	C399289	11-11-02	99.9	99.7	99.9
SCHLUMBERGER	C399290	11-11-02	100.0	99.9	100.1
SCHLUMBERGER	C399291	11-11-02	100.0	99.6	100.0
SCHLUMBERGER	C399292	11-11-02	99.9	100.2	99.7
SCHLUMBERGER	C399293	11-11-02	100.1	99.8	99.9
SCHLUMBERGER	C399294	11-11-02	100.1	99.8	99.9
SCHLUMBERGER	C399295	11-11-02	100.0	99.6	99.9
SCHLUMBERGER	C399296	11-11-02	99.9	99.7	100.1
SCHLUMBERGER	C399297	11-11-02	99.9	99.6	99.4
SCHLUMBERGER	C399298	11-11-02	100.1	99.7	100.1
SCHLUMBERGER	C399299	11-11-02	99.9	99.6	99.6
SCHLUMBERGER	C399300	11-11-02	100.1	99.7	100.0
SCHLUMBERGER	C399301	11-11-02	99.9	99.7	99.8
SCHLUMBERGER	C399302	11-11-02	100.0	100.4	99.8
SCHLUMBERGER	C399303	11-11-02	100.3	99.9	99.8
SCHLUMBERGER	C399304	11-11-02	100.0	99.7	100.0
SCHLUMBERGER	C399305	11-11-02	100.2	99.9	100.3
SCHLUMBERGER	C399306	11-11-02	100.1	99.8	100.2
SCHLUMBERGER	C399307	11-11-02	99.9	100.0	99.6
SCHLUMBERGER	C399308	11-11-02	100.0	99.9	99.8
SCHLUMBERGER	C399309	11-11-02	100.1	99.6	99.8
SCHLUMBERGER	C399310	11-11-02	100.1	99.8	100.0
SCHLUMBERGER	C399311	11-11-02	100.0	99.9	100.0
SCHLUMBERGER	C399312	11-11-02	99.9	100.0	99.8
SCHLUMBERGER	C399313	11-11-02	100.1	99.9	99.9
SCHLUMBERGER	C399314	11-11-02	100.1	99.6	100.2
SCHLUMBERGER	C399315	11-11-02	99.9	99.9	99.9
SCHLUMBERGER	C399316	11-11-02	100.1	100.1	99.9
SCHLUMBERGER	C399317	11-11-02	99.9	99.9	100.3
SCHLUMBERGER	C399318	11-11-02	100.0	99.9	99.8

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

PAGE 285
 RUN DATE: 1/14/03
 RUN TIME: 13.26.53

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	J5S	C399319	11-11-02	100.3	100.0	99.9
SCHLUMBERGER	J5S	C399320	11-11-02	99.9	99.7	100.2
SCHLUMBERGER	J5S	C399321	11-11-02	100.0	99.7	99.4
SCHLUMBERGER	J5S	C399322	11-11-02	99.8	99.7	99.8
SCHLUMBERGER	J5S	C399323	11-11-02	100.0	99.9	99.7
SCHLUMBERGER	J5S	C399324	11-11-02	99.9	99.6	99.9
SCHLUMBERGER	J5S	C399325	11-11-02	100.2	99.7	100.3
SCHLUMBERGER	J5S	C399326	11-11-02	100.1	99.8	100.1
SCHLUMBERGER	J5S	C399327	11-11-02	99.8	99.6	99.5
SCHLUMBERGER	J5S	C399328	11-11-02	100.0	99.8	99.8
SCHLUMBERGER	J5S	C399329	11-11-02	100.0	99.9	100.3
SCHLUMBERGER	J5S	C399330	11-11-02	100.0	99.7	99.9
SCHLUMBERGER	J5S	C399331	11-11-02	99.9	99.8	100.1
SCHLUMBERGER	J5S	C399332	11-11-02	100.1	100.1	100.0
SCHLUMBERGER	J5S	C399333	11-11-02	100.0	99.9	99.7
SCHLUMBERGER	J5S	C399334	11-11-02	99.9	99.8	99.7
SCHLUMBERGER	J5S	C399335	11-11-02	100.1	100.0	100.4
SCHLUMBERGER	J5S	C399336	11-11-02	100.1	100.0	99.8
SCHLUMBERGER	J5S	C399337	11-11-02	100.1	99.7	100.2
SCHLUMBERGER	J5S	C399338	11-11-02	100.1	100.0	100.2
SCHLUMBERGER	J5S	C399339	11-11-02	100.0	99.8	100.1
SCHLUMBERGER	J5S	C399340	11-11-02	100.0	99.8	99.9
SCHLUMBERGER	J5S	C399341	11-11-02	99.9	100.0	99.7
SCHLUMBERGER	J5S	C399342	11-11-02	99.9	99.7	99.8
SCHLUMBERGER	J5S	C399343	11-11-02	99.9	99.7	99.9
SCHLUMBERGER	J5S	C399344	11-11-02	100.1	99.9	99.9
SCHLUMBERGER	J5S	C399345	11-11-02	100.2	100.3	99.9
SCHLUMBERGER	J5S	C399346	11-11-02	100.0	99.6	99.9
SCHLUMBERGER	J5S	C399347	11-11-02	100.1	100.0	99.7
SCHLUMBERGER	J5S	C399348	11-11-02	100.1	99.9	99.8
SCHLUMBERGER	J5S	C399349	11-11-02	100.2	100.1	100.2
SCHLUMBERGER	J5S	C399350	11-11-02	100.1	99.8	100.0
SCHLUMBERGER	J5S	C399351	11-11-02	100.1	99.9	100.2
SCHLUMBERGER	J5S	C399352	11-11-02	100.1	99.7	100.2
SCHLUMBERGER	J5S	C399353	11-11-02	100.2	100.2	100.2
SCHLUMBERGER	J5S	C399354	11-11-02	100.1	99.6	100.0
SCHLUMBERGER	J5S	C399355	11-11-02	100.1	100.0	100.2
SCHLUMBERGER	J5S	C399356	11-11-02	99.9	99.6	99.8
SCHLUMBERGER	J5S	C399357	11-11-02	100.1	100.0	100.3
SCHLUMBERGER	J5S	C399358	11-11-02	100.0	99.7	100.0
SCHLUMBERGER	J5S	C399359	11-11-02	100.0	99.7	100.1
SCHLUMBERGER	J5S	C399360	11-11-02	100.0	99.8	99.6
SCHLUMBERGER	J5S	C399361	11-11-02	100.0	99.9	99.9
SCHLUMBERGER	J5S	C399362	11-11-02	100.1	100.2	100.2
SCHLUMBERGER	J5S	C399363	11-11-02	100.1	99.9	99.9
SCHLUMBERGER	J5S	C399364	11-11-02	100.1	100.0	100.2
SCHLUMBERGER	J5S	C399365	11-11-02	100.2	100.1	100.4
SCHLUMBERGER	J5S	C399366	11-11-02	100.0	99.7	99.3
SCHLUMBERGER	J5S	C399367	11-11-02	100.1	99.6	99.7
SCHLUMBERGER	J5S	C399368	11-11-02	100.0	99.9	100.1
SCHLUMBERGER	J5S	C399369	11-11-02	99.9	99.7	99.7

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

PAGE 286
 RUN DATE: 1/14/03
 RUN TIME: 13.26.53

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	J5S	C399370	11-11-02	100.0	100.0	99.7
SCHLUMBERGER	J5S	C399371	11-11-02	100.2	100.3	100.2
SCHLUMBERGER	J5S	C399372	11-11-02	100.0	100.0	99.5
SCHLUMBERGER	J5S	C399373	11-06-02	100.0	99.9	99.6
SCHLUMBERGER	J5S	C399374	11-06-02	100.1	99.9	99.8
SCHLUMBERGER	J5S	C399375	11-06-02	100.2	100.2	100.1
SCHLUMBERGER	J5S	C399376	11-06-02	100.1	99.9	100.2
SCHLUMBERGER	J5S	C399377	11-06-02	100.0	99.9	100.3
SCHLUMBERGER	J5S	C399378	11-06-02	99.8	99.9	99.4
SCHLUMBERGER	J5S	C399379	11-06-02	99.8	99.7	99.6
SCHLUMBERGER	J5S	C399380	11-06-02	99.9	99.9	99.9
SCHLUMBERGER	J5S	C399381	11-06-02	99.9	100.1	99.9
SCHLUMBERGER	J5S	C399382	11-06-02	100.0	100.0	100.2
SCHLUMBERGER	J5S	C399383	11-06-02	100.1	100.0	100.3
SCHLUMBERGER	J5S	C399384	11-06-02	99.8	99.8	99.6
SCHLUMBERGER	J5S	C399385	11-06-02	99.8	99.7	100.0
SCHLUMBERGER	J5S	C399386	11-06-02	100.0	99.9	100.0
SCHLUMBERGER	J5S	C399387	11-06-02	99.9	99.9	99.8
SCHLUMBERGER	J5S	C399388	11-26-02	100.3	100.0	99.8
SCHLUMBERGER	J5S	C399389	11-26-02	100.3	100.2	99.9
SCHLUMBERGER	J5S	C399390	11-26-02	100.0	100.1	99.4
SCHLUMBERGER	J5S	C399391	11-26-02	99.9	100.0	99.9
SCHLUMBERGER	J5S	C399392	11-26-02	100.1	100.2	99.8
SCHLUMBERGER	J5S	C399393	11-26-02	100.1	100.3	99.8
SCHLUMBERGER	J5S	C399394	11-26-02	100.3	100.2	99.7
SCHLUMBERGER	J5S	C399395	11-26-02	100.2	99.8	99.5
SCHLUMBERGER	J5S	C399396	11-26-02	100.2	99.9	99.8
SCHLUMBERGER	J5S	C399397	11-26-02	100.1	100.1	100.1
SCHLUMBERGER	J5S	C399398	11-26-02	99.9	99.8	99.3
SCHLUMBERGER	J5S	C399399	11-26-02	100.1	100.2	99.5
SCHLUMBERGER	J5S	C399400	11-26-02	100.0	100.2	99.6
SCHLUMBERGER	J5S	C399401	11-26-02	100.1	100.1	100.0
SCHLUMBERGER	J5S	C399402	11-26-02	100.0	100.1	99.5
SCHLUMBERGER	J5S	C399403	11-26-02	100.2	100.2	100.2
SCHLUMBERGER	J5S	C399404	11-26-02	100.0	99.9	99.8
SCHLUMBERGER	J5S	C399405	11-26-02	100.0	99.8	100.1
SCHLUMBERGER	J5S	C399406	11-26-02	100.0	99.6	99.7
SCHLUMBERGER	J5S	C399407	11-26-02	100.2	99.8	99.8
SCHLUMBERGER	J5S	C399408	11-26-02	99.8	99.7	99.5
SCHLUMBERGER	J5S	C399409	11-26-02	100.1	100.3	100.2
SCHLUMBERGER	J5S	C399410	11-26-02	100.2	100.2	99.9
SCHLUMBERGER	J5S	C399411	11-26-02	100.0	100.1	99.8
SCHLUMBERGER	J5S	C399412	11-26-02	100.3	100.2	99.7
SCHLUMBERGER	J5S	C399413	11-26-02	100.2	100.1	99.8
SCHLUMBERGER	J5S	C399414	11-26-02	100.2	100.1	99.8
SCHLUMBERGER	J5S	C399415	11-26-02	100.2	100.2	99.6
SCHLUMBERGER	J5S	C399416	11-26-02	100.0	100.1	99.7
SCHLUMBERGER	J5S	C399417	11-26-02	100.1	100.1	99.4
SCHLUMBERGER	J5S	C399418	11-26-02	100.0	99.8	99.9
SCHLUMBERGER	J5S	C399419	11-26-02	100.0	100.2	99.8
SCHLUMBERGER	J5S	C399420	11-26-02	99.9	100.3	99.7

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	J55	C399421	11-26-02	100.2	100.2	99.9
SCHLUMBERGER	J55	C399422	11-26-02	100.2	100.0	99.8
SCHLUMBERGER	J55	C399423	11-26-02	100.2	100.3	100.0
SCHLUMBERGER	J55	C399424	11-26-02	100.2	100.1	99.7
SCHLUMBERGER	J55	C399425	11-25-02	100.2	100.4	100.2
SCHLUMBERGER	J55	C399426	11-25-02	100.2	100.4	99.8
SCHLUMBERGER	J55	C399427	11-25-02	100.2	100.0	99.9
SCHLUMBERGER	J55	C399428	11-25-02	100.1	100.0	99.7
SCHLUMBERGER	J55	C399429	11-25-02	100.1	100.1	99.8
SCHLUMBERGER	J55	C399430	11-25-02	100.0	100.1	100.2
SCHLUMBERGER	J55	C399431	11-25-02	100.1	99.9	99.7
SCHLUMBERGER	J55	C399432	11-25-02	99.8	99.7	99.5
SCHLUMBERGER	J55	C399433	11-25-02	100.2	100.0	100.0
SCHLUMBERGER	J55	C399434	11-25-02	100.2	99.8	99.5
SCHLUMBERGER	J55	C399435	11-25-02	100.1	100.2	99.7
SCHLUMBERGER	J55	C399436	11-25-02	100.3	99.8	99.8
SCHLUMBERGER	J55	C399437	11-25-02	100.1	100.2	99.8
SCHLUMBERGER	J55	C399438	11-25-02	100.1	100.2	99.7
SCHLUMBERGER	J55	C399439	11-25-02	100.0	99.8	99.6
SCHLUMBERGER	J55	C399440	11-25-02	100.0	100.0	100.0
SCHLUMBERGER	J55	C399441	11-25-02	100.1	99.9	99.7
SCHLUMBERGER	J55	C399442	11-25-02	100.0	100.2	100.2
SCHLUMBERGER	J55	C399443	11-25-02	100.1	100.2	100.0
SCHLUMBERGER	J55	C399444	11-25-02	100.1	99.8	100.5
SCHLUMBERGER	J55	C399445	11-25-02	100.1	99.8	99.8
SCHLUMBERGER	J55	C399446	11-25-02	100.2	100.0	99.8
SCHLUMBERGER	J55	C399447	11-25-02	100.2	100.1	99.9
SCHLUMBERGER	J55	C399448	11-25-02	99.9	99.9	100.0
SCHLUMBERGER	J55	C399449	11-25-02	100.1	100.1	99.6
SCHLUMBERGER	J55	C399450	11-25-02	100.0	100.0	100.0
SCHLUMBERGER	J55	C399451	11-25-02	100.3	100.2	100.2
SCHLUMBERGER	J55	C399452	11-25-02	100.1	99.8	100.2
SCHLUMBERGER	J55	C399453	11-25-02	100.2	99.9	100.0
SCHLUMBERGER	J55	C399454	11-25-02	100.3	100.0	100.2
SCHLUMBERGER	J55	C399455	11-25-02	99.9	100.0	99.6
SCHLUMBERGER	J55	C399456	11-25-02	100.1	99.8	100.2
SCHLUMBERGER	J55	C399457	11-25-02	100.1	99.8	100.3
SCHLUMBERGER	J55	C399458	11-25-02	100.1	100.1	99.7
SCHLUMBERGER	J55	C399459	11-25-02	100.0	100.0	100.0
SCHLUMBERGER	J55	C399460	11-25-02	100.2	99.9	100.0
SCHLUMBERGER	J55	C399461	11-25-02	100.0	100.3	100.0
SCHLUMBERGER	J55	C399462	11-25-02	100.0	100.0	100.0
SCHLUMBERGER	J55	C399463	11-25-02	100.1	100.0	100.3
SCHLUMBERGER	J55	C399464	11-25-02	100.0	100.1	99.8
SCHLUMBERGER	J55	C399465	11-25-02	100.0	100.1	99.9
SCHLUMBERGER	J55	C399466	11-25-02	100.0	100.0	100.0
SCHLUMBERGER	J55	C399467	11-25-02	100.2	100.2	99.7
SCHLUMBERGER	J55	C399468	11-25-02	100.3	100.0	100.4
SCHLUMBERGER	J55	C399469	11-25-02	100.1	99.8	100.0
SCHLUMBERGER	J55	C399470	11-25-02	100.0	100.0	99.9
SCHLUMBERGER	J55	C399471	11-25-02	100.1	99.9	99.9

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

PAGE 288
 RUN DATE: 1/14/03
 RUN TIME: 13.26.53

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	J5S	C399472	11-25-02	100.2	100.1	100.2
SCHLUMBERGER	J5S	C399473	11-25-02	100.1	100.0	100.1
SCHLUMBERGER	J5S	C399474	11-25-02	100.1	100.1	99.9
SCHLUMBERGER	J5S	C399475	11-25-02	100.1	100.2	100.1
SCHLUMBERGER	J5S	C399476	11-25-02	99.9	100.0	100.1
SCHLUMBERGER	J5S	C399477	11-25-02	100.2	99.8	100.0
SCHLUMBERGER	J5S	C399478	11-25-02	100.1	100.1	100.2
SCHLUMBERGER	J5S	C399479	11-25-02	99.9	99.8	100.1
SCHLUMBERGER	J5S	C399480	11-25-02	99.9	99.8	100.0
SCHLUMBERGER	J5S	C399481	11-25-02	100.2	100.1	100.4
SCHLUMBERGER	J5S	C399482	11-25-02	100.2	99.9	100.4
SCHLUMBERGER	J5S	C399483	11-25-02	100.1	100.0	100.0
SCHLUMBERGER	J5S	C399484	11-25-02	100.1	99.8	100.2
SCHLUMBERGER	J5S	C399485	11-25-02	100.0	99.8	99.6
SCHLUMBERGER	J5S	C399486	11-25-02	100.2	100.0	100.1
SCHLUMBERGER	J5S	C399487	11-25-02	100.2	100.0	100.5
SCHLUMBERGER	J5S	C399488	11-25-02	99.9	99.7	100.7
SCHLUMBERGER	J5S	C399489	11-25-02	100.2	99.8	100.0
SCHLUMBERGER	J5S	C399490	11-25-02	100.2	99.9	99.8
SCHLUMBERGER	J5S	C399491	11-25-02	100.2	100.0	99.9
SCHLUMBERGER	J5S	C399492	11-25-02	100.1	99.9	99.9
SCHLUMBERGER	J5S	C399493	11-25-02	100.2	99.8	100.1
SCHLUMBERGER	J5S	C399494	11-25-02	100.1	100.2	99.9
SCHLUMBERGER	J5S	C399495	11-25-02	100.0	99.9	99.6
SCHLUMBERGER	J5S	C399496	11-25-02	100.1	100.0	100.3
SCHLUMBERGER	J5S	C399497	11-25-02	100.3	100.2	100.2
SCHLUMBERGER	J5S	C399498	11-25-02	100.2	100.0	100.6
SCHLUMBERGER	J5S	C399499	11-25-02	100.0	100.0	99.9
SCHLUMBERGER	J5S	C399500	11-25-02	100.0	99.7	99.8
SCHLUMBERGER	J5S	C399501	11-25-02	100.0	99.9	100.3
SCHLUMBERGER	J5S	C399502	11-25-02	100.2	99.9	99.9
SCHLUMBERGER	J5S	C399503	11-25-02	100.1	99.8	99.9
SCHLUMBERGER	J5S	C399504	11-25-02	100.3	100.0	100.3
SCHLUMBERGER	J5S	C399505	11-25-02	100.1	99.8	99.5
SCHLUMBERGER	J5S	C399506	11-25-02	100.1	100.0	100.0
SCHLUMBERGER	J5S	C399507	11-25-02	100.0	99.8	100.1
SCHLUMBERGER	J5S	C399508	11-25-02	100.1	99.6	99.6
SCHLUMBERGER	J5S	C399509	11-25-02	100.1	99.7	99.7
SCHLUMBERGER	J5S	C399510	11-25-02	100.1	100.3	99.9
SCHLUMBERGER	J5S	C399511	11-25-02	100.0	100.2	99.8
SCHLUMBERGER	J5S	C399512	11-25-02	100.0	99.8	100.1
SCHLUMBERGER	J5S	C399513	11-25-02	100.3	100.2	99.9
SCHLUMBERGER	J5S	C399514	11-25-02	100.0	100.2	100.0
SCHLUMBERGER	J5S	C399515	11-25-02	100.2	100.0	100.5
SCHLUMBERGER	J5S	C399516	11-25-02	100.3	100.1	100.2
SCHLUMBERGER	J5S	C399517	11-25-02	100.2	99.7	99.7
SCHLUMBERGER	J5S	C399518	11-25-02	100.1	99.9	100.0
SCHLUMBERGER	J5S	C399519	11-25-02	100.2	100.2	99.9
SCHLUMBERGER	J5S	C399520	11-25-02	100.3	100.1	99.7
SCHLUMBERGER	J5S	C399521	11-25-02	100.1	99.7	99.8
SCHLUMBERGER	J5S	C399522	11-25-02	100.0	99.7	100.2

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	J55	C399523	11-25-02	100.0	100.1	99.9
SCHLUMBERGER	J55	C399524	11-25-02	100.2	99.8	99.8
SCHLUMBERGER	J55	C399525	11-25-02	100.1	99.9	99.9
SCHLUMBERGER	J55	C399526	11-25-02	99.9	99.8	99.7
SCHLUMBERGER	J55	C399527	11-25-02	100.3	99.9	100.5
SCHLUMBERGER	J55	C399528	11-25-02	100.0	99.9	99.7
SCHLUMBERGER	J55	C399529	11-25-02	100.1	99.8	99.8
SCHLUMBERGER	J55	C399530	11-25-02	100.0	99.8	99.6
SCHLUMBERGER	J55	C399531	11-25-02	99.9	99.7	99.9
SCHLUMBERGER	J55	C399532	11-25-02	100.3	99.9	99.6
SCHLUMBERGER	J55	C399533	11-25-02	100.0	99.9	99.5
SCHLUMBERGER	J55	C399534	11-25-02	100.3	100.3	100.2
SCHLUMBERGER	J55	C399535	11-25-02	100.2	100.4	100.0
SCHLUMBERGER	J55	C399536	11-25-02	100.2	99.8	99.9
SCHLUMBERGER	J55	C399537	11-25-02	100.1	99.9	100.2
SCHLUMBERGER	J55	C399538	11-25-02	100.3	100.3	99.8
SCHLUMBERGER	J55	C399539	11-25-02	99.8	99.9	100.0
SCHLUMBERGER	J55	C399540	11-25-02	100.2	99.9	99.8
SCHLUMBERGER	J55	C399541	11-25-02	100.1	100.1	100.0
SCHLUMBERGER	J55	C399542	11-25-02	100.1	99.8	100.2
SCHLUMBERGER	J55	C399543	11-25-02	100.2	99.9	100.0
SCHLUMBERGER	J55	C399544	11-25-02	100.1	100.1	100.1
SCHLUMBERGER	J55	C399545	11-25-02	99.8	99.8	100.0
SCHLUMBERGER	J55	C399546	11-25-02	100.3	99.8	99.3
SCHLUMBERGER	J55	C399547	11-25-02	100.3	99.9	100.0
SCHLUMBERGER	J55	C399548	11-25-02	100.2	100.1	99.9
SCHLUMBERGER	J55	C399549	11-25-02	100.2	100.1	99.9
SCHLUMBERGER	J55	C399550	11-25-02	100.3	100.3	100.5
SCHLUMBERGER	J55	C399551	11-25-02	100.0	99.9	100.1
SCHLUMBERGER	J55	C399552	11-25-02	100.0	99.7	99.9
SCHLUMBERGER	J55	C399553	11-25-02	100.1	99.9	100.1
SCHLUMBERGER	J55	C399554	11-25-02	100.0	99.6	99.6
SCHLUMBERGER	J55	C399555	11-25-02	100.2	99.7	100.0
SCHLUMBERGER	J55	C399556	11-25-02	100.1	100.0	100.0
SCHLUMBERGER	J55	C399557	11-25-02	100.0	99.9	99.8
SCHLUMBERGER	J55	C399558	11-25-02	100.0	99.9	100.2
SCHLUMBERGER	J55	C399559	11-25-02	100.1	100.0	100.0
SCHLUMBERGER	J55	C399560	11-25-02	100.2	99.7	100.0
SCHLUMBERGER	J55	C399561	11-25-02	99.9	99.8	99.8
SCHLUMBERGER	J55	C399562	11-25-02	100.1	100.0	99.8
SCHLUMBERGER	J55	C399563	11-25-02	100.0	100.0	99.5
SCHLUMBERGER	J55	C399564	11-25-02	100.2	100.0	99.7
SCHLUMBERGER	J55	C399565	11-25-02	99.9	99.9	99.9
SCHLUMBERGER	J55	C399566	11-25-02	100.1	100.1	99.6
SCHLUMBERGER	J55	C399567	11-25-02	100.1	100.1	99.7
SCHLUMBERGER	J55	C399568	11-25-02	100.0	99.8	99.9
SCHLUMBERGER	J55	C399569	11-25-02	100.0	99.8	99.8
SCHLUMBERGER	J55	C399570	11-25-02	99.9	100.1	99.8
SCHLUMBERGER	J55	C399571	11-25-02	100.1	99.7	99.8
SCHLUMBERGER	J55	C399572	11-25-02	100.2	100.1	100.0
SCHLUMBERGER	J55	C399573	11-25-02	100.1	99.9	99.7

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	J5S	C399574	11-25-02	100.0	100.1	99.9
SCHLUMBERGER	J5S	C399575	11-25-02	99.8	100.0	99.8
SCHLUMBERGER	J5S	C399576	11-25-02	100.1	99.7	100.1
SCHLUMBERGER	J5S	C399577	11-25-02	100.0	99.9	99.7
SCHLUMBERGER	J5S	C399578	11-25-02	100.0	100.1	100.2
SCHLUMBERGER	J5S	C399579	11-25-02	100.0	100.1	99.7
SCHLUMBERGER	J5S	C399580	11-25-02	100.3	99.8	100.5
SCHLUMBERGER	J5S	C399581	11-25-02	100.1	100.1	100.0
SCHLUMBERGER	J5S	C399582	11-25-02	100.1	100.3	99.5
SCHLUMBERGER	J5S	C399583	11-25-02	99.8	99.7	99.5
SCHLUMBERGER	J5S	C399584	11-25-02	100.3	99.9	100.0
SCHLUMBERGER	J5S	C399585	11-25-02	100.3	99.9	99.9
SCHLUMBERGER	J5S	C399586	11-25-02	100.1	99.9	100.1
SCHLUMBERGER	J5S	C399587	11-25-02	100.2	100.1	99.8
SCHLUMBERGER	J5S	C399588	11-25-02	100.0	100.1	100.2
SCHLUMBERGER	J5S	C399589	11-25-02	100.1	99.8	100.0
SCHLUMBERGER	J5S	C399590	11-25-02	100.1	99.7	100.0
SCHLUMBERGER	J5S	C399591	11-25-02	100.2	99.7	99.7
SCHLUMBERGER	J5S	C399592	11-25-02	100.0	100.1	100.0
SCHLUMBERGER	J5S	C399593	11-25-02	100.0	100.1	100.1
SCHLUMBERGER	J5S	C399594	11-25-02	100.0	99.8	100.0
SCHLUMBERGER	J5S	C399595	11-25-02	100.1	100.0	99.5
SCHLUMBERGER	J5S	C399596	11-25-02	100.1	100.0	99.9
SCHLUMBERGER	J5S	C399597	11-25-02	100.1	99.9	100.1
SCHLUMBERGER	J5S	C399598	11-25-02	100.2	100.4	100.2
SCHLUMBERGER	J5S	C399599	11-25-02	99.9	100.0	99.8
SCHLUMBERGER	J5S	C399600	11-25-02	100.2	99.9	100.3
SCHLUMBERGER	J5S	C399601	11-25-02	100.0	100.2	99.9
SCHLUMBERGER	J5S	C399602	11-25-02	100.3	100.4	99.9
SCHLUMBERGER	J5S	C399603	11-25-02	100.3	100.0	100.2
SCHLUMBERGER	J5S	C399604	11-25-02	100.3	100.0	100.2
SCHLUMBERGER	J5S	C399605	11-25-02	100.1	99.9	99.9
SCHLUMBERGER	J5S	C399606	11-25-02	100.0	99.8	100.2
SCHLUMBERGER	J5S	C399607	11-25-02	100.1	99.8	99.8
SCHLUMBERGER	J5S	C399608	11-25-02	100.3	100.4	100.1
SCHLUMBERGER	J5S	C399609	11-25-02	100.1	100.1	99.5
SCHLUMBERGER	J5S	C399610	11-25-02	100.2	100.3	100.0
SCHLUMBERGER	J5S	C399611	11-25-02	100.2	100.2	100.0
SCHLUMBERGER	J5S	C399612	11-25-02	100.3	100.1	99.8
SCHLUMBERGER	J5S	C399613	11-25-02	99.9	99.7	99.6
SCHLUMBERGER	J5S	C399614	11-25-02	100.1	99.9	99.9
SCHLUMBERGER	J5S	C399615	11-25-02	100.0	100.3	99.8
SCHLUMBERGER	J5S	C399616	11-25-02	100.2	99.8	99.5
SCHLUMBERGER	J5S	C399617	11-25-02	100.0	100.1	100.2
SCHLUMBERGER	J5S	C399618	11-25-02	100.1	99.8	99.8
SCHLUMBERGER	J5S	C399619	11-25-02	100.3	100.1	100.2
SCHLUMBERGER	J5S	C399620	11-25-02	100.1	99.7	99.9
SCHLUMBERGER	J5S	C399621	11-25-02	100.2	100.0	100.1
SCHLUMBERGER	J5S	C399622	11-25-02	100.0	99.9	99.9
SCHLUMBERGER	J5S	C399623	11-25-02	100.3	100.2	100.2
SCHLUMBERGER	J5S	C399624	11-25-02	100.3	100.2	99.7

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

PAGE 291
 RUN DATE: 1/14/03
 RUN TIME: 13.26.53

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	J55	C399625	11-25-02	100.2	99.8	99.9
SCHLUMBERGER	J55	C399626	11-25-02	100.0	99.9	99.9
SCHLUMBERGER	J55	C399627	11-25-02	99.8	99.7	99.9
SCHLUMBERGER	J55	C399628	11-25-02	99.9	99.7	99.9
SCHLUMBERGER	J55	C399629	11-25-02	100.1	100.0	100.1
SCHLUMBERGER	J55	C399630	11-25-02	100.1	100.1	99.8
SCHLUMBERGER	J55	C399631	11-25-02	100.2	100.2	100.2
SCHLUMBERGER	J55	C399632	11-25-02	100.3	99.9	100.4
SCHLUMBERGER	J55	C399633	11-25-02	100.1	99.9	99.9
SCHLUMBERGER	J55	C399634	11-25-02	100.2	100.0	99.7
SCHLUMBERGER	J55	C399635	11-25-02	100.1	100.3	100.1
SCHLUMBERGER	J55	C399636	11-25-02	100.2	100.0	99.7
SCHLUMBERGER	J55	C399637	11-25-02	100.3	99.9	100.1
SCHLUMBERGER	J55	C399638	11-25-02	100.3	99.9	100.3
SCHLUMBERGER	J55	C399639	11-25-02	100.0	100.2	99.7
SCHLUMBERGER	J55	C399640	11-25-02	100.2	100.2	100.1
SCHLUMBERGER	J55	C399641	11-25-02	100.0	99.9	99.8
SCHLUMBERGER	J55	C399642	11-25-02	100.2	99.9	99.8
SCHLUMBERGER	J55	C399643	11-25-02	100.3	100.1	99.8
SCHLUMBERGER	J55	C399644	11-25-02	100.0	99.7	100.2
SCHLUMBERGER	J55	C399645	11-25-02	100.1	100.2	99.9
SCHLUMBERGER	J55	C399646	11-25-02	100.2	100.0	100.0
SCHLUMBERGER	J55	C399647	11-25-02	100.3	100.1	99.7
SCHLUMBERGER	J55	C399648	11-25-02	100.0	99.7	99.6
SCHLUMBERGER	J55	C399649	11-25-02	100.0	100.0	100.0
SCHLUMBERGER	J55	C399650	11-25-02	100.1	99.7	99.6
SCHLUMBERGER	J55	C399651	11-25-02	100.1	100.1	100.0
SCHLUMBERGER	J55	C399652	11-25-02	100.2	99.8	100.0
SCHLUMBERGER	J55	C399653	11-25-02	100.2	100.1	99.7
SCHLUMBERGER	J55	C399654	11-25-02	100.0	99.8	100.3
SCHLUMBERGER	J55	C399655	11-25-02	100.1	99.8	99.7
SCHLUMBERGER	J55	C399656	11-25-02	100.3	100.1	99.9
SCHLUMBERGER	J55	C399657	11-25-02	100.1	99.9	99.6
SCHLUMBERGER	J55	C399658	11-25-02	100.2	99.9	99.7
SCHLUMBERGER	J55	C399659	11-25-02	100.1	100.2	100.1
SCHLUMBERGER	J55	C399660	11-25-02	100.3	100.0	100.0
SCHLUMBERGER	J55	C399661	11-25-02	100.2	99.7	99.7
SCHLUMBERGER	J55	C399662	11-25-02	100.1	100.2	99.7
SCHLUMBERGER	J55	C399663	11-25-02	100.3	100.1	100.4
SCHLUMBERGER	J55	C399664	11-25-02	100.1	99.8	99.9
SCHLUMBERGER	J55	C399665	11-25-02	100.2	99.8	99.9
SCHLUMBERGER	J55	C399666	11-25-02	100.2	100.0	100.0
SCHLUMBERGER	J55	C399667	11-25-02	100.2	99.7	100.1
SCHLUMBERGER	J55	C399668	11-25-02	100.1	100.1	99.6
SCHLUMBERGER	J55	C399669	11-25-02	100.1	100.1	100.1
SCHLUMBERGER	J55	C399670	11-25-02	100.1	99.8	99.9
SCHLUMBERGER	J55	C399671	11-25-02	100.1	99.7	99.5
SCHLUMBERGER	J55	C399672	11-25-02	100.1	99.8	99.6
SCHLUMBERGER	J55	C399673	11-25-02	100.1	99.9	99.7
SCHLUMBERGER	J55	C399674	11-25-02	100.2	99.9	99.7
SCHLUMBERGER	J55	C399675	11-25-02	100.2	99.8	99.8

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

PAGE 292
 RUN DATE: 1/14/03
 RUN TIME: 13.26.53

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	J5S	C399676	11-25-02	100.2	100.2	100.0
SCHLUMBERGER	J5S	C399677	11-25-02	100.0	99.8	99.6
SCHLUMBERGER	J5S	C399678	11-25-02	100.1	100.0	100.3
SCHLUMBERGER	J5S	C399679	11-25-02	100.3	99.8	100.5
SCHLUMBERGER	J5S	C399680	11-25-02	100.2	100.2	100.0
SCHLUMBERGER	J5S	C399681	11-25-02	100.2	100.2	100.2
SCHLUMBERGER	J5S	C399682	11-25-02	100.1	100.2	100.0
SCHLUMBERGER	J5S	C399683	11-25-02	100.3	99.7	100.1
SCHLUMBERGER	J5S	C399684	11-25-02	100.1	99.7	99.7
SCHLUMBERGER	J5S	C399685	11-25-02	100.0	100.0	99.8
SCHLUMBERGER	J5S	C399686	11-25-02	99.9	99.9	100.0
SCHLUMBERGER	J5S	C399687	11-25-02	99.9	99.7	99.9
SCHLUMBERGER	J5S	C399688	11-25-02	100.1	100.1	99.5
SCHLUMBERGER	J5S	C399689	11-25-02	100.3	99.7	100.1
SCHLUMBERGER	J5S	C399690	11-25-02	100.1	99.9	99.9
SCHLUMBERGER	J5S	C399691	11-25-02	100.1	99.9	99.9
SCHLUMBERGER	J5S	C399692	11-25-02	100.1	99.9	100.1
SCHLUMBERGER	J5S	C399693	11-25-02	99.8	99.9	99.9
SCHLUMBERGER	J5S	C399694	11-25-02	100.0	99.8	100.0
SCHLUMBERGER	J5S	C399695	11-25-02	100.2	100.0	99.8
SCHLUMBERGER	J5S	C399696	11-25-02	100.2	100.3	99.9
SCHLUMBERGER	J5S	C399697	11-25-02	100.1	100.1	100.3
SCHLUMBERGER	J5S	C399698	11-25-02	100.3	100.1	100.0
SCHLUMBERGER	J5S	C399699	11-25-02	100.2	100.2	99.7
SCHLUMBERGER	J5S	C399700	11-25-02	100.1	100.1	99.8
SCHLUMBERGER	J5S	C399701	11-25-02	100.3	100.4	99.9
SCHLUMBERGER	J5S	C399702	11-25-02	100.1	100.0	100.0
SCHLUMBERGER	J5S	C399703	11-25-02	100.0	100.0	100.2
SCHLUMBERGER	J5S	C399704	11-25-02	99.9	99.9	100.0
SCHLUMBERGER	J5S	C399705	11-25-02	100.2	99.8	99.8
SCHLUMBERGER	J5S	C399706	11-25-02	100.2	99.7	99.9
SCHLUMBERGER	J5S	C399707	11-25-02	100.3	99.9	100.0
SCHLUMBERGER	J5S	C399708	11-25-02	100.2	99.8	100.4
SCHLUMBERGER	J5S	C399709	11-25-02	100.0	100.1	99.6
SCHLUMBERGER	J5S	C399710	11-25-02	100.0	100.0	100.1
SCHLUMBERGER	J5S	C399711	11-25-02	100.1	100.3	99.9
SCHLUMBERGER	J5S	C399712	11-25-02	100.0	99.9	100.1
SCHLUMBERGER	J5S	C399713	11-25-02	100.1	99.8	99.5
SCHLUMBERGER	J5S	C399714	11-25-02	100.3	100.4	99.8
SCHLUMBERGER	J5S	C399715	11-25-02	100.0	100.4	100.7
SCHLUMBERGER	J5S	C399716	11-25-02	100.1	99.9	99.9
SCHLUMBERGER	J5S	C399717	11-25-02	100.3	100.0	99.9
SCHLUMBERGER	J5S	C399718	11-25-02	100.2	100.2	99.8
SCHLUMBERGER	J5S	C399719	11-25-02	100.0	100.1	99.7
SCHLUMBERGER	J5S	C399720	11-25-02	100.0	99.9	100.2
SCHLUMBERGER	J5S	C399721	11-25-02	100.0	99.9	100.2
SCHLUMBERGER	J5S	C399722	11-25-02	100.0	99.9	100.2
SCHLUMBERGER	J5S	C399723	11-25-02	100.0	99.8	99.9
SCHLUMBERGER	J5S	C399724	11-25-02	100.1	100.0	99.8
SCHLUMBERGER	J5S	C399725	11-25-02	100.2	100.0	100.1
SCHLUMBERGER	J5S	C399726	11-25-02	100.0	99.7	100.4
SCHLUMBERGER	J5S	C399726	11-25-02	100.0	99.7	100.1

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	J5S	C399727	11-25-02	100.0	100.0	100.0
SCHLUMBERGER	J5S	C399728	11-25-02	99.9	99.7	100.0
SCHLUMBERGER	J5S	C399729	11-25-02	100.0	99.9	100.1
SCHLUMBERGER	J5S	C399730	11-25-02	100.0	99.8	100.6
SCHLUMBERGER	J5S	C399731	11-25-02	100.0	100.1	99.9
SCHLUMBERGER	J5S	C399732	11-25-02	100.3	100.0	100.1
SCHLUMBERGER	J5S	C399733	11-25-02	100.0	100.0	99.9
SCHLUMBERGER	J5S	C399734	11-25-02	99.9	100.1	99.8
SCHLUMBERGER	J5S	C399735	11-25-02	100.0	99.9	99.4
SCHLUMBERGER	J5S	C399736	11-25-02	100.0	100.0	100.0
SCHLUMBERGER	J5S	C399737	11-25-02	99.9	100.0	100.0
SCHLUMBERGER	J5S	C399738	11-25-02	100.1	100.2	99.9
SCHLUMBERGER	J5S	C399739	11-25-02	99.8	99.7	99.8
SCHLUMBERGER	J5S	C399740	11-25-02	100.1	100.0	99.7
SCHLUMBERGER	J5S	C399741	11-25-02	100.0	100.1	100.0
SCHLUMBERGER	J5S	C399742	11-25-02	100.1	99.9	99.9
SCHLUMBERGER	J5S	C399743	11-25-02	100.1	99.9	99.8
SCHLUMBERGER	J5S	C399744	11-25-02	100.3	100.0	100.2
SCHLUMBERGER	J5S	C399745	11-25-02	99.9	99.9	99.6
SCHLUMBERGER	J5S	C399746	11-25-02	100.0	100.0	99.8
SCHLUMBERGER	J5S	C399747	11-25-02	100.1	99.9	100.0
SCHLUMBERGER	J5S	C399748	11-25-02	100.2	100.2	100.0
SCHLUMBERGER	J5S	C399749	11-25-02	99.9	100.1	99.8
SCHLUMBERGER	J5S	C399750	11-25-02	100.2	99.7	99.8
SCHLUMBERGER	J5S	C399751	11-25-02	100.0	100.0	99.6
SCHLUMBERGER	J5S	C399752	11-25-02	100.1	100.0	99.6
SCHLUMBERGER	J5S	C399753	11-25-02	100.0	99.9	100.0
SCHLUMBERGER	J5S	C399754	11-25-02	100.0	99.9	99.6
SCHLUMBERGER	J5S	C399755	11-25-02	100.2	100.0	99.8
SCHLUMBERGER	J5S	C399756	11-25-02	100.3	100.1	100.4
SCHLUMBERGER	J5S	C399757	11-25-02	100.1	99.9	100.0
SCHLUMBERGER	J5S	C399758	11-25-02	100.1	99.7	99.6
SCHLUMBERGER	J5S	C399759	11-25-02	100.2	99.9	100.1
SCHLUMBERGER	J5S	C399760	11-25-02	100.2	100.0	100.3
SCHLUMBERGER	J5S	C399761	11-25-02	100.2	100.0	100.3
SCHLUMBERGER	J5S	C399762	11-25-02	100.3	100.2	99.5
SCHLUMBERGER	J5S	C399763	11-25-02	100.0	100.0	100.3
SCHLUMBERGER	J5S	C399764	11-25-02	100.0	99.9	99.4
SCHLUMBERGER	J5S	C399765	11-25-02	100.0	99.8	99.7
SCHLUMBERGER	J5S	C399766	11-25-02	100.0	99.8	99.3
SCHLUMBERGER	J5S	C399767	11-25-02	99.9	100.0	99.9
SCHLUMBERGER	J5S	C399768	11-25-02	100.0	100.0	99.7
SCHLUMBERGER	J5S	C399769	11-25-02	100.0	100.2	100.2
SCHLUMBERGER	J5S	C399770	11-25-02	100.3	100.0	100.2
SCHLUMBERGER	J5S	C399771	11-25-02	100.0	100.1	99.6
SCHLUMBERGER	J5S	C399772	11-25-02	100.0	100.1	99.9
SCHLUMBERGER	J5S	C399773	11-25-02	100.0	100.0	99.8
SCHLUMBERGER	J5S	C399774	11-25-02	100.1	99.7	99.6
SCHLUMBERGER	J5S	C399775	11-25-02	100.1	99.7	99.7
SCHLUMBERGER	J5S	C399776	11-25-02	100.0	100.0	99.9
SCHLUMBERGER	J5S	C399777	11-25-02	100.2	100.0	99.9

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

MANUFACTURER	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	C399778	11-25-02	100.1	99.8	100.0
SCHLUMBERGER	C399779	11-25-02	100.0	99.9	99.9
SCHLUMBERGER	C399780	11-25-02	100.0	100.1	99.6
SCHLUMBERGER	C399781	11-25-02	99.8	99.9	99.5
SCHLUMBERGER	C399782	11-25-02	100.2	99.9	99.7
SCHLUMBERGER	C399783	11-25-02	100.1	100.0	99.8
SCHLUMBERGER	C399784	11-25-02	100.2	100.1	99.8
SCHLUMBERGER	C399785	11-25-02	100.1	99.8	99.8
SCHLUMBERGER	C399786	11-25-02	100.1	100.0	99.6
SCHLUMBERGER	C399787	11-25-02	100.0	99.9	99.9
SCHLUMBERGER	C399788	11-25-02	100.0	100.1	99.5
SCHLUMBERGER	C399789	11-25-02	99.9	99.9	99.4
SCHLUMBERGER	C399790	11-25-02	100.2	100.1	99.8
SCHLUMBERGER	C399791	11-25-02	99.9	99.7	100.2
SCHLUMBERGER	C399792	11-25-02	100.2	99.9	99.7
SCHLUMBERGER	C399793	11-25-02	100.1	100.1	99.7
SCHLUMBERGER	C399794	11-25-02	100.0	100.0	99.6
SCHLUMBERGER	C399795	11-25-02	100.0	100.0	100.0
SCHLUMBERGER	C399796	11-25-02	100.0	100.1	99.5
SCHLUMBERGER	C399797	11-25-02	100.0	100.3	100.0
SCHLUMBERGER	C399798	11-25-02	100.0	99.7	99.4
SCHLUMBERGER	C399799	11-25-02	99.9	99.8	99.7
SCHLUMBERGER	C399800	11-25-02	100.0	99.7	99.5
SCHLUMBERGER	C399801	11-25-02	100.1	99.9	99.7
SCHLUMBERGER	C399802	11-25-02	100.2	99.8	99.9
SCHLUMBERGER	C399803	11-25-02	100.3	99.8	99.8
SCHLUMBERGER	C399804	11-25-02	99.9	100.1	99.6
SCHLUMBERGER	C399805	11-25-02	100.2	100.0	99.8
SCHLUMBERGER	C399806	11-25-02	100.1	100.3	99.6
SCHLUMBERGER	C399807	11-25-02	99.9	100.1	99.4
SCHLUMBERGER	C399808	11-25-02	100.1	100.0	99.5
SCHLUMBERGER	C399809	11-25-02	100.1	100.1	99.7
SCHLUMBERGER	C399810	11-25-02	100.1	100.1	100.1
SCHLUMBERGER	C399811	11-25-02	100.2	100.2	99.9
SCHLUMBERGER	C399812	11-25-02	100.0	99.9	99.6
SCHLUMBERGER	C399813	11-25-02	100.1	99.8	99.8
SCHLUMBERGER	C399814	11-25-02	100.1	100.1	100.1
SCHLUMBERGER	C399815	11-25-02	99.9	99.7	99.8
SCHLUMBERGER	C399816	11-25-02	100.3	100.0	100.3
SCHLUMBERGER	C399817	11-25-02	100.1	100.0	100.0
SCHLUMBERGER	C399818	11-25-02	100.1	99.7	99.7
SCHLUMBERGER	C399819	11-25-02	100.1	99.9	99.5
SCHLUMBERGER	C399820	11-25-02	100.1	100.0	100.0
SCHLUMBERGER	C399821	11-25-02	100.1	100.0	100.1
SCHLUMBERGER	C399822	11-25-02	100.2	100.1	99.8
SCHLUMBERGER	C399823	11-25-02	100.2	100.1	100.0
SCHLUMBERGER	C399824	11-25-02	100.2	100.2	99.9
SCHLUMBERGER	C399825	11-25-02	100.1	100.2	99.5
SCHLUMBERGER	C399826	11-25-02	100.1	100.1	99.8
SCHLUMBERGER	C399827	11-25-02	100.0	99.7	100.4
SCHLUMBERGER	C399828	11-25-02	100.0	99.8	99.7

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

PAGE 295
 RUN DATE: 1/14/03
 RUN TIME: 13.26.53

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	J55	C399829	11-25-02	100.0	100.0	99.7
SCHLUMBERGER	J55	C399830	11-25-02	100.3	100.1	99.9
SCHLUMBERGER	J55	C399831	11-25-02	100.0	100.0	99.6
SCHLUMBERGER	J55	C399832	11-25-02	99.9	99.9	99.8
SCHLUMBERGER	J55	C399833	11-25-02	99.9	99.7	99.5
SCHLUMBERGER	J55	C399834	11-25-02	99.9	99.9	99.9
SCHLUMBERGER	J55	C399835	11-25-02	100.2	100.2	100.2
SCHLUMBERGER	J55	C399836	11-25-02	100.0	100.1	99.6
SCHLUMBERGER	J55	C399837	11-25-02	100.2	99.7	99.7
SCHLUMBERGER	J55	C399838	11-25-02	100.0	99.8	99.8
SCHLUMBERGER	J55	C399839	11-25-02	100.1	100.1	100.0
SCHLUMBERGER	J55	C399840	11-25-02	100.1	99.8	99.8
SCHLUMBERGER	J55	C399841	11-25-02	100.0	99.9	99.8
SCHLUMBERGER	J55	C399842	11-25-02	100.1	99.8	99.6
SCHLUMBERGER	J55	C399843	11-25-02	100.2	99.7	100.2
SCHLUMBERGER	J55	C399844	11-25-02	99.9	99.8	99.7
SCHLUMBERGER	J55	C399845	11-25-02	100.0	99.7	99.7
SCHLUMBERGER	J55	C399846	11-25-02	100.3	100.4	99.9
SCHLUMBERGER	J55	C399847	11-25-02	100.3	99.6	99.6
SCHLUMBERGER	J55	C399848	11-25-02	100.2	100.1	100.2
SCHLUMBERGER	J55	C399849	11-25-02	100.1	100.2	99.8
SCHLUMBERGER	J55	C399850	11-25-02	100.1	100.2	99.9
SCHLUMBERGER	J55	C399851	11-25-02	100.0	99.8	99.7
SCHLUMBERGER	J55	C399852	11-25-02	100.0	99.8	99.8
SCHLUMBERGER	J55	C399853	11-25-02	100.1	100.4	100.3
SCHLUMBERGER	J55	C399854	11-25-02	100.1	100.2	99.5
SCHLUMBERGER	J55	C399855	11-25-02	100.1	100.0	99.6
SCHLUMBERGER	J55	C399856	11-25-02	100.2	100.3	99.9
SCHLUMBERGER	J55	C399857	11-25-02	99.9	99.9	100.0
SCHLUMBERGER	J55	C399858	11-25-02	100.0	100.1	100.3
SCHLUMBERGER	J55	C399859	11-25-02	100.1	99.9	100.2
SCHLUMBERGER	J55	C399860	11-25-02	100.3	100.1	100.2
SCHLUMBERGER	J55	C399861	11-25-02	100.0	99.8	100.4
SCHLUMBERGER	J55	C399862	11-25-02	100.1	100.1	100.1
SCHLUMBERGER	J55	C399863	11-25-02	100.1	100.2	99.7
SCHLUMBERGER	J55	C399864	11-25-02	100.2	100.0	99.9
SCHLUMBERGER	J55	C399865	11-25-02	100.0	100.1	99.8
SCHLUMBERGER	J55	C399866	11-25-02	100.0	100.0	99.5
SCHLUMBERGER	J55	C399867	11-25-02	100.0	99.7	99.8
SCHLUMBERGER	J55	C399868	11-25-02	100.1	100.0	100.3
SCHLUMBERGER	J55	C399869	11-25-02	99.9	100.1	99.5
SCHLUMBERGER	J55	C399870	11-25-02	100.2	100.2	100.3
SCHLUMBERGER	J55	C399871	11-25-02	99.9	100.1	100.0
SCHLUMBERGER	J55	C399872	11-25-02	100.0	100.0	99.8
SCHLUMBERGER	J55	C399873	11-25-02	100.0	99.9	99.7
SCHLUMBERGER	J55	C399874	11-25-02	100.1	100.1	99.8
SCHLUMBERGER	J55	C399875	11-25-02	100.2	100.2	99.8
SCHLUMBERGER	J55	C399876	11-25-02	99.9	99.8	100.1
SCHLUMBERGER	J55	C399877	11-25-02	100.3	100.0	99.8
SCHLUMBERGER	J55	C399878	11-25-02	100.2	100.0	99.8
SCHLUMBERGER	J55	C399879	11-25-02	100.0	100.0	99.8

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

PAGE 296
 RUN DATE: 1/14/03
 RUN TIME: 13.26.53

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	J5S	C399880	11-25-02	100.0	99.8	99.9
SCHLUMBERGER	J5S	C399881	11-25-02	100.2	100.1	99.8
SCHLUMBERGER	J5S	C399882	11-25-02	100.2	100.2	100.1
SCHLUMBERGER	J5S	C399883	11-25-02	100.1	100.0	100.2
SCHLUMBERGER	J5S	C399884	11-25-02	100.3	100.2	99.5
SCHLUMBERGER	J5S	C399885	11-25-02	100.1	99.7	99.7
SCHLUMBERGER	J5S	C399886	11-25-02	100.2	100.1	100.2
SCHLUMBERGER	J5S	C399887	11-25-02	100.0	100.2	100.3
SCHLUMBERGER	J5S	C399888	11-25-02	100.0	100.1	100.2
SCHLUMBERGER	J5S	C399889	11-25-02	100.2	100.0	99.9
SCHLUMBERGER	J5S	C399890	11-25-02	100.0	99.7	100.2
SCHLUMBERGER	J5S	C399891	11-25-02	100.2	100.0	100.0
SCHLUMBERGER	J5S	C399892	11-25-02	100.3	100.1	100.2
SCHLUMBERGER	J5S	C399893	11-25-02	100.2	100.1	100.1
SCHLUMBERGER	J5S	C399894	11-25-02	100.3	100.0	99.9
SCHLUMBERGER	J5S	C399895	11-25-02	100.2	100.0	100.0
SCHLUMBERGER	J5S	C399896	11-25-02	100.0	100.2	99.8
SCHLUMBERGER	J5S	C399897	11-25-02	100.2	100.3	99.9
SCHLUMBERGER	J5S	C399898	11-25-02	100.3	100.3	99.9
SCHLUMBERGER	J5S	C399899	11-25-02	100.0	100.1	100.5
SCHLUMBERGER	J5S	C399900	11-25-02	100.2	99.6	99.4
SCHLUMBERGER	J5S	C399901	11-25-02	100.0	99.9	100.4
SCHLUMBERGER	J5S	C399902	11-25-02	100.1	99.9	100.3
SCHLUMBERGER	J5S	C399903	11-25-02	99.9	99.9	99.6
SCHLUMBERGER	J5S	C399904	11-25-02	100.2	100.0	100.0
SCHLUMBERGER	J5S	C399905	11-25-02	100.2	100.0	100.1
SCHLUMBERGER	J5S	C399906	11-25-02	100.1	100.2	100.5
SCHLUMBERGER	J5S	C399907	11-25-02	100.2	100.2	99.9
SCHLUMBERGER	J5S	C399908	11-25-02	100.1	99.9	100.1
SCHLUMBERGER	J5S	C399909	11-25-02	100.2	100.0	99.7
SCHLUMBERGER	J5S	C399910	11-25-02	100.3	100.0	99.7
SCHLUMBERGER	J5S	C399911	11-25-02	100.1	100.2	100.5
SCHLUMBERGER	J5S	C399912	11-25-02	100.1	100.0	100.2
SCHLUMBERGER	J5S	C399913	11-25-02	100.3	100.0	99.6
SCHLUMBERGER	J5S	C399914	11-25-02	100.3	100.0	100.6
SCHLUMBERGER	J5S	C399915	11-25-02	100.2	100.2	100.5
SCHLUMBERGER	J5S	C399916	11-25-02	100.1	100.2	99.8
SCHLUMBERGER	J5S	C399917	11-25-02	100.2	100.0	99.5
SCHLUMBERGER	J5S	C399918	11-25-02	99.9	99.8	99.5
SCHLUMBERGER	J5S	C399919	11-25-02	99.9	99.8	99.5
SCHLUMBERGER	J5S	C399920	11-25-02	100.2	100.2	99.5
SCHLUMBERGER	J5S	C399921	11-25-02	100.1	99.9	100.3
SCHLUMBERGER	J5S	C399922	11-25-02	100.1	100.0	100.3
SCHLUMBERGER	J5S	C399923	11-25-02	100.1	100.1	100.1
SCHLUMBERGER	J5S	C399924	11-25-02	100.2	100.5	99.7
SCHLUMBERGER	J5S	C399925	11-25-02	100.0	100.1	99.6
SCHLUMBERGER	J5S	C399926	11-25-02	100.2	100.2	100.2
SCHLUMBERGER	J5S	C399927	11-25-02	100.0	100.1	99.6
SCHLUMBERGER	J5S	C399928	11-25-02	100.1	100.0	100.1
SCHLUMBERGER	J5S	C399929	11-25-02	100.2	100.1	99.8
SCHLUMBERGER	J5S	C399930	11-25-02	100.1	99.9	99.9

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

PAGE 297
 RUN DATE: 1/14/03
 RUN TIME: 13.26.53

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	J5S	C399931	11-25-02	100.1	100.0	99.8
SCHLUMBERGER	J5S	C399932	11-25-02	100.0	100.1	99.6
SCHLUMBERGER	J5S	C399933	11-25-02	100.0	99.6	100.2
SCHLUMBERGER	J5S	C399934	11-25-02	100.1	100.1	100.0
SCHLUMBERGER	J5S	C399935	11-25-02	100.2	100.2	99.8
SCHLUMBERGER	J5S	C399936	11-25-02	100.0	100.1	99.9
SCHLUMBERGER	J5S	C399937	11-25-02	100.1	100.1	99.9
SCHLUMBERGER	J5S	C399938	11-25-02	100.1	99.9	99.8
SCHLUMBERGER	J5S	C399939	11-25-02	100.3	100.1	100.2
SCHLUMBERGER	J5S	C399940	11-25-02	100.0	99.9	100.1
SCHLUMBERGER	J5S	C399941	11-25-02	100.2	99.9	100.4
SCHLUMBERGER	J5S	C399942	11-25-02	100.1	100.2	100.1
SCHLUMBERGER	J5S	C399943	11-25-02	100.1	100.1	99.7
SCHLUMBERGER	J5S	C399944	11-25-02	100.0	99.8	99.7
SCHLUMBERGER	J5S	C399945	11-25-02	100.1	100.1	99.9
SCHLUMBERGER	J5S	C399946	11-25-02	100.2	100.0	99.9
SCHLUMBERGER	J5S	C399947	11-25-02	100.3	100.2	99.9
SCHLUMBERGER	J5S	C399948	11-25-02	100.1	99.8	99.7
SCHLUMBERGER	J5S	C399949	11-25-02	100.0	99.8	99.8
SCHLUMBERGER	J5S	C399950	11-25-02	100.3	100.2	99.9
SCHLUMBERGER	J5S	C399951	11-25-02	100.3	100.2	100.0
SCHLUMBERGER	J5S	C399952	11-25-02	99.9	99.7	99.5
SCHLUMBERGER	J5S	C399953	11-25-02	100.3	100.2	99.7
SCHLUMBERGER	J5S	C399954	11-25-02	100.0	99.9	100.1
SCHLUMBERGER	J5S	C399955	11-25-02	100.2	99.8	99.8
SCHLUMBERGER	J5S	C399956	11-25-02	100.0	100.0	99.5
SCHLUMBERGER	J5S	C399957	11-25-02	100.2	99.8	100.0
SCHLUMBERGER	J5S	C399958	11-25-02	100.0	100.2	99.9
SCHLUMBERGER	J5S	C399959	11-25-02	100.3	100.1	99.7
SCHLUMBERGER	J5S	C399960	11-25-02	100.3	100.2	100.0
SCHLUMBERGER	J5S	C399961	11-25-02	100.1	99.9	100.0
SCHLUMBERGER	J5S	C399962	11-25-02	100.3	100.0	99.8
SCHLUMBERGER	J5S	C399963	11-25-02	100.1	100.1	99.9
SCHLUMBERGER	J5S	C399964	11-25-02	99.9	99.9	99.9
SCHLUMBERGER	J5S	C399965	11-25-02	100.2	100.0	99.8
SCHLUMBERGER	J5S	C399966	11-25-02	100.1	100.2	99.9
SCHLUMBERGER	J5S	C399967	11-25-02	100.1	100.3	99.9
SCHLUMBERGER	J5S	C399968	11-25-02	100.2	100.3	100.0
SCHLUMBERGER	J5S	C399969	11-25-02	100.2	100.2	100.1
SCHLUMBERGER	J5S	C399970	11-25-02	100.1	100.3	99.6
SCHLUMBERGER	J5S	C399971	11-25-02	100.1	100.0	99.7
SCHLUMBERGER	J5S	C399972	11-25-02	100.1	100.3	99.7
SCHLUMBERGER	J5S	C399973	11-25-02	100.1	99.6	100.2
SCHLUMBERGER	J5S	C399974	11-25-02	100.0	100.0	100.1
SCHLUMBERGER	J5S	C399975	11-25-02	100.2	99.9	100.1
SCHLUMBERGER	J5S	C399976	11-25-02	100.1	100.3	100.0
SCHLUMBERGER	J5S	C399977	11-25-02	100.1	100.1	99.8
SCHLUMBERGER	J5S	C399978	11-25-02	99.9	100.1	100.3
SCHLUMBERGER	J5S	C399979	11-25-02	100.3	100.2	100.1
SCHLUMBERGER	J5S	C399980	11-25-02	100.2	100.2	99.9
SCHLUMBERGER	J5S	C399981	11-25-02	100.3	100.3	100.3

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

PAGE 298
 RUN DATE: 1/14/03
 RUN TIME: 13.26.53

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	J5S	C399982	11-25-02	100.2	100.2	99.8
SCHLUMBERGER	J5S	C399983	11-25-02	100.2	100.2	100.4
SCHLUMBERGER	J5S	C399984	11-25-02	100.0	99.9	99.9
SCHLUMBERGER	J5S	C399985	11-25-02	100.0	100.2	100.2
SCHLUMBERGER	J5S	C399986	11-25-02	100.0	99.9	99.7
SCHLUMBERGER	J5S	C399987	11-25-02	100.1	99.8	100.2
SCHLUMBERGER	J5S	C399988	11-25-02	100.2	100.0	100.1
SCHLUMBERGER	J5S	C399989	11-25-02	100.2	99.9	99.6
SCHLUMBERGER	J5S	C399990	11-25-02	100.0	99.9	100.0
SCHLUMBERGER	J5S	C399991	11-25-02	100.2	100.2	100.1
SCHLUMBERGER	J5S	C399992	11-25-02	99.9	99.9	99.8
SCHLUMBERGER	J5S	C399993	11-25-02	100.0	100.1	100.1
SCHLUMBERGER	J5S	C399994	11-25-02	100.2	99.9	99.7
SCHLUMBERGER	J5S	C399995	11-25-02	100.3	99.9	99.8
SCHLUMBERGER	J5S	C399996	11-25-02	100.2	100.0	100.1
SCHLUMBERGER	J5S	C399997	11-25-02	100.3	100.1	100.1
SCHLUMBERGER	J5S	C399998	11-25-02	100.2	100.1	100.1
SCHLUMBERGER	J5S	C399999	11-25-02	100.3	100.2	100.0
SCHLUMBERGER	J5S	C400000	11-25-02	99.9	100.1	99.7
SCHLUMBERGER	J5S	C400001	11-25-02	100.1	100.2	99.7
SCHLUMBERGER	J5S	C400002	11-25-02	100.3	100.1	99.9
SCHLUMBERGER	J5S	C400003	11-25-02	99.9	99.9	99.7
SCHLUMBERGER	J5S	C400004	11-25-02	100.2	100.4	100.3
SCHLUMBERGER	J5S	C400005	11-25-02	100.0	100.2	99.7
SCHLUMBERGER	J5S	C400006	11-25-02	100.2	100.1	99.9
SCHLUMBERGER	J5S	C400007	11-25-02	100.0	100.0	100.0
SCHLUMBERGER	J5S	C400008	11-25-02	100.2	100.2	99.7
SCHLUMBERGER	J5S	C400009	11-25-02	100.3	100.1	99.9
SCHLUMBERGER	J5S	C400010	11-25-02	100.3	100.0	100.0
SCHLUMBERGER	J5S	C400011	11-25-02	100.3	100.4	100.3
SCHLUMBERGER	J5S	C400012	11-25-02	100.3	100.3	99.9
SCHLUMBERGER	J5S	C400013	11-25-02	100.2	100.1	99.9
SCHLUMBERGER	J5S	C400014	11-25-02	100.0	100.2	100.0
SCHLUMBERGER	J5S	C400015	11-25-02	100.3	100.1	99.9
SCHLUMBERGER	J5S	C400016	11-25-02	100.2	100.3	99.9
SCHLUMBERGER	J5S	C400017	11-25-02	100.3	100.0	99.7
SCHLUMBERGER	J5S	C400018	11-25-02	100.2	100.2	99.9
SCHLUMBERGER	J5S	C400019	11-25-02	100.2	100.3	100.3
SCHLUMBERGER	J5S	C400020	11-25-02	100.3	100.1	99.6
SCHLUMBERGER	J5S	C400021	11-25-02	100.0	99.9	100.0
SCHLUMBERGER	J5S	C400022	11-25-02	100.1	100.1	100.0
SCHLUMBERGER	J5S	C400023	11-25-02	100.2	100.1	100.0
SCHLUMBERGER	J5S	C400024	11-25-02	99.9	99.9	100.0
SCHLUMBERGER	J5S	C400025	11-25-02	100.0	99.9	100.0
SCHLUMBERGER	J5S	C400026	11-25-02	100.0	99.7	99.5
SCHLUMBERGER	J5S	C400027	11-25-02	100.1	100.0	99.8
SCHLUMBERGER	J5S	C400028	11-25-02	100.3	100.4	99.6
SCHLUMBERGER	J5S	C400029	11-25-02	100.2	100.0	99.9
SCHLUMBERGER	J5S	C400030	11-25-02	100.1	100.1	99.7
SCHLUMBERGER	J5S	C400031	11-25-02	100.0	99.8	99.7
SCHLUMBERGER	J5S	C400032	11-25-02	100.0	99.8	100.4

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

PAGE 299
 RUN DATE: 1/14/03
 RUN TIME: 13.26.53

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	J55	C400033	11-25-02	100.3	99.7	99.9
SCHLUMBERGER	J55	C400034	11-25-02	100.0	100.1	100.1
SCHLUMBERGER	J55	C400035	11-25-02	100.0	99.9	100.0
SCHLUMBERGER	J55	C400036	11-25-02	100.2	100.1	100.1
SCHLUMBERGER	J55	C400037	11-25-02	100.1	99.9	100.5
SCHLUMBERGER	J55	C400038	11-25-02	100.2	100.0	100.4
SCHLUMBERGER	J55	C400039	11-25-02	100.1	100.3	99.9
SCHLUMBERGER	J55	C400040	11-25-02	100.1	100.2	99.6
SCHLUMBERGER	J55	C400041	11-25-02	100.3	99.8	99.9
SCHLUMBERGER	J55	C400042	11-25-02	100.2	99.9	100.0
SCHLUMBERGER	J55	C400043	11-25-02	100.0	99.8	99.7
SCHLUMBERGER	J55	C400044	11-25-02	100.1	100.2	100.0
SCHLUMBERGER	J55	C400045	11-25-02	100.3	100.1	99.8
SCHLUMBERGER	J55	C400046	11-25-02	100.2	100.2	99.7
SCHLUMBERGER	J55	C400047	11-25-02	100.0	100.2	100.0
SCHLUMBERGER	J55	C400048	11-25-02	100.0	99.7	100.0
SCHLUMBERGER	J55	C400049	11-25-02	100.1	99.9	99.6
SCHLUMBERGER	J55	C400050	11-25-02	100.0	99.9	99.9
SCHLUMBERGER	J55	C400051	11-25-02	100.1	100.4	99.9
SCHLUMBERGER	J55	C400052	11-25-02	100.3	100.1	100.0
SCHLUMBERGER	J55	C400053	11-25-02	100.3	100.0	100.2
SCHLUMBERGER	J55	C400054	11-25-02	100.2	100.2	100.4
SCHLUMBERGER	J55	C400055	11-25-02	100.2	100.1	99.5
SCHLUMBERGER	J55	C400056	11-25-02	100.1	99.9	99.9
SCHLUMBERGER	J55	C400057	11-25-02	100.2	99.8	99.8
SCHLUMBERGER	J55	C400058	11-25-02	100.1	100.0	100.0
SCHLUMBERGER	J55	C400059	11-25-02	100.2	99.9	99.8
SCHLUMBERGER	J55	C400060	11-25-02	100.1	100.2	99.7
SCHLUMBERGER	J55	C400061	11-25-02	100.0	99.8	99.9
SCHLUMBERGER	J55	C400062	11-25-02	100.1	99.9	100.0
SCHLUMBERGER	J55	C400063	11-25-02	100.3	100.0	100.1
SCHLUMBERGER	J55	C400064	11-25-02	100.0	100.1	99.8
SCHLUMBERGER	J55	C400065	11-25-02	100.1	99.9	100.3
SCHLUMBERGER	J55	C400066	11-25-02	100.2	100.1	100.2
SCHLUMBERGER	J55	C400067	11-25-02	100.3	100.1	100.1
SCHLUMBERGER	J55	C400068	11-25-02	100.3	100.1	99.7
SCHLUMBERGER	J55	C400069	11-25-02	100.3	99.9	99.5
SCHLUMBERGER	J55	C400070	11-25-02	99.9	99.8	99.7
SCHLUMBERGER	J55	C400071	11-25-02	100.2	100.2	100.2
SCHLUMBERGER	J55	C400072	11-25-02	100.2	100.2	99.8
SCHLUMBERGER	J55	C400073	11-25-02	100.0	100.2	99.9
SCHLUMBERGER	J55	C400074	11-25-02	100.2	100.1	99.5
SCHLUMBERGER	J55	C400075	11-25-02	100.1	100.1	99.8
SCHLUMBERGER	J55	C400076	11-25-02	100.2	100.2	99.9
SCHLUMBERGER	J55	C400077	11-25-02	100.2	100.0	99.8
SCHLUMBERGER	J55	C400078	11-25-02	100.2	100.2	99.8
SCHLUMBERGER	J55	C400079	11-25-02	100.0	100.2	100.5
SCHLUMBERGER	J55	C400080	11-25-02	100.1	100.0	100.0
SCHLUMBERGER	J55	C400081	11-25-02	100.2	100.3	99.8
SCHLUMBERGER	J55	C400082	11-25-02	100.1	99.9	100.1
SCHLUMBERGER	J55	C400083	11-25-02	100.1	99.7	100.4
SCHLUMBERGER	J55				99.7	99.7

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

PAGE 300
 RUN DATE: 1/14/03
 RUN TIME: 13.26.53

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	J55	C400084	11-25-02	100.0	100.0	99.9
SCHLUMBERGER	J55	C400085	11-25-02	100.2	99.8	100.2
SCHLUMBERGER	J55	C400086	11-25-02	100.0	99.9	99.6
SCHLUMBERGER	J55	C400087	11-25-02	100.3	100.4	100.2
SCHLUMBERGER	J55	C400088	11-25-02	100.0	99.7	99.9
SCHLUMBERGER	J55	C400089	11-25-02	100.2	100.4	100.2
SCHLUMBERGER	J55	C400090	11-25-02	99.9	100.0	99.8
SCHLUMBERGER	J55	C400091	11-25-02	100.1	100.0	100.0
SCHLUMBERGER	J55	C400092	11-25-02	100.2	99.9	99.9
SCHLUMBERGER	J55	C400093	11-25-02	100.2	100.1	99.9
SCHLUMBERGER	J55	C400094	11-25-02	100.2	100.2	99.8
SCHLUMBERGER	J55	C400095	11-25-02	100.0	100.1	99.9
SCHLUMBERGER	J55	C400096	11-25-02	100.1	100.1	100.2
SCHLUMBERGER	J55	C400097	11-25-02	100.1	100.2	99.5
SCHLUMBERGER	J55	C400098	11-25-02	100.0	100.2	99.8
SCHLUMBERGER	J55	C400099	11-25-02	100.1	99.7	99.6
SCHLUMBERGER	J55	C400100	11-25-02	100.2	100.2	100.0
SCHLUMBERGER	J55	C400101	11-25-02	100.1	100.0	99.8
SCHLUMBERGER	J55	C400102	11-25-02	100.1	100.0	99.7
SCHLUMBERGER	J55	C400103	11-25-02	100.0	100.2	100.3
SCHLUMBERGER	J55	C400104	11-25-02	100.2	100.1	100.1
SCHLUMBERGER	J55	C400105	11-25-02	99.9	99.9	99.9
SCHLUMBERGER	J55	C400106	11-25-02	100.3	99.8	99.9
SCHLUMBERGER	J55	C400107	11-25-02	100.2	99.9	100.1
SCHLUMBERGER	J55	C400108	11-25-02	100.2	99.8	99.4
SCHLUMBERGER	J55	C400109	11-25-02	100.1	100.2	99.8
SCHLUMBERGER	J55	C400110	11-25-02	100.3	100.2	100.3
SCHLUMBERGER	J55	C400111	11-25-02	100.1	100.2	100.2
SCHLUMBERGER	J55	C400112	11-25-02	99.9	99.7	99.7
SCHLUMBERGER	J55	C400113	11-25-02	100.3	100.3	100.2
SCHLUMBERGER	J55	C400114	11-25-02	100.1	99.7	100.3
SCHLUMBERGER	J55	C400115	11-25-02	100.3	100.2	100.1
SCHLUMBERGER	J55	C400116	11-25-02	100.1	100.4	100.0
SCHLUMBERGER	J55	C400117	11-25-02	100.2	100.1	99.8
SCHLUMBERGER	J55	C400118	11-25-02	100.1	99.8	99.7
SCHLUMBERGER	J55	C400119	11-25-02	100.1	99.8	99.9
SCHLUMBERGER	J55	C400120	11-25-02	100.0	99.9	100.4
SCHLUMBERGER	J55	C400121	11-25-02	100.1	99.8	99.9
SCHLUMBERGER	J55	C400122	11-25-02	100.2	100.2	100.3
SCHLUMBERGER	J55	C400123	11-25-02	100.2	100.3	99.3
SCHLUMBERGER	J55	C400124	11-25-02	100.1	100.3	99.8
SCHLUMBERGER	J55	C400125	11-25-02	100.2	99.9	99.7
SCHLUMBERGER	J55	C400126	11-25-02	100.3	100.3	100.2
SCHLUMBERGER	J55	C400127	11-25-02	100.1	100.2	100.2
SCHLUMBERGER	J55	C400128	11-25-02	100.0	100.3	99.6
SCHLUMBERGER	J55	C400129	11-25-02	100.3	100.3	99.5
SCHLUMBERGER	J55	C400130	11-25-02	100.2	100.0	100.0
SCHLUMBERGER	J55	C400131	11-25-02	100.2	100.1	99.9
SCHLUMBERGER	J55	C400132	11-25-02	99.9	99.7	99.8
SCHLUMBERGER	J55	C400133	11-25-02	100.2	100.2	99.9
SCHLUMBERGER	J55	C400134	11-25-02	100.0	100.2	99.9

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

PAGE 301
 RUN DATE: 1/14/03
 RUN TIME: 13.26.53

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	J55	C400135	11-25-02	100.2	99.9	99.6
SCHLUMBERGER	J55	C400136	11-25-02	99.9	99.6	100.2
SCHLUMBERGER	J55	C400137	11-25-02	100.1	100.2	99.7
SCHLUMBERGER	J55	C400138	11-25-02	100.1	100.0	99.6
SCHLUMBERGER	J55	C400139	11-25-02	100.0	99.7	99.6
SCHLUMBERGER	J55	C400140	11-25-02	100.1	100.0	99.9
SCHLUMBERGER	J55	C400141	11-25-02	100.2	100.2	99.9
SCHLUMBERGER	J55	C400142	11-25-02	100.3	100.0	100.0
SCHLUMBERGER	J55	C400143	11-25-02	100.3	100.3	100.2
SCHLUMBERGER	J55	C400144	11-25-02	100.2	99.8	100.0
SCHLUMBERGER	J55	C400145	11-25-02	100.2	100.0	99.9
SCHLUMBERGER	J55	C400146	11-25-02	100.0	99.7	99.7
SCHLUMBERGER	J55	C400147	11-25-02	100.3	100.3	100.2
SCHLUMBERGER	J55	C400148	11-25-02	100.2	100.1	100.0
SCHLUMBERGER	J55	C400149	11-25-02	100.3	100.0	99.7
SCHLUMBERGER	J55	C400150	11-25-02	100.1	99.7	99.8
SCHLUMBERGER	J55	C400151	11-25-02	100.2	100.2	100.1
SCHLUMBERGER	J55	C400152	11-25-02	100.2	100.2	99.9
SCHLUMBERGER	J55	C400153	11-25-02	100.2	100.0	100.4
SCHLUMBERGER	J55	C400154	11-25-02	100.1	100.2	99.8
SCHLUMBERGER	J55	C400155	11-25-02	100.1	100.2	99.5
SCHLUMBERGER	J55	C400156	11-25-02	100.0	100.1	99.7
SCHLUMBERGER	J55	C400157	11-25-02	99.9	99.9	99.7
SCHLUMBERGER	J55	C400158	11-25-02	100.0	100.0	99.7
SCHLUMBERGER	J55	C400159	11-25-02	100.1	100.3	99.9
SCHLUMBERGER	J55	C400160	11-25-02	100.2	100.0	100.0
SCHLUMBERGER	J55	C400161	11-25-02	100.0	100.0	99.9
SCHLUMBERGER	J55	C400162	11-25-02	100.1	99.8	100.1
SCHLUMBERGER	J55	C400163	11-25-02	100.0	99.9	99.7
SCHLUMBERGER	J55	C400164	11-25-02	100.1	99.9	99.6
SCHLUMBERGER	J55	C400165	11-25-02	100.2	100.2	99.9
SCHLUMBERGER	J55	C400166	11-25-02	100.3	100.0	100.3
SCHLUMBERGER	J55	C400167	11-25-02	100.3	100.4	100.2
SCHLUMBERGER	J55	C400168	11-25-02	100.0	100.4	100.3
SCHLUMBERGER	J55	C400169	11-25-02	100.1	100.2	99.7
SCHLUMBERGER	J55	C400170	11-25-02	100.1	100.1	99.8
SCHLUMBERGER	J55	C400171	11-25-02	100.2	100.2	100.1
SCHLUMBERGER	J55	C400172	11-25-02	100.0	100.0	99.7
SCHLUMBERGER	J55	C400173	11-25-02	99.9	99.9	99.9
SCHLUMBERGER	J55	C400174	11-25-02	100.0	100.0	100.4
SCHLUMBERGER	J55	C400175	11-25-02	100.0	99.9	100.0
SCHLUMBERGER	J55	C400176	11-25-02	100.1	99.8	99.7
SCHLUMBERGER	J55	C400177	11-25-02	100.1	100.1	100.0
SCHLUMBERGER	J55	C400178	11-25-02	100.1	100.2	99.9
SCHLUMBERGER	J55	C400179	11-25-02	100.1	99.6	100.3
SCHLUMBERGER	J55	C400180	11-25-02	100.1	99.9	100.2
SCHLUMBERGER	J55	C400181	11-25-02	100.3	99.8	100.2
SCHLUMBERGER	J55	C400182	11-25-02	100.0	99.7	99.7
SCHLUMBERGER	J55	C400183	11-25-02	100.1	100.0	100.0
SCHLUMBERGER	J55	C400184	11-25-02	100.1	99.9	99.6
SCHLUMBERGER	J55	C400185	11-25-02	100.2	100.0	100.0

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

PAGE 302
 RUN DATE: 1/14/03
 RUN TIME: 13.26.53

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	J5S	C400186	11-25-02	100.1	99.9	99.4
SCHLUMBERGER	J5S	C400187	11-25-02	100.2	99.9	99.4
SCHLUMBERGER	J5S	C400188	11-25-02	100.2	100.3	99.7
SCHLUMBERGER	J5S	C400189	11-25-02	100.1	100.3	100.1
SCHLUMBERGER	J5S	C400190	11-25-02	100.1	100.0	100.2
SCHLUMBERGER	J5S	C400191	11-25-02	100.2	100.1	99.8
SCHLUMBERGER	J5S	C400192	11-25-02	100.0	99.7	99.9
SCHLUMBERGER	J5S	C400193	11-25-02	100.1	99.9	100.0
SCHLUMBERGER	J5S	C400194	11-25-02	100.0	99.9	99.9
SCHLUMBERGER	J5S	C400195	11-25-02	100.3	100.2	99.6
SCHLUMBERGER	J5S	C400196	11-25-02	100.2	99.7	99.6
SCHLUMBERGER	J5S	C400197	11-25-02	100.3	100.1	99.5
SCHLUMBERGER	J5S	C400198	11-25-02	100.0	100.1	99.8
SCHLUMBERGER	J5S	C400199	11-25-02	100.2	100.0	99.5
SCHLUMBERGER	J5S	C400200	11-25-02	100.2	100.3	99.9
SCHLUMBERGER	J5S	C400201	11-25-02	100.0	99.9	99.6
SCHLUMBERGER	J5S	C400202	11-25-02	100.2	99.7	99.7
SCHLUMBERGER	J5S	C400203	11-25-02	100.1	100.1	100.0
SCHLUMBERGER	J5S	C400204	11-25-02	100.1	99.9	100.0
SCHLUMBERGER	J5S	C400205	11-25-02	100.0	100.1	100.1
SCHLUMBERGER	J5S	C400206	11-25-02	100.1	100.0	100.0
SCHLUMBERGER	J5S	C400207	11-25-02	100.2	99.8	100.3
SCHLUMBERGER	J5S	C400208	11-25-02	100.1	100.0	99.7
SCHLUMBERGER	J5S	C400209	11-25-02	100.1	99.9	100.0
SCHLUMBERGER	J5S	C400210	11-25-02	100.0	100.0	99.5
SCHLUMBERGER	J5S	C400211	11-25-02	100.1	100.2	100.2
SCHLUMBERGER	J5S	C400212	11-25-02	100.3	100.4	100.4
SCHLUMBERGER	J5S	C400213	11-25-02	100.0	100.2	99.9
SCHLUMBERGER	J5S	C400214	11-25-02	100.2	99.9	99.7
SCHLUMBERGER	J5S	C400215	11-25-02	100.1	99.8	99.9
SCHLUMBERGER	J5S	C400216	11-25-02	100.2	100.1	100.1
SCHLUMBERGER	J5S	C400217	11-25-02	100.3	99.9	99.8
SCHLUMBERGER	J5S	C400218	11-25-02	99.9	99.9	100.3
SCHLUMBERGER	J5S	C400219	11-25-02	99.9	99.9	99.6
SCHLUMBERGER	J5S	C400220	11-25-02	100.3	100.1	100.0
SCHLUMBERGER	J5S	C400221	11-25-02	100.1	99.8	100.1
SCHLUMBERGER	J5S	C400222	11-25-02	100.1	99.7	100.2
SCHLUMBERGER	J5S	C400223	11-25-02	100.1	99.7	99.9
SCHLUMBERGER	J5S	C400224	11-25-02	100.2	100.2	100.4
SCHLUMBERGER	J5S	C400225	11-25-02	100.2	99.8	99.3
SCHLUMBERGER	J5S	C400226	11-25-02	100.3	99.8	99.9
SCHLUMBERGER	J5S	C400227	11-25-02	100.2	100.2	99.9
SCHLUMBERGER	J5S	C400228	11-25-02	100.2	100.2	100.1
SCHLUMBERGER	J5S	C400229	11-25-02	100.0	99.8	99.6
SCHLUMBERGER	J5S	C400230	11-25-02	100.1	99.9	100.0
SCHLUMBERGER	J5S	C400231	11-25-02	100.0	99.7	99.8
SCHLUMBERGER	J5S	C400232	11-25-02	100.0	99.8	99.8
SCHLUMBERGER	J5S	C400233	11-25-02	100.1	100.0	100.0
SCHLUMBERGER	J5S	C400234	11-25-02	100.1	100.0	99.8
SCHLUMBERGER	J5S	C400235	11-25-02	100.2	100.1	100.2
SCHLUMBERGER	J5S	C400236	11-25-02	100.2	100.0	99.7
SCHLUMBERGER	J5S	C400236	11-25-02	100.2	100.2	100.2

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

PAGE 303
 RUN DATE: 1/14/03
 RUN TIME: 13.26.53

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	J5S	C400237	11-25-02	100.2	100.2	100.3
SCHLUMBERGER	J5S	C400238	11-25-02	100.1	100.0	100.4
SCHLUMBERGER	J5S	C400239	11-25-02	99.9	99.6	99.7
SCHLUMBERGER	J5S	C400240	11-25-02	100.2	100.0	99.9
SCHLUMBERGER	J5S	C400241	11-25-02	100.2	99.7	99.9
SCHLUMBERGER	J5S	C400242	11-25-02	100.3	99.9	100.0
SCHLUMBERGER	J5S	C400243	11-25-02	100.1	99.8	100.1
SCHLUMBERGER	J5S	C400244	11-25-02	99.9	99.9	99.7
SCHLUMBERGER	J5S	C400245	11-25-02	100.3	100.2	100.4
SCHLUMBERGER	J5S	C400246	11-25-02	100.2	99.7	99.7
SCHLUMBERGER	J5S	C400247	11-25-02	100.2	100.1	99.8
SCHLUMBERGER	J5S	C400248	11-25-02	100.2	100.1	100.2
SCHLUMBERGER	J5S	C400249	11-25-02	100.1	100.2	99.9
SCHLUMBERGER	J5S	C400250	11-25-02	100.0	100.2	100.0
SCHLUMBERGER	J5S	C400251	11-25-02	100.0	99.9	99.5
SCHLUMBERGER	J5S	C400252	11-25-02	100.2	100.3	99.7
SCHLUMBERGER	J5S	C400253	11-25-02	100.3	100.2	100.1
SCHLUMBERGER	J5S	C400254	11-25-02	100.0	99.8	99.7
SCHLUMBERGER	J5S	C400255	11-25-02	100.2	99.8	100.2
SCHLUMBERGER	J5S	C400256	11-25-02	100.0	100.0	100.0
SCHLUMBERGER	J5S	C400257	11-25-02	100.1	100.1	99.6
SCHLUMBERGER	J5S	C400258	11-25-02	100.2	100.0	99.8
SCHLUMBERGER	J5S	C400259	11-25-02	100.1	100.1	99.8
SCHLUMBERGER	J5S	C400260	11-25-02	100.3	100.1	100.2
SCHLUMBERGER	J5S	C400261	11-25-02	100.1	99.9	100.1
SCHLUMBERGER	J5S	C400262	11-25-02	99.8	100.2	99.7
SCHLUMBERGER	J5S	C400263	11-25-02	100.3	99.7	100.4
SCHLUMBERGER	J5S	C400264	11-25-02	99.9	99.9	99.6
SCHLUMBERGER	J5S	C400265	11-25-02	100.1	100.1	99.7
SCHLUMBERGER	J5S	C400266	11-25-02	100.0	100.1	99.7
SCHLUMBERGER	J5S	C400267	11-25-02	100.3	100.0	100.0
SCHLUMBERGER	J5S	C400268	11-25-02	100.3	100.0	100.1
SCHLUMBERGER	J5S	C400269	11-25-02	100.1	100.3	99.6
SCHLUMBERGER	J5S	C400270	11-25-02	99.8	99.9	100.1
SCHLUMBERGER	J5S	C400271	11-25-02	100.1	100.1	99.6
SCHLUMBERGER	J5S	C400272	11-25-02	100.2	100.0	99.9
SCHLUMBERGER	J5S	C400273	11-25-02	100.2	100.2	99.6
SCHLUMBERGER	J5S	C400274	11-25-02	100.0	99.7	100.1
SCHLUMBERGER	J5S	C400275	11-25-02	100.3	100.4	99.6
SCHLUMBERGER	J5S	C400276	11-25-02	100.3	100.1	99.5
SCHLUMBERGER	J5S	C400277	11-25-02	100.0	100.1	99.9
SCHLUMBERGER	J5S	C400278	11-25-02	100.1	99.9	99.7
SCHLUMBERGER	J5S	C400279	11-25-02	100.1	100.0	99.5
SCHLUMBERGER	J5S	C400280	11-25-02	100.2	100.3	99.6
SCHLUMBERGER	J5S	C400281	11-25-02	100.1	100.3	100.1
SCHLUMBERGER	J5S	C400282	11-25-02	100.3	100.2	99.9
SCHLUMBERGER	J5S	C400283	11-25-02	100.1	100.3	99.8
SCHLUMBERGER	J5S	C400284	11-25-02	100.1	100.3	100.4
SCHLUMBERGER	J5S	C400285	11-25-02	100.2	99.9	99.9
SCHLUMBERGER	J5S	C400286	11-25-02	100.0	100.4	100.1
SCHLUMBERGER	J5S	C400287	11-25-02	100.3	99.8	100.1
SCHLUMBERGER	J5S	C400288	11-25-02	100.0	100.0	100.1

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

PAGE 304
 RUN DATE: 1/14/03
 RUN TIME: 13.26.53

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	J5S	C400288	11-25-02	100.1	99.8	99.5
SCHLUMBERGER	J5S	C400289	11-25-02	100.2	100.1	100.2
SCHLUMBERGER	J5S	C400290	11-25-02	100.2	100.4	100.1
SCHLUMBERGER	J5S	C400291	11-25-02	100.2	100.0	99.8
SCHLUMBERGER	J5S	C400292	11-25-02	100.0	99.9	99.7
SCHLUMBERGER	J5S	C400293	11-25-02	100.0	99.9	100.2
SCHLUMBERGER	J5S	C400294	11-25-02	100.1	99.9	99.8
SCHLUMBERGER	J5S	C400295	11-25-02	100.0	100.3	99.8
SCHLUMBERGER	J5S	C400296	11-25-02	99.9	99.7	99.8
SCHLUMBERGER	J5S	C400297	11-25-02	100.1	99.9	100.3
SCHLUMBERGER	J5S	C400298	11-25-02	100.2	99.9	99.9
SCHLUMBERGER	J5S	C400299	11-25-02	100.2	99.9	99.5
SCHLUMBERGER	J5S	C400300	11-25-02	100.1	99.9	99.6
SCHLUMBERGER	J5S	C400301	11-25-02	100.1	100.0	100.1
SCHLUMBERGER	J5S	C400302	11-25-02	100.1	99.8	99.7
SCHLUMBERGER	J5S	C400303	11-25-02	100.0	100.1	99.6
SCHLUMBERGER	J5S	C400304	11-25-02	100.0	99.9	99.9
SCHLUMBERGER	J5S	C400305	11-25-02	100.2	99.8	99.7
SCHLUMBERGER	J5S	C400306	11-25-02	100.2	100.0	99.7
SCHLUMBERGER	J5S	C400307	11-25-02	100.1	100.0	99.6
SCHLUMBERGER	J5S	C400308	11-25-02	100.2	100.2	100.0
SCHLUMBERGER	J5S	C400309	11-25-02	100.2	99.9	99.7
SCHLUMBERGER	J5S	C400310	11-25-02	100.0	99.7	99.7
SCHLUMBERGER	J5S	C400311	11-25-02	100.1	99.8	99.9
SCHLUMBERGER	J5S	C400312	11-25-02	100.2	99.8	99.9
SCHLUMBERGER	J5S	C400313	11-25-02	99.9	99.8	99.9
SCHLUMBERGER	J5S	C400314	11-25-02	99.9	100.0	99.9
SCHLUMBERGER	J5S	C400315	11-25-02	100.2	100.2	100.4
SCHLUMBERGER	J5S	C400316	11-25-02	99.8	99.7	99.5
SCHLUMBERGER	J5S	C400317	11-25-02	100.0	100.0	99.8
SCHLUMBERGER	J5S	C400318	11-25-02	100.2	100.1	100.0
SCHLUMBERGER	J5S	C400319	11-25-02	100.3	99.9	99.4
SCHLUMBERGER	J5S	C400320	11-25-02	99.9	99.7	99.8
SCHLUMBERGER	J5S	C400321	11-25-02	99.9	99.8	99.7
SCHLUMBERGER	J5S	C400322	11-25-02	100.0	99.8	100.1
SCHLUMBERGER	J5S	C400323	11-25-02	100.0	99.7	99.8
SCHLUMBERGER	J5S	C400324	11-25-02	100.2	100.1	100.2
SCHLUMBERGER	J5S	C400325	11-25-02	100.0	100.1	100.0
SCHLUMBERGER	J5S	C400326	11-25-02	100.0	99.8	99.5
SCHLUMBERGER	J5S	C400327	11-25-02	100.2	100.4	99.8
SCHLUMBERGER	J5S	C400328	11-25-02	100.1	100.0	100.1
SCHLUMBERGER	J5S	C400329	11-25-02	100.0	100.2	99.9
SCHLUMBERGER	J5S	C400330	11-25-02	100.3	100.2	100.2
SCHLUMBERGER	J5S	C400331	11-25-02	100.2	99.9	100.0
SCHLUMBERGER	J5S	C400332	11-25-02	99.9	99.9	99.8
SCHLUMBERGER	J5S	C400333	11-25-02	100.1	99.9	100.2
SCHLUMBERGER	J5S	C400334	11-25-02	100.1	100.0	99.8
SCHLUMBERGER	J5S	C400335	11-25-02	99.9	99.7	99.7
SCHLUMBERGER	J5S	C400336	11-25-02	99.9	99.9	99.7
SCHLUMBERGER	J5S	C400337	11-25-02	100.0	100.2	99.4
SCHLUMBERGER	J5S	C400338	11-25-02	100.0	100.0	99.6

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

PAGE 305
 RUN DATE: 1/14/03
 RUN TIME: 13.26.53

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	J55	C400339	11-25-02	100.0	99.9	100.4
SCHLUMBERGER	J55	C400340	11-25-02	100.1	100.0	100.2
SCHLUMBERGER	J55	C400341	11-25-02	100.0	100.0	100.6
SCHLUMBERGER	J55	C400342	11-25-02	100.0	99.8	99.7
SCHLUMBERGER	J55	C400343	11-25-02	100.0	99.9	99.7
SCHLUMBERGER	J55	C400344	11-25-02	100.0	99.8	100.2
SCHLUMBERGER	J55	C400345	11-25-02	100.0	100.1	100.1
SCHLUMBERGER	J55	C400346	11-25-02	100.0	99.6	99.6
SCHLUMBERGER	J55	C400347	11-25-02	100.0	100.0	99.8
SCHLUMBERGER	J55	C401349	12-19-02	100.0	99.7	99.6
SCHLUMBERGER	J55	C401350	12-19-02	100.0	99.7	99.5
SCHLUMBERGER	J55	C401351	12-19-02	100.0	99.8	99.6
SCHLUMBERGER	J55	C401352	12-19-02	100.1	99.8	99.7
SCHLUMBERGER	J55	C401353	12-19-02	100.0	99.8	99.7
SCHLUMBERGER	J55	C401354	12-19-02	100.1	100.0	99.9
SCHLUMBERGER	J55	C401355	12-19-02	100.0	99.9	100.1
SCHLUMBERGER	J55	C401356	12-19-02	100.1	100.1	99.7
SCHLUMBERGER	J55	C401357	12-19-02	100.1	100.1	100.1
SCHLUMBERGER	J55	C401358	12-19-02	100.1	99.8	100.2
SCHLUMBERGER	J55	C401359	12-19-02	100.1	100.0	100.4
SCHLUMBERGER	J55	C401360	12-19-02	100.0	99.9	99.9
SCHLUMBERGER	J55	C401361	12-19-02	100.2	99.8	100.3
SCHLUMBERGER	J55	C401362	12-19-02	100.1	99.6	99.7
SCHLUMBERGER	J55	C401363	12-19-02	100.2	100.2	100.0
SCHLUMBERGER	J55	C401364	12-19-02	100.0	99.9	100.0
SCHLUMBERGER	J55	C401365	12-19-02	100.1	99.7	100.0
SCHLUMBERGER	J55	C401366	12-19-02	100.2	100.0	100.0
SCHLUMBERGER	J55	C401367	12-19-02	100.0	99.8	100.0
SCHLUMBERGER	J55	C401368	12-19-02	100.1	100.0	99.9
SCHLUMBERGER	J55	C401369	12-19-02	99.8	99.6	99.4
SCHLUMBERGER	J55	C401370	12-19-02	100.1	100.0	99.7
SCHLUMBERGER	J55	C401371	12-19-02	100.1	99.8	100.0
SCHLUMBERGER	J55	C401372	12-19-02	100.1	99.9	100.2
SCHLUMBERGER	J55	C401373	12-19-02	100.2	99.9	100.1
SCHLUMBERGER	J55	C401374	12-19-02	99.9	99.8	99.9
SCHLUMBERGER	J55	C401375	12-19-02	100.0	99.9	100.2
SCHLUMBERGER	J55	C401376	12-19-02	100.0	99.7	99.6
SCHLUMBERGER	J55	C401377	12-19-02	99.9	99.9	99.6
SCHLUMBERGER	J55	C401378	12-19-02	100.0	99.8	99.7
SCHLUMBERGER	J55	C401379	12-19-02	100.1	99.8	100.2
SCHLUMBERGER	J55	C401380	12-19-02	100.1	99.9	99.9
SCHLUMBERGER	J55	C401381	12-19-02	100.2	100.0	100.2
SCHLUMBERGER	J55	C401382	12-19-02	100.1	100.0	100.0
SCHLUMBERGER	J55	C401383	12-19-02	99.9	99.7	99.4
SCHLUMBERGER	J55	C401384	12-19-02	100.0	99.7	100.0
SCHLUMBERGER	J55	C401385	12-19-02	100.0	99.8	99.7
SCHLUMBERGER	J55	C401386	12-19-02	100.0	99.8	99.9
SCHLUMBERGER	J55	C401387	12-19-02	100.0	99.9	99.9
SCHLUMBERGER	J55	C401388	12-19-02	100.1	100.0	99.7
SCHLUMBERGER	J55	C401389	12-19-02	100.0	99.6	99.3
SCHLUMBERGER	J55	C401390	12-19-02	100.1	100.0	100.1

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

PAGE 306
 RUN DATE: 1/14/03
 RUN TIME: 13.26.53

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	J55	C401391	12-19-02	99.8	99.9	99.6
SCHLUMBERGER	J55	C401392	12-19-02	100.2	100.0	99.8
SCHLUMBERGER	J55	C401393	12-19-02	100.0	99.9	100.0
SCHLUMBERGER	J55	C401394	12-19-02	100.1	100.0	99.8
SCHLUMBERGER	J55	C401395	12-19-02	100.3	100.1	99.9
SCHLUMBERGER	J55	C401396	12-19-02	99.9	100.1	100.1
SCHLUMBERGER	J55	C401397	12-19-02	99.9	99.9	99.5
SCHLUMBERGER	J55	C401398	12-19-02	100.2	99.9	100.1
SCHLUMBERGER	J55	C401399	12-19-02	100.0	100.0	100.0
SCHLUMBERGER	J55	C401400	12-19-02	100.0	99.8	99.9
SCHLUMBERGER	J55	C401401	12-19-02	100.1	100.1	99.9
SCHLUMBERGER	J55	C401402	12-19-02	99.9	100.1	99.9
SCHLUMBERGER	J55	C401403	12-19-02	99.9	100.3	99.6
SCHLUMBERGER	J55	C401404	12-19-02	100.2	100.1	100.0
SCHLUMBERGER	J55	C401405	12-19-02	99.9	99.8	99.8
SCHLUMBERGER	J55	C401406	12-19-02	100.1	99.8	100.0
SCHLUMBERGER	J55	C401407	12-19-02	100.0	100.2	99.8
SCHLUMBERGER	J55	C401408	12-19-02	100.0	99.7	100.1
SCHLUMBERGER	J55	C401409	12-19-02	100.1	99.6	99.8
SCHLUMBERGER	J55	C401410	12-19-02	100.1	99.7	99.8
SCHLUMBERGER	J55	C401411	12-19-02	100.1	99.7	99.8
SCHLUMBERGER	J55	C401412	12-19-02	100.1	100.0	100.1
SCHLUMBERGER	J55	C401413	12-19-02	100.0	99.7	99.8
SCHLUMBERGER	J55	C401414	12-19-02	100.1	99.8	99.6
SCHLUMBERGER	J55	C401415	12-19-02	100.1	100.0	100.5
SCHLUMBERGER	J55	C401416	12-19-02	100.1	100.0	100.2
SCHLUMBERGER	J55	C401417	12-19-02	100.1	100.1	99.8
SCHLUMBERGER	J55	C401418	12-19-02	100.3	99.8	100.1
SCHLUMBERGER	J55	C401419	12-19-02	100.2	100.2	99.8
SCHLUMBERGER	J55	C401420	12-19-02	99.9	100.0	99.8
SCHLUMBERGER	J55	C401421	12-19-02	100.1	100.4	99.3
SCHLUMBERGER	J55	C401422	12-19-02	100.1	100.0	99.8
SCHLUMBERGER	J55	C401423	12-19-02	100.2	100.0	100.2
SCHLUMBERGER	J55	C401424	12-19-02	100.1	99.7	100.0
SCHLUMBERGER	J55	C401425	12-19-02	99.9	100.1	100.3
SCHLUMBERGER	J55	C401426	12-19-02	100.2	100.2	99.9
SCHLUMBERGER	J55	C401427	12-19-02	100.2	100.1	100.2
SCHLUMBERGER	J55	C401428	12-19-02	100.1	99.8	100.1
SCHLUMBERGER	J55	C401429	12-19-02	100.1	100.0	99.8
SCHLUMBERGER	J55	C401430	12-19-02	100.1	99.9	99.7
SCHLUMBERGER	J55	C401431	12-19-02	100.0	99.8	99.5
SCHLUMBERGER	J55	C401432	12-19-02	100.0	99.8	99.7
SCHLUMBERGER	J55	C401433	12-19-02	100.3	100.4	99.3
SCHLUMBERGER	J55	C401434	12-19-02	100.3	100.1	99.7
SCHLUMBERGER	J55	C401435	12-19-02	100.3	99.7	99.8
SCHLUMBERGER	J55	C401436	12-19-02	99.8	99.7	99.3
SCHLUMBERGER	J55	C401437	12-19-02	100.1	99.9	100.3
SCHLUMBERGER	J55	C401438	12-19-02	100.1	99.7	99.9
SCHLUMBERGER	J55	C401439	12-19-02	100.1	99.9	99.8
SCHLUMBERGER	J55	C401440	12-19-02	100.0	100.1	99.3
SCHLUMBERGER	J55	C401441	12-19-02	100.0	99.6	99.7

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	J55	C401442	12-19-02	100.1	99.9	100.3
SCHLUMBERGER	J55	C401443	12-19-02	100.2	99.8	99.6
SCHLUMBERGER	J55	C401444	12-19-02	100.0	99.7	100.0
SCHLUMBERGER	J55	C401445	12-19-02	100.0	99.9	99.9
SCHLUMBERGER	J55	C401446	12-19-02	99.9	99.9	99.8
SCHLUMBERGER	J55	C401447	12-19-02	100.1	100.1	99.8
SCHLUMBERGER	J55	C401448	12-19-02	100.0	99.7	99.8
SCHLUMBERGER	J55	C401449	12-19-02	100.0	99.7	99.9
SCHLUMBERGER	J55	C401450	12-19-02	100.1	99.8	100.1
SCHLUMBERGER	J55	C401451	12-19-02	99.9	99.6	99.8
SCHLUMBERGER	J55	C401452	12-19-02	100.1	99.9	100.0
SCHLUMBERGER	J55	C401453	12-19-02	100.0	99.9	100.0
SCHLUMBERGER	J55	C401454	12-19-02	100.0	99.6	99.7
SCHLUMBERGER	J55	C401455	12-19-02	99.9	99.6	99.6
SCHLUMBERGER	J55	C401456	12-19-02	99.9	100.0	100.1
SCHLUMBERGER	J55	C401457	12-19-02	100.0	99.9	99.6
SCHLUMBERGER	J55	C401458	12-19-02	99.9	100.3	99.3
SCHLUMBERGER	J55	C401459	12-19-02	99.8	99.6	99.5
SCHLUMBERGER	J55	C401460	12-19-02	99.9	100.0	99.5
SCHLUMBERGER	J55	C401461	12-19-02	100.1	100.0	99.8
SCHLUMBERGER	J55	C401462	12-19-02	100.1	100.0	100.0
SCHLUMBERGER	J55	C401463	12-19-02	100.2	100.2	100.0
SCHLUMBERGER	J55	C401464	12-19-02	100.2	100.0	100.2
SCHLUMBERGER	J55	C401465	12-19-02	100.1	100.0	99.7
SCHLUMBERGER	J55	C401466	12-19-02	100.2	99.8	99.9
SCHLUMBERGER	J55	C401467	12-19-02	99.8	99.7	100.2
SCHLUMBERGER	J55	C401468	12-19-02	100.0	99.6	99.6
SCHLUMBERGER	J55	C401469	12-19-02	100.0	99.7	99.5
SCHLUMBERGER	J55	C401470	12-19-02	100.3	99.8	99.4
SCHLUMBERGER	J55	C401471	12-19-02	100.1	99.9	99.9
SCHLUMBERGER	J55	C401472	12-19-02	100.3	100.4	100.0
SCHLUMBERGER	J55	C401473	12-19-02	100.1	99.8	100.3
SCHLUMBERGER	J55	C401474	12-19-02	99.9	99.9	99.7
SCHLUMBERGER	J55	C401475	12-19-02	100.2	100.0	99.9
SCHLUMBERGER	J55	C401476	12-19-02	100.0	99.8	99.4
SCHLUMBERGER	J55	C401477	12-19-02	100.0	99.9	99.7
SCHLUMBERGER	J55	C401478	12-19-02	100.1	99.9	99.4
SCHLUMBERGER	J55	C401479	12-19-02	100.1	99.9	100.0
SCHLUMBERGER	J55	C401480	12-19-02	100.3	99.8	99.9
SCHLUMBERGER	J55	C401481	12-19-02	100.0	100.0	99.9
SCHLUMBERGER	J55	C401482	12-19-02	100.2	100.2	99.6
SCHLUMBERGER	J55	C401483	12-19-02	100.2	100.2	99.3
SCHLUMBERGER	J55	C401484	12-19-02	99.8	100.1	99.6
SCHLUMBERGER	J55	C401485	12-19-02	100.0	99.6	99.8
SCHLUMBERGER	J55	C401486	12-19-02	100.1	100.2	100.0
SCHLUMBERGER	J55	C401487	12-19-02	99.9	99.8	99.6
SCHLUMBERGER	J55	C401488	12-19-02	100.0	99.6	100.1
SCHLUMBERGER	J55	C401489	12-19-02	100.0	100.0	99.7
SCHLUMBERGER	J55	C401490	12-19-02	100.1	100.1	99.8
SCHLUMBERGER	J55	C401491	12-19-02	100.0	99.6	99.8
SCHLUMBERGER	J55	C401492	12-19-02	99.9	99.8	99.5

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

PAGE 308
 RUN DATE: 1/14/03
 RUN TIME: 13.26.53

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	J5S	C401493	12-19-02	100.2	100.1	100.1
SCHLUMBERGER	J5S	C401494	12-19-02	100.0	100.0	100.0
SCHLUMBERGER	J5S	C401495	12-19-02	99.9	100.0	99.8
SCHLUMBERGER	J5S	C401496	12-19-02	100.2	100.0	100.0
SCHLUMBERGER	J5S	C401497	12-19-02	99.9	99.7	99.9
SCHLUMBERGER	J5S	C401498	12-19-02	100.1	100.2	100.1
SCHLUMBERGER	J5S	C401499	12-19-02	100.0	100.0	99.8
SCHLUMBERGER	J5S	C401500	12-19-02	100.2	99.9	100.1
SCHLUMBERGER	J5S	C401501	12-19-02	100.3	100.0	100.3
SCHLUMBERGER	J5S	C401502	12-19-02	100.3	99.7	99.9
SCHLUMBERGER	J5S	C401503	12-19-02	100.0	100.0	99.8
SCHLUMBERGER	J5S	C401504	12-19-02	100.1	99.9	99.9
SCHLUMBERGER	J5S	C401505	12-19-02	100.1	100.3	100.0
SCHLUMBERGER	J5S	C401506	12-19-02	100.1	99.7	99.7
SCHLUMBERGER	J5S	C401507	12-19-02	100.2	99.8	100.2
SCHLUMBERGER	J5S	C401508	12-19-02	99.9	99.9	99.8
SCHLUMBERGER	J5S	C401509	12-19-02	100.0	99.9	99.8
SCHLUMBERGER	J5S	C401510	12-19-02	100.3	99.9	99.6
SCHLUMBERGER	J5S	C401511	12-19-02	100.0	99.7	99.9
SCHLUMBERGER	J5S	C401512	12-19-02	100.2	100.0	100.0
SCHLUMBERGER	J5S	C401513	12-19-02	100.2	100.0	100.3
SCHLUMBERGER	J5S	C401514	12-19-02	100.1	100.1	99.6
SCHLUMBERGER	J5S	C401515	12-19-02	100.1	99.9	99.7
SCHLUMBERGER	J5S	C401516	12-19-02	100.1	99.8	99.9
SCHLUMBERGER	J5S	C401517	12-19-02	100.3	100.0	100.3
SCHLUMBERGER	J5S	C401518	12-19-02	100.0	99.9	100.2
SCHLUMBERGER	J5S	C401519	12-19-02	100.0	99.6	99.7
SCHLUMBERGER	J5S	C401520	12-19-02	100.1	99.7	99.9
SCHLUMBERGER	J5S	C401521	12-19-02	100.1	100.0	100.2
SCHLUMBERGER	J5S	C401522	12-19-02	100.0	100.3	99.4
SCHLUMBERGER	J5S	C401523	12-19-02	99.9	99.9	99.9
SCHLUMBERGER	J5S	C401524	12-19-02	100.1	99.7	100.0
SCHLUMBERGER	J5S	C401525	12-19-02	100.1	99.7	99.8
SCHLUMBERGER	J5S	C401526	12-19-02	100.0	100.2	99.5
SCHLUMBERGER	J5S	C401527	12-19-02	100.1	99.6	100.1
SCHLUMBERGER	J5S	C401528	12-19-02	100.1	100.5	100.6
SCHLUMBERGER	J5S	C401529	12-19-02	99.9	99.9	99.9
SCHLUMBERGER	J5S	C401530	12-19-02	100.1	100.0	99.9
SCHLUMBERGER	J5S	C401531	12-19-02	100.0	99.7	99.7
SCHLUMBERGER	J5S	C401532	12-19-02	100.0	100.0	99.7
SCHLUMBERGER	J5S	C401533	12-19-02	100.0	99.8	99.9
SCHLUMBERGER	J5S	C401534	12-19-02	100.0	99.8	99.7
SCHLUMBERGER	J5S	C401535	12-19-02	100.0	100.0	100.0
SCHLUMBERGER	J5S	C401536	12-19-02	99.9	99.7	99.8
SCHLUMBERGER	J5S	C401537	12-19-02	100.1	100.1	100.1
SCHLUMBERGER	J5S	C401538	12-19-02	100.0	99.7	99.8
SCHLUMBERGER	J5S	C401539	12-19-02	100.1	99.6	99.8
SCHLUMBERGER	J5S	C401540	12-19-02	100.0	99.9	99.9
SCHLUMBERGER	J5S	D078916	10-01-02	100.0	100.0	99.6
SCHLUMBERGER	J5S	D078917	10-01-02	100.0	100.2	99.8
SCHLUMBERGER	J5S	D078918	10-01-02	100.0	99.7	99.8

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

PAGE 309
 RUN DATE: 1/14/03
 RUN TIME: 13.26.53

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	J55	D078919	10-01-02	99.9	100.3	99.7
SCHLUMBERGER	J55	D078920	10-01-02	100.0	99.8	99.8
SCHLUMBERGER	J55	D078921	10-01-02	99.9	100.3	99.8
SCHLUMBERGER	J55	D078922	10-01-02	100.0	99.8	99.8
SCHLUMBERGER	J55	D078923	10-01-02	99.8	100.2	99.6
SCHLUMBERGER	J55	D078924	10-01-02	100.0	100.0	99.5
SCHLUMBERGER	J55	D078925	10-01-02	100.1	99.9	99.9
SCHLUMBERGER	J55	D078926	10-01-02	100.3	99.7	99.8
SCHLUMBERGER	J55	D078927	10-01-02	100.1	99.7	99.8
SCHLUMBERGER	J55	D078928	10-01-02	100.0	99.8	99.4
SCHLUMBERGER	J55	D078929	10-01-02	100.1	99.7	99.7
SCHLUMBERGER	J55	D078930	10-01-02	100.0	100.1	99.4
SCHLUMBERGER	J55	D078931	10-01-02	100.2	99.7	99.8
SCHLUMBERGER	J55	D078932	10-01-02	100.1	100.1	100.0
SCHLUMBERGER	J55	D078933	10-01-02	99.9	99.8	99.9
SCHLUMBERGER	J55	D078934	10-01-02	100.0	100.2	99.8
SCHLUMBERGER	J55	D078935	10-01-02	100.3	99.9	100.1
SCHLUMBERGER	J55	D078936	10-01-02	100.2	100.2	99.4
SCHLUMBERGER	J55	D078937	10-01-02	100.0	99.7	100.1
SCHLUMBERGER	J55	D078938	10-01-02	100.3	99.6	99.6
SCHLUMBERGER	J55	D078939	10-01-02	100.3	99.8	99.6
SCHLUMBERGER	J55	D078940	10-01-02	100.0	100.0	99.5
SCHLUMBERGER	J55	D078941	10-01-02	100.1	99.8	100.1
SCHLUMBERGER	J55	D078942	10-01-02	100.0	99.7	99.5
SCHLUMBERGER	J55	D078943	10-01-02	100.1	99.9	99.6
SCHLUMBERGER	J55	D078944	10-01-02	99.9	100.0	99.9
SCHLUMBERGER	J55	D078945	10-01-02	100.1	99.8	99.9
SCHLUMBERGER	J55	D078946	10-01-02	100.3	99.9	99.5
SCHLUMBERGER	J55	D078947	10-01-02	100.1	99.9	100.1
SCHLUMBERGER	J55	D078948	10-01-02	99.9	99.8	99.5
SCHLUMBERGER	J55	D078949	10-01-02	99.9	100.3	99.9
SCHLUMBERGER	J55	D078950	10-01-02	100.1	100.0	99.6
SCHLUMBERGER	J55	D078951	10-01-02	100.1	99.6	100.0
SCHLUMBERGER	J55	D078952	10-01-02	99.9	99.8	99.6
SCHLUMBERGER	J55	D078953	10-01-02	100.1	99.7	100.2
SCHLUMBERGER	J55	D078954	10-01-02	99.8	99.6	99.7
SCHLUMBERGER	J55	D078955	10-01-02	100.3	99.8	99.5
SCHLUMBERGER	J55	D078956	10-01-02	100.0	100.2	99.7
SCHLUMBERGER	J55	D078957	10-01-02	100.1	100.0	100.2
SCHLUMBERGER	J55	D078958	10-01-02	100.0	99.8	99.6
SCHLUMBERGER	J55	D078959	10-01-02	100.1	99.6	99.8
SCHLUMBERGER	J55	D078960	10-01-02	100.2	99.9	99.9
SCHLUMBERGER	J55	D078961	10-01-02	100.1	99.6	99.6
SCHLUMBERGER	J55	D078962	10-01-02	100.1	99.8	99.5
SCHLUMBERGER	J55	D078963	10-01-02	100.0	99.7	99.6
SCHLUMBERGER	J55	D078964	10-01-02	100.0	99.8	99.6
SCHLUMBERGER	J55	D078965	10-01-02	100.0	100.0	99.6
SCHLUMBERGER	J55	D078966	10-01-02	100.2	99.6	100.0
SCHLUMBERGER	J55	D078967	10-01-02	100.0	99.9	100.2
SCHLUMBERGER	J55	D078968	10-01-02	99.9	99.9	99.4
SCHLUMBERGER	J55	D078969	10-01-02	100.0	99.8	100.0

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

PAGE 310
 RUN DATE: 1/14/03
 RUN TIME: 13.26.53

MANUFACTURER	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	D078970	10-01-02	99.9	100.0	99.6
SCHLUMBERGER	D078971	10-01-02	99.9	100.1	100.2
SCHLUMBERGER	D078972	10-01-02	99.9	99.8	99.8
SCHLUMBERGER	D078973	10-01-02	99.9	100.3	99.6
SCHLUMBERGER	D078974	10-01-02	99.9	99.6	100.1
SCHLUMBERGER	D078975	10-01-02	100.1	99.6	99.5
SCHLUMBERGER	D078976	10-01-02	100.1	100.2	99.9
SCHLUMBERGER	D078977	10-01-02	100.1	100.1	100.6
SCHLUMBERGER	D078978	10-01-02	99.9	99.7	100.2
SCHLUMBERGER	D078979	10-01-02	100.0	99.9	100.0
SCHLUMBERGER	D078980	10-01-02	100.2	99.9	99.7
SCHLUMBERGER	D078981	10-01-02	99.9	99.9	99.5
SCHLUMBERGER	D078982	10-01-02	100.1	99.8	100.0
SCHLUMBERGER	D078983	10-01-02	100.0	99.8	100.1
SCHLUMBERGER	D078984	10-01-02	99.9	99.9	99.3
SCHLUMBERGER	D078985	10-01-02	100.0	99.7	100.0
SCHLUMBERGER	D078986	10-01-02	100.1	99.6	99.7
SCHLUMBERGER	D078987	10-01-02	99.9	99.9	99.5
SCHLUMBERGER	D078988	10-01-02	100.3	99.9	99.7
SCHLUMBERGER	D078989	10-01-02	100.0	99.7	99.4
SCHLUMBERGER	D078990	10-01-02	99.9	99.7	99.5
SCHLUMBERGER	D078991	10-01-02	99.9	99.7	99.9
SCHLUMBERGER	D078992	10-01-02	100.0	99.9	100.3
SCHLUMBERGER	D078993	10-01-02	99.9	99.9	99.7
SCHLUMBERGER	D078994	10-01-02	99.9	99.6	99.6
SCHLUMBERGER	D078995	10-01-02	100.1	100.0	99.6
SCHLUMBERGER	D078996	10-01-02	99.9	99.8	99.6
SCHLUMBERGER	D078997	10-01-02	100.2	99.9	99.8
SCHLUMBERGER	D078998	10-01-02	100.0	99.8	100.0
SCHLUMBERGER	D078999	10-01-02	99.9	100.0	99.7
SCHLUMBERGER	D079000	10-01-02	100.0	99.9	99.8
SCHLUMBERGER	D079001	10-01-02	100.1	100.1	99.9
SCHLUMBERGER	D079002	10-01-02	100.0	100.0	99.9
SCHLUMBERGER	D079003	10-01-02	100.1	99.9	100.2
SCHLUMBERGER	D079004	10-01-02	99.9	100.3	99.4
SCHLUMBERGER	D079005	10-01-02	100.0	99.6	100.2
SCHLUMBERGER	D079006	10-01-02	99.9	99.8	99.9
SCHLUMBERGER	D079007	10-01-02	99.9	99.7	99.4
SCHLUMBERGER	D079008	10-01-02	100.0	100.2	99.9
SCHLUMBERGER	D079009	10-01-02	100.3	99.9	100.0
SCHLUMBERGER	D079010	10-01-02	100.0	100.4	99.8
SCHLUMBERGER	D079011	10-01-02	99.9	100.3	99.8
SCHLUMBERGER	D079012	10-01-02	100.2	99.8	99.9
SCHLUMBERGER	D079013	10-01-02	100.0	99.9	99.7
SCHLUMBERGER	D079014	10-01-02	99.9	99.8	99.5
SCHLUMBERGER	D079015	10-01-02	100.1	99.8	99.9
SCHLUMBERGER	D079016	10-01-02	100.2	99.8	100.3
SCHLUMBERGER	D079017	10-01-02	100.0	99.8	100.5
SCHLUMBERGER	D079018	10-01-02	100.0	99.8	99.9
SCHLUMBERGER	D079019	10-01-02	99.9	99.8	99.6
SCHLUMBERGER	D079020	10-01-02	99.9	100.1	100.2

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

PAGE 311
 RUN DATE: 1/14/03
 RUN TIME: 13.26.53

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	J55	D079021	10-01-02	100.0	100.2	100.0
SCHLUMBERGER	J55	D079022	10-01-02	99.9	100.0	99.8
SCHLUMBERGER	J55	D079023	10-01-02	100.0	100.0	100.2
SCHLUMBERGER	J55	D079024	10-01-02	100.2	99.9	100.2
SCHLUMBERGER	J55	D079025	10-01-02	99.9	99.7	100.1
SCHLUMBERGER	J55	D079026	10-01-02	100.0	100.0	99.6
SCHLUMBERGER	J55	D079027	10-01-02	100.2	99.7	100.0
SCHLUMBERGER	J55	D079028	10-01-02	99.9	100.2	100.2
SCHLUMBERGER	J55	D079029	10-01-02	100.1	99.8	100.1
SCHLUMBERGER	J55	D079030	10-01-02	99.9	99.7	99.8
SCHLUMBERGER	J55	D079031	10-01-02	99.9	99.6	100.7
SCHLUMBERGER	J55	D079032	10-01-02	99.9	100.1	99.9
SCHLUMBERGER	J55	D079033	10-01-02	99.9	99.6	100.1
SCHLUMBERGER	J55	D079034	10-01-02	99.9	99.6	99.6
SCHLUMBERGER	J55	D079035	10-01-02	100.0	99.6	99.8
SCHLUMBERGER	J55	D079036	10-01-02	99.8	100.1	99.9
SCHLUMBERGER	J55	D079037	10-01-02	100.0	99.8	99.9
SCHLUMBERGER	J55	D079038	10-01-02	99.9	100.0	99.9
SCHLUMBERGER	J55	D079039	10-01-02	99.9	99.7	99.7
SCHLUMBERGER	J55	D079040	10-01-02	100.0	100.0	99.7
SCHLUMBERGER	J55	D079041	10-01-02	99.9	99.8	99.4
SCHLUMBERGER	J55	D079042	10-01-02	100.2	100.4	99.4
SCHLUMBERGER	J55	D079043	10-01-02	99.9	99.7	100.0
SCHLUMBERGER	J55	D079044	10-01-02	99.9	100.3	99.7
SCHLUMBERGER	J55	D079045	10-01-02	100.0	99.8	100.0
SCHLUMBERGER	J55	D079046	10-01-02	99.9	100.1	99.7
SCHLUMBERGER	J55	D079047	10-01-02	100.2	99.8	100.2
SCHLUMBERGER	J55	D079048	10-01-02	99.9	99.7	99.9
SCHLUMBERGER	J55	D079049	10-01-02	100.3	99.8	99.9
SCHLUMBERGER	J55	D079050	10-01-02	100.0	99.8	99.6
SCHLUMBERGER	J55	D079051	10-01-02	99.9	100.3	99.8
SCHLUMBERGER	J55	D079052	10-01-02	100.0	99.6	99.8
SCHLUMBERGER	J55	D079053	10-01-02	99.9	99.8	99.6
SCHLUMBERGER	J55	D079054	10-01-02	100.0	99.9	100.1
SCHLUMBERGER	J55	D079055	10-01-02	99.9	99.9	99.7
SCHLUMBERGER	J55	D079056	10-01-02	100.2	100.1	100.1
SCHLUMBERGER	J55	D079057	10-01-02	100.1	100.2	100.1
SCHLUMBERGER	J55	D079058	10-01-02	100.0	99.8	100.1
SCHLUMBERGER	J55	D079059	10-01-02	100.3	99.7	99.8
SCHLUMBERGER	J55	D079060	10-01-02	100.0	99.7	99.5
SCHLUMBERGER	J55	D079061	10-01-02	99.9	100.0	99.8
SCHLUMBERGER	J55	D079062	10-01-02	99.9	100.4	99.8
SCHLUMBERGER	J55	D079063	10-01-02	99.9	100.0	100.1
SCHLUMBERGER	J55	D079064	10-01-02	99.8	99.4	99.4
SCHLUMBERGER	J55	D079065	10-01-02	100.0	99.7	100.4
SCHLUMBERGER	J55	D079066	10-01-02	100.0	99.8	100.1
SCHLUMBERGER	J55	D079067	10-01-02	99.9	99.7	99.7
SCHLUMBERGER	J55	D079068	10-01-02	100.0	100.3	99.6
SCHLUMBERGER	J55	D079069	10-01-02	99.9	100.0	99.6
SCHLUMBERGER	J55	D079070	10-01-02	100.0	99.9	100.2
SCHLUMBERGER	J55	D079071	10-01-02	99.8	99.8	99.8

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

PAGE 312
 RUN DATE: 1/14/03
 RUN TIME: 13.26.53

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	J5S	D079072	10-01-02	100.1	100.2	100.1
SCHLUMBERGER	J5S	D079073	10-01-02	99.9	100.0	100.0
SCHLUMBERGER	J5S	D079074	10-01-02	99.9	99.6	99.8
SCHLUMBERGER	J5S	D079075	10-01-02	100.0	99.8	99.7
SCHLUMBERGER	J5S	D079076	10-01-02	100.0	99.9	100.2
SCHLUMBERGER	J5S	D079077	10-01-02	100.1	100.0	100.1
SCHLUMBERGER	J5S	D079078	10-01-02	100.0	99.8	99.7
SCHLUMBERGER	J5S	D079079	10-01-02	100.0	100.2	100.0
SCHLUMBERGER	J5S	D079080	10-01-02	100.0	99.9	99.8
SCHLUMBERGER	J5S	D079081	10-01-02	100.0	99.9	99.8
SCHLUMBERGER	J5S	D079082	10-01-02	100.0	100.4	100.4
SCHLUMBERGER	J5S	D079083	10-01-02	100.0	99.7	100.0
SCHLUMBERGER	J5S	D079084	10-01-02	100.1	99.7	100.0
SCHLUMBERGER	J5S	D079085	10-01-02	100.0	100.1	100.0
SCHLUMBERGER	J5S	D079086	10-01-02	100.1	99.7	100.0
SCHLUMBERGER	J5S	D079087	10-01-02	99.9	99.7	100.0
SCHLUMBERGER	J5S	D079088	10-01-02	100.0	99.6	100.0
SCHLUMBERGER	J5S	D079089	10-01-02	100.0	100.3	100.2
SCHLUMBERGER	J5S	D079090	10-01-02	100.0	99.8	99.5
SCHLUMBERGER	J5S	D079091	10-01-02	100.0	99.7	100.0
SCHLUMBERGER	J5S	D079092	10-01-02	100.0	99.7	100.0
SCHLUMBERGER	J5S	D079093	10-01-02	100.1	99.5	100.0
SCHLUMBERGER	J5S	D079094	10-01-02	99.9	99.8	99.5
SCHLUMBERGER	J5S	D079095	10-01-02	100.0	100.0	99.8
SCHLUMBERGER	J5S	D079096	10-01-02	100.0	100.1	99.7
SCHLUMBERGER	J5S	D079097	10-01-02	100.0	100.0	100.0
SCHLUMBERGER	J5S	D079098	10-01-02	100.1	99.8	100.1
SCHLUMBERGER	J5S	D079099	10-01-02	99.9	99.7	99.9
SCHLUMBERGER	J5S	D079100	10-01-02	100.1	100.3	99.8
SCHLUMBERGER	J5S	D079101	10-01-02	99.8	100.0	99.6
SCHLUMBERGER	J5S	D079102	10-01-02	100.0	99.9	100.1
SCHLUMBERGER	J5S	D079103	10-01-02	99.8	99.9	99.6
SCHLUMBERGER	J5S	D079104	10-01-02	100.0	100.1	100.3
SCHLUMBERGER	J5S	D079105	10-01-02	100.0	100.3	99.8
SCHLUMBERGER	J5S	D079106	10-01-02	99.9	100.1	99.5
SCHLUMBERGER	J5S	D079107	10-01-02	99.9	99.8	99.6
SCHLUMBERGER	J5S	D079108	10-01-02	100.1	99.9	99.7
SCHLUMBERGER	J5S	D079109	10-01-02	100.0	99.8	99.9
SCHLUMBERGER	J5S	D079110	10-01-02	99.8	99.8	99.6
SCHLUMBERGER	J5S	D079111	10-01-02	99.9	100.4	99.7
SCHLUMBERGER	J5S	D079112	10-01-02	100.1	100.4	100.1
SCHLUMBERGER	J5S	D079113	10-01-02	100.0	99.9	99.9
SCHLUMBERGER	J5S	D079114	10-01-02	100.0	100.0	100.0
SCHLUMBERGER	J5S	D079115	10-01-02	100.3	99.7	99.4
SCHLUMBERGER	J5S	D079116	10-01-02	100.0	99.7	99.9
SCHLUMBERGER	J5S	D079117	10-01-02	100.2	100.3	100.1
SCHLUMBERGER	J5S	D079118	10-01-02	100.0	100.4	99.9
SCHLUMBERGER	J5S	D079119	10-01-02	100.0	100.3	99.9
SCHLUMBERGER	J5S	D079120	10-01-02	100.2	100.3	100.2
SCHLUMBERGER	J5S	D079121	10-01-02	100.1	99.9	99.9
SCHLUMBERGER	J5S	D079122	10-01-02	100.0	99.6	99.6

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	J55	D079123	10-01-02	100.1	99.8	99.6
SCHLUMBERGER	J55	D079124	10-01-02	100.2	99.8	99.9
SCHLUMBERGER	J55	D079125	10-01-02	99.9	99.8	100.2
SCHLUMBERGER	J55	D079126	10-01-02	100.1	99.8	99.8
SCHLUMBERGER	J55	D079127	10-01-02	100.0	99.9	99.9
SCHLUMBERGER	J55	D079128	10-01-02	99.9	99.7	99.6
SCHLUMBERGER	J55	D079129	10-01-02	100.1	99.8	99.8
SCHLUMBERGER	J55	D079130	10-01-02	100.1	99.8	99.9
SCHLUMBERGER	J55	D079131	10-01-02	99.9	99.7	99.7
SCHLUMBERGER	J55	D079132	10-01-02	100.1	99.8	99.9
SCHLUMBERGER	J55	D079133	10-01-02	99.9	100.2	99.6
SCHLUMBERGER	J55	D079134	10-01-02	100.0	99.9	100.1
SCHLUMBERGER	J55	D079135	10-01-02	99.8	99.6	99.7
SCHLUMBERGER	J55	D079136	10-01-02	100.1	100.1	99.7
SCHLUMBERGER	J55	D079137	10-01-02	100.1	99.8	99.8
SCHLUMBERGER	J55	D079138	10-01-02	100.0	99.7	99.9
SCHLUMBERGER	J55	D079139	10-01-02	100.0	100.0	100.1
SCHLUMBERGER	J55	D079140	10-01-02	100.0	99.8	99.9
SCHLUMBERGER	J55	D079141	10-01-02	100.3	99.9	99.9
SCHLUMBERGER	J55	D079142	10-01-02	100.1	100.1	100.1
SCHLUMBERGER	J55	D079143	10-01-02	100.0	99.6	99.9
SCHLUMBERGER	J55	D079144	10-01-02	100.0	99.9	100.0
SCHLUMBERGER	J55	D079145	10-01-02	100.0	99.8	99.8
SCHLUMBERGER	J55	D079146	10-01-02	100.0	99.6	100.1
SCHLUMBERGER	J55	D079147	10-01-02	99.8	100.0	99.9
SCHLUMBERGER	J55	D079148	10-01-02	100.0	99.9	99.8
SCHLUMBERGER	J55	D079149	10-01-02	99.9	99.7	99.9
SCHLUMBERGER	J55	D079150	10-01-02	100.0	99.9	99.9
SCHLUMBERGER	J55	D079151	10-01-02	99.9	100.0	99.8
SCHLUMBERGER	J55	D079152	10-01-02	100.1	100.0	100.1
SCHLUMBERGER	J55	D079153	10-01-02	100.1	99.6	100.0
SCHLUMBERGER	J55	D079154	10-01-02	99.9	100.1	100.2
SCHLUMBERGER	J55	D079155	10-01-02	100.1	100.0	100.2
SCHLUMBERGER	J55	D079156	10-01-02	100.0	99.7	100.1
SCHLUMBERGER	J55	D079157	10-01-02	100.1	100.4	99.7
SCHLUMBERGER	J55	D079158	10-01-02	100.2	100.5	100.2
SCHLUMBERGER	J55	D079159	10-01-02	100.1	99.8	99.5
SCHLUMBERGER	J55	D079160	10-01-02	100.0	100.3	100.3
SCHLUMBERGER	J55	D079161	10-01-02	100.0	100.1	100.2
SCHLUMBERGER	J55	D079162	10-01-02	100.0	100.4	99.8
SCHLUMBERGER	J55	D079163	10-01-02	100.0	99.6	99.8
SCHLUMBERGER	J55	D079164	10-01-02	100.1	99.6	99.8
SCHLUMBERGER	J55	D079165	10-01-02	100.1	99.9	100.3
SCHLUMBERGER	J55	D079166	10-01-02	99.9	99.6	99.5
SCHLUMBERGER	J55	D079167	10-01-02	100.1	99.7	100.2
SCHLUMBERGER	J55	D079168	10-01-02	100.0	100.2	99.7
SCHLUMBERGER	J55	D079169	10-01-02	100.3	99.7	100.2
SCHLUMBERGER	J55	D079170	10-01-02	100.1	100.0	99.7
SCHLUMBERGER	J55	D079171	10-01-02	99.9	99.9	100.0
SCHLUMBERGER	J55	D079172	10-01-02	100.0	100.1	99.9
SCHLUMBERGER	J55	D079173	10-01-02	100.0	100.4	99.5

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

PAGE 314
 RUN DATE: 1/14/03
 RUN TIME: 13.26.53

MANUFACTURER	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	D079174	10-01-02	100.0	99.9	99.9
SCHLUMBERGER	D079175	10-01-02	100.3	100.0	100.1
SCHLUMBERGER	D079176	10-01-02	100.2	99.7	100.2
SCHLUMBERGER	D079177	10-01-02	100.0	99.7	99.7
SCHLUMBERGER	D079178	10-01-02	100.0	100.2	100.1
SCHLUMBERGER	D079179	10-01-02	100.2	100.2	99.7
SCHLUMBERGER	D079180	10-01-02	100.1	99.9	99.7
SCHLUMBERGER	D079181	10-01-02	100.1	100.4	99.9
SCHLUMBERGER	D079182	10-01-02	100.0	100.1	99.9
SCHLUMBERGER	D079183	10-01-02	100.1	99.6	99.6
SCHLUMBERGER	D079184	10-01-02	100.2	100.2	99.9
SCHLUMBERGER	D079185	10-01-02	100.2	100.4	100.2
SCHLUMBERGER	D079186	10-01-02	100.0	99.8	99.5
SCHLUMBERGER	D079187	10-01-02	100.1	99.9	100.0
SCHLUMBERGER	D079188	10-01-02	100.1	99.8	100.0
SCHLUMBERGER	D079189	10-01-02	99.9	99.6	99.7
SCHLUMBERGER	D079190	10-01-02	99.9	99.8	99.7
SCHLUMBERGER	D079191	10-01-02	100.0	99.8	100.0
SCHLUMBERGER	D079192	10-01-02	99.8	100.0	99.7
SCHLUMBERGER	D079193	10-01-02	100.1	99.9	100.0
SCHLUMBERGER	D079194	10-01-02	100.3	100.0	100.0
SCHLUMBERGER	D079195	10-01-02	100.1	100.4	99.5
SCHLUMBERGER	D079196	10-01-02	100.0	99.8	100.0
SCHLUMBERGER	D079197	10-01-02	100.1	100.3	99.9
SCHLUMBERGER	D079198	10-01-02	100.2	100.4	100.2
SCHLUMBERGER	D079199	10-01-02	100.0	99.7	99.6
SCHLUMBERGER	D079200	10-01-02	100.2	100.0	100.1
SCHLUMBERGER	D079201	10-01-02	100.1	100.3	100.0
SCHLUMBERGER	D079202	10-01-02	100.1	99.7	100.4
SCHLUMBERGER	D079203	10-01-02	99.9	99.8	99.9
SCHLUMBERGER	D079204	10-01-02	100.0	100.4	99.8
SCHLUMBERGER	D079205	10-01-02	100.1	99.6	100.1
SCHLUMBERGER	D079206	10-01-02	100.0	99.7	99.6
SCHLUMBERGER	D079207	10-01-02	100.1	99.8	100.0
SCHLUMBERGER	D079208	10-01-02	99.9	99.8	99.9
SCHLUMBERGER	D079209	10-01-02	100.2	99.7	99.9
SCHLUMBERGER	D079210	10-01-02	100.1	99.8	99.8
SCHLUMBERGER	D079211	10-01-02	100.1	99.9	100.1
SCHLUMBERGER	D079212	10-01-02	100.0	99.6	99.6
SCHLUMBERGER	D079213	10-01-02	100.1	99.8	99.6
SCHLUMBERGER	D079214	10-01-02	100.1	99.8	100.1
SCHLUMBERGER	D079215	10-01-02	100.1	99.8	100.0
SCHLUMBERGER	D079216	10-01-02	100.2	100.0	99.3
SCHLUMBERGER	D079217	10-01-02	100.2	100.0	100.0
SCHLUMBERGER	D079218	10-01-02	100.1	100.0	100.3
SCHLUMBERGER	D079219	10-01-02	100.0	100.0	99.8
SCHLUMBERGER	D079220	10-01-02	100.1	99.8	100.0
SCHLUMBERGER	D079221	10-01-02	100.1	100.1	100.1
SCHLUMBERGER	D079222	10-01-02	100.0	100.0	99.2
SCHLUMBERGER	D079223	10-01-02	100.1	99.8	99.5
SCHLUMBERGER	D079224	10-01-02	100.1	100.1	100.3

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

PAGE 315
 RUN DATE: 1/14/03
 RUN TIME: 13.26.53

MANUFACTURER	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	D079225	10-01-02	100.1	99.9	100.2
SCHLUMBERGER	D079226	10-01-02	100.1	99.8	99.8
SCHLUMBERGER	D079227	10-01-02	100.0	99.9	100.0
SCHLUMBERGER	D079228	10-01-02	100.0	100.3	99.6
SCHLUMBERGER	D079229	10-01-02	100.1	100.1	100.0
SCHLUMBERGER	D079230	10-01-02	100.0	99.7	99.9
SCHLUMBERGER	D079231	10-01-02	100.0	99.9	100.2
SCHLUMBERGER	D079232	10-01-02	99.9	99.7	99.7
SCHLUMBERGER	D079233	10-01-02	99.9	99.7	99.3
SCHLUMBERGER	D079234	10-01-02	100.1	99.7	99.7
SCHLUMBERGER	D079235	10-01-02	100.0	100.0	99.8
SCHLUMBERGER	D079236	10-01-02	100.0	99.8	99.8
SCHLUMBERGER	D079237	10-01-02	100.0	99.9	99.7
SCHLUMBERGER	D079238	10-01-02	99.9	99.9	99.8
SCHLUMBERGER	D079239	10-01-02	99.9	100.0	99.7
SCHLUMBERGER	D079240	10-01-02	100.2	100.2	100.0
SCHLUMBERGER	D079241	10-01-02	99.9	99.6	99.8
SCHLUMBERGER	D079242	10-01-02	100.1	100.0	99.8
SCHLUMBERGER	D079243	10-01-02	100.0	99.7	100.0
SCHLUMBERGER	D079244	10-01-02	100.1	100.1	99.8
SCHLUMBERGER	D079245	10-01-02	100.1	100.3	99.7
SCHLUMBERGER	D079246	10-01-02	100.1	100.3	99.5
SCHLUMBERGER	D079247	10-01-02	100.0	99.9	99.9
SCHLUMBERGER	D079248	10-01-02	100.1	99.6	99.9
SCHLUMBERGER	D079249	10-01-02	100.0	100.2	99.9
SCHLUMBERGER	D079250	10-01-02	100.0	100.2	100.0
SCHLUMBERGER	D079251	10-01-02	100.2	100.4	100.2
SCHLUMBERGER	D079252	10-01-02	100.0	99.7	99.4
SCHLUMBERGER	D079253	10-01-02	99.8	99.9	99.7
SCHLUMBERGER	D079254	10-01-02	100.1	100.1	99.9
SCHLUMBERGER	D079255	10-01-02	100.1	100.2	99.9
SCHLUMBERGER	D079256	10-01-02	100.2	100.2	99.7
SCHLUMBERGER	D079257	10-01-02	100.2	100.5	100.4
SCHLUMBERGER	D079258	10-01-02	99.8	100.5	99.5
SCHLUMBERGER	D079259	10-01-02	100.2	100.1	99.9
SCHLUMBERGER	D079260	10-01-02	100.3	100.4	100.0
SCHLUMBERGER	D079261	10-01-02	100.1	100.5	100.3
SCHLUMBERGER	D079262	10-01-02	100.1	100.3	100.1
SCHLUMBERGER	D079263	10-01-02	100.2	100.0	100.0
SCHLUMBERGER	D079264	10-01-02	100.0	100.1	100.0
SCHLUMBERGER	D079265	10-01-02	100.0	99.7	99.9
SCHLUMBERGER	D079266	10-01-02	100.2	100.5	100.1
SCHLUMBERGER	D079267	10-01-02	100.0	100.4	99.7
SCHLUMBERGER	D079268	10-01-02	99.9	100.0	99.8
SCHLUMBERGER	D079269	10-01-02	100.0	99.8	99.7
SCHLUMBERGER	D079270	10-01-02	100.0	100.1	99.8
SCHLUMBERGER	D079271	10-01-02	100.3	100.3	99.9
SCHLUMBERGER	D079272	10-01-02	100.1	100.2	99.6
SCHLUMBERGER	D079273	10-01-02	100.0	100.2	99.9
SCHLUMBERGER	D079274	10-01-02	100.1	100.4	99.3
SCHLUMBERGER	D079275	10-01-02	100.1	100.0	100.2

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	J55	D079276	10-01-02	99.9	99.7	100.0
SCHLUMBERGER	J55	D079277	10-01-02	100.1	99.8	99.9
SCHLUMBERGER	J55	D079278	10-01-02	100.1	99.9	99.7
SCHLUMBERGER	J55	D079279	10-01-02	100.1	99.8	99.6
SCHLUMBERGER	J55	D079280	10-01-02	100.1	99.8	99.8
SCHLUMBERGER	J55	D079281	10-01-02	100.1	100.1	99.9
SCHLUMBERGER	J55	D079282	12-01-02	100.1	100.3	100.4
SCHLUMBERGER	J55	D079283	10-01-02	100.0	99.9	100.0
SCHLUMBERGER	J55	D079284	10-01-02	100.2	100.0	100.2
SCHLUMBERGER	J55	D079285	10-01-02	99.8	99.8	99.5
SCHLUMBERGER	J55	D079286	10-01-02	100.1	99.9	99.5
SCHLUMBERGER	J55	D079287	10-01-02	100.3	100.1	99.9
SCHLUMBERGER	J55	D079288	10-01-02	100.1	99.6	100.1
SCHLUMBERGER	J55	D079289	10-01-02	100.2	100.3	100.0
SCHLUMBERGER	J55	D079290	10-01-02	100.1	99.8	99.8
SCHLUMBERGER	J55	D079291	10-01-02	100.1	100.2	99.9
SCHLUMBERGER	J55	D079292	10-01-02	100.0	99.8	99.8
SCHLUMBERGER	J55	D079293	10-01-02	100.0	100.0	100.0
SCHLUMBERGER	J55	D079294	10-01-02	100.0	99.8	99.7
SCHLUMBERGER	J55	D079295	10-01-02	100.0	99.7	99.8
SCHLUMBERGER	J55	D079296	10-01-02	100.1	99.7	99.4
SCHLUMBERGER	J55	D079297	10-01-02	100.0	100.0	99.5
SCHLUMBERGER	J55	D079298	10-01-02	100.1	99.7	99.8
SCHLUMBERGER	J55	D079299	10-01-02	100.1	99.8	99.8
SCHLUMBERGER	J55	D079300	10-01-02	100.1	99.8	99.8
SCHLUMBERGER	J55	D079301	10-01-02	100.2	100.3	99.9
SCHLUMBERGER	J55	D079302	10-01-02	100.0	99.9	99.8
SCHLUMBERGER	J55	D079303	10-01-02	100.0	100.3	100.2
SCHLUMBERGER	J55	D079304	10-01-02	100.0	99.7	100.0
SCHLUMBERGER	J55	D079305	10-01-02	100.1	100.1	99.9
SCHLUMBERGER	J55	D079306	10-01-02	100.0	100.2	99.9
SCHLUMBERGER	J55	D079307	10-01-02	100.0	99.6	99.9
SCHLUMBERGER	J55	D079308	10-01-02	100.2	100.4	100.3
SCHLUMBERGER	J55	D079309	10-01-02	100.1	100.2	100.2
SCHLUMBERGER	J55	D079310	10-01-02	100.1	100.4	99.9
SCHLUMBERGER	J55	D079311	10-01-02	100.1	100.2	99.9
SCHLUMBERGER	J55	D079312	10-01-02	100.1	100.1	99.8
SCHLUMBERGER	J55	D079313	10-01-02	100.2	100.3	100.0
SCHLUMBERGER	J55	D079314	10-01-02	100.0	100.0	99.8
SCHLUMBERGER	J55	D079315	10-01-02	100.1	100.0	100.1
SCHLUMBERGER	J55	D079316	10-01-02	100.0	100.1	100.0
SCHLUMBERGER	J55	D079317	10-01-02	100.1	99.8	100.0
SCHLUMBERGER	J55	D079318	10-01-02	99.9	99.9	99.8
SCHLUMBERGER	J55	D079319	10-01-02	100.2	100.0	99.8
SCHLUMBERGER	J55	D079320	10-01-02	100.1	99.9	99.4
SCHLUMBERGER	J55	D079321	10-01-02	100.1	100.0	100.0
SCHLUMBERGER	J55	D079322	10-01-02	100.0	100.3	100.0
SCHLUMBERGER	J55	D079323	10-01-02	100.2	100.1	100.0
SCHLUMBERGER	J55	D079324	10-01-02	100.0	100.1	99.9
SCHLUMBERGER	J55	D079325	10-01-02	100.1	100.1	100.2
SCHLUMBERGER	J55	D079326	10-01-02	100.0	100.0	99.8

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	J55	D079327	10-01-02	100.0	99.8	100.0
SCHLUMBERGER	J55	D079328	10-01-02	100.1	100.2	100.1
SCHLUMBERGER	J55	D079329	10-01-02	100.1	99.9	100.2
SCHLUMBERGER	J55	D079330	10-01-02	100.0	99.8	99.7
SCHLUMBERGER	J55	D079331	10-01-02	99.9	100.3	99.8
SCHLUMBERGER	J55	D079332	10-01-02	100.1	100.3	99.9
SCHLUMBERGER	J55	D079333	10-01-02	100.0	100.2	99.5
SCHLUMBERGER	J55	D079334	10-01-02	99.9	100.1	99.9
SCHLUMBERGER	J55	D079335	10-01-02	99.9	99.8	99.7
SCHLUMBERGER	J55	D079336	10-01-02	100.2	100.2	100.0
SCHLUMBERGER	J55	D079337	10-01-02	100.0	100.2	100.2
SCHLUMBERGER	J55	D079338	10-01-02	100.0	99.6	99.9
SCHLUMBERGER	J55	D079339	10-01-02	100.1	100.2	100.0
SCHLUMBERGER	J55	D079340	10-01-02	100.1	100.2	99.3
SCHLUMBERGER	J55	D079341	10-01-02	100.3	99.9	100.3
SCHLUMBERGER	J55	D079342	10-01-02	100.2	100.2	100.3
SCHLUMBERGER	J55	D079343	10-01-02	100.1	100.4	100.4
SCHLUMBERGER	J55	D079344	10-01-02	100.3	100.0	99.9
SCHLUMBERGER	J55	D079345	10-01-02	100.1	100.0	100.0
SCHLUMBERGER	J55	D079346	10-01-02	100.1	99.7	100.0
SCHLUMBERGER	J55	D079347	10-01-02	100.3	100.4	100.2
SCHLUMBERGER	J55	D079348	10-01-02	100.1	99.8	100.6
SCHLUMBERGER	J55	D079349	10-01-02	100.1	99.7	100.1
SCHLUMBERGER	J55	D079350	10-01-02	100.3	100.1	100.0
SCHLUMBERGER	J55	D079351	10-01-02	100.0	99.7	99.7
SCHLUMBERGER	J55	D079352	10-01-02	100.3	100.3	100.2
SCHLUMBERGER	J55	D079353	10-01-02	100.1	99.8	99.7
SCHLUMBERGER	J55	D079354	10-01-02	100.0	99.7	100.0
SCHLUMBERGER	J55	D079355	10-01-02	100.0	100.0	100.3
SCHLUMBERGER	J55	D079356	10-01-02	100.0	100.0	100.1
SCHLUMBERGER	J55	D079357	10-01-02	99.9	99.9	99.7
SCHLUMBERGER	J55	D079358	10-01-02	100.1	100.2	99.9
SCHLUMBERGER	J55	D079359	10-01-02	100.0	99.8	100.2
SCHLUMBERGER	J55	D079360	10-01-02	100.1	99.8	100.1
SCHLUMBERGER	J55	D079361	10-01-02	99.9	100.3	99.8
SCHLUMBERGER	J55	D079362	10-01-02	100.2	100.3	100.0
SCHLUMBERGER	J55	D079363	10-01-02	100.1	99.8	100.2
SCHLUMBERGER	J55	D079364	10-01-02	100.2	100.3	100.2
SCHLUMBERGER	J55	D079365	10-01-02	100.1	100.3	99.9
SCHLUMBERGER	J55	D079366	10-01-02	100.0	99.8	99.7
SCHLUMBERGER	J55	D079367	10-01-02	100.2	99.9	100.3
SCHLUMBERGER	J55	D079368	10-01-02	100.2	100.2	100.1
SCHLUMBERGER	J55	D079369	10-01-02	100.1	100.2	99.8
SCHLUMBERGER	J55	D079370	10-01-02	100.1	100.0	99.6
SCHLUMBERGER	J55	D079371	10-01-02	100.2	99.9	100.0
SCHLUMBERGER	J55	D079372	10-01-02	100.0	100.0	100.0
SCHLUMBERGER	J55	D079373	10-01-02	99.9	100.0	100.0
SCHLUMBERGER	J55	D079374	10-01-02	100.0	100.0	100.1
SCHLUMBERGER	J55	D079375	10-01-02	100.3	100.1	100.3
SCHLUMBERGER	J55	D079376	10-01-02	100.0	100.2	100.0
SCHLUMBERGER	J55	D079377	10-01-02	100.0	100.1	100.0

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

PAGE 318
 RUN DATE: 1/14/03
 RUN TIME: 13.26.53

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	J5S	D079378	10-01-02	100.1	99.8	100.0
SCHLUMBERGER	J5S	D079379	10-01-02	99.9	100.3	99.7
SCHLUMBERGER	J5S	D079380	09-30-02	100.0	99.7	100.1
SCHLUMBERGER	J5S	D079381	09-30-02	100.1	99.6	100.3
SCHLUMBERGER	J5S	D079382	09-30-02	100.3	100.1	100.0
SCHLUMBERGER	J5S	D079383	09-30-02	100.1	99.7	100.1
SCHLUMBERGER	J5S	D079384	09-30-02	100.1	99.7	100.1
SCHLUMBERGER	J5S	D079385	09-30-02	100.1	99.7	100.1
SCHLUMBERGER	J5S	D079386	09-30-02	99.9	99.7	100.1
SCHLUMBERGER	J5S	D079387	09-30-02	100.0	99.8	100.2
SCHLUMBERGER	J5S	D079388	09-30-02	100.3	100.1	100.0
SCHLUMBERGER	J5S	D079389	09-30-02	100.1	99.8	100.1
SCHLUMBERGER	J5S	D079390	09-30-02	99.9	99.8	99.9
SCHLUMBERGER	J5S	D079391	09-30-02	100.2	100.1	99.7
SCHLUMBERGER	J5S	D079392	09-30-02	100.1	99.8	100.1
SCHLUMBERGER	J5S	D079393	09-30-02	100.1	99.8	99.9
SCHLUMBERGER	J5S	D079394	09-30-02	100.1	99.9	100.1
SCHLUMBERGER	J5S	D079395	09-30-02	100.1	100.1	100.2
SCHLUMBERGER	J5S	L317789	03-19-02	100.1	100.0	100.1
SCHLUMBERGER	J5S	L317790	03-19-02	100.1	99.8	100.1
SCHLUMBERGER	J5S	L317791	03-19-02	100.2	100.2	99.9
SCHLUMBERGER	J5S	L317792	03-19-02	100.1	99.8	99.5
SCHLUMBERGER	J5S	L317793	03-19-02	100.1	100.0	99.7
SCHLUMBERGER	J5S	L317794	03-19-02	100.1	99.6	99.7
SCHLUMBERGER	J5S	L317795	03-19-02	100.2	99.9	100.2
SCHLUMBERGER	J5S	L317796	03-19-02	100.0	100.2	100.0
SCHLUMBERGER	J5S	L317797	03-19-02	99.9	100.1	99.7
SCHLUMBERGER	J5S	L317798	03-19-02	100.2	100.1	100.0
SCHLUMBERGER	J5S	L317799	03-19-02	100.2	100.1	100.0
SCHLUMBERGER	J5S	L317800	03-19-02	99.8	100.1	100.5
SCHLUMBERGER	J5S	L317801	03-19-02	100.2	100.0	100.1
SCHLUMBERGER	J5S	L317802	03-19-02	100.1	99.9	100.1
SCHLUMBERGER	J5S	L317803	03-19-02	100.2	100.0	100.0
SCHLUMBERGER	J5S	L317804	03-19-02	100.2	100.0	100.5
SCHLUMBERGER	J5S	L317805	03-19-02	99.8	99.8	100.0
SCHLUMBERGER	J5S	L317806	03-19-02	100.2	99.8	100.0
SCHLUMBERGER	J5S	L317807	03-19-02	100.1	100.2	100.0
SCHLUMBERGER	J5S	L317808	03-19-02	100.0	99.9	100.3
SCHLUMBERGER	J5S	L317809	03-19-02	100.1	100.0	99.8
SCHLUMBERGER	J5S	L317810	03-19-02	100.1	99.7	100.0
SCHLUMBERGER	J5S	L317811	03-19-02	100.2	100.1	100.0
SCHLUMBERGER	J5S	L317812	03-19-02	100.2	100.4	100.4
SCHLUMBERGER	J5S	L317813	03-19-02	100.1	100.3	100.3
SCHLUMBERGER	J5S	L317814	03-19-02	100.3	99.8	100.0
SCHLUMBERGER	J5S	L317815	03-19-02	100.1	100.1	100.4
SCHLUMBERGER	J5S	L317816	03-19-02	99.9	99.9	100.2
SCHLUMBERGER	J5S	L317817	03-19-02	100.1	99.7	99.7
SCHLUMBERGER	J5S	L317818	03-19-02	100.0	99.7	100.1
SCHLUMBERGER	J5S	L317819	03-19-02	100.1	100.0	99.7
SCHLUMBERGER	J5S	L317820	03-19-02	100.1	99.9	99.8
SCHLUMBERGER	J5S	L317821	03-19-02	100.1	100.1	100.1

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. WD8880

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	J55	L317822	03-19-02	100.1	100.2	99.9
SCHLUMBERGER	J55	L317823	03-19-02	100.2	99.9	99.7
SCHLUMBERGER	J55	L317824	03-19-02	100.2	100.3	100.3
SCHLUMBERGER	J55	L317825	03-19-02	100.1	99.7	99.9
SCHLUMBERGER	J55	L317826	03-19-02	100.1	100.2	100.3
SCHLUMBERGER	J55	L317827	03-19-02	100.1	100.2	99.7
SCHLUMBERGER	J55	L317828	03-19-02	100.1	99.8	99.8
SCHLUMBERGER	J55	L317829	03-19-02	100.1	99.9	99.9
SCHLUMBERGER	J55	L317830	03-19-02	100.1	99.8	99.8
SCHLUMBERGER	J55	L317831	03-19-02	100.1	100.0	100.0
SCHLUMBERGER	J55	L317832	03-19-02	100.1	99.7	100.2
SCHLUMBERGER	J55	L317833	03-19-02	100.0	99.7	100.2
SCHLUMBERGER	J55	L317834	03-19-02	100.1	100.0	99.8
SCHLUMBERGER	J55	L317835	03-19-02	100.0	99.9	99.9
SCHLUMBERGER	J55	L317836	03-19-02	100.0	99.9	100.1
SCHLUMBERGER	J55	L317837	03-19-02	100.2	100.1	100.0
SCHLUMBERGER	J55	L317838	03-19-02	100.3	100.1	100.2
SCHLUMBERGER	J55	L317839	03-19-02	100.1	99.7	99.9
SCHLUMBERGER	J55	L317840	03-19-02	100.1	100.1	100.2
SCHLUMBERGER	J55	L317841	03-19-02	100.0	99.7	99.9
SCHLUMBERGER	J55	L317842	03-19-02	100.0	99.9	100.0
SCHLUMBERGER	J55	L317843	03-19-02	100.1	99.9	100.3
SCHLUMBERGER	J55	L317844	03-19-02	100.1	99.9	99.9
SCHLUMBERGER	J55	L317845	03-19-02	100.1	100.1	99.9
SCHLUMBERGER	J55	L317846	03-19-02	100.1	100.0	99.8
SCHLUMBERGER	J55	L317847	03-19-02	100.0	99.6	99.4
SCHLUMBERGER	J55	L317848	03-19-02	99.9	99.7	99.8
SCHLUMBERGER	J55	L317849	03-19-02	100.1	99.8	99.9
SCHLUMBERGER	J55	L317850	03-19-02	100.0	99.9	99.5
SCHLUMBERGER	J55	L317851	03-19-02	100.1	100.1	100.0
SCHLUMBERGER	J55	L317852	03-19-02	99.8	99.8	99.9
SCHLUMBERGER	J55	L317853	03-19-02	100.1	99.9	99.7
SCHLUMBERGER	J55	L317854	03-19-02	100.1	99.9	99.8
SCHLUMBERGER	J55	L317855	03-19-02	100.0	99.7	99.5
SCHLUMBERGER	J55	L317856	03-19-02	100.1	99.9	99.8
SCHLUMBERGER	J55	L317857	03-19-02	100.0	99.9	99.6
SCHLUMBERGER	J55	L317858	03-19-02	100.2	100.0	99.8
SCHLUMBERGER	J55	L317859	03-19-02	100.1	100.1	99.9
SCHLUMBERGER	J55	L317860	03-19-02	100.1	99.8	99.9
SCHLUMBERGER	J55	L317861	03-19-02	100.1	100.0	99.9
SCHLUMBERGER	J55	L317862	03-19-02	100.2	100.2	99.9
SCHLUMBERGER	J55	L317863	03-19-02	100.0	100.2	100.2
SCHLUMBERGER	J55	L317864	03-19-02	100.0	99.9	100.0
SCHLUMBERGER	J55	L317865	03-19-02	100.0	99.9	100.0
SCHLUMBERGER	J55	L317866	03-19-02	100.2	100.1	99.6
SCHLUMBERGER	J55	L317867	03-19-02	100.2	100.1	100.0
SCHLUMBERGER	J55	L317868	03-19-02	100.0	99.7	99.8
SCHLUMBERGER	J55	L317869	03-19-02	100.1	100.0	100.2
SCHLUMBERGER	J55	L317870	03-19-02	100.0	100.0	99.7
SCHLUMBERGER	J55	L317871	03-19-02	100.0	100.1	100.0
SCHLUMBERGER	J55	L317872	03-19-02	100.0	99.7	99.8

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

PAGE 320
 RUN DATE: 1/14/03
 RUN TIME: 13.26.53

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
SCHLUMBERGER	J5S	L317873	03-19-02	100.2	99.6	100.2
SCHLUMBERGER	J5S	L317874	03-19-02	100.0	99.9	100.0
SCHLUMBERGER	J5S	L317875	03-19-02	100.3	99.9	99.7
SCHLUMBERGER	J5S	L317876	03-19-02	100.1	99.7	99.9
SCHLUMBERGER	J5S	L317877	03-19-02	100.1	100.0	100.1
SCHLUMBERGER	J5S	L317878	03-19-02	100.3	99.9	99.8
SCHLUMBERGER	J5S	L317879	03-19-02	100.1	99.9	100.0
SCHLUMBERGER	J5S	L317880	03-19-02	100.2	100.1	100.6
SCHLUMBERGER	J5S	L317881	03-19-02	100.2	99.9	100.5
SCHLUMBERGER	J5S	L317882	03-19-02	100.0	100.0	100.4
SCHLUMBERGER	J5S	L317883	03-19-02	100.0	100.3	99.8
SCHLUMBERGER	J5S	L317884	03-19-02	100.1	99.8	100.0
SCHLUMBERGER	J5S	L317885	03-19-02	100.2	99.8	99.9
SCHLUMBERGER	J5S	L317886	03-19-02	100.0	100.2	99.8
SCHLUMBERGER	J5S	L317887	03-19-02	100.0	99.9	100.1
SCHLUMBERGER	J5S	L317888	03-19-02	100.1	99.8	99.8

MFG TYPE TOTAL 16,132

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

PAGE 321
 RUN DATE: 1/14/03
 RUN TIME: 13.26.53

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
LANDIS & GYR	MX	C390608	05-14-02	100.1	100.0	99.8
LANDIS & GYR	MX	C390609	05-14-02	99.9	99.9	100.0
LANDIS & GYR	MX	C390610	05-14-02	100.0	100.0	99.8
LANDIS & GYR	MX	C390611	05-14-02	100.1	100.1	100.4
LANDIS & GYR	MX	C390612	05-14-02	100.0	100.1	99.8
LANDIS & GYR	MX	C390613	05-14-02	100.1	100.1	99.8
LANDIS & GYR	MX	C390614	05-14-02	100.0	100.1	99.8
LANDIS & GYR	MX	C390615	05-14-02	100.0	100.0	99.6
LANDIS & GYR	MX	C390616	05-14-02	100.1	100.1	100.4
LANDIS & GYR	MX	C390617	05-14-02	100.0	100.0	100.2
LANDIS & GYR	MX	C390618	05-14-02	100.0	100.2	99.7
LANDIS & GYR	MX	C390619	05-14-02	99.9	100.0	100.0
LANDIS & GYR	MX	C390620	05-14-02	100.1	100.2	99.8
LANDIS & GYR	MX	C390621	05-14-02	100.1	100.2	100.2
LANDIS & GYR	MX	C390622	05-14-02	100.0	100.1	99.5
LANDIS & GYR	MX	C390623	05-14-02	100.0	100.1	99.9
LANDIS & GYR	MX	C390624	05-14-02	100.0	99.9	99.7
LANDIS & GYR	MX	C390625	05-14-02	100.0	100.0	99.8
LANDIS & GYR	MX	C390626	05-14-02	100.1	100.1	99.7
LANDIS & GYR	MX	C390627	05-14-02	100.0	99.9	100.0
LANDIS & GYR	MX	C390628	05-14-02	100.0	100.0	99.6
LANDIS & GYR	MX	C390629	05-14-02	100.1	100.2	100.0
LANDIS & GYR	MX	C390630	05-14-02	100.0	99.9	99.7
LANDIS & GYR	MX	C390631	05-14-02	100.1	100.1	100.0
LANDIS & GYR	MX	C390632	05-14-02	100.0	100.1	99.9
LANDIS & GYR	MX	C390633	05-14-02	100.1	100.1	99.9
LANDIS & GYR	MX	C390634	05-14-02	100.1	100.1	100.1
LANDIS & GYR	MX	C390635	05-14-02	100.0	100.1	99.7
LANDIS & GYR	MX	C390636	05-14-02	99.9	99.9	100.0
LANDIS & GYR	MX	C390637	05-14-02	100.0	100.0	100.2
LANDIS & GYR	MX	C390638	05-14-02	100.0	100.0	99.7
LANDIS & GYR	MX	C390639	05-14-02	100.0	100.1	100.0
LANDIS & GYR	MX	C390640	05-14-02	100.0	100.0	99.8
LANDIS & GYR	MX	C390641	05-14-02	100.1	99.9	99.8
LANDIS & GYR	MX	C390642	05-14-02	100.1	100.1	100.3
LANDIS & GYR	MX	C390643	05-14-02	100.0	100.2	100.0
LANDIS & GYR	MX	C390644	05-14-02	100.0	100.1	100.2
LANDIS & GYR	MX	C390645	05-14-02	100.0	100.0	100.1
LANDIS & GYR	MX	C390646	05-14-02	100.0	100.0	100.4
LANDIS & GYR	MX	C390647	05-14-02	100.1	100.0	100.3
LANDIS & GYR	MX	C390648	05-14-02	100.0	100.0	100.1
LANDIS & GYR	MX	C390649	05-14-02	100.0	100.0	99.6
LANDIS & GYR	MX	C390650	05-14-02	100.0	100.0	99.9
LANDIS & GYR	MX	C390651	05-14-02	100.0	100.0	100.4
LANDIS & GYR	MX	C390652	05-14-02	100.0	99.9	99.9
LANDIS & GYR	MX	C390653	05-14-02	100.0	99.9	99.9
LANDIS & GYR	MX	C390654	05-14-02	99.9	99.9	99.9
LANDIS & GYR	MX	C390655	05-14-02	100.0	100.0	99.9
LANDIS & GYR	MX	C390656	05-14-02	100.1	100.1	100.1
LANDIS & GYR	MX	C390657	05-14-02	100.1	100.0	100.4
LANDIS & GYR	MX	C390658	05-14-02	100.1	99.9	99.7

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

PAGE 322
 RUN DATE: 1/14/03
 RUN TIME: 13.26.53

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
LANDIS & GYR	MX	C390659	05-14-02	100.0	100.1	100.3
LANDIS & GYR	MX	C390660	05-14-02	100.0	100.0	99.6
LANDIS & GYR	MX	C390661	05-14-02	100.0	100.2	100.0
LANDIS & GYR	MX	C390662	05-14-02	100.1	100.1	99.9
LANDIS & GYR	MX	C390663	05-14-02	100.0	100.0	99.7
LANDIS & GYR	MX	C390664	05-14-02	100.1	100.0	99.7
LANDIS & GYR	MX	C390665	05-14-02	100.1	100.0	99.9
LANDIS & GYR	MX	C390666	05-14-02	100.1	100.1	99.9
LANDIS & GYR	MX	C390667	05-14-02	100.1	100.1	99.8
LANDIS & GYR	MX	C390668	05-14-02	100.0	100.0	99.6
LANDIS & GYR	MX	C390669	05-14-02	100.1	100.1	100.4
LANDIS & GYR	MX	C390670	05-14-02	99.9	99.9	99.6
LANDIS & GYR	MX	C390671	05-14-02	100.1	100.0	99.8
LANDIS & GYR	MX	C390672	05-14-02	100.1	100.1	100.3
LANDIS & GYR	MX	C390673	05-14-02	100.1	100.1	100.6
LANDIS & GYR	MX	C390674	05-14-02	100.1	100.1	99.9
LANDIS & GYR	MX	C390675	05-14-02	100.1	100.0	99.9
LANDIS & GYR	MX	C390676	05-14-02	100.1	100.0	100.0
LANDIS & GYR	MX	C390677	05-14-02	100.1	100.1	99.9
LANDIS & GYR	MX	C390678	05-14-02	100.1	100.0	99.8
LANDIS & GYR	MX	C390679	05-14-02	100.1	100.0	100.0
LANDIS & GYR	MX	C390680	05-14-02	100.0	99.9	100.2
LANDIS & GYR	MX	C390681	05-14-02	100.0	100.0	99.8
LANDIS & GYR	MX	C390682	05-14-02	100.1	100.1	100.1
LANDIS & GYR	MX	C390683	05-14-02	100.1	100.1	99.8
LANDIS & GYR	MX	C390684	05-14-02	100.0	100.2	99.7
LANDIS & GYR	MX	C390685	05-14-02	100.1	100.0	99.8
LANDIS & GYR	MX	C390686	05-14-02	100.1	100.0	100.4
LANDIS & GYR	MX	C390687	05-14-02	100.0	99.9	99.7
LANDIS & GYR	MX	C390688	05-14-02	100.0	99.9	99.7
LANDIS & GYR	MX	C390689	05-14-02	100.1	99.9	99.9
LANDIS & GYR	MX	C390690	05-14-02	100.1	100.1	100.1
LANDIS & GYR	MX	C390691	05-14-02	100.0	100.0	99.9
LANDIS & GYR	MX	C390692	05-14-02	99.9	100.0	99.8
LANDIS & GYR	MX	C390693	05-14-02	100.0	100.0	100.1
LANDIS & GYR	MX	C390694	05-14-02	100.1	100.2	99.8
LANDIS & GYR	MX	C390695	05-14-02	100.1	100.1	99.8
LANDIS & GYR	MX	C390696	05-14-02	100.0	99.9	99.7
LANDIS & GYR	MX	C390697	05-14-02	100.0	100.1	100.1
LANDIS & GYR	MX	C390698	05-14-02	100.1	100.1	99.8
LANDIS & GYR	MX	C390699	05-14-02	100.1	100.0	99.8
LANDIS & GYR	MX	C390700	05-14-02	100.1	100.2	100.0
LANDIS & GYR	MX	C390701	05-14-02	99.9	100.0	99.6
LANDIS & GYR	MX	C390702	05-14-02	100.1	100.1	100.0
LANDIS & GYR	MX	C390703	05-14-02	100.0	100.1	99.9
LANDIS & GYR	MX	C390704	05-14-02	100.1	100.1	100.0
LANDIS & GYR	MX	C390705	05-14-02	100.1	100.1	99.9
LANDIS & GYR	MX	C390706	05-14-02	100.0	99.9	99.7
LANDIS & GYR	MX	C390707	05-14-02	100.1	100.1	100.3
LANDIS & GYR	MX	C390708	05-14-02	100.1	100.1	99.9
LANDIS & GYR	MX	C390709	05-14-02	100.0	100.0	99.9

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
LANDIS & GYR	MX	C390710	05-14-02	99.9	99.9	100.2
LANDIS & GYR	MX	C390711	05-14-02	100.0	100.0	99.9
LANDIS & GYR	MX	C390712	05-14-02	100.0	100.0	100.3
LANDIS & GYR	MX	C390713	05-14-02	100.0	100.0	100.3
LANDIS & GYR	MX	C390714	05-14-02	100.1	100.1	100.2
LANDIS & GYR	MX	C390715	05-14-02	100.0	100.0	100.0
LANDIS & GYR	MX	C390716	05-14-02	100.1	100.1	100.1
LANDIS & GYR	MX	C390717	05-14-02	100.0	100.0	100.0
LANDIS & GYR	MX	C390718	05-14-02	100.0	100.0	100.1
LANDIS & GYR	MX	C390719	05-14-02	100.0	100.0	100.2
LANDIS & GYR	MX	C390720	05-14-02	100.0	100.0	100.3
LANDIS & GYR	MX	C390721	05-14-02	100.0	100.0	100.1
LANDIS & GYR	MX	C390722	05-14-02	100.1	99.9	100.2
LANDIS & GYR	MX	C390723	05-14-02	100.0	100.0	100.0
LANDIS & GYR	MX	C390724	05-14-02	100.1	100.1	100.3
LANDIS & GYR	MX	C390725	05-14-02	100.0	99.9	100.0
LANDIS & GYR	MX	C390726	05-14-02	100.1	100.1	100.3
LANDIS & GYR	MX	C390727	05-14-02	100.0	100.0	100.1
LANDIS & GYR	MX	C390728	05-14-02	100.1	100.2	100.3
LANDIS & GYR	MX	C390729	05-14-02	100.1	100.1	100.0
LANDIS & GYR	MX	C390730	05-14-02	100.0	100.0	99.6
LANDIS & GYR	MX	C390731	05-14-02	100.1	100.1	99.8
LANDIS & GYR	MX	C390732	05-14-02	100.0	100.1	99.8
LANDIS & GYR	MX	C390733	05-14-02	100.1	100.1	100.2
LANDIS & GYR	MX	C390734	05-14-02	100.1	100.2	99.7
LANDIS & GYR	MX	C390735	05-14-02	100.1	100.2	100.3
LANDIS & GYR	MX	C390736	05-14-02	100.0	100.1	100.1
LANDIS & GYR	MX	C390737	05-14-02	100.1	100.0	99.9
LANDIS & GYR	MX	C390738	05-14-02	100.1	99.9	100.1
LANDIS & GYR	MX	C390739	05-14-02	100.1	100.1	100.1
LANDIS & GYR	MX	C390740	05-14-02	100.0	100.1	100.0
LANDIS & GYR	MX	C390741	05-14-02	100.1	100.1	100.0
LANDIS & GYR	MX	C390742	05-14-02	100.1	100.1	99.9
LANDIS & GYR	MX	C390743	05-14-02	100.1	100.1	100.0
LANDIS & GYR	MX	C390744	05-14-02	100.1	100.2	100.1
LANDIS & GYR	MX	C390745	05-14-02	100.1	100.2	100.1
LANDIS & GYR	MX	C390746	05-14-02	100.0	100.0	100.1
LANDIS & GYR	MX	C390747	05-14-02	100.0	99.9	100.0
LANDIS & GYR	MX	C390748	05-14-02	100.0	100.0	100.1
LANDIS & GYR	MX	C390749	05-14-02	100.0	100.0	99.8
LANDIS & GYR	MX	C390750	05-14-02	100.0	100.0	100.0
LANDIS & GYR	MX	C390751	05-14-02	100.1	100.2	99.8
LANDIS & GYR	MX	C390752	05-14-02	100.0	99.9	100.1
LANDIS & GYR	MX	C390753	05-14-02	100.1	100.1	100.1
LANDIS & GYR	MX	C390754	05-14-02	100.1	100.2	100.4
LANDIS & GYR	MX	C390755	05-14-02	100.0	100.1	99.7
LANDIS & GYR	MX	C390756	05-14-02	100.0	100.1	99.7
LANDIS & GYR	MX	C390757	05-14-02	100.0	99.9	99.8
LANDIS & GYR	MX	C390758	05-14-02	100.0	100.0	100.2
LANDIS & GYR	MX	C390759	05-14-02	100.0	100.0	100.2
LANDIS & GYR	MX	C390760	05-14-02	100.0	100.1	99.7

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

PAGE 324
 RUN DATE: 1/14/03
 RUN TIME: 13.26.53

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
LANDIS & GYR	MX	C390761	05-14-02	100.0	100.0	100.3
LANDIS & GYR	MX	C390762	05-14-02	100.1	100.0	99.7
LANDIS & GYR	MX	C390763	05-14-02	100.0	99.9	100.2
LANDIS & GYR	MX	C390764	05-14-02	100.1	100.1	100.3
LANDIS & GYR	MX	C390765	05-14-02	100.1	100.1	100.2
LANDIS & GYR	MX	C390766	05-14-02	100.0	99.9	99.9
LANDIS & GYR	MX	C390767	05-14-02	100.1	100.1	100.3
LANDIS & GYR	MX	C390768	05-14-02	100.0	100.0	99.7
LANDIS & GYR	MX	C390769	05-14-02	100.1	100.1	100.1
LANDIS & GYR	MX	C390770	05-14-02	100.0	99.9	99.8
LANDIS & GYR	MX	C390771	05-14-02	100.0	100.1	99.9
LANDIS & GYR	MX	C390772	05-14-02	100.1	100.1	99.9
LANDIS & GYR	MX	C390773	05-14-02	100.1	100.0	100.0
LANDIS & GYR	MX	C390774	05-14-02	100.0	100.0	100.2
LANDIS & GYR	MX	C390775	05-14-02	100.1	100.2	99.7
LANDIS & GYR	MX	C390776	05-14-02	100.1	100.0	99.9
LANDIS & GYR	MX	C390777	05-14-02	100.1	100.2	100.0
LANDIS & GYR	MX	C390778	05-14-02	100.1	100.1	99.8
LANDIS & GYR	MX	C390779	05-14-02	100.1	100.1	99.9
LANDIS & GYR	MX	C390780	05-14-02	100.0	100.0	99.7
LANDIS & GYR	MX	C390781	05-14-02	100.0	100.0	100.0
LANDIS & GYR	MX	C390782	05-14-02	100.0	100.2	99.6
LANDIS & GYR	MX	C390783	05-14-02	100.0	100.0	99.7
LANDIS & GYR	MX	C390784	05-14-02	100.1	100.2	100.0
LANDIS & GYR	MX	C390785	05-14-02	100.1	100.1	99.9
LANDIS & GYR	MX	C390786	05-14-02	100.0	100.2	100.4
LANDIS & GYR	MX	C390787	05-14-02	100.0	100.0	100.2
LANDIS & GYR	MX	C390788	05-14-02	100.1	100.1	99.8
LANDIS & GYR	MX	C390789	05-14-02	100.0	99.9	100.2
LANDIS & GYR	MX	C390790	05-14-02	100.1	100.2	99.8
LANDIS & GYR	MX	C390791	05-14-02	100.1	100.1	99.9
LANDIS & GYR	MX	C390792	05-14-02	100.1	100.0	99.7
LANDIS & GYR	MX	C390793	05-14-02	100.1	100.2	99.7
LANDIS & GYR	MX	C390794	05-14-02	100.0	100.1	100.0
LANDIS & GYR	MX	C390795	05-14-02	100.1	100.1	99.9
LANDIS & GYR	MX	C390796	05-14-02	100.1	100.1	99.8
LANDIS & GYR	MX	C390797	05-14-02	100.0	99.9	100.0
LANDIS & GYR	MX	C390798	05-14-02	100.0	100.0	99.9
LANDIS & GYR	MX	C390799	05-14-02	100.1	100.1	99.8
LANDIS & GYR	MX	C390800	05-14-02	100.1	100.1	99.9
LANDIS & GYR	MX	C390801	05-14-02	100.1	100.0	100.2
LANDIS & GYR	MX	C390802	05-14-02	100.1	100.1	99.9
LANDIS & GYR	MX	C390803	05-14-02	100.0	100.0	100.0
LANDIS & GYR	MX	C390804	05-14-02	100.1	99.9	100.4
LANDIS & GYR	MX	C390805	05-14-02	100.0	100.1	99.9
LANDIS & GYR	MX	C390806	05-14-02	100.0	100.0	100.2
LANDIS & GYR	MX	C390807	05-14-02	100.0	100.1	99.8
LANDIS & GYR	MX	C390808	05-14-02	100.1	100.0	99.8
LANDIS & GYR	MX	C390809	05-14-02	100.0	100.1	100.2
LANDIS & GYR	MX	C390810	05-14-02	100.0	100.1	99.9
LANDIS & GYR	MX	C390811	05-14-02	100.1	100.0	99.7

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

PAGE 325
 RUN DATE: 1/14/03
 RUN TIME: 13.26.53

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
LANDIS & GYR	MX	C390812	05-14-02	100.0	100.0	99.6
LANDIS & GYR	MX	C390813	05-14-02	100.1	100.1	100.3
LANDIS & GYR	MX	C390814	05-14-02	100.0	100.1	100.0
LANDIS & GYR	MX	C390815	05-14-02	100.0	99.9	99.6
LANDIS & GYR	MX	C390816	05-14-02	100.1	100.2	100.3
LANDIS & GYR	MX	C390817	05-14-02	100.1	100.1	99.9
LANDIS & GYR	MX	C390818	05-14-02	100.0	100.0	99.8
LANDIS & GYR	MX	C390819	05-14-02	100.1	100.1	100.0
LANDIS & GYR	MX	C390820	05-14-02	100.1	99.9	100.0
LANDIS & GYR	MX	C390821	05-14-02	100.1	100.0	99.9
LANDIS & GYR	MX	C390822	05-14-02	100.1	100.2	100.1
LANDIS & GYR	MX	C390823	05-14-02	100.0	100.0	100.4
LANDIS & GYR	MX	C390824	05-14-02	100.0	100.1	99.8
LANDIS & GYR	MX	C390825	05-14-02	100.1	100.1	100.4
LANDIS & GYR	MX	C390826	05-14-02	100.0	100.0	99.9
LANDIS & GYR	MX	C390827	05-14-02	100.0	100.0	99.8
LANDIS & GYR	MX	C390828	05-14-02	100.1	99.9	100.3
LANDIS & GYR	MX	C390829	05-14-02	100.1	100.0	100.2
LANDIS & GYR	MX	C390830	05-14-02	99.9	99.9	99.9
LANDIS & GYR	MX	C390831	05-14-02	100.1	100.1	99.7
LANDIS & GYR	MX	C390832	05-14-02	99.9	99.9	99.6
LANDIS & GYR	MX	C390833	05-14-02	100.0	100.0	99.9
LANDIS & GYR	MX	C390834	05-14-02	100.0	100.0	99.8
LANDIS & GYR	MX	C390835	05-14-02	100.0	99.9	99.6
LANDIS & GYR	MX	C390836	05-14-02	100.1	100.0	99.6
LANDIS & GYR	MX	C390837	05-14-02	100.0	100.0	100.1
LANDIS & GYR	MX	C390838	05-14-02	100.0	100.2	99.7
LANDIS & GYR	MX	C390839	05-14-02	100.0	100.1	99.9
LANDIS & GYR	MX	C390840	05-14-02	100.0	100.0	99.6
LANDIS & GYR	MX	C390841	05-14-02	100.1	100.1	99.9
LANDIS & GYR	MX	C390842	05-14-02	100.1	100.1	99.6
LANDIS & GYR	MX	C390843	05-14-02	100.1	100.0	100.2
LANDIS & GYR	MX	C390844	05-14-02	100.0	100.0	100.3
LANDIS & GYR	MX	C390845	05-14-02	100.0	100.0	99.8
LANDIS & GYR	MX	C390846	05-14-02	100.0	100.0	99.8
LANDIS & GYR	MX	C390847	05-14-02	100.0	99.9	99.8
LANDIS & GYR	MX	C390848	05-14-02	100.1	100.1	100.2
LANDIS & GYR	MX	C390849	05-14-02	100.0	100.0	100.2
LANDIS & GYR	MX	C390850	05-14-02	100.1	100.0	100.2
LANDIS & GYR	MX	C390851	05-14-02	100.1	100.1	100.2
LANDIS & GYR	MX	C390852	05-14-02	100.1	99.9	100.0
LANDIS & GYR	MX	C390853	05-14-02	100.0	100.0	100.2
LANDIS & GYR	MX	C390854	05-14-02	100.1	100.1	100.1
LANDIS & GYR	MX	C390855	05-14-02	100.0	100.0	100.1
LANDIS & GYR	MX	C390856	05-14-02	100.0	99.9	100.0
LANDIS & GYR	MX	C390857	05-14-02	100.1	100.0	99.9
LANDIS & GYR	MX	C390858	05-14-02	100.1	100.1	100.1
LANDIS & GYR	MX	C390859	05-13-02	100.0	100.0	100.0
LANDIS & GYR	MX	C390860	05-14-02	100.0	99.9	100.0
LANDIS & GYR	MX	C390861	05-14-02	100.1	100.1	100.6
LANDIS & GYR	MX	C390862	05-14-02	99.9	100.1	99.9

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

PAGE 326
 RUN DATE: 1/14/03
 RUN TIME: 13.26.53

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
LANDIS & GYR	MX	C390863	05-14-02	100.1	100.2	100.3
LANDIS & GYR	MX	C390864	05-14-02	100.0	100.1	99.7
LANDIS & GYR	MX	C390865	05-14-02	100.0	100.1	99.9
LANDIS & GYR	MX	C390866	05-14-02	100.0	100.0	99.8
LANDIS & GYR	MX	C390867	05-14-02	100.0	100.1	99.8
LANDIS & GYR	MX	C390868	05-14-02	100.0	100.1	100.3
LANDIS & GYR	MX	C390869	05-14-02	100.1	100.1	100.0
LANDIS & GYR	MX	C390870	05-14-02	100.0	100.0	100.0
LANDIS & GYR	MX	C390871	05-14-02	100.1	100.1	99.8
LANDIS & GYR	MX	C390872	05-14-02	100.0	100.0	100.2
LANDIS & GYR	MX	C390873	05-14-02	100.1	100.2	99.9
LANDIS & GYR	MX	C390874	05-14-02	100.1	100.1	100.0
LANDIS & GYR	MX	C390875	05-14-02	100.0	100.0	100.2
LANDIS & GYR	MX	C390876	05-14-02	100.0	100.1	99.8
LANDIS & GYR	MX	C390877	05-14-02	100.1	100.1	99.9
LANDIS & GYR	MX	C390878	05-14-02	100.1	100.1	100.2
LANDIS & GYR	MX	C390879	05-14-02	100.1	100.1	100.2
LANDIS & GYR	MX	C390880	05-14-02	100.1	100.1	100.2
LANDIS & GYR	MX	C390881	05-14-02	100.0	99.9	99.9
LANDIS & GYR	MX	C390882	05-14-02	100.0	100.1	100.2
LANDIS & GYR	MX	C390883	05-14-02	100.1	100.2	100.4
LANDIS & GYR	MX	C390884	05-14-02	100.0	100.1	100.1
LANDIS & GYR	MX	C390885	05-14-02	100.0	100.0	100.1
LANDIS & GYR	MX	C390886	05-14-02	100.0	100.0	100.3
LANDIS & GYR	MX	C390887	05-14-02	100.0	99.9	100.2
LANDIS & GYR	MX	C390888	05-14-02	100.1	100.1	100.2
LANDIS & GYR	MX	C390889	05-14-02	100.0	100.0	100.2
LANDIS & GYR	MX	C390890	05-14-02	100.0	100.0	99.9
LANDIS & GYR	MX	C390891	05-14-02	100.0	100.1	99.6
LANDIS & GYR	MX	C390892	05-14-02	100.0	100.0	100.3
LANDIS & GYR	MX	C390893	05-14-02	100.0	99.9	99.8
LANDIS & GYR	MX	C390894	05-14-02	100.1	100.0	100.3
LANDIS & GYR	MX	C390895	05-14-02	100.1	100.0	100.5
LANDIS & GYR	MX	C390896	05-14-02	100.1	100.1	100.2
LANDIS & GYR	MX	C390897	05-14-02	100.1	100.0	100.0
LANDIS & GYR	MX	C390898	05-14-02	100.1	100.2	100.3
LANDIS & GYR	MX	C390899	05-14-02	100.1	100.1	100.6
LANDIS & GYR	MX	C390900	05-14-02	100.0	100.0	99.9
LANDIS & GYR	MX	C390901	05-14-02	100.0	99.9	100.6
LANDIS & GYR	MX	C390902	05-14-02	100.0	100.0	99.9
LANDIS & GYR	MX	C390903	05-14-02	100.0	100.0	100.1
LANDIS & GYR	MX	C390904	05-14-02	100.1	100.1	100.5
LANDIS & GYR	MX	C390905	05-14-02	100.1	100.1	100.2
LANDIS & GYR	MX	C390906	05-14-02	100.1	100.1	100.0
LANDIS & GYR	MX	C390907	05-14-02	100.0	99.9	99.7
LANDIS & GYR	MX	C390908	05-14-02	100.1	100.1	100.4
LANDIS & GYR	MX	C390909	05-14-02	100.1	100.1	100.4
LANDIS & GYR	MX	C390910	05-14-02	100.0	100.0	100.4
LANDIS & GYR	MX	C390911	05-14-02	100.0	100.0	99.8
LANDIS & GYR	MX	C390912	05-14-02	100.1	100.1	100.2
LANDIS & GYR	MX	C390913	05-14-02	100.0	100.1	100.1

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
LANDIS & GYR	MX	C390914	05-14-02	100.0	100.0	100.2
LANDIS & GYR	MX	C390915	05-14-02	100.0	100.0	99.9
LANDIS & GYR	MX	C390916	05-14-02	100.1	100.0	100.1
LANDIS & GYR	MX	C390917	05-14-02	100.0	100.1	100.5
LANDIS & GYR	MX	C390918	05-14-02	100.0	100.1	100.3
LANDIS & GYR	MX	C390919	05-14-02	100.1	100.0	100.3
LANDIS & GYR	MX	C390920	05-14-02	100.0	99.9	99.9
LANDIS & GYR	MX	C390921	05-14-02	100.0	99.9	100.0
LANDIS & GYR	MX	C390922	05-14-02	100.0	99.9	99.9
LANDIS & GYR	MX	C390923	05-14-02	100.0	100.0	99.8
LANDIS & GYR	MX	C390924	05-14-02	100.0	100.0	100.0
LANDIS & GYR	MX	C390925	05-14-02	100.1	100.1	100.3
LANDIS & GYR	MX	C390926	05-14-02	100.0	99.9	100.5
LANDIS & GYR	MX	C390927	05-14-02	100.0	100.0	100.3
LANDIS & GYR	MX	C390928	05-14-02	100.0	100.0	100.0
LANDIS & GYR	MX	C390929	05-14-02	100.0	100.1	100.2
LANDIS & GYR	MX	C390930	05-14-02	100.1	100.1	100.5
LANDIS & GYR	MX	C390931	05-14-02	100.1	100.1	100.0
LANDIS & GYR	MX	C390932	05-14-02	100.0	99.9	99.7
LANDIS & GYR	MX	C390933	05-14-02	100.0	99.9	100.3
LANDIS & GYR	MX	C390934	05-14-02	100.0	100.0	100.1
LANDIS & GYR	MX	C390935	05-14-02	100.0	99.9	100.1
LANDIS & GYR	MX	C390936	05-14-02	100.1	99.9	99.6
LANDIS & GYR	MX	C390937	05-14-02	100.0	99.9	100.2
LANDIS & GYR	MX	C390938	05-14-02	100.0	100.1	100.1
LANDIS & GYR	MX	C390939	05-14-02	100.0	100.0	100.2
LANDIS & GYR	MX	C390940	05-14-02	100.0	100.0	99.9
LANDIS & GYR	MX	C390941	05-14-02	100.0	100.0	99.6
LANDIS & GYR	MX	C390942	05-14-02	100.1	100.1	99.9
LANDIS & GYR	MX	C390943	05-14-02	100.0	100.0	100.3
LANDIS & GYR	MX	C390944	05-14-02	100.1	100.0	100.1
LANDIS & GYR	MX	C390945	05-14-02	100.1	100.0	100.1
LANDIS & GYR	MX	C390946	05-14-02	100.0	100.0	99.9
LANDIS & GYR	MX	C390947	05-14-02	100.1	100.2	99.9
LANDIS & GYR	MX	C390948	05-14-02	100.0	100.0	99.6
LANDIS & GYR	MX	C390949	05-14-02	100.1	100.1	99.9
LANDIS & GYR	MX	C390950	05-14-02	100.0	100.1	99.8
LANDIS & GYR	MX	C390951	05-14-02	100.1	100.1	100.0
LANDIS & GYR	MX	C390952	05-14-02	100.1	100.1	99.8
LANDIS & GYR	MX	C390953	05-14-02	100.0	100.1	100.3
LANDIS & GYR	MX	C390954	05-14-02	100.1	100.0	100.0
LANDIS & GYR	MX	C390955	05-14-02	100.1	100.2	100.0
LANDIS & GYR	MX	C390956	05-14-02	100.0	100.0	99.9
LANDIS & GYR	MX	C390957	05-14-02	100.0	100.0	100.0
LANDIS & GYR	MX	C390958	05-14-02	100.0	100.0	100.2
LANDIS & GYR	MX	C390959	05-14-02	100.0	100.1	99.9
LANDIS & GYR	MX	C390960	05-14-02	100.1	100.0	99.9
LANDIS & GYR	MX	C390961	05-14-02	100.0	100.0	100.1
LANDIS & GYR	MX	C390962	05-14-02	100.0	100.0	100.1
LANDIS & GYR	MX	C390963	05-14-02	100.0	100.0	99.8
LANDIS & GYR	MX	C390964	05-14-02	100.0	100.1	99.8

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
& GYR		C390965	05-14-02	100.0	100.1	99.8
& GYR		C390966	05-14-02	100.0	99.9	100.1
& GYR		C390967	05-14-02	100.1	100.1	100.1
& GYR		C390968	05-14-02	100.1	100.0	100.4
& GYR		C390969	05-14-02	100.1	100.1	99.8
& GYR		C390970	05-14-02	99.9	100.0	99.8
& GYR		C390971	05-14-02	100.0	100.2	99.9
& GYR		C390972	05-14-02	100.0	99.9	100.3
& GYR		C390973	05-14-02	99.9	100.0	100.2
& GYR		C390974	05-14-02	100.0	100.0	99.9
& GYR		C390975	05-14-02	100.1	100.0	99.9
& GYR		C390976	05-14-02	100.1	100.1	100.1
& GYR		C390977	05-14-02	100.1	100.1	100.0
& GYR		C390978	05-14-02	100.0	100.0	100.2
& GYR		C390979	05-14-02	100.0	100.0	99.8
& GYR		C390980	05-14-02	100.0	100.0	99.9
& GYR		C390981	05-14-02	100.0	100.1	99.7
& GYR		C390982	05-14-02	100.0	100.0	100.0
& GYR		C390983	05-14-02	100.0	100.0	99.7
& GYR		C390984	05-14-02	100.1	100.1	100.0
& GYR		C390985	05-14-02	100.1	100.1	99.8
& GYR		C390986	05-14-02	100.1	100.0	99.9
& GYR		C390987	05-14-02	100.1	100.1	100.2
& GYR		C390988	05-14-02	100.1	100.2	99.7
& GYR		C390989	05-14-02	100.1	100.0	100.1
& GYR		C390990	05-14-02	100.0	99.9	100.0
& GYR		C390991	05-14-02	100.1	100.0	99.9
& GYR		C390992	05-14-02	100.1	100.1	99.7
& GYR		C390993	05-14-02	100.0	100.0	100.0
& GYR		C390994	05-14-02	99.9	100.1	99.9
& GYR		C390995	05-14-02	100.0	100.0	100.1
& GYR		C390996	05-14-02	100.1	100.0	100.2
& GYR		C390997	05-14-02	100.0	100.1	100.0
& GYR		C390998	05-14-02	100.0	100.0	99.9
& GYR		C390999	05-14-02	100.0	100.0	100.0
& GYR		C391000	05-14-02	100.0	100.1	99.9
& GYR		C391001	05-14-02	100.1	100.1	100.3
& GYR		C391002	05-14-02	100.1	100.1	100.0
& GYR		C391003	05-14-02	100.0	100.0	99.9
& GYR		C391004	05-14-02	100.1	100.1	100.0
& GYR		C391005	05-14-02	99.9	100.0	99.9
& GYR		C391006	05-14-02	100.0	99.9	100.1
& GYR		C391007	05-14-02	100.0	99.9	100.0
& GYR		C391008	05-14-02	100.0	100.2	100.4
& GYR		C391009	05-14-02	100.1	100.0	99.9
& GYR		C391010	05-14-02	100.0	100.1	99.8
& GYR		C391011	05-14-02	100.1	100.1	99.9
& GYR		C391012	05-14-02	100.1	100.0	100.6
& GYR		C391013	05-14-02	100.0	100.1	99.7
& GYR		C391014	05-14-02	100.1	100.0	100.6
& GYR		C391015	05-14-02	100.0	100.0	100.0

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
LANDIS & GYR	MX	C391016	05-14-02	100.0	100.2	100.1
LANDIS & GYR	MX	C391017	05-14-02	100.1	100.1	100.1
LANDIS & GYR	MX	C391018	05-14-02	100.0	100.0	99.8
LANDIS & GYR	MX	C391019	05-14-02	100.0	99.9	99.8
LANDIS & GYR	MX	C391020	05-14-02	100.0	100.1	99.9
LANDIS & GYR	MX	C391021	05-14-02	100.1	100.2	99.6
LANDIS & GYR	MX	C391022	05-14-02	100.1	100.1	100.2
LANDIS & GYR	MX	C391023	05-14-02	100.0	99.9	99.9
LANDIS & GYR	MX	C391024	05-14-02	100.1	100.1	100.1
LANDIS & GYR	MX	C391025	05-14-02	100.1	99.9	100.4
LANDIS & GYR	MX	C391026	05-14-02	100.0	99.9	99.9
LANDIS & GYR	MX	C391027	05-14-02	100.1	100.0	100.0
LANDIS & GYR	MX	C391028	05-14-02	100.0	100.1	99.8
LANDIS & GYR	MX	C391029	05-14-02	100.0	99.9	100.2
LANDIS & GYR	MX	C391030	05-14-02	100.0	100.1	99.8
LANDIS & GYR	MX	C391031	05-14-02	100.1	100.1	100.2
LANDIS & GYR	MX	C391032	05-14-02	100.0	99.9	99.8
LANDIS & GYR	MX	C391033	05-14-02	100.0	99.9	99.8
LANDIS & GYR	MX	C391034	05-14-02	100.1	99.9	100.3
LANDIS & GYR	MX	C391035	05-14-02	100.0	99.9	99.9
LANDIS & GYR	MX	C391036	05-14-02	100.1	100.1	99.9
LANDIS & GYR	MX	C391037	05-14-02	100.1	100.2	100.0
LANDIS & GYR	MX	C391038	05-14-02	100.0	99.9	100.1
LANDIS & GYR	MX	C391039	05-14-02	100.1	100.1	100.1
LANDIS & GYR	MX	C391040	05-14-02	100.0	100.0	100.4
LANDIS & GYR	MX	C391041	05-14-02	100.0	100.1	99.7
LANDIS & GYR	MX	C391042	05-13-02	100.0	100.0	99.8
LANDIS & GYR	MX	C391043	05-14-02	100.0	100.0	99.9
LANDIS & GYR	MX	C391044	05-14-02	100.1	100.1	100.0
LANDIS & GYR	MX	C391045	05-14-02	100.0	100.0	100.0
LANDIS & GYR	MX	C391046	05-14-02	100.1	100.2	100.0
LANDIS & GYR	MX	C391047	05-14-02	100.0	99.9	100.1
LANDIS & GYR	MX	C391048	05-14-02	100.0	100.1	99.8
LANDIS & GYR	MX	C391049	05-14-02	100.1	99.9	99.6
LANDIS & GYR	MX	C391050	05-14-02	100.0	100.1	100.0
LANDIS & GYR	MX	C391051	05-14-02	100.0	100.0	99.9
LANDIS & GYR	MX	C391052	05-14-02	100.1	100.1	100.2
LANDIS & GYR	MX	C391053	05-14-02	100.1	100.1	100.0
LANDIS & GYR	MX	C391054	05-14-02	100.0	100.1	100.0
LANDIS & GYR	MX	C391055	05-14-02	100.0	100.0	99.9
LANDIS & GYR	MX	C391056	05-14-02	100.1	100.0	100.5
LANDIS & GYR	MX	C391057	05-14-02	100.1	100.1	100.0
LANDIS & GYR	MX	C391058	05-14-02	99.9	99.9	99.8
LANDIS & GYR	MX	C391059	05-14-02	100.1	100.1	100.0
LANDIS & GYR	MX	C391060	05-14-02	100.1	100.0	100.0
LANDIS & GYR	MX	C391061	05-14-02	100.0	100.0	99.8
LANDIS & GYR	MX	C391062	05-14-02	100.0	100.0	99.8
LANDIS & GYR	MX	C391063	05-14-02	100.1	100.2	100.1
LANDIS & GYR	MX	C391064	05-14-02	100.1	100.1	100.1
LANDIS & GYR	MX	C391065	05-14-02	100.1	100.0	100.2
LANDIS & GYR	MX	C391066	05-14-02	100.1	100.0	100.0

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

PAGE 330
 RUN DATE: 1/14/03
 RUN TIME: 13.26.53

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
LANDIS & GYR	MX	C391067	05-14-02	100.1	100.0	100.1
LANDIS & GYR	MX	C391068	05-14-02	100.0	100.0	100.0
LANDIS & GYR	MX	C391069	05-14-02	100.0	100.1	100.5
LANDIS & GYR	MX	C391070	05-14-02	100.0	100.0	100.1
LANDIS & GYR	MX	C391071	05-07-02	100.0	100.0	100.1
LANDIS & GYR	MX	C391072	05-14-02	100.0	100.0	99.9
LANDIS & GYR	MX	C391073	05-14-02	100.1	99.9	100.2
LANDIS & GYR	MX	C391074	05-14-02	100.1	100.1	100.1
LANDIS & GYR	MX	C391075	05-14-02	100.1	100.1	100.5
LANDIS & GYR	MX	C391076	05-14-02	100.0	100.0	100.4
LANDIS & GYR	MX	C391077	05-14-02	100.1	100.0	100.4
LANDIS & GYR	MX	C391078	05-14-02	100.1	100.0	100.2
LANDIS & GYR	MX	C391079	05-14-02	100.1	100.1	100.1
LANDIS & GYR	MX	C391080	05-14-02	100.1	100.1	100.0
LANDIS & GYR	MX	C391081	05-14-02	100.0	99.9	99.7
LANDIS & GYR	MX	C391082	05-14-02	100.0	100.0	100.0
LANDIS & GYR	MX	C391083	05-14-02	100.1	100.1	99.9
LANDIS & GYR	MX	C391084	05-14-02	100.1	100.0	100.1
LANDIS & GYR	MX	C391085	05-14-02	100.1	100.1	100.2
LANDIS & GYR	MX	C391086	05-14-02	100.0	100.1	99.9
LANDIS & GYR	MX	C391087	05-14-02	100.0	100.0	100.0
LANDIS & GYR	MX	C391088	05-14-02	100.0	100.0	100.3
LANDIS & GYR	MX	C391089	05-14-02	100.1	100.1	100.2
LANDIS & GYR	MX	C391090	05-14-02	100.1	100.1	99.8
LANDIS & GYR	MX	C391091	05-14-02	100.0	100.1	100.1
LANDIS & GYR	MX	C391092	05-14-02	100.1	99.9	99.5
LANDIS & GYR	MX	C391093	05-14-02	100.0	100.0	100.1
LANDIS & GYR	MX	C391094	05-14-02	100.1	100.0	100.5
LANDIS & GYR	MX	C391095	05-07-02	100.0	100.1	100.2
LANDIS & GYR	MX	C391096	05-14-02	100.0	99.9	99.9
LANDIS & GYR	MX	C391097	05-14-02	100.0	100.1	100.3
LANDIS & GYR	MX	C391098	05-14-02	100.0	100.0	99.8
LANDIS & GYR	MX	C391099	05-15-02	100.0	100.1	99.8
LANDIS & GYR	MX	C391100	05-14-02	100.1	100.1	100.2
LANDIS & GYR	MX	C391101	05-14-02	100.1	100.2	100.2
LANDIS & GYR	MX	C391102	05-14-02	100.0	100.1	100.1
LANDIS & GYR	MX	C391103	05-14-02	100.1	100.1	99.9
LANDIS & GYR	MX	C391104	05-14-02	100.1	100.1	99.9
LANDIS & GYR	MX	C391105	05-14-02	100.1	100.2	100.3
LANDIS & GYR	MX	C391106	05-14-02	100.1	100.1	100.3
LANDIS & GYR	MX	C391107	05-14-02	100.1	100.1	99.8
LANDIS & GYR	MX	C391108	05-14-02	100.1	100.1	100.4
LANDIS & GYR	MX	C391109	05-14-02	100.1	100.0	100.5
LANDIS & GYR	MX	C391110	05-14-02	100.1	100.1	99.7
LANDIS & GYR	MX	C391111	05-14-02	100.1	100.1	100.1
LANDIS & GYR	MX	C391112	05-14-02	100.0	100.0	100.2
LANDIS & GYR	MX	C391113	05-14-02	100.1	100.0	100.4
LANDIS & GYR	MX	C391114	05-14-02	100.1	100.2	100.2
LANDIS & GYR	MX	C391115	05-14-02	100.0	100.1	100.0
LANDIS & GYR	MX	C391116	05-14-02	100.0	100.1	100.2
LANDIS & GYR	MX	C391117	05-14-02	100.0	100.0	100.1

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

PAGE 331
 RUN DATE: 1/14/03
 RUN TIME: 13.26.53

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
LANDIS & GYR	MX	C391118	05-14-02	100.1	100.1	100.1
LANDIS & GYR	MX	C391119	05-14-02	100.0	100.0	99.9
LANDIS & GYR	MX	C391120	05-14-02	100.0	100.1	100.0
LANDIS & GYR	MX	C391121	05-14-02	100.0	99.9	99.8
LANDIS & GYR	MX	C391122	05-14-02	100.1	100.1	100.3
LANDIS & GYR	MX	C391123	05-14-02	100.1	100.1	100.1
LANDIS & GYR	MX	C391124	05-14-02	100.1	100.1	100.0
LANDIS & GYR	MX	C391125	05-14-02	100.1	100.1	99.9
LANDIS & GYR	MX	C391126	05-14-02	100.0	100.0	100.2
LANDIS & GYR	MX	C391127	05-14-02	100.1	100.1	100.0
LANDIS & GYR	MX	C391128	05-14-02	100.1	100.1	100.0
LANDIS & GYR	MX	C391129	05-14-02	100.1	100.1	100.0
LANDIS & GYR	MX	C391130	05-14-02	100.1	100.2	99.9
LANDIS & GYR	MX	C391131	05-14-02	100.0	100.0	100.6
LANDIS & GYR	MX	C391132	05-14-02	100.0	100.0	100.2
LANDIS & GYR	MX	C391133	05-14-02	100.0	100.0	100.0
LANDIS & GYR	MX	C391134	05-14-02	100.0	99.9	99.8
LANDIS & GYR	MX	C391135	05-14-02	100.0	100.1	100.0
LANDIS & GYR	MX	C391136	05-14-02	100.0	100.0	99.6
LANDIS & GYR	MX	C391137	05-14-02	100.0	99.9	100.3
LANDIS & GYR	MX	C391138	05-14-02	99.9	99.9	100.7
LANDIS & GYR	MX	C391139	05-14-02	100.1	100.1	100.1
LANDIS & GYR	MX	C391140	05-14-02	100.1	100.0	99.9
LANDIS & GYR	MX	C391141	05-14-02	100.0	100.1	99.7
LANDIS & GYR	MX	C391142	05-14-02	100.0	99.9	99.9
LANDIS & GYR	MX	C391143	05-14-02	100.0	100.0	99.9
LANDIS & GYR	MX	C391144	05-14-02	100.0	100.1	99.8
LANDIS & GYR	MX	C391145	05-14-02	100.1	100.2	100.1
LANDIS & GYR	MX	C391146	05-14-02	100.0	100.0	100.1
LANDIS & GYR	MX	C391147	05-14-02	100.0	99.9	99.9
LANDIS & GYR	MX	C391148	05-14-02	100.0	100.0	99.9
LANDIS & GYR	MX	C391149	05-14-02	100.1	100.2	99.9
LANDIS & GYR	MX	C391150	05-14-02	100.1	100.1	100.2
LANDIS & GYR	MX	C391151	05-14-02	100.0	100.0	100.2
LANDIS & GYR	MX	C391152	05-14-02	100.1	100.0	99.7
LANDIS & GYR	MX	C391153	05-14-02	100.0	100.0	99.9
LANDIS & GYR	MX	C391154	05-14-02	100.0	100.0	100.2
LANDIS & GYR	MX	C391155	05-14-02	100.0	100.0	100.2
LANDIS & GYR	MX	C391156	05-14-02	100.0	100.0	100.2
LANDIS & GYR	MX	C391157	05-14-02	100.0	100.0	99.7
LANDIS & GYR	MX	C391158	05-14-02	100.1	100.1	100.1
LANDIS & GYR	MX	C391159	05-14-02	100.1	100.0	99.9
LANDIS & GYR	MX	C391160	05-14-02	100.1	100.0	100.2
LANDIS & GYR	MX	C391161	05-14-02	100.1	100.1	100.0
LANDIS & GYR	MX	C391162	05-14-02	100.1	100.1	100.4
LANDIS & GYR	MX	C391163	05-14-02	100.1	100.1	100.1
LANDIS & GYR	MX	C391164	05-14-02	100.1	100.1	100.0
LANDIS & GYR	MX	C391165	05-14-02	100.1	100.1	100.1
LANDIS & GYR	MX	C391166	05-14-02	100.1	100.1	100.1
LANDIS & GYR	MX	C391167	05-14-02	100.1	100.1	100.4
LANDIS & GYR	MX	C391168	05-14-02	100.1	100.0	100.2

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

PAGE 332
 RUN DATE: 1/14/03
 RUN TIME: 13.26.53

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
LANDIS & GYR	MX	C391169	05-14-02	100.1	99.9	100.2
LANDIS & GYR	MX	C391170	05-14-02	100.1	100.0	100.3
LANDIS & GYR	MX	C391171	05-14-02	100.1	100.1	99.9
LANDIS & GYR	MX	C391172	05-14-02	100.0	100.0	100.1
LANDIS & GYR	MX	C391173	05-14-02	100.1	99.9	100.2
LANDIS & GYR	MX	C391174	05-14-02	100.1	100.0	99.9
LANDIS & GYR	MX	C391175	05-14-02	100.0	99.9	100.1
LANDIS & GYR	MX	C391176	05-14-02	100.0	100.0	99.9
LANDIS & GYR	MX	C391177	05-14-02	100.1	100.1	99.9
LANDIS & GYR	MX	C391178	05-14-02	100.1	100.1	99.9
LANDIS & GYR	MX	C391179	05-14-02	100.0	100.1	99.8
LANDIS & GYR	MX	C391180	05-14-02	100.1	100.1	100.3
LANDIS & GYR	MX	C391181	05-14-02	100.1	100.1	100.4
LANDIS & GYR	MX	C391182	05-14-02	100.0	100.1	99.8
LANDIS & GYR	MX	C391183	05-14-02	100.1	100.1	99.9
LANDIS & GYR	MX	C391184	05-14-02	100.0	100.1	100.3
LANDIS & GYR	MX	C391185	05-14-02	100.1	99.9	100.2
LANDIS & GYR	MX	C391186	05-14-02	100.0	100.1	100.0
LANDIS & GYR	MX	C391187	05-14-02	100.1	100.1	100.2
LANDIS & GYR	MX	C391188	05-14-02	100.0	100.0	99.5
LANDIS & GYR	MX	C391189	05-14-02	100.1	99.9	99.9
LANDIS & GYR	MX	C391190	05-14-02	100.1	100.0	100.3
LANDIS & GYR	MX	C391191	05-14-02	100.0	100.1	99.8
LANDIS & GYR	MX	C391192	05-14-02	100.1	100.1	100.0
LANDIS & GYR	MX	C391193	05-14-02	100.0	100.1	99.8
LANDIS & GYR	MX	C391194	05-14-02	100.1	100.1	99.9
LANDIS & GYR	MX	C391195	05-14-02	100.0	100.1	100.3
LANDIS & GYR	MX	C391196	05-14-02	100.0	99.9	100.1
LANDIS & GYR	MX	C391197	05-14-02	100.0	100.0	99.9
LANDIS & GYR	MX	C391198	05-14-02	100.1	100.0	100.4
LANDIS & GYR	MX	C391199	05-14-02	100.1	100.2	100.0
LANDIS & GYR	MX	C391200	05-14-02	100.0	100.0	99.6
LANDIS & GYR	MX	C391201	05-14-02	100.0	100.0	100.3
LANDIS & GYR	MX	C391202	05-14-02	100.1	100.1	99.9
LANDIS & GYR	MX	C391203	05-14-02	100.0	99.9	99.6
LANDIS & GYR	MX	C391204	05-14-02	100.0	100.1	100.5
LANDIS & GYR	MX	C391205	05-14-02	100.1	100.1	100.3
LANDIS & GYR	MX	C391206	05-14-02	100.1	100.1	100.0
LANDIS & GYR	MX	C391207	05-14-02	100.0	100.0	100.0
LANDIS & GYR	MX	C391208	05-14-02	100.0	100.1	99.6
LANDIS & GYR	MX	C391209	05-14-02	100.0	100.1	99.8
LANDIS & GYR	MX	C391210	05-14-02	100.1	100.0	99.5
LANDIS & GYR	MX	C391211	05-14-02	100.0	100.0	100.2
LANDIS & GYR	MX	C391212	05-14-02	100.0	100.0	100.3
LANDIS & GYR	MX	C391213	05-14-02	100.1	99.9	100.3
LANDIS & GYR	MX	C391214	05-14-02	100.0	100.1	99.7
LANDIS & GYR	MX	C391215	05-14-02	100.0	100.1	100.3
LANDIS & GYR	MX	C391216	05-14-02	100.0	100.0	99.7
LANDIS & GYR	MX	C391217	05-14-02	100.0	100.0	99.8
LANDIS & GYR	MX	C391218	05-14-02	100.0	100.1	99.8
LANDIS & GYR	MX	C391219	05-14-02	100.1	100.2	99.8

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

PAGE 333
 RUN DATE: 1/14/03
 RUN TIME: 13.26.53

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
LANDIS & GYR	MX	C391220	05-14-02	100.0	100.0	99.8
LANDIS & GYR	MX	C391221	05-14-02	100.0	99.9	99.9
LANDIS & GYR	MX	C391222	05-14-02	100.1	100.0	99.7
LANDIS & GYR	MX	C391223	05-14-02	99.9	100.2	99.8
LANDIS & GYR	MX	C391224	05-14-02	100.1	100.1	100.1
LANDIS & GYR	MX	C391225	05-14-02	100.0	100.0	99.8
LANDIS & GYR	MX	C391226	05-14-02	100.0	100.1	99.7
LANDIS & GYR	MX	C391227	05-14-02	100.0	100.0	100.1
LANDIS & GYR	MX	C391228	05-14-02	100.0	99.9	100.2
LANDIS & GYR	MX	C391229	05-14-02	100.1	100.0	99.9
LANDIS & GYR	MX	C391230	05-14-02	100.1	100.1	100.3
LANDIS & GYR	MX	C391231	05-14-02	100.0	100.0	99.5
LANDIS & GYR	MX	C391232	05-14-02	100.0	99.9	100.3
LANDIS & GYR	MX	C391233	05-14-02	100.0	100.0	100.4
LANDIS & GYR	MX	C391234	05-14-02	100.0	100.1	100.2
LANDIS & GYR	MX	C391235	05-14-02	100.0	99.9	100.5
LANDIS & GYR	MX	C391236	05-14-02	100.1	100.1	100.0
LANDIS & GYR	MX	C391237	05-14-02	100.0	100.0	100.3
LANDIS & GYR	MX	C391238	05-14-02	100.0	100.0	100.3
LANDIS & GYR	MX	C391239	05-14-02	100.0	100.0	100.2
LANDIS & GYR	MX	C391240	05-14-02	100.0	100.2	100.0
LANDIS & GYR	MX	C391241	05-14-02	100.1	100.1	100.0
LANDIS & GYR	MX	C391242	05-14-02	100.1	100.1	100.0
LANDIS & GYR	MX	C391243	05-14-02	100.0	100.0	100.2
LANDIS & GYR	MX	C391244	05-14-02	100.1	100.1	100.3
LANDIS & GYR	MX	C391245	05-14-02	100.1	100.1	100.0
LANDIS & GYR	MX	C391246	05-14-02	100.1	100.1	100.0
LANDIS & GYR	MX	C391247	05-14-02	100.0	100.1	100.1
LANDIS & GYR	MX	C391248	05-14-02	100.0	100.0	100.1
LANDIS & GYR	MX	C391249	05-14-02	100.1	100.1	100.6
LANDIS & GYR	MX	C391250	05-14-02	100.0	100.1	99.9
LANDIS & GYR	MX	C391251	05-14-02	100.1	100.0	100.1
LANDIS & GYR	MX	C391252	05-14-02	100.0	100.1	100.0
LANDIS & GYR	MX	C391253	05-14-02	100.1	100.1	100.3
LANDIS & GYR	MX	C391254	05-14-02	100.0	100.0	99.8
LANDIS & GYR	MX	C391255	05-14-02	100.0	100.0	99.9
LANDIS & GYR	MX	C391256	05-14-02	100.1	100.0	99.9
LANDIS & GYR	MX	C391257	05-14-02	100.0	100.2	100.0
LANDIS & GYR	MX	C391258	05-14-02	100.0	99.9	100.0
LANDIS & GYR	MX	C391259	05-14-02	100.0	100.0	100.2
LANDIS & GYR	MX	C391260	05-14-02	100.0	100.1	100.1
LANDIS & GYR	MX	C391261	05-14-02	100.1	100.0	99.9
LANDIS & GYR	MX	C391262	05-14-02	100.0	100.1	100.1
LANDIS & GYR	MX	C391263	05-14-02	100.1	100.1	100.0
LANDIS & GYR	MX	C391264	05-14-02	100.1	100.0	100.2
LANDIS & GYR	MX	C391265	05-14-02	100.0	100.1	100.2
LANDIS & GYR	MX	C391266	05-14-02	100.0	99.9	100.2
LANDIS & GYR	MX	C391267	05-14-02	100.1	100.1	100.4
LANDIS & GYR	MX	C391268	05-14-02	100.0	100.1	99.6
LANDIS & GYR	MX	C391269	05-14-02	100.0	100.0	99.5
LANDIS & GYR	MX	C391270	05-14-02	100.1	100.0	100.2

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

PAGE 334
 RUN DATE: 1/14/03
 RUN TIME: 13.26.53

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
& GYR	MX	C391271	05-14-02	100.1	100.1	100.0
& GYR	MX	C391272	05-14-02	100.0	100.1	99.9
& GYR	MX	C391273	05-14-02	100.0	100.0	99.9
& GYR	MX	C391274	05-14-02	100.1	100.0	99.8
& GYR	MX	C391275	05-14-02	100.0	100.0	100.4
& GYR	MX	C391276	05-14-02	100.1	100.1	100.0
& GYR	MX	C391277	05-14-02	100.0	100.1	99.9
& GYR	MX	C391278	05-14-02	100.1	99.9	100.0
& GYR	MX	C391279	05-14-02	100.0	100.1	99.7
& GYR	MX	C391280	05-14-02	100.0	100.1	99.8
& GYR	MX	C391281	05-14-02	100.1	100.1	99.8
& GYR	MX	C391282	05-14-02	100.1	100.1	100.0
& GYR	MX	C391283	05-14-02	100.0	100.0	100.0
& GYR	MX	C391284	05-14-02	100.1	100.1	99.9
& GYR	MX	C391285	05-14-02	100.0	100.1	100.0
& GYR	MX	C391286	05-14-02	100.0	100.1	100.5
& GYR	MX	C391287	05-14-02	100.1	100.2	99.7
& GYR	MX	C391288	05-14-02	100.1	100.1	100.4
& GYR	MX	C391289	05-14-02	100.1	100.1	100.1
& GYR	MX	C391290	05-14-02	100.1	100.1	99.8
& GYR	MX	C391291	05-14-02	100.0	100.1	100.1
& GYR	MX	C391292	05-14-02	100.0	100.0	100.1
& GYR	MX	C391293	05-14-02	100.1	100.0	100.0
& GYR	MX	C391294	05-14-02	100.1	100.0	100.3
& GYR	MX	C391295	05-14-02	100.0	100.1	100.0
& GYR	MX	C391296	05-14-02	100.1	100.2	100.0
& GYR	MX	C391297	05-14-02	100.1	100.0	99.8
& GYR	MX	C391298	05-14-02	100.0	100.0	99.8
& GYR	MX	C391299	05-14-02	100.1	100.0	100.3
& GYR	MX	C391300	05-14-02	100.0	100.0	100.3
& GYR	MX	C391301	05-14-02	100.1	100.2	100.0
& GYR	MX	C391302	05-14-02	100.1	100.1	100.0
& GYR	MX	C391303	05-14-02	100.1	100.2	99.7
& GYR	MX	C391304	05-14-02	100.0	100.2	100.0
& GYR	MX	C391305	05-14-02	100.0	100.1	99.8
& GYR	MX	C391306	05-14-02	100.0	100.1	100.0
& GYR	MX	C391307	05-14-02	100.1	100.2	100.0
& GYR	MX	C391308	05-14-02	100.0	100.0	99.9
& GYR	MX	C391309	05-14-02	100.1	100.0	100.2
& GYR	MX	C391310	05-14-02	100.1	99.9	100.2
& GYR	MX	C391311	05-14-02	100.0	99.9	99.8
& GYR	MX	C391312	05-14-02	100.0	100.0	100.0
& GYR	MX	C391313	05-14-02	100.0	100.0	100.0
& GYR	MX	C391314	05-14-02	100.0	100.1	100.0
& GYR	MX	C391315	05-14-02	100.1	100.1	99.9
& GYR	MX	C391316	05-14-02	100.0	99.9	100.0
& GYR	MX	C391317	05-14-02	100.1	100.1	100.0
& GYR	MX	C391318	05-14-02	100.1	100.0	100.4
& GYR	MX	C391319	05-14-02	100.1	100.1	99.9
& GYR	MX	C391320	05-14-02	100.0	100.2	100.2
& GYR	MX	C391321	05-14-02	100.0	100.0	100.0

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

PAGE 335
 RUN DATE: 1/14/03
 RUN TIME: 13.26.53

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
LANDIS & GYR	MX	C391322	05-14-02	100.1	100.1	100.0
LANDIS & GYR	MX	C391323	05-14-02	100.0	100.0	99.9
LANDIS & GYR	MX	C391324	05-14-02	100.0	100.1	100.1
LANDIS & GYR	MX	C391325	05-14-02	100.0	100.0	99.9
LANDIS & GYR	MX	C391326	05-14-02	100.0	100.1	100.0
LANDIS & GYR	MX	C391327	05-14-02	100.0	100.0	100.1
LANDIS & GYR	MX	C391328	05-14-02	100.1	100.1	100.1
LANDIS & GYR	MX	C391329	05-14-02	100.0	100.1	99.9
LANDIS & GYR	MX	C391330	05-14-02	100.1	100.1	100.1
LANDIS & GYR	MX	C391331	05-14-02	100.0	100.0	99.9
LANDIS & GYR	MX	C391332	05-14-02	100.1	100.1	100.1
LANDIS & GYR	MX	C391333	05-14-02	100.1	100.0	100.1
LANDIS & GYR	MX	C391334	05-14-02	100.1	100.1	99.7
LANDIS & GYR	MX	C391335	05-14-02	100.1	100.1	100.1
LANDIS & GYR	MX	C391336	05-14-02	100.0	100.0	99.5
LANDIS & GYR	MX	C391337	05-14-02	100.1	100.1	99.7
LANDIS & GYR	MX	C391338	05-14-02	100.1	100.0	99.8
LANDIS & GYR	MX	C391339	05-14-02	100.0	100.0	99.9
LANDIS & GYR	MX	C391340	05-14-02	100.1	100.1	100.3
LANDIS & GYR	MX	C391341	05-14-02	100.1	99.9	99.6
LANDIS & GYR	MX	C391342	05-14-02	100.0	100.0	100.1
LANDIS & GYR	MX	C391343	05-14-02	100.1	100.1	100.1
LANDIS & GYR	MX	C391344	05-14-02	100.0	100.1	100.1
LANDIS & GYR	MX	C391345	05-14-02	100.0	100.1	99.8
LANDIS & GYR	MX	C391346	05-14-02	100.1	100.2	100.1
LANDIS & GYR	MX	C391347	05-14-02	100.1	100.1	99.8
LANDIS & GYR	MX	C391348	05-14-02	100.0	100.1	100.3
LANDIS & GYR	MX	C391349	05-14-02	100.0	100.0	99.8
LANDIS & GYR	MX	C391350	05-14-02	100.1	100.1	100.0
LANDIS & GYR	MX	C391351	05-14-02	100.0	100.1	99.9
LANDIS & GYR	MX	C391352	05-14-02	99.9	100.0	99.9
LANDIS & GYR	MX	C391353	05-14-02	100.0	100.0	99.5
LANDIS & GYR	MX	C391354	05-14-02	100.1	100.0	99.8
LANDIS & GYR	MX	C391355	05-14-02	100.0	100.1	99.9
LANDIS & GYR	MX	C391356	05-14-02	100.0	100.1	100.0
LANDIS & GYR	MX	C391357	05-14-02	100.1	100.2	100.0
LANDIS & GYR	MX	C391358	05-14-02	100.0	99.9	99.8
LANDIS & GYR	MX	C391359	05-14-02	100.1	100.0	100.3
LANDIS & GYR	MX	C391360	05-14-02	100.0	100.1	99.8
LANDIS & GYR	MX	C391361	05-14-02	100.0	100.0	100.0
LANDIS & GYR	MX	C391362	05-14-02	100.0	100.0	99.9
LANDIS & GYR	MX	C391363	05-14-02	100.0	99.9	99.5
LANDIS & GYR	MX	C391364	05-14-02	100.1	100.2	100.6
LANDIS & GYR	MX	C391365	05-14-02	100.0	100.1	99.9
LANDIS & GYR	MX	C391366	05-14-02	100.1	100.0	100.0
LANDIS & GYR	MX	C391367	05-14-02	100.1	100.1	99.8
LANDIS & GYR	MX	C391368	05-14-02	100.0	99.9	99.9
LANDIS & GYR	MX	C391369	05-14-02	100.0	100.0	100.0
LANDIS & GYR	MX	C391370	05-14-02	100.1	100.1	99.9
LANDIS & GYR	MX	C391371	05-14-02	100.1	100.0	99.6
LANDIS & GYR	MX	C391372	05-14-02	100.0	100.0	99.8

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
LANDIS & GYR	MX	C391373	05-14-02	100.1	100.1	99.6
LANDIS & GYR	MX	C391374	05-14-02	100.1	100.0	100.3
LANDIS & GYR	MX	C391375	05-14-02	100.1	100.2	100.3
LANDIS & GYR	MX	C391376	05-15-02	100.0	99.9	100.2
LANDIS & GYR	MX	C391377	05-15-02	100.0	100.0	99.9
LANDIS & GYR	MX	C391378	05-15-02	100.1	100.0	100.5
LANDIS & GYR	MX	C391379	05-15-02	100.1	100.1	100.5
LANDIS & GYR	MX	C391380	05-15-02	100.1	100.1	99.9
LANDIS & GYR	MX	C391381	05-15-02	100.1	100.0	100.0
LANDIS & GYR	MX	C391382	05-15-02	100.1	100.0	100.0
LANDIS & GYR	MX	C391383	05-15-02	100.1	100.1	99.8
LANDIS & GYR	MX	C391384	05-14-02	100.1	100.1	100.1
LANDIS & GYR	MX	C391385	05-14-02	100.1	100.0	100.0
LANDIS & GYR	MX	C391386	05-14-02	100.1	100.0	100.0
LANDIS & GYR	MX	C391387	05-14-02	100.1	100.0	100.4
LANDIS & GYR	MX	C391388	05-14-02	100.1	100.0	100.3
LANDIS & GYR	MX	C391389	05-14-02	100.0	99.9	100.0
LANDIS & GYR	MX	C391390	05-14-02	100.0	100.0	100.3
LANDIS & GYR	MX	C391391	05-14-02	100.0	100.0	99.6
LANDIS & GYR	MX	C391392	05-14-02	100.0	100.1	99.9
LANDIS & GYR	MX	C391393	05-14-02	100.1	100.1	100.0
LANDIS & GYR	MX	C391394	05-14-02	100.1	100.0	100.0
LANDIS & GYR	MX	C391395	05-14-02	99.9	100.0	100.1
LANDIS & GYR	MX	C391396	05-14-02	100.1	100.0	100.3
LANDIS & GYR	MX	C391397	05-14-02	100.1	100.1	99.9
LANDIS & GYR	MX	C391398	05-14-02	100.1	100.1	100.4
LANDIS & GYR	MX	C391399	05-14-02	100.0	100.1	99.9
LANDIS & GYR	MX	C391400	05-14-02	99.9	100.2	99.8
LANDIS & GYR	MX	C391401	05-14-02	100.1	100.0	99.7
LANDIS & GYR	MX	C391402	05-14-02	100.1	100.0	100.3
LANDIS & GYR	MX	C391403	05-14-02	100.1	100.1	99.9
LANDIS & GYR	MX	C391404	05-14-02	100.1	100.1	100.2
LANDIS & GYR	MX	C391405	05-14-02	100.1	100.2	100.0
LANDIS & GYR	MX	C391406	05-14-02	100.0	100.0	100.0
LANDIS & GYR	MX	C391407	05-14-02	100.1	100.0	100.0
LANDIS & GYR	MX	C391408	05-14-02	100.0	100.0	99.7
LANDIS & GYR	MX	C391409	05-14-02	100.1	100.0	99.6
LANDIS & GYR	MX	C391410	05-14-02	100.0	100.0	100.0
LANDIS & GYR	MX	C391411	05-14-02	100.0	100.2	99.9
LANDIS & GYR	MX	C391412	05-14-02	100.0	99.9	99.9
LANDIS & GYR	MX	C391413	05-14-02	100.0	100.0	99.8
LANDIS & GYR	MX	C391414	05-14-02	100.1	100.0	99.9
LANDIS & GYR	MX	C391415	05-14-02	100.0	100.0	99.9
LANDIS & GYR	MX	C391416	05-14-02	100.0	100.0	99.7
LANDIS & GYR	MX	C391417	05-14-02	100.1	100.0	100.0
LANDIS & GYR	MX	C391418	05-14-02	100.0	100.0	99.9
LANDIS & GYR	MX	C391419	05-14-02	100.1	100.0	99.9
LANDIS & GYR	MX	C391420	05-14-02	100.1	100.1	99.9
LANDIS & GYR	MX	C391421	05-14-02	100.1	100.1	99.9
LANDIS & GYR	MX	C391422	05-14-02	100.1	100.2	100.1
LANDIS & GYR	MX	C391423	05-14-02	100.1	100.1	99.9

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

PAGE 337
 RUN DATE: 1/14/03
 RUN TIME: 13.26.53

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
LANDIS & GYR	MX	C391424	05-14-02	100.1	100.1	100.1
LANDIS & GYR	MX	C391425	05-14-02	100.0	100.2	99.7
LANDIS & GYR	MX	C391426	05-14-02	100.0	100.1	99.7
LANDIS & GYR	MX	C391427	05-14-02	100.0	100.0	99.8
LANDIS & GYR	MX	C391428	05-14-02	100.0	100.0	99.9
LANDIS & GYR	MX	C391429	05-14-02	100.0	100.1	100.0
LANDIS & GYR	MX	C391430	05-14-02	100.1	99.9	100.4
LANDIS & GYR	MX	C391431	05-14-02	100.0	100.0	100.0
LANDIS & GYR	MX	C391432	05-14-02	100.0	100.1	99.8
LANDIS & GYR	MX	C391433	05-14-02	100.1	100.1	100.2
LANDIS & GYR	MX	C391434	05-14-02	100.1	100.1	100.1
LANDIS & GYR	MX	C391435	05-14-02	100.0	100.0	99.8
LANDIS & GYR	MX	C391436	05-14-02	100.1	99.9	100.0
LANDIS & GYR	MX	C391437	05-14-02	100.0	100.1	100.0
LANDIS & GYR	MX	C391438	05-14-02	100.0	100.1	100.0
LANDIS & GYR	MX	C391439	05-14-02	100.1	100.1	100.2
LANDIS & GYR	MX	C391440	05-14-02	100.1	100.0	99.9
LANDIS & GYR	MX	C391441	05-14-02	100.1	100.1	99.9
LANDIS & GYR	MX	C391442	05-14-02	100.1	100.1	100.5
LANDIS & GYR	MX	C391443	05-14-02	100.0	100.0	99.8
LANDIS & GYR	MX	C391444	05-14-02	100.1	100.0	100.0
LANDIS & GYR	MX	C391445	05-14-02	100.1	100.0	100.1
LANDIS & GYR	MX	C391446	05-14-02	100.1	100.1	100.0
LANDIS & GYR	MX	C391447	05-14-02	100.0	100.0	99.8
LANDIS & GYR	MX	C391448	05-14-02	100.1	100.0	100.5
LANDIS & GYR	MX	C391449	05-14-02	100.0	100.0	99.9
LANDIS & GYR	MX	C391450	05-14-02	100.1	100.0	100.0
LANDIS & GYR	MX	C391451	05-14-02	100.1	100.2	100.1
LANDIS & GYR	MX	C391452	05-14-02	100.1	100.0	100.1
LANDIS & GYR	MX	C391453	05-14-02	100.0	100.0	100.0
LANDIS & GYR	MX	C391454	05-14-02	100.1	100.0	100.0
LANDIS & GYR	MX	C391455	05-14-02	100.0	100.0	100.0
LANDIS & GYR	MX	C391456	05-14-02	100.0	100.0	99.9
LANDIS & GYR	MX	C391457	05-14-02	100.0	100.1	99.8
LANDIS & GYR	MX	C391458	05-14-02	100.1	100.1	100.0
LANDIS & GYR	MX	C391459	05-14-02	100.0	100.1	99.7
LANDIS & GYR	MX	C391460	05-14-02	100.0	100.1	99.8
LANDIS & GYR	MX	C391461	05-14-02	100.0	100.0	99.9
LANDIS & GYR	MX	C391462	05-14-02	100.1	100.1	100.0
LANDIS & GYR	MX	C391463	05-14-02	100.0	100.1	99.9
LANDIS & GYR	MX	C391464	05-14-02	100.0	100.0	100.0
LANDIS & GYR	MX	C391465	05-14-02	100.0	100.1	100.1
LANDIS & GYR	MX	C391466	05-14-02	100.0	100.0	99.7
LANDIS & GYR	MX	C391467	05-14-02	100.1	100.2	99.9
LANDIS & GYR	MX	C391468	05-14-02	100.1	99.9	99.9
LANDIS & GYR	MX	C391469	05-14-02	100.0	100.0	100.0
LANDIS & GYR	MX	C391470	05-14-02	100.0	99.9	99.9
LANDIS & GYR	MX	C391471	05-14-02	100.0	99.9	99.6
LANDIS & GYR	MX	C391472	05-15-02	100.0	100.1	100.0
LANDIS & GYR	MX	C391473	05-15-02	100.1	100.1	100.2
LANDIS & GYR	MX	C391474	05-15-02	100.1	100.0	100.0

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
LANDIS & GYR	MX	C391475	05-15-02	100.1	100.1	100.0
LANDIS & GYR	MX	C391476	05-15-02	100.1	100.1	100.2
LANDIS & GYR	MX	C391477	05-15-02	100.0	100.0	100.1
LANDIS & GYR	MX	C391478	05-15-02	100.0	100.0	99.9
LANDIS & GYR	MX	C391479	05-15-02	100.0	99.9	100.0
LANDIS & GYR	MX	C391480	05-15-02	100.1	100.0	100.2
LANDIS & GYR	MX	C391481	05-15-02	100.1	100.0	100.1
LANDIS & GYR	MX	C391482	05-15-02	100.1	100.0	100.3
LANDIS & GYR	MX	C391483	05-15-02	100.1	100.1	100.4
LANDIS & GYR	MX	C391484	05-15-02	100.1	100.0	99.9
LANDIS & GYR	MX	C391485	05-15-02	100.1	100.2	100.6
LANDIS & GYR	MX	C391486	05-15-02	100.1	100.2	100.0
LANDIS & GYR	MX	C391487	05-15-02	100.0	99.9	100.6
LANDIS & GYR	MX	C391488	05-15-02	100.1	100.1	100.4
LANDIS & GYR	MX	C391489	05-15-02	100.1	100.0	100.0
LANDIS & GYR	MX	C391490	05-15-02	100.0	100.0	100.0
LANDIS & GYR	MX	C391491	05-15-02	100.0	100.0	100.2
LANDIS & GYR	MX	C391492	05-15-02	100.1	100.0	100.0
LANDIS & GYR	MX	C391493	05-15-02	100.1	100.0	100.0
LANDIS & GYR	MX	C391494	05-15-02	100.0	100.1	100.4
LANDIS & GYR	MX	C391495	05-15-02	100.0	100.0	100.1
LANDIS & GYR	MX	C391496	05-15-02	100.0	99.9	100.2
LANDIS & GYR	MX	C391497	05-15-02	100.1	100.1	100.2
LANDIS & GYR	MX	C391498	05-15-02	100.0	100.0	99.9
LANDIS & GYR	MX	C391499	05-15-02	100.1	100.2	99.8
LANDIS & GYR	MX	C391500	05-15-02	100.1	100.2	100.1
LANDIS & GYR	MX	C391501	05-15-02	100.1	100.2	100.0
LANDIS & GYR	MX	C391502	05-15-02	100.1	100.0	100.3
LANDIS & GYR	MX	C391503	05-15-02	100.1	100.1	100.3
LANDIS & GYR	MX	C391504	05-15-02	100.0	100.0	100.6
LANDIS & GYR	MX	C391505	05-15-02	100.1	100.1	100.3
LANDIS & GYR	MX	C391506	05-15-02	100.1	100.1	100.3
LANDIS & GYR	MX	C391507	05-15-02	100.0	100.0	100.1
LANDIS & GYR	MX	C391508	05-15-02	99.9	100.0	100.2
LANDIS & GYR	MX	C391509	05-15-02	100.0	99.9	99.7
LANDIS & GYR	MX	C391510	05-15-02	100.1	99.9	100.0
LANDIS & GYR	MX	C391511	05-15-02	99.9	99.9	99.9
LANDIS & GYR	MX	C391512	05-15-02	100.1	99.9	100.2
LANDIS & GYR	MX	C391513	05-15-02	100.1	100.1	100.0
LANDIS & GYR	MX	C391514	05-15-02	100.0	100.0	100.0
LANDIS & GYR	MX	C391515	05-15-02	100.0	100.1	100.0
LANDIS & GYR	MX	C391516	05-14-02	100.0	100.0	99.8
LANDIS & GYR	MX	C391517	05-15-02	100.0	99.9	100.4
LANDIS & GYR	MX	C391518	05-15-02	100.1	100.0	99.8
LANDIS & GYR	MX	C391519	05-09-02	100.0	100.1	100.1
LANDIS & GYR	MX	C391520	05-09-02	100.0	100.1	99.8
LANDIS & GYR	MX	C391521	05-15-02	100.1	100.0	100.3
LANDIS & GYR	MX	C391522	05-15-02	100.0	100.0	99.9
LANDIS & GYR	MX	C391523	05-09-02	100.0	99.9	99.7
LANDIS & GYR	MX	C391524	05-09-02	100.0	99.9	99.6
LANDIS & GYR	MX	C391525	05-15-02	100.0	99.9	99.8

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
LANDIS & GYR	MX	C391526	05-15-02	100.0	99.9	99.9
LANDIS & GYR	MX	C391527	05-15-02	100.0	100.2	99.9
LANDIS & GYR	MX	C391528	05-15-02	100.1	100.0	100.0
LANDIS & GYR	MX	C391529	05-15-02	100.0	100.0	100.0
LANDIS & GYR	MX	C391530	05-15-02	100.0	100.1	100.3
LANDIS & GYR	MX	C391531	05-15-02	100.0	100.1	100.1
LANDIS & GYR	MX	C391532	05-15-02	100.0	100.1	100.2
LANDIS & GYR	MX	C391533	05-15-02	100.1	100.1	100.1
LANDIS & GYR	MX	C391534	05-15-02	100.1	100.0	99.8
LANDIS & GYR	MX	C391535	05-15-02	100.1	100.0	99.6
LANDIS & GYR	MX	C391536	05-15-02	100.1	100.1	100.2
LANDIS & GYR	MX	C391537	05-14-02	100.0	100.1	100.0
LANDIS & GYR	MX	C391538	05-13-02	100.0	100.0	99.9
LANDIS & GYR	MX	C391539	04-22-02	100.0	100.1	100.4
LANDIS & GYR	MX	C391540	05-14-02	100.1	100.1	99.5
LANDIS & GYR	MX	C391541	05-14-02	99.9	99.9	99.9
LANDIS & GYR	MX	C391542	05-14-02	100.1	100.1	100.0
LANDIS & GYR	MX	C391543	05-14-02	100.0	99.9	100.3
LANDIS & GYR	MX	C391544	05-15-02	100.0	100.1	100.1
LANDIS & GYR	MX	C391545	05-15-02	100.0	100.0	99.9
LANDIS & GYR	MX	C391546	05-15-02	100.0	100.1	100.6
LANDIS & GYR	MX	C391547	05-15-02	100.1	100.1	100.2
LANDIS & GYR	MX	C391548	05-15-02	100.0	100.1	100.0
LANDIS & GYR	MX	C391549	05-15-02	100.1	100.1	100.0
LANDIS & GYR	MX	C391550	05-15-02	100.1	99.9	100.1
LANDIS & GYR	MX	C391551	05-15-02	100.1	100.2	100.2
LANDIS & GYR	MX	C391552	05-15-02	100.1	100.2	100.1
LANDIS & GYR	MX	C391553	05-15-02	100.1	100.0	100.0
LANDIS & GYR	MX	C391554	05-15-02	100.0	100.1	100.5
LANDIS & GYR	MX	C391555	05-15-02	100.1	100.1	100.5
LANDIS & GYR	MX	C391556	05-15-02	100.1	100.0	100.1
LANDIS & GYR	MX	C391557	05-15-02	100.0	100.0	100.5
LANDIS & GYR	MX	C391558	05-15-02	100.1	100.0	100.1
LANDIS & GYR	MX	C391559	05-15-02	100.1	99.9	100.2
LANDIS & GYR	MX	C391560	05-15-02	100.1	100.0	99.9
LANDIS & GYR	MX	C391561	05-15-02	100.0	100.1	100.0
LANDIS & GYR	MX	C391562	05-15-02	100.0	99.9	100.1
LANDIS & GYR	MX	C391563	05-15-02	100.0	100.0	100.2
LANDIS & GYR	MX	C391564	05-15-02	99.9	100.1	100.0
LANDIS & GYR	MX	C391565	05-15-02	100.1	100.2	99.9
LANDIS & GYR	MX	C391566	05-15-02	100.1	100.0	100.2
LANDIS & GYR	MX	C391567	05-15-02	99.9	99.9	100.0
LANDIS & GYR	MX	C391568	05-15-02	100.0	100.1	99.7
LANDIS & GYR	MX	C391569	05-15-02	100.1	100.2	100.2
LANDIS & GYR	MX	C391570	05-15-02	100.0	100.1	99.7
LANDIS & GYR	MX	C391571	05-15-02	100.0	100.0	100.4
LANDIS & GYR	MX	C391572	05-14-02	100.1	99.9	100.1
LANDIS & GYR	MX	C391573	05-15-02	100.1	100.1	100.2
LANDIS & GYR	MX	C391574	05-15-02	100.1	100.1	100.5
LANDIS & GYR	MX	C391575	05-15-02	100.0	99.9	100.2
LANDIS & GYR	MX	C391576	05-15-02	100.1	100.2	99.5

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
LANDIS & GYR	MX	C391577	05-15-02	100.1	100.1	99.8
LANDIS & GYR	MX	C391578	05-15-02	100.1	100.2	100.0
LANDIS & GYR	MX	C391579	05-15-02	100.0	100.0	99.7
LANDIS & GYR	MX	C391580	05-15-02	99.9	99.9	99.7
LANDIS & GYR	MX	C391581	05-15-02	100.0	99.9	99.6
LANDIS & GYR	MX	C391582	05-15-02	100.1	100.1	100.3
LANDIS & GYR	MX	C391583	05-15-02	100.0	100.1	100.4
LANDIS & GYR	MX	C391584	05-15-02	100.1	100.0	100.5
LANDIS & GYR	MX	C391585	05-15-02	100.0	100.0	99.9
LANDIS & GYR	MX	C391586	05-15-02	100.0	100.1	100.2
LANDIS & GYR	MX	C391587	05-15-02	100.1	99.9	100.0
LANDIS & GYR	MX	C391588	05-15-02	100.1	100.0	100.5
LANDIS & GYR	MX	C391589	05-15-02	100.0	100.0	100.0
LANDIS & GYR	MX	C391590	05-15-02	100.0	100.1	100.0
LANDIS & GYR	MX	C391591	05-15-02	100.1	100.0	100.0
LANDIS & GYR	MX	C391592	05-15-02	100.0	100.1	100.1
LANDIS & GYR	MX	C391593	05-15-02	100.0	99.9	99.7
LANDIS & GYR	MX	C391594	05-15-02	100.1	100.0	100.3
LANDIS & GYR	MX	C391595	05-15-02	100.0	100.0	100.1
LANDIS & GYR	MX	C391596	05-15-02	100.0	99.9	100.2
LANDIS & GYR	MX	C391597	05-15-02	100.0	100.0	99.9
LANDIS & GYR	MX	C391598	05-15-02	100.0	99.9	100.3
LANDIS & GYR	MX	C391599	05-15-02	100.1	99.9	100.0
LANDIS & GYR	MX	C391600	05-15-02	100.0	100.1	100.6
LANDIS & GYR	MX	C391601	05-15-02	100.1	100.2	100.2
LANDIS & GYR	MX	C391602	05-15-02	100.0	100.0	100.4
LANDIS & GYR	MX	C391603	05-15-02	100.0	100.1	100.5
LANDIS & GYR	MX	C391604	05-15-02	100.0	100.0	100.0
LANDIS & GYR	MX	C391605	05-15-02	100.1	100.2	100.2
LANDIS & GYR	MX	C391606	05-15-02	100.1	100.1	100.4
LANDIS & GYR	MX	C391607	05-15-02	100.0	100.1	99.8

MFG TYPE TOTAL 1,000

GRAND TOTAL 17,280

American Electric Power
101A Enterprise Drive
P O Box 5190
Frankfort, KY 40602-5190
www.aep.com



Thomas M. Dorman, Executive Director
Public Service Commission
P. O. Box 615
Frankfort, KY 40602

14 February 2003

RECEIVED

FEB 14 2003

PUBLIC SERVICE
COMMISSION

Dear Mr. Dorman:

Re: Case No. 99-441

Pursuant to the October 25, 2000 Revised Amended Sample Meter Pilot Testing Plan, Appendix A, Section I (4), enclosed for filing is the Company's certified test results of all new meters received.

Also, pursuant to Appendix A, Section II (D)(3)(b) of the Plan, enclosed for filing is the Statistical Sampling Plan for Kentucky Power Company's 2002 Sample Test Results.

The two attached reports meet the annual filing requirements outlined in the utilities Revised Amended Sample Meter Pilot Testing Plan.

Should you have questions regarding the reports, please contact me at 502/696-7010.

Sincerely,

A handwritten signature in cursive script that reads 'Errol K. Wagner'.

Errol K. Wagner
Director of Regulatory Services

jw

Attachments

RECEIVED

Sample Test Report

FEB 4 2003

Kentucky Power Company
2002 Sample Test ResultsPUBLIC SERVICE
COMMISSION

Based on: ANSI Z1.9 – 1980, Upper Limit – 102%, Lower Limit – 98%, AQL – 2.5, Table B3

Group Name	Meter Types	# of Meters in Service at time of the sample selection	# of meters sample tested	Average Accuracy (Bar X)	Standard Deviation (Sigma)	Pass/Fail
K2D41	D4S	9,424	75	100.01	0.228	Pass
K2D42	D4S	4,496	75	99.87	0.328	Pass
K2D51	D5S	3,590	75	100.14	0.246	Pass
K2GE1	I50S, I55A, I55S & I60S	4,180	75	99.99	0.205	Pass
K2I71	I70S	5,411	75	100.01	0.239	Pass
K2I72	I70S	9,618	75	100.04	0.261	Pass
K2I73	I70S	9,656	75	100.13	0.197	Pass
K2I74	I70S	9,618	75	100.06	0.195	Pass
K2I75	I70S	9,627	75	100.12	0.185	Pass
K2I76	I70S	9,635	75	100.15	0.176	Pass
K2I77	I70S	9,618	75	100.09	0.187	Pass
K2I78	I70S	6,026	75	99.91	0.200	Pass
K2I79	I70S	9,231	75	99.98	0.204	Pass
K2J3S	J3S	803	35	99.81	0.326	Pass
K2J41	J4S & J4ES	9,608	75	99.96	0.299	Pass
K2J42	J4S & J4ES	5,808	75	99.92	0.281	Pass
K2J51	J5S & J5SD	9,601	75	100.03	0.263	Pass
K2J52	J5S & J5SD	4,457	75	99.86	0.246	Pass
K2MQ1	MQS	234	15	100.42	0.408	Pass
K2MS1	MS, MSK, MS2K, PDRMT5A & SSM6A	9,618	75	100.07	0.294	Pass
K2MS2	MS, MSK, MS2K, PDRMT5A, SSM6A, DDMS & DDMS2K	9,654	75	99.99	0.274	Pass
K2MS3	MS, MSK, MS2K, PDRMT5A, SSM6A, DDMS & DDMS2K	9,581	75	99.99	0.308	Pass
K2MS4	MS, MSK, MS2K, PDRMT5A, SSM6A, DDMS & DDMS2K	1,834	50	100.06	0.152	Pass

Comments:

Sample Test Report

Kentucky Power Company
2002 Sample Test Results

Based on: ANSI Z1.9 – 1980, Upper Limit – 102%, Lower Limit – 98%, AQL – 2.5, Table B3

Meters removed in 2002 of Failed Groups

Group Name	Meter Types	Years of Group Failure	Meter In service as of 12/31/2002	Removed or Tested in 2002	Plans for present year

Comments:

Prepared By: Gary L. Tredeau / 02/13/2003

KY CTESTS for 2002

AEP Kentucky Power Company

Devc Cd	Mfr Devc Ser Nbr	Srs Acc Af FI	Srs Acc Af Lag	Srs Acc Af LI	Mfr Devc Type Cd	Test Date	Rcvd Date
00036	176633845	100.19	99.11	100.1	V62S	20020211	20020228
00036	176633846	99.98	99.62	100.04	V62S	20020211	20020228
00036	176633865	99.95	99.51	100.06	V62S	20020211	20020228
00006	220912898	100	100.48	100.09	I70S	20011205	20020102
00006	220912899	100.05	99.46	99.96	I70S	20011205	20020102
00006	220912900	99.95	100.24	100.01	I70S	20011205	20020102
00006	220912901	100.01	100.4	99.93	I70S	20011205	20020102
00006	220912902	99.98	100.06	99.94	I70S	20011205	20020102
00006	220912903	99.98	100.57	99.93	I70S	20011205	20020102
00006	220912904	100.03	100.19	100.14	I70S	20011205	20020102
00006	220912905	99.89	100.67	100.04	I70S	20011205	20020102
00006	220912906	100.08	100	99.9	I70S	20011205	20020102
00006	220912907	99.98	100.47	100.04	I70S	20011205	20020102
00006	220912908	100.12	100.42	100.13	I70S	20011205	20020102
00006	220912909	100.09	100.26	99.96	I70S	20011205	20020102
00006	220912910	99.96	99.76	99.99	I70S	20011205	20020102
00006	220912911	100.07	100.14	99.87	I70S	20011205	20020102
00006	220912912	100.02	100.24	100.05	I70S	20011205	20020102
00006	220912913	99.95	100.14	99.88	I70S	20011205	20020102
00006	220912914	100.06	100.06	99.92	I70S	20011205	20020102
00006	220912915	100	100.33	99.88	I70S	20011205	20020102
00006	220912916	100.1	99.93	100.12	I70S	20011205	20020102
00006	220912917	100.11	99.88	100.11	I70S	20011205	20020102
00006	220912918	100.03	99.97	100.1	I70S	20011205	20020102
00006	220912919	99.93	100.42	100.01	I70S	20011205	20020102
00006	220912920	100.1	100.07	100.07	I70S	20011205	20020102
00006	220912921	100.09	100.04	100.06	I70S	20011205	20020102
00006	220912922	99.87	100.04	100.14	I70S	20011205	20020102
00006	220912923	99.98	100.36	99.93	I70S	20011205	20020102
00006	220912924	100.03	99.88	99.93	I70S	20011205	20020102
00006	220912925	100.03	100.23	99.96	I70S	20011205	20020102
00006	220912927	100.01	100.03	99.86	I70S	20011205	20020102
00006	220912928	100.1	99.52	99.89	I70S	20011205	20020102
00006	220912929	99.9	99.97	99.88	I70S	20011205	20020102
00006	220912930	99.96	99.96	100.11	I70S	20011205	20020102
00006	220912931	100.07	99.75	100.07	I70S	20011205	20020102
00006	220912932	99.91	100.45	100.06	I70S	20011205	20020102
00006	220912933	99.94	100.07	99.86	I70S	20011205	20020102
00006	220912934	100.1	100.12	100.08	I70S	20011205	20020102
00006	220912935	100.03	100.52	100.04	I70S	20011205	20020102
00006	220912936	100.01	100.04	100	I70S	20011205	20020102
00006	220912937	99.96	99.5	99.97	I70S	20011205	20020102
00006	220912938	99.98	100	100.01	I70S	20011205	20020102
00006	220912939	99.98	100.03	99.93	I70S	20011205	20020102
00006	220912940	100.02	100.41	100.02	I70S	20011205	20020102
00006	220912941	100.14	99.88	100.1	I70S	20011205	20020102
00006	220912942	100.06	100.13	99.94	I70S	20011205	20020102
00006	220912943	99.96	100.59	100.1	I70S	20011205	20020102
00006	220912944	100	100.59	99.95	I70S	20011205	20020102
00006	220912945	100.11	100.1	100	I70S	20011205	20020102
00006	220912946	100.11	99.95	99.89	I70S	20011205	20020102
00006	220912947	100.02	100.03	99.92	I70S	20011205	20020102
00006	220912949	99.95	99.7	99.9	I70S	20011205	20020102
00006	220912950	99.86	99.48	100.07	I70S	20011205	20020102
00006	220912951	100	100.52	99.9	I70S	20011205	20020102
00006	220912952	100.09	100.26	99.96	I70S	20011205	20020102
00006	220912953	100.09	100.26	99.96	I70S	20011205	20020102
00006	220912954	99.95	100.09	99.88	I70S	20011205	20020102
00006	220912955	100.01	100.11	99.99	I70S	20011205	20020102
00006	220912956	99.99	100.19	99.99	I70S	20011205	20020102

RECEIVED
 FEB 14 2003
 PUBLIC SERVICE
 COMMISSION

KY CTESTS for 2002

00006	220912957	100.1	100.36	100.06	I70S	20011205	20020102
00006	220912958	100.05	100.24	99.88	I70S	20011205	20020102
00006	220912959	99.93	100.13	100.14	I70S	20011205	20020102
00006	220912960	100.02	100.24	100.05	I70S	20011205	20020102
00006	220912961	100.02	99.59	100.01	I70S	20011205	20020102
00006	220912962	99.92	100.64	99.94	I70S	20011205	20020102
00006	220912963	99.95	100.37	100.04	I70S	20011205	20020102
00006	220912964	100.02	100.57	100.05	I70S	20011205	20020102
00006	220912965	100.12	100.38	99.99	I70S	20011205	20020102
00006	220912966	99.98	100.57	100.01	I70S	20011205	20020102
00006	220912967	99.96	99.96	100.11	I70S	20011205	20020102
00006	220912968	99.94	100.19	100.08	I70S	20011205	20020102
00006	220912969	99.99	100.16	99.93	I70S	20011205	20020102
00006	220912970	99.93	100.42	100.01	I70S	20011205	20020102
00006	220912971	100.01	100.03	99.86	I70S	20011205	20020102
00006	220912972	100.06	100.35	100.11	I70S	20011205	20020102
00006	220912973	100.02	100.57	100.05	I70S	20011205	20020102
00006	220912974	100.05	100.14	100.01	I70S	20011205	20020102
00006	220912975	99.91	100.45	100.06	I70S	20011205	20020102
00006	220912976	99.96	100.52	100.04	I70S	20011205	20020102
00006	220912977	100.08	100.41	100.14	I70S	20011205	20020102
00006	220912978	100.13	100.35	100.1	I70S	20011205	20020102
00006	220912979	100.06	100.28	100.14	I70S	20011205	20020102
00006	220912981	100.07	100.42	100.1	I70S	20011205	20020102
00006	220912982	99.95	100.44	99.91	I70S	20011205	20020102
00006	220912983	100.01	100.61	99.9	I70S	20011205	20020102
00006	220912984	99.92	99.87	100.14	I70S	20011205	20020102
00006	220912985	100.01	99.74	99.94	I70S	20011205	20020102
00006	220912986	99.95	100.33	99.86	I70S	20011205	20020102
00006	220912987	99.96	100.36	99.9	I70S	20011205	20020102
00006	220912988	100.01	100.44	100.07	I70S	20011205	20020102
00006	220912989	100.01	100.44	99.99	I70S	20011205	20020102
00006	220912991	100.07	100.49	100.07	I70S	20011205	20020102
00006	220912992	100.01	100.33	100.08	I70S	20011205	20020102
00006	220912994	99.97	100.01	100.06	I70S	20011206	20020101
00006	220912995	100.07	100.66	100.02	I70S	20011206	20020101
00006	220912996	100.14	99.93	99.99	I70S	20011206	20020101
00006	220912997	99.97	100.66	100.13	I70S	20011206	20020101
00006	220912998	100.06	100.64	100	I70S	20011206	20020101
00006	220912999	100.02	100.32	99.99	I70S	20011206	20020101
00006	220913000	100.04	100.35	99.97	I70S	20011206	20020101
00006	220913001	99.98	100.24	100	I70S	20011206	20020101
00006	220913002	100.02	100.22	100	I70S	20011206	20020101
00006	220913003	99.99	100.25	100.08	I70S	20011206	20020101
00006	220913004	100.03	100.27	100.06	I70S	20011206	20020101
00006	220913005	100.1	100.16	100.03	I70S	20011206	20020101
00006	220913006	99.95	100.55	99.88	I70S	20011206	20020101
00006	220913007	99.94	100.66	99.91	I70S	20011206	20020101
00006	220913008	100.05	100.1	100.13	I70S	20011206	20020101
00006	220913009	100.04	100.6	100.09	I70S	20011206	20020101
00006	220913010	100.09	100.54	100.06	I70S	20011206	20020101
00006	220913011	100.08	100.42	99.97	I70S	20011206	20020101
00006	220913012	99.95	100.57	100.06	I70S	20011206	20020101
00006	220913013	100.06	100.3	100.11	I70S	20011206	20020101
00006	220913014	100.09	100.01	100.08	I70S	20011206	20020101
00006	220913015	99.99	100.21	100.04	I70S	20011206	20020101
00006	220913016	100.06	100.25	99.92	I70S	20011206	20020101
00006	220913017	99.99	100.53	99.86	I70S	20011206	20020101
00006	220913018	99.9	100.6	100.14	I70S	20011206	20020101
00006	220913019	100.03	99.8	100.02	I70S	20011206	20020101
00006	220913020	99.98	100.45	100.04	I70S	20011206	20020101

KY CTESTS for 2002

00006	220913021	100.06	100.46	99.92	I70S	20011206	20020101
00006	220913022	100.05	100.21	100.01	I70S	20011206	20020101
00006	220913023	100.01	100.21	99.95	I70S	20011206	20020101
00006	220913025	99.9	99.49	99.96	I70S	20011206	20020101
00006	220913026	99.94	100.01	100.1	I70S	20011206	20020101
00006	220913027	100	99.48	99.87	I70S	20011206	20020101
00006	220913028	100.03	100.36	100	I70S	20011206	20020101
00006	220913029	99.95	100.02	99.94	I70S	20011206	20020101
00006	220913030	100.05	99.73	100.12	I70S	20011206	20020101
00006	220913031	100.09	100.54	100.06	I70S	20011206	20020101
00006	220913032	100.03	99.82	100.09	I70S	20011206	20020101
00006	220913033	99.9	100.22	99.92	I70S	20011206	20020101
00006	220913034	100.06	100.13	99.88	I70S	20011206	20020101
00006	220913035	100.04	100.06	100.09	I70S	20011206	20020101
00006	220913036	99.97	100.5	99.88	I70S	20011206	20020101
00006	220913037	100	100.43	100.04	I70S	20011206	20020101
00006	220913038	99.96	99.86	99.97	I70S	20011206	20020101
00006	220913039	100.11	100.55	100.13	I70S	20011206	20020101
00006	220913040	100	100.5	100.02	I70S	20011206	20020101
00006	220913041	100.01	99.94	99.93	I70S	20011206	20020101
00006	220913042	99.96	99.92	100.12	I70S	20011206	20020101
00006	220913043	99.98	100.21	99.92	I70S	20011206	20020101
00006	220913044	100.04	100.6	100.09	I70S	20011206	20020101
00006	220913045	99.95	100.64	99.99	I70S	20011206	20020101
00006	220913046	100.08	100.44	100.09	I70S	20011206	20020101
00006	220913047	99.95	99.55	100.07	I70S	20011206	20020101
00006	220913048	100.07	99.77	100.06	I70S	20011206	20020101
00006	220913049	100.03	99.8	100.02	I70S	20011206	20020101
00006	220913050	100.03	100.24	99.9	I70S	20011206	20020101
00006	220913051	99.86	99.91	99.96	I70S	20011206	20020101
00006	220913052	99.94	99.96	99.96	I70S	20011206	20020101
00006	220913053	99.93	99.49	100.06	I70S	20011206	20020101
00006	220913054	100.04	99.68	99.95	I70S	20011206	20020101
00006	220913055	100.05	100.26	100.12	I70S	20011206	20020101
00006	220913056	99.9	99.93	100.06	I70S	20011206	20020101
00006	220913057	99.89	100.16	100.13	I70S	20011206	20020101
00006	220913058	99.97	100.16	99.86	I70S	20011206	20020101
00006	220913059	100.01	100.62	100.06	I70S	20011206	20020101
00006	220913060	100.07	100.14	99.98	I70S	20011206	20020101
00006	220913061	100.02	100.5	99.89	I70S	20011206	20020101
00006	220913062	100.03	100.69	100.11	I70S	20011206	20020101
00006	220913063	99.98	100.1	99.98	I70S	20011206	20020101
00006	220913064	100.02	100.02	99.86	I70S	20011206	20020101
00006	220913065	100.04	100.59	99.95	I70S	20011206	20020101
00006	220913066	100	100.3	100.04	I70S	20011206	20020101
00006	220913067	99.96	100.52	99.94	I70S	20011206	20020101
00006	220913068	100.11	99.9	99.91	I70S	20011206	20020101
00006	220913069	99.89	100.56	99.9	I70S	20011206	20020101
00006	220913070	100.04	100.04	100.13	I70S	20011206	20020101
00006	220913071	99.93	99.76	99.96	I70S	20011206	20020101
00006	220913072	100.08	100.01	99.9	I70S	20011206	20020101
00006	220913073	99.96	99.76	99.9	I70S	20011206	20020101
00006	220913074	100.03	100.16	100.08	I70S	20011206	20020101
00006	220913075	99.97	100.29	99.86	I70S	20011206	20020101
00006	220913077	100.04	100.68	100.08	I70S	20011206	20020101
00006	220913078	100.01	99.98	99.92	I70S	20011206	20020101
00006	220913081	100.12	100.55	100.14	I70S	20011206	20020101
00006	220913082	100.09	100.38	100.07	I70S	20011206	20020101
00006	220913083	100.05	100.21	100.01	I70S	20011206	20020101
00006	220913084	100.09	100.1	100.08	I70S	20011206	20020101
00006	220913085	99.98	100.68	99.94	I70S	20011206	20020101

KY CTESTS for 2002

00006	220913086	100.04	99.63	100.01	I70S	20011206	20020101
00006	220913087	100.02	100.14	100.04	I70S	20011206	20020101
00006	220913089	100.02	99.97	99.97	I70S	20011206	20020101
00006	220913332	99.97	100.35	100.06	I70S	20011205	20020102
00006	220916513	100.05	100.24	99.93	I70S	20011206	20020101
00006	220917030	99.95	99.54	99.97	I70S	20011207	20020101
00006	220917031	100.1	99.64	100.14	I70S	20011207	20020101
00006	220917032	100	100.05	100.09	I70S	20011207	20020101
00006	220917033	100.03	99.62	99.87	I70S	20011207	20020101
00006	220917034	99.99	100.27	100.07	I70S	20011207	20020101
00006	220917035	100.14	100.16	100.1	I70S	20011207	20020101
00006	220917036	99.86	99.58	99.92	I70S	20011207	20020101
00006	220917037	100.01	100.47	99.99	I70S	20011207	20020101
00006	220917038	100.09	100.36	100.07	I70S	20011207	20020101
00006	220917039	100.06	100.04	100.07	I70S	20011207	20020101
00006	220917040	99.92	99.92	99.95	I70S	20011207	20020101
00006	220917041	100.01	100.26	100.14	I70S	20011207	20020101
00006	220917042	100.07	100.24	100.03	I70S	20011207	20020101
00006	220917043	99.97	99.7	100.04	I70S	20011207	20020101
00006	220917044	100.08	100.05	100.09	I70S	20011207	20020101
00006	220917045	100.05	99.58	99.93	I70S	20011207	20020101
00006	220917046	100	99.45	99.91	I70S	20011207	20020101
00006	220917047	100.06	100.16	100.03	I70S	20011207	20020101
00006	220917048	99.94	99.78	99.87	I70S	20011207	20020101
00006	220917049	100.08	99.36	100.11	I70S	20011207	20020101
00006	220917050	99.97	100.25	99.96	I70S	20011207	20020101
00006	220917051	100.05	100.36	99.99	I70S	20011207	20020101
00006	220917052	100.08	100.01	99.97	I70S	20011207	20020101
00006	220917053	99.92	99.71	99.98	I70S	20011207	20020101
00006	220917054	100	100.35	99.97	I70S	20011207	20020101
00006	220917055	100	99.4	100.02	I70S	20011207	20020101
00006	220917056	99.98	100.02	100.11	I70S	20011207	20020101
00006	220917057	99.94	100.37	99.9	I70S	20011207	20020101
00006	220917058	99.98	99.81	99.86	I70S	20011207	20020101
00006	220917059	99.99	100.49	100.05	I70S	20011207	20020101
00006	220917060	99.95	99.85	100.09	I70S	20011207	20020101
00006	220917061	99.98	99.81	99.86	I70S	20011207	20020101
00006	220917062	100.03	100.02	100.08	I70S	20011207	20020101
00006	220917063	100.03	100.29	100.11	I70S	20011207	20020101
00006	220917064	100	100.14	100.02	I70S	20011207	20020101
00006	220917065	100.1	99.49	100.05	I70S	20011207	20020101
00006	220917066	99.94	100.39	99.94	I70S	20011207	20020101
00006	220917067	99.92	99.36	99.96	I70S	20011207	20020101
00006	220917068	99.97	100.39	99.95	I70S	20011207	20020101
00006	220917069	100.06	100.16	100.03	I70S	20011207	20020101
00006	220917070	100.02	99.9	100.04	I70S	20011207	20020101
00006	220917071	100.03	100	100.08	I70S	20011207	20020101
00006	220917072	100.05	100.41	100.06	I70S	20011207	20020101
00006	220917073	100.04	100.34	100.11	I70S	20011207	20020101
00006	220917074	100.04	99.97	100.03	I70S	20011207	20020101
00006	220917075	100.01	100.22	100.09	I70S	20011207	20020101
00006	220917076	100.04	99.93	100.01	I70S	20011207	20020101
00006	220917077	100.06	100.49	100.02	I70S	20011207	20020101
00006	220917078	99.89	99.53	100	I70S	20011207	20020101
00006	220917079	99.99	99.73	100.04	I70S	20011207	20020101
00006	220917080	99.95	99.54	99.97	I70S	20011207	20020101
00006	220917081	100	99.8	100.07	I70S	20011207	20020101
00006	220917082	100.06	99.77	99.96	I70S	20011207	20020101
00006	220917083	100.03	100.21	100.12	I70S	20011207	20020101
00006	220917084	100.03	100.5	100.07	I70S	20011207	20020101
00006	220917085	99.91	100.57	100.02	I70S	20011207	20020101

KY CTESTS for 2002

00006	220917086	100.02	100.69	99.91	I70S	20011207	20020101
00006	220917087	100.02	99.61	100	I70S	20011207	20020101
00006	220917088	100.06	99.67	100.07	I70S	20011207	20020101
00006	220917089	100.01	99.51	100.05	I70S	20011207	20020101
00006	220917090	100.12	100.23	100.07	I70S	20011207	20020101
00006	220917091	100.12	99.99	100.08	I70S	20011207	20020101
00006	220917092	100.06	100.09	99.92	I70S	20011207	20020101
00006	220917093	99.99	100.2	99.99	I70S	20011207	20020101
00006	220917094	100	100.29	99.99	I70S	20011207	20020101
00006	220917095	99.88	100	99.91	I70S	20011207	20020101
00006	220917096	99.99	99.34	99.89	I70S	20011207	20020101
00006	220917097	99.98	100.23	99.89	I70S	20011207	20020101
00006	220917098	100.07	100.41	100.13	I70S	20011207	20020101
00006	220917099	100.12	100.09	100.13	I70S	20011207	20020101
00006	220917100	100.06	100.32	99.94	I70S	20011207	20020101
00006	220917101	100	100.09	100	I70S	20011207	20020101
00006	220917102	99.91	99.94	99.87	I70S	20011207	20020101
00006	220917104	100.02	100.29	100.07	I70S	20011207	20020101
00006	220917105	100.03	99.48	100.13	I70S	20011207	20020101
00006	220917106	100	100.59	100.14	I70S	20011207	20020101
00006	220917107	99.99	99.87	99.98	I70S	20011207	20020101
00006	220917108	99.97	99.35	100.06	I70S	20011207	20020101
00006	220917109	99.94	99.84	99.91	I70S	20011207	20020101
00006	220917110	99.91	100.05	99.92	I70S	20011207	20020101
00006	220917111	99.99	100.51	100.05	I70S	20011207	20020101
00006	220917112	99.99	100.39	99.94	I70S	20011207	20020101
00006	220917113	99.98	99.75	100.14	I70S	20011207	20020101
00006	220917114	99.94	99.61	99.99	I70S	20011207	20020101
00006	220917115	99.98	100.05	100.12	I70S	20011207	20020101
00006	220917116	99.87	99.77	99.86	I70S	20011207	20020101
00006	220917117	100.02	100.25	99.9	I70S	20011207	20020101
00006	220917118	100.01	99.85	99.97	I70S	20011207	20020101
00006	220917119	100.04	99.92	99.91	I70S	20011207	20020101
00006	220917120	100.03	100.02	100.08	I70S	20011207	20020101
00006	220917121	99.97	100.39	99.95	I70S	20011207	20020101
00006	220917122	99.93	100.27	100.02	I70S	20011207	20020101
00006	220917123	100.11	100	100.04	I70S	20011207	20020101
00006	220917124	99.98	100.03	99.99	I70S	20011207	20020101
00006	220917125	100.08	100.01	99.97	I70S	20011207	20020101
00006	220917414	100.04	99.78	100.07	I70S	20011207	20020101
00006	220917415	100.03	99.75	100.07	I70S	20011207	20020101
00006	220917416	99.95	100	100.12	I70S	20011207	20020101
00006	220917417	100.09	100.04	99.93	I70S	20011207	20020101
00006	220917418	99.98	99.96	100.01	I70S	20011207	20020101
00006	220917419	99.94	100.08	99.91	I70S	20011207	20020101
00006	220917420	100.06	100.21	100.09	I70S	20011207	20020101
00006	220917421	100.12	100.35	100.05	I70S	20011207	20020101
00006	220917422	100.06	99.83	99.99	I70S	20011207	20020101
00006	220917423	100	99.96	99.97	I70S	20011207	20020101
00006	220917424	100.05	100.33	99.96	I70S	20011207	20020101
00006	220917425	100.14	99.92	99.87	I70S	20011207	20020101
00006	220917426	100.06	100.02	99.87	I70S	20011207	20020101
00006	220917427	100.01	100.63	100.03	I70S	20011207	20020101
00006	220917428	100.02	99.43	99.86	I70S	20011207	20020101
00006	220917429	99.91	100.61	100.12	I70S	20011207	20020101
00006	220917430	100.11	99.87	100.01	I70S	20011207	20020101
00006	220917431	99.98	99.88	100.01	I70S	20011207	20020101
00006	220917432	99.94	99.98	100.02	I70S	20011207	20020101
00006	220917433	99.9	99.96	100.01	I70S	20011207	20020101
00006	220917434	100.06	100.34	100.03	I70S	20011207	20020101
00006	220917435	100.01	100.4	100.14	I70S	20011207	20020101

KY CTESTS for 2002

00006	220917436	99.93	100.13	99.88	I70S	20011207	20020101
00006	220917437	100.04	100.35	100.02	I70S	20011207	20020101
00006	220917438	100.06	99.83	99.99	I70S	20011207	20020101
00006	220917439	99.95	99.86	100.06	I70S	20011207	20020101
00006	220917440	100.08	100.61	100.01	I70S	20011207	20020101
00006	220917441	99.94	100.16	99.92	I70S	20011207	20020101
00006	220917442	100.09	100.15	100.1	I70S	20011207	20020101
00006	220917443	99.93	99.64	99.95	I70S	20011207	20020101
00006	220917444	99.92	99.89	100.02	I70S	20011207	20020101
00006	220917445	100.01	100.03	100.06	I70S	20011207	20020101
00006	220917446	100.07	100.15	100.08	I70S	20011207	20020101
00006	220917447	100.04	100.53	100.07	I70S	20011207	20020101
00006	220917448	99.93	99.9	99.95	I70S	20011207	20020101
00006	220917449	100.03	99.94	99.95	I70S	20011207	20020101
00006	220917450	100.11	100.25	100.01	I70S	20011207	20020101
00006	220917451	100.13	99.4	100.14	I70S	20011207	20020101
00006	220917452	100.01	100.02	100.02	I70S	20011207	20020101
00006	220917453	100.13	100.34	99.87	I70S	20011207	20020101
00006	220917454	99.96	99.85	99.89	I70S	20011207	20020101
00006	220917455	100.04	100.49	99.89	I70S	20011207	20020101
00006	220917456	100.08	100.08	99.92	I70S	20011207	20020101
00006	220917458	100.04	100.53	100.07	I70S	20011207	20020101
00006	220917459	100.05	99.79	99.98	I70S	20011207	20020101
00006	220917460	100	99.59	100	I70S	20011207	20020101
00006	220917462	99.97	100.26	100.06	I70S	20011207	20020101
00006	220917463	99.97	100.56	100.01	I70S	20011207	20020101
00006	220917464	100.11	100.29	100.08	I70S	20011207	20020101
00006	220917465	100.06	100.08	100.09	I70S	20011207	20020101
00006	220917466	99.94	100.69	99.86	I70S	20011207	20020101
00006	220917467	100.08	99.91	99.94	I70S	20011207	20020101
00006	220917468	100.04	99.86	99.96	I70S	20011207	20020101
00006	220917469	99.98	99.94	99.94	I70S	20011207	20020101
00006	220917470	100.06	100.17	100.06	I70S	20011207	20020101
00006	220917471	100.04	100.14	99.86	I70S	20011207	20020101
00006	220917472	99.99	99.77	100.06	I70S	20011207	20020101
00006	220917473	99.99	100.3	100.07	I70S	20011207	20020101
00006	220917474	99.96	99.58	100.06	I70S	20011207	20020101
00006	220917475	100.04	100.3	100.02	I70S	20011207	20020101
00006	220917476	100.01	100.27	99.98	I70S	20011207	20020101
00006	220917477	100.03	100.01	99.95	I70S	20011207	20020101
00006	220917479	100.06	99.69	99.98	I70S	20011207	20020101
00006	220917480	100.07	100.26	100.02	I70S	20011207	20020101
00006	220917481	100.13	99.42	100.01	I70S	20011207	20020101
00006	220917482	100.11	100.09	99.88	I70S	20011207	20020101
00006	220917483	100.04	100.27	100.13	I70S	20011207	20020101
00006	220917484	99.97	99.77	99.94	I70S	20011207	20020101
00006	220917485	99.93	100.04	99.93	I70S	20011207	20020101
00006	220917486	99.97	100.18	99.96	I70S	20011207	20020101
00006	220917487	99.99	100.11	99.89	I70S	20011207	20020101
00006	220917488	100.07	100.16	99.95	I70S	20011207	20020101
00006	220917489	99.96	100.1	99.99	I70S	20011207	20020101
00006	220917490	100.03	100.24	100.02	I70S	20011207	20020101
00006	220917491	99.9	99.81	99.89	I70S	20011207	20020101
00006	220917492	100.05	100.06	99.99	I70S	20011207	20020101
00006	220917493	99.94	99.32	99.87	I70S	20011207	20020101
00006	220917494	100.06	99.93	99.9	I70S	20011207	20020101
00006	220917495	100.04	100.18	100.07	I70S	20011207	20020101
00006	220917497	100	99.33	99.91	I70S	20011207	20020101
00006	220917498	99.9	99.96	100.01	I70S	20011207	20020101
00006	220917499	100.12	100.25	99.99	I70S	20011207	20020101
00006	220917500	99.89	99.94	99.94	I70S	20011207	20020101

KY CTESTS for 2002

00006	220917501	100.07	99.88	99.98	I70S	20011207	20020101
00006	220917502	99.89	100.09	100.05	I70S	20011207	20020101
00006	220917503	100.06	100.19	100.14	I70S	20011207	20020101
00006	220917504	100.01	100.29	99.96	I70S	20011207	20020101
00006	220917505	100.11	100.63	100.06	I70S	20011207	20020101
00006	220917506	100.08	100.04	100.1	I70S	20011207	20020101
00006	220917507	100	99.78	99.98	I70S	20011207	20020101
00006	220917508	99.99	99.79	100.09	I70S	20011207	20020101
00006	220917509	99.87	100.1	100.1	I70S	20011207	20020101
00006	220917514	100.06	100.53	100.05	I70S	20011207	20020101
00006	220917515	99.99	100.08	100.02	I70S	20011207	20020101
00006	220917516	99.93	100.14	99.86	I70S	20011207	20020101
00006	220917517	100.05	100.17	100.04	I70S	20011207	20020101
00006	220917526	100.02	100.19	100.09	I70S	20011207	20020101
00006	220917527	100.04	100.49	99.89	I70S	20011207	20020101
00006	220917528	99.88	99.72	99.89	I70S	20011207	20020101
00006	220917529	99.96	100.09	99.97	I70S	20011207	20020101
00006	220917534	100.11	100.21	100.13	I70S	20011207	20020101
00006	220917535	100	100.1	99.92	I70S	20011207	20020101
00006	220917536	100.09	100.4	99.87	I70S	20011207	20020101
00006	220917537	100.05	100.11	99.95	I70S	20011207	20020101
00006	220917538	100.01	99.75	99.87	I70S	20011207	20020101
00006	220917539	100.14	100.54	99.97	I70S	20011207	20020101
00006	220917540	99.99	100.14	99.99	I70S	20011207	20020101
00006	220917541	99.93	99.96	99.87	I70S	20011207	20020101
00006	220917560	100.02	100.28	100.07	I70S	20011207	20020101
00006	220917561	100.03	100.12	99.91	I70S	20011207	20020101
00006	220917563	99.94	99.98	100.02	I70S	20011207	20020101
00006	220917564	99.94	100.14	99.89	I70S	20011207	20020101
00006	220917565	99.99	100.12	100.1	I70S	20011207	20020101
00006	220917582	100.09	100.04	99.93	I70S	20011207	20020101
00006	220917583	99.98	100.24	100.1	I70S	20011207	20020101
00006	220917584	99.94	100.14	99.89	I70S	20011207	20020101
00006	220917585	100.06	99.83	99.99	I70S	20011207	20020101
00006	220917598	99.97	99.81	99.96	I70S	20011207	20020101
00006	220917599	100	100.31	100.12	I70S	20011207	20020101
00006	220917600	100.14	99.92	99.87	I70S	20011207	20020101
00006	220917601	99.99	99.74	100.05	I70S	20011207	20020101
00006	220917602	100.09	100.04	99.93	I70S	20011207	20020101
00006	220917605	99.98	99.51	99.94	I70S	20011207	20020101
00006	220918950	100.01	99.74	100.05	I70S	20011208	20020102
00006	220918951	100.04	99.84	100.06	I70S	20011208	20020102
00006	220918952	100.02	99.91	99.95	I70S	20011208	20020102
00006	220918953	100.06	99.44	100.1	I70S	20011208	20020102
00006	220918954	99.95	99.85	99.96	I70S	20011208	20020102
00006	220918955	100.11	99.49	99.98	I70S	20011208	20020102
00006	220918956	100.05	100.11	100.07	I70S	20011208	20020102
00006	220918957	99.9	99.94	99.94	I70S	20011208	20020102
00006	220918958	99.96	100.18	99.99	I70S	20011208	20020102
00006	220918959	99.9	100.16	99.98	I70S	20011208	20020102
00006	220918960	100.01	99.8	100.1	I70S	20011208	20020102
00006	220918961	100.05	99.68	100.03	I70S	20011208	20020102
00006	220918962	100	100.32	100.14	I70S	20011208	20020102
00006	220918963	100.08	99.48	99.97	I70S	20011208	20020102
00006	220918964	100.07	100.29	100.07	I70S	20011208	20020102
00006	220918965	100.1	100.1	100.02	I70S	20011208	20020102
00006	220918970	100.08	99.62	99.96	I70S	20011208	20020102
00006	220918971	100.06	99.73	99.98	I70S	20011208	20020102
00006	220918973	100.06	100.2	99.94	I70S	20011208	20020102
00006	220918990	100.05	99.58	100.03	I70S	20011208	20020102
00006	220918991	100.06	100.67	99.99	I70S	20011208	20020102

KY CTESTS for 2002

00006	220918992	100.07	99.56	99.97	I70S	20011208	20020102
00006	220918993	99.99	99.74	100.04	I70S	20011208	20020102
00006	220918994	100	99.36	100.13	I70S	20011208	20020102
00006	220918995	100.06	99.44	100.1	I70S	20011208	20020102
00006	220918996	99.88	99.49	99.99	I70S	20011208	20020102
00006	220918997	99.99	100.49	100.05	I70S	20011208	20020102
00006	220918998	100.01	99.73	100.02	I70S	20011208	20020102
00006	220918999	100.01	100.31	100.1	I70S	20011208	20020102
00006	220919000	100.07	99.88	100.05	I70S	20011210	20020102
00006	220919001	100	100.41	100.05	I70S	20011208	20020102
00006	220919018	100.05	99.97	100.09	I70S	20011208	20020102
00006	220919019	99.99	100.02	100.08	I70S	20011208	20020102
00006	220919020	100	100.01	99.93	I70S	20011208	20020102
00006	220919021	100.04	99.96	99.94	I70S	20011208	20020102
00006	220919022	100.03	100.07	100.06	I70S	20011208	20020102
00006	220919023	99.99	99.88	99.98	I70S	20011208	20020102
00006	220919024	100.08	100.03	99.96	I70S	20011208	20020102
00006	220919025	100.04	99.67	100.01	I70S	20011208	20020102
00006	220919026	100	99.61	99.95	I70S	20011208	20020102
00006	220919027	100.07	100.06	99.94	I70S	20011208	20020102
00006	220919028	100.01	99.45	100.02	I70S	20011208	20020102
00006	220919029	100.08	99.94	100	I70S	20011208	20020102
00006	220919030	99.9	99.87	99.89	I70S	20011208	20020102
00006	220919031	100.03	99.84	100.09	I70S	20011208	20020102
00006	220919032	99.95	99.39	99.91	I70S	20011208	20020102
00006	220919033	100.08	99.85	99.92	I70S	20011208	20020102
00006	220919034	100.02	100.24	99.88	I70S	20011208	20020102
00006	220919035	100.04	99.61	100.02	I70S	20011208	20020102
00006	220919036	100.04	99.96	99.94	I70S	20011208	20020102
00006	220919037	100.01	100.22	100.08	I70S	20011208	20020102
00006	220919038	99.99	99.96	100.02	I70S	20011208	20020102
00006	220919039	99.98	99.95	100.01	I70S	20011208	20020102
00006	220919040	100.01	99.93	100.08	I70S	20011208	20020102
00006	220919041	100.04	100.32	100.1	I70S	20011208	20020102
00006	220919042	100.01	100.48	100.12	I70S	20011208	20020102
00006	220919043	100.01	100.18	100	I70S	20011208	20020102
00006	220919044	100.01	99.8	100.03	I70S	20011208	20020102
00006	220919045	99.95	100.03	100.14	I70S	20011208	20020102
00006	220945101	100.06	100.46	100.12	I70S	20011213	20020109
00006	220945103	99.93	100.24	99.89	I70S	20011213	20020109
00006	220945104	100.05	100.19	100.06	I70S	20011213	20020109
00006	220945105	100.05	99.91	99.88	I70S	20011213	20020109
00006	220945106	100	100.18	99.98	I70S	20011213	20020109
00006	220945107	99.95	100.14	99.94	I70S	20011213	20020109
00006	220945108	99.99	99.52	99.97	I70S	20011213	20020109
00006	220945109	99.92	100.07	99.95	I70S	20011213	20020109
00006	220945110	100.01	100	99.91	I70S	20011213	20020109
00006	220945111	100.05	100.16	99.94	I70S	20011213	20020109
00006	220945112	99.97	99.84	99.96	I70S	20011213	20020109
00006	220945114	100.06	99.92	100.14	I70S	20011213	20020109
00006	220945115	100.13	99.98	100.14	I70S	20011213	20020109
00006	220945116	100.05	100.23	99.91	I70S	20011213	20020109
00006	220945117	99.96	100.14	99.96	I70S	20011213	20020109
00006	220945118	100.02	99.85	99.95	I70S	20011213	20020109
00006	220945119	99.91	99.77	99.88	I70S	20011213	20020109
00006	220945123	99.87	100.24	100.12	I70S	20011213	20020109
00006	220945124	100.01	99.33	100.01	I70S	20011213	20020109
00006	220945125	100.01	99.92	100.03	I70S	20011213	20020109
00006	220945126	100.05	100	99.95	I70S	20011213	20020109
00006	220945127	100.03	100.16	99.91	I70S	20011213	20020109
00006	220945128	99.99	100.01	99.92	I70S	20011213	20020109

KY CTESTS for 2002

00006	220945129	100.07	100.23	99.96	I70S	20011213	20020109
00006	220945130	100.03	100.22	100.05	I70S	20011213	20020109
00006	220945131	100.01	99.55	100.05	I70S	20011213	20020109
00006	220945134	99.99	99.93	100.01	I70S	20011213	20020109
00006	220945135	99.93	99.83	100.14	I70S	20011213	20020109
00006	220945136	99.99	100.35	99.98	I70S	20011213	20020109
00006	220945137	100.05	100.24	100.06	I70S	20011213	20020109
00006	220945138	100.03	99.44	99.97	I70S	20011213	20020109
00006	220945139	99.96	100.07	99.97	I70S	20011213	20020109
00006	220945141	100.09	100.36	100.08	I70S	20011213	20020109
00006	220945142	100.05	100.1	100.02	I70S	20011213	20020109
00006	220945143	99.94	99.73	99.99	I70S	20011213	20020109
00006	220945145	100.01	99.69	99.91	I70S	20011213	20020109
00006	220945146	100.04	99.84	99.91	I70S	20011213	20020109
00006	220945147	100.04	100.17	100.12	I70S	20011213	20020109
00006	220945148	99.96	99.86	99.91	I70S	20011213	20020109
00006	220945150	99.99	99.95	99.92	I70S	20011213	20020109
00006	220945151	99.97	100.08	99.92	I70S	20011213	20020109
00006	220945154	100.01	100.31	100.08	I70S	20011213	20020109
00006	220945160	99.96	99.84	100.02	I70S	20011213	20020109
00006	220945161	100.03	100.02	100.12	I70S	20011213	20020109
00006	220945162	99.95	99.69	99.91	I70S	20011213	20020109
00006	220945163	99.97	100.32	100.03	I70S	20011213	20020109
00006	220945164	100.04	100.3	99.95	I70S	20011213	20020109
00006	220945165	100.02	99.82	100.03	I70S	20011215	20020109
00006	220945166	100.02	99.95	100.04	I70S	20011215	20020109
00006	220945167	100.04	100.44	99.89	I70S	20011215	20020109
00006	220945168	100.03	99.76	99.96	I70S	20011215	20020109
00006	220945169	100.06	99.95	99.96	I70S	20011215	20020109
00006	220945170	99.93	99.71	99.87	I70S	20011215	20020109
00006	220945171	100.02	100.11	100	I70S	20011215	20020109
00006	220945172	100.07	100.3	100.12	I70S	20011215	20020109
00006	220945173	100.08	99.95	99.95	I70S	20011215	20020109
00006	220945174	99.99	100	100.14	I70S	20011215	20020109
00006	220945175	99.93	100.47	99.99	I70S	20011215	20020109
00006	220945180	99.99	100.23	99.87	I70S	20011215	20020109
00006	220945181	99.95	100.1	99.98	I70S	20011215	20020109
00006	220945182	99.9	100.11	99.97	I70S	20011215	20020109
00006	220945183	100.07	99.81	100.13	I70S	20011215	20020109
00006	220945184	100.02	100.04	100.08	I70S	20011215	20020109
00006	220945186	100.02	100.07	100.06	I70S	20011215	20020109
00006	220945189	100.04	100	99.88	I70S	20011215	20020109
00006	220945192	99.98	99.5	100.05	I70S	20011215	20020109
00006	220945193	100	100.32	99.98	I70S	20011215	20020109
00006	220945194	99.95	100.01	99.88	I70S	20011215	20020109
00006	220945196	99.88	99.94	100.07	I70S	20011213	20020109
00006	220945197	100.05	100.55	99.87	I70S	20011213	20020109
00006	220945200	100.09	100.04	99.98	I70S	20011213	20020109
00006	220945201	100.03	100.09	99.95	I70S	20011213	20020109
00006	220945202	100.04	100.2	99.91	I70S	20011213	20020109
00006	220945203	100.05	99.87	99.91	I70S	20011213	20020109
00006	220945204	99.97	99.96	100	I70S	20011213	20020109
00006	220945205	100	100.12	99.99	I70S	20011213	20020109
00006	220945206	100.05	99.7	99.95	I70S	20011213	20020109
00006	220945207	100.02	100	100.09	I70S	20011213	20020109
00006	220945208	100.02	100.34	100.04	I70S	20011213	20020109
00006	220945209	99.94	99.96	100.08	I70S	20011213	20020109
00006	220945210	100.01	99.77	99.99	I70S	20011213	20020109
00006	220945211	99.97	99.89	99.96	I70S	20011213	20020109
00006	220945212	100.07	99.76	100.12	I70S	20011213	20020109
00006	220945213	99.94	100.14	99.97	I70S	20011213	20020109

KY CTESTS for 2002

00006	220945214	99.94	99.7	99.87	I70S	20011213	20020109
00006	220945215	100.06	99.81	100.06	I70S	20011213	20020109
00006	220945216	100.09	99.73	99.9	I70S	20011213	20020109
00006	220945217	99.95	99.8	99.97	I70S	20011213	20020109
00006	220945218	100.01	100.4	99.96	I70S	20011213	20020109
00006	220945219	100.06	99.34	100.05	I70S	20011213	20020109
00006	220945220	99.87	99.98	99.92	I70S	20011213	20020109
00006	220945222	100.06	99.96	99.87	I70S	20011213	20020109
00006	220945223	99.88	99.75	100.01	I70S	20011213	20020109
00006	220945224	99.94	99.68	100.12	I70S	20011213	20020109
00006	220945225	100.04	100.08	100.02	I70S	20011213	20020109
00006	220945226	99.99	100.08	99.89	I70S	20011213	20020109
00006	220945227	99.94	100.59	99.86	I70S	20011213	20020109
00006	220945228	100.01	100.47	100	I70S	20011213	20020109
00006	220945229	100.08	100.07	100.01	I70S	20011213	20020109
00006	220945230	100.07	99.54	99.98	I70S	20011213	20020109
00006	220945231	99.87	99.56	99.94	I70S	20011213	20020109
00006	220945232	99.93	100.65	99.95	I70S	20011213	20020109
00006	220945233	99.92	100.19	99.87	I70S	20011213	20020109
00006	220945234	100.07	100.17	99.98	I70S	20011213	20020109
00006	220945235	100.03	99.82	100.11	I70S	20011213	20020109
00006	220945236	99.97	100.49	99.98	I70S	20011213	20020109
00006	220945237	100.01	100.11	100.11	I70S	20011213	20020109
00006	220945238	100	99.84	100.04	I70S	20011213	20020109
00006	220945239	99.9	100.04	99.98	I70S	20011213	20020109
00006	220945240	99.92	99.92	99.88	I70S	20011213	20020109
00006	220945241	100	99.65	99.99	I70S	20011213	20020109
00006	220945242	99.98	99.78	99.98	I70S	20011213	20020109
00006	220945243	100.01	100.12	100.03	I70S	20011213	20020109
00006	220945244	99.92	100.2	99.99	I70S	20011213	20020109
00006	220945245	100.02	100.09	99.89	I70S	20011213	20020109
00006	220945246	99.98	100.35	100.05	I70S	20011213	20020109
00006	220945247	100.06	99.64	100.05	I70S	20011213	20020109
00006	220945248	100.02	100.16	100.02	I70S	20011213	20020109
00006	220945249	99.95	99.96	99.99	I70S	20011213	20020109
00006	220945250	100.03	99.9	100.03	I70S	20011213	20020109
00006	220945251	99.97	100.45	99.94	I70S	20011213	20020109
00006	220945252	100	99.55	99.92	I70S	20011213	20020109
00006	220945253	99.99	99.73	99.97	I70S	20011213	20020109
00006	220945254	100.05	100.33	99.99	I70S	20011213	20020109
00006	220945255	100.08	100.11	99.92	I70S	20011213	20020109
00006	220945256	99.96	99.96	99.86	I70S	20011213	20020109
00006	220945257	100.01	99.9	100.09	I70S	20011213	20020109
00006	220945258	100.09	99.73	99.9	I70S	20011213	20020109
00006	220945259	100.07	99.89	100.08	I70S	20011213	20020109
00006	220945260	99.94	100.01	99.92	I70S	20011213	20020109
00006	220945261	100.05	99.77	99.96	I70S	20011213	20020109
00006	220945262	99.99	100.61	100.09	I70S	20011213	20020109
00006	220945263	99.86	100.17	99.88	I70S	20011213	20020109
00006	220945264	99.99	100.61	100.09	I70S	20011213	20020109
00006	220945265	100.07	100.06	100.04	I70S	20011213	20020109
00006	220945266	100.11	99.99	100.05	I70S	20011213	20020109
00006	220945267	100.06	100.13	100.1	I70S	20011213	20020109
00006	220945268	100.04	100.05	100.1	I70S	20011213	20020109
00006	220945269	99.97	99.69	99.91	I70S	20011213	20020109
00006	220945272	100.02	100.35	100.04	I70S	20011213	20020109
00006	220945273	100.02	100.34	100.04	I70S	20011213	20020109
00006	220945274	100.06	99.34	100.05	I70S	20011213	20020109
00006	220945276	99.98	99.93	99.91	I70S	20011213	20020109
00006	220945277	99.97	100.03	99.88	I70S	20011213	20020109
00006	220945278	100.03	100.09	99.95	I70S	20011213	20020109

KY CTESTS for 2002

00006	220945279	99.95	99.46	100.06	I70S	20011213	20020109
00006	220945280	100.02	100.39	100.03	I70S	20011213	20020109
00006	220945281	100.08	99.9	99.9	I70S	20011213	20020109
00006	220945282	99.95	99.51	99.9	I70S	20011213	20020109
00006	220945283	100.05	100.09	99.87	I70S	20011213	20020109
00006	220945284	100.07	99.89	100.08	I70S	20011213	20020109
00006	220945285	99.96	100.43	99.95	I70S	20011213	20020109
00006	220945286	99.95	99.96	99.99	I70S	20011213	20020109
00006	220945287	100.01	99.68	100.11	I70S	20011213	20020109
00006	220945288	100.05	100.18	100.1	I70S	20011213	20020109
00006	220945289	100.04	99.99	99.91	I70S	20011213	20020109
00006	220945290	100.04	99.52	99.96	I70S	20011213	20020109
00006	220945291	99.96	99.69	100.03	I70S	20011213	20020109
00006	220945580	99.99	99.9	100.08	I70S	20011213	20020109
00006	220945581	99.96	100.11	100.07	I70S	20011213	20020109
00006	220945582	100	100.26	99.94	I70S	20011213	20020109
00006	220945583	100.01	99.83	100	I70S	20011213	20020109
00006	220945584	100.12	100.22	99.86	I70S	20011213	20020109
00006	220945585	99.98	99.78	99.86	I70S	20011213	20020109
00006	220945586	100.09	100.51	100.06	I70S	20011213	20020109
00006	220945587	99.88	99.91	100.13	I70S	20011213	20020109
00006	220945588	100.1	100.36	100.01	I70S	20011213	20020109
00006	220945589	100.04	100.63	100.08	I70S	20011213	20020109
00006	220945590	99.97	99.59	100	I70S	20011213	20020109
00006	220945591	99.99	100.16	100.02	I70S	20011213	20020109
00006	220945592	100.11	99.81	100.12	I70S	20011213	20020109
00006	220945593	100.09	100.35	100.08	I70S	20011213	20020109
00006	220945594	100	100.06	99.92	I70S	20011213	20020109
00006	220945595	99.98	100.56	99.92	I70S	20011213	20020109
00006	220945596	100.05	100	99.88	I70S	20011213	20020109
00006	220945597	99.91	99.86	100.01	I70S	20011213	20020109
00006	220945598	99.98	100.13	100.01	I70S	20011213	20020109
00006	220945599	100.03	99.73	99.9	I70S	20011214	20020109
00006	220945600	100	99.83	100	I70S	20011214	20020109
00006	220945601	100.08	99.73	100.14	I70S	20011214	20020109
00006	220945602	99.95	100.58	99.94	I70S	20011214	20020109
00006	220945603	99.92	99.91	99.89	I70S	20011214	20020109
00006	220945604	99.93	100.68	99.88	I70S	20011214	20020109
00006	220945605	100.06	100.55	100.04	I70S	20011214	20020109
00006	220945606	100.02	99.55	99.9	I70S	20011214	20020109
00006	220945607	99.96	100.3	100	I70S	20011214	20020109
00006	220945608	100.06	99.89	99.86	I70S	20011214	20020109
00006	220945609	100.04	100.52	99.99	I70S	20011214	20020109
00006	220945610	99.95	99.61	100.14	I70S	20011214	20020109
00006	220945611	99.92	99.78	100.03	I70S	20011214	20020109
00006	220945612	100.02	100.22	100.08	I70S	20011214	20020109
00006	220945613	100.13	100.08	99.98	I70S	20011214	20020109
00006	220945614	99.97	100.16	99.9	I70S	20011214	20020109
00006	220945615	100	99.99	100.02	I70S	20011214	20020109
00006	220945616	100.13	99.99	99.91	I70S	20011214	20020109
00006	220945617	100.05	100.34	100.03	I70S	20011214	20020109
00006	220945618	99.91	100.06	100.05	I70S	20011214	20020109
00006	220945619	99.91	100.33	99.89	I70S	20011214	20020109
00006	220945620	99.95	99.94	100.01	I70S	20011214	20020109
00006	220945621	100.09	100.19	100.01	I70S	20011214	20020109
00006	220945622	99.95	99.52	99.87	I70S	20011214	20020109
00006	220945623	100.1	100.24	100.1	I70S	20011214	20020109
00006	220945624	99.98	100.11	100.02	I70S	20011214	20020109
00006	220945625	100.04	100.15	100	I70S	20011214	20020109
00006	220945626	100.07	100.68	100.11	I70S	20011214	20020109
00006	220945627	100.07	100.58	99.94	I70S	20011214	20020109

KY CTESTS for 2002

00006	220945628	99.95	100.08	99.9	I70S	20011214	20020109
00006	220945629	100.02	100.34	99.94	I70S	20011214	20020109
00006	220945630	100.03	99.93	99.97	I70S	20011214	20020109
00006	220945631	100.03	99.73	99.95	I70S	20011214	20020109
00006	220945632	100.1	100.37	100	I70S	20011214	20020109
00006	220945633	100.06	100.37	100.08	I70S	20011214	20020109
00006	220945634	100.11	100.44	100	I70S	20011214	20020109
00006	220945635	100.01	100.11	99.87	I70S	20011214	20020109
00006	220945636	100.03	100.11	99.91	I70S	20011214	20020109
00006	220945637	100.03	100.16	100.14	I70S	20011214	20020109
00006	220945638	100.12	100.47	99.87	I70S	20011214	20020109
00006	220945639	100	100.33	99.95	I70S	20011214	20020109
00006	220945640	99.97	100.16	99.98	I70S	20011214	20020109
00006	220945641	100.06	100.41	100.09	I70S	20011214	20020109
00006	220945642	100.1	99.99	100.11	I70S	20011214	20020109
00006	220945643	99.99	100.11	100.08	I70S	20011214	20020109
00006	220945644	100.04	99.8	99.91	I70S	20011214	20020109
00006	220945645	100.01	100.19	100.01	I70S	20011214	20020109
00006	220945646	100.04	100.47	100.1	I70S	20011214	20020109
00006	220945647	100	99.87	100.13	I70S	20011214	20020109
00006	220945648	99.91	100.41	100.05	I70S	20011214	20020109
00006	220945649	100.03	100.47	99.89	I70S	20011214	20020109
00006	220945650	99.92	100.29	99.87	I70S	20011214	20020109
00006	220945651	99.98	99.93	100.1	I70S	20011214	20020109
00006	220945652	99.9	99.81	99.95	I70S	20011214	20020109
00006	220945653	99.88	99.85	100	I70S	20011214	20020109
00006	220945654	99.9	99.86	99.94	I70S	20011214	20020109
00006	220945655	100.04	99.92	99.99	I70S	20011214	20020109
00006	220945656	100.01	100.41	99.93	I70S	20011214	20020109
00006	220945657	100.07	100	100.14	I70S	20011214	20020109
00006	220945658	99.96	100.09	99.9	I70S	20011214	20020109
00006	220945659	99.95	100.35	100.07	I70S	20011214	20020109
00006	220945660	100.01	100.52	100.05	I70S	20011214	20020109
00006	220945661	99.98	99.96	100.05	I70S	20011214	20020109
00006	220945662	100.11	100.42	99.91	I70S	20011214	20020109
00006	220945663	99.96	99.46	99.88	I70S	20011214	20020109
00006	220945664	99.97	100.41	99.97	I70S	20011214	20020109
00006	220945665	100.01	100.21	100.01	I70S	20011214	20020109
00006	220945666	99.94	99.9	99.95	I70S	20011214	20020109
00006	220945667	99.95	99.91	100.01	I70S	20011214	20020109
00006	220945668	100.04	100.15	100.13	I70S	20011214	20020109
00006	220945669	100	100.22	100.13	I70S	20011214	20020109
00006	220945670	100.03	100.15	100.13	I70S	20011214	20020109
00006	220945671	100.06	99.4	100.05	I70S	20011214	20020109
00006	220945673	99.91	99.97	99.92	I70S	20011214	20020109
00006	220945674	99.93	99.74	100.05	I70S	20011214	20020109
00006	220945675	100.06	100.21	100.06	I70S	20011214	20020109
00006	220945676	99.95	100	100	I70S	20011213	20020109
00006	220945677	99.96	100.28	100.09	I70S	20011213	20020109
00006	220945678	99.99	100.15	100.06	I70S	20011213	20020109
00006	220945679	99.93	100.04	100.06	I70S	20011213	20020109
00006	220945680	100.05	99.88	99.9	I70S	20011213	20020109
00006	220945681	100.02	99.67	99.92	I70S	20011213	20020109
00006	220945682	99.98	100.29	100.02	I70S	20011213	20020109
00006	220945683	100.06	99.56	100.08	I70S	20011213	20020109
00006	220945684	100.06	100.41	100.12	I70S	20011213	20020109
00006	220945685	100.02	100.48	100.12	I70S	20011213	20020109
00006	220945686	99.93	99.62	100.09	I70S	20011213	20020109
00006	220945687	100.02	100.34	100.04	I70S	20011213	20020109
00006	220945688	99.95	99.9	99.96	I70S	20011213	20020109
00006	220945689	99.99	99.79	99.9	I70S	20011213	20020109

KY CTESTS for 2002

00006	220945690	100.07	100.02	100.1	I70S	20011213	20020109
00006	220945691	100.03	99.33	100.13	I70S	20011213	20020109
00006	220945692	100.01	100.1	100.14	I70S	20011213	20020109
00006	220945693	100.07	99.82	99.87	I70S	20011213	20020109
00006	220945694	100.08	100.66	100.03	I70S	20011213	20020109
00006	220945695	99.97	100.08	100.02	I70S	20011213	20020109
00006	220945696	99.88	99.46	99.91	I70S	20011213	20020109
00006	220945697	100.06	99.83	99.99	I70S	20011213	20020109
00006	220945698	99.86	100.67	99.92	I70S	20011213	20020109
00006	220945699	100.07	99.84	99.92	I70S	20011213	20020109
00006	220945700	100.03	100.18	100.13	I70S	20011213	20020109
00006	220945701	99.97	99.9	99.91	I70S	20011213	20020109
00006	220945703	100.09	99.87	100.1	I70S	20011213	20020109
00006	220945704	99.92	99.84	100	I70S	20011213	20020109
00006	220945705	100.05	99.83	99.9	I70S	20011213	20020109
00006	220945706	100.08	100.66	100.06	I70S	20011213	20020109
00006	220945707	99.98	100.29	100.11	I70S	20011213	20020109
00006	220945708	100.06	99.56	100.01	I70S	20011213	20020109
00006	220945709	100.12	99.85	100	I70S	20011213	20020109
00006	220945710	100.01	100.14	100.14	I70S	20011213	20020109
00006	220945711	100.04	99.56	99.94	I70S	20011213	20020109
00006	220945712	99.99	100.1	99.95	I70S	20011213	20020109
00006	220945713	99.97	99.87	99.96	I70S	20011213	20020109
00006	220945714	99.99	100.13	100	I70S	20011213	20020109
00006	220945715	99.94	100.16	99.97	I70S	20011213	20020109
00006	220945716	100.02	99.75	99.92	I70S	20011213	20020109
00006	220945717	100.08	99.87	100.01	I70S	20011213	20020109
00006	220945718	100.03	100.28	100.05	I70S	20011213	20020109
00006	220945719	99.96	99.54	99.89	I70S	20011213	20020109
00006	220945720	100.02	99.85	100.05	I70S	20011213	20020109
00006	220945721	100.01	100.56	100	I70S	20011213	20020109
00006	220945722	99.91	100.08	100.12	I70S	20011213	20020109
00006	220945723	100.02	99.67	100	I70S	20011213	20020109
00006	220945724	99.97	99.92	100.14	I70S	20011213	20020109
00006	220945725	99.96	99.59	100.08	I70S	20011213	20020109
00006	220945726	99.97	99.41	99.89	I70S	20011213	20020109
00006	220945727	100	99.88	100.06	I70S	20011213	20020109
00006	220945728	100.06	100.17	99.94	I70S	20011213	20020109
00006	220945729	100.02	100.66	99.86	I70S	20011213	20020109
00006	220945730	100.07	99.84	99.92	I70S	20011213	20020109
00006	220945731	100.03	99.75	100.14	I70S	20011213	20020109
00006	220945732	100.05	99.43	99.94	I70S	20011213	20020109
00006	220945733	99.97	99.9	99.91	I70S	20011213	20020109
00006	220945734	100.02	99.85	99.9	I70S	20011213	20020109
00006	220945735	100	99.98	99.95	I70S	20011213	20020109
00006	220945736	100.03	99.91	99.86	I70S	20011213	20020109
00006	220945737	99.93	99.73	99.89	I70S	20011213	20020109
00006	220945738	100.07	100.33	100.06	I70S	20011213	20020109
00006	220945739	99.98	99.86	100.1	I70S	20011213	20020109
00006	220945740	100.04	99.95	99.93	I70S	20011213	20020109
00006	220945741	100.05	99.93	100.14	I70S	20011213	20020109
00006	220945744	100.07	100.15	99.97	I70S	20011213	20020109
00006	220945745	100.06	100.14	99.98	I70S	20011213	20020109
00006	220945746	100.04	100.33	99.89	I70S	20011213	20020109
00006	220945747	99.98	100.22	99.88	I70S	20011213	20020109
00006	220945748	99.86	99.5	100.06	I70S	20011213	20020109
00006	220945749	100.01	99.9	100.12	I70S	20011213	20020109
00006	220945750	100.03	99.67	99.92	I70S	20011213	20020109
00006	220945752	99.96	99.54	99.89	I70S	20011213	20020109
00006	220945753	99.96	99.73	100.03	I70S	20011213	20020109
00006	220945754	100.02	100.65	100	I70S	20011213	20020109

KY CTESTS for 2002

00006	220945755	100.08	100.39	100.08	I70S	20011213	20020109
00006	220945756	100.01	100.07	99.87	I70S	20011213	20020109
00006	220945757	100.04	99.89	99.92	I70S	20011213	20020109
00006	220945758	100.01	100.13	100.09	I70S	20011213	20020109
00006	220945760	100.05	100.04	99.87	I70S	20011213	20020109
00006	220945761	100.07	100.15	99.97	I70S	20011213	20020109
00006	220945762	100.06	100.17	99.94	I70S	20011213	20020109
00006	220945763	100.08	100.1	99.95	I70S	20011213	20020109
00006	220945764	99.95	100.07	99.93	I70S	20011213	20020109
00006	220945765	100.12	99.64	99.95	I70S	20011213	20020109
00006	220945766	99.99	100.29	99.98	I70S	20011213	20020109
00006	220945767	99.92	100.12	100.07	I70S	20011213	20020109
00006	220945768	100.04	99.79	99.99	I70S	20011213	20020109
00006	220945769	100.01	99.79	99.97	I70S	20011213	20020109
00006	220945770	100.04	99.79	99.99	I70S	20011213	20020109
00006	220945771	100.02	99.92	100.12	I70S	20011213	20020109
00006	220945868	100.03	99.5	100.01	I70S	20011213	20020109
00006	220945869	100.14	100	100	I70S	20011213	20020109
00006	220945870	100.07	99.73	99.91	I70S	20011213	20020109
00006	220945871	100.03	100.25	100.08	I70S	20011213	20020109
00006	220945873	100.02	100.45	100.14	I70S	20011213	20020109
00006	220945874	100.01	99.61	100.04	I70S	20011213	20020109
00006	220945875	99.92	100.34	100.02	I70S	20011213	20020109
00006	220945876	100.12	99.84	100.12	I70S	20011213	20020109
00006	220945877	100.01	100.03	99.9	I70S	20011213	20020109
00006	220945878	100.08	99.34	100.05	I70S	20011213	20020109
00006	220945879	100.03	99.87	100.06	I70S	20011213	20020109
00006	220945880	99.93	99.77	100.02	I70S	20011213	20020109
00006	220945881	99.89	99.76	100.01	I70S	20011213	20020109
00006	220945882	100	100.4	99.87	I70S	20011213	20020109
00006	220945883	99.99	99.69	100.08	I70S	20011213	20020109
00006	220945884	100.05	99.97	99.86	I70S	20011213	20020109
00006	220945885	100.1	99.96	100	I70S	20011213	20020109
00006	220945886	100	100.4	99.94	I70S	20011213	20020109
00006	220945887	99.97	99.65	99.9	I70S	20011213	20020109
00006	220945888	100.02	100.29	100.14	I70S	20011213	20020109
00006	220945889	100.04	100.11	100.04	I70S	20011213	20020109
00006	220945890	100.13	99.75	99.97	I70S	20011213	20020109
00006	220945891	100	100.24	100.02	I70S	20011213	20020109
00006	220945892	99.99	99.7	100.02	I70S	20011213	20020109
00006	220945893	100	99.67	99.96	I70S	20011213	20020109
00006	220945894	99.94	100.39	99.95	I70S	20011213	20020109
00006	220945895	100.08	100	100.05	I70S	20011213	20020109
00006	220945896	99.92	100.34	100.02	I70S	20011213	20020109
00006	220945897	99.91	100.44	99.94	I70S	20011213	20020109
00006	220945898	100.02	100.04	99.88	I70S	20011213	20020109
00006	220945899	99.99	99.6	100.02	I70S	20011213	20020109
00006	220945900	99.98	99.67	100.06	I70S	20011213	20020109
00006	220945901	100.03	99.77	100.09	I70S	20011213	20020109
00006	220945902	100.03	100.23	100.08	I70S	20011213	20020109
00006	220945903	99.96	99.9	99.95	I70S	20011213	20020109
00006	220945904	100.06	99.87	99.9	I70S	20011213	20020109
00006	220945905	100.04	100.18	99.88	I70S	20011213	20020109
00006	220945906	100.07	100.15	100.09	I70S	20011213	20020109
00006	220945907	100.03	99.5	99.86	I70S	20011213	20020109
00006	220945908	100.02	99.49	99.89	I70S	20011213	20020109
00006	220945909	99.97	99.56	100.12	I70S	20011213	20020109
00006	220945910	100	99.74	100.07	I70S	20011213	20020109
00006	220945911	100.07	100.43	100.08	I70S	20011213	20020109
00006	220945912	100.04	99.69	100.11	I70S	20011213	20020109
00006	220945913	100.11	100.35	100.08	I70S	20011213	20020109

KY CTESTS for 2002

00006	220945914	99.9	99.67	100.04	I70S	20011213	20020109
00006	220945915	99.88	99.37	99.91	I70S	20011213	20020109
00006	220945916	100.06	99.62	100.09	I70S	20011213	20020109
00006	220945917	99.97	99.85	100.1	I70S	20011213	20020109
00006	220945918	100.04	99.98	100.02	I70S	20011213	20020109
00006	220945919	99.9	99.84	99.94	I70S	20011213	20020109
00006	220945920	100.02	99.76	99.87	I70S	20011213	20020109
00006	220945921	99.94	99.69	99.88	I70S	20011213	20020109
00006	220945922	100.1	99.96	100	I70S	20011213	20020109
00006	220945923	99.93	99.56	99.95	I70S	20011213	20020109
00006	220945924	99.99	99.6	100.02	I70S	20011213	20020109
00006	220945925	100.09	99.71	100.02	I70S	20011213	20020109
00006	220945926	99.93	100.49	100.06	I70S	20011213	20020109
00006	220945927	99.99	100.11	100.11	I70S	20011213	20020109
00006	220945928	99.99	99.86	99.9	I70S	20011213	20020109
00006	220945929	100.1	100.49	100.1	I70S	20011213	20020109
00006	220945930	99.99	99.86	99.9	I70S	20011213	20020109
00006	220945931	100.03	99.93	99.88	I70S	20011213	20020109
00006	220945933	100.05	99.74	99.97	I70S	20011213	20020109
00006	220945934	100.06	100.08	100.1	I70S	20011213	20020109
00006	220945935	100.11	99.82	100.05	I70S	20011213	20020109
00006	220945936	100.03	100.13	99.86	I70S	20011213	20020109
00006	220945937	99.92	99.85	99.98	I70S	20011213	20020109
00006	220945938	100.13	99.75	99.97	I70S	20011213	20020109
00006	220945939	99.99	99.84	99.92	I70S	20011213	20020109
00006	220945940	99.92	100.18	100.02	I70S	20011213	20020109
00006	220945941	100.03	100.07	100.05	I70S	20011213	20020109
00006	220945942	99.92	99.81	100.08	I70S	20011213	20020109
00006	220945943	99.99	100.21	99.97	I70S	20011213	20020109
00006	220945944	100.03	99.5	100.01	I70S	20011213	20020109
00006	220945945	99.99	100	100.07	I70S	20011214	20020109
00006	220945946	99.96	100.18	99.91	I70S	20011214	20020109
00006	220945947	100.14	99.75	100.13	I70S	20011214	20020109
00006	220945948	100.02	100.52	100.05	I70S	20011214	20020109
00006	220945949	100.07	100.01	100.08	I70S	20011214	20020109
00006	220945950	100.01	99.6	99.98	I70S	20011214	20020109
00006	220945951	100	99.96	100.01	I70S	20011214	20020109
00006	220945952	99.98	99.93	99.94	I70S	20011214	20020109
00006	220945953	100.01	99.48	100.02	I70S	20011214	20020109
00006	220945954	100.04	100.15	99.86	I70S	20011214	20020109
00006	220945955	99.91	100.15	100.05	I70S	20011214	20020109
00006	220945956	100.14	99.93	100.14	I70S	20011214	20020109
00006	220945957	100.06	99.97	100.05	I70S	20011214	20020109
00006	220945958	100	99.99	100.02	I70S	20011214	20020109
00006	220945959	99.96	99.74	100.09	I70S	20011214	20020109
00006	220945960	99.97	99.36	99.9	I70S	20011214	20020109
00006	220945961	100.05	100.25	100.08	I70S	20011214	20020109
00006	220945962	99.88	99.37	99.91	I70S	20011214	20020109
00006	220945963	99.88	100.37	100.01	I70S	20011214	20020109
00006	220946253	100.02	100	100.13	I70S	20011214	20020109
00006	220946255	100.05	99.95	100.09	I70S	20011214	20020109
00006	220946256	100.04	99.66	99.92	I70S	20011214	20020109
00006	220946261	99.95	99.61	100.07	I70S	20011214	20020109
00006	220946263	99.97	100.22	99.88	I70S	20011214	20020109
00006	220946264	99.94	99.42	99.94	I70S	20011214	20020109
00006	220946265	100.04	99.99	100.08	I70S	20011214	20020109
00006	220946267	99.94	100.22	100	I70S	20011214	20020109
00006	220946269	99.96	99.67	99.88	I70S	20011214	20020109
00006	220946272	100.01	100.39	99.88	I70S	20011214	20020109
00006	220946273	100.06	100.58	99.93	I70S	20011214	20020109
00006	220946275	100.13	100.18	99.9	I70S	20011214	20020109

KY CTESTS for 2002

00006	220946444	100.08	100.27	100.04	I70S	20011214	20020109
00006	220946445	100.03	100.32	99.97	I70S	20011214	20020109
00006	220946446	99.9	100.19	99.96	I70S	20011214	20020109
00006	220946447	100.06	100.07	99.99	I70S	20011214	20020109
00006	220946448	100.04	100.15	100.13	I70S	20011214	20020109
00006	220946449	99.9	100.3	99.97	I70S	20011214	20020109
00006	220946450	99.91	100.53	100.03	I70S	20011214	20020109
00006	220946451	100.05	100.53	99.92	I70S	20011214	20020109
00006	220946452	100.1	100.69	99.98	I70S	20011214	20020109
00006	220946453	100.08	100.5	100.14	I70S	20011214	20020109
00006	220946454	99.96	100.19	99.94	I70S	20011214	20020109
00006	220946455	100.09	100.45	100.06	I70S	20011214	20020109
00006	220946456	100.04	100.61	100.09	I70S	20011214	20020109
00006	220946457	100.07	100.32	100.09	I70S	20011214	20020109
00006	220946458	100.04	99.83	100.07	I70S	20011214	20020109
00006	220946459	99.94	100.08	99.89	I70S	20011214	20020109
00006	220946460	100.07	100.03	100	I70S	20011214	20020109
00006	220946461	99.99	100.12	99.9	I70S	20011214	20020109
00006	220946463	99.98	100.39	99.97	I70S	20011214	20020109
00006	220946464	100.06	100.59	99.89	I70S	20011214	20020109
00006	220946465	100.02	100.3	100.05	I70S	20011214	20020109
00006	220946466	100.06	100.27	100.05	I70S	20011214	20020109
00006	220946467	99.96	100.26	99.97	I70S	20011214	20020109
00006	220946468	99.98	100.69	99.98	I70S	20011214	20020109
00006	220946469	99.94	100.21	99.99	I70S	20011214	20020109
00006	220946470	99.95	100.53	100.11	I70S	20011214	20020109
00006	220946471	99.93	100.11	99.88	I70S	20011214	20020109
00006	220946472	100.01	100.37	99.97	I70S	20011214	20020109
00006	220946473	99.94	100.39	99.97	I70S	20011214	20020109
00006	220946474	99.92	100.68	99.92	I70S	20011214	20020109
00006	220946475	99.99	100.56	100.03	I70S	20011214	20020109
00006	220946476	100.05	100.39	99.92	I70S	20011214	20020109
00006	220946477	100	100.21	99.97	I70S	20011214	20020109
00006	220946478	100.02	99.72	100.05	I70S	20011214	20020109
00006	220946479	100.06	100.37	100.11	I70S	20011214	20020109
00006	220946480	100.03	100.16	100.04	I70S	20011214	20020109
00006	220946481	100.03	100.46	100.02	I70S	20011214	20020109
00006	220946482	100.07	100.03	100.13	I70S	20011214	20020109
00006	220946483	99.95	100.42	99.89	I70S	20011214	20020109
00006	220946484	100.12	100.47	100.01	I70S	20011214	20020109
00006	220946485	100	100.15	99.9	I70S	20011214	20020109
00006	220946486	100.02	100.49	100.12	I70S	20011214	20020109
00006	220946487	100.1	100.06	99.96	I70S	20011214	20020109
00006	220946488	100.02	100.14	99.88	I70S	20011214	20020109
00006	220946489	100.07	100.32	100.05	I70S	20011214	20020109
00006	220946490	100	100.23	100.02	I70S	20011214	20020109
00006	220946491	99.96	100.11	99.87	I70S	20011214	20020109
00006	220946492	99.99	100.52	99.94	I70S	20011214	20020109
00006	220946493	100.02	100.04	100.09	I70S	20011214	20020109
00006	220946494	100.11	100.17	100.13	I70S	20011214	20020109
00006	220946495	100.03	100.68	100.03	I70S	20011214	20020109
00006	220946496	100.11	100.38	99.96	I70S	20011214	20020109
00006	220946497	99.92	99.92	99.88	I70S	20011214	20020109
00006	220946498	100.05	100.36	100	I70S	20011214	20020109
00006	220946499	99.97	100.23	100.07	I70S	20011214	20020109
00006	220946500	100.04	100.64	100.11	I70S	20011214	20020109
00006	220946501	100.07	100.48	99.89	I70S	20011214	20020109
00006	220946502	100.03	100.56	100.06	I70S	20011214	20020109
00006	220946503	100	100.24	99.88	I70S	20011214	20020109
00006	220946504	100	100.09	99.9	I70S	20011214	20020109
00006	220946505	100.06	100.12	100.09	I70S	20011214	20020109

KY CTESTS for 2002

00006	220946506	99.95	99.82	99.9	I70S	20011214	20020109
00006	220946507	100.11	100.58	100.1	I70S	20011214	20020109
00006	220946508	99.89	99.4	100.02	I70S	20011214	20020109
00006	220946509	99.95	100.36	99.86	I70S	20011214	20020109
00006	220946510	99.97	100.41	100.01	I70S	20011214	20020109
00006	220946511	100.1	99.32	100.05	I70S	20011214	20020109
00006	220946512	100.02	100.31	100.12	I70S	20011214	20020109
00006	220946513	100.03	100.37	100.08	I70S	20011214	20020109
00006	220946514	99.94	100.08	99.89	I70S	20011214	20020109
00006	220946515	100.11	100.16	100.12	I70S	20011214	20020109
00006	220946516	100.01	100.1	100.04	I70S	20011214	20020109
00006	220946517	100.05	100.09	99.98	I70S	20011214	20020109
00006	220946518	100	100.02	99.93	I70S	20011214	20020109
00006	220946519	100.09	100.08	100.08	I70S	20011214	20020109
00006	220946520	100.05	100.54	99.86	I70S	20011214	20020109
00006	220946521	100.02	100.38	99.93	I70S	20011214	20020109
00006	220946522	99.98	100.28	100.13	I70S	20011214	20020109
00006	220946523	99.95	99.81	100.05	I70S	20011214	20020109
00006	220946524	100	100.35	99.97	I70S	20011214	20020109
00006	220946525	100.03	100.3	100.03	I70S	20011214	20020109
00006	220946526	100.02	100.36	99.97	I70S	20011214	20020109
00006	220946527	100.08	100.03	100.01	I70S	20011214	20020109
00006	220946528	99.97	100.2	99.94	I70S	20011214	20020109
00006	220946529	100.03	99.98	100.14	I70S	20011214	20020109
00006	220946531	100.11	100.07	100.12	I70S	20011214	20020109
00006	220946532	99.91	100.34	100.07	I70S	20011214	20020109
00006	220946533	100.09	100.15	99.92	I70S	20011214	20020109
00006	220946534	100	100.28	99.91	I70S	20011214	20020109
00006	220946535	99.93	100.67	99.9	I70S	20011214	20020109
00006	220946536	99.99	99.93	99.93	I70S	20011214	20020109
00006	220946537	100.11	100.09	99.95	I70S	20011214	20020109
00006	220946538	100.05	100.48	99.88	I70S	20011214	20020109
00006	220946539	100.07	100.17	100.14	I70S	20011214	20020109
SNNA8	221342047	99.99	100.02	100.01	KVS	20011206	20020109
SNNA8	221342048	99.99	99.98	99.94	KVS	20011206	20020109
SNNA8	221342049	99.99	99.98	100.1	KVS	20011206	20020109
SNNA8	221342051	100	100	100.04	KVS	20011206	20020109
SNNA8	221342052	100	100.01	100.01	KVS	20011206	20020109
SNNA8	221342054	100	99.97	99.97	KVS	20011206	20020109
SNNA8	221342055	100	100.02	100.03	KVS	20011206	20020109
SNNA8	221342056	100	99.97	100.02	KVS	20011206	20020109
SNNA8	221342057	100	99.99	99.99	KVS	20011206	20020109
SNNA8	221342058	99.99	99.96	100.12	KVS	20011206	20020109
SNNA8	221342059	99.99	100.02	99.97	KVS	20011206	20020109
SNNA8	221342060	100.01	100.01	100.08	KVS	20011206	20020109
SNNA8	221342061	100.01	100.02	99.97	KVS	20011206	20020109
SNNA8	221342062	99.99	100	99.97	KVS	20011206	20020109
SNNA8	221342063	100	100.02	100.04	KVS	20011206	20020109
SNNA8	221342064	99.99	100	100.08	KVS	20011206	20020109
SNNA8	221342065	99.99	99.97	100.07	KVS	20011206	20020109
SNNA8	221342066	100	100	100.03	KVS	20011206	20020109
SNNA8	221342067	100	100.01	100.06	KVS	20011206	20020109
SNNA8	221342068	100.01	99.99	99.94	KVS	20011206	20020109
SNNA8	221342069	99.99	100	100	KVS	20011206	20020109
SNNA8	221342070	99.99	100.01	99.98	KVS	20011206	20020109
SNNA8	221342071	100.02	99.99	99.98	KVS	20011206	20020109
SNNA8	221342073	100.01	99.99	100.07	KVS	20011206	20020109
SNNA8	221342074	100	99.96	100.11	KVS	20011206	20020109
SNNA8	221342075	99.99	99.98	100.06	KVS	20011206	20020109
SNNA8	221342076	100.01	100.01	99.86	KVS	20011206	20020109
SNNA8	221342077	100.01	100.01	99.94	KVS	20011206	20020109

KY CTESTS for 2002

SNNA8	221342078	99.99	100	100.05	KVS	20011206	20020109
SNNA8	221342079	99.99	99.99	99.96	KVS	20011206	20020109
SNNA8	221342080	100	100.01	100	KVS	20011206	20020109
SNNA8	221342081	99.99	100.01	100.04	KVS	20011206	20020109
SNNA8	221342082	99.99	99.99	100.12	KVS	20011206	20020109
SNNA8	221342083	100	100.04	99.93	KVS	20011206	20020109
SNNA8	221342084	100	100.01	100.13	KVS	20011206	20020109
SNNA8	221342085	100	100.02	100.09	KVS	20011206	20020109
SNNA8	221342087	100	100.01	99.99	KVS	20011206	20020109
SNNA8	221342088	99.99	100	99.97	KVS	20011206	20020109
SNNA8	221342089	100	100	100.05	KVS	20011206	20020109
SNNA8	221342090	99.99	99.99	99.94	KVS	20011206	20020109
SNNA8	221342091	99.99	99.97	100.02	KVS	20011206	20020109
SNNA8	221342092	99.99	100.02	100.05	KVS	20011206	20020109
SNNA8	221342093	100	100.01	99.95	KVS	20011206	20020109
SNNA8	221342094	100.02	100.01	99.97	KVS	20011206	20020109
SNNA8	221343885	99.99	99.96	99.94	KVS	20011209	20020101
SNNA8	221344099	100	100.01	100.03	KVS	20011207	20020101
SNNA8	221344100	99.99	100	100.03	KVS	20011207	20020101
SNNA8	221344101	100	99.99	100.06	KVS	20011207	20020101
SNNA8	221344102	99.99	99.98	100.09	KVS	20011207	20020101
SNNA8	221344103	99.99	99.98	100	KVS	20011207	20020101
S2TA8	221344104	100	100.01	100.07	KVS	20011207	20020101
SNNA8	221344105	100.01	100.01	100.03	KVS	20011207	20020101
SNNA8	221344106	99.99	100.03	100.12	KVS	20011207	20020101
SNNA8	221344107	100.01	99.98	100.06	KVS	20011207	20020101
S2TA8	221344108	99.99	100.01	100.04	KVS	20011207	20020101
SNNA8	221344109	99.99	99.97	99.98	KVS	20011207	20020101
SNNA8	221344110	100	100.01	100.07	KVS	20011207	20020101
SNNA8	221344111	99.99	100	100.04	KVS	20011207	20020101
SNNA8	221344112	99.98	100.02	100.06	KVS	20011207	20020101
SNNA8	221344113	100.01	100	100.11	KVS	20011207	20020101
SNNA8	221344114	100	99.98	100	KVS	20011207	20020101
SNNA8	221346706	100	99.99	99.91	KVS	20011212	20020101
SNNA8	221346707	100	100.02	100.06	KVS	20011212	20020101
SNNA8	221346708	100.01	100.01	99.95	KVS	20011212	20020101
SNNA8	221346709	100.01	100.01	100.08	KVS	20011212	20020101
SNNA8	221346710	99.98	99.99	100.13	KVS	20011212	20020101
SNNA8	221346711	99.99	100.05	100.09	KVS	20011212	20020101
SNNA8	221346712	99.99	99.97	100.03	KVS	20011212	20020101
SNNA8	221346713	100.01	99.99	100.05	KVS	20011212	20020101
SNNA8	221346714	99.99	100	100.04	KVS	20011212	20020101
SNNA8	221346715	100.01	100.04	99.99	KVS	20011212	20020101
SNNA8	221346716	100.01	100	100.01	KVS	20011212	20020101
SNNA8	221346717	100.01	100.02	100.05	KVS	20011212	20020101
SNNA8	221346718	99.98	100	100.02	KVS	20011212	20020101
SNNA8	221346719	99.99	100.01	99.98	KVS	20011212	20020101
SNNA8	221346720	100	99.99	100.08	KVS	20011212	20020101
SNNA8	221346721	99.99	99.98	100.03	KVS	20011212	20020101
SNNA8	221346722	100	100	99.91	KVS	20011212	20020101
SNNA8	221346723	100	99.98	100	KVS	20011212	20020101
SNNA8	221346724	99.99	100.04	100.14	KVS	20011212	20020101
SNNA8	221346725	99.99	99.99	100.06	KVS	20011212	20020101
SNNA8	221346726	99.99	99.96	100.07	KVS	20011212	20020101
SNNA8	221346727	100	100.01	100.1	KVS	20011212	20020101
SNNA8	221346728	99.99	100	100	KVS	20011212	20020101
SNNA8	221346729	100.01	100.01	100.07	KVS	20011212	20020101
SNNA8	221366349	100	99.97	100	KVS	20020205	20020401
SNNA8	221366350	100.02	99.99	100.02	KVS	20020205	20020401
SNNA8	221366351	100	100.03	99.99	KVS	20020205	20020401
SNNA8	221366352	100.01	100	100.05	KVS	20020205	20020401

KY CTESTS for 2002

SNNA8	221366353	99.99	100.04	100.06	KVS	20020205	20020401
SNNA8	221366354	100	99.99	99.96	KVS	20020205	20020401
SNNA8	221366355	100.01	100.01	100.08	KVS	20020205	20020401
SNNA8	221366356	100	100.03	100.1	KVS	20020205	20020401
SNNA8	221366357	100.01	100.02	100.1	KVS	20020205	20020401
SNNA8	221366358	100	100.02	100.02	KVS	20020205	20020401
SNNA8	221366359	99.99	99.98	100.05	KVS	20020205	20020401
SNNA8	221366361	100	100.05	100.03	KVS	20020205	20020401
SNNA8	221366362	100	99.99	100.06	KVS	20020206	20020401
SNNA8	221366363	99.99	99.99	100.04	KVS	20020205	20020401
SNNA8	221366364	100	100.01	100.03	KVS	20020205	20020401
SNNA8	221366365	99.98	100.04	99.99	KVS	20020205	20020401
SNNA8	221366366	100.01	100.03	100.13	KVS	20020205	20020401
SNNA8	221366367	99.98	100	100.02	KVS	20020205	20020401
SNNA8	221366368	99.99	99.98	99.97	KVS	20020205	20020401
SNNA8	221366370	100	99.99	100.1	KVS	20020205	20020401
SNNA8	221366371	99.99	100.01	100.03	KVS	20020205	20020401
SNNA8	221366372	100	100	100.1	KVS	20020205	20020401
SNNA8	221366373	99.99	100	100.02	KVS	20020205	20020401
SNNA8	221366374	100	100.02	100.06	KVS	20020205	20020401
SNNA8	221366375	100	100.02	100.03	KVS	20020205	20020401
SNNA8	221366376	99.99	100.02	100.03	KVS	20020205	20020401
SNNA8	221366505	99.99	100	100.03	KVS	20020205	20020401
SNNA8	221366506	100.01	100.02	100	KVS	20020205	20020401
SNNA8	221366507	100.01	100.01	100.05	KVS	20020205	20020401
SNNA8	221366508	100	100.03	100.03	KVS	20020205	20020401
SNNA8	221366509	100.01	100.04	100.12	KVS	20020205	20020401
SNNA8	221366510	100	100.03	100.05	KVS	20020205	20020401
SNNA8	221366511	99.99	100	100.09	KVS	20020205	20020401
SNNA8	221366512	99.99	100.02	100.06	KVS	20020205	20020401
SNNA8	221366513	100	99.97	100.04	KVS	20020205	20020401
SNNA8	221366514	100.01	100.01	100.09	KVS	20020205	20020401
SNNA8	221366515	99.99	99.98	100.05	KVS	20020205	20020401
SNNA8	221366516	99.99	99.97	100.08	KVS	20020205	20020401
SNNA8	221366517	99.98	100.01	100.06	KVS	20020205	20020401
SNNA8	221366518	100	100.01	100	KVS	20020205	20020401
SNNA8	221366519	100	100	100.02	KVS	20020205	20020401
SNNA8	221366520	100	100.01	100.1	KVS	20020205	20020401
SNNA8	221366521	100	99.98	100.14	KVS	20020205	20020401
SNNA8	221366522	100	99.99	100.09	KVS	20020205	20020401
S2TA8	221366523	99.99	99.99	100.11	KVS	20020205	20020401
SNNA8	221366524	100	100.03	99.97	KVS	20020205	20020401
SNNA8	221366525	99.98	100	100	KVS	20020206	20020401
SNNA8	221366526	100	100.04	99.97	KVS	20020205	20020401
SNNA8	221366527	99.98	100	99.98	KVS	20020205	20020401
SNNA8	221366528	99.98	100.03	100.07	KVS	20020205	20020401
SNNA8	221366AX	100	100.02	100.05	KVS	20020205	20020401
SNNA8	221366I70S	100	100	100.04	KVS	20020205	20020401
SNNA8	221430357	100.01	99.98	99.99	KVS	20020423	20020620
SNNA8	221430358	100	100.02	100.07	KVS	20020423	20020620
SNNA8	221430359	99.99	100	100.06	KVS	20020423	20020620
SNNA8	221430361	100	99.96	100.06	KVS	20020423	20020620
SNNA8	221430362	100.02	100.02	100.01	KVS	20020423	20020620
SNNA8	221430363	99.99	99.97	100.01	KVS	20020423	20020620
SNNA8	221430364	100.01	100.05	100.05	KVS	20020423	20020620
SNNA8	221430365	100	99.98	100.04	KVS	20020423	20020620
SNNA8	221430366	100	100.01	100.01	KVS	20020423	20020620
SNNA8	221430367	100.01	99.99	100.11	KVS	20020423	20020620
SNNA8	221430368	100	99.99	100.01	KVS	20020423	20020620
SNNA8	221430370	100	100.03	100.06	KVS	20020423	20020620
SNNA8	221430371	100.01	99.98	99.98	KVS	20020423	20020620

KY CTESTS for 2002

SNNA8	221430372	99.99	99.99	100	KVS	20020423	20020620
SNNA8	221430373	99.99	99.97	100.06	KVS	20020423	20020620
SNNA8	221430374	99.99	100.01	99.96	KVS	20020423	20020620
SNNA8	221430375	100.01	100.03	100.12	KVS	20020423	20020620
SNNA8	221430376	100.02	99.99	100.06	KVS	20020423	20020620
SNNA8	221430377	100.01	100	100.03	KVS	20020423	20020620
SNNA8	221430378	100	99.98	100.01	KVS	20020423	20020620
SNNA8	221430381	100	100.03	99.98	KVS	20020423	20020620
SNNA8	221430382	100	99.97	100.02	KVS	20020423	20020620
SNNA8	221430384	100.02	100	100.05	KVS	20020423	20020620
SNNA8	221430385	99.99	100.04	99.98	KVS	20020423	20020620
SNNA8	221430386	100	100.02	100.05	KVS	20020423	20020620
SNNA8	221430387	99.98	99.99	100	KVS	20020423	20020620
SNNA8	221430388	100.01	99.98	100.03	KVS	20020423	20020620
SNNA8	221430389	100.01	99.97	99.99	KVS	20020423	20020620
SNNA8	221430390	100	100.04	100.08	KVS	20020423	20020620
SNNA8	221430391	99.99	100	100.02	KVS	20020423	20020620
SNNA8	221430392	99.99	100.02	100.07	KVS	20020423	20020620
SNNA8	221430393	100.01	99.99	100.04	KVS	20020423	20020620
SNNA8	221430394	100	100.02	100.14	KVS	20020423	20020620
SNNA8	221430395	100.01	100.01	100.01	KVS	20020423	20020620
SNNA8	221430396	100	99.97	100.04	KVS	20020423	20020620
SNNA8	221430397	100	100.04	99.97	KVS	20020423	20020620
SNNA8	221430398	99.99	100.01	99.99	KVS	20020423	20020620
SNNA8	221430399	100.01	99.98	99.97	KVS	20020423	20020620
SNNA8	221430401	100	99.96	100.07	KVS	20020423	20020620
SNNA8	221430402	100	100.03	100.1	KVS	20020423	20020620
SNNA8	221430403	100	100	100.05	KVS	20020423	20020620
SNNA8	221430404	100	100.01	100.03	KVS	20020423	20020620
SNNA8	221430517	99.99	100.02	100.03	KVS	20020514	20020627
SNNA8	221430518	100	100.02	100.04	KVS	20020514	20020627
SNNA8	221430519	100.02	100.01	99.96	KVS	20020514	20020627
SNNA8	221430520	100.01	100.01	100.06	KVS	20020514	20020627
SNNA8	221430521	99.99	100.04	99.98	KVS	20020514	20020627
SNNA8	221430522	99.99	100	100.02	KVS	20020514	20020627
SNNA8	221430523	99.99	99.96	100.01	KVS	20020514	20020627
SNNA8	221430524	100	99.98	99.97	KVS	20020514	20020627
SNNA8	221430541	99.98	100.01	99.96	KVS	20020514	20020627
SNNA8	221430542	100	99.98	99.97	KVS	20020514	20020627
SNNA8	221430543	99.99	100	99.95	KVS	20020514	20020627
SNNA8	221430544	100	100.01	99.98	KVS	20020514	20020627
SNNA8	221430545	100.02	99.97	99.99	KVS	20020514	20020627
SNNA8	221430546	99.98	99.98	99.97	KVS	20020514	20020627
SNNA8	221430547	99.99	100	99.85	KVS	20020514	20020627
SNNA8	221430548	99.98	99.98	99.96	KVS	20020514	20020627
SNNA8	221430585	100	100.02	100.04	KVS	20020514	20020627
SNNA8	221430586	100	100	99.99	KVS	20020514	20020627
SNNA8	221430587	100	100.01	100.01	KVS	20020514	20020627
SNNA8	221430588	100.01	100	99.99	KVS	20020514	20020627
SNNA8	221430749	100	99.98	100.01	KVS	20020424	20020603
SNNA8	221430750	100	99.99	100.04	KVS	20020424	20020603
SNNA8	221430751	99.98	100	100.07	KVS	20020425	20020603
SNNA8	221430752	99.99	99.98	100.03	KVS	20020424	20020603
SNNA8	221430753	100.01	99.98	100.07	KVS	20020424	20020603
SNNA8	221430754	99.99	100.04	100.11	KVS	20020424	20020603
SNNA8	221430755	100.01	100.02	100.05	KVS	20020424	20020603
SNNA8	221430756	100	100.01	100.03	KVS	20020424	20020603
SNNA8	221430757	100	99.97	100.02	KVS	20020424	20020603
SNNA8	221430758	100	99.99	100.01	KVS	20020424	20020603
SNNA8	221430759	100.01	100.01	99.99	KVS	20020424	20020603
SNNA8	221430760	100.01	100	100.03	KVS	20020424	20020603

KY CTESTS for 2002

SNNA8	221430AX	99.99	100.01	100.05	KVS	20020423	20020620
SNNA8	221430I70S	99.99	99.98	100.01	KVS	20020423	20020620
SNNA8	221430KV2	99.99	100.01	100.01	KVS	20020423	20020620
SNNA8	221474388	100.02	99.99	100	KVS	20020617	20020702
SNNA8	221474389	100	100	100.06	KVS	20020617	20020702
SNNA8	221474390	99.99	99.99	100.02	KVS	20020617	20020702
SNNA8	221474391	99.98	99.99	99.98	KVS	20020617	20020702
SNNA8	221474584	100.01	99.98	100.09	KVS	20020618	20020702
SNNA8	221474585	100.01	100.01	99.99	KVS	20020618	20020702
SNNA8	221474586	100	99.98	100	KVS	20020618	20020702
SNNA8	221474587	99.99	99.98	100.09	KVS	20020618	20020702
SNNA8	221474588	99.99	99.97	100.03	KVS	20020618	20020702
SNNA8	221474589	100	100.01	100.11	KVS	20020618	20020702
SNNA8	221474590	100	100.01	100.14	KVS	20020618	20020702
SNNA8	221474591	99.98	99.99	100.02	KVS	20020618	20020702
SNNA8	221474600	99.99	99.98	100.06	KVS	20020618	20020702
SNNA8	221474601	99.99	100	100.04	KVS	20020618	20020702
SNNA8	221474604	99.99	100	100.02	KVS	20020618	20020702
SNNA8	221474605	100.01	99.98	100.03	KVS	20020618	20020702
SNNA8	221474606	99.98	99.97	100.01	KVS	20020618	20020702
SNNA8	221474607	100	100.01	99.97	KVS	20020618	20020702
SNNA8	221474608	100	99.99	100.05	KVS	20020618	20020702
SNNA8	221474609	100.01	100.05	99.96	KVS	20020618	20020702
SNNA8	221474610	99.99	100.01	99.98	KVS	20020618	20020702
S2TA8	221474611	99.99	99.99	100.07	KVS	20020618	20020702
SNNA8	221474612	100.01	100.02	100.03	KVS	20020618	20020702
SNNA8	221474613	100	99.99	100.07	KVS	20020618	20020702
SNNA8	221474614	99.99	99.97	99.99	KVS	20020618	20020702
SNNA8	221474615	99.99	100.01	100.01	KVS	20020618	20020702
SNNA8	221474616	100	100.03	100.04	KVS	20020618	20020702
SNNA8	221474617	99.99	99.98	100.02	KVS	20020618	20020702
SNNA8	221474618	100	100.03	100.02	KVS	20020618	20020702
SNNA8	221474619	99.99	99.99	100.05	KVS	20020618	20020702
SNNA8	221474620	100	99.95	100.02	KVS	20020618	20020702
SNNA8	221474621	99.99	99.99	100.01	KVS	20020618	20020702
SNNA8	221474622	100	100.02	100.04	KVS	20020618	20020702
SNNA8	221474623	99.99	100	100.03	KVS	20020618	20020702
00006	222520454	100.04	99.72	100.13	I70S	20020211	20020220
00006	222520455	99.97	99.95	99.88	I70S	20020211	20020220
00006	222520456	99.97	99.85	100.01	I70S	20020211	20020220
00006	222520457	100.04	99.7	100.04	I70S	20020211	20020220
00006	222520458	99.94	99.42	100.13	I70S	20020211	20020220
00006	222520459	99.95	99.45	99.96	I70S	20020211	20020220
00006	222520460	100	99.32	99.94	I70S	20020211	20020220
00006	222520461	100.03	100.15	100.13	I70S	20020211	20020220
00006	222520462	100.05	99.8	100	I70S	20020211	20020220
00006	222520463	100.01	100.25	99.89	I70S	20020211	20020220
00006	222520464	100.03	99.54	100.05	I70S	20020211	20020220
00006	222520465	100	100.02	100.09	I70S	20020211	20020220
00006	222520467	99.92	99.58	100	I70S	20020211	20020220
00006	222520468	99.93	100.01	99.95	I70S	20020211	20020220
00006	222520469	100.04	99.75	99.96	I70S	20020211	20020220
00006	222520470	99.94	99.66	99.87	I70S	20020211	20020220
00006	222520471	100.07	99.92	99.96	I70S	20020211	20020220
00006	222520472	100.08	100.03	100.03	I70S	20020211	20020220
00006	222520473	100.07	100.35	100.07	I70S	20020211	20020220
00006	222520474	100.06	99.71	99.92	I70S	20020211	20020220
00006	222520475	100.04	99.66	100.11	I70S	20020211	20020220
00006	222520477	100.08	99.42	100.1	I70S	20020211	20020220
00006	222520478	99.97	100.52	100.05	I70S	20020211	20020220
00006	222520479	100.05	99.92	99.97	I70S	20020211	20020220

KY CTESTS for 2002

00006	222520480	100	99.31	99.86	I70S	20020211	20020220
00006	222520481	100.01	99.99	100.02	I70S	20020211	20020220
00006	222520482	100.07	100.28	100.14	I70S	20020211	20020220
00006	222520483	99.99	100.15	100.03	I70S	20020211	20020220
00006	222520484	99.93	100.55	99.92	I70S	20020211	20020220
00006	222520485	99.92	99.87	100.04	I70S	20020211	20020220
00006	222520486	100.04	99.67	99.91	I70S	20020211	20020220
00006	222520487	99.98	99.63	99.86	I70S	20020211	20020220
00006	222520488	100	100.23	100.1	I70S	20020211	20020220
00006	222520489	99.95	100.32	100.01	I70S	20020211	20020220
00006	222520490	100.14	100.58	100.14	I70S	20020211	20020220
00006	222520491	100.08	100.09	100.13	I70S	20020211	20020220
00006	222520492	100	99.7	99.97	I70S	20020211	20020220
00006	222520493	100.07	99.76	100.07	I70S	20020211	20020220
00006	222520494	99.94	99.7	99.96	I70S	20020211	20020220
00006	222520495	100.14	99.98	100.03	I70S	20020211	20020220
00006	222520496	100.04	99.41	99.89	I70S	20020211	20020220
00006	222520497	100.03	100.28	99.89	I70S	20020211	20020220
00006	222520498	99.96	99.35	100.03	I70S	20020211	20020220
00006	222520499	100.06	100.13	100.11	I70S	20020211	20020220
00006	222520500	100	100.05	100.09	I70S	20020211	20020220
00006	222520501	100.05	100.04	100.04	I70S	20020211	20020220
00006	222520502	100.01	100.22	100.12	I70S	20020211	20020220
00006	222520503	100.07	99.79	100.06	I70S	20020211	20020220
00006	222520504	99.95	99.73	99.96	I70S	20020211	20020220
00006	222520505	100.06	99.35	100.01	I70S	20020211	20020220
00006	222520506	99.97	99.71	100.04	I70S	20020211	20020220
00006	222520507	100.01	99.87	99.96	I70S	20020211	20020220
00006	222520508	100.06	100.21	100.02	I70S	20020211	20020220
00006	222520509	100.07	99.72	100.04	I70S	20020211	20020220
00006	222520510	100.04	99.75	99.96	I70S	20020211	20020220
00006	222520511	99.99	99.65	100.07	I70S	20020211	20020220
00006	222520512	100.04	99.69	99.86	I70S	20020211	20020220
00006	222520513	99.98	100.23	99.96	I70S	20020211	20020220
00006	222520514	100	99.32	99.94	I70S	20020211	20020220
00006	222520515	99.99	99.62	100.11	I70S	20020211	20020220
00006	222520516	99.88	100.21	100.08	I70S	20020211	20020220
00006	222520517	100.11	99.9	99.99	I70S	20020211	20020220
00006	222520518	100.1	99.33	99.9	I70S	20020211	20020220
00006	222520519	100	99.89	99.9	I70S	20020211	20020220
00006	222520520	100.09	99.42	100.13	I70S	20020211	20020220
00006	222520521	99.98	99.79	99.87	I70S	20020211	20020220
00006	222520522	100	100.01	100.06	I70S	20020211	20020220
00006	222520523	100.04	99.87	100.02	I70S	20020211	20020220
00006	222520524	99.99	100.18	99.98	I70S	20020211	20020220
00006	222520525	100.02	99.64	100	I70S	20020211	20020220
00006	222520526	100.12	99.53	99.91	I70S	20020211	20020220
00006	222520527	100	99.68	100.11	I70S	20020211	20020220
00006	222520528	99.97	100.15	100.13	I70S	20020211	20020220
00006	222520529	100.01	99.98	99.96	I70S	20020211	20020220
00006	222520530	99.99	99.84	99.88	I70S	20020211	20020220
00006	222520531	100.03	99.54	100.05	I70S	20020211	20020220
00006	222520532	100.02	100.39	100.05	I70S	20020211	20020220
00006	222520533	100.07	99.38	99.89	I70S	20020211	20020220
00006	222520534	99.98	99.71	100.14	I70S	20020211	20020220
00006	222520535	100.01	99.74	100.1	I70S	20020211	20020220
00006	222520536	99.94	100.46	99.97	I70S	20020211	20020220
00006	222520537	100.04	100.06	99.9	I70S	20020211	20020220
00006	222520538	100.14	99.56	100.09	I70S	20020211	20020220
00006	222520539	100.06	99.99	100	I70S	20020211	20020220
00006	222520540	100.03	99.71	100.14	I70S	20020211	20020220

KY CTESTS for 2002

00006	222520541	100.04	100.04	99.98	I70S	20020211	20020220
00006	222520542	100	99.91	100.07	I70S	20020211	20020220
00006	222520544	99.91	99.67	99.91	I70S	20020211	20020220
00006	222520545	100.1	99.31	99.93	I70S	20020211	20020220
00006	222520547	100	100.01	100.06	I70S	20020211	20020220
00006	222520548	100.01	100	99.88	I70S	20020211	20020220
00006	222520549	99.98	99.42	100.04	I70S	20020211	20020220
00006	222520550	99.99	99.84	99.88	I70S	20020211	20020220
00006	222520551	100.01	99.95	99.91	I70S	20020211	20020220
00006	222520552	100.14	100.55	99.89	I70S	20020211	20020220
00006	222520553	100	100.15	100.13	I70S	20020211	20020220
00006	222520554	99.89	99.66	99.87	I70S	20020211	20020220
00006	222520555	100.02	99.94	99.99	I70S	20020211	20020220
00006	222520556	100.03	100.34	99.98	I70S	20020211	20020220
00006	222520557	99.94	99.8	99.91	I70S	20020211	20020220
00006	222520558	100.08	99.77	99.94	I70S	20020211	20020220
00006	222520559	100.04	99.69	99.86	I70S	20020211	20020220
00006	222520560	100	99.86	100.03	I70S	20020211	20020220
00006	222520561	99.99	100.48	99.93	I70S	20020211	20020220
00006	222520562	100.04	99.9	99.9	I70S	20020211	20020220
00006	222520563	100.1	99.54	99.86	I70S	20020211	20020220
00006	222520564	99.88	99.9	99.88	I70S	20020211	20020220
00006	222520565	99.99	99.57	99.98	I70S	20020211	20020220
00006	222520566	100.03	100.21	99.93	I70S	20020211	20020220
00006	222520567	99.99	99.96	99.98	I70S	20020211	20020220
00006	222520568	100.01	100.18	100.09	I70S	20020211	20020220
00006	222520569	100	100	99.9	I70S	20020211	20020220
00006	222520570	100.06	99.53	99.98	I70S	20020211	20020220
00006	222520571	100.03	99.87	100.06	I70S	20020211	20020220
00006	222520573	100	99.42	100.1	I70S	20020211	20020220
00006	222520574	99.98	99.96	100.11	I70S	20020211	20020220
00006	222520575	99.99	100.13	100.02	I70S	20020211	20020220
00006	222520576	99.94	100.16	99.92	I70S	20020211	20020220
00006	222520577	100.05	100.26	99.92	I70S	20020211	20020220
00006	222520578	100.06	99.99	100.12	I70S	20020211	20020220
00006	222520579	100.07	99.66	100.03	I70S	20020211	20020220
00006	222520580	100	100.1	99.9	I70S	20020211	20020220
00006	222520581	99.96	99.86	100.05	I70S	20020211	20020220
00006	222520582	99.99	100.02	100.07	I70S	20020211	20020220
00006	222520584	99.95	99.77	100.08	I70S	20020211	20020220
00006	222520585	99.99	99.6	99.88	I70S	20020211	20020220
00006	222520586	100.03	99.86	100.11	I70S	20020211	20020220
00006	222520587	100.01	99.99	99.91	I70S	20020211	20020220
00006	222520588	100	99.78	99.88	I70S	20020211	20020220
00006	222520589	99.96	100.49	99.97	I70S	20020211	20020220
00006	222520590	100	99.85	99.98	I70S	20020211	20020220
00006	222520591	100	100.01	100.06	I70S	20020211	20020220
00006	222520592	99.96	100.63	99.9	I70S	20020211	20020220
00006	222520593	99.96	99.56	99.86	I70S	20020211	20020220
00006	222520594	100.04	100.04	99.98	I70S	20020211	20020220
00006	222520595	100.08	100	99.86	I70S	20020211	20020220
00006	222520596	100.06	100.34	100.04	I70S	20020211	20020220
00006	222520597	100.01	99.37	100.04	I70S	20020211	20020220
00006	222520598	100	99.89	100.14	I70S	20020211	20020220
00006	222520600	99.94	99.47	99.9	I70S	20020211	20020220
00006	222520601	99.95	99.4	100.13	I70S	20020211	20020220
00006	222520602	100.04	99.57	99.87	I70S	20020211	20020220
00006	222520603	100.04	100.19	100.1	I70S	20020211	20020220
00006	222520604	100.05	99.67	100.07	I70S	20020211	20020220
00006	222520605	100.05	99.77	99.97	I70S	20020211	20020220
00006	222520606	99.98	99.91	99.98	I70S	20020211	20020220

KY CTESTS for 2002

00006	222520607	99.98	99.86	100.04	170S	20020211	20020220
00006	222520608	99.96	99.62	99.88	170S	20020211	20020220
00006	222520609	100	99.84	99.88	170S	20020211	20020220
00006	222520610	100.09	99.93	100.1	170S	20020211	20020220
00006	222520611	100.03	99.45	100.14	170S	20020211	20020220
00006	222520612	100.04	99.93	99.97	170S	20020211	20020220
00006	222520613	100.06	100.02	99.93	170S	20020211	20020220
00006	222520615	100.06	99.4	99.98	170S	20020211	20020220
00006	222520616	100.06	99.52	100	170S	20020211	20020220
00006	222520617	100.07	100.22	100.12	170S	20020211	20020220
00006	222520618	99.92	100.24	99.98	170S	20020211	20020220
00006	222520619	100.08	99.65	99.96	170S	20020211	20020220
00006	222520620	100.12	100.17	99.91	170S	20020211	20020220
00006	222520621	99.89	99.4	99.97	170S	20020211	20020220
00006	222520622	100.12	100.32	100.01	170S	20020211	20020220
00006	222520623	100.1	100.21	100	170S	20020211	20020220
00006	222520624	99.97	100.27	100.04	170S	20020211	20020220
00006	222520625	99.99	100.41	99.87	170S	20020211	20020220
00006	222520626	100.06	99.5	100	170S	20020211	20020220
00006	222520627	99.93	100.18	100.06	170S	20020211	20020220
00006	222520628	99.99	100.09	99.99	170S	20020211	20020220
00006	222520629	99.96	99.53	99.9	170S	20020211	20020220
00006	222520630	99.95	100.55	99.89	170S	20020211	20020220
00006	222520631	100.05	99.62	100.09	170S	20020211	20020220
00006	222520632	99.98	99.91	99.98	170S	20020211	20020220
00006	222520634	100.1	100.03	100.07	170S	20020211	20020220
00006	222520635	100.07	99.38	100.09	170S	20020211	20020220
00006	222520636	99.88	99.9	99.88	170S	20020211	20020220
00006	222520637	100	99.55	99.88	170S	20020211	20020220
00006	222520639	99.92	100.1	100.05	170S	20020211	20020220
00006	222520640	100.02	99.55	99.93	170S	20020211	20020220
00006	222520641	100.04	100.06	100	170S	20020211	20020220
00006	222520642	99.96	99.63	99.93	170S	20020211	20020220
00006	222520643	100.07	100.05	100.02	170S	20020211	20020220
00006	222520644	100	99.62	100.11	170S	20020211	20020220
00006	222520645	100.11	100.1	100.14	170S	20020211	20020220
00006	222520646	100	99.89	100.14	170S	20020211	20020220
00006	222520648	100.02	100.18	99.9	170S	20020211	20020220
00006	222520649	99.98	99.84	99.96	170S	20020211	20020220
00006	222520650	99.96	99.39	100.03	170S	20020211	20020220
00006	222520651	100.07	100.52	100.06	170S	20020211	20020220
00006	222520652	99.97	100.15	100.07	170S	20020211	20020220
00006	222520653	100.07	99.66	100.03	170S	20020211	20020220
00006	222520654	100	99.93	99.92	170S	20020211	20020220
00006	222520655	100.03	99.81	100.11	170S	20020211	20020220
00006	222520656	99.94	99.63	99.9	170S	20020211	20020220
00006	222520657	100.02	100	100.05	170S	20020211	20020220
00006	222520658	100.11	99.59	100.08	170S	20020211	20020220
00006	222520659	99.97	99.37	100.12	170S	20020211	20020220
00006	222520660	99.97	100.14	99.95	170S	20020211	20020220
00006	222520661	100.08	100.16	100.05	170S	20020211	20020220
00006	222520662	99.97	99.62	100.11	170S	20020211	20020220
00006	222520663	100.07	100.04	100.08	170S	20020211	20020220
00006	222520664	100.02	100.4	99.9	170S	20020211	20020220
00006	222520665	100	100.1	99.9	170S	20020211	20020220
00006	222520666	100.05	100.25	100.05	170S	20020211	20020220
00006	222520667	100.05	99.79	100	170S	20020211	20020220
00006	222520668	100.04	100.19	100.1	170S	20020211	20020220
00006	222520669	100.06	99.64	100.03	170S	20020211	20020220
00006	222520670	100.01	99.59	99.88	170S	20020211	20020220
00006	222520671	99.98	99.98	100.13	170S	20020211	20020220

KY CTESTS for 2002

00006	222520672	100	99.85	99.98	I70S	20020211	20020220
00006	222520673	100.13	99.98	100.02	I70S	20020211	20020220
00006	222520674	99.9	99.9	99.89	I70S	20020211	20020220
00006	222520675	99.97	99.63	99.92	I70S	20020211	20020220
00006	222520676	99.98	99.88	99.96	I70S	20020211	20020220
00006	222520677	100.02	99.84	100.12	I70S	20020211	20020220
00006	222520678	100	99.96	100.05	I70S	20020211	20020220
00006	222520679	99.91	99.74	99.98	I70S	20020211	20020220
00006	222520680	100.03	99.58	100	I70S	20020211	20020220
00006	222520681	99.95	99.79	99.86	I70S	20020211	20020220
00006	222520682	99.87	100.08	99.97	I70S	20020211	20020220
00006	222520683	99.98	100.27	99.98	I70S	20020211	20020220
00006	222520684	100.12	99.96	100.07	I70S	20020211	20020220
00006	222520685	99.96	99.43	100.02	I70S	20020211	20020220
00006	222520686	100.02	100.67	99.92	I70S	20020211	20020220
00006	222520687	99.97	100	99.96	I70S	20020211	20020220
00006	222520688	99.93	99.99	99.96	I70S	20020211	20020220
00006	222520689	100.03	100.09	100.08	I70S	20020211	20020220
00006	222520690	99.96	100.11	100.05	I70S	20020211	20020220
00006	222520691	100.03	100.14	100.02	I70S	20020211	20020220
00006	222520692	100.03	99.62	99.96	I70S	20020211	20020220
00006	222520693	100.08	99.53	99.88	I70S	20020211	20020220
00006	222520694	100.08	99.65	99.96	I70S	20020211	20020220
00006	222520696	99.91	100.01	100.13	I70S	20020211	20020220
00006	222520697	100.02	100.03	99.86	I70S	20020211	20020220
00006	222520698	100.12	99.78	99.92	I70S	20020211	20020220
00006	222520699	100	99.99	100.08	I70S	20020211	20020220
00006	222520701	99.97	100.34	99.96	I70S	20020211	20020220
00006	222520702	99.96	99.46	100.05	I70S	20020211	20020220
00006	222520703	99.92	99.38	99.92	I70S	20020211	20020220
00006	222520704	100.08	99.41	99.98	I70S	20020211	20020220
00006	222520705	100.01	100.2	100	I70S	20020211	20020220
00006	222520706	100	99.78	100.12	I70S	20020211	20020220
00006	222520707	100.01	99.95	100.06	I70S	20020211	20020220
00006	222520708	100.12	99.5	100.08	I70S	20020211	20020220
00006	222520709	100.03	99.59	99.93	I70S	20020211	20020220
00006	222520710	99.96	99.95	99.99	I70S	20020211	20020220
00006	222520711	100	99.48	99.92	I70S	20020211	20020220
00006	222520712	100.02	100.05	99.89	I70S	20020211	20020220
00006	222520713	100.07	99.37	100.08	I70S	20020211	20020220
00006	222520714	100	99.31	99.91	I70S	20020211	20020220
00006	222520715	100.04	99.96	100.02	I70S	20020211	20020220
00006	222520716	99.95	99.85	99.94	I70S	20020211	20020220
00006	222520717	99.91	99.38	99.93	I70S	20020211	20020220
00006	222520718	99.95	99.87	100.02	I70S	20020211	20020220
00006	222520719	100.1	99.54	99.97	I70S	20020211	20020220
00006	222520720	100.01	100.31	99.93	I70S	20020211	20020220
00006	222520721	100.12	100.18	99.89	I70S	20020211	20020220
00006	222520722	100.04	99.74	100.13	I70S	20020211	20020220
00006	222520723	99.93	99.57	100.07	I70S	20020211	20020220
00006	222520724	100.12	99.54	100.06	I70S	20020211	20020220
00006	222520725	99.99	100.3	100.03	I70S	20020211	20020220
00006	222520726	100	100.18	99.98	I70S	20020211	20020220
00006	222520727	99.98	100.48	99.93	I70S	20020211	20020220
00006	222520728	100.01	99.38	99.95	I70S	20020211	20020220
00006	222520729	100.02	99.92	100.11	I70S	20020211	20020220
00006	222520730	100.04	99.48	99.92	I70S	20020211	20020220
00006	222520731	100.03	100.25	99.99	I70S	20020211	20020220
00006	222520732	99.98	99.35	100.08	I70S	20020211	20020220
00006	222520733	99.99	99.57	99.98	I70S	20020211	20020220
00006	222520734	100.02	99.65	100.07	I70S	20020211	20020220

KY CTESTS for 2002

00006	222520735	100.03	99.52	99.86	I70S	20020211	20020220
00006	222520736	100	99.83	100.11	I70S	20020211	20020220
00006	222520737	99.95	99.52	99.93	I70S	20020211	20020220
00006	222520738	100.01	100.07	100.01	I70S	20020211	20020220
00006	222520739	100.04	100.35	100.01	I70S	20020211	20020220
00006	222520740	99.95	100.41	99.96	I70S	20020211	20020220
00006	222520741	100.04	99.73	100.12	I70S	20020211	20020220
00006	222520742	100.03	99.55	100.05	I70S	20020211	20020220
00006	222520743	100.03	100.11	100.09	I70S	20020211	20020220
00006	222520744	100.01	100.2	100.12	I70S	20020211	20020220
00006	222520745	100.05	99.89	100.12	I70S	20020211	20020220
00006	222520746	100.05	99.96	100.07	I70S	20020211	20020220
00006	222520747	100.03	99.4	100.05	I70S	20020211	20020220
00006	222520748	100.04	100.06	100	I70S	20020211	20020220
00006	222520749	99.9	100.01	99.97	I70S	20020211	20020220
00006	222520750	100.05	99.45	100.12	I70S	20020211	20020220
00006	222520751	100.12	100.35	100.04	I70S	20020211	20020220
00006	222520752	100.03	100.21	99.93	I70S	20020211	20020220
00006	222520753	100.02	100.39	100.06	I70S	20020211	20020220
00006	222520754	100.05	99.52	100.07	I70S	20020211	20020220
00006	222520755	100.01	99.75	100.1	I70S	20020211	20020220
00006	222520756	100.03	99.67	99.96	I70S	20020211	20020220
00006	222520757	99.97	99.42	99.99	I70S	20020211	20020220
00006	222520758	100.14	99.92	100.11	I70S	20020211	20020220
00006	222520759	100.02	99.83	100.12	I70S	20020211	20020220
00006	222520760	100.06	100.27	100.14	I70S	20020211	20020220
00006	222520761	100.02	100.22	100.07	I70S	20020211	20020220
00006	222520762	100.08	99.33	100.02	I70S	20020211	20020220
00006	222520763	99.93	100.13	99.87	I70S	20020211	20020220
00006	222520764	100.08	100.07	100.09	I70S	20020211	20020220
00006	222520765	100.04	99.73	100.12	I70S	20020211	20020220
00006	222520766	100.03	99.54	100.05	I70S	20020211	20020220
00006	222520767	100.01	99.8	100.01	I70S	20020211	20020220
00006	222520768	100.02	100.05	99.93	I70S	20020211	20020220
00006	222520769	99.94	99.42	100.13	I70S	20020211	20020220
00006	222520770	99.99	99.47	99.87	I70S	20020211	20020220
00006	222520771	100.01	99.62	99.91	I70S	20020211	20020220
00006	222520772	99.99	99.86	99.98	I70S	20020211	20020220
00006	222520773	100.12	99.51	99.94	I70S	20020211	20020220
00006	222520774	100.01	99.81	100.14	I70S	20020211	20020220
00006	222520775	100.05	99.52	100.07	I70S	20020211	20020220
00006	222520776	100.02	99.62	99.94	I70S	20020211	20020220
00006	222520777	100.04	99.79	100.09	I70S	20020211	20020220
00006	222520778	100.03	100.11	100.09	I70S	20020211	20020220
00006	222520779	99.92	99.74	99.97	I70S	20020211	20020220
00006	222520780	100.08	99.84	100.1	I70S	20020211	20020220
00006	222520781	99.99	99.5	100.05	I70S	20020211	20020220
00006	222520782	100	99.74	100.02	I70S	20020211	20020220
00006	222520783	100.02	99.85	99.99	I70S	20020211	20020220
00006	222520784	99.97	100.16	99.97	I70S	20020211	20020220
00006	222520785	99.96	100.59	100.08	I70S	20020211	20020220
00006	222520786	99.89	99.7	100.02	I70S	20020211	20020220
00006	222520787	100.08	100.16	100.05	I70S	20020211	20020220
00006	222520788	100.08	100.09	99.98	I70S	20020211	20020220
00006	222520789	100.02	100.37	99.92	I70S	20020211	20020220
00006	222520790	100.09	99.54	99.92	I70S	20020211	20020220
00006	222520791	100	99.46	100.09	I70S	20020211	20020220
00006	222520792	100.08	99.98	100.08	I70S	20020211	20020220
00006	222520793	100.04	99.45	99.87	I70S	20020211	20020220
00006	222520794	100.03	100.09	100.11	I70S	20020211	20020220
00006	222520795	100.01	99.59	99.88	I70S	20020211	20020220

KY CTESTS for 2002

00006	222520796	100.1	100.02	100.01	I70S	20020211	20020220
00006	222520797	100.04	99.54	100.06	I70S	20020211	20020220
00006	222520798	100.01	100.03	99.87	I70S	20020211	20020220
00006	222520799	99.96	99.63	99.93	I70S	20020211	20020220
00006	222520800	99.97	99.69	100.07	I70S	20020211	20020220
00006	222520801	99.94	99.97	100.09	I70S	20020211	20020220
00006	222520802	99.9	99.9	99.89	I70S	20020211	20020220
00006	222520803	99.88	99.92	99.88	I70S	20020211	20020220
00006	222520804	100.04	99.74	100.04	I70S	20020211	20020220
00006	222520805	100.05	100.08	99.95	I70S	20020211	20020220
00006	222520806	99.98	99.61	99.9	I70S	20020211	20020220
00006	222520807	99.99	100.06	99.92	I70S	20020211	20020220
00006	222520808	100.1	99.76	100.05	I70S	20020211	20020220
00006	222520809	100.08	100.04	100.07	I70S	20020211	20020220
00006	222520810	99.95	100.41	99.96	I70S	20020211	20020220
00006	222520811	99.88	99.9	99.97	I70S	20020211	20020220
00006	222520812	100.02	99.72	100.01	I70S	20020211	20020220
00006	222520813	99.98	100.13	100.12	I70S	20020211	20020220
00006	222520814	100.11	100.26	99.87	I70S	20020211	20020220
00006	222520815	100.02	100.22	100.07	I70S	20020211	20020220
00006	222520816	100.02	99.98	100.08	I70S	20020211	20020220
00006	222520817	99.96	99.55	100	I70S	20020211	20020220
00006	222520818	100.1	100.3	100.09	I70S	20020211	20020220
00006	222520819	99.97	100.46	99.96	I70S	20020211	20020220
00006	222520820	100.14	99.92	100.11	I70S	20020211	20020220
00006	222520821	99.91	99.85	99.94	I70S	20020211	20020220
00006	222520822	99.98	99.38	100.01	I70S	20020211	20020220
00006	222520823	100	99.74	100.02	I70S	20020211	20020220
00006	222520824	100.02	100.26	99.99	I70S	20020211	20020220
00006	222520825	99.98	100.21	100.1	I70S	20020211	20020220
00006	222520826	99.99	99.58	99.88	I70S	20020211	20020220
00006	222520827	99.96	99.48	99.9	I70S	20020211	20020220
00006	222520828	100.07	99.6	100.11	I70S	20020211	20020220
00006	222520829	99.97	99.62	100.11	I70S	20020211	20020220
00006	222520830	100.07	100.55	100	I70S	20020211	20020220
00006	222520831	99.95	99.31	99.87	I70S	20020211	20020220
00006	222520832	99.98	99.81	100.1	I70S	20020211	20020220
00006	222520834	100.03	100.11	100.09	I70S	20020211	20020220
00006	222520835	100.07	99.85	100.05	I70S	20020211	20020220
00006	222520836	100.11	100.22	99.93	I70S	20020211	20020220
00006	222523420	99.98	99.69	100	I70S	20020211	20020211
00006	222523728	99.99	99.8	100.01	I70S	20020211	20020301
00006	222523729	99.88	99.56	100.04	I70S	20020211	20020301
00006	222523731	100.04	100.2	100	I70S	20020211	20020301
00006	222523732	100	100.18	99.98	I70S	20020211	20020301
00006	222523826	99.98	100.16	100.04	I70S	20020212	20020301
00006	222523828	100.09	100.09	99.99	I70S	20020212	20020301
00006	222523829	100.04	99.7	99.96	I70S	20020212	20020301
00006	222523831	100.05	99.9	99.95	I70S	20020212	20020301
00006	222523832	100	99.88	100	I70S	20020212	20020301
00006	222578065	99.93	99.81	100.06	I70S	20020225	20020312
00006	222578066	100.05	99.58	100.13	I70S	20020225	20020312
00006	222578075	100.03	99.59	100.01	I70S	20020225	20020312
00006	222578076	100.05	99.75	100.09	I70S	20020225	20020312
00006	222578079	99.94	99.85	99.9	I70S	20020225	20020312
00006	222578080	100.08	99.99	100.02	I70S	20020225	20020312
00006	222578081	100.03	99.95	100.01	I70S	20020225	20020312
00006	222578082	99.99	100	100.08	I70S	20020225	20020312
00006	222578083	100.02	100.05	100.02	I70S	20020225	20020312
00006	222578084	100.11	100.35	100.12	I70S	20020225	20020312
00006	222578086	99.89	99.88	100.14	I70S	20020225	20020312

KY CTESTS for 2002

00006	222578087	100.06	100.2	100.06	I70S	20020225	20020312
00006	222578088	100.06	100.41	100.05	I70S	20020225	20020312
00006	222578089	100.07	99.86	100.08	I70S	20020225	20020312
00006	222578091	99.91	99.58	100	I70S	20020225	20020312
00006	222578092	100.09	100.12	99.94	I70S	20020225	20020312
00006	222578093	99.93	99.99	99.98	I70S	20020225	20020312
00006	222578094	100.08	99.39	100.1	I70S	20020225	20020312
00006	222578095	100.06	99.95	100.03	I70S	20020225	20020312
00006	222578096	99.98	99.66	99.91	I70S	20020225	20020312
00006	222578097	99.98	99.35	100.14	I70S	20020225	20020312
00006	222578098	99.98	99.93	100.07	I70S	20020225	20020312
00006	222578099	99.95	99.9	99.99	I70S	20020225	20020312
00006	222578100	100.01	100.17	100.02	I70S	20020225	20020312
00006	222578102	100.09	100.05	100.11	I70S	20020225	20020312
00006	222578107	99.92	99.8	99.89	I70S	20020225	20020312
00006	222578108	100.04	99.47	99.98	I70S	20020225	20020312
00006	222578109	99.99	99.61	99.89	I70S	20020225	20020312
00006	222578112	100	99.76	99.94	I70S	20020225	20020312
00006	222578113	100.02	99.51	100.01	I70S	20020225	20020312
00006	222578114	100.05	99.86	100	I70S	20020225	20020312
00006	222578115	99.97	99.71	99.9	I70S	20020225	20020312
00006	222578116	99.92	99.85	99.96	I70S	20020225	20020312
00006	222578117	99.9	99.7	100.06	I70S	20020225	20020312
00006	222578118	100.04	99.33	100.05	I70S	20020225	20020312
00006	222578119	99.88	99.64	100.08	I70S	20020225	20020312
00006	222578120	99.97	99.62	99.91	I70S	20020225	20020312
00006	222578121	100.07	100.04	100.14	I70S	20020225	20020312
00006	222578122	99.92	99.59	99.92	I70S	20020225	20020312
00006	222578123	100.02	100.4	100.13	I70S	20020225	20020312
00006	222578124	100.06	99.76	99.95	I70S	20020225	20020312
00006	222578125	100.01	99.46	99.96	I70S	20020225	20020312
00006	222578126	100	100	99.9	I70S	20020225	20020312
00006	222578127	99.99	99.79	99.87	I70S	20020225	20020312
00006	222578129	100	99.78	100.07	I70S	20020225	20020312
00006	222578130	100.01	100.31	100.1	I70S	20020225	20020312
00006	222578131	99.98	99.72	99.9	I70S	20020225	20020312
00006	222578132	100.01	100.13	99.97	I70S	20020225	20020312
00006	222578133	100.03	100.48	100	I70S	20020225	20020312
00006	222578134	100	100.11	99.9	I70S	20020225	20020312
00006	222578135	99.93	99.81	100.06	I70S	20020225	20020312
00006	222578136	100.04	99.88	99.94	I70S	20020225	20020312
00006	222578137	100.01	100.03	99.96	I70S	20020225	20020312
00006	222578138	99.96	100.11	100.12	I70S	20020225	20020312
00006	222578139	100.09	100.2	99.96	I70S	20020225	20020312
00006	222578140	100.03	99.98	100.08	I70S	20020225	20020312
00006	222578141	99.98	100.3	99.99	I70S	20020225	20020312
00006	222578142	100.06	99.99	100.12	I70S	20020225	20020312
00006	222578143	100.1	99.97	100.11	I70S	20020225	20020312
00006	222578144	100.05	99.58	100.13	I70S	20020225	20020312
00006	222578145	100.08	100.14	100.12	I70S	20020225	20020312
00006	222578146	100.03	100.2	100.06	I70S	20020225	20020312
00006	222578147	100.06	99.74	100.13	I70S	20020225	20020312
00006	222578148	100.06	100.01	100.13	I70S	20020225	20020312
00006	222578149	100.01	100.17	100.01	I70S	20020225	20020312
00006	222578150	100.05	99.74	100.1	I70S	20020225	20020312
00006	222578151	100.03	99.6	100.01	I70S	20020225	20020312
00006	222578152	100.04	100.1	100.03	I70S	20020225	20020312
00006	222578153	99.99	100.38	100.02	I70S	20020225	20020312
00006	222578154	100.11	100.23	99.99	I70S	20020225	20020312
00006	222578155	100.13	99.96	99.98	I70S	20020225	20020312
00006	222578156	99.92	99.83	100.01	I70S	20020225	20020312

KY CTESTS for 2002

00006	222578157	99.94	99.76	100.02	170S	20020225	20020312
00006	222578158	100.02	99.74	100.1	170S	20020225	20020312
00006	222578159	100.03	99.41	99.92	170S	20020225	20020312
00006	222578160	99.99	100.25	99.96	170S	20020225	20020312
00006	222578161	100.03	99.6	99.94	170S	20020225	20020312
00006	222578162	100	100.26	100.06	170S	20020225	20020312
00006	222578163	100.02	99.75	99.98	170S	20020225	20020312
00006	222578164	100.07	100.5	100.02	170S	20020225	20020312
00006	222578165	99.96	99.84	100.08	170S	20020225	20020312
00006	222578166	100.08	100.05	100.13	170S	20020225	20020312
00006	222578167	100.13	99.86	100.13	170S	20020225	20020312
00006	222578168	99.98	100.59	100.08	170S	20020225	20020312
00006	222578169	99.91	99.76	99.98	170S	20020225	20020312
00006	222578170	100.02	100.16	100	170S	20020225	20020312
00006	222578171	99.94	100.52	99.97	170S	20020225	20020312
00006	222578172	100.03	99.36	99.86	170S	20020225	20020312
00006	222578173	99.97	100.11	100.08	170S	20020225	20020312
00006	222578174	99.89	99.48	99.9	170S	20020225	20020312
00006	222578175	100.01	99.62	100.08	170S	20020225	20020312
00006	222578176	99.94	99.38	100	170S	20020225	20020312
00006	222578177	99.96	99.86	99.95	170S	20020225	20020312
00006	222578178	100.03	99.71	99.97	170S	20020225	20020312
00006	222578179	100.05	100.13	99.99	170S	20020225	20020312
00006	222578180	100.08	100.07	99.95	170S	20020225	20020312
00006	222578181	100	99.35	100.14	170S	20020225	20020312
00006	222578182	100.07	100.33	99.92	170S	20020225	20020312
00006	222578183	99.91	99.48	99.9	170S	20020225	20020312
00006	222578184	99.96	100.43	100.02	170S	20020225	20020312
00006	222578185	99.94	99.64	99.95	170S	20020225	20020312
00006	222578186	99.99	99.75	99.9	170S	20020225	20020312
00006	222578187	100.07	100.34	100.1	170S	20020225	20020312
00006	222578188	100.06	99.88	99.93	170S	20020225	20020312
00006	222578189	100.06	99.78	99.88	170S	20020225	20020312
00006	222578190	99.95	100.13	100.01	170S	20020225	20020312
00006	222578191	100.01	100.44	99.93	170S	20020225	20020312
00006	222578192	99.98	100.08	100.11	170S	20020225	20020312
00006	222578193	100.05	100.57	100.04	170S	20020225	20020312
00006	222578194	100.06	100.3	100.11	170S	20020225	20020312
00006	222578195	99.95	100.07	99.98	170S	20020225	20020312
00006	222578196	100	100.24	99.96	170S	20020225	20020312
00006	222578197	100.12	100.21	99.96	170S	20020225	20020312
00006	222578198	99.98	99.57	99.95	170S	20020225	20020312
00006	222578199	99.96	99.63	99.95	170S	20020225	20020312
00006	222578200	100.05	99.84	100.02	170S	20020225	20020312
00006	222578201	100.02	99.73	100.03	170S	20020225	20020312
00006	222578202	100.02	99.67	100.01	170S	20020225	20020312
00006	222578203	99.92	100.1	99.89	170S	20020225	20020312
00006	222578204	100.03	99.98	100.08	170S	20020225	20020312
00006	222578205	99.98	100.08	99.99	170S	20020225	20020312
00006	222578206	99.99	100.38	100.02	170S	20020225	20020312
00006	222578303	99.97	100.4	99.93	170S	20020225	20020312
00006	222578304	100.08	100.37	100.03	170S	20020225	20020312
00006	222578305	100.03	99.64	100.05	170S	20020225	20020312
00006	222578306	99.96	99.76	100.08	170S	20020225	20020312
00006	222578307	100.01	99.66	100.1	170S	20020225	20020312
00006	222578308	99.95	99.65	99.92	170S	20020225	20020312
00006	222578309	99.96	99.89	99.94	170S	20020225	20020312
00006	222578310	100.03	100.09	100	170S	20020225	20020312
00006	222578311	99.99	99.85	100.1	170S	20020225	20020312
00006	222578312	100	100.4	99.95	170S	20020225	20020312
00006	222578313	100.01	100.13	100.03	170S	20020225	20020312

KY CTESTS for 2002

00006	222578314	100	100.41	99.96	170S	20020225	20020312
00006	222578315	99.96	99.8	99.87	170S	20020225	20020312
00006	222578316	100.09	100.37	100.12	170S	20020225	20020312
00006	222578317	100.05	100.16	100.1	170S	20020225	20020312
00006	222578318	99.94	99.97	99.91	170S	20020225	20020312
00006	222578319	99.98	100.52	100.05	170S	20020225	20020312
00006	222578320	100.04	99.57	99.97	170S	20020225	20020312
00006	222578321	100.04	99.58	100.05	170S	20020225	20020312
00006	222578322	100.05	99.89	99.92	170S	20020225	20020312
00006	222578323	99.99	99.89	99.97	170S	20020225	20020312
00006	222578324	100.01	100.15	100.08	170S	20020225	20020312
00006	222578325	100.04	99.89	99.87	170S	20020225	20020312
00006	222578326	100.02	99.85	100.13	170S	20020225	20020312
00006	222578327	99.98	100.3	99.96	170S	20020225	20020312
00006	222578328	100	100.25	99.94	170S	20020225	20020312
00006	222578329	100.01	100.45	100.12	170S	20020225	20020312
00006	222578330	100.07	99.97	100.08	170S	20020225	20020312
00006	222578331	99.92	99.76	100.08	170S	20020225	20020312
00006	222578332	100.03	100.03	100.02	170S	20020225	20020312
00006	222578333	100.09	100.09	100.09	170S	20020225	20020312
00006	222578334	100.14	100.28	99.93	170S	20020225	20020312
00006	222578335	100.04	100.13	100.07	170S	20020225	20020312
00006	222578336	100.01	99.85	100.14	170S	20020225	20020312
00006	222578337	99.97	99.88	99.93	170S	20020225	20020312
00006	222578338	99.92	100.05	99.94	170S	20020225	20020312
00006	222578339	99.99	100.1	99.94	170S	20020225	20020312
00006	222578340	100	100	100.01	170S	20020225	20020312
00006	222578341	100.09	99.96	100.04	170S	20020225	20020312
00006	222578342	100.03	99.85	100.09	170S	20020225	20020312
00006	222578344	100	100	99.99	170S	20020225	20020312
00006	222578346	100.01	99.63	99.98	170S	20020225	20020312
00006	222578347	100.04	100.31	99.92	170S	20020225	20020312
00006	222578348	100.01	99.9	99.88	170S	20020225	20020312
00006	222578349	100	100.11	99.95	170S	20020225	20020312
00006	222578350	100.01	99.45	99.86	170S	20020225	20020312
00006	222578351	99.9	100.06	100.1	170S	20020225	20020312
00006	222578352	99.99	99.94	99.88	170S	20020225	20020312
00006	222578353	100.09	99.75	99.9	170S	20020225	20020312
00006	222578354	100.08	100	100.06	170S	20020225	20020312
00006	222578355	99.98	99.64	100.03	170S	20020225	20020312
00006	222578356	99.99	99.6	100.05	170S	20020225	20020312
00006	222578357	99.96	100.01	100.09	170S	20020225	20020312
00006	222578358	100.02	99.59	99.91	170S	20020225	20020312
00006	222578359	99.98	100.16	99.86	170S	20020225	20020312
00006	222578361	100	99.65	100.03	170S	20020225	20020312
00006	222578362	100.04	100.5	100.02	170S	20020225	20020312
00006	222578363	99.92	100.13	99.97	170S	20020225	20020312
00006	222578364	100.07	100.07	100.04	170S	20020225	20020312
00006	222578365	100	100.27	100.03	170S	20020225	20020312
00006	222578366	100.09	100.42	100.02	170S	20020225	20020312
00006	222578367	100.03	99.48	100.01	170S	20020225	20020312
00006	222578368	99.93	100.06	99.88	170S	20020225	20020312
00006	222578370	100.14	99.83	99.95	170S	20020225	20020312
00006	222578371	100.03	99.83	100.14	170S	20020225	20020312
00006	222578372	99.92	99.71	100	170S	20020225	20020312
00006	222578373	100.03	99.36	99.94	170S	20020225	20020312
00006	222578374	100	100.28	99.98	170S	20020225	20020312
00006	222578375	100.07	100	100.02	170S	20020225	20020312
00006	222578376	100	99.6	99.96	170S	20020225	20020312
00006	222578377	100.06	100.05	100.05	170S	20020225	20020312
00006	222578378	100.01	99.89	99.98	170S	20020225	20020312

KY CTESTS for 2002

00006	222578379	99.98	100.01	100.02	I70S	20020225	20020312
00006	222578380	99.95	100.23	99.91	I70S	20020225	20020312
00006	222578381	100.02	99.66	100.03	I70S	20020225	20020312
00006	222578382	99.99	100.25	99.98	I70S	20020225	20020312
00006	222578383	100.04	100.15	100.02	I70S	20020225	20020312
00006	222578384	99.95	99.92	100	I70S	20020225	20020312
00006	222578385	100.03	100.23	99.92	I70S	20020225	20020312
00006	222578386	100.02	99.97	100.13	I70S	20020225	20020312
00006	222578387	99.9	99.41	99.89	I70S	20020225	20020312
00006	222578388	100.09	100.57	99.97	I70S	20020225	20020312
00006	222578389	99.97	99.81	99.95	I70S	20020225	20020312
00006	222578390	100.01	99.86	99.89	I70S	20020225	20020312
00006	222578391	100.01	100.05	100.06	I70S	20020225	20020312
00006	222578392	99.97	99.88	99.9	I70S	20020225	20020312
00006	222578393	99.99	99.81	100.01	I70S	20020225	20020312
00006	222578394	99.97	99.64	99.96	I70S	20020225	20020312
00006	222578395	99.98	100.03	100.04	I70S	20020225	20020312
00006	222578396	100.1	100.17	100.1	I70S	20020225	20020312
00006	222578397	100.03	99.89	99.88	I70S	20020225	20020312
00006	222578398	99.92	100.12	100.07	I70S	20020225	20020312
00006	222578465	100.07	100.13	100.11	I70S	20020225	20020312
00006	222578495	99.97	99.86	100.02	I70S	20020225	20020312
00006	222578496	100.01	100.24	100.03	I70S	20020225	20020312
00006	222578497	99.99	100.52	100.01	I70S	20020225	20020312
00006	222578498	99.91	100.33	100.03	I70S	20020225	20020312
00006	222578499	99.93	99.51	100.03	I70S	20020225	20020312
00006	222578500	99.96	99.91	99.91	I70S	20020225	20020312
00006	222578501	99.93	99.93	99.88	I70S	20020225	20020312
00006	222578502	100.04	100	100.03	I70S	20020225	20020312
00006	222578503	100.06	99.33	100.04	I70S	20020225	20020312
00006	222578504	100.05	100.33	99.95	I70S	20020225	20020312
00006	222578505	100.01	100.57	99.94	I70S	20020225	20020312
00006	222578506	99.95	99.51	99.89	I70S	20020225	20020312
00006	222578507	100.03	100.17	100.13	I70S	20020225	20020312
00006	222578508	99.87	100.17	99.88	I70S	20020225	20020312
00006	222578509	99.97	99.89	100.09	I70S	20020225	20020312
00006	222578510	99.97	99.87	100.11	I70S	20020225	20020312
00006	222578511	100.08	99.63	100.02	I70S	20020225	20020312
00006	222578512	100.04	99.91	99.99	I70S	20020225	20020312
00006	222578513	100	99.69	100.14	I70S	20020225	20020312
00006	222578514	99.99	100.12	100.06	I70S	20020225	20020312
00006	222578515	99.95	100.16	100.06	I70S	20020225	20020312
00006	222578516	100.02	99.98	99.91	I70S	20020225	20020312
00006	222578517	100.12	100.69	99.95	I70S	20020225	20020312
00006	222578518	100.11	99.97	100.08	I70S	20020225	20020312
00006	222578519	99.95	100.08	100.09	I70S	20020225	20020312
00006	222578520	99.91	100.38	99.93	I70S	20020225	20020312
00006	222578521	100	99.94	99.96	I70S	20020225	20020312
00006	222578522	100.08	100.39	99.96	I70S	20020225	20020312
00006	222578523	100	100.42	99.96	I70S	20020225	20020312
00006	222578524	100.06	99.92	100.03	I70S	20020225	20020312
00006	222578525	100.06	100	100	I70S	20020225	20020312
00006	222578526	100.07	100.08	100	I70S	20020225	20020312
00006	222578527	100	99.7	99.97	I70S	20020225	20020312
00006	222578528	100	100.02	100.11	I70S	20020225	20020312
00006	222578529	100.07	99.83	100.14	I70S	20020225	20020312
00006	222578530	99.92	100.63	99.98	I70S	20020225	20020312
00006	222578531	100.07	100.56	100.1	I70S	20020225	20020312
00006	222578532	99.95	100.6	100.03	I70S	20020225	20020312
00006	222578533	100.05	99.84	99.99	I70S	20020225	20020312
00006	222578534	100.06	100.32	100.02	I70S	20020225	20020312

KY CTESTS for 2002

00006	222578535	99.97	100	99.92	I70S	20020225	20020312
00006	222578536	100.09	100.13	99.97	I70S	20020225	20020312
00006	222578537	99.97	100.55	100.03	I70S	20020225	20020312
00006	222578538	99.9	99.65	100.04	I70S	20020225	20020312
00006	222578539	99.96	100.34	99.87	I70S	20020225	20020312
00006	222578540	100.01	100.47	100.14	I70S	20020225	20020312
00006	222578541	100.05	99.95	100.09	I70S	20020225	20020312
00006	222578542	100.01	99.66	99.98	I70S	20020225	20020312
00006	222578543	100.04	100.4	100.09	I70S	20020225	20020312
00006	222578544	100	100.58	99.92	I70S	20020225	20020312
00006	222578545	99.96	100.01	99.91	I70S	20020225	20020312
00006	222578546	100.04	100	100.03	I70S	20020225	20020312
00006	222578547	99.94	100.14	100.03	I70S	20020225	20020312
00006	222578548	100.02	99.84	100.02	I70S	20020225	20020312
00006	222578549	100.06	99.52	99.96	I70S	20020225	20020312
00006	222578550	99.97	100.34	99.86	I70S	20020225	20020312
00006	222578551	99.94	100.25	99.9	I70S	20020225	20020312
00006	222578552	99.98	99.67	100.02	I70S	20020225	20020312
00006	222578553	100.01	100.03	99.88	I70S	20020225	20020312
00006	222578554	100.01	100.64	100.01	I70S	20020225	20020312
00006	222578555	100.01	99.72	99.96	I70S	20020225	20020312
00006	222578556	100.04	100.42	100.12	I70S	20020225	20020312
00006	222578557	99.96	100.2	99.94	I70S	20020225	20020312
00006	222578558	99.89	99.59	100.02	I70S	20020225	20020312
00006	222578559	99.99	100.12	99.89	I70S	20020225	20020312
00006	222578560	99.98	100.19	99.99	I70S	20020225	20020312
00006	222578561	99.9	100.22	99.88	I70S	20020225	20020312
00006	222578562	100.07	100.05	100.07	I70S	20020225	20020312
00006	222578563	99.98	99.88	100.09	I70S	20020225	20020312
00006	222578564	99.97	99.93	100	I70S	20020225	20020312
00006	222578565	100.02	100.5	99.9	I70S	20020225	20020312
00006	222578566	99.88	100.39	100.13	I70S	20020225	20020312
00006	222578567	99.95	100.16	100.06	I70S	20020225	20020312
00006	222578568	100.08	100.37	100.04	I70S	20020225	20020312
00006	222578569	100.01	100.23	99.95	I70S	20020225	20020312
00006	222578570	99.94	100	100.02	I70S	20020225	20020312
00006	222578571	99.96	99.92	99.93	I70S	20020225	20020312
00006	222578572	99.98	99.83	99.94	I70S	20020225	20020312
00006	222578573	99.99	100.32	100.13	I70S	20020225	20020312
00006	222578574	99.98	99.67	100.02	I70S	20020225	20020312
00006	222578575	99.86	99.79	99.97	I70S	20020225	20020312
00006	222578576	100.05	100.03	99.94	I70S	20020225	20020312
00006	222578577	100.09	100.13	100.12	I70S	20020225	20020312
00006	222578578	100.13	100.08	100.14	I70S	20020225	20020312
00006	222578579	99.95	100.67	100.03	I70S	20020225	20020312
00006	222578580	99.95	100.38	99.94	I70S	20020225	20020312
00006	222578581	100.01	99.93	99.99	I70S	20020225	20020312
00006	222578582	99.93	99.99	99.93	I70S	20020225	20020312
00006	222578583	99.97	100.15	100.04	I70S	20020225	20020312
00006	222578584	99.96	100.05	100.02	I70S	20020225	20020312
00006	222578585	99.98	99.98	100.05	I70S	20020225	20020312
00006	222578586	99.89	100.16	99.9	I70S	20020225	20020312
00006	222578587	100.05	100.22	99.94	I70S	20020225	20020312
00006	222578588	99.99	99.99	100.02	I70S	20020225	20020312
00006	222578589	99.93	99.61	100.1	I70S	20020225	20020312
00006	222578590	100.07	100.05	99.97	I70S	20020225	20020312
00006	222578592	100.11	99.97	100.08	I70S	20020225	20020312
00006	222578593	99.96	99.85	99.99	I70S	20020225	20020312
00006	222578594	100.04	99.73	100.02	I70S	20020225	20020312
00006	222578595	99.95	99.5	100.02	I70S	20020225	20020312
00006	222578596	100.01	100.13	99.95	I70S	20020225	20020312

KY CTESTS for 2002

00006	222578597	100	100	100.03	I70S	20020225	20020312
00006	222578598	100.07	100.68	99.95	I70S	20020225	20020312
00006	222578599	100.07	99.87	100.1	I70S	20020225	20020312
00006	222578601	100.01	100.28	99.92	I70S	20020225	20020312
00006	222578602	99.91	99.63	99.87	I70S	20020225	20020312
00006	222578603	99.98	100	100.01	I70S	20020225	20020312
00006	222578604	100.01	100.29	99.91	I70S	20020225	20020312
00006	222578605	99.99	100.2	100.14	I70S	20020225	20020312
00006	222578606	100.05	100.52	100.14	I70S	20020225	20020312
00006	222578607	99.93	99.61	100.01	I70S	20020225	20020312
00006	222578608	100.03	99.98	99.88	I70S	20020225	20020312
00006	222578609	99.95	99.59	99.96	I70S	20020225	20020312
00006	222578611	100	99.83	100.06	I70S	20020225	20020312
00006	222578612	99.94	100.4	100.09	I70S	20020225	20020312
00006	222578613	99.95	99.59	99.96	I70S	20020225	20020312
00006	222578614	100.08	100.68	99.95	I70S	20020225	20020312
00006	222578615	99.97	99.76	100.14	I70S	20020225	20020312
00006	222578616	99.87	100.43	99.94	I70S	20020225	20020312
00006	222578617	99.99	100.68	99.92	I70S	20020225	20020312
00006	222578618	99.97	100.19	100.14	I70S	20020225	20020312
00006	222578619	100	100.02	100.11	I70S	20020225	20020312
00006	222578620	100.03	100.01	100.03	I70S	20020225	20020312
00006	222578621	99.97	99.47	99.94	I70S	20020225	20020312
00006	222578622	100.09	99.61	100.12	I70S	20020225	20020312
00006	222578623	99.98	100.06	99.9	I70S	20020225	20020312
00006	222578624	99.98	99.35	99.97	I70S	20020225	20020312
00006	222578625	99.88	100.67	99.87	I70S	20020225	20020312
00006	222578626	100.02	100.53	100.09	I70S	20020225	20020312
00006	222578627	100.04	99.79	99.97	I70S	20020225	20020312
00006	222578628	99.92	100.66	99.96	I70S	20020225	20020312
00006	222578629	100.02	99.83	100.08	I70S	20020225	20020312
00006	222578630	99.96	100.56	100.06	I70S	20020225	20020312
00006	222578631	99.98	99.68	99.97	I70S	20020225	20020312
00006	222578632	99.99	100.32	99.94	I70S	20020225	20020312
00006	222578633	100.03	99.89	99.92	I70S	20020225	20020312
00006	222578634	100.04	99.59	100.14	I70S	20020225	20020312
00006	222578635	99.88	100.59	99.95	I70S	20020225	20020312
00006	222578636	100.04	99.58	100.05	I70S	20020225	20020312
00006	222578637	100.07	100.29	100.02	I70S	20020225	20020312
00006	222578638	100.02	100.49	100.01	I70S	20020225	20020312
00006	222578639	100.04	99.91	100.04	I70S	20020225	20020312
00006	222578640	100.08	99.86	99.93	I70S	20020225	20020312
00006	222578641	100.02	100.25	99.9	I70S	20020225	20020312
00006	222578642	99.9	100.02	99.96	I70S	20020225	20020312
00006	222578643	99.97	100.06	100.11	I70S	20020225	20020312
00006	222578644	100.01	100.08	100.13	I70S	20020225	20020312
00006	222578645	100.03	99.51	99.87	I70S	20020225	20020312
00006	222578646	100.04	99.71	99.91	I70S	20020225	20020312
00006	222578647	100.11	100.68	99.92	I70S	20020225	20020312
00006	222578648	99.92	99.65	99.93	I70S	20020225	20020312
00006	222578649	100	100.1	100	I70S	20020225	20020312
00006	222578650	99.99	99.79	99.92	I70S	20020225	20020312
00006	222578651	99.94	99.63	99.97	I70S	20020225	20020312
00006	222578652	99.93	100.64	100.01	I70S	20020225	20020312
00006	222578653	100.03	99.81	99.98	I70S	20020225	20020312
00006	222578654	100.02	100.01	100.11	I70S	20020225	20020312
00006	222578655	99.98	99.67	100.02	I70S	20020225	20020312
00006	222578656	100.07	100.01	100.14	I70S	20020225	20020312
00006	222578657	99.9	99.74	100.11	I70S	20020225	20020312
00006	222578659	100.07	100.01	100	I70S	20020225	20020312
00006	222578660	100.04	100.01	100.12	I70S	20020225	20020312

KY CTESTS for 2002

00006	222578661	100.06	99.8	100.14	I70S	20020225	20020312
00006	222578662	100.03	100.56	99.88	I70S	20020225	20020312
00006	222578663	100.05	100.24	100.09	I70S	20020225	20020312
00006	222578664	100.02	99.9	99.97	I70S	20020225	20020312
00006	222578665	99.95	100.45	99.99	I70S	20020225	20020312
00006	222578667	100.01	99.92	100.02	I70S	20020225	20020312
00006	222578668	99.93	99.94	99.98	I70S	20020225	20020312
00006	222578669	99.9	99.92	99.87	I70S	20020225	20020312
00006	222578670	100.09	100.13	100.12	I70S	20020225	20020312
00006	222578671	100.02	100.33	99.94	I70S	20020225	20020312
00006	222578672	99.92	100.63	99.87	I70S	20020225	20020312
00006	222578673	99.98	100.35	100.04	I70S	20020225	20020312
00006	222578674	99.89	99.45	99.98	I70S	20020225	20020312
00006	222578675	99.89	99.85	100.1	I70S	20020225	20020312
00006	222578676	100.06	99.85	100.1	I70S	20020225	20020312
00006	222578677	100.01	100.29	100.12	I70S	20020225	20020312
00006	222578678	100.01	99.93	100.03	I70S	20020225	20020312
00006	222578679	99.87	100.07	100.03	I70S	20020225	20020312
00006	222578680	99.86	99.86	99.95	I70S	20020225	20020312
00006	222578681	100.09	100.08	99.92	I70S	20020225	20020312
00006	222578682	99.87	100.3	99.98	I70S	20020225	20020312
00006	222578683	99.86	100.07	100.01	I70S	20020225	20020312
00006	222578684	99.94	100.67	100	I70S	20020225	20020312
00006	222578685	100.07	100.08	100.05	I70S	20020225	20020312
00006	222578686	99.94	99.68	100.04	I70S	20020225	20020312
00006	222578687	100.04	99.78	100.08	I70S	20020225	20020312
00006	222578688	100.11	99.95	100.13	I70S	20020225	20020312
00006	222578689	99.96	100.01	99.96	I70S	20020225	20020312
00006	222578690	100.01	100.35	100.01	I70S	20020225	20020312
00006	222578691	100.01	100.51	100.05	I70S	20020225	20020312
00006	222578692	100	100.06	99.98	I70S	20020225	20020312
00006	222578693	99.99	100.1	99.99	I70S	20020225	20020312
00006	222578694	99.97	100.68	100.05	I70S	20020225	20020312
00006	222578695	99.96	100.06	99.97	I70S	20020225	20020312
00006	222578696	100.05	100.41	100.05	I70S	20020225	20020312
00006	222578697	99.97	99.92	100.01	I70S	20020225	20020312
00006	222578698	99.94	99.61	99.89	I70S	20020225	20020312
00006	222578699	99.97	100.09	99.95	I70S	20020225	20020312
00006	222578700	100.03	99.77	100	I70S	20020225	20020312
00006	222578701	100.03	100.18	99.96	I70S	20020225	20020312
00006	222578702	99.98	99.9	100.12	I70S	20020225	20020312
00006	222578703	99.96	99.85	99.99	I70S	20020225	20020312
00006	222578704	99.99	99.89	99.97	I70S	20020225	20020312
00006	222578705	100.04	100.63	99.88	I70S	20020225	20020312
00006	222578706	99.96	99.94	99.9	I70S	20020225	20020312
00006	222578707	99.86	99.98	99.91	I70S	20020225	20020312
00006	222578708	99.99	100.07	99.95	I70S	20020225	20020312
00006	222578709	100.05	99.86	100.12	I70S	20020225	20020312
00006	222578710	100.11	100.25	100.12	I70S	20020225	20020312
00006	222578712	99.89	99.9	99.98	I70S	20020225	20020312
00006	222578713	100.01	100.04	100.14	I70S	20020225	20020312
00006	222578714	100.04	100.6	100.03	I70S	20020225	20020312
00006	222578715	100.05	100.3	100.09	I70S	20020225	20020312
00006	222578716	100.01	100.19	100.12	I70S	20020225	20020312
00006	222578717	99.96	100.1	99.88	I70S	20020225	20020312
00006	222578718	100	99.88	99.99	I70S	20020225	20020312
00006	222578719	100.06	99.66	100.01	I70S	20020225	20020312
00006	222578720	100.07	99.81	99.99	I70S	20020225	20020312
00006	222578721	100.12	100.56	100.1	I70S	20020225	20020312
00006	222578722	100.01	100.5	99.88	I70S	20020225	20020312
00006	222578723	99.93	100.55	100	I70S	20020225	20020312

KY CTESTS for 2002

00006	222578724	100.11	99.99	100.08	I70S	20020225	20020312
00006	222578725	100.02	100.47	100.08	I70S	20020225	20020312
00006	222578726	100.02	99.98	100.08	I70S	20020225	20020312
00006	222578727	100.09	99.68	100.02	I70S	20020225	20020312
00006	222578728	99.96	99.58	99.96	I70S	20020225	20020312
00006	222578729	100	100.08	99.97	I70S	20020225	20020312
00006	222578730	99.93	100.5	100.05	I70S	20020226	20020312
00006	222578731	100.07	99.76	100.14	I70S	20020225	20020312
00006	222578732	99.95	100.47	99.92	I70S	20020225	20020312
00006	222578733	99.97	99.96	99.88	I70S	20020225	20020312
00006	222578734	99.99	99.84	100.11	I70S	20020225	20020312
00006	222578735	100.07	100.29	100.02	I70S	20020225	20020312
00006	222578736	100.01	100.31	100.07	I70S	20020225	20020312
00006	222578737	99.98	99.65	100.01	I70S	20020225	20020312
00006	222578738	100.02	100.51	100.07	I70S	20020225	20020312
00006	222578739	99.92	99.55	99.92	I70S	20020225	20020312
00006	222578740	99.92	100.63	99.89	I70S	20020225	20020312
00006	222578741	100.03	99.7	99.99	I70S	20020225	20020312
00006	222578742	100.06	100.63	99.96	I70S	20020225	20020312
00006	222578743	100	100.29	99.89	I70S	20020225	20020312
00006	222578744	99.96	100.59	99.93	I70S	20020225	20020312
00006	222578745	99.92	100.25	99.93	I70S	20020225	20020312
00006	222578746	99.95	100.06	99.89	I70S	20020225	20020312
00006	222578747	99.95	100.1	99.97	I70S	20020225	20020312
00006	222578748	99.9	100.48	100.05	I70S	20020225	20020312
00006	222578749	99.99	100.27	100.14	I70S	20020225	20020312
00006	222578750	99.86	100.23	100.08	I70S	20020225	20020312
00006	222578751	100.06	100.57	100.01	I70S	20020225	20020312
00006	222578752	100.1	100.37	100.03	I70S	20020225	20020312
00006	222578753	99.97	99.5	100.14	I70S	20020225	20020312
00006	222578754	100.01	100.23	99.95	I70S	20020225	20020312
00006	222578755	99.98	99.69	99.97	I70S	20020225	20020312
00006	222578756	99.91	99.94	100.13	I70S	20020225	20020312
00006	222578757	100.11	100.24	100.02	I70S	20020225	20020312
00006	222578758	99.93	100.44	99.93	I70S	20020225	20020312
00006	222578760	100	99.83	99.9	I70S	20020225	20020312
00006	222578761	100.1	100.07	100.01	I70S	20020225	20020312
00006	222578762	99.96	99.62	99.88	I70S	20020225	20020312
00006	222578763	100.06	99.72	99.9	I70S	20020225	20020312
00006	222578764	100.02	99.69	100.07	I70S	20020225	20020312
00006	222578765	100	100.61	100.05	I70S	20020225	20020312
00006	222578766	99.93	100.28	100.05	I70S	20020225	20020312
00006	222578767	99.94	100.47	99.87	I70S	20020225	20020312
00006	222578768	100.06	100.41	100.03	I70S	20020225	20020312
00006	222578769	100.11	99.91	100	I70S	20020225	20020312
00006	222578770	100.12	100.45	100.06	I70S	20020225	20020312
00006	222578771	99.9	99.85	99.92	I70S	20020225	20020312
00006	222578772	100.07	99.8	100	I70S	20020225	20020312
00006	222578773	100.06	100.12	100.08	I70S	20020225	20020312
00006	222578774	100.06	100.18	100.13	I70S	20020225	20020312
00006	222578775	100.08	100.35	99.98	I70S	20020225	20020312
00006	222578776	100.03	100.39	99.9	I70S	20020225	20020312
00006	222578777	99.95	99.71	100.05	I70S	20020225	20020312
00006	222578778	100.01	99.91	100.09	I70S	20020225	20020312
00006	222578779	99.95	100.29	100.01	I70S	20020225	20020312
00006	222578780	100.06	99.85	100.1	I70S	20020225	20020312
00006	222578781	99.97	99.88	100.14	I70S	20020225	20020312
00006	222578782	100.01	100.66	100.12	I70S	20020225	20020312
00006	222578783	99.93	100.17	99.87	I70S	20020225	20020312
00006	222578784	100.06	100.03	99.98	I70S	20020225	20020312
00006	222578785	100.12	100.6	100.01	I70S	20020225	20020312

KY CTESTS for 2002

00006	222578786	100.05	99.96	99.99	170S	20020225	20020312
00006	222578787	99.99	99.89	99.97	170S	20020225	20020312
00006	222578788	100.09	100.67	99.95	170S	20020225	20020312
00006	222578789	100.05	100.44	100.07	170S	20020225	20020312
00006	222578790	100.08	99.84	99.94	170S	20020225	20020312
00006	222578791	99.92	99.84	99.87	170S	20020225	20020312
00006	222578792	100.14	100.18	99.92	170S	20020225	20020312
00006	222578794	99.97	100.26	99.9	170S	20020225	20020312
00006	222578796	99.89	100.42	99.95	170S	20020225	20020312
00006	222578797	100.01	100.31	100.07	170S	20020225	20020312
00006	222578798	99.99	100.18	100.09	170S	20020225	20020312
00006	222578800	99.96	99.84	99.94	170S	20020225	20020312
00006	222578801	100.06	100.57	100.01	170S	20020225	20020312
00006	222578802	100.05	100.37	100.11	170S	20020225	20020312
00006	222578803	100.05	99.86	100.12	170S	20020225	20020312
00006	222578804	99.89	100.09	100.08	170S	20020225	20020312
00006	222578805	99.91	99.99	100.13	170S	20020225	20020312
00006	222578806	100.03	100.27	100.08	170S	20020225	20020312
00006	222578807	99.98	100.55	99.92	170S	20020225	20020312
00006	222578808	100	99.97	100.08	170S	20020225	20020312
00006	222578809	100.09	99.78	99.88	170S	20020225	20020312
00006	222578810	100.02	99.89	99.9	170S	20020225	20020312
00006	222578811	100.02	100.26	99.93	170S	20020225	20020312
00006	222578812	99.96	100.45	100.02	170S	20020225	20020312
00006	222578813	99.96	100.04	100.05	170S	20020225	20020312
00006	222578814	100.01	100.42	100.01	170S	20020225	20020312
00006	222578815	100.11	100.41	99.94	170S	20020225	20020312
00006	222578816	100.04	100.64	100.08	170S	20020225	20020312
00006	222578817	100.04	99.54	100.14	170S	20020225	20020312
00006	222578818	100	99.79	99.87	170S	20020225	20020312
00006	222578819	100	100.56	99.9	170S	20020225	20020312
00006	222578821	100.12	100.21	99.98	170S	20020225	20020312
00006	222578822	100.06	100.56	99.86	170S	20020225	20020312
00006	222578823	100.09	100.35	100.11	170S	20020225	20020312
00006	222578824	99.96	99.49	99.87	170S	20020225	20020312
00006	222578825	100.1	100.39	99.92	170S	20020225	20020312
00006	222578826	100.12	100.39	100	170S	20020225	20020312
00006	222578827	100.03	100.23	100.1	170S	20020225	20020312
00006	222578828	100.03	100.6	100.14	170S	20020225	20020312
00006	222578829	100.07	100.29	99.94	170S	20020225	20020312
00006	222578830	100.11	100.05	99.95	170S	20020225	20020312
00006	222578831	100	100.42	99.95	170S	20020225	20020312
00006	222578832	100.07	100.38	100.14	170S	20020225	20020312
00006	222578833	99.96	100.19	99.89	170S	20020225	20020312
00006	222578834	99.95	100.39	99.97	170S	20020225	20020312
00006	222578835	99.88	99.87	99.99	170S	20020225	20020312
00006	222578836	99.99	100.61	100.06	170S	20020225	20020312
00006	222578837	100.07	99.59	100.05	170S	20020225	20020312
00006	222578838	100.01	100.58	100.02	170S	20020225	20020312
00006	222578839	100.03	99.71	100.04	170S	20020225	20020312
00006	222578840	100.02	100.04	100.12	170S	20020225	20020312
00006	222578841	99.95	100.08	99.89	170S	20020225	20020312
00006	222578842	100	100	100.02	170S	20020225	20020312
00006	222578843	100.11	100.37	99.93	170S	20020225	20020312
00006	222578844	100.06	100.25	99.99	170S	20020225	20020312
00006	222578845	99.87	100.35	99.89	170S	20020225	20020312
00006	222578846	99.98	100.43	99.96	170S	20020225	20020312
00006	222578847	99.99	100.11	100.06	170S	20020225	20020312
00006	222578848	100.02	100.38	99.93	170S	20020225	20020312
00006	222578849	100	100.28	100.11	170S	20020225	20020312
00006	222578850	100.04	100.14	100.13	170S	20020225	20020312

KY CTESTS for 2002

00006	222578851	99.9	100.11	100.05	I70S	20020225	20020312
00006	222578852	100.08	100	100.01	I70S	20020225	20020312
00006	222578853	99.86	99.95	99.9	I70S	20020225	20020312
00006	222578854	100	99.38	99.87	I70S	20020225	20020312
00006	222578855	99.99	100.21	100	I70S	20020225	20020312
00006	222578856	100	100.68	100.05	I70S	20020225	20020312
00006	222578857	99.97	100.55	100.13	I70S	20020225	20020312
00006	222578858	100.03	99.81	99.98	I70S	20020225	20020312
00006	222578859	100.1	100.17	100.04	I70S	20020225	20020312
00006	222578860	100.13	100.05	99.97	I70S	20020225	20020312
00006	222578861	99.98	99.65	100.01	I70S	20020225	20020312
00006	222578862	100.12	99.69	100.12	I70S	20020225	20020312
00006	222578863	99.91	100.33	99.88	I70S	20020225	20020312
00006	222578864	99.93	100.28	100.05	I70S	20020225	20020312
00006	222578865	99.96	99.58	99.96	I70S	20020225	20020312
00006	222578866	99.96	99.65	100	I70S	20020225	20020312
00006	222578867	99.97	100	100.11	I70S	20020225	20020312
00006	222578868	100.04	100.61	100.03	I70S	20020225	20020312
00006	222578869	100.01	100.64	100.14	I70S	20020225	20020312
00006	222578870	99.97	100.21	99.86	I70S	20020225	20020312
00006	222578871	100.04	100.61	100.03	I70S	20020225	20020312
00006	222578872	100.01	100.32	99.88	I70S	20020225	20020312
00006	222578873	100.04	100.56	99.96	I70S	20020225	20020312
00006	222578874	100.03	100.13	100.01	I70S	20020225	20020312
00006	222578875	99.93	99.61	100.01	I70S	20020225	20020312
00006	222578876	100	100.15	99.96	I70S	20020225	20020312
00006	222578877	99.91	99.88	99.88	I70S	20020225	20020312
00006	222578878	100.03	100.07	99.9	I70S	20020225	20020312
00006	222578880	100	100.29	99.92	I70S	20020225	20020312
00006	222578881	100.12	100.6	100.01	I70S	20020225	20020312
00006	222578882	99.96	100.11	100	I70S	20020225	20020312
00006	222578883	100.14	100.26	100.02	I70S	20020225	20020312
00006	222578884	100.02	100.14	99.96	I70S	20020225	20020312
00006	222578887	100.02	100.16	100.11	I70S	20020225	20020312
00006	222578888	99.91	99.9	99.98	I70S	20020225	20020312
00006	222578889	100	100.08	99.88	I70S	20020225	20020312
00006	222578890	99.88	100.39	100.11	I70S	20020225	20020312
00006	222578891	100.05	99.72	100	I70S	20020225	20020312
00006	222578892	99.89	100.42	99.95	I70S	20020225	20020312
00006	222578893	100.01	100.06	99.86	I70S	20020225	20020312
00006	222578894	100.08	99.61	100.13	I70S	20020225	20020312
00006	222578895	100.05	100.42	99.9	I70S	20020225	20020312
00006	222578896	100	100.35	99.93	I70S	20020225	20020312
00006	222578897	99.99	100.1	99.93	I70S	20020225	20020312
00006	222578898	100	100.33	99.88	I70S	20020225	20020312
00006	222578899	99.96	99.49	99.87	I70S	20020225	20020312
00006	222578900	100	99.79	100.08	I70S	20020225	20020312
00006	222578901	100.1	99.59	100.13	I70S	20020225	20020312
00006	222578902	99.97	99.96	100.07	I70S	20020225	20020312
00006	222578903	100.11	99.78	99.93	I70S	20020225	20020312
00006	222578904	100.01	100.52	100.14	I70S	20020225	20020312
00006	222578905	99.93	99.62	99.91	I70S	20020225	20020312
00006	222578906	100.07	100.29	99.94	I70S	20020225	20020312
00006	222578907	99.95	99.75	100.12	I70S	20020225	20020312
00006	222578908	100.03	100.32	99.9	I70S	20020225	20020312
00006	222578910	99.94	100.1	100.14	I70S	20020225	20020312
00006	222578911	99.89	100.35	99.97	I70S	20020225	20020312
00006	222578912	100.1	100.32	100.05	I70S	20020225	20020312
00006	222578913	99.86	99.36	99.94	I70S	20020225	20020312
00006	222578914	100.04	100.66	100.04	I70S	20020225	20020312
00006	222578915	100	100.06	99.89	I70S	20020225	20020312

KY CTESTS for 2002

00006	222578916	100	100.26	99.97	170S	20020225	20020312
00006	222578917	99.96	99.64	100.1	170S	20020225	20020312
00006	222578918	99.96	99.64	99.98	170S	20020225	20020312
00006	222578919	100.04	99.97	100.03	170S	20020225	20020312
00006	222578920	100.01	100.66	100.12	170S	20020225	20020312
00006	222578921	99.98	99.78	99.97	170S	20020225	20020312
00006	222578922	99.99	99.94	100.02	170S	20020225	20020312
00006	222578923	99.93	100.09	99.97	170S	20020225	20020312
00006	222578924	99.95	99.81	99.93	170S	20020225	20020312
00006	222578925	100.04	99.95	99.99	170S	20020225	20020312
00006	222578926	99.99	100.16	99.97	170S	20020225	20020312
00006	222578927	100.02	100.26	100.12	170S	20020225	20020312
00006	222578928	100	100.52	100.06	170S	20020225	20020312
00006	222578929	99.97	100.68	100.07	170S	20020225	20020312
00006	222578931	99.99	100.11	100.06	170S	20020225	20020312
00006	222578932	100.03	100.39	99.9	170S	20020225	20020312
00006	222578933	99.89	99.98	99.9	170S	20020225	20020312
00006	222578934	100.05	100.21	99.98	170S	20020225	20020312
00006	222578935	100.04	100.11	100.12	170S	20020225	20020312
00006	222578936	100.03	99.96	100.12	170S	20020225	20020312
00006	222578937	100.05	99.81	100.09	170S	20020225	20020312
00006	222578938	100.06	99.87	100.05	170S	20020225	20020312
00006	222578940	99.96	100.3	100.09	170S	20020225	20020312
00006	222578941	100.01	100.41	100.08	170S	20020225	20020312
00006	222578943	100.03	100.36	100.06	170S	20020225	20020312
00006	222578944	100.02	100.13	99.88	170S	20020225	20020312
00006	222578945	99.98	100.06	100.07	170S	20020225	20020312
00006	222578946	99.99	100.3	100.02	170S	20020225	20020312
00006	222578947	99.96	99.88	99.86	170S	20020225	20020312
00006	222578948	99.93	100.04	100.01	170S	20020225	20020312
00006	222578949	100	100	99.94	170S	20020225	20020312
00006	222578950	100.06	100.24	99.88	170S	20020225	20020312
00006	222578951	100	100.05	100.04	170S	20020225	20020312
00006	222578952	100.1	100.17	100.04	170S	20020225	20020312
00006	222578953	100.13	99.97	100.08	170S	20020225	20020312
00006	222578954	100.06	100.23	100.14	170S	20020225	20020312
00006	222578955	99.96	100.02	99.88	170S	20020225	20020312
00006	222578956	100.01	100.11	99.94	170S	20020225	20020312
00006	222578957	100.09	99.99	100.09	170S	20020225	20020312
00006	222578958	100.03	100.08	99.96	170S	20020225	20020312
00006	222578960	100.08	100	100.06	170S	20020225	20020312
00006	222578961	99.92	100.35	100	170S	20020225	20020312
00006	222578962	100.01	100.66	100.12	170S	20020225	20020312
00006	222578963	99.99	100.35	100.07	170S	20020225	20020312
00006	222578964	99.93	100.05	99.88	170S	20020225	20020312
00006	222578965	100.07	100.47	99.93	170S	20020225	20020312
00006	222578966	100.11	100.52	100.08	170S	20020225	20020312
00006	222578967	99.96	100.28	100.05	170S	20020225	20020312
00006	222578968	99.97	99.96	100.07	170S	20020225	20020312
00006	222578969	99.98	100.23	99.86	170S	20020225	20020312
00006	222578970	100.08	100.56	99.93	170S	20020225	20020312
00006	222578972	99.98	100.44	99.91	170S	20020225	20020312
00006	222578973	100	99.56	99.87	170S	20020225	20020312
00006	222578974	99.92	100.23	100.1	170S	20020225	20020312
00006	222578AX	99.86	99.85	99.87	170S	20020225	20020312
00006	222578I70S	100.02	100.42	100.02	170S	20020225	20020312
00006	222578KVS	100.05	99.8	99.94	170S	20020225	20020312
00006	222579071	99.97	100.36	99.98	170S	20020225	20020312
00006	222579072	99.86	100.25	100.02	170S	20020225	20020312
00006	222579073	100.08	100.13	100.05	170S	20020225	20020312
00006	222579074	100.01	99.89	100.07	170S	20020225	20020312

KY CTESTS for 2002

00006	222579075	99.92	100.16	100.14	I70S	20020225	20020312
00006	222579076	99.95	99.64	99.86	I70S	20020225	20020312
00006	222579077	100.05	100.03	100.1	I70S	20020225	20020312
00006	222579078	99.96	100.05	100.12	I70S	20020225	20020312
00006	222579079	99.92	99.91	100.01	I70S	20020225	20020312
00006	222579080	99.99	100.32	99.97	I70S	20020225	20020312
00006	222579081	99.98	99.73	100.06	I70S	20020225	20020312
00006	222579082	100.09	100.47	100.02	I70S	20020225	20020312
00006	222579083	100.09	100.08	100.06	I70S	20020225	20020312
00006	222579084	99.97	100.15	100.02	I70S	20020225	20020312
00006	222579085	100.01	99.81	99.96	I70S	20020225	20020312
00006	222579087	100	99.52	100.12	I70S	20020225	20020312
00006	222579088	100.09	99.79	99.97	I70S	20020225	20020312
00006	222579089	99.87	100.03	99.92	I70S	20020225	20020312
00006	222579090	99.97	99.38	100.01	I70S	20020225	20020312
00006	222579091	99.93	100.19	99.87	I70S	20020225	20020312
00006	222579092	100.01	99.83	99.94	I70S	20020225	20020312
00006	222579093	100.04	100.15	100.1	I70S	20020225	20020312
00006	222579094	99.96	100.05	99.88	I70S	20020225	20020312
00006	222579095	99.87	99.31	99.89	I70S	20020225	20020312
00006	222579096	99.95	100.13	99.9	I70S	20020225	20020312
00006	222579097	100	99.93	100.09	I70S	20020225	20020312
00006	222579098	100.1	99.95	100.04	I70S	20020225	20020312
00006	222579099	100.08	99.69	100.11	I70S	20020225	20020312
00006	222579100	100.02	100.17	100.09	I70S	20020225	20020312
00006	222579101	99.88	100.2	99.9	I70S	20020225	20020312
00006	222579102	99.9	99.79	99.93	I70S	20020225	20020312
00006	222579103	100	100.19	99.99	I70S	20020225	20020312
00006	222579104	99.96	100.05	99.88	I70S	20020225	20020312
00006	222579106	99.93	100.1	100.01	I70S	20020225	20020312
00006	222579107	100.1	99.62	99.88	I70S	20020225	20020312
00006	222579108	100.13	100.31	99.86	I70S	20020225	20020312
00006	222579109	100	100.55	100.01	I70S	20020225	20020312
00006	222579110	100.05	100.09	100.1	I70S	20020225	20020312
00006	222579111	100.01	100.23	100.05	I70S	20020225	20020312
00006	222579112	99.92	100.19	99.94	I70S	20020225	20020312
00006	222579113	100.11	100.06	100	I70S	20020225	20020312
00006	222579114	100.02	100.48	100.12	I70S	20020225	20020312
00006	222579115	100	99.84	99.96	I70S	20020225	20020312
00006	222579116	99.86	100.4	99.92	I70S	20020225	20020312
00006	222579117	100.05	100.09	100.1	I70S	20020225	20020312
00006	222579118	99.91	100.27	99.98	I70S	20020225	20020312
00006	222579119	100.03	100.49	99.96	I70S	20020225	20020312
00006	222579120	100.06	100.32	100.13	I70S	20020225	20020312
00006	222579121	99.99	100.12	100.13	I70S	20020225	20020312
00006	222579122	99.93	100.02	100.11	I70S	20020225	20020312
00006	222579123	100.03	99.87	100.06	I70S	20020225	20020312
00006	222579124	100.05	100.26	100	I70S	20020225	20020312
00006	222579125	99.89	99.57	99.95	I70S	20020225	20020312
00006	222579127	99.89	99.82	99.98	I70S	20020225	20020312
00006	222579128	100.01	99.59	99.98	I70S	20020225	20020312
00006	222579129	100.04	100.41	99.87	I70S	20020225	20020312
00006	222579130	100.13	100.43	100	I70S	20020225	20020312
00006	222579131	100.03	100.23	100.03	I70S	20020225	20020312
00006	222579132	100.03	100.23	100.03	I70S	20020225	20020312
00006	222579133	99.92	100.29	100.14	I70S	20020225	20020312
00006	222579134	100.1	100.23	99.96	I70S	20020225	20020312
00006	222579135	100.11	100.12	100.1	I70S	20020225	20020312
00006	222579136	100	99.7	99.96	I70S	20020225	20020312
00006	222579137	100.09	100.2	100	I70S	20020225	20020312
00006	222579138	99.9	100.26	100.08	I70S	20020225	20020312

KY CTESTS for 2002

00006	222579139	100.03	99.8	99.99	I70S	20020225	20020312
00006	222579140	100.14	100.26	100.02	I70S	20020225	20020312
00006	222579141	100.02	100.21	100.13	I70S	20020225	20020312
00006	222579142	99.94	99.95	99.88	I70S	20020225	20020312
00006	222579143	100	100.34	99.98	I70S	20020225	20020312
00006	222579144	99.95	100.13	99.9	I70S	20020225	20020312
00006	222579145	99.91	100.43	100.13	I70S	20020225	20020312
00006	222579146	99.97	100.25	99.92	I70S	20020225	20020312
00006	222579147	100.02	100.51	100.01	I70S	20020225	20020312
00006	222579148	99.98	100.4	99.88	I70S	20020225	20020312
00006	222579149	99.96	99.62	99.95	I70S	20020225	20020312
00006	222579150	100.07	100.22	99.97	I70S	20020225	20020312
00006	222579151	100.02	100.42	100.06	I70S	20020225	20020312
00006	222579152	99.92	99.79	99.92	I70S	20020225	20020312
00006	222579153	100.03	99.81	99.89	I70S	20020225	20020312
00006	222579154	100.01	100.15	100.01	I70S	20020225	20020312
00006	222579155	99.93	99.96	99.93	I70S	20020225	20020312
00006	222579156	99.92	99.79	99.92	I70S	20020225	20020312
00006	222579157	100.08	99.69	100.11	I70S	20020225	20020312
00006	222579158	99.95	99.64	99.86	I70S	20020225	20020312
00006	222579159	100.07	100.22	99.97	I70S	20020225	20020312
00006	222579160	99.97	100.11	100.09	I70S	20020225	20020312
00006	222579161	100.08	100.45	99.9	I70S	20020225	20020312
00006	222579162	100.08	99.96	100.02	I70S	20020225	20020312
00006	222579163	99.97	99.41	99.97	I70S	20020225	20020312
00006	222579164	100.1	100.03	100	I70S	20020225	20020312
00006	222579165	100	100	99.92	I70S	20020225	20020312
00006	222579166	99.86	99.94	99.96	I70S	20020225	20020312
00006	222579263	100.05	99.95	100.09	I70S	20020225	20020312
00006	222579266	100.02	100.21	100.13	I70S	20020225	20020312
00006	222579267	100.01	100.38	100.03	I70S	20020225	20020312
00006	222579268	100.12	100.1	100.06	I70S	20020225	20020312
00006	222579269	99.92	100	99.97	I70S	20020225	20020312
00006	222579270	99.96	100.13	100.07	I70S	20020225	20020312
00006	222579272	100.09	99.95	100.13	I70S	20020225	20020312
00006	222579275	99.88	100.24	100.08	I70S	20020225	20020312
00006	222579276	100.09	100.63	100.13	I70S	20020225	20020312
00006	222579277	100.02	100.18	100.07	I70S	20020225	20020312
00006	222579279	100.02	100.12	99.97	I70S	20020225	20020312
00006	222579280	100.01	100.3	99.93	I70S	20020225	20020312
00006	222579281	100.07	99.86	100.11	I70S	20020225	20020312
00006	222579282	100	100.1	100.1	I70S	20020225	20020312
00006	222579283	100	100.31	99.87	I70S	20020225	20020312
00006	222579285	100.05	99.81	99.95	I70S	20020225	20020312
00006	222579286	99.94	99.63	100.04	I70S	20020225	20020312
00006	222579288	100.02	100.13	100.11	I70S	20020225	20020312
00006	222579289	99.95	99.86	100.03	I70S	20020225	20020312
00006	222579291	100.01	100.29	99.93	I70S	20020225	20020312
00006	222579293	100.1	100.07	99.9	I70S	20020225	20020312
00006	222579294	100.03	99.89	100.04	I70S	20020225	20020312
00006	222579295	99.97	100.58	100.01	I70S	20020225	20020312
00006	222579296	100	99.77	100.03	I70S	20020225	20020312
00006	222579297	100.09	100.27	100.05	I70S	20020225	20020312
00006	222579298	99.91	100.25	100.08	I70S	20020225	20020312
00006	222579306	99.99	100.37	99.88	I70S	20020225	20020312
00006	222579308	100.02	100.13	100.08	I70S	20020225	20020312
00006	222579312	100	100.13	99.92	I70S	20020225	20020312
00006	222579313	100.11	100.06	100.03	I70S	20020225	20020312
00006	222579314	99.95	100	100.01	I70S	20020225	20020312
00006	222579316	100.05	99.76	100.07	I70S	20020225	20020312
00006	222579317	99.89	100.08	99.9	I70S	20020225	20020312

KY CTESTS for 2002

00006	222579318	99.97	100	99.97	I70S	20020225	20020312
00006	222579320	99.86	100.15	100.05	I70S	20020225	20020312
00006	222579321	100	100.42	99.94	I70S	20020225	20020312
00006	222579322	99.96	100.44	100.05	I70S	20020225	20020312
00006	222579323	99.92	99.94	100.12	I70S	20020225	20020312
00006	222579325	100.03	99.8	100.1	I70S	20020225	20020312
00006	222579326	100	100.49	99.96	I70S	20020225	20020312
00006	222579335	99.94	100.49	99.89	I70S	20020225	20020312
00006	222579336	100	100.38	99.96	I70S	20020225	20020312
00006	222579337	100.03	100.14	100.13	I70S	20020225	20020312
00006	222579340	100.02	100.21	100.13	I70S	20020225	20020312
00006	222579341	99.95	99.94	100.07	I70S	20020225	20020312
00006	222579342	100.05	99.98	99.94	I70S	20020225	20020312
00006	222579343	99.88	99.9	99.98	I70S	20020225	20020312
00006	222579346	100	100.25	99.98	I70S	20020225	20020312
00006	222579350	99.98	100.33	100.13	I70S	20020225	20020312
00006	222579352	100.03	100.08	100.05	I70S	20020225	20020312
00006	222579355	99.98	100.31	100.08	I70S	20020225	20020312
00006	222579356	99.97	100.1	100.01	I70S	20020225	20020312
00006	222579839	100.05	100.69	99.97	I70S	20020226	20020312
00006	222579840	100.04	100.42	99.94	I70S	20020226	20020312
00006	222579841	100.03	99.92	99.96	I70S	20020226	20020312
00006	222579842	100.03	100.41	100.12	I70S	20020226	20020312
00006	222579843	99.95	99.92	100.13	I70S	20020226	20020312
00006	222579844	100.09	100.59	100.04	I70S	20020226	20020312
00006	222579845	99.95	99.61	99.93	I70S	20020226	20020312
00006	222579846	100.07	100.41	100.11	I70S	20020226	20020312
00006	222579847	99.96	100.03	100.1	I70S	20020226	20020312
00006	222579848	99.96	99.78	99.9	I70S	20020226	20020312
00006	222579849	100.07	100.2	100.01	I70S	20020226	20020312
00006	222579850	99.98	99.92	99.88	I70S	20020226	20020312
00006	222579851	100.12	100.21	100.06	I70S	20020226	20020312
00006	222579852	100.1	100.02	100.14	I70S	20020226	20020312
00006	222579853	100.04	100.56	100.05	I70S	20020226	20020312
00006	222579854	99.92	99.82	99.86	I70S	20020226	20020312
00006	222579855	100.14	100.04	99.86	I70S	20020226	20020312
00006	222579856	99.89	99.73	99.89	I70S	20020226	20020312
00006	222579857	100.05	100.01	99.94	I70S	20020226	20020312
00006	222579858	99.94	99.33	99.87	I70S	20020226	20020312
00006	222579859	99.94	100.29	100.11	I70S	20020226	20020312
00006	222579860	100.09	100.59	100.04	I70S	20020226	20020312
00006	222579861	100	100.21	99.98	I70S	20020226	20020312
00006	222579862	100.01	100.02	100.01	I70S	20020226	20020312
00006	222579863	99.95	100.51	100.03	I70S	20020226	20020312
00006	222579864	100.03	100.42	100.09	I70S	20020226	20020312
00006	222579865	100	100.12	100.11	I70S	20020226	20020312
00006	222579866	99.89	100.27	99.9	I70S	20020226	20020312
00006	222579867	99.86	100.12	99.9	I70S	20020226	20020312
00006	222579868	99.94	100.35	99.91	I70S	20020226	20020312
00006	222579869	99.86	100.23	100.01	I70S	20020226	20020312
00006	222579870	100.04	99.79	100.12	I70S	20020226	20020312
00006	222579871	99.96	99.96	100.03	I70S	20020226	20020312
00006	222579872	99.9	99.63	99.95	I70S	20020226	20020312
00006	222579873	100.05	100.69	99.97	I70S	20020226	20020312
00006	222579874	99.99	99.92	99.87	I70S	20020226	20020312
00006	222579876	99.98	100.41	99.96	I70S	20020226	20020312
00006	222579877	99.97	100	99.88	I70S	20020226	20020312
00006	222579878	100.03	100.18	99.95	I70S	20020226	20020312
00006	222579879	100	99.95	99.96	I70S	20020226	20020312
00006	222579880	100.04	99.73	99.92	I70S	20020226	20020312
00006	222579881	100.08	100.07	99.94	I70S	20020226	20020312

KY CTESTS for 2002

00006	222579882	100	99.83	100.13	I70S	20020226	20020312
00006	222579883	100.03	100.57	100	I70S	20020226	20020312
00006	222579884	100.03	100.45	100.1	I70S	20020226	20020312
00006	222579885	99.96	100.22	100.04	I70S	20020226	20020312
00006	222579886	100.08	100.34	100.1	I70S	20020226	20020312
00006	222579887	99.99	100.44	99.87	I70S	20020226	20020312
00006	222579888	100.08	100.17	100.06	I70S	20020226	20020312
00006	222579890	99.96	99.84	99.91	I70S	20020226	20020312
00006	222579891	100.01	100.41	99.95	I70S	20020226	20020312
00006	222579892	99.9	100.32	100.03	I70S	20020226	20020312
00006	222579893	100.11	100.47	100.02	I70S	20020226	20020312
00006	222579894	99.99	100.22	99.88	I70S	20020226	20020312
00006	222579895	100	100.11	100.05	I70S	20020226	20020312
00006	222579896	100.12	99.83	100.02	I70S	20020226	20020312
00006	222579897	99.98	100.27	99.92	I70S	20020226	20020312
00006	222579898	100.01	100.11	100.08	I70S	20020226	20020312
00006	222579899	100.05	100.16	99.93	I70S	20020226	20020312
00006	222579900	100	100.69	100.07	I70S	20020226	20020312
00006	222579901	99.98	100.38	99.87	I70S	20020226	20020312
00006	222579902	99.88	100.02	99.98	I70S	20020226	20020312
00006	222579903	100.01	100	100.08	I70S	20020226	20020312
00006	222579904	100	99.57	100.04	I70S	20020226	20020312
00006	222579905	100.02	100.38	100.08	I70S	20020226	20020312
00006	222579906	100.14	100.68	100.13	I70S	20020226	20020312
00006	222579908	100.03	100.45	99.9	I70S	20020226	20020312
00006	222579909	99.96	100.27	100.02	I70S	20020226	20020312
00006	222579910	100.02	100.45	100.08	I70S	20020226	20020312
00006	222579911	100.09	100.43	99.86	I70S	20020226	20020312
00006	222579912	99.97	100.16	100.07	I70S	20020226	20020312
00006	222579913	100.06	100.19	100.03	I70S	20020226	20020312
00006	222579914	100.04	100.42	99.94	I70S	20020226	20020312
00006	222579916	100.02	100.14	100.07	I70S	20020226	20020312
00006	222579917	100.06	100.37	100	I70S	20020226	20020312
00006	222579918	99.98	100.1	100	I70S	20020226	20020312
00006	222579919	100.07	100.31	99.9	I70S	20020226	20020312
00006	222579920	99.91	99.44	99.92	I70S	20020226	20020312
00006	222579921	100.14	100.52	100	I70S	20020226	20020312
00006	222579922	99.95	100.28	100.09	I70S	20020226	20020312
00006	222579923	100.01	100.52	100.04	I70S	20020226	20020312
00006	222579924	100.04	99.83	99.99	I70S	20020226	20020312
00006	222579925	100.08	100.15	100.1	I70S	20020226	20020312
00006	222579927	99.95	100.5	99.86	I70S	20020226	20020312
00006	222579928	99.9	100.37	99.89	I70S	20020226	20020312
00006	222579929	100.07	100.52	100.07	I70S	20020226	20020312
00006	222579930	100.06	100.19	100.07	I70S	20020226	20020312
00006	222579931	100.04	99.96	100.09	I70S	20020226	20020312
00006	222579932	100	100.62	99.86	I70S	20020226	20020312
00006	222579933	100.09	100.68	99.87	I70S	20020226	20020312
00006	222579934	99.98	100.69	99.89	I70S	20020226	20020312
00006	222579KVS	99.92	100.13	99.93	I70S	20020225	20020312
00006	222628659	100.05	99.92	100.06	I70S	20020314	20020328
00006	222628660	99.93	99.59	100.04	I70S	20020314	20020328
00006	222628661	100.03	100.21	99.88	I70S	20020314	20020328
00006	222628662	100.13	99.51	99.99	I70S	20020314	20020328
00006	222628663	100.01	99.55	99.92	I70S	20020314	20020328
00006	222628664	99.86	100.12	100.1	I70S	20020314	20020328
00006	222628665	99.94	100.64	99.95	I70S	20020314	20020328
00006	222628666	99.99	100.2	100.03	I70S	20020314	20020328
00006	222628667	100.13	100.19	100.11	I70S	20020314	20020328
00006	222628669	99.87	100.13	99.96	I70S	20020314	20020328
00006	222628670	100.03	100.16	100.04	I70S	20020314	20020328

KY CTESTS for 2002

00006	222628671	100.01	100.02	99.96	I70S	20020314	20020328
00006	222628672	99.95	100.23	99.95	I70S	20020314	20020328
00006	222628673	100.12	100.08	100.12	I70S	20020314	20020328
00006	222628674	100.07	100.29	100.04	I70S	20020314	20020328
00006	222628675	100.1	100.12	100.08	I70S	20020314	20020328
00006	222628676	99.93	99.94	99.9	I70S	20020314	20020328
00006	222628677	100	100.2	99.96	I70S	20020314	20020328
00006	222628678	99.87	100.08	99.91	I70S	20020314	20020328
00006	222628679	99.93	100.17	100.01	I70S	20020314	20020328
00006	222628680	100.09	100.01	100.08	I70S	20020314	20020328
00006	222628682	99.93	99.87	99.98	I70S	20020314	20020328
00006	222628683	99.98	100.28	100.03	I70S	20020314	20020328
00006	222628684	100.07	99.99	100.14	I70S	20020314	20020328
00006	222628685	100.11	100.09	99.93	I70S	20020314	20020328
00006	222628686	100.02	100.33	100.1	I70S	20020314	20020328
00006	222628687	99.94	100.25	99.9	I70S	20020314	20020328
00006	222628688	99.94	100.14	99.95	I70S	20020314	20020328
00006	222628689	100.04	100.01	100.08	I70S	20020314	20020328
00006	222628690	99.89	100.01	99.86	I70S	20020314	20020328
00006	222628691	99.97	100.04	100.06	I70S	20020314	20020328
00006	222628692	99.95	99.85	99.86	I70S	20020314	20020328
00006	222628693	99.93	100.51	99.86	I70S	20020314	20020328
00006	222628694	100.03	100.12	100.12	I70S	20020314	20020328
00006	222628695	100.01	99.74	99.97	I70S	20020314	20020328
00006	222628696	100.05	99.97	99.87	I70S	20020314	20020328
00006	222628697	99.97	99.73	100.02	I70S	20020314	20020328
00006	222628698	100.04	99.62	99.99	I70S	20020314	20020328
00006	222628699	100.1	100.55	100.08	I70S	20020314	20020328
00006	222628700	99.95	99.81	100.07	I70S	20020314	20020328
00006	222628701	100.04	100.32	100.14	I70S	20020314	20020328
00006	222628702	100	100.15	99.91	I70S	20020314	20020328
00006	222628703	100.03	100.29	100.09	I70S	20020314	20020328
00006	222628704	100.02	100.41	99.94	I70S	20020314	20020328
00006	222628705	100.12	100.25	100.05	I70S	20020314	20020328
00006	222628707	100.01	100.66	100.05	I70S	20020314	20020328
00006	222628708	100.02	100.01	100.04	I70S	20020314	20020328
00006	222628709	99.94	99.38	99.97	I70S	20020314	20020328
00006	222628710	100	99.75	99.94	I70S	20020314	20020328
00006	222628711	100	100.4	99.94	I70S	20020314	20020328
00006	222628712	99.99	99.93	99.86	I70S	20020314	20020328
00006	222628713	99.97	100.62	100.07	I70S	20020314	20020328
00006	222628714	99.99	99.91	99.95	I70S	20020314	20020328
00006	222628715	100.07	99.58	100.04	I70S	20020314	20020328
00006	222628716	100.1	100.47	99.97	I70S	20020314	20020328
00006	222628717	100.14	99.88	100	I70S	20020314	20020328
00006	222628718	100.02	100.13	99.9	I70S	20020314	20020328
00006	222628719	100.04	100.45	99.92	I70S	20020314	20020328
00006	222628720	99.99	100.14	99.87	I70S	20020314	20020328
00006	222628721	99.95	99.77	100.12	I70S	20020314	20020328
00006	222628722	100.05	99.78	99.98	I70S	20020314	20020328
00006	222628724	100.02	99.78	100.08	I70S	20020314	20020328
00006	222628725	99.99	100.53	100.05	I70S	20020314	20020328
00006	222628726	100.1	100.13	100.07	I70S	20020314	20020328
00006	222628727	100.05	100	99.88	I70S	20020314	20020328
00006	222628728	99.99	99.63	100.12	I70S	20020314	20020328
00006	222628729	99.96	100.26	100	I70S	20020314	20020328
00006	222628731	100.03	100.22	100.01	I70S	20020314	20020328
00006	222628732	99.97	99.69	100.05	I70S	20020314	20020328
00006	222628733	99.9	100.01	100.11	I70S	20020314	20020328
00006	222628734	99.94	100.1	99.92	I70S	20020314	20020328
00006	222628735	99.89	100.1	100.14	I70S	20020314	20020328

KY CTESTS for 2002

00006	222628736	100.04	99.5	100.06	I70S	20020314	20020328
00006	222628737	100.13	100.35	99.96	I70S	20020314	20020328
00006	222628738	99.99	99.83	99.94	I70S	20020314	20020328
00006	222628739	100	99.73	100.09	I70S	20020314	20020328
00006	222628740	100.06	100.03	99.88	I70S	20020314	20020328
00006	222628741	99.95	100.06	100.05	I70S	20020314	20020328
00006	222628742	99.97	99.96	100.08	I70S	20020314	20020328
00006	222628743	100	99.79	99.89	I70S	20020314	20020328
00006	222628744	100	99.66	99.95	I70S	20020314	20020328
00006	222628745	100	99.84	99.95	I70S	20020314	20020328
00006	222628746	99.99	100.06	99.91	I70S	20020314	20020328
00006	222628747	100.08	100.38	100.06	I70S	20020314	20020328
00006	222628749	99.96	99.59	99.94	I70S	20020314	20020328
00006	222628750	99.86	99.87	99.86	I70S	20020314	20020328
00006	222628751	100.04	100.23	99.92	I70S	20020314	20020328
00006	222628752	99.97	99.94	99.97	I70S	20020314	20020328
00006	222628753	99.98	100.4	99.88	I70S	20020314	20020328
00006	222628754	100.02	100.06	100.01	I70S	20020314	20020328
00006	222628755	99.97	100.35	100.05	I70S	20020314	20020328
00006	222628756	100.01	99.51	100.01	I70S	20020314	20020328
00006	222628757	100.08	99.76	99.88	I70S	20020314	20020328
00006	222628758	99.99	99.82	100	I70S	20020314	20020328
00006	222628759	100.11	100.05	100.14	I70S	20020314	20020328
00006	222628760	100.04	99.77	100.12	I70S	20020314	20020328
00006	222628761	100	100.35	100.01	I70S	20020314	20020328
00006	222628762	99.93	100.12	100.06	I70S	20020314	20020328
00006	222628763	99.98	100.09	100.08	I70S	20020314	20020328
00006	222628764	99.99	100.14	99.99	I70S	20020314	20020328
00006	222628765	100.01	99.99	99.95	I70S	20020314	20020328
00006	222628766	99.97	99.74	99.92	I70S	20020314	20020328
00006	222628767	100.07	99.89	100.08	I70S	20020314	20020328
00006	222628768	100	99.83	100.13	I70S	20020314	20020328
00006	222628769	99.87	99.53	99.99	I70S	20020314	20020328
00006	222628770	100.08	99.47	99.87	I70S	20020314	20020328
00006	222628771	100.01	100.14	100.03	I70S	20020314	20020328
00006	222628772	99.97	99.56	100.03	I70S	20020314	20020328
00006	222628773	100.08	100.09	100.11	I70S	20020314	20020328
00006	222628774	99.99	99.74	100.01	I70S	20020314	20020328
00006	222628775	100.06	99.7	99.9	I70S	20020314	20020328
00006	222628776	99.99	99.8	100.04	I70S	20020314	20020328
00006	222628777	99.97	99.99	99.91	I70S	20020314	20020328
00006	222628778	100.06	99.87	99.93	I70S	20020314	20020328
00006	222628779	99.92	99.85	99.89	I70S	20020314	20020328
00006	222628780	99.9	99.62	99.91	I70S	20020314	20020328
00006	222628781	100.02	99.98	100.09	I70S	20020314	20020328
00006	222628782	99.98	100.02	100.06	I70S	20020314	20020328
00006	222628783	100.06	99.63	100.01	I70S	20020314	20020328
00006	222628784	99.93	99.99	99.89	I70S	20020314	20020328
00006	222628785	99.97	99.89	100	I70S	20020314	20020328
00006	222628786	100.05	100.08	100.11	I70S	20020314	20020328
00006	222628787	100.02	100.05	99.97	I70S	20020314	20020328
00006	222628788	99.98	99.82	99.96	I70S	20020314	20020328
00006	222628789	100.04	100.03	99.92	I70S	20020314	20020328
00006	222628790	100.09	99.93	100.1	I70S	20020314	20020328
00006	222628791	100.07	100.14	100.12	I70S	20020314	20020328
00006	222628792	100.02	99.95	99.92	I70S	20020314	20020328
00006	222628793	99.96	99.7	99.93	I70S	20020314	20020328
00006	222628794	100.12	100.49	100.02	I70S	20020314	20020328
00006	222628795	100.03	100.37	99.96	I70S	20020314	20020328
00006	222628796	99.97	100.25	99.97	I70S	20020314	20020328
00006	222628797	99.97	100.05	99.9	I70S	20020314	20020328

KY CTESTS for 2002

00006	222628798	100	100	99.93	170S	20020314	20020328
00006	222628799	100.09	99.86	100.05	170S	20020314	20020328
00006	222628800	99.94	100.18	100.03	170S	20020314	20020328
00006	222628801	99.98	99.9	100.08	170S	20020314	20020328
00006	222628802	99.89	99.83	99.94	170S	20020314	20020328
00006	222628851	100.03	100.18	99.95	170S	20020314	20020328
00006	222628852	99.89	100.13	100.03	170S	20020314	20020328
00006	222628853	100.04	99.85	99.99	170S	20020314	20020328
00006	222628854	99.89	99.79	99.93	170S	20020314	20020328
00006	222628855	100.12	99.87	100.01	170S	20020314	20020328
00006	222628856	99.86	100.06	99.92	170S	20020314	20020328
00006	222628857	100	99.98	99.98	170S	20020314	20020328
00006	222628858	99.99	99.84	99.87	170S	20020314	20020328
00006	222628859	100.1	100.32	100.11	170S	20020314	20020328
00006	222628860	100.12	100.34	99.99	170S	20020314	20020328
00006	222628861	99.9	99.47	99.99	170S	20020314	20020328
00006	222628862	100	100.12	99.89	170S	20020314	20020328
00006	222628863	100.06	99.37	100.08	170S	20020314	20020328
00006	222628864	99.88	99.73	99.93	170S	20020314	20020328
00006	222628865	100.02	100.16	100.11	170S	20020314	20020328
00006	222628866	100.01	100.23	99.88	170S	20020314	20020328
00006	222628867	100.1	100.32	100.09	170S	20020314	20020328
00006	222628868	100.07	99.55	99.95	170S	20020314	20020328
00006	222628869	99.87	99.85	99.95	170S	20020314	20020328
00006	222628870	99.92	99.86	100.03	170S	20020314	20020328
00006	222628871	100.01	99.77	99.97	170S	20020314	20020328
00006	222628872	100.03	99.58	100.07	170S	20020314	20020328
00006	222628873	99.98	100.05	99.92	170S	20020314	20020328
00006	222628874	100.04	100.46	100.08	170S	20020314	20020328
00006	222628875	100.07	100.28	100.1	170S	20020314	20020328
00006	222628876	99.96	99.88	100.04	170S	20020314	20020328
00006	222628877	100.06	100.17	99.91	170S	20020314	20020328
00006	222628878	100.02	99.92	100.07	170S	20020314	20020328
00006	222628879	100.04	99.99	100.09	170S	20020314	20020328
00006	222628880	100.02	99.88	100.06	170S	20020314	20020328
00006	222628881	100	100.17	99.97	170S	20020314	20020328
00006	222628882	100	100.28	100.06	170S	20020314	20020328
00006	222628883	99.98	100.22	100	170S	20020314	20020328
00006	222628884	100.06	99.82	100	170S	20020314	20020328
00006	222628885	100	100.18	99.95	170S	20020314	20020328
00006	222628886	100.04	100.16	100.03	170S	20020314	20020328
00006	222628887	100.02	100.26	100.07	170S	20020314	20020328
00006	222628888	100.1	100.53	100.11	170S	20020314	20020328
00006	222628889	99.91	100.22	100.11	170S	20020314	20020328
00006	222628890	99.99	99.88	100.13	170S	20020314	20020328
00006	222628891	99.91	100.15	99.92	170S	20020314	20020328
00006	222628892	99.98	99.67	99.87	170S	20020314	20020328
00006	222628893	100	99.85	99.86	170S	20020314	20020328
00006	222628894	100.04	99.63	99.91	170S	20020314	20020328
00006	222628895	99.92	99.92	99.92	170S	20020314	20020328
00006	222628896	99.98	100.09	99.97	170S	20020314	20020328
00006	222628897	99.97	100.01	99.94	170S	20020314	20020328
00006	222628898	100.09	99.6	100.04	170S	20020314	20020328
00006	222628899	100.01	100.19	99.97	170S	20020314	20020328
00006	222628900	99.93	99.8	99.91	170S	20020314	20020328
00006	222628901	100.1	100.68	100.1	170S	20020314	20020328
00006	222628902	99.98	100.02	99.86	170S	20020314	20020328
00006	222628903	100.13	99.98	100.07	170S	20020314	20020328
00006	222628904	99.92	99.81	99.94	170S	20020314	20020328
00006	222628905	100.09	99.86	99.99	170S	20020314	20020328
00006	222628906	99.89	99.58	100.06	170S	20020314	20020328

KY CTESTS for 2002

00006	222628907	99.89	99.86	99.87	I70S	20020314	20020328
00006	222628908	99.95	99.65	99.99	I70S	20020314	20020328
00006	222628909	100.08	100.11	100.1	I70S	20020314	20020328
00006	222628910	99.96	99.74	99.86	I70S	20020314	20020328
00006	222628912	100.02	100.08	99.88	I70S	20020314	20020328
00006	222628913	100.02	99.99	100.04	I70S	20020314	20020328
00006	222628917	100	100.07	100.04	I70S	20020314	20020328
00006	222628918	99.98	100.27	100.01	I70S	20020314	20020328
00006	222628919	100.12	99.71	100.14	I70S	20020314	20020328
00006	222628920	99.93	100.1	99.94	I70S	20020314	20020328
00006	222628921	100	100.11	99.9	I70S	20020314	20020328
00006	222628922	100	99.62	99.93	I70S	20020314	20020328
00006	222628923	100.02	99.57	99.87	I70S	20020314	20020328
00006	222628925	99.98	99.87	99.93	I70S	20020314	20020328
00006	222628927	100.03	100.53	100.06	I70S	20020314	20020328
00006	222628928	100.07	100.15	100.05	I70S	20020314	20020328
00006	222628929	99.92	99.74	99.86	I70S	20020314	20020328
00006	222628930	100.09	100.07	100.12	I70S	20020314	20020328
00006	222628931	100.08	99.94	99.9	I70S	20020314	20020328
00006	222628932	100	99.98	100	I70S	20020314	20020328
00006	222628933	99.99	99.6	99.92	I70S	20020314	20020328
00006	222628935	99.87	100.1	99.88	I70S	20020314	20020328
00006	222628936	100.07	100.15	99.93	I70S	20020314	20020328
00006	222628937	100.11	99.4	99.98	I70S	20020314	20020328
00006	222628938	100.1	100.57	100.07	I70S	20020314	20020328
00006	222628939	100.07	100.39	100.03	I70S	20020314	20020328
00006	222628940	100	100.09	99.91	I70S	20020314	20020328
00006	222628941	100.07	100.22	100.02	I70S	20020314	20020328
00006	222628942	100.03	100.05	99.99	I70S	20020314	20020328
00006	222628943	100.1	99.92	99.94	I70S	20020314	20020328
00006	222628944	99.97	99.79	100.06	I70S	20020314	20020328
00006	222628945	100.08	100.1	100.13	I70S	20020314	20020328
00006	222628946	99.98	100.23	100.1	I70S	20020314	20020328
00006	222628947	100.03	99.85	99.89	I70S	20020314	20020328
00006	222628949	100.05	99.47	99.91	I70S	20020314	20020328
00006	222628951	99.97	100.19	99.87	I70S	20020314	20020328
00006	222628952	99.96	99.92	99.92	I70S	20020314	20020328
00006	222628953	100	100.39	100.14	I70S	20020314	20020328
00006	222628954	99.92	99.79	100.04	I70S	20020314	20020328
00006	222628955	100.04	100.51	100.1	I70S	20020314	20020328
00006	222628956	100.12	100.27	100.1	I70S	20020314	20020328
00006	222628957	100.05	100.01	100.06	I70S	20020314	20020328
00006	222628958	99.92	99.88	99.98	I70S	20020314	20020328
00006	222628959	99.87	100.26	99.95	I70S	20020314	20020328
00006	222628960	99.9	99.8	100.05	I70S	20020314	20020328
00006	222628961	99.97	100.1	100.04	I70S	20020314	20020328
00006	222628962	100.02	99.87	100.05	I70S	20020314	20020328
00006	222628971	99.87	99.75	99.9	I70S	20020314	20020328
00006	222628973	99.93	100.04	100.08	I70S	20020314	20020328
00006	222628974	99.92	99.76	100.03	I70S	20020314	20020328
00006	222628975	99.88	99.48	100.07	I70S	20020314	20020328
00006	222628976	100.09	99.74	100.14	I70S	20020314	20020328
00006	222628977	100	99.98	100.03	I70S	20020314	20020328
00006	222628978	99.89	99.94	100.03	I70S	20020314	20020328
00006	222628979	99.97	99.61	99.9	I70S	20020314	20020328
00006	222628980	99.97	100.51	99.89	I70S	20020314	20020328
00006	222628981	99.93	99.5	99.87	I70S	20020314	20020328
00006	222628982	100.06	99.74	100	I70S	20020314	20020328
00006	222628985	100.08	100.52	99.97	I70S	20020314	20020328
00006	222628987	100.03	100.47	99.98	I70S	20020314	20020328
00006	222628988	99.99	99.54	99.96	I70S	20020314	20020328

KY CTESTS for 2002

00006	222628989	100.01	99.39	99.92	I70S	20020314	20020328
00006	222628990	99.92	100.62	99.94	I70S	20020314	20020328
00006	222628991	99.9	99.86	99.98	I70S	20020314	20020328
00006	222628992	100.02	99.56	100.07	I70S	20020314	20020328
00006	222628993	100.07	100.62	99.91	I70S	20020314	20020328
00006	222628994	99.89	100.15	99.89	I70S	20020314	20020328
00006	222628999	100.09	100.31	100.08	I70S	20020314	20020328
00006	222629000	99.95	99.65	99.98	I70S	20020314	20020328
00006	222629001	100.07	99.84	99.86	I70S	20020314	20020328
00006	222629002	99.91	100.02	99.88	I70S	20020314	20020328
00006	222629003	100	99.94	100.07	I70S	20020314	20020328
00006	222629004	100.04	99.7	100.09	I70S	20020314	20020328
00006	222629005	99.96	100.46	99.93	I70S	20020314	20020328
00006	222629006	99.96	99.52	100.1	I70S	20020314	20020328
00006	222629007	100.05	100.14	100.1	I70S	20020314	20020328
00006	222629008	100.06	100.34	99.98	I70S	20020314	20020328
00006	222629009	100.08	100.11	100.07	I70S	20020314	20020328
00006	222629019	100.07	100.11	100.06	I70S	20020314	20020328
00006	222629020	100.03	100.24	100.14	I70S	20020314	20020328
00006	222629021	99.97	99.92	100.13	I70S	20020314	20020328
00006	222629022	100.03	100.15	100.04	I70S	20020314	20020328
00006	222629023	99.94	100.45	100.03	I70S	20020314	20020328
00006	222629024	99.94	99.67	99.99	I70S	20020314	20020328
00006	222629025	99.86	99.73	99.98	I70S	20020314	20020328
00006	222629026	100	99.84	100.1	I70S	20020314	20020328
00006	222629027	100	100.13	99.91	I70S	20020314	20020328
00006	222629028	100.08	99.94	99.93	I70S	20020314	20020328
00006	222629029	100.13	100.06	99.92	I70S	20020314	20020328
00006	222629030	100.13	100.07	99.97	I70S	20020314	20020328
00006	222629031	100	100.2	99.87	I70S	20020314	20020328
00006	222629032	99.98	99.5	99.86	I70S	20020314	20020328
00006	222629033	100.11	99.99	99.9	I70S	20020314	20020328
00006	222629034	100.12	99.89	100.07	I70S	20020314	20020328
00006	222629035	100.01	100.19	99.92	I70S	20020314	20020328
00006	222629036	100.03	99.86	99.86	I70S	20020314	20020328
00006	222629037	99.87	99.7	99.94	I70S	20020314	20020328
00006	222629038	99.93	100.48	99.95	I70S	20020314	20020328
00006	222629039	100.14	99.38	100.07	I70S	20020314	20020328
00006	222629040	100.03	99.75	99.97	I70S	20020314	20020328
00006	222629041	100.03	100.04	100.13	I70S	20020314	20020328
00006	222629042	100.04	100.59	100.08	I70S	20020311	20020328
00006	222721100	99.91	99.66	99.91	I70S	20020403	20020524
00006	222721729	100.11	100.06	100.11	I70S	20020403	20020603
00006	222722595	100.05	99.5	99.89	I70S	20020321	20020605
00006	222722596	99.98	99.9	99.92	I70S	20020321	20020605
00006	222722597	100.09	100.36	100.07	I70S	20020321	20020605
00006	222722598	99.94	100.15	99.99	I70S	20020321	20020605
00006	222722600	100.01	99.77	100.09	I70S	20020321	20020605
00006	222722604	99.96	99.75	99.91	I70S	20020321	20020605
00006	222722605	99.9	99.92	99.94	I70S	20020321	20020605
00006	222722606	100.05	99.84	100.13	I70S	20020321	20020605
00006	222722607	99.96	99.72	99.97	I70S	20020321	20020605
00006	222722608	99.95	99.94	100.06	I70S	20020321	20020605
00006	222722611	100.02	100.11	100.09	I70S	20020321	20020605
00006	222722613	100.06	100.07	100.12	I70S	20020321	20020605
00006	222722614	100.06	100	100.03	I70S	20020321	20020605
00006	222722615	99.88	100.17	99.88	I70S	20020321	20020605
00006	222722616	99.94	99.39	99.9	I70S	20020321	20020605
00006	222722617	100.09	99.63	99.86	I70S	20020321	20020605
00006	222722618	100.04	100.01	100.1	I70S	20020321	20020605
00006	222722620	99.98	99.83	99.9	I70S	20020321	20020605

KY CTESTS for 2002

00006	222722627	99.91	99.97	99.94	I70S	20020321	20020605
00006	222722629	99.91	100.22	99.97	I70S	20020321	20020605
00006	222722631	100.01	100.36	99.95	I70S	20020321	20020605
00006	222722632	99.89	100.32	100.09	I70S	20020321	20020605
00006	222722633	99.87	99.92	99.89	I70S	20020321	20020605
00006	222722635	99.99	99.8	99.98	I70S	20020321	20020605
00006	222722636	99.9	100.49	100	I70S	20020321	20020605
00006	222722637	99.96	99.6	100.08	I70S	20020321	20020605
00006	222722638	100.05	99.99	100.04	I70S	20020321	20020605
00006	222722639	100.05	99.84	100.13	I70S	20020321	20020605
00006	222722640	99.94	100	100.06	I70S	20020321	20020605
00006	222722641	99.97	100.25	99.89	I70S	20020321	20020605
00006	222722642	100	100.02	100.09	I70S	20020321	20020605
00006	222722643	100	99.97	99.97	I70S	20020321	20020605
00006	222722645	99.98	99.79	100.07	I70S	20020321	20020605
00006	222722647	100.14	99.92	99.99	I70S	20020321	20020605
00006	222722648	99.99	99.89	99.93	I70S	20020321	20020605
00006	222722649	99.96	99.93	99.93	I70S	20020321	20020605
00006	222722651	99.9	100.08	99.96	I70S	20020321	20020605
00006	222722652	100	100.27	99.94	I70S	20020321	20020605
00006	222722653	99.95	100.16	99.91	I70S	20020321	20020605
00006	222722654	99.93	100.05	99.94	I70S	20020321	20020605
00006	222722655	99.97	99.76	99.99	I70S	20020321	20020605
00006	222722658	100.11	100.32	100.05	I70S	20020321	20020605
00006	222722663	100	99.93	99.98	I70S	20020321	20020605
00006	222722672	100.02	99.86	99.86	I70S	20020321	20020605
00006	222722674	100.03	100.09	100.01	I70S	20020321	20020605
00006	222722676	100.04	99.91	99.91	I70S	20020321	20020605
00006	222722677	99.89	99.95	100.01	I70S	20020321	20020605
00006	222722678	100.1	99.63	100.09	I70S	20020321	20020605
00006	222722680	100.03	100.33	99.9	I70S	20020321	20020605
00006	222722682	100.05	99.93	100.13	I70S	20020321	20020605
00006	222722689	100.01	99.86	100.14	I70S	20020321	20020605
00006	222723171	100.03	100.14	100.14	I70S	20020320	20020605
00006	222723172	100.11	100.57	100.09	I70S	20020320	20020605
00006	222723173	99.96	99.93	100.07	I70S	20020320	20020605
00006	222723174	100.02	100.11	99.88	I70S	20020320	20020605
00006	222723175	100.04	99.81	100.13	I70S	20020320	20020605
00006	222723176	99.96	99.61	100.03	I70S	20020320	20020605
00006	222723177	100.02	100.51	100.05	I70S	20020320	20020605
00006	222723178	100.03	100.44	100.12	I70S	20020320	20020605
00006	222723179	99.99	100.19	99.98	I70S	20020320	20020605
00006	222723180	99.91	100.04	99.96	I70S	20020320	20020605
00006	222723181	99.94	99.56	99.9	I70S	20020320	20020605
00006	222723182	100	99.73	99.99	I70S	20020320	20020605
00006	222723183	100.01	99.41	99.89	I70S	20020320	20020605
00006	222723184	99.99	100.2	100.05	I70S	20020320	20020605
00006	222723185	100.03	100.19	100.1	I70S	20020320	20020605
00006	222723186	100.04	100.1	100.03	I70S	20020320	20020605
00006	222723187	100.13	99.96	100.05	I70S	20020320	20020605
00006	222723188	99.98	100.14	99.87	I70S	20020320	20020605
00006	222723189	100.02	99.32	100	I70S	20020320	20020605
00006	222723190	99.88	99.63	100.06	I70S	20020320	20020605
00006	222723191	99.97	100.39	100.04	I70S	20020320	20020605
00006	222723192	100.07	100.26	100.13	I70S	20020320	20020605
00006	222723193	99.99	99.93	99.93	I70S	20020320	20020605
00006	222723194	100.04	99.69	100.08	I70S	20020320	20020605
00006	222723195	99.9	100.31	100.01	I70S	20020320	20020605
00006	222723196	99.9	99.92	99.94	I70S	20020320	20020605
00006	222723197	99.89	99.55	99.88	I70S	20020320	20020605
00006	222723198	100	99.71	99.92	I70S	20020320	20020605

KY CTESTS for 2002

00006	222723199	100.01	99.8	100.02	I70S	20020320	20020605
00006	222723200	100.12	100.11	100.05	I70S	20020320	20020605
00006	222723201	99.99	99.64	100.11	I70S	20020320	20020605
00006	222723202	100	99.83	99.96	I70S	20020320	20020605
00006	222723203	99.86	99.49	100	I70S	20020320	20020605
00006	222723204	99.86	99.49	100	I70S	20020320	20020605
00006	222723205	99.95	100	100.05	I70S	20020320	20020605
00006	222723206	100.09	99.75	100.09	I70S	20020320	20020605
00006	222723207	99.98	99.75	100.07	I70S	20020320	20020605
00006	222723208	100.08	99.85	100.1	I70S	20020320	20020605
00006	222723209	100.02	99.98	100.14	I70S	20020320	20020605
00006	222723210	100.01	99.82	99.95	I70S	20020320	20020605
00006	222723211	100.03	100.04	100.06	I70S	20020320	20020605
00006	222723212	100.02	99.73	99.94	I70S	20020320	20020605
00006	222723213	99.91	100.27	99.93	I70S	20020320	20020605
00006	222723214	100.01	100.14	99.86	I70S	20020320	20020605
00006	222723215	100.06	100.56	99.98	I70S	20020320	20020605
00006	222723216	100.04	99.65	99.92	I70S	20020320	20020605
00006	222723217	100.01	100.16	99.91	I70S	20020320	20020605
00006	222723218	99.97	99.49	100.03	I70S	20020320	20020605
00006	222723219	100.04	99.69	100.08	I70S	20020320	20020605
00006	222723220	99.91	99.82	100.11	I70S	20020320	20020605
00006	222723221	99.9	99.87	100.06	I70S	20020320	20020605
00006	222723222	100.04	99.8	100	I70S	20020320	20020605
00006	222723223	100.14	100.34	99.99	I70S	20020320	20020605
00006	222723224	100	100.11	99.86	I70S	20020320	20020605
00006	222723225	100	99.88	99.9	I70S	20020320	20020605
00006	222723226	100.07	99.95	100.09	I70S	20020320	20020605
00006	222723227	100.05	100.42	99.92	I70S	20020320	20020605
00006	222723228	99.94	99.94	100.1	I70S	20020320	20020605
00006	222723229	100.02	99.74	100.03	I70S	20020320	20020605
00006	222723230	99.98	99.42	99.88	I70S	20020320	20020605
00006	222723231	100.12	100.26	100.08	I70S	20020320	20020605
00006	222723232	100.11	99.97	100.08	I70S	20020320	20020605
00006	222723233	99.86	99.49	100	I70S	20020320	20020605
00006	222723234	100.05	99.81	99.99	I70S	20020320	20020605
00006	222723235	99.93	99.55	99.94	I70S	20020320	20020605
00006	222723236	100	100.64	99.95	I70S	20020320	20020605
00006	222723237	100.05	100.1	100.13	I70S	20020320	20020605
00006	222723238	99.93	100.31	100.08	I70S	20020320	20020605
00006	222723239	99.88	99.8	99.87	I70S	20020320	20020605
00006	222723240	100.01	100.12	100.04	I70S	20020320	20020605
00006	222723241	100.02	99.91	99.86	I70S	20020320	20020605
00006	222723242	99.89	99.73	99.96	I70S	20020320	20020605
00006	222723243	100.06	100.19	100.05	I70S	20020320	20020605
00006	222723244	99.96	100.04	100.04	I70S	20020320	20020605
00006	222723245	99.98	100.26	99.87	I70S	20020320	20020605
00006	222723246	99.92	100.13	100	I70S	20020320	20020605
00006	222723247	100	100.2	100.1	I70S	20020320	20020605
00006	222723248	100.09	99.87	100.07	I70S	20020320	20020605
00006	222723249	99.87	99.52	99.88	I70S	20020320	20020605
00006	222723250	99.93	100.26	100.11	I70S	20020320	20020605
00006	222723251	99.99	100.23	100.11	I70S	20020320	20020605
00006	222723252	100.04	100.11	99.93	I70S	20020320	20020605
00006	222723253	100.02	99.73	100.12	I70S	20020320	20020605
00006	222723254	99.98	99.93	100.03	I70S	20020320	20020605
00006	222723255	99.97	100.23	100.08	I70S	20020320	20020605
00006	222723256	100.03	99.95	99.95	I70S	20020320	20020605
00006	222723257	100.12	100.09	100.01	I70S	20020320	20020605
00006	222723259	100.08	100.11	99.92	I70S	20020320	20020605
00006	222723260	100.07	100.3	100.1	I70S	20020320	20020605

KY CTESTS for 2002

00006	222723261	99.95	99.92	99.87	I70S	20020320	20020605
00006	222723262	99.99	99.86	100.02	I70S	20020320	20020605
00006	222723263	100.03	100.45	99.87	I70S	20020320	20020605
00006	222723264	99.96	99.98	100.03	I70S	20020320	20020605
00006	222723265	100.11	100.31	100.13	I70S	20020320	20020605
00006	222723266	99.98	100.04	100.02	I70S	20020320	20020605
00006	222900725	99.94	100.26	99.95	I70S	20020509	20020524
00006	222900726	100.01	100.65	99.97	I70S	20020509	20020524
00006	222900727	100.12	99.84	99.93	I70S	20020509	20020524
00006	222901052	100.06	99.93	100.08	I70S	20020517	20020603
00006	222901055	99.92	99.8	99.86	I70S	20020517	20020603
00006	222901059	100.05	100.11	100.06	I70S	20020517	20020603
00006	222901064	100.02	100	100.04	I70S	20020517	20020603
00006	222901065	99.86	99.69	99.95	I70S	20020517	20020603
00006	222901066	99.92	99.95	99.88	I70S	20020517	20020603
00006	222901067	99.89	99.69	99.97	I70S	20020517	20020603
00006	222901069	100.07	99.74	100.04	I70S	20020517	20020603
00006	222901070	100.03	99.52	100.04	I70S	20020517	20020603
00006	222901071	99.99	100.46	99.97	I70S	20020517	20020603
00006	222901076	100	100.06	99.93	I70S	20020517	20020603
00006	222901077	100	100.13	100.1	I70S	20020517	20020603
00006	222901078	99.9	99.84	99.94	I70S	20020517	20020603
00006	222901079	100.07	99.98	99.98	I70S	20020517	20020603
00006	222901084	100.08	99.79	100.12	I70S	20020517	20020603
00006	222901085	100.04	99.93	100.13	I70S	20020517	20020603
00006	222901087	100.03	100.59	99.87	I70S	20020517	20020603
00006	222901091	99.99	100.33	99.97	I70S	20020517	20020603
00006	222901092	100.02	100.17	100.12	I70S	20020517	20020603
00006	222901093	100	100.26	100.09	I70S	20020517	20020603
00006	222901095	100.03	100.1	100.12	I70S	20020517	20020603
00006	222901096	100.05	100.31	99.93	I70S	20020517	20020603
00006	222901099	99.99	99.9	99.99	I70S	20020517	20020603
00006	222901100	100.01	99.9	99.97	I70S	20020517	20020603
00006	222901103	100.07	100.25	99.91	I70S	20020517	20020603
00006	222901105	99.97	99.72	99.94	I70S	20020517	20020603
00006	222901106	99.99	100.05	99.97	I70S	20020517	20020603
00006	222901108	100.07	100.32	100.05	I70S	20020517	20020603
00006	222901114	100	99.95	99.87	I70S	20020517	20020603
00006	222901123	100.06	100.15	100.04	I70S	20020517	20020603
00006	222901124	99.86	99.72	99.97	I70S	20020517	20020603
00006	222901125	99.97	100.05	99.87	I70S	20020517	20020603
00006	222901127	99.94	100.12	100.04	I70S	20020517	20020603
00006	222901128	100.01	99.88	99.97	I70S	20020517	20020603
00006	222901131	99.98	99.67	100.08	I70S	20020517	20020603
00006	222901137	100.01	99.38	99.89	I70S	20020517	20020603
00006	222901140	99.89	99.97	99.87	I70S	20020517	20020603
00006	222901141	99.97	100.2	99.92	I70S	20020517	20020603
00006	222901142	100.08	100.1	100.09	I70S	20020517	20020603
00006	222901143	100.07	100.41	99.99	I70S	20020517	20020603
00006	222901144	99.99	99.82	99.87	I70S	20020517	20020603
00006	222901146	99.97	99.83	100.05	I70S	20020517	20020603
00006	222901148	99.96	100.06	100.08	I70S	20020517	20020603
00006	222901149	100.03	100.12	100.01	I70S	20020517	20020603
00006	222901150	99.87	99.63	99.88	I70S	20020517	20020603
00006	222901151	100.11	100.16	100.1	I70S	20020517	20020603
00006	222901152	100.05	100	99.93	I70S	20020517	20020603
00006	222901153	100.03	99.99	99.96	I70S	20020517	20020603
00006	222901154	100.09	99.94	99.88	I70S	20020517	20020603
00006	222901155	99.91	99.77	99.99	I70S	20020517	20020603
00006	222901156	100.01	100.03	100.11	I70S	20020517	20020603
00006	222901157	99.98	99.95	99.91	I70S	20020517	20020603

KY CTESTS for 2002

00006	222901158	100.07	100.21	100.1	I70S	20020517	20020603
00006	222901159	99.98	99.71	100.02	I70S	20020517	20020603
00006	222901160	100	100.21	100.04	I70S	20020517	20020603
00006	222901161	100.11	100.16	100.12	I70S	20020517	20020603
00006	222901162	100.08	100.39	99.93	I70S	20020517	20020603
00006	222901163	100.09	99.83	100.12	I70S	20020517	20020603
00006	222901164	99.96	100.23	99.9	I70S	20020517	20020603
00006	222901165	100.07	100.06	100.06	I70S	20020517	20020603
00006	222901166	99.98	100.08	100.06	I70S	20020517	20020603
00006	222901167	99.89	99.65	100.02	I70S	20020517	20020603
00006	222901168	100.02	99.37	99.93	I70S	20020517	20020603
00006	222901169	100.01	99.73	100.06	I70S	20020517	20020603
00006	222901170	99.99	99.73	99.96	I70S	20020517	20020603
00006	222901171	100	100.03	99.86	I70S	20020517	20020603
00006	222901173	99.95	99.7	100	I70S	20020517	20020603
00006	222901174	100.12	100.42	99.93	I70S	20020517	20020603
00006	222901175	99.97	99.86	99.91	I70S	20020517	20020603
00006	222901176	100.05	100.19	99.94	I70S	20020517	20020603
00006	222901177	99.89	99.76	99.95	I70S	20020517	20020603
00006	222901178	100.06	100.03	99.99	I70S	20020517	20020603
00006	222901179	100.08	100.25	100.07	I70S	20020517	20020603
00006	222901180	99.93	99.47	99.92	I70S	20020517	20020603
00006	222901181	100.03	99.62	100.03	I70S	20020517	20020603
00006	222901182	99.99	100.01	99.89	I70S	20020517	20020603
00006	222901183	100.1	100.1	100.08	I70S	20020517	20020603
00006	222901184	99.96	99.32	99.86	I70S	20020517	20020603
00006	222901185	100.11	99.74	100	I70S	20020517	20020603
00006	222901186	99.98	99.97	99.92	I70S	20020517	20020603
00006	222901187	100.1	99.97	100.07	I70S	20020517	20020603
00006	222901188	99.87	99.57	99.89	I70S	20020517	20020603
00006	222901189	100.13	100.2	100.11	I70S	20020517	20020603
00006	222901190	100	100.14	100.05	I70S	20020517	20020603
00006	222901191	99.91	100.04	99.97	I70S	20020517	20020603
00006	222901192	99.94	99.52	100	I70S	20020517	20020603
00006	222901193	99.86	100.02	99.94	I70S	20020517	20020603
00006	222901195	99.94	100.15	99.96	I70S	20020517	20020603
00006	222901196	99.96	100.11	99.87	I70S	20020517	20020603
00006	222901197	100.05	99.7	99.94	I70S	20020517	20020603
00006	222901198	100.05	100.11	100.03	I70S	20020517	20020603
00006	222901199	99.89	99.79	100.09	I70S	20020517	20020603
00006	222901200	99.98	99.71	99.97	I70S	20020517	20020603
00006	222901202	100.13	99.8	100.12	I70S	20020517	20020603
00006	222901203	100.1	99.85	99.95	I70S	20020517	20020603
00006	222901204	99.92	99.92	100.1	I70S	20020517	20020603
00006	222901205	99.92	100.61	99.93	I70S	20020517	20020603
00006	222901206	99.96	99.72	100.1	I70S	20020517	20020603
00006	222901207	99.94	99.7	99.87	I70S	20020517	20020603
00006	222901208	100.01	100.16	100.01	I70S	20020517	20020603
00006	222901209	99.97	100.09	100.12	I70S	20020517	20020603
00006	222901210	100.02	100.24	100.05	I70S	20020517	20020603
00006	222901211	100	99.83	100.04	I70S	20020517	20020603
00006	222901212	100.01	99.32	100.02	I70S	20020517	20020603
00006	222901213	100.06	100.08	99.92	I70S	20020517	20020603
00006	222901214	99.99	99.77	99.91	I70S	20020517	20020603
00006	222901215	100.03	99.77	99.99	I70S	20020517	20020603
00006	222901216	100.02	99.92	99.93	I70S	20020517	20020603
00006	222901217	100.14	100.05	100.08	I70S	20020517	20020603
00006	222901218	99.98	99.56	99.96	I70S	20020517	20020603
00006	222901219	99.98	100.46	99.96	I70S	20020517	20020603
00006	222901220	100.09	99.35	100.07	I70S	20020517	20020603
00006	222901221	100.12	99.89	100.03	I70S	20020517	20020603

KY CTESTS for 2002

00006	222901222	99.94	99.87	99.87	I70S	20020517	20020603
00006	222901223	100.06	99.9	100.05	I70S	20020517	20020603
00006	222901224	99.95	99.87	99.96	I70S	20020517	20020603
00006	222901225	100.02	99.71	99.87	I70S	20020517	20020603
00006	222901226	99.97	100.11	100.14	I70S	20020517	20020603
00006	222901227	99.98	100.25	99.96	I70S	20020517	20020603
00006	222901228	99.91	99.61	99.95	I70S	20020517	20020603
00006	222901229	100.05	99.78	100	I70S	20020517	20020603
00006	222901230	100.05	99.69	99.99	I70S	20020517	20020603
00006	222901231	100.02	99.99	100.06	I70S	20020517	20020603
00006	222901232	100.04	100.32	100.08	I70S	20020517	20020603
00006	222901233	100.02	100.62	100.02	I70S	20020517	20020603
00006	222901234	100.1	100.35	100.11	I70S	20020517	20020603
00006	222901235	100.02	99.32	99.96	I70S	20020517	20020603
00006	222901236	99.93	99.94	99.88	I70S	20020517	20020603
00006	222901237	100.02	100.07	100.06	I70S	20020517	20020603
00006	222901238	99.97	100.06	99.91	I70S	20020517	20020603
00006	222901239	99.99	99.93	100.03	I70S	20020517	20020603
00006	222901240	100.1	99.85	99.96	I70S	20020517	20020603
00006	222901241	99.95	100.05	100.01	I70S	20020517	20020603
00006	222901242	100.06	100.09	100.08	I70S	20020517	20020603
00006	222901243	100.07	99.76	99.91	I70S	20020517	20020603
00006	222908276	100.01	100.16	99.92	I70S	20020605	20020626
00006	222908277	99.93	100.06	99.87	I70S	20020605	20020626
00006	222908278	100.04	99.95	100.04	I70S	20020605	20020626
00006	222908279	99.94	99.78	99.98	I70S	20020605	20020626
00006	222908280	100.04	99.99	99.92	I70S	20020605	20020626
00006	222908281	99.98	100.22	100	I70S	20020605	20020626
00006	222908282	99.95	100.32	99.86	I70S	20020605	20020626
00006	222908283	99.96	100.2	99.97	I70S	20020605	20020626
00006	222908284	100.07	100.31	99.96	I70S	20020605	20020626
00006	222908285	100.06	99.65	99.92	I70S	20020605	20020626
00006	222908286	99.98	100.1	100.02	I70S	20020605	20020626
00006	222908287	100.1	100.3	100.06	I70S	20020605	20020626
00006	222908288	100.05	100.2	100.12	I70S	20020605	20020626
00006	222908289	99.95	100.02	100.04	I70S	20020605	20020626
00006	222908290	99.97	100.47	99.88	I70S	20020605	20020626
00006	222908291	100.02	100.16	100.14	I70S	20020605	20020626
00006	222908293	99.87	100.23	99.92	I70S	20020605	20020626
00006	222908294	100.02	100.25	100.11	I70S	20020605	20020626
00006	222908295	99.96	100.07	99.99	I70S	20020605	20020626
00006	222908296	100.04	100.04	100.02	I70S	20020605	20020626
00006	222908297	100.01	99.31	99.87	I70S	20020605	20020626
00006	222908298	100.03	99.85	100.02	I70S	20020605	20020626
00006	222908299	100.13	99.39	100.08	I70S	20020605	20020626
00006	222908300	100.06	100.23	99.89	I70S	20020605	20020626
00006	222908301	99.99	100.17	99.96	I70S	20020605	20020626
00006	222908302	99.93	100.05	100.04	I70S	20020605	20020626
00006	222908303	100.05	99.4	99.99	I70S	20020605	20020626
00006	222908304	100.05	99.83	99.88	I70S	20020605	20020626
00006	222908305	100.02	100.17	100.01	I70S	20020605	20020626
00006	222908306	100.12	100.25	100.09	I70S	20020605	20020626
00006	222908307	99.92	100.09	99.97	I70S	20020605	20020626
00006	222908308	100.01	99.98	100.06	I70S	20020605	20020626
00006	222908309	100.08	100.39	99.94	I70S	20020605	20020626
00006	222908310	100	100.32	100.14	I70S	20020605	20020626
00006	222908311	100.04	100.23	99.93	I70S	20020605	20020626
00006	222908312	100.06	100.12	100.07	I70S	20020605	20020626
00006	222908313	100.14	100.08	99.95	I70S	20020605	20020626
00006	222908314	99.91	100.08	99.87	I70S	20020605	20020626
00006	222908315	100.01	99.63	99.86	I70S	20020605	20020626

KY CTESTS for 2002

00006	222908316	100.01	100.19	99.9	I70S	20020605	20020626
00006	222908317	99.91	100.14	100.04	I70S	20020605	20020626
00006	222908318	100.14	100.33	100.11	I70S	20020605	20020626
00006	222908319	99.96	100.02	99.92	I70S	20020605	20020626
00006	222908320	99.98	100.2	99.9	I70S	20020605	20020626
00006	222908321	100.03	100.13	100.01	I70S	20020605	20020626
00006	222908322	99.88	100.19	99.89	I70S	20020605	20020626
00006	222908323	99.98	100.39	100.06	I70S	20020605	20020626
00006	222908324	99.95	100.26	99.89	I70S	20020605	20020626
00006	222908325	99.94	99.97	100.02	I70S	20020605	20020626
00006	222908326	99.93	99.83	99.93	I70S	20020605	20020626
00006	222908327	100.03	100.1	100.1	I70S	20020605	20020626
00006	222908328	100.02	100.07	99.98	I70S	20020605	20020626
00006	222908329	100.05	99.65	100	I70S	20020605	20020626
00006	222908330	100.13	99.47	100.13	I70S	20020605	20020626
00006	222908331	99.97	100.18	99.95	I70S	20020605	20020626
00006	222908332	100.01	100.6	100.13	I70S	20020605	20020626
00006	222908334	99.98	100.39	100.14	I70S	20020605	20020626
00006	222908335	99.94	100	99.97	I70S	20020605	20020626
00006	222908336	99.94	99.63	99.87	I70S	20020605	20020626
00006	222908337	100.08	99.41	99.96	I70S	20020605	20020626
00006	222908338	99.97	100	99.88	I70S	20020605	20020626
00006	222908339	99.93	99.81	100.1	I70S	20020605	20020626
00006	222908340	100.02	99.86	99.96	I70S	20020605	20020626
00006	222908341	100.03	100.11	100.05	I70S	20020605	20020626
00006	222908342	100.06	100.33	100.05	I70S	20020605	20020626
00006	222908343	100.13	100.32	100.01	I70S	20020605	20020626
00006	222908344	99.99	100.18	100.06	I70S	20020605	20020626
00006	222908346	100.1	100.18	99.99	I70S	20020605	20020626
00006	222908347	100.01	100.07	99.96	I70S	20020605	20020626
00006	222908348	99.97	100.16	100.01	I70S	20020605	20020626
00006	222908349	100	100.56	99.96	I70S	20020605	20020626
00006	222908350	99.98	99.82	99.99	I70S	20020605	20020626
00006	222908351	100.01	100.3	100.05	I70S	20020605	20020626
00006	222908352	99.96	99.79	99.94	I70S	20020605	20020626
00006	222908353	99.94	99.44	99.98	I70S	20020605	20020626
00006	222908354	100.05	100.05	100.04	I70S	20020605	20020626
00006	222908355	99.98	99.82	100.03	I70S	20020605	20020626
00006	222908356	100.03	100.07	99.96	I70S	20020605	20020626
00006	222908357	99.93	100.18	99.92	I70S	20020605	20020626
00006	222908358	99.93	99.98	100.1	I70S	20020605	20020626
00006	222908359	100.01	99.95	99.91	I70S	20020605	20020626
00006	222908361	100.13	100.23	100.01	I70S	20020605	20020626
00006	222908362	100.05	100.13	100.1	I70S	20020605	20020626
00006	222908363	99.98	100.05	100.13	I70S	20020605	20020626
00006	222908364	100.07	100.17	100.02	I70S	20020605	20020626
00006	222908365	99.97	100.31	99.98	I70S	20020605	20020626
00006	222908366	100	99.53	100.02	I70S	20020605	20020626
00006	222908367	100.12	99.67	100	I70S	20020605	20020626
00006	222908368	99.95	100.67	100.09	I70S	20020605	20020626
00006	222908370	100.02	99.68	100	I70S	20020605	20020626
00006	222908371	99.98	100.49	100.01	I70S	20020605	20020626
00006	222908372	99.9	99.91	99.95	I70S	20020605	20020626
00006	222908373	100.02	99.75	100.12	I70S	20020605	20020626
00006	222908374	99.99	100.2	100.04	I70S	20020605	20020626
00006	222908375	99.87	100.14	99.88	I70S	20020605	20020626
00006	222908376	100.08	99.78	100.1	I70S	20020605	20020626
00006	222908377	99.97	99.82	100.01	I70S	20020605	20020626
00006	222908378	99.89	100.58	99.91	I70S	20020605	20020626
00006	222908379	99.9	99.82	100.03	I70S	20020605	20020626
00006	222908381	99.98	100.03	99.92	I70S	20020605	20020626

KY CTESTS for 2002

00006	222908382	99.91	99.54	99.87	I70S	20020605	20020626
00006	222908383	99.9	99.42	100.07	I70S	20020605	20020626
00006	222908384	100.02	100.21	100.11	I70S	20020605	20020626
00006	222908385	99.96	100.31	99.91	I70S	20020605	20020626
00006	222908386	99.99	99.42	100.13	I70S	20020605	20020626
00006	222908387	100.09	100.04	99.98	I70S	20020605	20020626
00006	222908388	99.91	99.78	100	I70S	20020605	20020626
00006	222908389	99.93	99.9	99.9	I70S	20020605	20020626
00006	222908390	100.01	100.08	100.09	I70S	20020605	20020626
00006	222908391	99.99	100.45	100.01	I70S	20020605	20020626
00006	222908392	100.04	100.55	100.04	I70S	20020605	20020626
00006	222908393	100.1	99.72	100.01	I70S	20020605	20020626
00006	222908394	100.01	100.2	100.08	I70S	20020605	20020626
00006	222908395	99.88	99.81	99.97	I70S	20020605	20020626
00006	222908396	100.02	100.12	100.01	I70S	20020605	20020626
00006	222908397	100.05	100.24	100.1	I70S	20020605	20020626
00006	222908398	99.87	99.78	99.97	I70S	20020605	20020626
00006	222908399	100.05	99.62	99.91	I70S	20020605	20020626
00006	222908401	99.94	100.5	100.03	I70S	20020605	20020626
00006	222908402	99.92	100	100.06	I70S	20020605	20020626
00006	222908403	100.07	100.16	100.12	I70S	20020605	20020626
00006	222908404	100.01	100.16	100.07	I70S	20020605	20020626
00006	222908405	100.09	100.63	100.1	I70S	20020605	20020626
00006	222908406	100	100.12	99.94	I70S	20020605	20020626
00006	222908407	100.08	99.41	99.94	I70S	20020605	20020626
00006	222908408	99.93	99.98	100.1	I70S	20020605	20020626
00006	222908409	100.08	100.28	100.06	I70S	20020605	20020626
00006	222908410	100	99.77	99.86	I70S	20020605	20020626
00006	222908411	100.06	100.15	99.97	I70S	20020605	20020626
00006	222908412	100.01	100.19	100.13	I70S	20020605	20020626
00006	222908413	100.04	100.09	100.09	I70S	20020605	20020626
00006	222908414	99.96	100.36	99.94	I70S	20020605	20020626
00006	222908415	100.04	99.64	100.03	I70S	20020605	20020626
00006	222908416	99.98	99.72	100.03	I70S	20020605	20020626
00006	222908417	100.08	100.36	100.13	I70S	20020605	20020626
00006	222908418	99.91	100.13	100.04	I70S	20020605	20020626
00006	222908419	100.13	100.23	100.01	I70S	20020605	20020626
00006	222908420	100.01	99.95	99.94	I70S	20020605	20020626
00006	222908421	100.11	100.49	99.98	I70S	20020605	20020626
00006	222908422	100.04	100.08	100.02	I70S	20020605	20020626
00006	222908423	99.98	100.07	100.04	I70S	20020605	20020626
00006	222908424	100.05	99.6	99.92	I70S	20020605	20020626
00006	222908425	99.95	99.42	99.94	I70S	20020605	20020626
00006	222908426	99.92	99.89	99.9	I70S	20020605	20020626
00006	222908427	100.08	99.89	99.88	I70S	20020605	20020626
00006	222908428	100.02	100.01	100.11	I70S	20020605	20020626
00006	222908429	99.89	99.98	99.92	I70S	20020605	20020626
00006	222908430	99.98	99.88	100.05	I70S	20020605	20020626
00006	222908431	100	99.89	99.86	I70S	20020605	20020626
00006	222908432	99.93	100.18	99.92	I70S	20020605	20020626
00006	222908433	100.12	100.2	100.05	I70S	20020605	20020626
00006	222908434	99.99	100.33	99.92	I70S	20020605	20020626
00006	222908435	99.94	100.22	100.02	I70S	20020605	20020626
00006	222908436	100.11	99.81	99.98	I70S	20020605	20020626
00006	222908437	100.1	100.64	99.98	I70S	20020605	20020626
00006	222908438	100	100.14	100	I70S	20020605	20020626
00006	222908439	100.08	100.05	100.03	I70S	20020605	20020626
00006	222908440	99.94	99.72	99.87	I70S	20020605	20020626
00006	222908441	99.87	99.9	100.09	I70S	20020605	20020626
00006	222908442	100.1	100.07	99.96	I70S	20020605	20020626
00006	222908443	100.03	99.73	99.94	I70S	20020605	20020626

KY CTESTS for 2002

00006	222908444	100.01	100.2	100.05	170S	20020605	20020626
00006	222908445	100.05	100.13	99.98	170S	20020605	20020626
00006	222908446	100.02	100.01	99.93	170S	20020605	20020626
00006	222908447	100.09	99.48	100.12	170S	20020605	20020626
00006	222908448	100.01	100.02	100.11	170S	20020605	20020626
00006	222908449	100.03	100.4	100.04	170S	20020605	20020626
00006	222908450	99.99	100.16	99.89	170S	20020605	20020626
00006	222908451	100	99.5	99.91	170S	20020605	20020626
00006	222908452	100.01	99.83	99.9	170S	20020605	20020626
00006	222908453	99.99	99.81	100.02	170S	20020605	20020626
00006	222908454	99.95	99.72	100.06	170S	20020605	20020626
00006	222908455	99.96	99.95	99.94	170S	20020605	20020626
00006	222908456	99.97	99.74	100.05	170S	20020605	20020626
00006	222908457	100.08	99.82	100.11	170S	20020605	20020626
00006	222908458	99.99	99.65	99.97	170S	20020605	20020626
00006	222908459	100.09	99.48	100.12	170S	20020605	20020626
00006	222908460	99.93	100.12	99.98	170S	20020605	20020626
00006	222908461	100.13	100.38	100.07	170S	20020605	20020626
00006	222908462	100.05	100.65	99.88	170S	20020605	20020626
00006	222908463	99.86	100.18	99.86	170S	20020605	20020626
00006	222908464	99.97	99.98	100.07	170S	20020605	20020626
00006	222908465	100.01	99.59	99.96	170S	20020605	20020626
00006	222908466	100.01	100.2	100.05	170S	20020605	20020626
00006	222908467	100.06	100.03	100.07	170S	20020605	20020626
00006	222908468	100.01	99.52	99.95	170S	20020605	20020626
00006	222908469	100.07	100.4	100.12	170S	20020605	20020626
00006	222908470	100.02	100.41	100.03	170S	20020605	20020626
00006	222908471	99.96	100.2	99.89	170S	20020605	20020626
00006	222908472	100.04	99.66	99.92	170S	20020605	20020626
00006	222908473	100.02	100.19	100.01	170S	20020605	20020626
00006	222908474	100.02	100.01	100.11	170S	20020605	20020626
00006	222908475	99.99	99.93	99.97	170S	20020605	20020626
00006	222908476	100	99.89	99.86	170S	20020605	20020626
00006	222908477	100.01	99.99	100	170S	20020605	20020626
00006	222908478	100.04	100.09	100.09	170S	20020605	20020626
00006	222908479	99.96	100.15	99.92	170S	20020605	20020626
00006	222908480	100.03	100.16	99.92	170S	20020605	20020626
00006	222908481	100.06	100.2	99.89	170S	20020605	20020626
00006	222908482	100.04	100.34	99.9	170S	20020605	20020626
00006	222908483	100.03	100.21	100.01	170S	20020605	20020626
00006	222908484	100.08	99.76	100.13	170S	20020605	20020626
00006	222908485	99.94	99.43	100.11	170S	20020605	20020626
00006	222908486	99.97	100.21	100.01	170S	20020605	20020626
00006	222908487	100.05	100.24	99.88	170S	20020605	20020626
00006	222908488	100.08	100.24	100.01	170S	20020605	20020626
00006	222908489	100.04	99.8	100.05	170S	20020605	20020626
00006	222908490	100.04	99.89	99.93	170S	20020605	20020626
00006	222908491	100	100.3	100.11	170S	20020605	20020626
00006	222908492	100.1	100.33	100.06	170S	20020605	20020626
00006	222908493	100.02	100.34	100	170S	20020605	20020626
00006	222908494	100.05	100.05	100.02	170S	20020605	20020626
00006	222908495	99.9	100.65	100.12	170S	20020605	20020626
00006	222908496	99.99	99.67	100	170S	20020605	20020626
00006	222908497	99.96	99.91	100.05	170S	20020605	20020626
00006	222908498	100.06	100.69	100.08	170S	20020605	20020626
00006	222908499	99.88	99.55	100.1	170S	20020605	20020626
00006	222908500	99.97	99.7	100.03	170S	20020605	20020626
00006	222908501	100.14	99.62	99.93	170S	20020605	20020626
00006	222908502	99.91	99.94	100.13	170S	20020605	20020626
00006	222908503	100.05	100.31	100.11	170S	20020605	20020626
00006	222908504	100.06	99.99	100.1	170S	20020605	20020626

KY CTESTS for 2002

00006	222908505	100.03	100.52	100.03	I70S	20020605	20020626
00006	222908506	100.07	100.52	100.09	I70S	20020605	20020626
00006	222908507	100.03	99.48	99.92	I70S	20020605	20020626
00006	222908508	99.99	99.42	100.13	I70S	20020605	20020626
00006	222908509	100.01	100.33	99.98	I70S	20020605	20020626
00006	222908510	100	100.09	99.89	I70S	20020605	20020626
00006	222908511	100	100.14	99.88	I70S	20020605	20020626
00006	222908512	100.06	99.96	100.02	I70S	20020605	20020626
00006	222908513	99.98	100.21	99.97	I70S	20020605	20020626
00006	222908514	100.01	99.95	99.94	I70S	20020605	20020626
00006	222908515	100.01	100.07	99.97	I70S	20020605	20020626
00006	222908516	100.05	99.89	100.02	I70S	20020605	20020626
00006	222908517	100.14	100.14	99.94	I70S	20020605	20020626
00006	222908518	99.9	100.1	99.89	I70S	20020605	20020626
00006	222908519	100.09	100.17	99.99	I70S	20020605	20020626
00006	222908520	99.86	99.66	100	I70S	20020605	20020626
00006	222908521	99.92	99.89	99.9	I70S	20020605	20020626
00006	222908522	99.91	99.86	100.09	I70S	20020605	20020626
00006	222908523	99.96	99.95	99.94	I70S	20020605	20020626
00006	222908524	100.12	100.2	100.05	I70S	20020605	20020626
00006	222908525	99.94	99.72	99.87	I70S	20020605	20020626
00006	222908526	99.95	100.09	99.94	I70S	20020605	20020626
00006	222908527	100	100.45	99.86	I70S	20020605	20020626
00006	222908528	99.89	100.11	100.07	I70S	20020605	20020626
00006	222908529	100.04	100.38	100.11	I70S	20020605	20020626
00006	222908530	99.89	99.46	99.87	I70S	20020605	20020626
00006	222908531	100.02	99.65	100.1	I70S	20020605	20020626
00006	222908532	100.08	100.62	100	I70S	20020605	20020626
00006	222908533	99.98	100.02	99.87	I70S	20020605	20020626
00006	222908534	100.08	99.89	99.88	I70S	20020605	20020626
00006	222908535	99.99	100.21	99.93	I70S	20020605	20020626
00006	222908536	99.94	99.88	99.98	I70S	20020605	20020626
00006	222908537	100.07	100.14	100.02	I70S	20020605	20020626
00006	222908538	100	100.15	99.89	I70S	20020605	20020626
00006	222908539	99.9	99.91	99.95	I70S	20020605	20020626
00006	222908540	100.06	100.36	99.97	I70S	20020605	20020626
00006	222908541	99.89	100.14	100.06	I70S	20020605	20020626
00006	222908542	100.03	99.95	99.88	I70S	20020605	20020626
00006	222908543	99.95	100	100.09	I70S	20020605	20020626
00006	222908544	100.11	100.51	100.07	I70S	20020605	20020626
00006	222908545	100.07	100.47	100.1	I70S	20020605	20020626
00006	222908546	100.11	100.26	100.07	I70S	20020605	20020626
00006	222908547	100.03	100.19	99.96	I70S	20020605	20020626
00006	222908548	99.9	99.65	99.93	I70S	20020605	20020626
00006	222908549	99.99	100.38	100.02	I70S	20020605	20020626
00006	222908550	99.87	99.9	100.09	I70S	20020605	20020626
00006	222908551	99.98	100.08	99.86	I70S	20020605	20020626
00006	222908552	99.87	99.58	99.97	I70S	20020605	20020626
00006	222908553	99.96	100.03	100.03	I70S	20020605	20020626
00006	222908554	99.92	99.88	100.14	I70S	20020605	20020626
00006	222908555	99.93	100.1	99.99	I70S	20020605	20020626
00006	222908556	100.01	100.11	99.95	I70S	20020605	20020626
00006	222908557	100.03	100.23	99.9	I70S	20020605	20020626
00006	222908558	100.09	100.31	100.1	I70S	20020605	20020626
00006	222908559	99.97	100.02	100.07	I70S	20020605	20020626
00006	222908560	100.05	100.64	99.99	I70S	20020605	20020626
00006	222908561	99.97	100.45	99.98	I70S	20020605	20020626
00006	222908562	99.99	100.59	99.95	I70S	20020605	20020626
00006	222908563	100.06	100.11	100.12	I70S	20020605	20020626
00006	222908564	100.02	100.2	99.98	I70S	20020605	20020626
00006	222908565	100.03	99.94	100.05	I70S	20020605	20020626

KY CTESTS for 2002

00006	222908566	100.04	100.07	100.12	170S	20020605	20020626
00006	222908567	100	100.4	100.03	170S	20020605	20020626
00006	222908568	100.05	100.04	99.94	170S	20020605	20020626
00006	222908569	100.12	99.67	100	170S	20020605	20020626
00006	222908570	99.94	100.06	99.92	170S	20020605	20020626
00006	222908571	100.02	100.39	100	170S	20020605	20020626
00006	222908572	100.06	100.33	100.03	170S	20020605	20020626
00006	222908573	100.12	100.15	100.03	170S	20020605	20020626
00006	222908574	100.06	100.13	100.12	170S	20020605	20020626
00006	222908575	99.89	100.35	100.03	170S	20020605	20020626
00006	222908576	100.02	100.38	99.94	170S	20020605	20020626
00006	222908577	100.03	100.15	100.09	170S	20020605	20020626
00006	222908578	99.9	99.8	100.12	170S	20020605	20020626
00006	222908579	100.02	100.02	100.07	170S	20020605	20020626
00006	222908580	100.11	100.16	100.11	170S	20020605	20020626
00006	222908581	100.03	100.12	99.86	170S	20020605	20020626
00006	222908582	100.09	99.75	99.95	170S	20020605	20020626
00006	222908583	100.06	100.5	100.04	170S	20020605	20020626
00006	222908584	100.07	99.85	100	170S	20020605	20020626
00006	222908585	99.95	99.42	99.94	170S	20020605	20020626
00006	222908586	100.03	100.17	100.11	170S	20020605	20020626
00006	222908587	100.01	99.38	100.01	170S	20020605	20020626
00006	222908588	100.04	100.17	100.05	170S	20020605	20020626
00006	222908589	100.12	100.21	100.14	170S	20020605	20020626
00006	222908590	99.89	99.62	100.13	170S	20020605	20020626
00006	222908591	100.02	99.69	100.14	170S	20020605	20020626
00006	222908592	99.86	99.74	99.88	170S	20020605	20020626
00006	222908593	99.88	100.18	100.12	170S	20020605	20020626
00006	222908594	99.87	99.9	100.09	170S	20020605	20020626
00006	222908595	100.02	99.97	100.04	170S	20020605	20020626
00006	222908596	99.97	99.91	100.03	170S	20020605	20020626
00006	222908597	100.02	100.2	99.98	170S	20020605	20020626
00006	222908598	100.03	100.15	99.94	170S	20020605	20020626
00006	222908599	99.88	100.45	99.93	170S	20020605	20020626
00006	222908600	100.03	99.6	99.97	170S	20020605	20020626
00006	222908601	100	99.81	99.94	170S	20020605	20020626
00006	222908602	99.94	100.31	100.03	170S	20020605	20020626
00006	222908603	100.08	99.94	100.07	170S	20020605	20020626
00006	222908604	99.94	100.13	99.92	170S	20020605	20020626
00006	222908605	100.09	100.04	100.02	170S	20020605	20020626
00006	222908606	99.88	100.66	100.03	170S	20020605	20020626
00006	222908607	99.97	99.47	99.95	170S	20020605	20020626
00006	222908608	100.01	100.63	99.86	170S	20020605	20020626
00006	222908609	100.04	99.62	100.07	170S	20020605	20020626
00006	222908610	99.94	99.88	99.98	170S	20020605	20020626
00006	222908611	100.1	100.35	99.95	170S	20020605	20020626
00006	222908612	100.05	99.91	100.08	170S	20020605	20020626
00006	222908613	99.98	100.08	99.86	170S	20020605	20020626
00006	222908614	100.11	100.03	99.97	170S	20020605	20020626
00006	222908615	99.99	99.81	99.87	170S	20020605	20020626
00006	222908616	99.98	99.96	100.03	170S	20020605	20020626
00006	222908617	100	100.46	99.97	170S	20020605	20020626
00006	222908618	100.08	100.29	100.04	170S	20020605	20020626
00006	222908619	100.03	99.92	100.14	170S	20020605	20020626
00006	222908620	100	99.86	99.99	170S	20020605	20020626
00006	222908621	99.91	100.44	100.06	170S	20020605	20020626
00006	222908622	99.93	100.1	99.99	170S	20020605	20020626
00006	222908623	99.98	99.54	99.96	170S	20020605	20020626
00006	222908624	100.05	99.61	99.87	170S	20020605	20020626
00006	222908625	99.94	99.44	99.92	170S	20020605	20020626
00006	222908626	100.04	100.23	99.87	170S	20020605	20020626

KY CTESTS for 2002

00006	222908627	99.95	100.09	99.94	I70S	20020605	20020626
00006	222908628	100.06	100.03	100.09	I70S	20020605	20020626
00006	222908629	100.01	100.36	99.96	I70S	20020605	20020626
00006	222908630	99.99	100.03	100.05	I70S	20020605	20020626
00006	222908631	99.99	99.95	100	I70S	20020605	20020626
00006	222908632	100.03	100.16	99.99	I70S	20020605	20020626
00006	222908633	99.9	99.84	100.11	I70S	20020605	20020626
00006	222908634	100.05	99.89	99.86	I70S	20020605	20020626
00006	222908635	100.11	100.26	100.07	I70S	20020605	20020626
00006	222908636	99.94	100.69	99.98	I70S	20020605	20020626
00006	222908637	100.01	100.24	100.07	I70S	20020605	20020626
00006	222908638	99.98	100.34	100.07	I70S	20020605	20020626
00006	222908639	99.89	99.9	99.91	I70S	20020605	20020626
00006	222908640	100.02	100.23	99.89	I70S	20020605	20020626
00006	222908641	100.02	99.86	99.98	I70S	20020605	20020626
00006	222908642	100.01	99.82	100.14	I70S	20020605	20020626
00006	222908643	99.91	100.23	100.02	I70S	20020605	20020626
00006	222908644	100.07	100.37	100.1	I70S	20020605	20020626
00006	222908645	100.12	99.67	100.13	I70S	20020605	20020626
00006	222908646	100.1	100.15	100.06	I70S	20020605	20020626
00006	222908647	100.04	100.29	100.11	I70S	20020605	20020626
00006	222908648	99.94	99.84	99.86	I70S	20020605	20020626
00006	222908649	99.97	100.45	100.05	I70S	20020605	20020626
00006	222908650	99.93	99.87	100.09	I70S	20020605	20020626
00006	222908651	99.97	99.8	99.96	I70S	20020605	20020626
00006	222908652	99.94	99.81	100.04	I70S	20020605	20020626
00006	222908653	99.94	99.78	99.99	I70S	20020605	20020626
00006	222908654	100.06	100.25	99.95	I70S	20020605	20020626
00006	222908655	100.11	100.23	99.91	I70S	20020605	20020626
00006	222908656	100.03	100.23	100.05	I70S	20020605	20020626
00006	222908657	99.91	100.4	99.89	I70S	20020605	20020626
00006	222908658	100.05	100.22	100.14	I70S	20020605	20020626
00006	222908659	99.93	100.03	99.96	I70S	20020605	20020626
00006	222908AX	99.99	99.99	99.97	I70S	20020605	20020626
00006	222908I70S	99.99	100.06	99.99	I70S	20020605	20020626
00006	222908KV2	100.05	100.2	100.12	I70S	20020605	20020626
00006	222908KVS	100	99.68	99.88	I70S	20020605	20020626
00006	222909044	99.91	100.03	99.96	I70S	20020606	20020620
00006	222909045	100.04	100.66	100.02	I70S	20020606	20020620
00006	222909046	100	100.06	99.94	I70S	20020606	20020620
00006	222909047	99.96	100.01	99.89	I70S	20020606	20020620
00006	222909048	100.07	100.19	100.13	I70S	20020606	20020620
00006	222909049	100.14	100.05	100.01	I70S	20020606	20020620
00006	222909050	100.05	99.88	99.99	I70S	20020606	20020620
00006	222909051	99.95	99.85	100.12	I70S	20020606	20020620
00006	222909052	99.97	99.56	99.95	I70S	20020606	20020620
00006	222909053	99.98	100.28	99.98	I70S	20020606	20020620
00006	222909054	100.04	100.37	99.98	I70S	20020606	20020620
00006	222909055	100.01	99.87	99.94	I70S	20020606	20020620
00006	222909056	100	100.6	100.09	I70S	20020606	20020620
00006	222909057	99.98	99.35	100.03	I70S	20020606	20020620
00006	222909058	99.97	99.79	99.96	I70S	20020606	20020620
00006	222909059	100.03	100.56	99.93	I70S	20020606	20020620
00006	222909060	100.13	100	100.03	I70S	20020606	20020620
00006	222909061	100.01	100.59	100.05	I70S	20020606	20020620
00006	222909062	100.04	99.89	100.06	I70S	20020606	20020620
00006	222909063	100.08	100.61	100.06	I70S	20020606	20020620
00006	222909064	100.04	99.79	99.9	I70S	20020606	20020620
00006	222909065	100.04	100.11	100	I70S	20020606	20020620
00006	222909066	99.99	100.1	100.02	I70S	20020606	20020620
00006	222909067	100.11	100.12	100.09	I70S	20020606	20020620

KY CTESTS for 2002

00006	222909068	99.95	99.87	99.95	I70S	20020606	20020620
00006	222909069	99.97	99.71	100.04	I70S	20020606	20020620
00006	222909070	99.92	100.28	99.93	I70S	20020606	20020620
00006	222909071	100.05	100.01	99.92	I70S	20020606	20020620
00006	222909072	99.97	100.46	99.88	I70S	20020606	20020620
00006	222909073	100.06	100.22	99.95	I70S	20020606	20020620
00006	222909074	99.87	99.8	99.94	I70S	20020606	20020620
00006	222909075	100.02	100.48	99.9	I70S	20020606	20020620
00006	222909076	100.03	100.14	100.06	I70S	20020606	20020620
00006	222909077	99.9	99.46	99.87	I70S	20020606	20020620
00006	222909078	100.01	100.31	100.02	I70S	20020606	20020620
00006	222909079	100.06	100.18	99.91	I70S	20020606	20020620
00006	222909080	100.1	100.11	100.06	I70S	20020606	20020620
00006	222909081	99.93	99.87	100.05	I70S	20020606	20020620
00006	222909082	99.94	100.03	99.95	I70S	20020606	20020620
00006	222909083	99.98	100.56	99.86	I70S	20020606	20020620
00006	222909084	100.12	100.12	99.9	I70S	20020606	20020620
00006	222909085	100.09	99.95	99.92	I70S	20020606	20020620
00006	222909086	100	100.27	99.99	I70S	20020606	20020620
00006	222909087	99.94	99.9	100.06	I70S	20020606	20020620
00006	222909088	100	99.96	99.96	I70S	20020606	20020620
00006	222909089	100.05	100.25	99.92	I70S	20020606	20020620
00006	222909090	100	100.28	100.07	I70S	20020606	20020620
00006	222909091	100.01	100.15	99.96	I70S	20020606	20020620
00006	222909092	99.87	99.88	99.9	I70S	20020606	20020620
00006	222909093	99.96	99.79	99.93	I70S	20020606	20020620
00006	222909094	99.93	100.26	99.91	I70S	20020606	20020620
00006	222909095	100.02	99.99	99.94	I70S	20020606	20020620
00006	222909096	100.02	99.56	99.98	I70S	20020606	20020620
00006	222909097	100.13	99.72	100.11	I70S	20020606	20020620
00006	222909098	100.14	99.95	99.95	I70S	20020606	20020620
00006	222909099	100	99.47	99.96	I70S	20020606	20020620
00006	222909100	99.94	100.03	99.99	I70S	20020606	20020620
00006	222909101	100.02	100.18	100.09	I70S	20020606	20020620
00006	222909102	99.95	99.9	100.03	I70S	20020606	20020620
00006	222909103	100.07	100.2	100.11	I70S	20020606	20020620
00006	222909104	99.94	100.03	99.87	I70S	20020606	20020620
00006	222909106	99.87	99.47	99.99	I70S	20020606	20020620
00006	222909107	99.96	100.41	99.86	I70S	20020606	20020620
00006	222909108	100.02	100.23	99.87	I70S	20020606	20020620
00006	222909109	99.88	99.82	99.92	I70S	20020606	20020620
00006	222909110	99.91	100.64	99.92	I70S	20020606	20020620
00006	222909111	99.99	99.83	100.02	I70S	20020606	20020620
00006	222909112	99.87	99.6	99.9	I70S	20020606	20020620
00006	222909113	99.95	99.98	99.91	I70S	20020606	20020620
00006	222909114	99.96	99.8	100.13	I70S	20020606	20020620
00006	222909115	99.94	99.47	100.04	I70S	20020606	20020620
00006	222909116	99.92	99.9	100.02	I70S	20020606	20020620
00006	222909117	100.03	100	99.93	I70S	20020606	20020620
00006	222909118	99.97	99.75	100.06	I70S	20020606	20020620
00006	222909119	99.94	99.61	99.86	I70S	20020606	20020620
00006	222909120	99.88	99.89	100.08	I70S	20020606	20020620
00006	222909121	99.93	99.77	99.98	I70S	20020606	20020620
00006	222909122	100	99.79	100	I70S	20020606	20020620
00006	222909123	100.07	99.7	100.01	I70S	20020606	20020620
00006	222909124	100.04	99.55	99.98	I70S	20020606	20020620
00006	222909125	100.04	99.48	99.91	I70S	20020606	20020620
00006	222909126	99.97	99.79	99.87	I70S	20020606	20020620
00006	222909127	100.04	99.59	100.09	I70S	20020606	20020620
00006	222909128	99.88	100.37	99.87	I70S	20020606	20020620
00006	222909129	100.01	100.24	99.9	I70S	20020606	20020620

KY CTESTS for 2002

00006	222909130	100	99.58	100.09	170S	20020606	20020620
00006	222909131	99.94	99.83	100.09	170S	20020606	20020620
00006	222909132	100.02	99.8	99.91	170S	20020606	20020620
00006	222909133	100.05	100.05	99.9	170S	20020606	20020620
00006	222909134	99.97	99.79	100.09	170S	20020606	20020620
00006	222909135	99.96	100.07	99.96	170S	20020606	20020620
00006	222909136	99.97	99.89	100.07	170S	20020606	20020620
00006	222909137	100.06	99.77	99.88	170S	20020606	20020620
00006	222909138	100.13	100.51	100.06	170S	20020606	20020620
00006	222909139	100.1	99.87	100.01	170S	20020606	20020620
00006	222909140	99.99	100.11	100.01	170S	20020606	20020620
00006	222909141	99.94	99.82	99.91	170S	20020606	20020620
00006	222909142	99.99	99.66	100.07	170S	20020606	20020620
00006	222909143	100.04	99.93	99.92	170S	20020606	20020620
00006	222909144	99.87	99.51	99.93	170S	20020606	20020620
00006	222909145	100.07	99.8	99.94	170S	20020606	20020620
00006	222909146	99.89	99.74	99.9	170S	20020606	20020620
00006	222909147	99.97	100.05	99.98	170S	20020606	20020620
00006	222909148	100.12	99.32	100.12	170S	20020606	20020620
00006	222909149	99.98	99.64	100.09	170S	20020606	20020620
00006	222909150	100.09	100.27	99.94	170S	20020606	20020620
00006	222909151	100.05	99.96	100.1	170S	20020606	20020620
00006	222909152	99.99	99.89	100.07	170S	20020606	20020620
00006	222909153	99.86	99.36	100.01	170S	20020606	20020620
00006	222909154	99.97	99.9	99.93	170S	20020606	20020620
00006	222909155	99.95	100.31	100.14	170S	20020606	20020620
00006	222909156	99.95	100.07	99.98	170S	20020606	20020620
00006	222909157	100.02	99.46	99.9	170S	20020606	20020620
00006	222909158	100.08	100.03	100.08	170S	20020606	20020620
00006	222909159	99.95	99.62	99.89	170S	20020606	20020620
00006	222909161	100.03	100.45	100.03	170S	20020606	20020620
00006	222909163	99.93	100.12	99.96	170S	20020606	20020620
00006	222909164	99.97	100.59	99.9	170S	20020606	20020620
00006	222909165	100.03	100.27	100.07	170S	20020606	20020620
00006	222909167	100.02	99.9	100.11	170S	20020606	20020620
00006	222909168	100.01	99.57	99.95	170S	20020606	20020620
00006	222909169	100.03	100.32	100.07	170S	20020606	20020620
00006	222909170	99.98	100.68	99.95	170S	20020606	20020620
00006	222909171	99.86	99.83	99.89	170S	20020606	20020620
00006	222909172	99.99	99.92	99.89	170S	20020606	20020620
00006	222909173	100.1	100.2	100.11	170S	20020606	20020620
00006	222909174	100.04	99.55	99.86	170S	20020606	20020620
00006	222909175	100.02	99.87	99.91	170S	20020606	20020620
00006	222909176	100.08	100.12	99.93	170S	20020606	20020620
00006	222909177	100	100.3	99.87	170S	20020606	20020620
00006	222909178	99.99	99.66	99.98	170S	20020606	20020620
00006	222909179	99.95	99.87	99.95	170S	20020606	20020620
00006	222909180	99.99	99.97	100.05	170S	20020606	20020620
00006	222909181	100.07	99.75	100.08	170S	20020606	20020620
00006	222909182	99.95	99.86	100.14	170S	20020606	20020620
00006	222909183	99.89	99.69	99.95	170S	20020606	20020620
00006	222909184	99.98	99.95	100.04	170S	20020606	20020620
00006	222909185	100.05	99.82	99.96	170S	20020606	20020620
00006	222909186	100.06	100.08	99.88	170S	20020606	20020620
00006	222909187	100	100.1	100.02	170S	20020606	20020620
00006	222909188	99.88	99.74	100.03	170S	20020606	20020620
00006	222909189	100	100.06	100.08	170S	20020606	20020620
00006	222909190	100.05	100.04	99.96	170S	20020606	20020620
00006	222909191	100.09	100.03	99.86	170S	20020606	20020620
00006	222909192	100.01	100.26	99.86	170S	20020606	20020620
00006	222909193	99.87	100.18	99.97	170S	20020606	20020620

KY CTESTS for 2002

00006	222909194	100.02	99.85	100.12	I70S	20020606	20020620
00006	222909195	100.06	100.05	100.12	I70S	20020606	20020620
00006	222909196	100	99.96	100.03	I70S	20020606	20020620
00006	222909197	100.12	100.29	99.98	I70S	20020606	20020620
00006	222909198	99.91	100.39	99.88	I70S	20020606	20020620
00006	222909199	99.89	99.68	100.03	I70S	20020606	20020620
00006	222909200	100.08	100.14	100.07	I70S	20020606	20020620
00006	222909201	100.02	99.77	99.88	I70S	20020606	20020620
00006	222909202	100.06	100.01	100.08	I70S	20020606	20020620
00006	222909203	100.06	100.08	100.08	I70S	20020606	20020620
00006	222909204	100.14	100.23	100.01	I70S	20020606	20020620
00006	222909205	99.98	99.73	99.93	I70S	20020606	20020620
00006	222909206	99.92	99.46	99.87	I70S	20020606	20020620
00006	222909207	100.04	99.84	99.94	I70S	20020606	20020620
00006	222909208	100.04	99.55	100.09	I70S	20020606	20020620
00006	222909209	99.89	99.7	100.01	I70S	20020606	20020620
00006	222909210	100.12	100.33	99.98	I70S	20020606	20020620
00006	222909212	100	99.85	99.89	I70S	20020606	20020620
00006	222909213	100.1	100.06	100.06	I70S	20020606	20020620
00006	222909214	100.07	100.1	100.1	I70S	20020606	20020620
00006	222909215	100.04	99.69	100.08	I70S	20020606	20020620
00006	222909216	100.06	99.7	99.99	I70S	20020606	20020620
00006	222909217	100.07	99.7	100.07	I70S	20020606	20020620
00006	222909218	100.02	99.94	100.13	I70S	20020606	20020620
00006	222909219	99.91	99.63	99.9	I70S	20020606	20020620
00006	222909220	99.98	99.84	99.91	I70S	20020606	20020620
00006	222909221	99.99	99.68	100	I70S	20020606	20020620
00006	222909222	99.98	99.88	100.06	I70S	20020606	20020620
00006	222909223	100.04	100.36	100.03	I70S	20020606	20020620
00006	222909224	99.95	100.33	100.04	I70S	20020606	20020620
00006	222909225	100.01	99.83	100.14	I70S	20020606	20020620
00006	222909226	99.98	100.17	100.05	I70S	20020606	20020620
00006	222909227	99.89	100.01	99.91	I70S	20020606	20020620
00006	222909228	100.03	99.87	99.98	I70S	20020606	20020620
00006	222909229	100.01	99.98	100.06	I70S	20020606	20020620
00006	222909230	100.12	100.27	100.06	I70S	20020606	20020620
00006	222909231	99.91	99.76	99.99	I70S	20020606	20020620
00006	222909233	99.94	99.92	100.13	I70S	20020606	20020620
00006	222909234	99.99	100.18	99.91	I70S	20020606	20020620
00006	222909235	100.03	99.99	99.92	I70S	20020606	20020620
00006	222909237	99.94	99.6	99.87	I70S	20020606	20020620
00006	222909238	100.06	100.14	100.07	I70S	20020606	20020620
00006	222909239	100.11	100.19	100.13	I70S	20020606	20020620
00006	222909240	100.11	100.19	100.13	I70S	20020606	20020620
00006	222909241	100.1	99.82	99.96	I70S	20020606	20020620
00006	222909242	100.05	100.09	100.05	I70S	20020606	20020620
00006	222909243	100.01	100.01	100.08	I70S	20020606	20020620
00006	222909244	100.03	99.7	99.91	I70S	20020606	20020620
00006	222909245	100.03	99.42	99.89	I70S	20020606	20020620
00006	222909246	99.96	99.91	100	I70S	20020606	20020620
00006	222909247	99.97	100.22	100.05	I70S	20020606	20020620
00006	222909248	100.1	100.27	99.93	I70S	20020606	20020620
00006	222909249	99.95	99.89	99.98	I70S	20020606	20020620
00006	222909250	99.95	99.89	99.98	I70S	20020606	20020620
00006	222909251	99.99	99.77	100.08	I70S	20020606	20020620
00006	222909252	100	99.77	100.03	I70S	20020606	20020620
00006	222909253	99.99	99.69	99.93	I70S	20020606	20020620
00006	222909254	99.9	99.41	99.94	I70S	20020606	20020620
00006	222909255	100.03	100.25	100.14	I70S	20020606	20020620
00006	222909257	100.01	99.67	100.02	I70S	20020606	20020620
00006	222909258	99.96	99.6	100.09	I70S	20020606	20020620

KY CTESTS for 2002

00006	222909259	99.99	99.77	100.08	I70S	20020606	20020620
00006	222909260	100.04	99.78	99.94	I70S	20020606	20020620
00006	222909261	100.06	99.99	100.11	I70S	20020606	20020620
00006	222909262	99.97	100.31	99.93	I70S	20020606	20020620
00006	222909263	99.94	99.97	99.87	I70S	20020606	20020620
00006	222909264	100.11	100.14	99.87	I70S	20020606	20020620
00006	222909265	100.03	99.78	99.9	I70S	20020606	20020620
00006	222909266	99.92	100.21	99.98	I70S	20020606	20020620
00006	222909267	100	100.36	99.89	I70S	20020606	20020620
00006	222909268	100.12	100.09	100.01	I70S	20020606	20020620
00006	222909269	99.94	99.89	100.14	I70S	20020606	20020620
00006	222909270	100.14	99.55	99.89	I70S	20020606	20020620
00006	222909271	100.04	99.78	100	I70S	20020606	20020620
00006	222909272	100	99.85	99.95	I70S	20020606	20020620
00006	222909273	99.86	99.75	99.96	I70S	20020606	20020620
00006	222909274	100.08	99.91	99.91	I70S	20020606	20020620
00006	222909275	100.14	99.81	99.94	I70S	20020606	20020620
00006	222909276	100	99.78	99.98	I70S	20020606	20020620
00006	222909277	99.96	100.02	99.96	I70S	20020606	20020620
00006	222909278	99.86	99.75	99.96	I70S	20020606	20020620
00006	222909279	99.96	100.07	99.91	I70S	20020606	20020620
00006	222909280	100.02	99.94	100.13	I70S	20020606	20020620
00006	222909281	99.99	99.72	100.1	I70S	20020606	20020620
00006	222909282	99.93	99.95	99.97	I70S	20020606	20020620
00006	222909283	99.9	100.26	99.87	I70S	20020606	20020620
00006	222909284	99.89	100.63	100.07	I70S	20020606	20020620
00006	222909285	99.96	100.33	100.03	I70S	20020606	20020620
00006	222909286	100.1	100.62	100.08	I70S	20020606	20020620
00006	222909287	100.02	100.09	99.96	I70S	20020606	20020620
00006	222909288	100.14	99.69	99.96	I70S	20020606	20020620
00006	222909289	100.13	100.14	99.96	I70S	20020606	20020620
00006	222909290	100.07	100.05	99.95	I70S	20020606	20020620
00006	222909291	99.97	99.57	99.95	I70S	20020606	20020620
00006	222909292	100.01	100.09	100.1	I70S	20020606	20020620
00006	222909293	99.95	99.81	99.96	I70S	20020606	20020620
00006	222909294	99.96	99.96	99.89	I70S	20020606	20020620
00006	222909295	99.96	100.01	99.96	I70S	20020606	20020620
00006	222909296	100.1	100.31	99.89	I70S	20020606	20020620
00006	222909297	100.1	99.72	100.09	I70S	20020606	20020620
00006	222909298	100.08	99.68	100.12	I70S	20020606	20020620
00006	222909299	100.01	100.43	100.04	I70S	20020606	20020620
00006	222909300	100.12	99.94	99.93	I70S	20020606	20020620
00006	222909301	100.08	100.54	99.96	I70S	20020606	20020620
00006	222909302	100.01	99.68	99.93	I70S	20020606	20020620
00006	222909303	100.07	100.2	100.1	I70S	20020606	20020620
00006	222909304	99.93	100.42	100.04	I70S	20020606	20020620
00006	222909305	100.07	99.89	100.01	I70S	20020606	20020620
00006	222909306	99.93	99.72	99.99	I70S	20020606	20020620
00006	222909307	100.12	99.94	99.93	I70S	20020606	20020620
00006	222909308	100.11	99.88	99.89	I70S	20020606	20020620
00006	222909309	100.1	100.49	100.05	I70S	20020606	20020620
00006	222909310	99.98	99.91	99.95	I70S	20020606	20020620
00006	222909311	100.01	99.95	99.86	I70S	20020606	20020620
00006	222909312	99.96	99.76	100	I70S	20020606	20020620
00006	222909313	100.14	99.69	99.96	I70S	20020606	20020620
00006	222909314	100.01	100.18	100.13	I70S	20020606	20020620
00006	222909315	99.94	100.03	99.87	I70S	20020606	20020620
00006	222909316	100.01	100.3	100.08	I70S	20020606	20020620
00006	222909317	100.06	100.15	99.95	I70S	20020606	20020620
00006	222909318	100.06	100.15	99.95	I70S	20020606	20020620
00006	222909319	100.06	100.15	99.95	I70S	20020606	20020620

KY CTESTS for 2002

00006	222909320	100.06	100.15	99.95	I70S	20020606	20020620
00006	222909321	100.05	99.44	100.02	I70S	20020606	20020620
00006	222909322	99.99	99.97	99.9	I70S	20020606	20020620
00006	222909323	100.07	100.15	99.97	I70S	20020606	20020620
00006	222909324	100.05	99.44	100.02	I70S	20020606	20020620
00006	222909325	99.94	100.03	99.87	I70S	20020606	20020620
00006	222909326	100.07	100.05	99.95	I70S	20020606	20020620
00006	222909327	100.04	100.33	100.06	I70S	20020606	20020620
00006	222909328	99.96	100.33	100.03	I70S	20020606	20020620
00006	222909329	100.11	100.14	100.03	I70S	20020606	20020620
00006	222909330	99.96	100.33	100.03	I70S	20020606	20020620
00006	222909331	99.99	100.39	100.01	I70S	20020606	20020620
00006	222909332	99.97	100.48	100.07	I70S	20020606	20020620
00006	222909333	100.13	100.08	100.14	I70S	20020606	20020620
00006	222909334	100.13	100.08	100.14	I70S	20020606	20020620
00006	222909335	100	100.13	99.86	I70S	20020606	20020620
00006	222909336	100.1	100.05	100.08	I70S	20020606	20020620
00006	222909337	99.96	100.3	99.99	I70S	20020606	20020620
00006	222909338	100.01	100.33	100.05	I70S	20020606	20020620
00006	222909339	100.07	100.06	100.06	I70S	20020606	20020620
00006	222909340	99.94	99.5	99.87	I70S	20020606	20020620
00006	222909341	99.96	100.03	100.08	I70S	20020606	20020620
00006	222909342	99.95	100.2	100.04	I70S	20020606	20020620
00006	222909343	100.08	100.36	100.03	I70S	20020606	20020620
00006	222909344	100.06	100.22	100.05	I70S	20020606	20020620
00006	222909346	100.07	99.88	99.97	I70S	20020606	20020620
00006	222909347	100.05	100.12	100	I70S	20020606	20020620
00006	222909348	100.04	100.22	99.97	I70S	20020606	20020620
00006	222909349	99.98	100.27	99.86	I70S	20020606	20020620
00006	222909350	99.96	100.02	100.11	I70S	20020606	20020620
00006	222909351	99.98	99.85	99.92	I70S	20020606	20020620
00006	222909352	99.96	100.02	100.11	I70S	20020606	20020620
00006	222909353	100.06	100.04	100.06	I70S	20020606	20020620
00006	222909354	99.99	100.57	99.95	I70S	20020606	20020620
00006	222909355	100.04	99.74	99.9	I70S	20020606	20020620
00006	222909356	100.07	99.67	100.06	I70S	20020606	20020620
00006	222909357	99.9	100.41	100.12	I70S	20020606	20020620
00006	222909358	100.07	99.67	100.06	I70S	20020606	20020620
00006	222909359	99.9	100.18	99.86	I70S	20020606	20020620
00006	222909361	99.9	99.93	100.06	I70S	20020606	20020620
00006	222909362	100.08	100.13	100.12	I70S	20020606	20020620
00006	222909363	99.98	100.25	100	I70S	20020606	20020620
00006	222909364	99.87	100.07	99.91	I70S	20020606	20020620
00006	222909365	99.97	100.24	100.04	I70S	20020606	20020620
00006	222909366	100.04	100.02	99.89	I70S	20020606	20020620
00006	222909367	99.97	99.83	100.04	I70S	20020606	20020620
00006	222909368	100.14	100.22	99.97	I70S	20020606	20020620
00006	222909370	99.93	100.33	99.88	I70S	20020606	20020620
00006	222909371	100.04	100.44	100.12	I70S	20020606	20020620
00006	222909372	100.02	99.86	99.89	I70S	20020606	20020620
00006	222909373	100.03	100.34	99.96	I70S	20020606	20020620
00006	222909374	100.04	100.31	100.01	I70S	20020606	20020620
00006	222909375	100.02	100.1	100.02	I70S	20020606	20020620
00006	222909376	100.1	100.09	100.11	I70S	20020606	20020620
00006	222909377	100.06	100.31	99.9	I70S	20020606	20020620
00006	222909378	100	100.1	100.04	I70S	20020606	20020620
00006	222909379	100.13	100.13	100.02	I70S	20020606	20020620
00006	222909380	99.96	100.17	100.06	I70S	20020606	20020620
00006	222909381	100.02	100.1	100.02	I70S	20020606	20020620
00006	222909382	100.07	99.94	100.04	I70S	20020606	20020620
00006	222909383	100.07	100.35	100.14	I70S	20020606	20020620

KY CTESTS for 2002

00006	222909384	100	100.04	99.95	I70S	20020606	20020620
00006	222909385	100.05	99.98	99.95	I70S	20020606	20020620
00006	222909386	100.03	100.39	100.11	I70S	20020606	20020620
00006	222909387	99.96	99.96	99.96	I70S	20020606	20020620
00006	222909388	99.96	100.24	100.05	I70S	20020606	20020620
00006	222909389	99.96	100.17	100.06	I70S	20020606	20020620
00006	222909390	99.98	100.34	99.89	I70S	20020606	20020620
00006	222909391	99.94	100.28	99.9	I70S	20020606	20020620
00006	222909392	100.04	100.41	99.97	I70S	20020606	20020620
00006	222909393	100.08	100.25	100.1	I70S	20020606	20020620
00006	222909394	100.1	100.02	99.97	I70S	20020606	20020620
00006	222909395	100.12	100.08	100.1	I70S	20020606	20020620
00006	222909396	100	99.78	99.96	I70S	20020606	20020620
00006	222909397	100.04	100.39	100.05	I70S	20020606	20020620
00006	222909398	99.96	100.02	100.11	I70S	20020606	20020620
00006	222909399	100.02	99.67	100.03	I70S	20020606	20020620
00006	222909401	100.01	100.39	100.01	I70S	20020606	20020620
00006	222909402	99.91	99.88	99.96	I70S	20020606	20020620
00006	222909403	99.86	99.93	99.94	I70S	20020606	20020620
00006	222909404	99.95	100.28	99.96	I70S	20020606	20020620
00006	222909405	100.08	100.15	99.93	I70S	20020606	20020620
00006	222909406	100.08	100.21	100.1	I70S	20020606	20020620
00006	222909407	100.03	100.38	100.1	I70S	20020606	20020620
00006	222909408	99.98	100.26	99.96	I70S	20020606	20020620
00006	222909409	100.11	100.04	100	I70S	20020606	20020620
00006	222909410	100.02	100.43	99.86	I70S	20020606	20020620
00006	222909411	99.96	99.98	99.95	I70S	20020606	20020620
00006	222909412	100.04	100.02	99.89	I70S	20020606	20020620
00006	222909413	100.06	100.45	99.88	I70S	20020606	20020620
00006	222909414	100.1	100.49	99.98	I70S	20020606	20020620
00006	222909415	100.01	100.07	100.12	I70S	20020606	20020620
00006	222909416	99.96	100.03	99.98	I70S	20020606	20020620
00006	222909417	99.94	100.26	99.88	I70S	20020606	20020620
00006	222909418	100.03	100.23	100.03	I70S	20020606	20020620
00006	222909419	99.99	99.8	100.03	I70S	20020606	20020620
00006	222909420	100.09	100.54	100.14	I70S	20020606	20020620
00006	222909421	100.06	100.62	100.05	I70S	20020606	20020620
00006	222909422	100.05	100.52	100.14	I70S	20020606	20020620
00006	222909423	99.95	100.12	99.93	I70S	20020606	20020620
00006	222909424	100.06	100.62	100.05	I70S	20020606	20020620
00006	222909425	100.03	100.21	99.88	I70S	20020606	20020620
00006	222909426	99.94	100.06	99.94	I70S	20020606	20020620
00006	222909427	100.07	100.1	100.09	I70S	20020606	20020620
00006	222909AX	100.1	100.07	99.92	I70S	20020606	20020620
00006	222909I70S	100.06	100.01	100.04	I70S	20020606	20020620
00006	222909KVS	100.06	100.22	100.05	I70S	20020606	20020620
00006	222924620	100.01	99.7	100.01	I70S	20020711	20020726
00006	222924621	100	99.51	100.01	I70S	20020711	20020726
00006	222924622	100.04	99.63	100	I70S	20020711	20020726
00006	222924628	99.99	99.84	99.88	I70S	20020713	20020726
00006	222924629	99.95	99.45	100.07	I70S	20020713	20020726
00006	222924630	100.06	100.19	100.02	I70S	20020713	20020726
00006	222924631	99.96	100.07	100.07	I70S	20020713	20020726
00006	222924632	100	99.82	99.97	I70S	20020713	20020726
00006	222924633	100.01	99.83	100.1	I70S	20020713	20020726
00006	222924634	100.13	99.69	100.1	I70S	20020713	20020726
00006	222924635	100.04	99.82	99.96	I70S	20020713	20020726
00006	222924636	100.07	99.71	99.97	I70S	20020713	20020726
00006	222924637	100.01	99.83	100.1	I70S	20020713	20020726
00006	222924638	100.01	100.18	100.02	I70S	20020713	20020726
00006	222924639	100.11	99.86	100.03	I70S	20020713	20020726

KY CTESTS for 2002

00006	222924640	100.01	100.18	100.02	I70S	20020713	20020726
00006	222924641	99.99	100.35	100.04	I70S	20020713	20020726
00006	222924642	100.05	99.61	99.94	I70S	20020713	20020726
00006	222924643	100.04	99.95	100.03	I70S	20020713	20020726
00006	222924644	99.93	99.54	100.07	I70S	20020713	20020726
00006	222924645	99.94	100.38	100.1	I70S	20020713	20020726
00006	222924646	100.03	99.7	99.96	I70S	20020713	20020726
00006	222924647	100.04	99.42	100.01	I70S	20020713	20020726
00006	222924648	100.09	99.52	100.06	I70S	20020713	20020726
00006	222924649	100.02	99.55	100.03	I70S	20020713	20020726
00006	222924650	100.13	99.56	100.11	I70S	20020713	20020726
00006	222924651	100.13	99.89	100.09	I70S	20020713	20020726
00006	222924652	100	99.42	99.99	I70S	20020713	20020726
00006	222924653	99.87	100.29	99.94	I70S	20020713	20020726
00006	222924654	100.06	99.83	100.01	I70S	20020713	20020726
00006	222924655	100.02	99.62	100.02	I70S	20020713	20020726
00006	222924656	99.98	99.96	100.13	I70S	20020713	20020726
00006	222924657	99.93	99.73	99.86	I70S	20020713	20020726
00006	222924658	99.98	99.36	99.93	I70S	20020713	20020726
00006	222924659	100.04	99.79	100.05	I70S	20020713	20020726
00006	222924660	99.89	99.77	99.9	I70S	20020713	20020726
00006	222924661	99.99	99.77	100.08	I70S	20020713	20020726
00006	222924662	99.89	99.41	99.91	I70S	20020713	20020726
00006	222924663	100.11	100.29	100.08	I70S	20020713	20020726
00006	222924664	99.92	100.41	99.87	I70S	20020713	20020726
00006	222924665	100.09	100.07	100.08	I70S	20020713	20020726
00006	222924666	99.87	99.96	99.86	I70S	20020713	20020726
00006	222924667	100.07	99.64	100.05	I70S	20020713	20020726
00006	222924668	99.97	100	99.98	I70S	20020713	20020726
00006	222924669	100.03	99.56	100.03	I70S	20020713	20020726
00006	222924670	99.97	99.34	100.05	I70S	20020713	20020726
00006	222924671	99.99	99.62	99.99	I70S	20020713	20020726
00006	222924672	99.99	99.75	99.86	I70S	20020713	20020726
00006	222924673	99.99	99.51	99.89	I70S	20020713	20020726
00006	222924674	99.97	99.7	99.93	I70S	20020713	20020726
00006	222924675	100.11	100.38	99.97	I70S	20020713	20020726
00006	222924676	100.05	99.53	99.95	I70S	20020713	20020726
00006	222924677	100.05	99.55	100.07	I70S	20020713	20020726
00006	222924678	100.02	99.95	99.96	I70S	20020713	20020726
00006	222924679	100.11	99.62	99.96	I70S	20020713	20020726
00006	222924680	99.94	99.74	99.98	I70S	20020713	20020726
00006	222924681	100.1	99.84	99.89	I70S	20020713	20020726
00006	222924682	100.13	100.02	100.13	I70S	20020713	20020726
00006	222924683	99.96	99.8	99.93	I70S	20020713	20020726
00006	222924684	100.06	99.98	100.11	I70S	20020713	20020726
00006	222924685	99.94	99.45	99.96	I70S	20020713	20020726
00006	222924686	100.02	99.66	100	I70S	20020713	20020726
00006	222924687	100.02	99.55	99.87	I70S	20020713	20020726
00006	222924688	100.01	99.99	100.08	I70S	20020713	20020726
00006	222924689	99.92	100.21	99.93	I70S	20020713	20020726
00006	222924690	100.09	100.07	99.99	I70S	20020713	20020726
00006	222924691	99.87	99.42	99.86	I70S	20020713	20020726
00006	222924692	99.98	99.65	99.94	I70S	20020713	20020726
00006	222924693	99.96	99.79	100.11	I70S	20020713	20020726
00006	222924694	99.93	99.64	99.93	I70S	20020713	20020726
00006	222924695	100.09	99.54	99.92	I70S	20020713	20020726
00006	222924696	99.88	99.82	100.12	I70S	20020713	20020726
00006	222924697	100.05	99.89	99.96	I70S	20020713	20020726
00006	222924698	99.89	99.72	100.11	I70S	20020713	20020726
00006	222924699	99.97	99.78	100.04	I70S	20020713	20020726
00006	222924700	100.04	99.57	100.08	I70S	20020713	20020726

KY CTESTS for 2002

00006	222924701	100.03	99.37	99.92	I70S	20020713	20020726
00006	222924702	99.93	99.65	100.03	I70S	20020713	20020726
00006	222924703	100	99.33	100.07	I70S	20020713	20020726
00006	222924704	99.9	99.85	100.04	I70S	20020713	20020726
00006	222924705	99.92	99.62	100.11	I70S	20020713	20020726
00006	222924706	99.96	99.57	99.99	I70S	20020713	20020726
00006	222924707	99.96	99.99	99.88	I70S	20020713	20020726
00006	222924708	100.12	99.58	99.92	I70S	20020713	20020726
00006	222924709	100.02	99.56	99.96	I70S	20020713	20020726
00006	222924710	100.11	99.62	99.9	I70S	20020713	20020726
00006	222924711	100.08	99.64	99.94	I70S	20020713	20020726
00006	222924712	99.95	100.02	100.11	I70S	20020713	20020726
00006	222924713	100.01	99.62	100.13	I70S	20020713	20020726
00006	222924714	100.05	99.78	99.98	I70S	20020713	20020726
00006	222924715	99.97	99.7	99.86	I70S	20020713	20020726
00006	222924716	99.93	99.56	99.93	I70S	20020713	20020726
00006	222924717	99.99	100.65	99.87	I70S	20020713	20020726
00006	222924718	99.96	99.49	99.9	I70S	20020713	20020726
00006	222924720	100.01	99.7	99.95	I70S	20020713	20020726
00006	222924721	100.01	99.7	99.95	I70S	20020713	20020726
00006	222924722	99.99	99.5	99.96	I70S	20020713	20020726
00006	222924723	100.01	100.39	99.98	I70S	20020713	20020726
00006	222924724	99.97	100.2	99.93	I70S	20020711	20020726
00006	222924725	99.91	99.38	99.97	I70S	20020711	20020726
00006	222924726	99.92	99.61	100.02	I70S	20020711	20020726
00006	222924727	99.98	100.12	99.86	I70S	20020711	20020726
00006	222924728	100.09	99.46	100.04	I70S	20020711	20020726
00006	222924729	99.95	99.66	99.92	I70S	20020711	20020726
00006	222924730	100.03	99.6	100.04	I70S	20020711	20020726
00006	222924731	99.99	99.63	100	I70S	20020711	20020726
00006	222924732	99.9	99.38	99.98	I70S	20020711	20020726
00006	222924733	100.11	100.19	100	I70S	20020711	20020726
00006	222924734	100.12	99.85	100.14	I70S	20020711	20020726
00006	222924735	100	99.72	100.11	I70S	20020711	20020726
00006	222924736	99.93	99.49	99.97	I70S	20020711	20020726
00006	222924737	100.02	99.66	100.02	I70S	20020711	20020726
00006	222924738	100.02	99.74	99.95	I70S	20020711	20020726
00006	222924739	99.86	99.36	99.86	I70S	20020711	20020726
00006	222924740	99.93	99.99	100.03	I70S	20020711	20020726
00006	222924741	100.07	100.02	100.02	I70S	20020711	20020726
00006	222924742	100.03	99.71	99.97	I70S	20020711	20020726
00006	222924743	99.98	99.59	100.07	I70S	20020711	20020726
00006	222924744	100.09	100.06	100.11	I70S	20020711	20020726
00006	222924745	100.06	99.56	100.14	I70S	20020711	20020726
00006	222924746	99.98	99.69	99.89	I70S	20020711	20020726
00006	222924747	99.99	99.65	99.96	I70S	20020711	20020726
00006	222924748	99.89	99.4	99.98	I70S	20020711	20020726
00006	222924749	99.95	99.85	99.97	I70S	20020711	20020726
00006	222924750	99.97	99.83	100.14	I70S	20020711	20020726
00006	222924751	100.04	100.01	100.08	I70S	20020711	20020726
00006	222924752	100.01	99.5	100.06	I70S	20020711	20020726
00006	222924753	99.99	99.78	99.86	I70S	20020711	20020726
00006	222924754	100	99.7	100.08	I70S	20020711	20020726
00006	222924755	100.01	99.69	100.06	I70S	20020711	20020726
00006	222924756	99.98	99.61	100.04	I70S	20020711	20020726
00006	222924757	100.03	99.99	100.01	I70S	20020711	20020726
00006	222924758	100.07	99.65	100.04	I70S	20020711	20020726
00006	222924759	100.04	99.58	100.1	I70S	20020711	20020726
00006	222924760	99.87	99.46	100.01	I70S	20020711	20020726
00006	222924761	100.01	99.4	100.1	I70S	20020711	20020726
00006	222924762	99.94	99.64	99.94	I70S	20020711	20020726

KY CTESTS for 2002

00006	222924763	99.88	100.03	99.92	I70S	20020711	20020726
00006	222924764	99.99	99.96	99.92	I70S	20020711	20020726
00006	222924765	100.13	99.96	100.05	I70S	20020711	20020726
00006	222924766	100.09	99.75	99.98	I70S	20020711	20020726
00006	222924767	100.04	99.79	99.98	I70S	20020711	20020726
00006	222924768	99.91	99.84	100.01	I70S	20020711	20020726
00006	222924769	100.14	100.16	100.1	I70S	20020711	20020726
00006	222924770	100.08	99.76	100.07	I70S	20020711	20020726
00006	222924771	100.02	99.76	100.12	I70S	20020711	20020726
00006	222924772	100.11	100.18	99.86	I70S	20020711	20020726
00006	222924773	100.02	99.82	99.9	I70S	20020711	20020726
00006	222924774	100.04	99.86	100.04	I70S	20020711	20020726
00006	222924775	99.94	99.58	99.93	I70S	20020711	20020726
00006	222924776	99.94	99.81	99.89	I70S	20020711	20020726
00006	222924777	99.87	99.52	100.06	I70S	20020711	20020726
00006	222924778	99.87	99.6	99.9	I70S	20020711	20020726
00006	222924779	99.92	99.85	100.13	I70S	20020711	20020726
00006	222924780	100.05	99.93	99.94	I70S	20020711	20020726
00006	222924781	100.09	99.44	100.13	I70S	20020711	20020726
00006	222924782	100.14	99.79	99.91	I70S	20020711	20020726
00006	222924783	100.08	99.82	100.01	I70S	20020711	20020726
00006	222924784	100.05	99.7	99.97	I70S	20020711	20020726
00006	222924785	100.08	99.49	100.06	I70S	20020711	20020726
00006	222924786	99.89	99.91	100.02	I70S	20020711	20020726
00006	222924787	99.97	99.48	99.93	I70S	20020711	20020726
00006	222924788	99.95	99.74	99.89	I70S	20020711	20020726
00006	222924789	100.12	99.92	100.03	I70S	20020711	20020726
00006	222924790	100.01	99.37	100.12	I70S	20020711	20020726
00006	222924791	100.05	99.97	100.11	I70S	20020711	20020726
00006	222924792	100.03	99.65	100.02	I70S	20020711	20020726
00006	222924793	100.1	99.74	99.92	I70S	20020711	20020726
00006	222924794	100.05	99.9	99.88	I70S	20020711	20020726
00006	222924795	99.96	99.66	99.9	I70S	20020711	20020726
00006	222924796	99.99	99.6	99.97	I70S	20020711	20020726
00006	222924797	100.09	100.04	99.94	I70S	20020711	20020726
00006	222924798	100.1	100.07	100.07	I70S	20020711	20020726
00006	222924799	99.98	99.59	99.99	I70S	20020711	20020726
00006	222924800	100.01	99.98	99.91	I70S	20020711	20020726
00006	222924801	100.04	100	99.95	I70S	20020711	20020726
00006	222924802	100.02	99.86	99.87	I70S	20020711	20020726
00006	222924803	100.08	100.04	99.97	I70S	20020711	20020726
00006	222924804	100.02	99.96	99.95	I70S	20020711	20020726
00006	222924805	100.03	100.23	99.98	I70S	20020711	20020726
00006	222924806	100.06	99.84	100.09	I70S	20020711	20020726
00006	222924807	99.95	99.45	100.01	I70S	20020711	20020726
00006	222924808	100.08	99.99	100.07	I70S	20020711	20020726
00006	222924809	100.1	99.73	100.09	I70S	20020711	20020726
00006	222924810	99.99	99.74	100.12	I70S	20020711	20020726
00006	222924811	99.96	99.58	100	I70S	20020711	20020726
00006	222924812	99.98	99.52	100.03	I70S	20020711	20020726
00006	222924813	99.98	99.52	100.03	I70S	20020711	20020726
00006	222924814	99.91	99.53	100.14	I70S	20020711	20020726
00006	222924815	100.1	100.09	99.92	I70S	20020711	20020726
00006	222924816	99.98	100.1	100.03	I70S	20020711	20020726
00006	222924817	99.99	99.57	99.97	I70S	20020711	20020726
00006	222924818	100	99.95	99.91	I70S	20020711	20020726
00006	222924819	100.01	99.95	100.02	I70S	20020711	20020726
00006	222924916	100.01	99.88	100	I70S	20020711	20020726
00006	222924917	100.08	99.83	99.95	I70S	20020711	20020726
00006	222924918	99.95	99.67	100.01	I70S	20020711	20020726
00006	222924919	100.07	99.73	99.93	I70S	20020711	20020726

KY CTESTS for 2002

00006	222924920	99.99	100.26	100.07	I70S	20020711	20020726
00006	222924921	99.96	100.06	100.07	I70S	20020711	20020726
00006	222924922	99.97	99.89	100.14	I70S	20020711	20020726
00006	222924923	99.95	99.84	99.87	I70S	20020711	20020726
00006	222924924	100.12	100.06	100.14	I70S	20020711	20020726
00006	222924925	100.01	99.73	100	I70S	20020711	20020726
00006	222924926	99.96	99.83	99.92	I70S	20020711	20020726
00006	222924927	100.05	99.97	100.05	I70S	20020711	20020726
00006	222924928	99.94	99.67	100.02	I70S	20020711	20020726
00006	222924929	99.98	99.54	99.97	I70S	20020711	20020726
00006	222924930	99.97	99.69	99.92	I70S	20020711	20020726
00006	222924931	100	99.73	99.91	I70S	20020711	20020726
00006	222924932	99.86	99.33	100.03	I70S	20020711	20020726
00006	222924933	99.95	99.59	100.11	I70S	20020711	20020726
00006	222924934	100.13	100.09	99.9	I70S	20020711	20020726
00006	222924935	100.02	99.83	100.11	I70S	20020711	20020726
00006	222924936	99.89	99.76	99.91	I70S	20020711	20020726
00006	222924937	100.03	99.96	99.91	I70S	20020711	20020726
00006	222924938	100.07	100.11	100.14	I70S	20020711	20020726
00006	222924939	99.99	99.79	100.1	I70S	20020711	20020726
00006	222924940	100.02	99.97	100.04	I70S	20020711	20020726
00006	222924941	100.1	99.8	100.05	I70S	20020711	20020726
00006	222924942	99.98	99.88	100.02	I70S	20020711	20020726
00006	222924943	99.97	99.6	99.88	I70S	20020711	20020726
00006	222924944	100.01	99.75	100	I70S	20020711	20020726
00006	222924945	100.14	99.89	100.07	I70S	20020711	20020726
00006	222924946	100	100.11	100.03	I70S	20020711	20020726
00006	222924947	100.11	99.77	100.06	I70S	20020711	20020726
00006	222924948	99.98	99.79	100.13	I70S	20020711	20020726
00006	222924949	100.05	99.99	100.05	I70S	20020711	20020726
00006	222924950	100.06	99.82	99.93	I70S	20020711	20020726
00006	222924951	100.06	99.39	100.03	I70S	20020711	20020726
00006	222924952	99.98	99.76	99.9	I70S	20020711	20020726
00006	222924953	99.89	100.67	99.94	I70S	20020711	20020726
00006	222924954	100.14	100.11	100.12	I70S	20020713	20020726
00006	222924955	99.91	99.6	99.93	I70S	20020711	20020726
00006	222924956	99.97	99.64	99.87	I70S	20020711	20020726
00006	222924957	100.01	100	100.1	I70S	20020711	20020726
00006	222924958	99.95	99.44	99.89	I70S	20020711	20020726
00006	222924959	99.96	99.88	99.91	I70S	20020711	20020726
00006	222924960	99.99	99.55	100.07	I70S	20020711	20020726
00006	222924961	100	99.79	100.03	I70S	20020711	20020726
00006	222924962	100.01	100.01	99.93	I70S	20020711	20020726
00006	222924963	100.04	99.92	99.97	I70S	20020711	20020726
00006	222924964	100.1	100.19	99.92	I70S	20020711	20020726
00006	222924965	100	99.6	100.03	I70S	20020711	20020726
00006	222924966	99.96	99.94	100.06	I70S	20020711	20020726
00006	222924967	100.1	99.78	100.03	I70S	20020711	20020726
00006	222924968	100.06	99.84	99.94	I70S	20020711	20020726
00006	222924969	99.86	99.87	100.02	I70S	20020711	20020726
00006	222924970	99.95	99.74	99.88	I70S	20020711	20020726
00006	222924971	100.01	99.82	99.9	I70S	20020711	20020726
00006	222924972	100.14	99.98	100.14	I70S	20020711	20020726
00006	222924973	100.09	100.33	99.94	I70S	20020711	20020726
00006	222924974	99.99	100.18	99.96	I70S	20020711	20020726
00006	222924975	99.99	99.9	100.08	I70S	20020711	20020726
00006	222924976	100.02	99.79	99.97	I70S	20020711	20020726
00006	222924977	99.91	100.06	99.87	I70S	20020711	20020726
00006	222924978	99.92	99.6	100.01	I70S	20020711	20020726
00006	222924979	100.11	99.96	100.02	I70S	20020711	20020726
00006	222924980	100.05	99.84	100.04	I70S	20020711	20020726

KY CTESTS for 2002

00006	222924981	100.01	99.8	99.96	I70S	20020711	20020726
00006	222924982	100.14	99.88	100.08	I70S	20020711	20020726
00006	222924983	99.99	99.87	99.97	I70S	20020711	20020726
00006	222924984	99.96	99.77	99.98	I70S	20020711	20020726
00006	222924985	100.06	99.64	100.06	I70S	20020711	20020726
00006	222924986	100.09	99.79	100.05	I70S	20020711	20020726
00006	222924987	100.09	100.35	100.12	I70S	20020711	20020726
00006	222924988	100.04	99.92	100.1	I70S	20020711	20020726
00006	222924989	100.05	99.78	99.98	I70S	20020711	20020726
00006	222924990	100.1	100.06	100.08	I70S	20020711	20020726
00006	222924991	99.99	99.77	99.96	I70S	20020711	20020726
00006	222924992	100	99.71	100.1	I70S	20020711	20020726
00006	222924993	100.11	99.75	100.12	I70S	20020711	20020726
00006	222924994	99.98	99.91	99.95	I70S	20020711	20020726
00006	222924995	100.06	99.75	100.14	I70S	20020711	20020726
00006	222924996	100.05	99.59	100.02	I70S	20020711	20020726
00006	222924997	100.1	99.85	99.91	I70S	20020711	20020726
00006	222924998	100.06	99.78	100.03	I70S	20020711	20020726
00006	222924999	100.01	99.99	100.09	I70S	20020711	20020726
00006	222925000	100.14	99.78	100.06	I70S	20020711	20020726
00006	222925001	100.05	99.92	100.04	I70S	20020711	20020726
00006	222925002	100.01	100.11	100.13	I70S	20020711	20020726
00006	222925003	100.1	100.52	99.89	I70S	20020711	20020726
00006	222925004	100.07	100.13	100.01	I70S	20020711	20020726
00006	222925005	100.06	100.13	100.12	I70S	20020711	20020726
00006	222925006	100.12	99.48	100.11	I70S	20020711	20020726
00006	222925007	100.07	100	100.12	I70S	20020711	20020726
00006	222925008	99.97	99.75	100.04	I70S	20020711	20020726
00006	222925009	100.01	99.8	99.96	I70S	20020711	20020726
00006	222925010	99.88	99.72	99.9	I70S	20020711	20020726
00006	222925011	100.08	100.04	100.14	I70S	20020711	20020726
00006	222925012	100.05	100.06	100.04	I70S	20020711	20020726
00006	222925013	99.96	99.66	99.98	I70S	20020711	20020726
00006	222925014	100.12	99.73	100.14	I70S	20020711	20020726
00006	222925015	99.98	100.28	100	I70S	20020711	20020726
00006	222925016	99.9	99.64	99.95	I70S	20020711	20020726
00006	222925017	100.09	99.97	99.92	I70S	20020711	20020726
00006	222925018	100.09	99.96	99.86	I70S	20020711	20020726
00006	222925019	99.9	99.91	99.92	I70S	20020711	20020726
00006	222925020	99.97	99.86	100.04	I70S	20020711	20020726
00006	222925021	100.08	100.12	100.02	I70S	20020711	20020726
00006	222925022	100.1	99.86	100.12	I70S	20020711	20020726
00006	222925023	100.03	100.01	100.09	I70S	20020711	20020726
00006	222925024	100.06	99.75	100.14	I70S	20020711	20020726
00006	222925025	99.98	99.75	99.97	I70S	20020711	20020726
00006	222925026	100.14	99.37	100.06	I70S	20020711	20020726
00006	222925027	100.03	99.95	100.07	I70S	20020711	20020726
00006	222925028	99.98	99.7	100.01	I70S	20020711	20020726
00006	222925029	100.06	99.88	99.86	I70S	20020711	20020726
00006	222925030	100.03	100.14	100	I70S	20020711	20020726
00006	222925031	100	99.62	99.96	I70S	20020711	20020726
00006	222925032	100.01	99.94	99.86	I70S	20020711	20020726
00006	222925033	100.03	99.89	100.08	I70S	20020711	20020726
00006	222925034	100	100.06	99.97	I70S	20020711	20020726
00006	222925035	100.05	100.25	100.13	I70S	20020711	20020726
00006	222925036	100.03	99.91	100.12	I70S	20020711	20020726
00006	222925037	99.97	99.8	100.04	I70S	20020711	20020726
00006	222925038	100.13	99.99	99.98	I70S	20020711	20020726
00006	222925039	99.99	99.85	99.96	I70S	20020711	20020726
00006	222925040	100.14	99.95	100.09	I70S	20020711	20020726
00006	222925041	99.95	99.75	99.92	I70S	20020711	20020726

KY CTESTS for 2002

00006	222925042	100.05	99.76	99.91	I70S	20020711	20020726
00006	222925043	99.99	99.56	99.88	I70S	20020711	20020726
00006	222925044	100.09	100.38	100.14	I70S	20020711	20020726
00006	222925045	100.06	99.98	99.98	I70S	20020711	20020726
00006	222925046	99.97	99.71	99.97	I70S	20020711	20020726
00006	222925047	99.99	100.16	100.14	I70S	20020711	20020726
00006	222925048	100.01	99.73	99.93	I70S	20020711	20020726
00006	222925049	99.97	99.59	99.93	I70S	20020711	20020726
00006	222925050	100.02	99.97	100.12	I70S	20020711	20020726
00006	222925051	100.02	100.41	99.96	I70S	20020711	20020726
00006	222925052	99.97	100.39	99.87	I70S	20020711	20020726
00006	222925053	100.04	99.76	100.14	I70S	20020711	20020726
00006	222925054	100.04	99.92	100.1	I70S	20020711	20020726
00006	222925055	99.98	100.24	99.91	I70S	20020711	20020726
00006	222925056	100.04	100.41	100.06	I70S	20020711	20020726
00006	222925057	100.02	99.98	99.93	I70S	20020711	20020726
00006	222925058	100.04	99.59	99.91	I70S	20020711	20020726
00006	222925059	100.04	99.96	99.94	I70S	20020711	20020726
00006	222925060	100.03	99.65	99.96	I70S	20020711	20020726
00006	222925061	100.04	100.52	99.89	I70S	20020711	20020726
00006	222925062	100.02	99.72	100.12	I70S	20020711	20020726
00006	222925063	100.14	100.67	100.08	I70S	20020711	20020726
00006	222925064	100.04	99.9	100.05	I70S	20020711	20020726
00006	222925065	100.03	99.78	100.13	I70S	20020711	20020726
00006	222925066	99.95	99.68	99.95	I70S	20020711	20020726
00006	222925067	99.98	99.66	100.12	I70S	20020711	20020726
00006	222925068	100.01	99.98	99.88	I70S	20020711	20020726
00006	222925069	100.07	100.56	99.96	I70S	20020711	20020726
00006	222925070	100.05	99.84	100.03	I70S	20020711	20020726
00006	222925071	100.07	99.92	100.03	I70S	20020711	20020726
00006	222925072	100.06	100.25	99.91	I70S	20020711	20020726
00006	222925073	99.99	99.73	100.04	I70S	20020711	20020726
00006	222925074	99.95	99.87	100.07	I70S	20020711	20020726
00006	222925075	100.01	99.72	100.09	I70S	20020711	20020726
00006	222925076	99.98	100.14	100.04	I70S	20020711	20020726
00006	222925077	100.03	99.61	100.08	I70S	20020711	20020726
00006	222925078	100.08	99.9	99.94	I70S	20020711	20020726
00006	222925079	99.88	99.47	99.86	I70S	20020711	20020726
00006	222925080	99.91	100.02	99.91	I70S	20020711	20020726
00006	222925081	99.98	99.88	100.04	I70S	20020711	20020726
00006	222925082	100.04	99.66	99.98	I70S	20020711	20020726
00006	222925083	100.1	100.14	100.12	I70S	20020711	20020726
00006	222925084	100.1	99.8	100.12	I70S	20020711	20020726
00006	222925085	99.98	99.7	100.01	I70S	20020711	20020726
00006	222925086	99.93	99.92	100.11	I70S	20020711	20020726
00006	222925087	100.04	100	100.08	I70S	20020711	20020726
00006	222925088	100.07	99.65	100.01	I70S	20020711	20020726
00006	222925089	99.96	100.04	99.95	I70S	20020711	20020726
00006	222925090	100.14	99.93	99.96	I70S	20020711	20020726
00006	222925091	100.05	99.82	100.09	I70S	20020711	20020726
00006	222925092	100	99.81	100.13	I70S	20020711	20020726
00006	222925093	100	100.13	99.99	I70S	20020711	20020726
00006	222925094	100.02	99.96	99.93	I70S	20020711	20020726
00006	222925095	99.9	99.46	99.93	I70S	20020711	20020726
00006	222925096	100.01	99.71	100.1	I70S	20020711	20020726
00006	222925097	100.03	99.79	100.12	I70S	20020711	20020726
00006	222925098	99.97	99.73	99.9	I70S	20020711	20020726
00006	222925099	100.03	99.91	99.95	I70S	20020711	20020726
00006	222925100	99.91	99.33	100.01	I70S	20020711	20020726
00006	222925101	100.03	99.87	99.92	I70S	20020711	20020726
00006	222925102	100.05	100	99.95	I70S	20020711	20020726

KY CTESTS for 2002

00006	222925103	100.05	100.02	99.99	I70S	20020711	20020726
00006	222925104	100.07	99.81	100.05	I70S	20020711	20020726
00006	222925105	99.98	99.68	100.01	I70S	20020711	20020726
00006	222925106	99.94	99.87	99.9	I70S	20020711	20020726
00006	222925107	100.03	99.96	99.91	I70S	20020711	20020726
00006	222925396	100.04	100.04	100.04	I70S	20020711	20020726
00006	222925397	100.02	99.82	99.92	I70S	20020711	20020726
00006	222925398	99.98	99.79	99.99	I70S	20020711	20020726
00006	222925399	100	99.79	99.87	I70S	20020711	20020726
00006	222925401	99.97	100.33	99.96	I70S	20020711	20020726
00006	222925402	99.95	100.2	99.99	I70S	20020711	20020726
00006	222925403	99.93	99.88	100.06	I70S	20020711	20020726
00006	222925404	99.99	100.1	100.06	I70S	20020711	20020726
00006	222925405	99.87	100.13	100.12	I70S	20020711	20020726
00006	222925406	99.93	99.93	99.89	I70S	20020711	20020726
00006	222925407	100.01	99.6	99.89	I70S	20020711	20020726
00006	222925408	100.1	99.82	100.07	I70S	20020711	20020726
00006	222925409	100.06	100.28	99.92	I70S	20020711	20020726
00006	222925410	99.97	99.42	99.86	I70S	20020711	20020726
00006	222925411	99.96	99.79	99.87	I70S	20020711	20020726
00006	222925412	100.04	100.22	100.04	I70S	20020711	20020726
00006	222925413	99.99	99.99	99.95	I70S	20020711	20020726
00006	222925414	100.07	100.49	100.11	I70S	20020711	20020726
00006	222925415	100.08	99.85	100.06	I70S	20020711	20020726
00006	222925416	100.08	100.07	99.98	I70S	20020711	20020726
00006	222925417	100.13	100.07	99.91	I70S	20020711	20020726
00006	222925418	100.06	100.23	99.9	I70S	20020711	20020726
00006	222925419	99.9	99.93	99.99	I70S	20020711	20020726
00006	222925420	100.1	99.89	100.12	I70S	20020711	20020726
00006	222925421	99.93	99.7	100.06	I70S	20020711	20020726
00006	222925422	100	100.01	100.05	I70S	20020711	20020726
00006	222925423	99.97	99.81	100.03	I70S	20020711	20020726
00006	222925424	100.12	100.46	100.07	I70S	20020711	20020726
00006	222925425	99.92	100.3	99.91	I70S	20020711	20020726
00006	222925426	100.03	99.69	99.87	I70S	20020711	20020726
00006	222925427	99.99	100.48	99.89	I70S	20020711	20020726
00006	222925428	100.11	100.07	100.12	I70S	20020711	20020726
00006	222925429	100.06	99.72	100.05	I70S	20020711	20020726
00006	222925430	99.91	100.58	99.93	I70S	20020711	20020726
00006	222925431	100.09	100	100.1	I70S	20020711	20020726
00006	222925432	100.11	99.75	100	I70S	20020711	20020726
00006	222925433	99.93	99.97	99.95	I70S	20020711	20020726
00006	222925434	100.11	100.42	100.12	I70S	20020711	20020726
00006	222925435	99.94	100.38	99.88	I70S	20020711	20020726
00006	222925436	99.92	99.92	100	I70S	20020711	20020726
00006	222925437	100	99.95	100.09	I70S	20020711	20020726
00006	222925438	100	100.05	99.87	I70S	20020711	20020726
00006	222925439	99.96	99.99	100.06	I70S	20020711	20020726
00006	222925440	100.07	99.83	100.06	I70S	20020711	20020726
00006	222925441	100.07	99.88	100.02	I70S	20020711	20020726
00006	222925442	99.95	100.48	99.93	I70S	20020711	20020726
00006	222925443	99.97	99.97	99.98	I70S	20020711	20020726
00006	222925444	100.01	99.6	99.89	I70S	20020711	20020726
00006	222925445	100.09	100.18	100.09	I70S	20020711	20020726
00006	222925446	100.03	100.22	100.01	I70S	20020711	20020726
00006	222925447	100.09	100.16	100.04	I70S	20020711	20020726
00006	222925448	99.98	100.02	100.08	I70S	20020711	20020726
00006	222925449	99.98	100.34	99.92	I70S	20020711	20020726
00006	222925450	99.98	100.18	100.05	I70S	20020711	20020726
00006	222925451	100.11	99.9	99.87	I70S	20020711	20020726
00006	222925452	99.99	99.88	100.06	I70S	20020711	20020726

KY CTESTS for 2002

00006	222925453	99.93	100.16	99.96	I70S	20020711	20020726
00006	222925454	100.05	100.11	100.04	I70S	20020711	20020726
00006	222925455	100.04	99.94	100.05	I70S	20020711	20020726
00006	222925456	100.03	100.43	100.04	I70S	20020711	20020726
00006	222925457	99.94	100.55	99.97	I70S	20020711	20020726
00006	222925458	99.93	99.74	99.89	I70S	20020711	20020726
00006	222925459	100.1	100.4	100.02	I70S	20020711	20020726
00006	222925460	99.99	100.03	99.99	I70S	20020711	20020726
00006	222925461	100.03	100.59	99.86	I70S	20020711	20020726
00006	222925462	100	100.1	99.89	I70S	20020711	20020726
00006	222925463	100.02	100.57	99.88	I70S	20020711	20020726
00006	222925464	99.91	99.57	100.03	I70S	20020711	20020726
00006	222925465	100.02	99.49	100.07	I70S	20020711	20020726
00006	222925466	100.08	99.85	100.06	I70S	20020711	20020726
00006	222925467	99.97	100.23	99.98	I70S	20020711	20020726
00006	222925468	100.01	99.96	100.08	I70S	20020711	20020726
00006	222925469	99.98	99.54	99.97	I70S	20020711	20020726
00006	222925470	99.96	99.57	99.9	I70S	20020711	20020726
00006	222925471	99.97	99.42	99.86	I70S	20020711	20020726
00006	222925472	100.09	100.56	100	I70S	20020711	20020726
00006	222925473	100.02	100.14	100	I70S	20020711	20020726
00006	222925474	100.06	100.23	99.9	I70S	20020711	20020726
00006	222925475	100.04	100.11	99.89	I70S	20020711	20020726
00006	222925476	99.87	99.37	100.02	I70S	20020711	20020726
00006	222925477	100.02	100.39	100.05	I70S	20020711	20020726
00006	222925478	100.05	100.39	100.03	I70S	20020711	20020726
00006	222925479	99.96	99.56	100.08	I70S	20020711	20020726
00006	222925480	99.86	100.1	100.09	I70S	20020711	20020726
00006	222925481	99.89	99.9	100.02	I70S	20020711	20020726
00006	222925482	99.94	100.38	99.88	I70S	20020711	20020726
00006	222925483	99.95	99.53	100.08	I70S	20020711	20020726
00006	222925484	100.04	99.97	100.09	I70S	20020711	20020726
00006	222925485	99.97	99.95	100.05	I70S	20020711	20020726
00006	222925486	100.02	99.77	99.93	I70S	20020711	20020726
00006	222925487	100.03	100.12	99.94	I70S	20020711	20020726
00006	222925488	100.04	100.15	99.96	I70S	20020711	20020726
00006	222925489	100.05	99.57	100.02	I70S	20020711	20020726
00006	222925490	100.1	99.89	100.12	I70S	20020711	20020726
00006	222925491	100.01	99.89	99.94	I70S	20020711	20020726
00006	222925KV2	99.94	99.93	99.89	I70S	20020711	20020726
00006	223322010	99.91	99.97	100.01	I70S	20020911	20020927
00006	223322015	99.99	99.5	100.01	I70S	20020911	20020927
00006	223322016	99.96	100	100.04	I70S	20020911	20020927
00006	223322017	100.11	100.13	100	I70S	20020911	20020927
00006	223322018	99.95	100.33	100.06	I70S	20020911	20020927
00006	223322019	99.93	100.05	99.94	I70S	20020911	20020927
00006	223322020	100.03	100.26	100.02	I70S	20020911	20020927
00006	223322021	99.96	99.33	99.93	I70S	20020911	20020927
00006	223322022	100.01	100.12	99.88	I70S	20020911	20020927
00006	223322024	100.05	99.99	100.08	I70S	20020911	20020927
00006	223322025	100.02	100.48	100.13	I70S	20020911	20020927
00006	223322026	99.91	99.61	99.99	I70S	20020911	20020927
00006	223322027	100.02	100.27	100.04	I70S	20020911	20020927
00006	223322028	99.99	100.2	99.97	I70S	20020911	20020927
00006	223322033	99.97	100.45	99.89	I70S	20020911	20020927
00006	223322035	99.99	100.34	100.04	I70S	20020911	20020927
00006	223322036	99.98	100.3	99.88	I70S	20020911	20020927
00006	223322038	100.03	100.15	100.13	I70S	20020911	20020927
00006	223322040	100.03	100.01	99.97	I70S	20020911	20020927
00006	223322041	99.91	99.45	99.91	I70S	20020911	20020927
00006	223322042	100.1	100.5	99.99	I70S	20020911	20020927

KY CTESTS for 2002

00006	223322044	100.04	100.47	100.1	I70S	20020911	20020927
00006	223322045	99.98	100.06	100.1	I70S	20020911	20020927
00006	223322047	100.13	99.55	100.02	I70S	20020911	20020927
00006	223322050	99.97	99.91	100.1	I70S	20020911	20020927
00006	223322051	100.04	100.57	100.02	I70S	20020911	20020927
00006	223322052	99.98	99.75	99.91	I70S	20020911	20020927
00006	223322053	100	100.23	100.11	I70S	20020911	20020927
00006	223322056	100.01	100.04	99.98	I70S	20020911	20020927
00006	223322057	99.95	100.07	99.92	I70S	20020911	20020927
00006	223322058	100.04	100.05	100.01	I70S	20020911	20020927
00006	223322059	99.95	99.93	99.94	I70S	20020911	20020927
00006	223322062	100	100.21	100.14	I70S	20020911	20020927
00006	223322064	99.88	100.43	100.12	I70S	20020911	20020927
00006	223322065	100	100.28	99.93	I70S	20020911	20020927
00006	223322066	99.9	99.82	100.08	I70S	20020911	20020927
00006	223322067	100.09	99.92	100.08	I70S	20020911	20020927
00006	223322068	100.07	100.19	100	I70S	20020911	20020927
00006	223322069	100.11	100.49	100.11	I70S	20020911	20020927
00006	223322070	100.07	100.18	100.07	I70S	20020911	20020927
00006	223322071	99.93	100.47	100.01	I70S	20020911	20020927
00006	223322076	100.02	100.51	99.87	I70S	20020911	20020927
00006	223322078	100.03	100.11	99.87	I70S	20020911	20020927
00006	223322081	100.09	99.78	99.86	I70S	20020911	20020927
00006	223322087	99.87	100.47	99.89	I70S	20020911	20020927
00006	223322090	99.87	100.43	100.1	I70S	20020911	20020927
00006	223322091	99.96	99.84	99.92	I70S	20020911	20020927
00006	223322092	100.02	99.87	100.14	I70S	20020911	20020927
00006	223322557	100.05	99.84	99.92	I70S	20020911	20020927
00006	223322563	100.14	100.53	99.88	I70S	20020911	20020927
00006	223322621	100.09	100.18	100	I70S	20020911	20020927
00006	223322622	100.03	99.93	99.96	I70S	20020911	20020927
00006	223322623	100.14	100.47	100.04	I70S	20020911	20020927
00006	223322624	100.02	100.37	99.96	I70S	20020911	20020927
00006	223426457	99.91	99.7	100.14	I70S	20021105	20021114
00006	223426458	100.1	100.19	99.99	I70S	20021105	20021114
00006	223426459	100.06	99.97	100.06	I70S	20021105	20021114
00006	223426460	99.89	99.86	100.14	I70S	20021105	20021114
00006	223426461	100.1	100	99.97	I70S	20021105	20021114
00006	223426462	99.99	99.98	99.93	I70S	20021105	20021114
00006	223426463	99.96	99.79	100	I70S	20021105	20021114
00006	223426464	100.04	99.93	100.1	I70S	20021105	20021114
00006	223426465	100.07	99.74	100.14	I70S	20021105	20021114
00006	223426466	99.99	99.6	99.92	I70S	20021105	20021114
00006	223426467	100.04	100.13	100.02	I70S	20021105	20021114
00006	223426468	100.1	99.56	99.88	I70S	20021105	20021114
00006	223426469	100.07	99.67	100.03	I70S	20021105	20021114
00006	223426470	99.99	99.47	100.08	I70S	20021105	20021114
00006	223426471	99.95	99.54	100.04	I70S	20021105	20021114
00006	223426472	100.03	99.78	99.93	I70S	20021105	20021114
00006	223426473	100.04	100	100.06	I70S	20021105	20021114
00006	223426474	99.99	99.57	99.93	I70S	20021105	20021114
00006	223426475	99.95	100.07	99.91	I70S	20021105	20021114
00006	223426476	99.98	99.94	99.93	I70S	20021105	20021114
00006	223426477	100	100.45	100	I70S	20021105	20021114
00006	223426478	99.93	99.69	100.05	I70S	20021105	20021114
00006	223426479	99.95	100.06	99.95	I70S	20021105	20021114
00006	223426480	99.9	99.6	99.9	I70S	20021105	20021114
00006	223426481	99.97	99.55	100.11	I70S	20021105	20021114
00006	223426482	99.88	99.56	99.89	I70S	20021105	20021114
00006	223426483	99.96	100.4	100.05	I70S	20021105	20021114
00006	223426484	99.99	100.39	100.08	I70S	20021105	20021114

KY CTESTS for 2002

00006	223426485	100.09	99.42	99.91	I70S	20021105	20021114
00006	223426486	100.02	100.31	100.12	I70S	20021105	20021114
00006	223426487	100.11	100.34	100.1	I70S	20021105	20021114
00006	223426488	99.97	99.94	100.11	I70S	20021105	20021114
00006	223426489	100.1	99.58	100	I70S	20021105	20021114
00006	223426490	100.03	100.25	99.89	I70S	20021105	20021114
00006	223426491	100	100.19	99.95	I70S	20021105	20021114
00006	223426492	99.88	100.2	99.86	I70S	20021105	20021114
00006	223426493	99.98	99.78	100.07	I70S	20021105	20021114
00006	223426494	100.01	100.2	100.03	I70S	20021105	20021114
00006	223426495	100.03	100.39	99.99	I70S	20021105	20021114
00006	223426497	100.03	99.87	99.98	I70S	20021105	20021114
00006	223426498	100.03	100.07	100.09	I70S	20021105	20021114
00006	223426499	99.97	99.45	99.88	I70S	20021105	20021114
00006	223426500	99.89	100.55	100.08	I70S	20021105	20021114
00006	223426501	99.99	99.72	99.87	I70S	20021105	20021114
00006	223426502	100.01	100	100.14	I70S	20021105	20021114
00006	223426503	100.06	99.94	100.09	I70S	20021105	20021114
00006	223426504	100.06	100.12	99.99	I70S	20021105	20021114
00006	223426505	99.93	100.19	100.13	I70S	20021105	20021114
00006	223426506	100.06	100.36	100.1	I70S	20021105	20021114
00006	223426507	99.94	100.31	100.04	I70S	20021105	20021114
00006	223426508	100.08	99.99	100.08	I70S	20021105	20021114
00006	223426510	99.92	99.35	100.1	I70S	20021105	20021114
00006	223426513	99.94	100.64	100.07	I70S	20021105	20021114
00006	223426514	100.05	100.26	100.06	I70S	20021105	20021114
00006	223426515	99.99	99.33	99.92	I70S	20021105	20021114
00006	223426516	100.01	99.94	100.01	I70S	20021105	20021114
00006	223426517	100.12	100.29	100.09	I70S	20021105	20021114
00006	223426518	100.07	99.35	100.05	I70S	20021105	20021114
00006	223426519	99.97	99.76	100.05	I70S	20021105	20021114
00006	223426520	99.93	100.4	100.07	I70S	20021105	20021114
00006	223426521	99.9	99.67	99.86	I70S	20021105	20021114
00006	223426522	100.14	100.21	100.12	I70S	20021105	20021114
00006	223426523	99.91	100.69	99.94	I70S	20021105	20021114
00006	223426524	100.01	100.35	99.86	I70S	20021105	20021114
00006	223426525	100.02	100.17	100.04	I70S	20021105	20021114
00006	223426526	100.06	100.29	100.04	I70S	20021105	20021114
00006	223426527	100.09	99.72	100.07	I70S	20021105	20021114
00006	223426528	99.96	99.97	100.04	I70S	20021105	20021114
00006	223426529	100	99.64	100.1	I70S	20021105	20021114
00006	223426530	99.94	99.89	99.97	I70S	20021105	20021114
00006	223426531	100.05	100.55	100.03	I70S	20021105	20021114
00006	223426532	99.93	99.65	99.94	I70S	20021105	20021114
00006	223426533	99.96	99.6	100.07	I70S	20021105	20021114
00006	223426534	100.02	99.44	99.99	I70S	20021105	20021114
00006	223426535	100.08	99.87	100	I70S	20021105	20021114
00006	223426536	99.91	99.77	99.9	I70S	20021105	20021114
00006	223426537	100.04	99.7	99.9	I70S	20021105	20021114
00006	223426538	100.09	100	100.12	I70S	20021105	20021114
00006	223426539	99.99	99.6	99.91	I70S	20021105	20021114
00006	223426540	99.95	100.13	100.1	I70S	20021105	20021114
00006	223426541	99.95	100.34	100.06	I70S	20021105	20021114
00006	223426542	99.98	99.63	100.04	I70S	20021105	20021114
00006	223426543	99.92	99.79	100.1	I70S	20021105	20021114
00006	223426544	100.05	100.35	100.03	I70S	20021105	20021114
00006	223426545	100.01	99.63	100.08	I70S	20021105	20021114
00006	223426546	100.11	100.39	100.13	I70S	20021105	20021114
00006	223426547	99.92	100.55	99.94	I70S	20021105	20021114
00006	223426548	100.11	99.87	100.02	I70S	20021105	20021114
00006	223426549	100.08	99.85	100.14	I70S	20021105	20021114

KY CTESTS for 2002

00006	223426551	100.02	99.93	100.1	I70S	20021105	20021114
00006	223426552	99.98	99.78	100.01	I70S	20021105	20021114
00006	223432889	99.9	99.53	100.07	I70S	20021023	20021106
00006	223432890	100.02	99.79	100.07	I70S	20021023	20021106
00006	223432891	100.11	99.99	100.03	I70S	20021023	20021106
00006	223432892	100.08	100.31	100.07	I70S	20021023	20021106
00006	223432893	100.11	100.04	99.98	I70S	20021023	20021106
00006	223432894	99.93	100.35	99.91	I70S	20021023	20021106
00006	223432895	99.96	99.49	99.97	I70S	20021023	20021106
00006	223432896	100.04	99.6	100.01	I70S	20021023	20021106
00006	223432897	99.94	99.73	99.95	I70S	20021023	20021106
00006	223432898	100.05	99.39	100.03	I70S	20021023	20021106
00006	223432899	99.9	100.16	99.99	I70S	20021023	20021106
00006	223432900	99.96	100.05	100	I70S	20021023	20021106
00006	223432901	100.01	99.67	99.95	I70S	20021023	20021106
00006	223432902	100.04	99.94	100.14	I70S	20021023	20021106
00006	223432903	100.05	99.76	100.06	I70S	20021023	20021106
00006	223432904	99.97	99.66	100	I70S	20021023	20021106
00006	223432905	100.04	99.83	99.97	I70S	20021023	20021106
00006	223432906	100.11	99.86	99.97	I70S	20021023	20021106
00006	223432907	100.02	100.26	99.93	I70S	20021023	20021106
00006	223432908	100	100.16	100.14	I70S	20021023	20021106
00006	223432909	99.97	100.5	99.99	I70S	20021023	20021106
00006	223432910	100.03	99.88	100.06	I70S	20021023	20021106
00006	223432911	100.06	100.62	99.87	I70S	20021023	20021106
00006	223432912	100.03	100.41	99.87	I70S	20021023	20021106
00006	223432913	100	99.78	100.1	I70S	20021023	20021106
00006	223432914	99.94	100.26	99.92	I70S	20021024	20021106
00006	223432915	100.09	99.98	100.03	I70S	20021024	20021106
00006	223432916	99.98	99.83	100.06	I70S	20021024	20021106
00006	223432917	99.96	99.75	100.05	I70S	20021024	20021106
00006	223432918	99.98	99.92	100.08	I70S	20021024	20021106
00006	223432919	99.99	99.99	99.87	I70S	20021024	20021106
00006	223432920	100.08	100.38	100.05	I70S	20021024	20021106
00006	223432921	100.01	99.93	99.98	I70S	20021024	20021106
00006	223432922	100.06	100.04	99.98	I70S	20021024	20021106
00006	223432923	100.07	99.73	99.98	I70S	20021024	20021106
00006	223432924	100.01	100.03	100.07	I70S	20021024	20021106
00006	223432925	100.06	99.72	99.94	I70S	20021024	20021106
00006	223432926	99.98	99.43	100.08	I70S	20021024	20021106
00006	223432927	99.98	99.78	99.89	I70S	20021024	20021106
00006	223432928	100.12	99.79	99.97	I70S	20021024	20021106
00006	223432929	100.03	100.11	100.02	I70S	20021024	20021106
00006	223432930	100.1	100.28	100.08	I70S	20021024	20021106
00006	223432931	100.07	100.04	100.05	I70S	20021024	20021106
00006	223432932	100.07	99.99	99.91	I70S	20021024	20021106
00006	223432933	100.09	99.61	100.03	I70S	20021024	20021106
00006	223432934	99.9	99.35	99.86	I70S	20021024	20021106
00006	223432935	100.12	100.25	99.99	I70S	20021024	20021106
00006	223432936	99.98	99.87	99.87	I70S	20021024	20021106
00006	223432937	100.01	99.91	100.1	I70S	20021024	20021106
00006	223432938	99.94	99.76	99.89	I70S	20021024	20021106
00006	223432939	100.01	100.03	100.04	I70S	20021024	20021106
00006	223432940	100.1	100.07	99.98	I70S	20021024	20021106
00006	223432941	99.88	99.49	99.89	I70S	20021024	20021106
00006	223432942	99.99	100.09	100	I70S	20021024	20021106
00006	223432943	100.03	99.82	100.09	I70S	20021024	20021106
00006	223432944	100.08	99.32	100.03	I70S	20021024	20021106
00006	223432945	100.04	99.9	99.98	I70S	20021024	20021106
00006	223432946	99.97	99.73	99.87	I70S	20021024	20021106
00006	223432947	100.12	100.04	100.13	I70S	20021024	20021106

KY CTESTS for 2002

00006	223432948	100	99.99	100.11	170S	20021024	20021106
00006	223432949	100.01	99.71	99.96	170S	20021024	20021106
00006	223432950	100.11	100.63	100.13	170S	20021024	20021106
00006	223432951	99.91	99.49	100.04	170S	20021024	20021106
00006	223432952	100	100.19	99.95	170S	20021024	20021106
00006	223432953	99.86	100.02	100.07	170S	20021024	20021106
00006	223432954	100.14	100.28	99.91	170S	20021024	20021106
00006	223432955	99.99	99.89	99.95	170S	20021024	20021106
00006	223432956	100.04	100.37	100.07	170S	20021024	20021106
00006	223432957	100.04	99.95	100.12	170S	20021024	20021106
00006	223432958	100.09	99.72	100.03	170S	20021024	20021106
00006	223432959	99.92	99.91	100.09	170S	20021024	20021106
00006	223432960	99.96	99.74	99.89	170S	20021024	20021106
00006	223432961	100.01	99.47	100	170S	20021024	20021106
00006	223432962	99.97	99.65	100.04	170S	20021024	20021106
00006	223432963	100.08	100.21	100.11	170S	20021024	20021106
00006	223432964	100.06	99.83	99.97	170S	20021024	20021106
00006	223432965	100.02	99.78	99.86	170S	20021024	20021106
00006	223432966	100.06	99.81	100.07	170S	20021024	20021106
00006	223432967	100.12	99.9	100.04	170S	20021024	20021106
00006	223432968	99.89	99.7	99.97	170S	20021024	20021106
00006	223432969	100.02	99.6	99.9	170S	20021024	20021106
00006	223432970	99.91	99.68	99.97	170S	20021024	20021106
00006	223432971	100.03	99.61	100.06	170S	20021024	20021106
00006	223432972	99.94	99.49	99.89	170S	20021024	20021106
00006	223432973	100.14	99.85	100.05	170S	20021024	20021106
00006	223432974	99.95	99.68	99.91	170S	20021024	20021106
00006	223432975	99.96	99.84	100.11	170S	20021024	20021106
00006	223432976	100.09	100.06	100	170S	20021024	20021106
00006	223432977	100	99.56	100.12	170S	20021024	20021106
00006	223432978	99.91	99.78	100.08	170S	20021024	20021106
00006	223432979	99.99	99.83	100.07	170S	20021024	20021106
00006	223432980	99.99	99.78	99.93	170S	20021024	20021106
00006	223432981	99.99	99.59	99.92	170S	20021024	20021106
00006	223432982	100.07	99.59	100.05	170S	20021024	20021106
00006	223432983	100.02	99.82	100.08	170S	20021024	20021106
00006	223432984	100.06	100.03	100.02	170S	20021024	20021106
00006	223433293	100.03	99.63	100.1	170S	20021024	20021106
00006	223433294	99.94	100.14	99.93	170S	20021024	20021106
00006	223433295	99.96	99.65	99.89	170S	20021024	20021106
00006	223433296	100.02	99.43	100	170S	20021024	20021106
00006	223433465	100.09	100.4	100	170S	20021025	20021106
00006	223433466	99.89	100.62	99.94	170S	20021025	20021106
00006	223433467	100	100.01	99.99	170S	20021025	20021106
00006	223433468	100	99.66	99.94	170S	20021025	20021106
00006	223433469	100.07	99.75	100.03	170S	20021025	20021106
00006	223433470	100	100.69	100.09	170S	20021025	20021106
00006	223433471	100.04	99.44	100.02	170S	20021025	20021106
00006	223433472	100	100.38	100.13	170S	20021025	20021106
00006	223433473	100.06	99.69	99.93	170S	20021025	20021106
00006	223433474	100.1	100.34	99.92	170S	20021025	20021106
00006	223433475	100	99.61	100.12	170S	20021025	20021106
00006	223433476	99.93	99.55	99.91	170S	20021025	20021106
00006	223433477	100.03	100.08	100.08	170S	20021025	20021106
00006	223433478	100.02	100.29	100.11	170S	20021025	20021106
00006	223433479	100.13	99.72	100.1	170S	20021025	20021106
00006	223433480	100.02	99.99	99.98	170S	20021025	20021106
00006	223433481	99.91	99.82	99.95	170S	20021025	20021106
00006	223433482	100.07	99.33	100.12	170S	20021025	20021106
00006	223433483	100	99.93	99.93	170S	20021025	20021106
00006	223433484	100.02	100.22	100.13	170S	20021025	20021106

KY CTESTS for 2002

00006	223433485	99.93	99.85	100.01	I70S	20021025	20021106
00006	223433486	100.02	100.2	99.98	I70S	20021025	20021106
00006	223433487	99.98	99.78	99.95	I70S	20021025	20021106
00006	223433488	100.06	99.51	100.04	I70S	20021025	20021106
00006	223433489	100.04	100.43	99.91	I70S	20021025	20021106
00006	223433490	99.97	100.2	99.95	I70S	20021025	20021106
00006	223433491	99.93	99.97	100.05	I70S	20021025	20021106
00006	223433492	100.03	99.83	99.97	I70S	20021025	20021106
00006	223433493	99.89	100.61	99.86	I70S	20021025	20021106
00006	223433494	100.1	100.21	100.11	I70S	20021025	20021106
00006	223433495	100.01	99.83	100.04	I70S	20021025	20021106
00006	223433496	100.05	99.56	99.96	I70S	20021025	20021106
00006	223433497	100.02	100.13	100.13	I70S	20021025	20021106
00006	223433498	100	100.22	100.14	I70S	20021025	20021106
00006	223433499	100.07	100.18	100	I70S	20021025	20021106
00006	223433500	100.1	99.99	99.89	I70S	20021025	20021106
00006	223433501	100.02	100.01	100.13	I70S	20021025	20021106
00006	223433502	99.98	99.78	99.95	I70S	20021025	20021106
00006	223433503	100	100.38	100.13	I70S	20021025	20021106
00006	223433504	100.02	99.57	100.04	I70S	20021025	20021106
00006	223433505	100	100.5	100.03	I70S	20021025	20021106
00006	223433506	100.03	99.89	100.12	I70S	20021025	20021106
00006	223433507	99.97	99.94	99.89	I70S	20021025	20021106
00006	223433508	99.93	99.5	100.1	I70S	20021025	20021106
00006	223433509	100.08	100.13	100.04	I70S	20021025	20021106
00006	223433510	99.86	99.76	99.91	I70S	20021025	20021106
00006	223433511	99.99	99.43	100.08	I70S	20021025	20021106
00006	223433512	100.06	100.68	100.12	I70S	20021025	20021106
00006	223433513	100.08	99.94	100.02	I70S	20021025	20021106
00006	223433514	99.99	99.92	99.89	I70S	20021025	20021106
00006	223433515	100.07	100.56	100.13	I70S	20021025	20021106
00006	223433516	99.93	100.1	99.96	I70S	20021025	20021106
00006	223433517	99.97	100.52	99.91	I70S	20021025	20021106
00006	223433518	100.02	99.75	100.01	I70S	20021025	20021106
00006	223433519	100.05	100.02	100.14	I70S	20021025	20021106
00006	223433520	100.11	99.97	100.09	I70S	20021025	20021106
00006	223433521	100.05	100.37	99.94	I70S	20021025	20021106
00006	223433522	100.07	99.88	100.02	I70S	20021025	20021106
00006	223433523	100.13	99.78	100.1	I70S	20021025	20021106
00006	223433524	99.99	99.84	99.96	I70S	20021025	20021106
00006	223433525	99.97	99.55	100.09	I70S	20021025	20021106
00006	223433526	100.02	99.45	100.02	I70S	20021025	20021106
00006	223433527	100.12	99.76	100.14	I70S	20021025	20021106
00006	223433528	99.98	100.14	99.93	I70S	20021025	20021106
00006	223433529	100.02	100.09	100.06	I70S	20021025	20021106
00006	223433530	99.99	99.67	99.87	I70S	20021025	20021106
00006	223433531	100.14	100.47	100.13	I70S	20021025	20021106
00006	223433532	99.97	99.73	100.02	I70S	20021025	20021106
00006	223433533	100	99.6	100.12	I70S	20021025	20021106
00006	223433534	99.98	100.42	100.09	I70S	20021025	20021106
00006	223433535	99.94	99.67	99.91	I70S	20021025	20021106
00006	223433536	100.11	99.89	100.04	I70S	20021025	20021106
00006	223433537	99.96	100.14	99.89	I70S	20021025	20021106
00006	223433538	99.94	99.51	99.95	I70S	20021025	20021106
00006	223433539	99.97	99.39	99.91	I70S	20021025	20021106
00006	223433540	100.13	100.16	99.87	I70S	20021025	20021106
00006	223433541	100.01	99.63	99.96	I70S	20021025	20021106
00006	223433542	100.09	100.13	100.12	I70S	20021025	20021106
00006	223433543	100.04	100.13	99.97	I70S	20021025	20021106
00006	223433544	99.92	99.49	100.07	I70S	20021025	20021106
00006	223433545	100.04	99.66	99.91	I70S	20021025	20021106

KY CTESTS for 2002

00006	223433546	99.97	99.44	99.99	I70S	20021025	20021106
00006	223433547	100.12	99.91	100.01	I70S	20021025	20021106
00006	223433548	100.06	100.45	100.12	I70S	20021025	20021106
00006	223433549	99.91	99.89	100.02	I70S	20021025	20021106
00006	223433550	99.94	99.39	99.87	I70S	20021025	20021106
00006	223433551	99.92	100.53	99.89	I70S	20021025	20021106
00006	223433552	99.98	99.65	100	I70S	20021025	20021106
00006	223433553	99.94	100.15	99.9	I70S	20021025	20021106
00006	223433554	100.08	100.39	99.88	I70S	20021025	20021106
00006	223433555	99.87	100.59	99.95	I70S	20021025	20021106
00006	223433556	100.08	99.62	99.94	I70S	20021025	20021106
00006	223433557	100.04	99.86	99.89	I70S	20021025	20021106
00006	223433558	99.95	99.33	100.12	I70S	20021025	20021106
00006	223433559	100.04	99.67	100.02	I70S	20021025	20021106
00006	223433560	99.95	99.94	100.11	I70S	20021025	20021106
00006	223433945	99.97	99.87	100.02	I70S	20021110	20021125
00006	223433946	100.01	100.11	100.11	I70S	20021110	20021125
00006	223433947	99.91	100.07	99.98	I70S	20021110	20021125
00006	223433948	100.08	99.91	100.13	I70S	20021110	20021125
00006	223433949	100.04	100.66	100.1	I70S	20021110	20021125
00006	223433950	100.05	100.49	99.97	I70S	20021110	20021125
00006	223433951	100.01	99.57	99.86	I70S	20021110	20021125
00006	223433952	99.91	99.82	99.94	I70S	20021110	20021125
00006	223433953	99.94	100.25	99.91	I70S	20021110	20021125
00006	223433954	100.11	100.6	100.13	I70S	20021110	20021125
00006	223433955	99.96	100.64	99.99	I70S	20021110	20021125
00006	223433956	99.97	99.62	99.86	I70S	20021110	20021125
00006	223433957	100.1	99.78	100.12	I70S	20021110	20021125
00006	223433958	99.99	99.97	99.92	I70S	20021110	20021125
00006	223433959	99.99	100.62	99.93	I70S	20021110	20021125
00006	223433960	100.13	99.83	100.11	I70S	20021110	20021125
00006	223433961	100.02	100.22	100.04	I70S	20021110	20021125
00006	223433962	99.95	99.99	99.9	I70S	20021110	20021125
00006	223433963	100.12	100.29	100.1	I70S	20021110	20021125
00006	223433964	99.96	99.84	99.86	I70S	20021110	20021125
00006	223433965	100.1	100.29	100.12	I70S	20021110	20021125
00006	223433966	100	100.3	99.89	I70S	20021110	20021125
00006	223433967	99.99	99.56	100.02	I70S	20021110	20021125
00006	223433968	100.14	100.53	100.13	I70S	20021110	20021125
00006	223433969	99.89	100.28	100.04	I70S	20021110	20021125
00006	223433970	100.01	100.13	100	I70S	20021110	20021125
00006	223433971	100.08	99.74	100.14	I70S	20021110	20021125
00006	223433972	99.92	99.91	100.01	I70S	20021110	20021125
00006	223433973	99.89	99.86	99.87	I70S	20021110	20021125
00006	223433974	100.07	100.19	99.87	I70S	20021110	20021125
00006	223433975	100.06	100.19	99.95	I70S	20021110	20021125
00006	223433976	100	99.51	99.91	I70S	20021110	20021125
00006	223433977	99.97	100.22	99.94	I70S	20021110	20021125
00006	223433978	100.08	99.91	99.98	I70S	20021110	20021125
00006	223433979	99.87	99.62	100.12	I70S	20021110	20021125
00006	223433980	99.97	100.65	100	I70S	20021110	20021125
00006	223433981	100.03	100.09	99.96	I70S	20021110	20021125
00006	223433982	99.96	99.67	100.07	I70S	20021110	20021125
00006	223433983	99.99	99.9	100.06	I70S	20021110	20021125
00006	223433984	99.96	100.3	99.93	I70S	20021110	20021125
00006	223433985	99.98	100.04	99.88	I70S	20021110	20021125
00006	223433986	100.03	100.45	100.01	I70S	20021110	20021125
00006	223433987	100.07	100	100.06	I70S	20021110	20021125
00006	223433988	100.04	99.4	100.09	I70S	20021110	20021125
00006	223433989	99.87	99.59	100.08	I70S	20021110	20021125
00006	223433990	100.02	99.5	99.94	I70S	20021110	20021125

KY CTESTS for 2002

00006	223433991	100.01	100.16	100.03	I70S	20021110	20021125
00006	223433992	99.91	99.75	99.97	I70S	20021110	20021125
00006	223433993	100.03	100.09	100.13	I70S	20021110	20021125
00006	223433994	100.07	99.63	100.08	I70S	20021110	20021125
00006	223433995	100.13	100.03	100.04	I70S	20021110	20021125
00006	223433996	99.96	99.85	99.88	I70S	20021110	20021125
00006	223433997	99.96	100.17	99.97	I70S	20021110	20021125
00006	223433998	100	100.62	100.02	I70S	20021110	20021125
00006	223433999	100.11	100.18	100.1	I70S	20021110	20021125
00006	223434010	100.01	100.33	99.95	I70S	20021110	20021125
00006	223434011	100.08	99.96	100.09	I70S	20021110	20021125
00006	223434012	99.91	100.22	99.89	I70S	20021111	20021125
00006	223434013	100.05	99.82	99.89	I70S	20021111	20021125
00006	223434014	100.01	100.17	100.14	I70S	20021111	20021125
00006	223434015	99.97	100.11	99.92	I70S	20021111	20021125
00006	223434016	100.01	99.89	100.03	I70S	20021111	20021125
00006	223434017	99.9	100.04	99.91	I70S	20021111	20021125
00006	223434018	100.02	100.04	100	I70S	20021111	20021125
00006	223434019	100.03	100.27	99.9	I70S	20021111	20021125
00006	223434020	99.91	100.46	100.04	I70S	20021111	20021125
00006	223434021	100.07	100.07	100.1	I70S	20021111	20021125
00006	223434022	100.01	99.89	99.93	I70S	20021111	20021125
00006	223434023	100.05	100.58	100.13	I70S	20021111	20021125
00006	223434024	100.02	100.06	100.03	I70S	20021111	20021125
00006	223434025	99.93	100.68	100	I70S	20021111	20021125
00006	223434026	100	99.99	99.89	I70S	20021111	20021125
00006	223434027	99.95	99.93	100.06	I70S	20021111	20021125
00006	223434028	99.9	99.89	99.95	I70S	20021111	20021125
00006	223434029	99.98	100.01	99.98	I70S	20021111	20021125
00006	223434030	100.07	100.59	99.99	I70S	20021111	20021125
00006	223434031	100	100.21	100	I70S	20021111	20021125
00006	223434032	99.92	99.96	100.12	I70S	20021111	20021125
00006	223434033	99.93	100.1	99.95	I70S	20021111	20021125
00006	223434034	99.9	100.6	99.92	I70S	20021111	20021125
00006	223434035	100.09	99.92	100.11	I70S	20021111	20021125
00006	223434036	99.91	100.21	100.04	I70S	20021111	20021125
00006	223434037	100.03	100.19	100.04	I70S	20021111	20021125
00006	223434038	100.04	100.39	99.92	I70S	20021111	20021125
00006	223434039	99.99	100.12	100.09	I70S	20021111	20021125
00006	223434040	100.09	100.32	99.94	I70S	20021111	20021125
00006	223434137	99.97	100.14	100.11	I70S	20021111	20021125
00006	223434138	100.08	100.14	100.07	I70S	20021111	20021125
00006	223434139	99.93	100.01	99.89	I70S	20021111	20021125
00006	223434140	100.03	99.84	100.14	I70S	20021111	20021125
00006	223434141	99.94	100.18	100.06	I70S	20021111	20021125
00006	223434142	99.97	100.09	100.14	I70S	20021111	20021125
00006	223434143	100.01	99.99	100.07	I70S	20021111	20021125
00006	223434144	100.09	100.56	100.13	I70S	20021111	20021125
00006	223434145	99.98	100.09	100.12	I70S	20021111	20021125
00006	223434146	100.1	100.23	100.06	I70S	20021111	20021125
00006	223434147	100.07	100.01	100.1	I70S	20021111	20021125
00006	223434148	99.9	100	99.87	I70S	20021111	20021125
00006	223434149	100.03	100.04	100	I70S	20021111	20021125
00006	223434150	99.94	99.93	100.09	I70S	20021111	20021125
00006	223434151	100.13	100.32	99.97	I70S	20021111	20021125
00006	223434152	100	100.5	99.99	I70S	20021111	20021125
00006	223434153	100.02	100.65	99.93	I70S	20021111	20021125
00006	223434154	100.04	100.45	99.97	I70S	20021111	20021125
00006	223434155	100.09	99.73	100.14	I70S	20021111	20021125
00006	223434156	100.05	100	100.06	I70S	20021111	20021125
00006	223434157	99.94	99.61	100.14	I70S	20021111	20021125

KY CTESTS for 2002

00006	223434158	99.95	99.72	99.91	I70S	20021111	20021125
00006	223434159	99.87	99.98	100.1	I70S	20021111	20021125
00006	223434160	99.99	100.16	100.01	I70S	20021111	20021125
00006	223434161	100.05	100.11	100.03	I70S	20021111	20021125
00006	223434162	100.05	99.7	99.97	I70S	20021111	20021125
00006	223434163	100.09	99.94	99.92	I70S	20021111	20021125
00006	223434164	99.96	100.49	99.99	I70S	20021111	20021125
00006	223434165	100.14	100.52	100.04	I70S	20021111	20021125
00006	223434166	100.03	99.95	100.1	I70S	20021111	20021125
00006	223434167	100.06	99.97	100.03	I70S	20021111	20021125
00006	223434168	100.07	100.37	99.98	I70S	20021111	20021125
00006	223434169	100.01	99.77	100.08	I70S	20021111	20021125
00006	223434170	100.04	100.14	100.1	I70S	20021111	20021125
00006	223434171	99.9	100.12	99.87	I70S	20021111	20021125
00006	223434172	100.01	100.13	99.92	I70S	20021111	20021125
00006	223434173	100.01	100.07	100.14	I70S	20021111	20021125
00006	223434174	100.09	100.27	99.96	I70S	20021111	20021125
00006	223434175	100.09	100.14	100.11	I70S	20021111	20021125
00006	223434176	99.91	99.77	99.95	I70S	20021111	20021125
00006	223434177	99.94	100.23	100	I70S	20021111	20021125
00006	223434178	99.99	99.83	100.01	I70S	20021111	20021125
00006	223434179	100.01	100.02	99.9	I70S	20021111	20021125
00006	223434180	99.96	99.84	100.03	I70S	20021111	20021125
00006	223434181	99.93	99.96	100.04	I70S	20021111	20021125
00006	223434182	100.08	100.1	99.97	I70S	20021111	20021125
00006	223434183	99.99	99.88	100.06	I70S	20021111	20021125
00006	223434184	100.01	100.05	99.96	I70S	20021111	20021125
00006	223434185	100	100.5	100.07	I70S	20021111	20021125
00006	223434186	100.01	99.95	100.06	I70S	20021111	20021125
00006	223434187	100.07	100.52	99.89	I70S	20021111	20021125
00006	223434188	100.07	100.2	99.98	I70S	20021111	20021125
00006	223434189	100.02	100.14	99.95	I70S	20021111	20021125
00006	223434190	99.91	100.02	100.03	I70S	20021111	20021125
00006	223434191	99.88	99.96	99.96	I70S	20021111	20021125
00006	223434192	100	99.7	99.87	I70S	20021111	20021125
00006	223434193	100.01	99.43	99.88	I70S	20021111	20021125
00006	223434194	99.89	99.87	99.88	I70S	20021111	20021125
00006	223434195	99.9	100.12	99.86	I70S	20021111	20021125
00006	223434196	99.9	99.99	99.92	I70S	20021111	20021125
00006	223434197	100.08	100.35	99.89	I70S	20021111	20021125
00006	223434198	100	100.28	100.11	I70S	20021111	20021125
00006	223434199	100.04	99.74	99.9	I70S	20021111	20021125
00006	223434200	99.94	100.06	99.93	I70S	20021111	20021125
00006	223434201	99.93	100.17	99.89	I70S	20021111	20021125
00006	223434202	99.95	100.04	100	I70S	20021111	20021125
00006	223434203	100.07	100.34	100.07	I70S	20021111	20021125
00006	223434204	99.97	100.06	99.89	I70S	20021111	20021125
00006	223434205	100.12	100.2	99.94	I70S	20021111	20021125
00006	223434206	100.01	99.98	99.92	I70S	20021111	20021125
00006	223434207	100.05	99.89	99.92	I70S	20021111	20021125
00006	223434208	100.14	100.55	99.9	I70S	20021111	20021125
00006	223434209	100.03	99.78	100.05	I70S	20021111	20021125
00006	223434210	99.89	100.1	99.9	I70S	20021111	20021125
00006	223434211	100	99.91	99.92	I70S	20021111	20021125
00006	223434212	100.05	100.14	99.89	I70S	20021111	20021125
00006	223434213	99.97	100.04	100	I70S	20021111	20021125
00006	223434214	100.02	99.85	99.86	I70S	20021111	20021125
00006	223434215	99.98	99.87	99.91	I70S	20021111	20021125
00006	223434216	100.06	100.38	100.13	I70S	20021111	20021125
00006	223434217	100.02	100.21	99.99	I70S	20021111	20021125
00006	223434218	100	100.4	99.9	I70S	20021111	20021125

KY CTESTS for 2002

00006	223434219	100.04	100.44	100.02	I70S	20021111	20021125
00006	223434220	100.06	100.47	100.09	I70S	20021111	20021125
00006	223434221	99.93	99.51	100.02	I70S	20021111	20021125
00006	223434222	100.14	100.1	99.88	I70S	20021111	20021125
00006	223434223	100.02	100.08	100.14	I70S	20021111	20021125
00006	223434224	100.14	100.19	100.09	I70S	20021111	20021125
00006	223434225	100.01	100.15	100.02	I70S	20021111	20021125
00006	223434226	99.98	100.15	100.08	I70S	20021111	20021125
00006	223434227	100.01	99.71	99.87	I70S	20021111	20021125
00006	223434228	99.96	100.33	99.92	I70S	20021111	20021125
00006	223434229	100	100.31	99.9	I70S	20021111	20021125
00006	223434230	99.9	99.42	100.07	I70S	20021111	20021125
00006	223434231	99.91	99.77	100.08	I70S	20021111	20021125
00006	223434232	99.91	99.69	100	I70S	20021111	20021125
00006	22343KV20	100.01	99.99	99.86	I70S	20021110	20021125
00006	22343KV21	100.05	99.81	100.14	I70S	20021110	20021125
00006	22343KV22	100.09	99.87	100.12	I70S	20021110	20021125
00006	22343KV23	99.93	100.09	99.93	I70S	20021110	20021125
00006	22343KV24	99.89	100.64	99.96	I70S	20021110	20021125
00006	22343KV25	99.95	100.61	99.89	I70S	20021110	20021125
00006	22343KV26	99.96	99.68	100.03	I70S	20021110	20021125
00006	22343KV27	99.99	99.95	100	I70S	20021110	20021125
00006	22343KV28	100.1	99.82	100.06	I70S	20021110	20021125
00006	22343KV29	99.95	100.06	99.93	I70S	20021110	20021125
SNNA8	223530512	100.02	100.01	100.06	KVS	20021003	20021105
SNNA8	223530514	100	99.99	100.05	KVS	20021003	20021105
SNNA8	223530515	100.01	100.04	100.01	KVS	20021003	20021105
SNNA8	223530516	100	100.01	100.02	KVS	20021003	20021105
SNNA8	223530517	99.99	99.98	100.06	KVS	20021003	20021105
00006	224532776	100.05	99.96	99.97	I70S	20021126	20021206
00006	224532777	100.11	100.21	99.86	I70S	20021126	20021206
00006	224532778	99.96	99.77	100.11	I70S	20021126	20021206
00006	224532779	100.02	99.83	99.9	I70S	20021126	20021206
00006	224532780	100.05	100.51	100.03	I70S	20021126	20021206
00006	224532781	99.97	100.06	100.01	I70S	20021126	20021206
00006	224532782	100.07	100.3	100.1	I70S	20021126	20021206
00006	224532783	99.95	100.26	100.1	I70S	20021126	20021206
00006	224532784	99.94	99.8	99.94	I70S	20021126	20021206
00006	224532785	99.94	99.78	99.95	I70S	20021126	20021206
00006	224532786	100.09	99.97	99.99	I70S	20021126	20021206
00006	224532787	100.07	99.85	99.93	I70S	20021126	20021206
00006	224532788	99.95	100.17	100.04	I70S	20021126	20021206
00006	224532789	99.99	100.21	99.86	I70S	20021126	20021206
00006	224532790	99.99	99.97	100.14	I70S	20021126	20021206
00006	224532791	100.05	99.92	99.92	I70S	20021126	20021206
00006	224532792	100.05	100.1	99.99	I70S	20021126	20021206
00006	224532793	100.06	99.74	100	I70S	20021126	20021206
00006	224532794	99.92	100.18	99.92	I70S	20021126	20021206
00006	224532795	100.12	100.08	100.09	I70S	20021126	20021206
00006	224532796	99.87	99.94	99.98	I70S	20021126	20021206
00006	224532797	99.95	99.79	99.96	I70S	20021126	20021206
00006	224532798	99.9	100.14	99.94	I70S	20021126	20021206
00006	224532799	100.01	100.04	100.13	I70S	20021126	20021206
00006	224532800	100.06	100.04	99.93	I70S	20021126	20021206
00006	224532801	99.99	100.01	100.11	I70S	20021126	20021206
00006	224532802	100.11	99.68	100.1	I70S	20021126	20021206
00006	224532803	100.13	100.14	100.01	I70S	20021126	20021206
00006	224532804	100.06	99.8	100.13	I70S	20021126	20021206
00006	224532805	100.06	99.9	99.99	I70S	20021126	20021206
00006	224532806	100.09	100.29	100.11	I70S	20021126	20021206
00006	224532807	99.98	100.09	99.95	I70S	20021126	20021206

KY CTESTS for 2002

00006	224532808	100.04	99.71	100.02	I70S	20021126	20021206
00006	224532809	100.04	100.3	100.09	I70S	20021126	20021206
00006	224532810	100.01	100.2	99.95	I70S	20021126	20021206
00006	224532811	99.98	99.91	99.96	I70S	20021126	20021206
00006	224532812	100.1	100.08	100.02	I70S	20021126	20021206
00006	224532813	100.14	100.08	100.09	I70S	20021126	20021206
00006	224532814	100.08	100.41	99.98	I70S	20021126	20021206
00006	224532815	99.99	99.83	99.96	I70S	20021126	20021206
00006	224532816	99.99	100.1	100.14	I70S	20021126	20021206
00006	224532817	99.99	99.93	100.09	I70S	20021126	20021206
00006	224532818	100.11	100.31	99.89	I70S	20021126	20021206
00006	224532819	99.96	99.97	99.99	I70S	20021126	20021206
00006	224532820	100.01	100.16	100.11	I70S	20021126	20021206
00006	224532821	99.98	100.38	100	I70S	20021126	20021206
00006	224532822	100.05	100.3	99.93	I70S	20021126	20021206
00006	224532823	100.02	99.71	99.95	I70S	20021126	20021206
00006	224532824	100.02	100.22	100.05	I70S	20021126	20021206
00006	224532825	100.01	100.4	100.05	I70S	20021126	20021206
00006	224532826	99.97	99.9	100.06	I70S	20021126	20021206
00006	224532827	100.01	99.8	99.99	I70S	20021126	20021206
00006	224532828	99.99	99.92	99.86	I70S	20021126	20021206
00006	224532829	99.96	100.1	99.96	I70S	20021126	20021206
00006	224532830	100.02	100.22	99.93	I70S	20021126	20021206
00006	224532831	99.99	99.98	99.91	I70S	20021126	20021206
00006	224532832	99.98	100	100.03	I70S	20021126	20021206
00006	224532833	99.89	99.99	99.92	I70S	20021126	20021206
00006	224532834	99.88	100.4	100.08	I70S	20021126	20021206
00006	224532835	100.11	100.1	99.96	I70S	20021126	20021206
00006	224532836	100.05	99.72	100.04	I70S	20021126	20021206
00006	224532837	100.02	100.24	99.9	I70S	20021126	20021206
00006	224532838	100.1	99.94	100.07	I70S	20021126	20021206
00006	224532839	99.95	99.81	99.91	I70S	20021126	20021206
00006	224532840	100.05	99.83	100.11	I70S	20021126	20021206
00006	224532841	100.07	99.89	100.1	I70S	20021126	20021206
00006	224532842	100.03	99.98	99.86	I70S	20021126	20021206
00006	224532843	99.98	99.8	99.87	I70S	20021126	20021206
00006	224532844	100.02	100.04	100.12	I70S	20021126	20021206
00006	224532845	100.14	100.08	100.14	I70S	20021126	20021206
00006	224532846	99.99	100.21	99.96	I70S	20021126	20021206
00006	224532847	100.06	100.03	100.08	I70S	20021126	20021206
00006	224532848	100.03	99.75	100.01	I70S	20021126	20021206
00006	224532849	100.1	100.1	100.06	I70S	20021126	20021206
00006	224532850	100.06	100.07	100.12	I70S	20021126	20021206
00006	224532851	100.07	99.67	99.95	I70S	20021126	20021206
00006	224532852	100.01	100.28	99.97	I70S	20021126	20021206
00006	224532853	99.92	99.83	100.11	I70S	20021126	20021206
00006	224532854	99.96	99.76	99.93	I70S	20021126	20021206
00006	224532855	99.92	100.01	100.03	I70S	20021126	20021206
00006	224532856	99.94	100.17	100.06	I70S	20021126	20021206
00006	224532857	100	100.21	99.87	I70S	20021126	20021206
00006	224532858	99.97	99.82	99.92	I70S	20021126	20021206
00006	224532859	99.92	99.73	99.91	I70S	20021126	20021206
00006	224532860	100.04	100.03	99.9	I70S	20021126	20021206
00006	224532861	99.98	100.14	100.02	I70S	20021126	20021206
00006	224532862	100.08	100.05	99.86	I70S	20021126	20021206
00006	224532863	99.94	99.81	99.95	I70S	20021126	20021206
00006	224532864	100.09	99.81	100.02	I70S	20021126	20021206
00006	224532865	100.06	99.94	99.94	I70S	20021126	20021206
00006	224532866	99.95	100.03	100.12	I70S	20021126	20021206
00006	224532867	99.99	99.95	99.98	I70S	20021126	20021206
00006	224532868	100.05	100	99.86	I70S	20021126	20021206

KY CTESTS for 2002

00006	224532869	100	99.93	99.88	I70S	20021126	20021206
00006	224532870	100.09	100.17	99.97	I70S	20021126	20021206
00006	224532871	99.98	100.01	100.03	I70S	20021126	20021206
GNNA1	321344315	100	99.99	100.01	KV2	20011206	20020101
GNNA1	321344316	99.99	99.96	99.98	KV2	20011206	20020101
GNNA1	321344317	100	99.99	100.01	KV2	20011206	20020101
GNNA1	321344318	100	99.98	100.01	KV2	20011206	20020101
GNNA1	321344319	100	99.99	100.01	KV2	20011206	20020101
GNNA1	321344320	100	100	100	KV2	20011206	20020101
GNNA1	321344321	100	99.98	100	KV2	20011206	20020101
GNNA1	321344322	100	99.99	100	KV2	20011206	20020101
GNNA1	321344327	100	99.98	100.01	KV2	20011206	20020101
GNNA1	321344328	100	99.98	100.02	KV2	20011206	20020101
GNNA1	321344329	100	100	100.02	KV2	20011206	20020101
GNNA1	321344330	100	99.98	100.02	KV2	20011206	20020101
GNNA1	321344351	100	99.99	100.03	KV2	20011206	20020101
GNNA1	321344352	100	99.99	100.02	KV2	20011206	20020101
GNNA1	321344353	100	99.98	100.01	KV2	20011206	20020101
GNNA1	321344354	100.01	99.98	100	KV2	20011206	20020101
GNNA1	321344355	100	99.99	100.01	KV2	20011206	20020101
GNNA1	321344356	100	99.98	100.02	KV2	20011206	20020101
GNNA1	321344357	100.01	99.96	100	KV2	20011206	20020101
GNNA1	321344358	100	99.99	100.02	KV2	20011206	20020101
GNNA1	321344411	100	99.98	100.02	KV2	20011206	20020101
GNNA1	321344412	100	99.98	100.01	KV2	20011206	20020101
GNNA1	321344413	100	100	100.01	KV2	20011206	20020101
GNNA1	321344414	100	99.97	99.99	KV2	20011206	20020101
GNNA1	321344415	100	99.96	100	KV2	20011206	20020101
GNNA1	321344416	100	99.98	100.02	KV2	20011206	20020101
GNNA1	321344417	100	99.98	100.02	KV2	20011206	20020101
GNNA1	321344418	100.01	99.98	100.02	KV2	20011206	20020101
GNNA1	321344419	100	99.98	100.01	KV2	20011206	20020101
GNNA1	321344420	100	99.99	100.01	KV2	20011206	20020101
GNNA1	321344421	100	99.98	100.01	KV2	20011206	20020101
GNNA1	321344422	100	100	100.02	KV2	20011206	20020101
GNNA1	321344435	100	99.98	100.02	KV2	20011206	20020101
GNNA1	321344436	100	99.99	100.03	KV2	20011206	20020101
GNNA1	321344437	99.99	99.99	100.02	KV2	20011206	20020101
GNNA1	321344438	100	99.99	99.99	KV2	20011206	20020101
GNNA1	321344499	100	99.98	100.01	KV2	20011206	20020101
GNNA1	321344500	100	99.98	100.02	KV2	20011206	20020101
GNNA1	321344501	100	99.99	100.02	KV2	20011206	20020101
GNNA1	321344502	100	99.99	100.01	KV2	20011206	20020101
GNNA1	321344563	100	99.99	100.03	KV2	20011206	20020101
GNNA1	321344564	100	99.99	100.01	KV2	20011206	20020101
GNNA1	321344565	100	99.99	100.01	KV2	20011206	20020101
GNNA1	321344566	100	99.97	100.01	KV2	20011206	20020101
GNNA1	321344I70S	99.99	99.99	100.01	KV2	20011206	20020101
GNNA8	321347793	100	100.02	100.01	KV2	20011213	20020101
GNNA8	321347794	100	100.01	100.03	KV2	20011213	20020101
GNNA8	321347795	100	99.98	100.04	KV2	20011213	20020101
GNNA8	321347796	100.01	99.97	100.04	KV2	20011213	20020101
GNNA8	321347797	100.01	99.97	100.05	KV2	20011213	20020101
GNNA8	321347798	100	99.98	100.07	KV2	20011213	20020101
GNNA8	321347799	100.01	100.01	100.03	KV2	20011213	20020101
GNNA8	321347800	100	99.97	100.03	KV2	20011213	20020101
GNNA8	321347813	100	100.01	100.03	KV2	20011213	20020101
GNNA8	321347814	100	99.97	100.04	KV2	20011213	20020101
GNNA8	321347815	100.01	99.98	100.03	KV2	20011213	20020101
GNNA8	321347816	100	99.98	100.08	KV2	20011213	20020101
GNNA8	321347821	100	100.01	100.02	KV2	20011213	20020101

KY CTESTS for 2002

GNNA8	321347822	100	99.98	100.04	KV2	20011213	20020101
GNNA8	321347823	100	99.97	100.02	KV2	20011213	20020101
GNNA8	321347824	100.01	100.01	100.03	KV2	20011213	20020101
GNNA8	321347829	100	100.01	100.02	KV2	20011213	20020101
GNNA8	321347832	100	99.99	100.04	KV2	20011213	20020101
GNNA1	321348284	100	99.98	100.02	KV2	20011212	20020101
GNNA1	321348286	100	99.98	100	KV2	20011212	20020101
GNNA1	321348287	100	99.98	99.99	KV2	20011212	20020101
GNNA1	321348288	100	99.98	100.01	KV2	20011212	20020101
GNNA1	321348289	100	99.99	100.02	KV2	20011212	20020101
GNNA1	321348291	100	99.98	99.99	KV2	20011212	20020101
GNNA1	321348296	100	99.98	100.01	KV2	20011212	20020101
GNNA1	321348298	100	99.97	100	KV2	20011212	20020101
GNNA1	321348300	100	99.99	100	KV2	20011212	20020101
GNNA1	321348301	100	99.99	100	KV2	20011212	20020101
GNNA1	321348302	100	99.98	100.03	KV2	20011212	20020101
GNNA1	321348303	100	99.98	100.01	KV2	20011212	20020101
GNNA1	321348304	100	99.98	100	KV2	20011212	20020101
GNNA1	321348305	100.01	99.98	100.01	KV2	20011212	20020101
GNNA1	321348306	99.99	99.99	100.01	KV2	20011212	20020101
GNNA1	321348398	100	100	100.03	KV2	20011213	20020101
GNNA1	321348436	100	99.98	100.01	KV2	20011213	20020101
GNNA1	321348437	100	99.98	100.01	KV2	20011213	20020101
GNNA1	321348438	100	99.98	100.02	KV2	20011213	20020101
GNNA1	321348439	100	99.99	100	KV2	20011213	20020101
GNNA1	321348468	99.99	99.98	100.02	KV2	20011213	20020101
GNNA1	321348469	100	99.98	100.01	KV2	20011213	20020101
GNNA1	321348470	100	99.99	100.02	KV2	20011213	20020101
GNNA1	321348471	100.01	100	100.02	KV2	20011213	20020101
GNNA1	321348473	100	99.99	100.02	KV2	20011213	20020101
GNNA1	321348474	100	100	100.01	KV2	20011213	20020101
GNNA1	321348475	100	99.99	100.01	KV2	20011213	20020101
GNNA1	321348504	100	99.98	100.02	KV2	20011218	20020101
GNNA1	321348505	100	99.97	100.01	KV2	20011218	20020101
GNNA1	321348506	100	99.97	100	KV2	20011218	20020101
GNNA1	321348507	100	99.99	100	KV2	20011218	20020101
GNNA1	321348516	100	99.99	100	KV2	20011218	20020101
GNNA1	321348517	100	99.99	100	KV2	20011218	20020101
GNNA1	321348518	100	99.99	100.01	KV2	20011218	20020101
GNNA1	321348519	100.01	99.98	100.02	KV2	20011218	20020101
G60F8	321348749	100	100.01	100.02	KV2	20011214	20020101
G60F8	321348750	100.01	99.97	100.01	KV2	20011214	20020101
G60F8	321348785	99.99	99.97	100.03	KV2	20011214	20020101
G60F8	321348786	99.99	100.01	99.98	KV2	20011214	20020101
G60F8	321348787	100	100.01	100.02	KV2	20011214	20020101
G60F8	321348788	100.01	99.98	100	KV2	20011214	20020101
G60F8	321348789	100	100.01	99.97	KV2	20011214	20020101
G60F8	321348790	99.99	99.97	100.03	KV2	20011214	20020101
G60F8	321348791	100	100.01	99.99	KV2	20011214	20020101
G60F8	321348792	100	100.02	100.03	KV2	20011214	20020101
G60F8	321348793	100	99.96	100.04	KV2	20011214	20020101
G60F8	321348794	100	100.01	100	KV2	20011214	20020101
G60F8	321348795	100.01	99.97	100.01	KV2	20011214	20020101
G60F8	321348796	100	99.95	100.02	KV2	20011214	20020101
G60F8	321348833	100	100.01	100.02	KV2	20011216	20020101
G60F8	321348834	99.99	100.02	99.97	KV2	20011216	20020101
G60F8	321348835	100	99.96	100	KV2	20011216	20020101
G60F8	321348836	100	99.98	100	KV2	20011216	20020101
G60F8	321348837	100	100.01	100.01	KV2	20011216	20020101
G60F8	321348838	100	100.01	99.98	KV2	20011216	20020101
G60F8	321348839	100	99.98	100	KV2	20011216	20020101

KY CTESTS for 2002

G60F8	321348840	100	99.96	100.04	KV2	20011216	20020101
G60F8	321348841	100	100.01	100.04	KV2	20011216	20020101
G60F8	321348842	100	99.98	100.03	KV2	20011216	20020101
G60F8	321348843	100	99.95	100	KV2	20011216	20020101
G60F8	321348844	100	99.97	100	KV2	20011216	20020101
G60F8	321348853	100	100	100.02	KV2	20011216	20020101
G60F8	321348854	100.02	99.98	100.06	KV2	20011216	20020101
G60F8	321348855	99.99	99.95	100.06	KV2	20011216	20020101
G60F8	321348856	100	100.02	100.04	KV2	20011216	20020101
G60F8	321348869	100	99.95	100.04	KV2	20011216	20020101
G60F8	321348870	100	99.97	100.03	KV2	20011216	20020101
G60F8	321348871	100	100.01	100.01	KV2	20011216	20020101
G60F8	321348872	100	99.98	100.03	KV2	20011216	20020101
G60F8	321348873	100	99.95	100	KV2	20011216	20020101
G60F8	321348874	100	99.96	100.02	KV2	20011216	20020101
G60F8	321348875	100.01	100	100.02	KV2	20011216	20020101
G60F8	321348876	100	100.02	100.02	KV2	20011216	20020101
GNNA8	321351856	100	99.96	100	KV2	20011214	20020102
GNNA8	321351857	99.99	100	100	KV2	20011214	20020102
GNNA8	321351858	100	100.02	100.02	KV2	20011214	20020102
GNNA8	321351859	99.99	99.97	100.02	KV2	20011214	20020102
GNNA8	321351860	99.99	100.02	100.01	KV2	20011214	20020102
GNNA8	321351861	100.01	99.98	100.05	KV2	20011214	20020102
GNNA8	321351862	99.99	99.99	100.03	KV2	20011214	20020102
GNNA8	321351863	100	100.01	100.03	KV2	20011214	20020102
GNNA8	321351864	100	99.98	100.03	KV2	20011214	20020102
GNNA8	321351865	100	100	100.02	KV2	20011214	20020102
GNNA8	321351866	100	100	100.03	KV2	20011214	20020102
GNNA8	321351867	100	99.99	100.04	KV2	20011214	20020102
GNNA8	321415519	100.01	100	100.02	KV2	20020403	20020503
GNNA8	321415520	100	100.01	100.02	KV2	20020403	20020503
GNNA8	321415521	100	100.02	100.04	KV2	20020403	20020503
GNNA8	321415522	100.01	99.98	100.07	KV2	20020403	20020503
GNNA8	321415523	100	99.97	100.02	KV2	20020403	20020503
GNNA8	321415526	100.01	99.98	100.05	KV2	20020403	20020503
GNNA8	321415527	100	100.02	100.06	KV2	20020403	20020503
GNNA8	321415528	100	100.02	100.02	KV2	20020403	20020503
GNNA8	321415529	100	99.99	100.03	KV2	20020403	20020503
GNNA8	321415530	100.01	99.99	100.06	KV2	20020403	20020503
GNNA8	321415532	100	100.01	100.01	KV2	20020403	20020503
GNNA8	321415533	100	99.98	100.04	KV2	20020403	20020503
GNNA8	321415535	100	100.01	100.02	KV2	20020403	20020503
GNNA8	321415536	99.99	100.02	100.01	KV2	20020403	20020503
GNNA8	321415537	100.01	100.03	100.04	KV2	20020403	20020503
GNNA8	321415538	100.01	99.99	100.04	KV2	20020403	20020503
GNNA8	321415567	100.01	99.98	100.04	KV2	20020403	20020503
GNNA8	321415568	100	99.98	100.03	KV2	20020403	20020503
GNNA8	321415569	100	99.96	100.01	KV2	20020403	20020503
GNNA8	321415570	100	99.99	100.01	KV2	20020403	20020503
GNNA8	321415579	100	100.02	100.02	KV2	20020403	20020503
GNNA8	321415580	100	100.01	100.04	KV2	20020403	20020503
GNNA8	321415581	100	100	100.04	KV2	20020403	20020503
GNNA8	321415582	100.02	99.98	100.05	KV2	20020403	20020503
GNNA8	321415583	100	99.98	100.05	KV2	20020403	20020503
GNNA8	321415584	100	99.97	100.04	KV2	20020403	20020503
GNNA8	321415585	100	99.98	100.01	KV2	20020403	20020503
GNNA8	321415586	100	99.99	99.99	KV2	20020403	20020503
GNNA1	321415727	100	99.99	100.01	KV2	20020403	20020412
GNNA1	321415728	100.01	99.98	100.01	KV2	20020403	20020412
GNNA1	321415729	100	99.98	99.99	KV2	20020403	20020412
GNNA1	321415730	100	100	100	KV2	20020403	20020412

KY CTESTS for 2002

GNNA1	321415731	100	99.99	100.01	KV2	20020403	20020412
GNNA1	321415732	100	99.99	100	KV2	20020403	20020412
GNNA1	321415733	100.01	99.99	100.02	KV2	20020403	20020412
GNNA1	321415734	100	99.99	100	KV2	20020403	20020412
GNNA1	321415751	100	99.99	100.01	KV2	20020403	20020412
GNNA1	321415752	100	99.99	100.01	KV2	20020403	20020412
GNNA1	321415753	100	99.98	100.02	KV2	20020403	20020412
GNNA1	321415754	100	99.98	100	KV2	20020403	20020412
GNNA1	321415819	100.01	99.99	100.01	KV2	20020403	20020412
GNNA1	321415820	100	99.98	99.99	KV2	20020404	20020412
GNNA1	321415821	100.01	99.99	100.02	KV2	20020404	20020412
GNNA1	321415822	100	99.99	100	KV2	20020404	20020412
GNNA1	321415823	100	100	100.01	KV2	20020404	20020412
GNNA1	321415824	100	99.98	100	KV2	20020404	20020412
GNNA1	321415825	100	99.99	100.01	KV2	20020404	20020412
GNNA1	321415826	100	99.98	100.02	KV2	20020404	20020412
GNNA1	321415891	100.01	99.99	100.03	KV2	20020404	20020412
GNNA1	321415892	100	99.98	100	KV2	20020404	20020412
GNNA1	321415893	100	99.99	99.99	KV2	20020404	20020412
GNNA1	321415894	100	99.97	100.01	KV2	20020404	20020412
GNNA1	321415899	100.01	99.99	100	KV2	20020404	20020412
GNNA1	321415900	100.01	99.98	100.01	KV2	20020404	20020412
GNNA1	321415901	100.01	100	100.01	KV2	20020404	20020412
GNNA1	321415902	100	99.98	100	KV2	20020404	20020412
GNNA1	321437742	100	99.99	100.02	KV2	20020606	20020627
GNNA1	321437743	100	99.97	100	KV2	20020606	20020627
GNNA1	321437744	100	99.99	100.02	KV2	20020606	20020627
GNNA1	321437745	100.01	99.99	100.01	KV2	20020606	20020627
GNNA1	321437746	100	99.96	100.01	KV2	20020606	20020627
GNNA1	321437747	100	99.99	100.02	KV2	20020606	20020627
GNNA1	321437748	100.01	99.99	100.03	KV2	20020606	20020627
GNNA1	321437749	100	99.99	100.02	KV2	20020606	20020627
GNNA1	321437750	100	99.98	100	KV2	20020606	20020627
GNNA1	321437751	100	99.99	99.99	KV2	20020606	20020627
GNNA1	321437752	100	99.99	100.02	KV2	20020606	20020627
GNNA1	321437753	100.01	99.99	100.02	KV2	20020606	20020627
GNNA1	321437762	100.01	99.97	100	KV2	20020606	20020627
GNNA1	321437763	100	99.99	100	KV2	20020606	20020627
GNNA1	321437764	100.01	100	100.01	KV2	20020606	20020627
GNNA1	321437765	100	100	99.99	KV2	20020606	20020627
GNNA1	321437822	100	100	100.01	KV2	20020606	20020627
GNNA1	321437823	100	99.99	100	KV2	20020606	20020627
GNNA1	321437824	100	99.98	100	KV2	20020606	20020627
GNNA1	321437825	100	99.99	100.01	KV2	20020606	20020627
GNNA1	321437846	100	100	100	KV2	20020606	20020627
GNNA1	321437847	100	99.99	100.02	KV2	20020606	20020627
GNNA1	321437848	100.01	99.97	100.03	KV2	20020606	20020627
GNNA1	321437849	100	99.99	100.02	KV2	20020606	20020627
GNNA1	321437851	100	99.99	100.01	KV2	20020606	20020627
GNNA1	321437852	100	99.99	100	KV2	20020606	20020627
GNNA1	321437853	100.01	99.99	100.03	KV2	20020606	20020627
GNNA1	321437886	100	100	100.02	KV2	20020430	20020530
GNNA1	321437887	100	99.99	100.01	KV2	20020430	20020530
GNNA1	321437888	100	99.99	100.01	KV2	20020430	20020530
GNNA1	321437889	100	99.99	100.01	KV2	20020430	20020530
GNNA1	321437906	100	99.99	100.02	KV2	20020430	20020530
GNNA1	321437907	100.01	99.99	100.03	KV2	20020430	20020530
GNNA1	321437908	100	99.99	100.03	KV2	20020430	20020530
GNNA1	321437909	100	99.99	100.02	KV2	20020430	20020530
GNNA1	321437930	100	99.99	100	KV2	20020430	20020530
GNNA1	321437931	100	99.98	99.99	KV2	20020430	20020530

KY CTESTS for 2002

GNNA1	321437932	100.01	100	100.03	KV2	20020430	20020530
GNNA1	321437933	100	99.99	100.02	KV2	20020430	20020530
GNNA1	321437934	100	99.98	100.01	KV2	20020430	20020530
GNNA1	321437935	100	99.99	100.01	KV2	20020430	20020530
GNNA1	321437982	100	99.98	100.01	KV2	20020501	20020530
GNNA1	321437983	100	100	100.05	KV2	20020501	20020530
GNNA1	321437984	100	99.99	100	KV2	20020501	20020530
GNNA1	321437985	100.01	99.99	100.04	KV2	20020501	20020530
GNNA1	321438014	100	99.99	100.02	KV2	20020501	20020530
GNNA1	321438021	100	99.99	100.03	KV2	20020501	20020530
GNNA1	321438022	100	99.98	99.99	KV2	20020501	20020530
GNNA1	321438023	100	99.98	100.01	KV2	20020501	20020530
GNNA1	321438025	100.01	99.98	100.03	KV2	20020501	20020530
GNNA1	321438027	100.01	99.99	100.02	KV2	20020501	20020530
GNNA1	321438028	100	99.99	100.01	KV2	20020501	20020530
GNNA1	321438029	100	100	100.03	KV2	20020501	20020530
GNNA1	321438032	100	99.99	100.01	KV2	20020501	20020530
GNNA1	321438034	100	99.98	100.01	KV2	20020501	20020530
GNNA1	321438035	100	99.98	100	KV2	20020501	20020530
GNNA1	321438036	100	99.99	100.01	KV2	20020501	20020530
GNNA8	321476361	100.02	99.98	100.06	KV2	20020617	20020702
GNNA8	321476362	100	100.02	100.03	KV2	20020617	20020702
GNNA8	321476363	100.01	100.02	100.03	KV2	20020617	20020702
GNNA8	321476388	100	100.01	100	KV2	20020617	20020702
GNNA8	321476389	100	99.96	100.03	KV2	20020617	20020702
GNNA8	321476390	100.01	100.02	100.09	KV2	20020617	20020702
GNNA8	321476391	100	99.99	100.03	KV2	20020617	20020702
GNNA8	321476396	100	100.01	100.03	KV2	20020617	20020702
GNNA8	321476397	100	99.98	100.02	KV2	20020617	20020702
GNNA8	321476398	100	100.01	100.03	KV2	20020617	20020702
GNNA8	321476399	100.01	99.98	100.02	KV2	20020617	20020702
GNNA1	321476420	100	99.99	100	KV2	20020618	20020702
GNNA1	321476421	100	100	100.02	KV2	20020618	20020702
GNNA1	321476422	100.01	99.99	100.01	KV2	20020618	20020702
GNNA1	321476423	100	99.99	100	KV2	20020618	20020702
GNNA1	321476424	100	100	100	KV2	20020618	20020702
GNNA1	321476425	100	99.99	99.98	KV2	20020618	20020702
GNNA1	321476426	100	99.98	100	KV2	20020618	20020702
GNNA1	321476427	100	99.99	100	KV2	20020618	20020702
GNNA1	321476452	100	99.99	100.02	KV2	20020618	20020702
GNNA1	321476484	100	99.99	100	KV2	20020618	20020702
GNNA1	321476487	100	99.99	100	KV2	20020618	20020702
GNNA1	321476768	100	99.98	100.01	KV2	20020627	20020702
GNNA1	321476769	100	99.99	100.01	KV2	20020627	20020702
GNNA1	321476770	100	99.99	100.01	KV2	20020627	20020702
GNNA1	321476771	100	99.99	100	KV2	20020627	20020702
GNNA1	321476776	100	100	99.98	KV2	20020627	20020702
GNNA1	321476777	100	99.99	99.99	KV2	20020627	20020702
GNNA1	321476778	100	100	99.99	KV2	20020627	20020702
GNNA1	321476779	100	99.99	100	KV2	20020627	20020702
GNNA1	321476792	100	99.99	100.01	KV2	20020627	20020702
GNNA1	321476793	100	99.99	99.98	KV2	20020627	20020702
GNNA1	321476794	100.01	100	100.02	KV2	20020627	20020702
GNNA1	321476795	100	99.99	100	KV2	20020627	20020702
GNNA1	321476804	100.01	99.99	100.01	KV2	20020627	20020702
GNNA1	321476805	100	99.99	100	KV2	20020627	20020702
GNNA1	321476808	100	99.99	100	KV2	20020627	20020702
GNNA1	321476809	100.01	99.99	99.99	KV2	20020627	20020702
GNNA1	321476810	100	100	100.01	KV2	20020627	20020702
GNNA1	321476811	100.01	99.99	100	KV2	20020627	20020702
GNNA1	321476812	100.01	99.99	100	KV2	20020627	20020702

KY CTESTS for 2002

GNNA1	321476813	100	99.99	100.01	KV2	20020627	20020702
GNNA1	321476814	100	99.99	100	KV2	20020627	20020702
GNNA1	321476815	100	99.99	99.99	KV2	20020627	20020702
GNNA8	321476170S	100	99.97	100.06	KV2	20020617	20020702
G60F8	321480527	100	99.96	100.01	KV2	20020711	20020718
G60F8	321480528	100	100.01	100.03	KV2	20020711	20020718
G60F8	321480529	100	100.01	100.01	KV2	20020711	20020718
G60F8	321480530	100	100.02	100.02	KV2	20020711	20020718
G60F8	321480567	100	99.95	100.02	KV2	20020711	20020718
G60F8	321480568	100	100.01	100.05	KV2	20020711	20020718
G60F8	321480569	100	100.01	100	KV2	20020711	20020718
G60F8	321480570	100	99.98	100.01	KV2	20020711	20020718
G60F8	321481415	100	99.95	100.03	KV2	20020730	20020805
GNNA1	321AX359	100	99.98	100	KV2	20020123	20020221
GNNA1	321AX373	100	99.99	100	KV2	20020123	20020221
GNNA1	321AX374	100	99.99	100	KV2	20020123	20020221
GNNA1	321AX375	100	99.99	100	KV2	20020123	20020221
GNNA1	321AX376	100	99.98	100.01	KV2	20020123	20020221
GNNA1	321AX385	100	99.98	100.01	KV2	20020124	20020221
GNNA1	321AX386	100	99.99	100.01	KV2	20020124	20020221
GNNA1	321AX387	100	99.98	100	KV2	20020124	20020221
GNNA1	321AX388	100.01	99.99	100.02	KV2	20020124	20020221
GNNA1	321AX397	100	99.99	100	KV2	20020124	20020221
GNNA1	321AX398	100	99.99	100.02	KV2	20020124	20020221
GNNA1	321AX399	100	99.99	100.01	KV2	20020124	20020221
GNNA1	321AX409	100	99.99	100.01	KV2	20020124	20020221
GNNA1	321AX410	100	99.99	100.02	KV2	20020124	20020221
GNNA1	321AX411	100.01	100	100.03	KV2	20020124	20020221
GNNA1	321AX412	100	99.99	100.01	KV2	20020124	20020221
GNNA1	321AX529	100	99.98	100.01	KV2	20020125	20020328
GNNA1	321AX530	100	99.99	100.03	KV2	20020125	20020328
GNNA1	321AX531	100	99.99	100.01	KV2	20020125	20020328
GNNA1	321AX532	100	99.98	100.01	KV2	20020125	20020328
GNNA1	321AX537	100	99.99	100.01	KV2	20020125	20020328
GNNA1	321AX538	100	99.99	100.02	KV2	20020125	20020328
GNNA1	321AX539	100	99.98	100	KV2	20020125	20020328
GNNA1	321AX540	100	99.99	100.02	KV2	20020125	20020328
GNNA1	321AX553	100	99.99	100.02	KV2	20020125	20020328
GNNA1	321AX554	100	99.98	100.02	KV2	20020125	20020328
GNNA1	321AX555	99.99	99.99	100	KV2	20020125	20020328
GNNA1	321AX556	100	99.98	100	KV2	20020125	20020328
GNNA1	321AXKV2	100	99.98	100.02	KV2	20020124	20020221
GNNA1	323558689	100	99.99	100.01	KV2	20021202	20021206
GNNA1	323558690	100	99.98	99.99	KV2	20021202	20021206
GNNA1	323558691	100	100	99.99	KV2	20021202	20021206
GNNA1	323558692	100	99.99	100	KV2	20021202	20021206
GNNA1	323558693	100	99.97	100	KV2	20021202	20021206
GNNA1	323558694	100	99.99	100.01	KV2	20021202	20021206
GNNA1	323558695	100	99.99	100.01	KV2	20021202	20021206
GNNA1	323558696	100	99.99	100	KV2	20021202	20021206
GNNA1	323558705	100.01	99.98	100	KV2	20021202	20021206
GNNA1	323558706	100	99.98	99.99	KV2	20021202	20021206
GNNA1	323558707	100	100	99.99	KV2	20021202	20021206
GNNA1	323558708	100	99.98	100	KV2	20021202	20021206
66007	83249647	100.02	100.09	100.09	AX	20020212	20020226
66007	83249648	100	100.12	100.12	AX	20020212	20020226
66007	83249653	100	100.12	100.12	AX	20020212	20020226
66007	83249656	99.97	100.08	100.08	AX	20020212	20020226
66007	83249671	99.99	100.09	100.09	AX	20020212	20020226
66007	83249674	100.04	100.1	100.1	AX	20020212	20020226
66007	83249681	100	100.09	100.09	AX	20020212	20020226

KY CTESTS for 2002

66007	83249685	100.02	100.13	100.13	AX	20020212	20020226
66007	83249719	100.01	100.09	100.09	AX	20020212	20020226
66007	83249721	99.99	100.11	100.11	AX	20020212	20020226
66007	84059393	100	100.15	100.15	AX	20020912	20020918
66007	84059398	100.01	100.23	100.23	AX	20020912	20020918
66007	84059410	100.04	100.21	100.21	AX	20020912	20020918
66007	84104751	99.98	100.18	100.18	AX	20020913	20020920
66007	84104760	99.96	100.14	100.14	AX	20020912	20020920
66007	84104774	100.02	100.18	100.18	AX	20020912	20020920