## COMMONWEALTH OF KENTUCKY BEFORE THE PUBLIC SERVICE COMMISSION

_		~	
ln	the	Matt	er ot:

GRAYSON RURAL ELECTRIC COOPERATIVE CORPORATION	)	
AN ASSESSMENT OF KENTUCKY'S	)	CASE NO. 2005-00090
ELECTRIC GENERATION, TRANSMISSION	)	
AND DISTRIBUTION NEEDS	)	

Comes now Grayson Rural Electric Cooperative Corporation moves the Commission for an order granting the Movant until April 14, 2005, within which to appropriately respond to the order of March 10, 2005. Attached hereto are the documents previously requested that are now available.

In support of this motion, the Movant states that the additional time is necessary to gather the requested information and appropriately file the requested information due to the nature of the request.

RESPECTFULLY SUBMITTED,

W. JEFFREY SCO/T/T. P.S.C.

ATTORNEY FOR GRAYSON RURAL ELECTRIC COOPERATIVE CORPORATION

P.O. BOX 608

GRAYSON, KY 41143

(606) 474-5194

This is to certify that the original of the foregoing Motion and ten photocopies of same were this date served by express mail upon Elizabeth O'Donnell, Executive Director, Public Service Commission, 211 Sower Boulevard, P.O. Box 615, Frankfort, Kentucky, 40601; furthermore, it was served by mailing a true and correct of same, first class postage prepaid, to:

Allen Anderson South Kentucky RECC P.O. Box 910 Somerset, KY 42502-0910

Mark A. Bailey Kenergy Corp. P.O. Box 1389 Owensboro, KY 42302

Michael S. Beer VP – Rates & Regulatory Kentucky Utilities Co. c/o LG&E P.O. Box 32010 Louisville, KY 40232-2010

Kent Blake
Director – State Regulation and Rates
Louisville Gas and Electric Company
P.O. Box 32010
Louisville, KY 40232-2010

Sarah Botkin Business Service Manager Berea College, Electric Utility Dept. CPO 2207 Berea, KY 40404

Dudley Bottom Jr.
Shelby Energy Cooperative, Inc.
620 Old Finchville Road
Shelbyville, KY 40065

James B. Gainer, Legal Division The Union Light Heat and Power Co. 139 E. Fourth Street Cincinnati, OH 45202

Ted Hampton Cumberland Valley Electric, Inc. P.O. Box 440 Gray, KY 40734 Daniel W. Brewer Blue Grass Energy Cooperative Corp. P.O. Box 990 Nicholasville, KY 40340-0990

Jackie B. Browning Farmers R.E.C.C. P.O. Box 1298 Glasgow, KY 42141-1298

Overt L. Carroll Clark Energy Cooperative, Inc. P.O. Box 748 Winchester, KY 40392-0748

Sharon K. Carson Finance & Accounting Manager Jackson Energy Cooperative P.O. Box 307 McKee, KY 40447

Michael H. Core Big Rivers Electric Corporation P.O. Box 24 Henderson, KY 42420

Bill Duncan Licking Valley R.E.C.C. P.O. Box 605 West Liberty, KY 41472

Michael L. Miller, President & CEO Nolin R.E.C.C. 411 Ring Road Elizabethtown, KY 42701-8701

Timothy C. Mosher American Electric Power P.O. Box 5190 Frankfort, KY 40602 Larry Hicks
Salt River Electric Cooperative Corp.
P.O. Box 609
Bardstown, KY 40004

James Jacobus Inter-County Energy Cooperative Corp. P.O. Box 87 Danville, KY 40423-0087

Robert M. Marshall Owen Electric Cooperative, Inc. P.O. Box 400 Owenton, KY 40359

Burns E. Mercer Meade County R.E.C.C. P.O. Box 489 Brandenburg, KY 40108-0489

Bobby D. Sexton Big Sandy R.E.C.C. 504 11<sup>th</sup> Street Paintsville, KY 41240-1422

Hon. Michael L. Kurtz Boehm, Kurtz, & Lowry 36 East Seventh Street, Suite 1510 Cincinnati, Ohio 45202

This, 🐠 day of March, 2005.

Barry L. Myers Taylor County R.E.C.C. P.O. Box 100 Campbellsville, KY 42719

G. Kelly Nuckols Jackson Purchase Energy Corporation P.O. Box 4030 Paducah, KY 42002-4030

Anthony P. Overbey Fleming-Mason Energy Cooperative P.O. Box 328 Flemingsburg, KY 41041

Roy M. Palk East KY Power Cooperative, Inc. P.O. Box 707 Winchester, KY 40392-0707

Hon. Gregory D. Stumbo Attorney General 1024 Capital Center Drive, Suite 200 Frankfort, KY 40601-8204

Hon. David Brown 1800 Providian Center 400 West Market Street Louisville, KY 40202

# **Grayson Rural Electric Cooperative Corporation's Responses to PSC Case# 2005-00090**

1. Our wholesale power supplier is East Kentucky Power Cooperative, Inc., P.O. Box 707 Winchester, Ky. 40391. EKPC provides all transmission requirements, and provides technical assistance with our power requirement study which is reviewed and updated every two years. Our power requirement study and demand side management programs are based on historical data and twenty- year projections for demand and energy consumption for all classes of consumers served by Grayson RECC. Additional considerations include new subdivisions, industrial and commercial growth and established and potential growth patterns. We also use demographic research from our Area Development Districts and other accredited sources. All projections and supporting data are reviewed by our RUS Field Representative.

The Power Requirement Study provides the basis for the Individual Substation Forecast. This is part of our 4 year construction work plan, which is developed in consultation with R.W. Beck Consulting and submitted to RUS, and to EKPC to become a part of their projected work plan. All studies and projections are reviewed and approved by RUS. Our current Long Range System Study projects system loads and budget needs through 2016 and we are in the process of extending our study through 2026.

Grayson RECC constantly monitors the system distribution requirements and makes adjustments as necessary to meet the needs of our members. Any necessary adjustments that will have a significant impact on EKPC transmission or substation requirements will be reported immediately. Adjustments will be reported to RUS as required by that agency.

- 2. Grayson Rural Electric constantly monitors technologies associated with reliability, efficiency and safety and makes considerations as to their place in our utility.
  - a. We have implemented the use of automated meter reading equipment through Hunt Technologies over the past 4 years. We are in the process of evaluating remote disconnect controls through BLP for the safety of our employees.
  - b. Not applicable.

5. The following table provides actual and weather-normalized annual coincident peak demands for Grayson Rural Electric for the years 2000 through 2004.

Annual Peak	Actual Peak Demand (MW)	Weather Response Function (MW / Degree)	Actual Peak Day Temperature (Degrees F)	Normal Peak Day Temperature (Degrees F)	Weather Normalized Peak Demand (MW)
December-00	57.8	-0.65	3	0	59.8
January-01	58.4	-0.65	10	0	64.9
February-02	56.6	-0.65	12	0	64.4
January-03	61.3	-0.55	8	0	65.8
January-04	66.5	-0.65	2	0	67.8
	Base	ed on Huntington and Grayson RE	WV Weather S CC Hourly Load	tation Data d Data	

Grayson Rural Electric has only native, firm loads.


17. Grayson RECC and East Kentucky Power Cooperative work together to design DSM programs. Program implementation is done by Grayson, with assistance by EKPC. DSM programs are exclusively residential in nature, and almost always involve HVAC or water heating efficiency measures.

DSM programs currently in place are as follows:

- 1. Air-Source Heat Pump Incentive
- 2. Button Up Weatherization
- 3. Electric Thermal Storage (ETS)
- 4. Electric Water Heater Incentive
- 5. Geothermal Heating and Cooling

- 6. Touchstone Energy Home<sup>1</sup>
- 7. Tune Up HVAC Maintenance

In 2004, the programs had the following number of participants.



The next two pages summarize the programs.

<sup>&</sup>lt;sup>1</sup> Note that a home meeting the guidelines for this program would also qualify as an Energystar home.

### Button Up Weatherization Program

The program requires the installation of insulation materials or the use of other weatherization techniques to reduce heat loss in the home. Any retail member living in a stick-built or manufactured home that is at least two years old and which uses electric as the primary source of heat is eligible.

### Air-Source Heat Pump Incentive

This program promotes efficient air-source heat pumps. The primary targets for this program are retail members building new homes in areas where natural gas heat is an option. An important secondary target is the HVAC retrofit market, offering incentives to retail members to replace electric furnaces and gas or propane heat with high-efficiency electric heat pumps.

### Electric Thermal Storage

This program involves heating bricks during off-peak hours, thus storing the heat. During on-peak times, the heat is dispersed into the home. A time-of-day rate for ETS energy encourages retail members to use heating energy off-peak rather than on-peak. While this program is not a conservation program, it nonetheless helps to clip winter peak demand.

### Electric Water Heater Incentive

The electric water heater incentive is designed to encourage residential customers engaged in new construction to choose a high-efficiency electric water heater over other available options. It is also designed to encourage conversion from a fossil-fuel water heater to a high-efficiency electric water heater.

### Geothermal Heating and Cooling

Traditional air-source heat pumps remove heat from the air. Geothermal heating is a heat pump that removes heat from the ground. It is a very efficient heating and cooling appliance. EKPC and its member systems pioneered the development and implementation of geothermal heating and cooling during the eighties and nineties.

### Touchstone Energy Home

This program provides incentives and support relating to new home construction. A home built to Touchstone Energy specifications will be at least as efficient as an Energystar home.

# Tune Up HVAC Maintenance

This program includes cleaning indoor and outdoor heat-exchanger coils, changing filters, measuring the temperature differential across the indoor coil to determine proper compressor operation, checking the thermostat to verify operation and proper staging, measuring air flows to ensure proper conditioned air distribution, and sealing ductwork either through traditional mastic sealers or the Aeroseal dust sealing system.

### **Demand / Energy Impacts and Annual Budget**

The table below reports program impacts. Note that this data is per installation.

	Energy Impact (kWh)	Impact On Winter Peak (kW)	Impact On Summer Peak (kW)
Button Up	(2,700)	(2.7)	(1.0)
Tune Up	(2,200)	(2.2)	(1.0)
Geothermal	(6,000)	(3.5)	(1.5)
ETS	9300*	(2.1)	0.0
Efficient Heat Pump In New Construction	(925)	2.5**	(1.0)
Touchstone Energy Home	(5,100)	(2.4)	(1.4)
Efficient Water Heater	700**	0.2**	0.1**

<sup>\*</sup> Off-peak

<sup>\*\*</sup> Impacts are positive due to customers who normally would have chosen natural gas

Annual budgets are a function of administrative cost and incentive payments. The table below reports EKPC administrative costs, and typical administrative costs and incentive payments by EKPC member distribution cooperatives.

	EKPC Administrative Costs	Distribution Cooperative Administrative Costs*	Incentive Payment
Button Up	\$32	\$163	\$20 per 1,000 Btu saved
Geothermal	\$17	\$254	\$300
ETS	\$57	\$304	\$50 per kW Installed
Efficient Heat Pump In New Construction	\$13	\$182	\$300
Touchstone Energy Home	\$13	\$162	\$1,000
Efficient Water Heater	\$8	\$61	\$100

These numbers are average costs by all participating distribution cooperatives. These numbers can vary by distribution cooperative.

For a more in depth discussion of EKPC and member distribution cooperative DSM programs, please see Administrative Case No. 2003-00051, Appendix II.

- 18. Grayson Rural Electric defines transmission as voltages at or above 69,000 volts and/or lines owned and operated East Kentucky Power. Distribution is considered voltages 25,000 volts and under. Grayson Rural Electric currently operates all distribution facilities at 12,470 volts.
- 19. Grayson Rural Electric does not interconnect with any other distribution utility. East Kentucky Power provides transmission and substation facilities for Grayson

Rural Electric and has interconnections with other utilities. (See EKPC's response)

- 20. Not applicable
- 21. Not applicable
- 22. Grayson Rural Electric in conjunction with East Kentucky Power currently does not have any transmission facility additions scheduled.
- 23. Not Applicable
- 24. Not Applicable
- 25. Not Applicable
- 26. The following are the SAIDI and SAIFI for our system excluding major storms.

	Excluding M	ajor Storms
	SAIDI	SAIFI
2(0)0(0)	2.54	1.29
2001	1.87	0.93
2002	3.07	1.02
2003	2.32	1.00
2004	2.90	1.11

27. The following is the SAIDI and SAIFI for our system including major storms.

	All Ou	iages
	SAIDI	SAIFI
2(0)(0)(0)	1.38	1.38
2001	2.73	1.06
2002	3.40	1.11
2003	2.60	1.06
2(0(0)4)	2.91	1.11

Major Outages are defined as outages in excess of 4 hours and 500 consumers.

- 28. This report is the first time Grayson Rural Electric has categorized outages using the SAIDI and SAIFI indices and therefore we have not defined acceptable values.
- 29. CAIDI and CAIFI for past 5 years with and w/o major outages.

All Ou	tagjes	Excluding M	ajor Outages
CAND)	CANFI	C/AIDI	CAIFI
2.99	0.09	2.46	0.09
2.73	0.08	1.87	0.07
2.77	0.07	1.90	0.07
2.82	0.07	1.93	0.06
4.19	0.06	4.18	0.06
	2.99 2.73 2.77 2.82	2.99     0.09       2.73     0.08       2.77     0.07       2.82     0.07	CAIDI         CAIFI         CAIDI           2.99         0.09         2.46           2.73         0.08         1.87           2.77         0.07         1.90           2.82         0.07         1.93

This is the first time Grayson Rural Electric has categorized outage data using the CAIFI indices and therefore we have not established an acceptable value. Acceptable

values for the system average CAIDI is any value under 3 hours (180 minutes) per year.

Grayson Rural Electric and its consumers were affected by an ice storm February 13<sup>th</sup>, 2003. The storm caused wide spread damage and outages across the entire cooperative's system. The last consumer to get their power restored was 17 days later

This outage was the only reportable outage Grayson Rural Electric has experienced during the request time period.

- 31. Grayson Rural Electric does have a distribution reliability improvement program.
  - a. We measure reliability through outage reports, CAIDI, member complaints and excessive breaker operations.
  - b. The information is monitored daily through outage reports and member information.
  - c. Through the information gathered, Grayson Rural Electric makes alterations to its electrical system to rectify the problems. Problems that are not deemed to require immediate solutions are addressed in the construction work plan.
  - d. Relatively simple improvements for reliability are approved by the Manager of Construction and Engineering. Improvements that are more involved are added to the construction work plan which requires approval of the board of directors.
- 32. a. Grayson Rural Electric manages it's right-of-way through handheld sprayers, tractors equipped with bush hogs, bull dozers and hand cutting and trimming. We are on a 5 year rotation and our annual budgets were as follows:

Year	Actual Budget
2000	\$533,177
2001	\$1,062,557
2002	\$750,780
2003	\$684,559
2004	\$771,015

- Grayson Rural Electric does not separate control of right-of-way and control of vegetation.
- c. Grayson Rural Electric inspects it's distribution system on an annual basis through the utilization of in-house line maintenance personnel. This is an integral part of the job and the actual time inspecting isn't monitored. It is estimated we spent approximately \$8,500 each of the past 5 years on line inspections.
- Grayson Rural Electric replaces poles and/or conductors based on the age of the plant, physical conditions, load growth, equipment failure and outage times. Each of these criteria are considered at length when evaluating our potential projects

that are being considered. The following table identifies our costs/budgets for the years 2000-2007.

51 52 53 54 55 56 56 57 58

# EXHIBIT 1-2

# PROJECTED UTILITY PLANT ADDITIONS GRAYSON RECC

System Planning Guide (Inflated Dollars)

1 ANNUAL MWI SALES 2 3 ADDITIONAL CUSTOMERS 4 Number of Customers (1) 5 6 Number of New Customers 7 Gross Number of New Customers 7 Gross Number of New Customers 9 Cost of Primary & Service (3) 9 Cost of Transformer & Meter (3) 10 Cost per New Customer 11 Total Cost for New Customer 12 Total Cost for New Customers 13	Ratio Inflation 1.78% 150% 3.50% 3.50%	 181,487 12,963 12,963 227 416 \$ 1,644 \$ 524 \$ 2,168 \$ 901,888	188.364 188.364 13.240 13.27 416 \$ 1,702 \$ 542 \$ 2,244 \$ 933,454	1994 1994 \$ \$ 13	4 4 4 4 A	983 993 794 416 416 823 \$ 823 \$ 404 \$ 939 \$	205,719  14,071  14,071  277  416  1,887  601  2,488  1,034,937	2001 211,216 211,216 14,348 277 416 \$ 1,953 \$ 622 \$ 2,575 \$ 1,071,160	218 218 218 5 1,108	<b>м ммм</b>	2003 224,462 14,902 14,902 277 416 2,092 667 2,758 1,147,453	231,003  231,003  15,179  277  416  \$ 2,165  \$ 690  \$ 1,187,614	248,769  248,769  15,447  268  402  \$ 2,241  \$ 714  \$ 2,955  \$ 1,187,814
14 LIGHIS 15 Number of Lights (4) 16 Cost of Lights (3) 17 Total Cost for Lights 18 19 INCREASED CAPACITY	0.54% 3.50%	70 \$178 \$12,460	71 \$184 \$13,064	\$ 13	49 49	74 197 <b>\$</b> 14,578 <b>\$</b>	76 204 15,504	77 \$211 \$6,247	5 218 \$ 17,222	22 E \$ E	80 226 18,080	82 \$ 234 \$ 19,188	\$ 20,086
istomers (4) (3) Capacity	0.44% 3.50%	57 \$1,312 \$74,784	58 \$ 1,358 \$ 78,764	\$ 1.4	<b>69 69</b>	61 1.455 \$ 88,755 \$	62 1.506 93,372	63 \$ 1.559 \$ 98,217	64 \$ 1.614 \$ 103,296	\$ <del>14</del> 8	66 1.670 110,220	67 \$ 1.728 \$ 115,776	5 121,584
	3.50%	\$ 125,000 \$ \$ 125,000	\$ 129,375 \$ - \$ 129,375	\$ 133,903 \$ - \$ 133,903	4 44	138,590 \$ \$ 138,590 \$	143,441	\$ 148,461 \$ - \$ 148,461	\$ 153,657 \$ \$ 153,657	57 \$ \s	159,035 159,035	\$ 164,601 \$ - \$ 164,601	\$ 170,362 \$ 170,362
	3.50% 3.50% 3.50%	\$ - \$ - \$	\$ . \$ . \$ . \$ . \$ . \$ . \$ . \$ . \$ . \$ .	\$ \$	4 4 4 4	. \$ . \$ . 876,688 \$ . 876,688 \$	<u>515,488</u> 515,488	\$ - \$ - \$ -533,530 \$ -533,530	\$ - \$ <u>552,204</u> \$ <u>552,204</u>	04 lps 45 45		\$ - \$ - 591,534 \$ 591,534	\$
35 ORDINARY REPLACEMENTS 36 Transmission 37 Substation 38 Copper Conductor (6) 39 Misc. Distribution (7) 40 Total Ordinary Replacements	3.50% 3.50% 3.50% 3.50%	\$ . \$ . \$ . \$ . \$ . \$ . \$ . \$ . \$ . \$ .	\$ - \$ 347,760 \$ 347,407 \$ 835,167	\$ - \$ 359,932 \$ 504,467 \$ 864,399	8 8 8 8 8	\$ 372,529 \$ 522,123 \$ 894,652 \$	385,568 540,397 925,965	\$ - \$ 399,063 \$ 559,311 \$ 958,374	\$ - \$ 413,030 \$ 578,887 \$ 991,917	<del>60   60   60   60   60   60   60   60  </del>	427,486 599,148 1,026,634	\$	\$ 457,934 \$ 457,934 \$ 641,822 \$ 1,099,756
42 RETIREMENTS 43 Retirement w/o Replacement 44 45 TOTAL CAPITAL REQUIREMENTS		\$ - \$ 2,711,779	\$ - \$ 2,808,221	\$ 2,908,292	<del>u</del> 49	- \$ 3,013,202 \$	2,728,707	\$ - \$ 2,825,989	\$ - \$ 2,926,947	69 69	3,032,953	\$ - \$ 3,141,279	\$ 3,211,840
47 Current Plant (8) 48 CUMULATIVE PLANT 49 50		\$ 28,116,328 \$ 30,828,107	\$ 33,636,328	\$ 36,544,620	20 \$ 39,557,822		\$ 42,286,529	\$ 45,112,518	\$ 48,039,465		1,072,418	\$ 51,072,418 \$ 54,213,697 \$ 57,425,537	\$ 57,425

- NOTES:

  (1) Number of customers based on 1995 PRS forecast.
  (2) Based on the ratio of the 1995-99 CWP "New Member Extensions" to the projected PRS customer growth.
  (3) Based on the 1995-99 CWP cost inflated 3.5% to 1996 Dollars.
  (4) Average based on 1995-99 CWP values expressed as a percent of the projected number of customers.
  (5) Based on the Preferred Expansion Plan from the 1996 System Plan.
  (6) Based on an estimated 250 line miles of 6 & 8 ACWC conductor minus the Preferred Expansion Plan improvements.
  (7) Based on the 1995-99 CWP averages for Poles, Sectionalizing Equipment, Arrestors and Cut-outs inflated 3.5% to 1996 dollars.
  (8) Based on 1995 Form 7.

Inflated Dallare)											
(injinita Dolinis)	LT11	LL12	LL13	1114	1115	LL16	LL17	LL18	LL19	LL20	Totals
CAPITAL REQUIREMENTS	2006	2007	2008	2009	2010	2011	2012	2013	2014	2015	1996-2015
ANNUAL MWh SALES	254,014	260,652	266,848	273,089	277,818	285,749	293,081	298,893	306,075	313,136	
ADDITIONAL CUSTOMERS Number of Customers (1)	15,714	15,981	16,248	16,515	16,782	17,049	17,316	17,583	17,850	18,117	
Number of New Customers Cross Number of New Customers (2)	267 401	267 401	267 401	267 401	267 401	267 401	267 401	267 401	267 401	267 401	
9		2,400	2,484	2,571	2	\$ 2,754	\$ 2,851	2	ω	\$ 3,161	
Cost per New Customer	3,058	\$ 3,165	\$ 3,276	\$ 3,391	\$ 3,509	\$ 3,632	\$ 3,759	\$ 3,891	\$ 4,027	\$ 4,168	
Total Cost for New Customers	\$ 1,226,329	\$ 1,269,251	\$ 1,313,675	\$ 1,359,653	\$ 1,407,241	\$ 1,456,495	\$ 1,507,472	\$ 1,560,233	\$ 1,614,842	\$ 1,671,361	1,671,361 \$ 24,925,587
LIGHTS Number of Lights (4)		86	88	89	16	92	94	95	96	86	
Cost of Lights (3) Total Cost for Lights	\$ 250 \$ 21,250	\$ 22,274	\$ 23,584	\$ 24,653	\$ 26,117	\$ 27,324	\$ 28,858	\$ 30,210	\$ 31,584	\$ 33,418	\$ 429,571
INCREASED CAPACITY	:	!	!	!	!	ŀ	ţ		!	}	
Gross Number of I. C. Customers (4) Cost of Service Upgrades (3)	1.851	70 1,916	71 1,983	73 2,052				1		1	
Jotal Cost for Increased Capacity	\$ 127,719	\$ 134,120	\$ 140,793	\$ 149,/9b	\$ 157,176	\$ 164,850	\$ 1/2,900	\$ 181,335	\$ 192,523	\$ 201,760	\$ 2,590,694
GENERAL PLANT ADDITIONS  Normal Plant Additions	176,325	182,496	188,883	\$ 195,494	\$ 202,336	\$ 209,418	\$ 216,748	\$ 224,334	\$ 232,186	\$ 240,313	
Buildings Total General Plant additions	\$ 176,325	\$ 182,496	\$ 188,883	\$ 195,494	\$ 202,336	\$ 209,418	\$ - \$ 216,748	\$ 224,334	\$ 232,186	\$ 240,313	\$ 3,534,958
SYSTEM IMPROVEMENTS (5)											
Transmission			,		,	+ <del>(4)</del>	÷ € <del>7</del>	÷ €A ,	· <del>(</del> •	,	
Substation  Distribution	\$ 495,250	\$ 512,584	\$ 530,524	\$ 549,092	\$ 568,311	\$ 588,202	\$ 608,789	\$ 630,096	\$ 652,150	\$ 674,975	
Total System Improvements	495,250		530,524	\$ 549,092	\$ 568,311	\$ 588,202		\$ 630,096			\$ 12,519,346
ORDINARY REPLACEMENTS											
Transmission	1	,		,		, <del>(,</del>	· <del>49</del>	· <del>(</del> 49	1 <del>(A</del>	, <del>to</del>	
Substation		,		n ten			e te	n <del>(</del> n	9 <del>6</del> 9	n €0	
Copper Conductor (6) Misc. Distribution (7)	\$ 664,286	\$ 687,536	\$ 711,600	\$ 736,506	\$ 762,284	\$ 788,964	\$ 816,577	\$ 845,158	\$ 874,738	\$ 905,354	
Total Ordinary Replacements	664,286			\$ 736,506		\$ 788,964	\$ 816,577	\$ 845,158	\$ 874,738	\$ 905,354	\$ 17,259,358
RETIREMENTS  Retirement w/o Replacement	<del>υ</del>	<del>⊌</del>	<del>'</del>		,	•	•	••	<b>₩</b>	<del>.</del>	t <del>/s</del>
TOTAL CAPITAL REQUIREMENTS	\$ 2,711,159	\$ 2,808,261	\$ 2,909,059	\$ 3,015,194	\$ 3,123,465	\$ 3,235,253	\$ 3,351,344	\$ 3,471,366	\$ 3,598,023	\$ 3,727,181	\$ 61,259,514
Current Plant (8)											
CUMULATIVE PLANT	\$ 60,136,696	\$ 62,944,957	\$ 65,854,016	\$ 68,869,210	\$ 71,992,675	\$ 75,227,928	\$ 78,579,272	\$ 82,050,638	\$ 85,648,661	\$ 89,375,842	
	NOTES: (1) Number of customers based on 1995 PRS forecast.	customers base	d on 1995 PRS	forecast.							
	(2) Based on the ratio of the 1995-99 CWP "New Member Extensions" to the projected PRS customer growth	e ratio of the 1	995-99 CWP "N	lew Member E	xtensions" to th	ne projected P	RS customer gr	owth.			
	(a) based on the 1995-99 CWP values expressed as a percent of the projected number of customers (4) Average based on 1995-99 CWP values expressed as a percent of the projected number of customers	sed on 1995-99	CWP values ex	kpressed as a p	ercent of the p	rojected numb	er of customer	s.			
	(3) Based on the Freierred Expansion Fian from the 1990 System Fian. (6) Based on an estimated 250 line miles of 6 & 8 ACWC conductor minus the Preferred Expansion Plan improvemen	e Preferred Ex 1 estimated 25(	line miles of 6	% 8 ACWC co	ystem trian. nductor minus	the Preferred	Expansion Pla	n improvement	nts.		
	(7) Based on the 1995-99 CWP averages for Poles, Sectionalizing Equipment, Arrestors and Cut-outs inflated 3.5% to	le 1995-99 CWI	averages for I	oles, Sectional	izing Equipme	ent, Arrestors a	nd Cut-outs in		1996 dollars.		
	(8) Based on 1995 Form	95 Form 7									]

- NOTES:

  (1) Number of customers based on 1995 PRS forecast.

  (2) Based on the ratio of the 1995-99 CWP "New Member Extensions" to the projected PRS customer growth.

  (3) Based on the 1995-99 CWP cost inflated 3.5% to 1996 Dollars.

  (4) Average based on 1995-99 CWP values expressed as a percent of the projected number of customers.

  (5) Based on the Preferred Expansion Plan from the 1996 System Plan.

  (6) Based on the Preferred Expansion Plan from the 1996 System Plan.

  (7) Based on the 1995-99 CWP averages for Poles, Sectionalizing Equipment, Arrestors and Cut-outs inflated 3.5% to 1996 dollars. (8) Based on 1995 Form 7.