

John O. Hicks, III

Attorney at Law

105 Main Street

P.O. Box 64

Calhoun, Kentucky 42327

(270) 273-5749

RECEIVED

JUL 21 2005

PUBLIC SERVICE
COMMISSION

July 18, 2005

Beth O'Donnell
Public Service Commission
211 Sower Blvd.
P.O. Box 615
Frankfort, KY 40602-0615


RE: Purchased Water Rate Adjustment
North McLean County Water District
Case No. 2005-00165

Dear Ms. O'Donnell:

Pursuant to that Order of the Public Service Commission, dated May 12, 2005, enclosed please find copy of the published Notice to Customers, verifying that such Notice has been given. Said Notice was published in the McLean County News on June 9, 2005, prior to rendering of the first bill to customers at the increased rate which was not rendered until about the 28th day of June, 2005.

Should further information be needed, please be sure to let me know.

Very truly yours,


John O. Hicks, III

JOH/lis

Enclosure

cc: Nathel Jennings, Chairman

RECEIVED
JUL 2 10 00 AM '05
COMMUNICATIONS SECTION

No phone calls to KeEnergy please.
EOE/M/F/D

Find the job that's right for you.
Read the McLean Co. News Classifieds

Notice is given that the final settlement in the estate of Racheal Jones is set for hearing and confirmation on June 28, 2005, at 1:00 P.M. in the McLean District Court. Objections and exceptions shall be filed in the Office of the Circuit Court Clerk on or before said date.

COMMONWEALTH OF KENTUCKY TRANSPORTATION CABINET DEPARTMENT OF HIGHWAYS NOTICE TO CONTRACTORS
Sealed bids will be received by the Department of Highways in the Division of Contract Procurement on the 3rd floor and/or the Auditorium located on the 1st floor of the Transportation Cabinet Office Building, Frankfort, Kentucky until 10:00 A.M. DAYLIGHT SAVINGS TIME on the 17 DAY OF JUNE, 2005, at which time bids will be publicly opened and read for the improvement of:
MCLEAN COUNTY FD05 075 0431 008-012: LIVERMORE-OWENSBORO ROAD (US 431) FROM KY 1080 (MP 8.265) EXTENDING NORTH TO DAVIESS COUNTY LINE (MP 11.573), A DISTANCE OF 3.31 MILES. ASPHALT RESURFACING.
Bid proposals for all projects will be available at the Division of Contract Procurement until 3:00 p.m. Daylight Saving Time, preceding the day of the letting of Friday, JUNE 17, 2005. Bid proposals for all projects will be available at a cost of \$10 each and remittance payable to the State Treasurer of Kentucky must accompany request for proposals (NON-REFUNDABLE). BID PROPOSALS ARE ISSUED TO PREQUALIFIED CONTRACTORS. Specimen proposals for all projects will be available to all interested parties.

Messenger-Inquirer
P. O. Box 1480
Owensboro, KY 42302

Paxton Media Group LLC is an equal opportunity employer and does not discriminate on the basis of race, religion, sex, age, national origin or disability. EOE

Deal Classifieds

PUBLIC NOTICE
Pursuant to Order of the Public Service Commission of Kentucky (PSC), North McLean County Water District has been granted authority under the PSC's Regulation 807 KAR 5:068, relating to purchased water adjustments, to revise its rate schedule to reflect its increased cost of purchased water from its supplier, West Daviess County Water District.
The revised rate schedule, effective on and after May 8, 2005, is as follows:

REVISED RATE SCHEDULE

Usage Blocks
First ...2,000 gallons
Next ...8,000 gallons
Next ...30,000 gallons
Over ...40,000 gallons

Monthly Rates
\$13.60...Minimum Bill
\$4.75...per 1,000 gallons
\$4.24...per 1,000 gallons
\$3.76...per 1,000 gallons

Payment of water bills rendered by the District should be made to either North McLean County Water District, 217 Hill Street, P.O. Box 68, Livermore, KY 42352 or to Independence Bank, P.O. Box 39, Livermore, KY 42352.

CALHOUN CITY ORDINANCE #2, SERIES 2005
ORDINANCE AMENDING THE OFFICIAL ZONING MAP OF THE CITY OF CALHOUN RELATING TO LOTS LOCATED AT 505 MAIN STREET, 535 MAIN STREET AND 305 WEST FOURTH STREET

WHEREAS, pursuant to Section 153.148 of the Calhoun Zoning Code, a written request for amendment was presented to the Planning Commission for study and recommendation, and

WHEREAS, the Planning Commission held a public hearing, and


WHEREAS, subsequent to said public hearing, the Planning Commission forwarded a recommendation to the City Council, and

WHEREAS, the City Council received said recommendation and chose to adopt the recommendation regarding rezoning the lots located at 505 Main Street and 535 Main Street and chose to reject the recommendation and modify same with respect to the lot located at 305 West Fourth Street so that zoning change would be adopted.

NOW THEREFORE, it is ordained that in accordance City Ordinance 153.148 and Chapter 100 of the Kentucky Revised Statutes, the official zoning map is amended, and entry shall be made thereon, as follows:

- The property located with the addresses of 505 Main Street and 535 Main Street shall be hereby reclassified on the official City Zoning Map to the designation of C-2.
- The property located at 305 West Fourth Street shall be re-designated on the official zoning map as having a classification of R-2.

Adopted this the 12th day of April, 2005, on first reading, upon second reading the 10th day of May, 2005.


THOMAS C. FULKERSON, SR., MAYOR

ATTEST:

Picocuries per liter (pCi/L) - a measure of the radioactivity of water.
Million Fibers per Liter (MFL) - a measure of the presence of asbestos.

As authorized and approved by EPA, the State has reduced monitoring often than once per year because the concentrations of these contaminants from year to year. Some of the data in this table, though representative per results are from the North McLean Water District. A=The City of Daviess Water District, D=The City of Livermore

	Allowable Levels	Highest Single Measurement
Turbidity (NTU) (TT)	Less than 0.5 NTU 95% of samples each month.	B=4.89

REGULATED CONTAMINANT TESTS					
Contaminant [code] (units)	MCL	MCLG	Level Detected	Range	Date Samp
Total Coliform Bacteria 40 or more samples monthly (% positive samples)	5%	0	C=1.58%	BDL-1.58%	2002
Total Organic Carbon (ppm) measured as ppm, but reported as a ratio *	TT*	N/A	B=1.42 (annual average)	1.04-2.22 (monthly ratios)	2002

*Monthly ratio is the % TCC removal achieved to the % TCC removal required. Annual average of the monthly ratio

Atrazine [2050] (ppb)	3	3	1.8	1.8	12/04
Berium [1010] (ppm)	2	2	B=0.0262 0.0262	0.0262	2004
Alpha emitters [4000] (pCi/l)	15	0	A=4.0	4.0	2004
Combined radium (pCi/l)	5	0	A=2.0	2.0	2004
Copper [1022] (ppm)	AL=1.3	1.3	0.0227 (90th percentile)	(0 sites exceeded the AL)	Sept 2002
Fluoride [1025] (ppm)	4	4	A=1.3	1.3	2004
Lead [1030] (ppb)	AL=15	0	BDL (90th percentile)	BDL-3.5 (0 site exceeded the AL)	Sept 2002
Nitrate (as Nitrogen) [1040] (ppm)	10	10	A=1.29	1.29	2004
Nitrite (as Nitrogen) [1041] (ppm)	1	1	D=0.01	N/A	2003
Cadmium [1015] (ppb)	5	5	C=0.07	N/A	2002

TTHM [total trihalomethanes] (ppb)	100 (80)*	0	D=133 (annual average)	21-153	2004
Haloacetic acids or HAA (ppb)	60	N/A	D=79 (annual average)	21-79	2004
Chlorine (ppm) Result from N. McLean Water District	MRDL 4	MRDLG 4	1.23 (highest average)	.06-2.2	2004

Total Coliform. Coliforms are bacteria that are naturally present in their bacteria may be present. Coliforms were found in more samples than

Water Quality Violations and Health Effects

Ohio Co. Water District received a MCL violation from Ky. D lomethanes. Some people who drink water containing trihalomethan their liver, kidneys, or central nervous systems, and may have an incr program and is taking steps to reduce the levels of trihalomethanes in ering changing chemical feed points to mitigate TTHM formation.

Ohio Co. Water District received a MCL violation from Ky. Di acids, or HAA. Some people who drink water containing haloacetic or getting cancer. The water

RECEIVED
 JUL 21 2005
 PUBLIC SERVICE
 COMMISSION

<p>100 FULL-TIME</p> <p>General - WELDERS</p> <p>Must have experience with Flux-Core. Competitive wages & benefits. Apply in person at: Yager Materials 5001 Hwy. 60 E. No Phone Calls</p> <p>Something Missing? Let McLean Co. News Classifieds help you find it. Toll Free: 1-866-926-6161</p>	<p>100 FULL-TIME</p> <p>General Cool Jobs!!</p> <p>Now hiring 10 sharp people to work and travel with unique business group. Travel to Orlando, Chicago, L.A., Dallas, and other major U.S. cities. Seeking enthusiastic people to start today. 2 weeks paid training, transportation furnished, return trip guaranteed. Daily and weekly bonuses. For information call Mike 877-222-5589 <i>No investment required.</i></p>	<p>100 FULL-TIME</p> <p>Health Care - Experienced COOK Needed. Apply in person at: <i>Fern Terrace 45 Woodford Ave.</i></p> <p>NURSING - CNA Positions For All Shifts!</p> <p>Apply in person at: Bon Harbor Nursing & Rehabilitation Center, 2420 W. 3rd Street Owensboro, KY AAP/ E.E.O.C.</p>	<p>100 FULL-TIME</p> <p>Nursing - RN/LPN NEEDED for 2-10 SHIFT</p> <p>Competitive salary, 401K, vacation, health insurance, etc. <i>Apply in person: Fordsville Nursing & Rehab, 313 Main St. Fordsville, KY 42343 E.O.E.</i></p> <p>Sell your car, buy a truck! McLean County News Classifieds 270-273-3287</p>	<p>100 FULL-TIME</p> <p>Insurance Position</p> <p>available for qualified group health agent. Opportunity to assume an existing book of business with established agency. Excellent income and benefits package for motivated, experienced health agent. <i>Please send resume to: Office Manager PO Box 1677 Owensboro, KY 42302-1677. EOE</i></p>
--	---	---	---	--



**North McLean Co. Water District
 2004 Annual Water Quality Report
 PWSID #0300320**

ide you with this year's Annual Water informed about the quality of our water over the past year. Our goal is and safe and dependable supply of drinking efforts we make continually to improve our water resources. We are committed remains at the highest level and the our community. A vulnerability assessment the District and our suppliers. We are el of security for our facilities and distri-

he City of Calhoun, Ohio County Water trict, and City of Livermore. The City of reen River. Ohio County Water District

The City of Livermore treats surface River and Green River. West Daviess unicipal Utilities (OMU). OMU's water omes from a deep underground aquifer is aquifer contains water that has been n through the layers of the earth. OMU ay 60 East. Owensboro's water is clas-

North Mclean Co., The City of Calhoun, West Daviess Co. Water District, The City of Calhoun, and Ohio Co. Water District routinely monitor for contaminants in your drinking water according to Federal and State laws. The table enclosed within shows the results of our monitoring for the period of January 1st to December 31st, 2004.

In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems.

The final source water assessments with a summary of the system's susceptibility to potential sources of contamination are in the process of being revised. Source water assessments are available in the current County Water Supply Plans. These plans are available for inspection at Green River Area Development District 270-926-4433, located 3860 U S Highway 60 West, Owensboro, Ky. 42301-0200.

If you have any questions about this report or concerning your water utility, please contact T.C. Owen at (270) 278-2800. We want our valued customers to be informed about their water utility. If you want to learn more, please contact us anytime prior to any of our regularly scheduled meetings. They are normally held on the third Monday of each month at 7:00 p.m. in the City-County Building, Calhoun, Ky.

any terms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the

ory analysis indicates that the contaminant is not present.

illion corresponds to one minute in two years or a single penny in \$10,000.

ion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.

a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

measure of the clarity of water. Turbidity in excess of 5 NTU is just noticeable to the average person.

technique is a required intended to reduce the level of a contaminant in drinking water.

s the highest level of a contaminant that is allowed in king water. MCLs are set as close to the MCLGs as feasible using the

MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs

- (MRDL) the highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disin-ial contaminants.

Goal - (MRDLG) the level of a drinking water disinfectant below which there is no known or expected risk to health. e use of disinfectants to control microbial contaminants.

of the radioactivity in water.

re of the presence of asbestos fibers that are longer than 10 micrometers.

e State has reduced monitoring requirements for certain contaminants to less concentrations of these contaminants are not expected to vary significantly this table, though representative, is more than one year old. Lead and Cop- Water District. A=The City of Calhoun, B=Ohio Co. Water District, C=West ivermore

Special Precautions:
 Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemo-therapy, persons who have under-

els	Highest Single Measurement	Lowest Monthly %	Violation Y/N	Likely Source
samples each	B=4.89	99%	N	Soil runoff

MCLEAN COUNTY NEWS

Affadavit

RECEIVED
JUL 21 2005
PUBLIC SERVICE
COMMISSION

I, Jonna Spelbring Priester, of the McLean County News, published at Calhoun and having the largest general circulation of any newspaper in McLean County, Kentucky, do hereby certify that from my own knowledge and a check of this newspaper that the advertisement of North McLean County Water District was inserted in the McLean County News on the following dates:

Date 6-9-05 Page 7B Column 2+3

Date _____ Page _____ Column _____

Date _____ Page _____ Column _____

Date _____ Page _____ Column _____

Signature [Handwritten Signature]
this 17th day of June, 2005.

Notary Public Linda S. Lowe

My commission expires April 24, 2006

