



RECEIVED

FEB 29 2008

PUBLIC SERVICE
COMMISSION

Ms. Elizabeth O'Donnell
Public Service Commission
211 Sower Boulevard
P. O. Box 615
Frankfort, Kentucky 40601

E.ON U.S. LLC
Regulatory Affairs &
Compliance
220 W. Main Street
Louisville, KY 40202
www.eon-us.com

Martin J. Reinert
Regulatory Analyst II
O 502-627-4173
MARTY.REINERT@eon-us.com

February 27, 2008

Re: *In the Matter of: Joint Application of Inter County Energy Cooperative, Kentucky Power Company, Kentucky Utilities Company, Louisville Gas and Electric Company, Owen Electric Cooperative, Shelby Energy Cooperative, Inc., and the Union Light, Heat & Power Company for Approval of a Pilot Meter Testing Plan Pursuant 807 KAR 5:041, Section 13, 15, 16, 17, and 22, Case No. 2005-00276*

Annual Report – Kentucky Utilities Company

Dear Ms. O'Donnell:

The Kentucky Public Service Commission (“Commission”) originally approved a pilot sample meter testing plan for participating electric utilities in its Order of December 12, 2000, in Case Number 99-441. On November 10, 2005, in Case No. 2005-00276, the Commission approved the 2006 Sample Meter Testing Plan submitted by participating electric utilities on a permanent basis effective January 1, 2006.


Pursuant to the 2006 Sample Meter Testing Plan (originally filed on July 1, 2005), Section I(4) and Section II(D)(4), **Kentucky Utilities Company** submits the following:

The Certified Test Results of all new meters
received
(Attachment A)

2007 Statistical Sampling Test Results and
Summary
(Attachment B)

If you have any questions please do not hesitate to contact me.

Sincerely,

A handwritten signature in black ink that reads "Marty J. Reinert". The signature is written in a cursive style with a large, prominent 'M' and 'R'.

Marty J. Reinert

Cc: Jim Welch, Engineering Director PSC

Attachments

ATTACHMENT
A

Certified Test Results

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

 CO MANUFACTURER TYPE METER NUMBER TEST DATE FULL LOAD LIGHT LOAD PFACOR

CO	MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACOR
KUE		I210	C455947	02-23-07	100.0	100.0	100.1
KUE		I210	C455948	02-23-07	100.0	100.0	100.0
KUE		I210	C455949	02-23-07	100.0	100.0	100.1
KUE		I210	C455950	02-23-07	100.0	100.0	100.0
KUE		I210	C455951	02-23-07	100.0	100.0	100.0
KUE		I210	C455952	02-23-07	100.0	100.0	100.0
KUE		I210	C455953	02-23-07	100.0	100.0	100.0
KUE		I210	C455954	02-23-07	100.1	100.0	100.0
KUE		I210	C455955	02-23-07	100.0	100.0	100.0
KUE		I210	C455956	02-23-07	100.0	100.0	100.0
KUE		I210	C455957	02-23-07	100.0	100.0	100.0
KUE		I210	C455958	02-23-07	100.0	100.0	100.0
KUE		I210	C455959	02-23-07	100.0	100.0	100.0
KUE		I210	C455960	02-23-07	100.0	100.0	100.0
KUE		I210	C455961	02-23-07	100.0	100.0	100.0
KUE		I210	C455962	02-23-07	100.1	100.0	100.0
KUE		I210	C455963	02-23-07	100.0	100.0	100.0
KUE		I210	C455964	02-23-07	100.0	100.0	100.0
KUE		I210	C455965	02-23-07	100.0	100.0	100.0
KUE		I210	C455966	02-23-07	100.0	100.0	100.0
KUE		I210	C455967	02-23-07	100.0	100.0	100.0
KUE		I210	C455968	02-23-07	100.1	100.0	100.0
KUE		I210	C455969	02-23-07	100.0	100.0	100.0
KUE		I210	C455970	02-23-07	100.1	100.0	100.0
KUE		I210	C455971	02-23-07	100.0	100.0	100.0
KUE		I210	C455972	02-23-07	100.1	100.0	100.0
KUE		I210	C455973	02-23-07	100.0	100.0	100.0
KUE		I210	C455974	02-23-07	100.0	100.0	100.0
KUE		I210	C455975	02-23-07	100.0	100.0	100.0
KUE		I210	C455976	02-23-07	100.0	100.0	100.0
KUE		I210	C455977	02-23-07	100.0	100.0	100.0
KUE		I210	C455978	02-23-07	100.0	100.0	100.0
KUE		I210	C455979	02-23-07	100.0	100.0	100.0
KUE		I210	C455980	02-23-07	100.0	100.0	100.0
KUE		I210	C455981	02-23-07	100.1	100.0	100.0
KUE		I210	C455982	02-23-07	100.0	100.0	100.0
KUE		I210	C455983	02-23-07	100.0	100.0	100.0
KUE		I210	C455984	02-23-07	100.0	100.0	100.0
KUE		I210	C455985	02-23-07	100.0	100.0	100.0
KUE		I210	C455986	02-23-07	100.0	100.0	100.0
KUE		I210	C455987	02-23-07	100.0	100.0	100.0
KUE		I210	C455988	02-23-07	100.0	100.0	100.0
KUE		I210	C455989	02-23-07	100.1	100.0	100.0
KUE		I210	C455990	02-23-07	100.0	100.0	100.0
KUE		I210	C455991	02-23-07	100.0	100.0	100.0
KUE		I210	C455992	02-23-07	100.0	100.0	100.1
KUE		I210	C455993	02-23-07	100.0	100.0	100.0
KUE		I210	C455994	02-23-07	100.0	100.0	100.0
KUE		I210	C455995	02-23-07	100.0	100.0	100.0
KUE		I210	C455996	02-23-07	100.0	100.0	100.0
KUE		I210	C455997	02-23-07	100.0	100.0	99.9

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

CO	MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
KUE		I210	C456345	07-19-07	100.0	100.0	100.0
KUE		I210	C456346	07-19-07	100.0	100.0	100.0
KUE		I210	C456347	07-19-07	100.0	100.0	100.0
KUE		I210	C456348	07-19-07	100.0	100.0	100.0
KUE		I210	C456349	07-19-07	100.0	100.0	100.0
KUE		I210	C456350	07-19-07	100.0	100.0	99.9
KUE		I210	C456351	07-19-07	100.0	100.0	100.0
KUE		I210	C456352	07-19-07	100.0	100.0	100.0
KUE		I210	C456353	07-19-07	100.0	100.0	100.0
KUE		I210	C456354	07-19-07	100.0	100.0	100.0
KUE		I210	C456355	07-19-07	100.0	100.0	100.0
KUE		I210	C456356	07-19-07	100.1	100.1	100.0
KUE		I210	C456357	07-19-07	100.0	100.0	100.1
KUE		I210	C456358	07-19-07	100.0	100.0	100.0
KUE		I210	C456359	07-19-07	99.9	99.9	100.1
KUE		I210	C456360	07-19-07	100.0	100.0	100.0
KUE		I210	C456361	07-19-07	100.0	100.0	100.0
KUE		I210	C456362	07-19-07	100.0	100.0	100.0
KUE		I210	C456363	07-19-07	100.0	100.0	100.0
KUE		I210	C456364	07-19-07	100.1	100.1	100.0
KUE		I210	C456365	07-19-07	100.0	100.0	100.0
KUE		I210	C456366	07-19-07	100.0	100.0	99.9
KUE		I210	C456367	07-19-07	100.0	100.0	100.0
KUE		I210	C456368	07-19-07	100.0	100.0	100.0
KUE		I210	C456369	07-19-07	100.0	100.0	100.0
KUE		I210	C456370	07-19-07	100.1	100.1	100.1
KUE		I210	C456371	07-19-07	100.0	100.0	100.0
KUE		I210	C456372	07-19-07	100.0	100.0	100.0
KUE		I210	C456373	07-19-07	100.0	100.0	100.1
KUE		I210	C456374	07-19-07	100.0	100.0	100.0
KUE		I210	C456375	07-19-07	100.0	99.9	100.1
KUE		I210	C456376	07-19-07	100.0	100.0	100.0
KUE		I210	C456377	07-19-07	100.0	99.9	100.0
KUE		I210	C456378	07-19-07	100.0	100.0	99.9
KUE		I210	C456379	07-19-07	100.0	100.0	100.0
KUE		I210	C456380	07-19-07	100.0	100.0	100.1
KUE		I210	C456381	07-19-07	100.0	100.0	100.0
KUE		I210	C456382	07-19-07	100.0	100.0	100.0
KUE		I210	C456383	07-19-07	100.0	100.0	100.0
KUE		I210	C456384	07-19-07	100.0	100.0	100.1
KUE		I210	C456385	07-19-07	100.0	100.0	100.0
KUE		I210	C456386	07-19-07	100.0	100.0	100.1
KUE		I210	C456387	07-19-07	100.0	100.0	100.0
KUE		I210	C456388	07-19-07	100.1	100.1	100.0
KUE		I210	C456389	07-19-07	100.0	99.9	100.1
KUE		I210	C456390	07-19-07	100.0	100.0	100.0
KUE		I210	C456391	07-19-07	100.0	100.0	100.0
KUE		I210	C456392	07-19-07	100.0	100.0	100.0
KUE		I210	C456393	07-19-07	100.0	100.0	100.1
KUE		I210	C456394	07-19-07	100.0	100.0	100.0
KUE		I210	C456395	07-19-07	100.0	100.0	100.1

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

CO	MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
KUE		I210	C456447	07-17-07	100.0	100.0	100.1
KUE		I210	C456448	07-17-07	100.0	100.0	100.0
KUE		I210	C456449	07-17-07	100.0	100.0	99.9
KUE		I210	C456450	07-17-07	100.0	100.0	100.1
KUE		I210	C456451	07-17-07	100.0	100.0	100.0
KUE		I210	C456452	07-17-07	100.0	100.0	100.0
KUE		I210	C456453	07-17-07	100.0	100.0	100.1
KUE		I210	C456454	07-17-07	100.0	100.0	99.9
KUE		I210	C456455	07-17-07	100.0	100.0	100.0
KUE		I210	C456456	07-17-07	100.0	99.9	100.0
KUE		I210	C456457	07-17-07	100.0	100.0	100.0
KUE		I210	C456458	07-17-07	100.1	100.1	100.0
KUE		I210	C456459	07-17-07	100.0	100.0	100.0
KUE		I210	C456460	07-17-07	100.0	100.0	100.1
KUE		I210	C456461	07-17-07	100.0	100.0	100.0
KUE		I210	C456462	07-17-07	100.0	100.0	100.0
KUE		I210	C456463	07-17-07	100.0	100.0	100.0
KUE		I210	C456464	07-17-07	100.0	100.0	100.0
KUE		I210	C456465	07-17-07	100.1	100.1	100.0
KUE		I210	C456466	07-17-07	100.0	100.0	100.0
KUE		I210	C456467	07-17-07	100.0	100.0	100.0
KUE		I210	C456468	07-17-07	100.0	100.0	100.0
KUE		I210	C456469	07-17-07	100.0	100.0	100.0
KUE		I210	C456470	07-17-07	100.0	100.0	100.0
KUE		I210	C456471	07-17-07	100.0	100.0	100.0
KUE		I210	C456472	07-17-07	100.0	100.0	100.0
KUE		I210	C456473	07-17-07	100.0	100.0	100.1
KUE		I210	C456474	07-17-07	100.0	100.0	100.0
KUE		I210	C456475	07-17-07	100.0	100.0	99.9
KUE		I210	C456476	07-17-07	100.0	100.0	100.0
KUE		I210	C456477	07-17-07	100.1	100.1	99.9
KUE		I210	C456478	07-17-07	100.1	100.1	100.0
KUE		I210	C456479	07-17-07	100.0	100.0	100.1
KUE		I210	C456480	07-17-07	100.0	100.0	100.1
KUE		I210	C456481	07-17-07	100.0	100.1	100.0
KUE		I210	C456482	07-17-07	100.1	100.1	100.0
KUE		I210	C456483	07-17-07	100.0	100.0	100.0
KUE		I210	C456484	07-17-07	100.0	100.0	100.0
KUE		I210	C456485	07-17-07	100.0	100.0	99.9
KUE		I210	C456486	07-17-07	100.0	100.0	99.9
KUE		I210	C456487	07-17-07	100.0	100.0	100.0
KUE		I210	C456488	07-17-07	100.0	100.0	100.0
KUE		I210	C456489	07-17-07	100.0	100.0	100.0
KUE		I210	C456490	07-17-07	100.0	100.0	100.0
KUE		I210	C456491	07-17-07	100.1	100.0	99.9
KUE		I210	C456492	07-17-07	100.1	100.1	99.9
KUE		I210	C456493	07-17-07	100.0	100.0	100.0
KUE		I210	C456494	07-17-07	100.0	100.0	100.0
KUE		I210	C456495	07-17-07	100.0	100.0	100.0
KUE		I210	C456496	07-17-07	100.0	100.0	100.1
KUE		I210	C456497	07-17-07	100.0	100.0	100.0

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

CO	MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
KUE		I210	C456549	07-17-07	100.0	100.0	100.0
KUE		I210	C456550	07-17-07	100.0	100.0	100.0
KUE		I210	C456551	07-17-07	100.0	100.0	100.0
KUE		I210	C456552	07-17-07	100.0	100.0	100.0
KUE		I210	C456553	07-17-07	99.9	99.9	100.0
KUE		I210	C456554	07-17-07	99.9	99.9	100.0
KUE		I210	C456555	07-17-07	100.0	100.0	100.0
KUE		I210	C456556	07-17-07	100.0	100.0	100.0
KUE		I210	C456557	07-17-07	100.0	100.0	100.0
KUE		I210	C456558	07-17-07	100.0	100.0	100.0
KUE		I210	C456559	07-17-07	100.0	100.0	100.0
KUE		I210	C456560	07-17-07	100.0	100.0	100.0
KUE		I210	C456561	07-17-07	100.0	100.0	100.0
KUE		I210	C456562	07-17-07	100.0	100.0	100.0
KUE		I210	C456563	07-17-07	100.0	100.0	100.0
KUE		I210	C456564	07-17-07	99.9	99.9	99.9
KUE		I210	C456565	07-17-07	100.0	100.0	100.0
KUE		I210	C456566	07-17-07	100.0	100.0	100.0
KUE		I210	C456567	07-17-07	99.9	99.9	100.0
KUE		I210	C456568	07-17-07	99.9	99.9	100.0
KUE		I210	C456569	07-17-07	100.0	100.0	100.0
KUE		I210	C456570	07-17-07	100.0	100.0	100.0
KUE		I210	C456571	07-17-07	99.9	99.9	100.0
KUE		I210	C456572	07-17-07	100.0	100.0	100.0
KUE		I210	C456573	07-17-07	100.0	100.0	100.0
KUE		I210	C456574	07-17-07	100.0	100.0	100.0
KUE		I210	C456575	07-17-07	100.0	100.0	100.0
KUE		I210	C456576	07-17-07	100.0	99.9	100.0
KUE		I210	C456577	07-17-07	100.0	100.0	100.0
KUE		I210	C456578	07-17-07	100.0	100.0	100.0
KUE		I210	C456579	07-17-07	100.0	100.0	100.0
KUE		I210	C456580	07-17-07	100.0	100.0	100.0
KUE		I210	C456581	07-17-07	100.0	100.0	100.0
KUE		I210	C456582	07-17-07	100.0	100.0	100.0
KUE		I210	C456583	07-17-07	100.0	100.0	100.0
KUE		I210	C456584	07-17-07	100.0	100.0	100.0
KUE		I210	C456585	07-17-07	100.0	100.0	99.9
KUE		I210	C456586	07-17-07	100.0	100.0	100.0
KUE		I210	C456587	07-17-07	100.0	99.9	100.0
KUE		I210	C456588	07-17-07	100.0	100.0	100.0
KUE		I210	C456589	07-17-07	100.0	100.0	100.0
KUE		I210	C456590	07-17-07	100.0	100.0	100.0
KUE		I210	C456591	07-17-07	100.0	100.0	100.0
KUE		I210	C456592	07-17-07	100.0	100.0	100.0
KUE		I210	C456593	07-17-07	100.0	100.0	99.9
KUE		I210	C456594	07-17-07	100.0	100.0	100.0
KUE		I210	C456595	07-17-07	100.0	100.0	100.0
KUE		I210	C456596	07-17-07	99.9	100.0	100.0
KUE		I210	C456597	07-17-07	100.0	100.0	100.0
KUE		I210	C456598	07-17-07	100.0	100.0	100.0
KUE		I210	C456599	07-17-07	100.0	100.0	100.0

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

CO	MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
KUE		I210	C4566651	07-17-07	100.0	100.0	99.9
KUE		I210	C4566652	07-17-07	100.1	100.1	100.1
KUE		I210	C4566653	07-17-07	100.0	100.0	100.0
KUE		I210	C4566654	07-17-07	99.9	99.9	100.0
KUE		I210	C4566655	07-17-07	100.0	100.0	100.1
KUE		I210	C4566656	07-17-07	100.0	100.0	100.0
KUE		I210	C4566657	07-17-07	100.0	100.0	100.0
KUE		I210	C4566658	07-17-07	100.0	100.0	100.0
KUE		I210	C4566659	07-17-07	100.0	100.0	100.1
KUE		I210	C4566660	07-17-07	100.0	100.0	100.0
KUE		I210	C4566661	07-17-07	100.1	100.1	100.1
KUE		I210	C4566662	07-17-07	100.1	100.1	100.0
KUE		I210	C4566663	07-17-07	100.1	100.1	100.0
KUE		I210	C4566664	07-17-07	100.0	100.0	100.0
KUE		I210	C4566665	07-17-07	100.0	100.0	100.1
KUE		I210	C4566666	07-17-07	100.0	100.0	100.0
KUE		I210	C4566667	07-17-07	100.0	100.0	100.1
KUE		I210	C4566668	07-17-07	100.0	100.0	100.0
KUE		I210	C4566669	07-17-07	100.1	100.1	100.1
KUE		I210	C4566670	07-17-07	100.0	100.0	100.0
KUE		I210	C4566671	07-17-07	100.0	100.0	99.9
KUE		I210	C4566672	07-17-07	100.0	100.0	100.1
KUE		I210	C4566673	07-17-07	100.0	100.0	100.0
KUE		I210	C4566674	07-17-07	100.0	100.0	100.0
KUE		I210	C4566675	07-17-07	100.0	100.0	100.0
KUE		I210	C4566676	07-17-07	100.0	100.0	100.1
KUE		I210	C4566677	07-17-07	100.0	100.0	100.0
KUE		I210	C4566678	07-17-07	100.0	100.0	100.0
KUE		I210	C4566679	07-17-07	100.1	100.1	100.0
KUE		I210	C4566680	07-17-07	100.0	100.0	100.1
KUE		I210	C4566681	07-17-07	100.0	100.0	100.0
KUE		I210	C4566682	07-17-07	100.0	100.0	99.9
KUE		I210	C4566683	07-17-07	100.0	100.0	100.0
KUE		I210	C4566684	07-17-07	100.0	100.0	100.0
KUE		I210	C4566685	07-17-07	100.0	100.0	100.0
KUE		I210	C4566687	07-17-07	100.1	100.1	100.0
KUE		I210	C4566688	07-17-07	100.0	100.0	100.0
KUE		I210	C4566689	07-17-07	100.0	100.0	100.0
KUE		I210	C4566690	07-17-07	100.0	100.0	100.1
KUE		I210	C4566691	07-17-07	100.0	100.0	100.1
KUE		I210	C4566692	07-17-07	100.0	100.0	100.0
KUE		I210	C4566693	07-17-07	100.1	100.1	100.0
KUE		I210	C4566694	07-17-07	100.1	100.1	100.0
KUE		I210	C4566695	07-17-07	100.1	100.1	100.0
KUE		I210	C4566696	07-17-07	100.1	100.1	100.0
KUE		I210	C4566697	07-17-07	100.0	100.0	100.0
KUE		I210	C4566698	07-17-07	100.0	100.0	100.0
KUE		I210	C4566699	07-17-07	100.0	100.0	100.0
KUE		I210	C4566700	07-17-07	100.0	100.0	100.0
KUE		I210	C4566701	07-17-07	100.0	100.0	100.1

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

PAGE 11
 RUN DATE: 1/15/08
 RUN TIME: 22.00.58

CO	MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
KUE		I210	C456753	07-17-07	100.0	100.0	100.0
KUE		I210	C456754	07-17-07	100.0	100.0	100.0
KUE		I210	C456755	07-17-07	100.1	100.1	100.0
KUE		I210	C456756	07-17-07	100.1	100.1	99.9
KUE		I210	C456757	07-17-07	100.0	100.0	100.1
KUE		I210	C456758	07-17-07	100.0	100.0	100.0
KUE		I210	C456759	07-17-07	100.1	100.0	100.0
KUE		I210	C456760	07-17-07	100.0	100.0	100.0
KUE		I210	C456761	07-17-07	100.0	100.0	100.1
KUE		I210	C456762	07-17-07	100.0	100.1	100.1
KUE		I210	C456763	07-17-07	100.0	100.0	100.0
KUE		I210	C456764	07-17-07	100.0	100.1	100.0
KUE		I210	C456765	07-17-07	100.0	99.9	100.1
KUE		I210	C456766	07-17-07	100.0	100.1	100.1
KUE		I210	C456767	07-17-07	100.1	100.1	100.0
KUE		I210	C456768	07-17-07	100.0	100.0	100.0
KUE		I210	C456769	07-17-07	100.0	100.0	100.0
KUE		I210	C456770	07-17-07	100.0	100.0	100.0
KUE		I210	C456771	07-17-07	100.0	100.0	100.1
KUE		I210	C456772	07-17-07	100.0	100.0	100.0
KUE		I210	C456773	07-17-07	99.9	100.0	100.0
KUE		I210	C456774	07-17-07	100.0	100.1	100.0
KUE		I210	C456775	07-17-07	100.0	100.1	100.0
KUE		I210	C456776	07-17-07	100.0	100.0	100.0
KUE		I210	C456777	07-17-07	100.1	100.1	100.1
KUE		I210	C456778	07-17-07	100.0	100.0	100.0
KUE		I210	C456779	07-17-07	100.0	100.0	100.1
KUE		I210	C456780	07-17-07	100.0	100.0	100.1
KUE		I210	C456781	07-17-07	100.0	100.0	100.0
KUE		I210	C456782	07-17-07	100.0	100.1	100.0
KUE		I210	C456783	07-17-07	100.0	100.0	100.0
KUE		I210	C456784	07-17-07	99.9	99.9	100.0
KUE		I210	C456785	07-17-07	99.9	99.9	100.0
KUE		I210	C456786	07-17-07	100.0	100.0	100.0
KUE		I210	C456787	07-17-07	100.0	100.0	100.0
KUE		I210	C456788	07-17-07	100.0	100.0	100.1
KUE		I210	C456789	07-17-07	100.0	100.1	100.0
KUE		I210	C456790	07-17-07	100.0	100.0	100.0
KUE		I210	C456791	07-17-07	100.1	100.1	99.9
KUE		I210	C456792	07-17-07	100.0	100.0	100.1
KUE		I210	C456793	07-17-07	100.0	100.0	100.0
KUE		I210	C456794	07-17-07	100.0	100.0	100.0
KUE		I210	C456795	07-17-07	100.1	100.1	100.0
KUE		I210	C456796	07-17-07	100.1	100.1	100.0
KUE		I210	C456797	07-17-07	100.1	100.0	100.0
KUE		I210	C456798	07-17-07	100.1	100.0	100.0
KUE		I210	C456799	07-17-07	100.0	100.0	100.1
KUE		I210	C456800	07-17-07	99.9	100.0	100.0
KUE		I210	C456801	07-17-07	99.9	99.9	100.0
KUE		I210	C456802	07-17-07	100.1	100.1	100.1
KUE		I210	C456803	07-17-07	100.0	100.0	100.0

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

CO	MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
KUE		I210	C456855	07-17-07	100.0	100.0	100.1
KUE		I210	C456856	07-17-07	100.0	100.0	100.0
KUE		I210	C456857	07-17-07	100.0	100.0	100.0
KUE		I210	C456858	07-17-07	100.0	100.0	100.0
KUE		I210	C456859	07-17-07	100.0	100.0	100.1
KUE		I210	C456860	07-17-07	100.0	100.0	100.1
KUE		I210	C456861	07-17-07	100.0	100.0	100.0
KUE		I210	C456862	07-17-07	100.0	100.0	100.0
KUE		I210	C456863	07-17-07	100.0	100.0	100.1
KUE		I210	C456864	07-17-07	100.0	100.0	100.1
KUE		I210	C456865	07-17-07	100.0	100.0	100.0
KUE		I210	C456866	07-17-07	100.0	100.0	100.0
KUE		I210	C456867	07-17-07	100.0	100.1	100.0
KUE		I210	C456868	07-17-07	100.0	100.0	100.0
KUE		I210	C456869	07-17-07	100.0	100.1	100.0
KUE		I210	C456870	07-17-07	100.0	100.0	100.0
KUE		I210	C456871	07-17-07	100.0	100.0	100.0
KUE		I210	C456872	07-17-07	100.0	100.0	100.0
KUE		I210	C456873	07-17-07	100.0	100.0	100.0
KUE		I210	C456874	07-17-07	100.0	100.0	99.9
KUE		I210	C456875	07-17-07	100.0	100.0	100.0
KUE		I210	C456876	07-17-07	100.0	100.0	100.0
KUE		I210	C456877	07-17-07	100.0	100.0	100.0
KUE		I210	C456878	07-17-07	100.0	100.0	100.0
KUE		I210	C456879	07-17-07	100.0	100.1	100.0
KUE		I210	C456880	07-17-07	100.0	100.0	100.0
KUE		I210	C456881	07-17-07	100.0	100.0	100.0
KUE		I210	C456882	07-17-07	100.0	100.1	100.0
KUE		I210	C456883	07-17-07	100.0	100.1	100.0
KUE		I210	C456884	07-17-07	100.0	100.0	100.0
KUE		I210	C456885	07-17-07	100.0	100.0	100.0
KUE		I210	C456886	07-17-07	100.0	100.0	100.0
KUE		I210	C456887	07-17-07	100.0	100.0	100.0
KUE		I210	C456888	07-17-07	100.0	100.0	100.0
KUE		I210	C456889	07-17-07	100.0	100.0	100.0
KUE		I210	C456890	07-17-07	100.0	100.0	100.0
KUE		I210	C456891	07-17-07	100.0	100.0	100.0
KUE		I210	C456892	07-17-07	100.0	100.0	99.9
KUE		I210	C456893	07-17-07	100.0	100.0	100.0
KUE		I210	C456894	07-17-07	100.0	100.0	100.0
KUE		I210	C456895	07-17-07	100.0	100.0	100.0
KUE		I210	C456896	07-17-07	100.0	100.0	100.0
KUE		I210	C456897	07-17-07	100.0	100.0	100.0
KUE		I210	C456898	07-17-07	100.0	100.0	100.0
KUE		I210	C456899	07-17-07	100.0	100.0	100.0
KUE		I210	C456900	07-17-07	100.0	100.0	100.0
KUE		I210	C456901	07-17-07	100.0	100.0	100.0
KUE		I210	C456902	07-17-07	100.0	100.0	100.0
KUE		I210	C456903	07-17-07	100.0	100.0	100.0
KUE		I210	C456904	07-17-07	100.0	100.0	100.0
KUE		I210	C456905	07-17-07	100.0	100.0	100.0

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

CO	MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
KUE		I210	C456957	07-17-07	100.0	100.0	100.1
KUE		I210	C456958	07-17-07	100.0	100.0	100.1
KUE		I210	C456959	07-17-07	100.0	100.0	100.1
KUE		I210	C456960	07-17-07	100.0	100.0	100.1
KUE		I210	C456961	07-17-07	100.0	100.0	100.1
KUE		I210	C456962	07-17-07	100.0	100.0	100.1
KUE		I210	C456963	07-17-07	100.0	100.0	100.1
KUE		I210	C456964	07-17-07	100.0	100.0	100.1
KUE		I210	C456965	07-17-07	100.0	100.0	100.1
KUE		I210	C456966	07-17-07	100.0	100.0	100.1
KUE		I210	C456967	07-17-07	100.0	100.0	100.1
KUE		I210	C456968	07-17-07	100.0	100.0	100.1
KUE		I210	C456969	07-17-07	100.0	100.0	100.1
KUE		I210	C456970	07-17-07	100.0	100.0	100.1
KUE		I210	C456971	07-17-07	100.0	100.0	100.1
KUE		I210	C456972	07-17-07	100.0	100.0	100.1
KUE		I210	C456973	07-17-07	100.0	100.0	100.1
KUE		I210	C456974	07-17-07	100.0	100.0	100.1
KUE		I210	C456975	07-17-07	100.0	100.0	100.1
KUE		I210	C456976	07-17-07	100.0	100.0	100.1
KUE		I210	C456977	07-17-07	100.0	100.0	100.1
KUE		I210	C456978	07-17-07	100.0	100.0	100.1
KUE		I210	C456979	07-17-07	100.0	100.0	100.1
KUE		I210	C456980	07-17-07	100.0	100.0	100.1
KUE		I210	C456981	07-17-07	100.0	100.0	100.1
KUE		I210	C456982	07-17-07	100.0	100.0	100.1
KUE		I210	C456983	07-17-07	100.0	100.0	100.1
KUE		I210	C456984	07-17-07	100.0	100.0	100.1
KUE		I210	C456985	07-17-07	100.0	100.0	100.1
KUE		I210	C456986	07-17-07	100.0	100.0	100.1
KUE		I210	C456987	07-17-07	100.0	100.0	100.1
KUE		I210	C456988	07-17-07	100.0	100.0	100.1
KUE		I210	C456989	07-17-07	100.0	100.0	100.1
KUE		I210	C456990	07-17-07	100.0	100.0	100.1
KUE		I210	C456991	07-17-07	100.0	100.0	100.1
KUE		I210	C456992	07-17-07	100.0	100.0	100.1
KUE		I210	C456993	07-17-07	100.0	100.0	100.1
KUE		I210	C456994	07-17-07	100.0	100.0	100.1
KUE		I210	C456995	07-17-07	100.0	100.0	100.1
KUE		I210	C456996	07-17-07	100.0	100.0	100.1
KUE		I210	C456997	07-17-07	100.0	100.0	100.1
KUE		I210	C456998	07-17-07	100.0	100.0	100.1
KUE		I210	C456999	07-17-07	100.0	100.0	100.1
KUE		I210	C457000	07-17-07	100.0	100.0	100.1
KUE		I210	C457001	07-17-07	100.0	100.0	100.1
KUE		I210	C457002	07-17-07	100.0	100.0	100.1
KUE		I210	C457003	07-17-07	100.0	100.0	100.1
KUE		I210	C457004	07-17-07	100.0	100.0	100.1
KUE		I210	C457005	07-17-07	100.0	100.0	100.1
KUE		I210	C457006	07-17-07	100.0	100.0	100.1
KUE		I210	C457007	07-17-07	100.0	100.0	100.1

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

CO	MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
KUE		I210	C457059	07-17-07	100.0	100.0	100.0
KUE		I210	C457060	07-17-07	100.0	100.0	100.0
KUE		I210	C457061	07-17-07	100.0	100.0	100.0
KUE		I210	C457062	07-17-07	100.0	100.0	100.0
KUE		I210	C457063	07-17-07	100.0	100.0	100.0
KUE		I210	C457064	07-17-07	99.9	99.9	100.0
KUE		I210	C457065	07-17-07	100.0	100.0	100.0
KUE		I210	C457066	07-17-07	100.0	100.0	100.0
KUE		I210	C457067	07-17-07	100.0	100.0	100.0
KUE		I210	C457068	07-17-07	100.0	100.0	100.0
KUE		I210	C457069	07-17-07	100.0	100.0	100.0
KUE		I210	C457070	07-17-07	100.0	100.0	100.0
KUE		I210	C457071	07-17-07	100.0	100.0	100.0
KUE		I210	C457072	07-17-07	100.0	100.0	100.0
KUE		I210	C457073	07-17-07	100.0	100.0	100.0
KUE		I210	C457074	07-17-07	100.0	100.0	100.0
KUE		I210	C457075	07-17-07	100.0	100.0	100.0
KUE		I210	C457076	07-17-07	100.0	100.0	99.9
KUE		I210	C457077	07-17-07	100.0	100.0	100.0
KUE		I210	C457078	07-17-07	100.0	100.0	100.0
KUE		I210	C457079	07-17-07	100.0	100.0	100.0
KUE		I210	C457080	07-17-07	100.0	100.0	100.0
KUE		I210	C457081	07-17-07	100.0	100.0	100.0
KUE		I210	C457082	07-17-07	100.0	100.0	100.0
KUE		I210	C457083	07-17-07	100.0	100.0	100.0
KUE		I210	C457084	07-17-07	100.0	100.0	100.0
KUE		I210	C457085	07-17-07	100.0	100.0	100.0
KUE		I210	C457086	07-17-07	99.9	99.9	100.0
KUE		I210	C457087	07-17-07	100.0	100.0	100.0
KUE		I210	C457088	07-17-07	100.0	100.0	100.0
KUE		I210	C457089	07-17-07	100.0	100.0	100.0
KUE		I210	C457090	07-17-07	100.0	100.0	99.9
KUE		I210	C457091	07-17-07	100.0	100.0	100.0
KUE		I210	C457092	07-17-07	100.0	100.0	100.0
KUE		I210	C457093	07-17-07	100.0	100.0	100.0
KUE		I210	C457094	07-17-07	100.0	100.0	100.0
KUE		I210	C457095	07-17-07	100.0	100.0	99.9
KUE		I210	C457096	07-17-07	100.0	100.0	100.0
KUE		I210	C457097	07-17-07	100.0	100.0	100.0
KUE		I210	C457098	07-17-07	100.0	100.0	100.0
KUE		I210	C457099	07-17-07	100.0	100.0	100.0
KUE		I210	C457100	07-17-07	100.0	100.0	100.0
KUE		I210	C457101	07-17-07	100.0	100.0	100.0
KUE		I210	C457102	07-17-07	100.0	100.0	99.9
KUE		I210	C457103	07-17-07	100.0	100.0	100.0
KUE		I210	C457104	07-17-07	100.0	100.0	100.0
KUE		I210	C457105	07-17-07	100.0	100.0	100.0
KUE		I210	C457106	07-17-07	100.0	100.0	100.0
KUE		I210	C457107	07-17-07	100.0	100.0	100.0
KUE		I210	C457108	07-17-07	100.0	100.0	100.0
KUE		I210	C457109	07-17-07	100.0	100.0	100.0

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

CO	MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
KUE		I210	C4571161	07-17-07	100.0	100.0	99.9
KUE		I210	C4571162	07-17-07	100.0	100.1	100.0
KUE		I210	C4571163	07-17-07	100.0	100.0	100.0
KUE		I210	C4571164	07-17-07	100.0	100.0	100.0
KUE		I210	C4571165	07-17-07	100.0	100.0	100.1
KUE		I210	C4571166	07-17-07	100.0	100.0	100.0
KUE		I210	C4571167	07-17-07	100.0	100.1	100.0
KUE		I210	C4571168	07-17-07	100.0	100.0	100.1
KUE		I210	C4571169	07-17-07	100.0	100.0	100.0
KUE		I210	C4571170	07-17-07	100.0	100.1	100.0
KUE		I210	C4571171	07-17-07	100.0	100.0	100.1
KUE		I210	C4571172	07-17-07	100.0	100.0	100.0
KUE		I210	C4571173	07-17-07	100.0	100.0	100.1
KUE		I210	C4571174	07-17-07	100.0	100.0	100.1
KUE		I210	C4571175	07-17-07	100.0	100.0	100.1
KUE		I210	C4571176	07-17-07	100.0	100.0	100.0
KUE		I210	C4571177	07-17-07	100.0	100.0	100.0
KUE		I210	C4571178	07-17-07	100.0	100.1	100.0
KUE		I210	C4571179	07-17-07	100.0	100.0	99.9
KUE		I210	C4571180	07-17-07	99.9	99.9	100.0
KUE		I210	C4571181	07-17-07	100.0	100.0	100.1
KUE		I210	C4571182	07-17-07	100.0	100.0	100.0
KUE		I210	C4571183	07-17-07	100.0	100.0	100.0
KUE		I210	C4571184	07-17-07	100.0	100.0	100.1
KUE		I210	C4571185	07-17-07	100.0	100.0	100.1
KUE		I210	C4571186	07-17-07	100.0	100.0	100.0
KUE		I210	C4571187	07-17-07	99.9	100.0	100.0
KUE		I210	C4571188	07-17-07	100.0	100.0	100.1
KUE		I210	C4571189	07-17-07	100.0	100.1	100.1
KUE		I210	C4571190	07-17-07	100.0	100.0	100.0
KUE		I210	C4571191	07-17-07	100.0	100.0	100.1
KUE		I210	C4571192	07-17-07	100.0	100.0	100.1
KUE		I210	C4571193	07-17-07	99.9	100.0	100.1
KUE		I210	C4571194	07-17-07	100.1	100.0	100.1
KUE		I210	C4571195	07-17-07	100.0	100.0	100.1
KUE		I210	C4571196	07-17-07	100.0	100.0	100.0
KUE		I210	C4571197	07-17-07	100.0	100.0	100.1
KUE		I210	C4571198	07-17-07	100.0	100.1	100.0
KUE		I210	C4571199	07-17-07	100.0	100.0	99.9
KUE		I210	C457200	07-17-07	100.0	100.0	100.0
KUE		I210	C457201	07-17-07	100.0	100.0	100.0
KUE		I210	C457202	07-17-07	100.1	100.0	100.0
KUE		I210	C457203	07-17-07	100.0	100.0	100.0
KUE		I210	C457204	07-17-07	100.0	100.1	100.1
KUE		I210	C457205	07-17-07	100.0	100.0	100.0
KUE		I210	C457206	07-17-07	100.0	100.0	100.1
KUE		I210	C457207	07-17-07	100.0	100.0	100.1
KUE		I210	C457208	07-17-07	100.0	100.0	100.0
KUE		I210	C457209	07-17-07	100.0	100.0	100.1
KUE		I210	C457210	07-17-07	100.1	100.1	100.1
KUE		I210	C457211	07-17-07	100.0	100.0	100.0

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

CO	MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
KUE		I210	C457263	07-17-07	100.0	100.0	100.0
KUE		I210	C457264	07-17-07	100.0	100.0	99.9
KUE		I210	C457265	07-17-07	100.0	100.0	100.1
KUE		I210	C457266	07-17-07	100.1	100.1	100.1
KUE		I210	C457267	07-17-07	100.0	100.0	100.1
KUE		I210	C457268	07-17-07	100.0	100.0	100.1
KUE		I210	C457269	07-17-07	100.0	100.1	100.0
KUE		I210	C457270	07-17-07	100.0	100.0	100.0
KUE		I210	C457271	07-17-07	100.0	100.0	100.0
KUE		I210	C457272	07-17-07	100.0	100.1	100.0
KUE		I210	C457273	07-17-07	100.0	100.0	100.0
KUE		I210	C457274	07-17-07	100.0	100.0	100.0
KUE		I210	C457275	07-17-07	100.0	100.0	99.9
KUE		I210	C457276	07-17-07	100.0	100.0	99.9
KUE		I210	C457277	07-17-07	100.0	100.0	100.0
KUE		I210	C457278	07-17-07	100.1	100.1	100.0
KUE		I210	C457279	07-17-07	100.0	100.0	100.0
KUE		I210	C457280	07-17-07	100.0	100.0	100.0
KUE		I210	C457281	07-17-07	100.1	100.1	100.0
KUE		I210	C457282	07-17-07	100.0	100.0	99.9
KUE		I210	C457283	07-17-07	100.0	100.0	100.0
KUE		I210	C457284	07-17-07	100.0	100.0	100.1
KUE		I210	C457285	07-17-07	100.0	100.0	100.0
KUE		I210	C457286	07-17-07	100.0	100.0	100.0
KUE		I210	C457287	07-17-07	100.0	100.0	100.0
KUE		I210	C457288	07-17-07	100.0	100.0	100.0
KUE		I210	C457289	07-17-07	100.0	100.0	100.0
KUE		I210	C457290	07-17-07	100.0	100.0	99.9
KUE		I210	C457291	07-17-07	100.0	100.0	100.1
KUE		I210	C457292	07-17-07	100.0	100.0	100.1
KUE		I210	C457293	07-17-07	100.0	100.0	100.0
KUE		I210	C457294	07-17-07	100.1	100.0	100.0
KUE		I210	C457295	07-17-07	100.0	100.0	100.0
KUE		I210	C457296	07-17-07	100.0	100.0	100.1
KUE		I210	C457297	07-17-07	100.0	100.0	100.0
KUE		I210	C457298	07-17-07	100.0	100.0	100.0
KUE		I210	C457299	07-17-07	100.0	100.0	100.0
KUE		I210	C457300	07-17-07	100.0	100.0	100.1
KUE		I210	C457301	07-17-07	100.0	100.1	100.0
KUE		I210	C457302	07-17-07	100.0	100.0	100.1
KUE		I210	C457303	07-17-07	100.0	100.0	100.0
KUE		I210	C457304	07-17-07	100.0	100.0	100.1
KUE		I210	C457305	07-17-07	100.0	100.0	100.1
KUE		I210	C457306	07-17-07	100.1	100.1	100.1
KUE		I210	C457307	07-17-07	100.0	100.0	100.0
KUE		I210	C457308	07-17-07	100.0	100.0	100.0
KUE		I210	C457309	07-17-07	100.0	100.0	100.0
KUE		I210	C457310	07-17-07	100.0	100.0	100.0
KUE		I210	C457311	07-17-07	100.0	100.0	100.1
KUE		I210	C457312	07-17-07	100.1	100.0	100.1
KUE		I210	C457313	07-17-07	100.0	100.1	100.0

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

CO	MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
KUE		I210	C457365	07-17-07	100.0	100.0	100.1
KUE		I210	C457366	07-17-07	100.0	100.0	100.1
KUE		I210	C457367	07-17-07	100.0	100.0	100.1
KUE		I210	C457368	07-17-07	100.1	100.1	100.0
KUE		I210	C457369	07-17-07	100.1	100.1	99.9
KUE		I210	C457370	07-17-07	100.0	100.1	100.0
KUE		I210	C457371	07-17-07	100.0	100.0	100.0
KUE		I210	C457372	07-17-07	100.0	100.1	100.0
KUE		I210	C457373	07-17-07	100.0	100.0	100.0
KUE		I210	C457374	07-17-07	100.0	100.0	100.0
KUE		I210	C457375	07-17-07	100.0	100.0	100.1
KUE		I210	C457376	07-17-07	100.0	100.1	100.1
KUE		I210	C457377	07-17-07	100.0	100.0	99.9
KUE		I210	C457378	07-17-07	100.0	100.0	100.1
KUE		I210	C457379	07-17-07	100.0	100.0	100.0
KUE		I210	C457380	07-17-07	100.0	100.1	99.9
KUE		I210	C457381	07-17-07	100.1	100.1	100.1
KUE		I210	C457382	07-17-07	100.0	100.0	100.1
KUE		I210	C457383	07-17-07	100.0	100.0	100.0
KUE		I210	C457384	07-17-07	100.0	100.0	100.1
KUE		I210	C457385	07-17-07	100.0	100.0	100.0
KUE		I210	C457386	07-17-07	100.0	100.0	100.0
KUE		I210	C457387	07-17-07	100.0	100.0	99.9
KUE		I210	C457388	07-17-07	99.9	99.9	100.1
KUE		I210	C457389	07-17-07	100.0	100.0	100.0
KUE		I210	C457390	07-17-07	100.0	100.0	100.0
KUE		I210	C457391	07-17-07	100.0	100.0	99.9
KUE		I210	C457392	07-17-07	100.0	100.0	100.1
KUE		I210	C457393	07-17-07	100.0	100.1	100.1
KUE		I210	C457394	07-17-07	100.0	100.0	100.0
KUE		I210	C457395	07-17-07	100.0	100.0	100.0
KUE		I210	C457396	07-17-07	100.1	100.1	100.0
KUE		I210	C457397	07-17-07	99.9	99.9	100.0
KUE		I210	C457398	07-17-07	100.0	100.1	100.0
KUE		I210	C457399	07-17-07	100.0	100.0	100.0
KUE		I210	C457400	07-17-07	100.0	100.0	100.0
KUE		I210	C457401	07-17-07	100.0	100.0	100.0
KUE		I210	C457402	07-17-07	100.0	100.0	100.0
KUE		I210	C457403	07-17-07	100.0	100.0	100.1
KUE		I210	C457404	07-17-07	100.0	100.0	100.0
KUE		I210	C457405	07-17-07	100.0	100.0	100.1
KUE		I210	C457406	07-17-07	100.0	100.0	100.0
KUE		I210	C457407	07-17-07	100.0	100.0	100.1
KUE		I210	C457408	07-17-07	100.0	100.0	100.0
KUE		I210	C457409	07-17-07	100.0	100.0	100.0
KUE		I210	C457410	07-17-07	100.1	100.1	100.0
KUE		I210	C457411	07-17-07	100.0	100.0	100.0
KUE		I210	C457412	07-17-07	100.0	100.0	100.0
KUE		I210	C457413	07-17-07	100.0	100.0	100.1
KUE		I210	C457414	07-17-07	100.0	100.0	100.0
KUE		I210	C457415	07-17-07	100.0	100.0	100.0

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

CO	MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
KUE		I210	C457467	07-17-07	100.0	100.0	100.0
KUE		I210	C457468	07-17-07	100.0	100.0	100.1
KUE		I210	C457469	07-17-07	100.1	100.0	100.0
KUE		I210	C457470	07-17-07	100.1	100.1	100.0
KUE		I210	C457471	07-17-07	99.9	100.0	100.0
KUE		I210	C457472	07-17-07	100.0	100.0	100.0
KUE		I210	C457473	07-17-07	100.0	100.0	100.0
KUE		I210	C457474	07-17-07	100.0	100.0	100.0
KUE		I210	C457475	07-17-07	100.1	100.1	100.0
KUE		I210	C457476	07-17-07	100.0	100.0	100.0
KUE		I210	C457477	07-17-07	100.0	100.0	100.1
KUE		I210	C457478	07-17-07	100.0	100.0	99.9
KUE		I210	C457479	07-17-07	100.0	100.0	100.1
KUE		I210	C457480	07-17-07	100.0	99.9	100.0
KUE		I210	C457481	07-17-07	100.0	99.9	100.0
KUE		I210	C457482	07-17-07	100.0	100.0	100.0
KUE		I210	C457483	07-17-07	100.0	100.0	100.1
KUE		I210	C457484	07-17-07	100.0	100.1	100.0
KUE		I210	C457485	07-17-07	100.0	100.0	100.1
KUE		I210	C457486	07-17-07	100.1	100.0	100.1
KUE		I210	C457487	07-17-07	100.0	100.1	100.0
KUE		I210	C457488	07-17-07	100.0	100.1	100.0
KUE		I210	C457489	07-17-07	100.0	100.0	100.0
KUE		I210	C457490	07-17-07	100.0	100.0	100.1
KUE		I210	C457491	07-17-07	100.0	100.0	100.0
KUE		I210	C457492	07-17-07	99.9	100.0	100.0
KUE		I210	C457493	07-17-07	100.0	100.0	100.0
KUE		I210	C457494	07-17-07	100.0	100.0	100.0
KUE		I210	C457495	07-17-07	100.0	100.1	100.0
KUE		I210	C457496	07-17-07	100.0	100.0	100.0
KUE		I210	C457497	07-17-07	100.0	100.1	100.1
KUE		I210	C457498	07-17-07	100.0	100.0	100.0
KUE		I210	C457499	07-17-07	100.0	100.0	100.0
KUE		I210	C457500	07-17-07	100.0	100.0	100.1
KUE		I210	C457501	07-17-07	100.0	100.0	100.1
KUE		I210	C457502	07-17-07	100.0	100.0	100.0
KUE		I210	C457503	07-17-07	100.0	100.0	100.0
KUE		I210	C457504	07-17-07	100.0	100.0	100.1
KUE		I210	C457505	07-17-07	100.0	100.0	99.9
KUE		I210	C457506	07-17-07	100.0	100.0	100.0
KUE		I210	C457507	07-17-07	100.0	100.0	100.1
KUE		I210	C457508	07-17-07	100.1	100.0	99.9
KUE		I210	C457509	07-17-07	100.0	100.0	100.0
KUE		I210	C457510	07-17-07	100.0	100.0	100.0
KUE		I210	C457511	07-17-07	100.0	100.1	99.9
KUE		I210	C457512	07-17-07	100.0	100.0	100.1
KUE		I210	C457513	07-17-07	100.0	100.0	100.1
KUE		I210	C457514	07-17-07	100.0	100.0	99.9
KUE		I210	C457515	07-17-07	100.0	100.0	100.0
KUE		I210	C457516	07-17-07	100.0	100.0	99.9
KUE		I210	C457517	07-17-07	100.0	100.0	100.0

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

PAGE 27
 RUN DATE: 1/15/08
 RUN TIME: 22.00.58

CO	MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
KUE		I210	C457569	07-17-07	100.0	100.0	100.0
KUE		I210	C457570	07-17-07	100.0	100.1	100.0
KUE		I210	C457571	07-17-07	100.0	100.0	100.1
KUE		I210	C457572	07-17-07	100.0	100.0	100.0
KUE		I210	C457573	07-19-07	100.0	100.0	100.1
KUE		I210	C457574	07-19-07	100.0	100.0	100.1
KUE		I210	C457575	07-31-07	100.0	100.0	100.0
KUE		I210	C457576	07-31-07	100.0	100.0	100.0
KUE		I210	C457577	07-31-07	100.0	100.0	100.0
KUE		I210	C457578	07-31-07	100.0	100.0	100.0
KUE		I210	C457579	07-31-07	100.0	100.0	100.0
KUE		I210	C457580	07-31-07	100.0	100.0	100.0
KUE		I210	C457581	07-31-07	100.0	100.0	100.0
KUE		I210	C457582	07-31-07	100.0	100.0	100.0
KUE		I210	C457583	07-31-07	100.0	100.0	100.0
KUE		I210	C457584	07-31-07	100.0	100.0	100.0
KUE		I210	C457585	07-31-07	100.0	100.0	100.0
KUE		I210	C457586	07-31-07	100.0	100.0	100.0
KUE		I210	C457587	07-31-07	100.1	100.1	100.0
KUE		I210	C457588	07-31-07	100.1	100.1	100.0
KUE		I210	C457589	07-31-07	100.1	100.1	100.0
KUE		I210	C457590	07-31-07	100.1	100.1	100.0
KUE		I210	C457591	07-31-07	100.0	100.0	100.0
KUE		I210	C457592	07-31-07	100.0	100.0	100.0
KUE		I210	C457593	07-31-07	100.0	100.0	100.0
KUE		I210	C457594	07-31-07	100.0	100.0	100.0
KUE		I210	C457595	07-31-07	100.0	100.0	100.0
KUE		I210	C457596	07-31-07	100.0	100.0	100.0
KUE		I210	C457597	07-31-07	100.0	100.1	100.0
KUE		I210	C457598	07-31-07	100.0	100.0	100.0
KUE		I210	C457599	07-31-07	100.0	100.0	100.0
KUE		I210	C457600	07-31-07	100.0	100.0	100.0
KUE		I210	C457601	07-31-07	99.9	99.9	100.0
KUE		I210	C457602	07-31-07	100.0	100.0	100.0
KUE		I210	C457603	07-31-07	99.9	99.9	100.0
KUE		I210	C457604	07-31-07	100.0	100.0	100.0
KUE		I210	C457605	07-31-07	100.0	100.0	100.0
KUE		I210	C457606	07-31-07	100.0	100.0	100.0
KUE		I210	C457607	07-31-07	100.0	100.0	100.0
KUE		I210	C457608	07-31-07	100.1	100.1	100.0
KUE		I210	C457609	07-31-07	100.0	100.0	100.0
KUE		I210	C457610	07-31-07	100.0	100.1	100.0
KUE		I210	C457611	07-31-07	100.0	100.0	100.0
KUE		I210	C457612	07-31-07	100.0	100.0	100.0
KUE		I210	C457613	07-31-07	100.0	100.0	100.0
KUE		I210	C457614	07-31-07	100.0	100.0	100.0
KUE		I210	C457615	07-31-07	100.0	100.0	100.0
KUE		I210	C457616	07-31-07	100.0	100.0	100.0
KUE		I210	C457617	07-31-07	100.0	100.0	100.0
KUE		I210	C457618	07-31-07	100.0	100.0	100.0
KUE		I210	C457619	07-31-07	100.0	100.0	100.0

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

PAGE 29
 RUN DATE: 1/15/08
 RUN TIME: 22.00.58

CO	MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
KUE	LANDIS & GYR	MX	C446347	01-24-07	100.0	99.9	99.8
KUE	LANDIS & GYR	MX	C446348	01-24-07	99.9	99.9	100.0
KUE	LANDIS & GYR	MX	C446349	01-24-07	100.1	100.1	100.0
KUE	LANDIS & GYR	MX	C446350	01-24-07	100.0	100.2	100.4
KUE	LANDIS & GYR	MX	C446351	01-24-07	100.1	100.2	100.4
KUE	LANDIS & GYR	MX	C446352	01-24-07	100.1	100.2	100.3
KUE	LANDIS & GYR	MX	C446353	01-24-07	100.1	100.1	99.9
KUE	LANDIS & GYR	MX	C446354	01-24-07	100.0	100.2	99.9
KUE	LANDIS & GYR	MX	C446355	01-24-07	100.1	100.1	100.4
KUE	LANDIS & GYR	MX	C446356	01-24-07	100.1	100.1	100.0
KUE	LANDIS & GYR	MX	C446357	01-24-07	100.1	100.2	99.9
KUE	LANDIS & GYR	MX	C446358	01-24-07	100.1	100.2	100.2
KUE	LANDIS & GYR	MX	C446359	01-24-07	100.0	99.9	99.8
KUE	LANDIS & GYR	MX	C446360	01-24-07	100.0	100.0	100.0
KUE	LANDIS & GYR	MX	C446361	01-24-07	100.0	99.9	100.0
KUE	LANDIS & GYR	MX	C446362	01-24-07	100.0	100.1	100.0
KUE	LANDIS & GYR	MX	C446363	01-24-07	100.0	100.1	100.2
KUE	LANDIS & GYR	MX	C446364	01-24-07	100.0	100.1	100.2
KUE	LANDIS & GYR	MX	C446365	01-24-07	100.1	100.2	100.4
KUE	LANDIS & GYR	MX	C446366	01-24-07	100.1	100.1	100.2
KUE	LANDIS & GYR	MX	C446367	01-24-07	100.0	99.9	100.0
KUE	LANDIS & GYR	MX	C446368	01-24-07	100.0	100.0	100.1
KUE	LANDIS & GYR	MX	C446369	01-24-07	100.0	100.1	99.8
KUE	LANDIS & GYR	MX	C446370	01-24-07	100.0	100.0	99.9
KUE	LANDIS & GYR	MX	C446371	01-24-07	100.0	100.1	100.0
KUE	LANDIS & GYR	MX	C446372	01-24-07	100.0	100.0	100.0
KUE	LANDIS & GYR	MX	C446373	01-24-07	100.0	100.0	100.0
KUE	LANDIS & GYR	MX	C446374	01-24-07	100.0	99.9	100.2
KUE	LANDIS & GYR	MX	C446375	01-24-07	100.1	99.9	100.1
KUE	LANDIS & GYR	MX	C446376	01-24-07	100.1	100.2	100.3
KUE	LANDIS & GYR	MX	C446377	01-24-07	100.0	100.1	99.9
KUE	LANDIS & GYR	MX	C446378	01-24-07	100.0	99.9	100.0
KUE	LANDIS & GYR	MX	C446379	01-24-07	100.1	100.1	99.9
KUE	LANDIS & GYR	MX	C446380	01-24-07	100.1	100.1	99.9
KUE	LANDIS & GYR	MX	C446381	01-23-07	99.9	100.0	100.0
KUE	LANDIS & GYR	MX	C446382	01-24-07	100.0	100.0	99.9
KUE	LANDIS & GYR	MX	C446383	01-24-07	100.1	100.2	100.3
KUE	LANDIS & GYR	MX	C446384	01-24-07	100.0	99.9	100.0
KUE	LANDIS & GYR	MX	C446385	01-24-07	100.1	99.9	100.1
KUE	LANDIS & GYR	MX	C446386	01-24-07	100.0	100.0	100.4
KUE	LANDIS & GYR	MX	C446387	01-24-07	100.1	100.2	100.1
KUE	LANDIS & GYR	MX	C446388	01-24-07	100.0	100.1	100.4
KUE	LANDIS & GYR	MX	C446389	01-24-07	100.1	100.1	100.6
KUE	LANDIS & GYR	MX	C446390	01-24-07	100.1	100.2	100.2
KUE	LANDIS & GYR	MX	C446391	01-24-07	100.0	100.1	100.3
KUE	LANDIS & GYR	MX	C446392	01-24-07	100.1	100.0	99.7
KUE	LANDIS & GYR	MX	C446393	01-24-07	100.1	100.0	100.2
KUE	LANDIS & GYR	MX	C446394	01-24-07	100.0	99.9	100.2
KUE	LANDIS & GYR	MX	C446395	01-24-07	100.0	100.0	100.2
KUE	LANDIS & GYR	MX	C446396	01-24-07	100.0	100.1	100.1
KUE	LANDIS & GYR	MX	C446397	01-24-07	100.0	100.0	99.16

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

PAGE 31
 RUN DATE: 1/15/08
 RUN TIME: 22.00.58

CO	MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
KUE	LANDIS & GYR	MX	C446449	01-24-07	100.0	100.0	99.7
KUE	LANDIS & GYR	MX	C446450	01-24-07	100.1	100.1	100.3
KUE	LANDIS & GYR	MX	C446451	01-24-07	100.1	100.1	100.3
KUE	LANDIS & GYR	MX	C446452	01-24-07	100.1	100.1	100.3
KUE	LANDIS & GYR	MX	C446453	01-24-07	100.0	100.0	100.3
KUE	LANDIS & GYR	MX	C446454	01-24-07	100.1	100.1	100.0
KUE	LANDIS & GYR	MX	C446455	01-24-07	100.1	100.0	99.9
KUE	LANDIS & GYR	MX	C446456	01-24-07	100.0	100.0	100.4
KUE	LANDIS & GYR	MX	C446457	01-24-07	100.0	100.0	99.8
KUE	LANDIS & GYR	MX	C446458	01-24-07	100.0	100.1	100.1
KUE	LANDIS & GYR	MX	C446459	01-24-07	100.0	100.1	100.2
KUE	LANDIS & GYR	MX	C446460	01-24-07	100.1	100.1	99.9
KUE	LANDIS & GYR	MX	C446461	01-24-07	100.1	100.1	100.1
KUE	LANDIS & GYR	MX	C446462	01-24-07	100.0	100.0	99.9
KUE	LANDIS & GYR	MX	C446463	01-24-07	100.1	100.1	100.3
KUE	LANDIS & GYR	MX	C446464	01-24-07	100.0	100.1	100.2
KUE	LANDIS & GYR	MX	C446465	01-24-07	100.1	100.1	100.3
KUE	LANDIS & GYR	MX	C446466	01-24-07	100.0	99.9	100.0
KUE	LANDIS & GYR	MX	C446467	01-24-07	100.0	100.1	100.2
KUE	LANDIS & GYR	MX	C446468	01-24-07	100.0	100.1	100.1
KUE	LANDIS & GYR	MX	C446469	01-24-07	100.0	100.0	99.9
KUE	LANDIS & GYR	MX	C446470	01-24-07	100.0	100.0	100.1
KUE	LANDIS & GYR	MX	C446471	01-24-07	100.0	100.0	99.9
KUE	LANDIS & GYR	MX	C446472	01-24-07	100.0	100.1	100.0
KUE	LANDIS & GYR	MX	C446473	01-24-07	99.9	100.0	99.8
KUE	LANDIS & GYR	MX	C446474	01-24-07	100.0	100.0	100.1
KUE	LANDIS & GYR	MX	C446475	01-24-07	100.1	99.9	100.0
KUE	LANDIS & GYR	MX	C446476	01-24-07	100.0	100.1	99.9
KUE	LANDIS & GYR	MX	C446477	01-24-07	100.0	100.0	99.9
KUE	LANDIS & GYR	MX	C446478	01-24-07	100.0	100.2	100.2
KUE	LANDIS & GYR	MX	C446479	01-24-07	100.1	100.1	100.2
KUE	LANDIS & GYR	MX	C446480	01-24-07	100.1	100.0	100.2
KUE	LANDIS & GYR	MX	C446481	01-24-07	100.0	99.9	100.3
KUE	LANDIS & GYR	MX	C446482	01-24-07	100.1	100.0	99.9
KUE	LANDIS & GYR	MX	C446483	01-24-07	99.9	100.0	100.1
KUE	LANDIS & GYR	MX	C446484	01-24-07	100.0	100.0	100.1
KUE	LANDIS & GYR	MX	C446485	01-24-07	100.1	100.2	100.5
KUE	LANDIS & GYR	MX	C446486	01-24-07	100.0	100.1	100.0
KUE	LANDIS & GYR	MX	C446487	01-24-07	100.0	100.1	100.2
KUE	LANDIS & GYR	MX	C446488	01-24-07	100.1	100.0	100.0
KUE	LANDIS & GYR	MX	C446489	01-24-07	100.0	100.1	100.4
KUE	LANDIS & GYR	MX	C446490	01-24-07	100.0	100.1	100.2
KUE	LANDIS & GYR	MX	C446491	01-24-07	100.0	99.9	99.6
KUE	LANDIS & GYR	MX	C446492	01-24-07	100.1	99.9	100.1
KUE	LANDIS & GYR	MX	C446493	01-24-07	100.0	100.0	100.1
KUE	LANDIS & GYR	MX	C446494	01-24-07	100.0	99.9	100.1
KUE	LANDIS & GYR	MX	C446495	01-24-07	100.0	100.0	100.2
KUE	LANDIS & GYR	MX	C446496	01-24-07	100.0	100.0	100.2
KUE	LANDIS & GYR	MX	C446497	01-24-07	100.0	100.0	100.5
KUE	LANDIS & GYR	MX	C446498	01-24-07	100.0	100.0	100.5
KUE	LANDIS & GYR	MX	C446499	01-24-07	100.1	100.1	100.1

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

CO	MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
KUE	LANDIS & GYR	MX	C446551	01-24-07	100.1	100.2	100.0
KUE	LANDIS & GYR	MX	C446552	01-24-07	100.0	100.0	100.3
KUE	LANDIS & GYR	MX	C446553	01-24-07	100.0	100.1	100.0
KUE	LANDIS & GYR	MX	C446554	01-24-07	100.1	100.1	100.2
KUE	LANDIS & GYR	MX	C446555	01-24-07	100.1	100.1	100.3
KUE	LANDIS & GYR	MX	C446556	01-24-07	100.0	99.9	100.3
KUE	LANDIS & GYR	MX	C446557	01-24-07	100.0	100.0	99.9
KUE	LANDIS & GYR	MX	C446558	01-24-07	100.1	100.2	100.2
KUE	LANDIS & GYR	MX	C446559	01-24-07	100.1	100.1	100.1
KUE	LANDIS & GYR	MX	C446560	01-24-07	100.0	100.1	100.1
KUE	LANDIS & GYR	MX	C446561	01-24-07	100.0	100.0	99.5
KUE	LANDIS & GYR	MX	C446562	01-24-07	100.1	100.0	100.3
KUE	LANDIS & GYR	MX	C446563	01-24-07	100.1	100.1	100.4
KUE	LANDIS & GYR	MX	C446564	01-24-07	100.1	100.1	100.5
KUE	LANDIS & GYR	MX	C446565	01-24-07	100.1	100.0	100.3
KUE	LANDIS & GYR	MX	C446566	01-24-07	100.1	100.1	99.7
KUE	LANDIS & GYR	MX	C446567	01-24-07	100.0	100.1	100.3
KUE	LANDIS & GYR	MX	C446568	01-24-07	100.0	100.1	100.2
KUE	LANDIS & GYR	MX	C446569	01-24-07	100.1	100.0	100.2
KUE	LANDIS & GYR	MX	C446570	01-24-07	100.0	100.1	100.4
KUE	LANDIS & GYR	MX	C446571	01-24-07	100.0	100.2	99.6
KUE	LANDIS & GYR	MX	C446572	01-24-07	100.1	100.0	99.9
KUE	LANDIS & GYR	MX	C446573	01-24-07	99.9	100.1	100.0
KUE	LANDIS & GYR	MX	C446574	01-24-07	100.0	100.1	99.8
KUE	LANDIS & GYR	MX	C446575	01-24-07	100.0	100.0	99.8
KUE	LANDIS & GYR	MX	C446576	01-24-07	100.0	99.9	100.1
KUE	LANDIS & GYR	MX	C446577	01-24-07	100.0	100.1	100.0
KUE	LANDIS & GYR	MX	C446578	01-24-07	100.1	100.1	100.0
KUE	LANDIS & GYR	MX	C446579	01-24-07	100.0	100.0	100.1
KUE	LANDIS & GYR	MX	C446580	01-24-07	100.0	100.0	100.4
KUE	LANDIS & GYR	MX	C446581	01-24-07	100.0	99.9	100.2
KUE	LANDIS & GYR	MX	C446582	01-24-07	100.0	100.1	99.9
KUE	LANDIS & GYR	MX	C446583	01-24-07	100.0	100.1	99.9
KUE	LANDIS & GYR	MX	C446584	01-24-07	100.1	100.1	100.2
KUE	LANDIS & GYR	MX	C446585	01-24-07	100.0	99.9	99.8
KUE	LANDIS & GYR	MX	C446586	01-24-07	100.1	100.2	100.0
KUE	LANDIS & GYR	MX	C446587	01-24-07	100.0	100.0	99.9
KUE	LANDIS & GYR	MX	C446588	01-24-07	100.0	99.9	100.1
KUE	LANDIS & GYR	MX	C446589	01-24-07	100.0	100.1	99.7
KUE	LANDIS & GYR	MX	C446590	01-24-07	100.0	100.0	100.2
KUE	LANDIS & GYR	MX	C446591	01-24-07	100.0	100.0	100.1
KUE	LANDIS & GYR	MX	C446592	01-24-07	100.1	100.2	100.4
KUE	LANDIS & GYR	MX	C446593	01-24-07	100.0	100.0	99.8
KUE	LANDIS & GYR	MX	C446594	01-24-07	100.1	100.1	100.4
KUE	LANDIS & GYR	MX	C446595	01-24-07	100.0	100.0	100.5
KUE	LANDIS & GYR	MX	C446596	01-24-07	100.1	100.1	100.4
KUE	LANDIS & GYR	MX	C446597	01-24-07	100.0	100.2	99.9
KUE	LANDIS & GYR	MX	C446598	01-24-07	100.0	100.1	99.7
KUE	LANDIS & GYR	MX	C446599	01-24-07	100.0	100.0	100.1
KUE	LANDIS & GYR	MX	C446600	01-24-07	100.1	100.0	100.0
KUE	LANDIS & GYR	MX	C446601	01-24-07	100.0	100.0	100.0

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

PAGE 35
 RUN DATE: 1/15/08
 RUN TIME: 22.00.58

CO	MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
KUE	LANDIS & GYR	MX	C446653	01-24-07	100.0	100.0	99.9
KUE	LANDIS & GYR	MX	C446654	01-24-07	100.0	100.0	99.9
KUE	LANDIS & GYR	MX	C446655	01-24-07	100.0	100.0	99.9
KUE	LANDIS & GYR	MX	C446656	01-24-07	100.0	100.1	100.4
KUE	LANDIS & GYR	MX	C446657	01-24-07	100.1	100.0	100.2
KUE	LANDIS & GYR	MX	C446658	01-24-07	100.1	100.1	100.2
KUE	LANDIS & GYR	MX	C446659	01-24-07	100.1	100.0	100.0
KUE	LANDIS & GYR	MX	C446660	01-24-07	100.1	100.0	99.6
KUE	LANDIS & GYR	MX	C446661	01-24-07	100.0	100.1	100.5
KUE	LANDIS & GYR	MX	C446662	01-24-07	100.0	99.9	99.8
KUE	LANDIS & GYR	MX	C446663	01-24-07	100.1	100.1	100.1
KUE	LANDIS & GYR	MX	C446664	01-24-07	100.1	100.2	100.5
KUE	LANDIS & GYR	MX	C446665	01-24-07	100.0	100.0	100.3
KUE	LANDIS & GYR	MX	C446666	01-24-07	100.0	100.0	100.0
KUE	LANDIS & GYR	MX	C446667	01-24-07	100.0	99.9	100.3
KUE	LANDIS & GYR	MX	C446668	01-24-07	100.0	99.9	100.2
KUE	LANDIS & GYR	MX	C446669	01-24-07	100.1	100.0	100.2
KUE	LANDIS & GYR	MX	C446670	01-24-07	100.0	100.1	99.8
KUE	LANDIS & GYR	MX	C446671	01-24-07	100.1	100.1	100.1
KUE	LANDIS & GYR	MX	C446672	01-24-07	99.9	100.2	99.5
KUE	LANDIS & GYR	MX	C446673	01-24-07	100.1	100.0	100.4
KUE	LANDIS & GYR	MX	C446674	01-24-07	100.0	100.1	100.5
KUE	LANDIS & GYR	MX	C446675	01-24-07	100.0	100.0	99.7
KUE	LANDIS & GYR	MX	C446676	01-24-07	100.0	100.2	100.0
KUE	LANDIS & GYR	MX	C446677	01-24-07	100.1	100.0	100.4
KUE	LANDIS & GYR	MX	C446678	01-24-07	100.1	100.1	100.5
KUE	LANDIS & GYR	MX	C446679	01-24-07	100.0	100.0	100.1
KUE	LANDIS & GYR	MX	C446680	01-24-07	100.0	100.0	99.8
KUE	LANDIS & GYR	MX	C446681	01-24-07	100.0	100.0	100.2
KUE	LANDIS & GYR	MX	C446682	01-24-07	100.1	100.1	100.1
KUE	LANDIS & GYR	MX	C446683	01-24-07	100.1	100.2	100.1
KUE	LANDIS & GYR	MX	C446684	01-24-07	100.1	100.2	99.9
KUE	LANDIS & GYR	MX	C446685	01-24-07	100.0	99.9	100.1
KUE	LANDIS & GYR	MX	C446686	01-24-07	100.0	99.9	100.2
KUE	LANDIS & GYR	MX	C446687	01-24-07	100.0	100.1	100.2
KUE	LANDIS & GYR	MX	C446688	01-24-07	100.0	100.1	100.0
KUE	LANDIS & GYR	MX	C446689	01-24-07	100.0	100.0	100.2
KUE	LANDIS & GYR	MX	C446690	01-24-07	100.1	100.0	99.9
KUE	LANDIS & GYR	MX	C446691	01-24-07	100.0	100.1	100.2
KUE	LANDIS & GYR	MX	C446692	01-24-07	100.1	100.2	100.0
KUE	LANDIS & GYR	MX	C446693	01-24-07	100.0	100.1	100.0
KUE	LANDIS & GYR	MX	C446694	01-24-07	100.1	100.1	100.2
KUE	LANDIS & GYR	MX	C446695	01-24-07	100.1	100.2	100.3
KUE	LANDIS & GYR	MX	C446696	01-24-07	100.1	100.1	100.1
KUE	LANDIS & GYR	MX	C446697	01-24-07	100.0	100.0	100.1
KUE	LANDIS & GYR	MX	C446698	01-24-07	100.0	100.1	99.5
KUE	LANDIS & GYR	MX	C446699	01-24-07	100.1	100.1	100.4
KUE	LANDIS & GYR	MX	C446700	01-24-07	100.0	100.2	99.9
KUE	LANDIS & GYR	MX	C446701	01-24-07	100.0	100.0	100.0
KUE	LANDIS & GYR	MX	C446702	01-24-07	100.0	100.0	100.1
KUE	LANDIS & GYR	MX	C446703	01-24-07	100.0	99.9	100.1

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

PAGE 37
 RUN DATE: 1/15/08
 RUN TIME: 22.00.58

CO	MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
KUE	LANDIS & GYR	MX	C446755	01-24-07	100.1	100.1	100.0
KUE	LANDIS & GYR	MX	C446756	01-24-07	100.1	100.2	100.3
KUE	LANDIS & GYR	MX	C446757	01-24-07	100.1	99.9	100.3
KUE	LANDIS & GYR	MX	C446758	01-24-07	100.1	100.1	100.2
KUE	LANDIS & GYR	MX	C446759	01-24-07	100.0	100.1	100.3
KUE	LANDIS & GYR	MX	C446760	01-24-07	100.1	100.0	100.2
KUE	LANDIS & GYR	MX	C446761	01-24-07	100.1	100.0	100.3
KUE	LANDIS & GYR	MX	C446762	01-24-07	100.1	100.1	100.1
KUE	LANDIS & GYR	MX	C446763	01-24-07	99.9	99.9	99.9
KUE	LANDIS & GYR	MX	C446764	01-24-07	100.0	100.0	100.0
KUE	LANDIS & GYR	MX	C446765	01-24-07	100.1	100.0	99.7
KUE	LANDIS & GYR	MX	C446766	01-24-07	100.0	100.0	100.1
KUE	LANDIS & GYR	MX	C446767	01-24-07	100.0	100.1	100.2
KUE	LANDIS & GYR	MX	C446768	01-24-07	100.0	100.0	100.2
KUE	LANDIS & GYR	MX	C446769	01-24-07	100.1	99.9	100.2
KUE	LANDIS & GYR	MX	C446770	01-24-07	100.1	100.0	100.1
KUE	LANDIS & GYR	MX	C446771	01-24-07	100.1	100.1	100.1
KUE	LANDIS & GYR	MX	C446772	01-24-07	100.1	100.0	99.8
KUE	LANDIS & GYR	MX	C446773	01-24-07	100.1	100.0	100.4
KUE	LANDIS & GYR	MX	C446774	01-24-07	100.0	100.1	100.0
KUE	LANDIS & GYR	MX	C446775	01-24-07	100.1	100.0	100.4
KUE	LANDIS & GYR	MX	C446776	01-24-07	100.0	99.9	100.5
KUE	LANDIS & GYR	MX	C446777	01-24-07	100.0	100.1	100.0
KUE	LANDIS & GYR	MX	C446778	01-24-07	100.1	100.1	100.1
KUE	LANDIS & GYR	MX	C446779	01-24-07	100.1	100.0	100.2
KUE	LANDIS & GYR	MX	C446780	01-24-07	100.0	100.1	99.9
KUE	LANDIS & GYR	MX	C446781	01-24-07	100.0	100.0	100.2
KUE	LANDIS & GYR	MX	C446782	01-24-07	100.0	100.1	100.0
KUE	LANDIS & GYR	MX	C446783	01-24-07	100.0	100.1	100.3
KUE	LANDIS & GYR	MX	C446784	01-24-07	100.0	100.1	99.9
KUE	LANDIS & GYR	MX	C446785	01-24-07	100.0	100.1	99.9
KUE	LANDIS & GYR	MX	C446786	01-24-07	100.0	99.9	100.4
KUE	LANDIS & GYR	MX	C446787	01-24-07	100.1	100.2	100.4
KUE	LANDIS & GYR	MX	C446788	01-24-07	100.0	100.0	100.1
KUE	LANDIS & GYR	MX	C446789	01-24-07	100.0	100.1	100.0
KUE	LANDIS & GYR	MX	C446790	01-24-07	100.1	100.1	100.2
KUE	LANDIS & GYR	MX	C446791	01-24-07	100.1	99.9	100.3
KUE	LANDIS & GYR	MX	C446792	01-24-07	100.1	100.1	99.6
KUE	LANDIS & GYR	MX	C446793	01-24-07	100.0	100.0	100.3
KUE	LANDIS & GYR	MX	C446794	01-24-07	100.1	100.1	100.3
KUE	LANDIS & GYR	MX	C446795	01-24-07	100.1	100.0	100.2
KUE	LANDIS & GYR	MX	C446796	01-24-07	100.0	100.1	100.4
KUE	LANDIS & GYR	MX	C446797	01-24-07	100.1	100.1	100.2
KUE	LANDIS & GYR	MX	C446798	01-24-07	100.1	100.0	100.1
KUE	LANDIS & GYR	MX	C446799	01-24-07	100.1	100.1	99.9
KUE	LANDIS & GYR	MX	C446800	01-24-07	100.0	100.0	99.9
KUE	LANDIS & GYR	MX	C446801	01-24-07	100.1	100.0	100.1
KUE	LANDIS & GYR	MX	C446802	01-24-07	100.0	100.0	100.0
KUE	LANDIS & GYR	MX	C446803	01-24-07	100.1	100.0	100.5
KUE	LANDIS & GYR	MX	C446804	01-24-07	100.1	100.1	100.1
KUE	LANDIS & GYR	MX	C446805	01-24-07	100.1	100.0	100.3

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

PAGE 39
 RUN DATE: 1/15/08
 RUN TIME: 22.00.58

CO	MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
KUE	LANDIS & GYR	MX	C446857	01-24-07	100.1	100.1	99.6
KUE	LANDIS & GYR	MX	C446858	01-24-07	100.1	100.0	100.0
KUE	LANDIS & GYR	MX	C446859	01-24-07	100.1	100.0	100.1
KUE	LANDIS & GYR	MX	C446860	01-24-07	100.1	100.2	99.9
KUE	LANDIS & GYR	MX	C446861	01-24-07	100.0	100.2	100.1
KUE	LANDIS & GYR	MX	C446862	01-24-07	100.0	100.1	99.8
KUE	LANDIS & GYR	MX	C446863	01-24-07	100.0	99.9	99.7
KUE	LANDIS & GYR	MX	C446864	01-24-07	100.1	99.9	100.3
KUE	LANDIS & GYR	MX	C446865	01-24-07	100.0	100.1	99.6
KUE	LANDIS & GYR	MX	C446866	01-24-07	100.1	100.1	100.1
KUE	LANDIS & GYR	MX	C446867	01-24-07	100.1	100.0	100.1
KUE	LANDIS & GYR	MX	C446868	01-24-07	100.0	99.9	100.0
KUE	LANDIS & GYR	MX	C446869	01-24-07	100.0	100.2	100.1
KUE	LANDIS & GYR	MX	C446870	01-24-07	100.1	100.0	100.2
KUE	LANDIS & GYR	MX	C446871	01-24-07	100.0	100.0	100.2
KUE	LANDIS & GYR	MX	C446872	01-24-07	100.1	100.0	100.2
KUE	LANDIS & GYR	MX	C446873	01-24-07	100.1	100.0	100.2
KUE	LANDIS & GYR	MX	C446874	01-24-07	100.1	100.2	99.6
KUE	LANDIS & GYR	MX	C446875	01-24-07	100.1	100.1	100.4
KUE	LANDIS & GYR	MX	C446876	01-24-07	100.1	100.0	100.4
KUE	LANDIS & GYR	MX	C446877	01-24-07	100.1	100.0	99.7
KUE	LANDIS & GYR	MX	C446878	01-24-07	100.0	100.1	100.1
KUE	LANDIS & GYR	MX	C446879	01-24-07	100.1	100.2	100.0
KUE	LANDIS & GYR	MX	C446880	01-24-07	100.1	100.1	99.9
KUE	LANDIS & GYR	MX	C446881	01-24-07	100.1	100.0	99.8
KUE	LANDIS & GYR	MX	C446882	01-24-07	100.0	100.2	99.9
KUE	LANDIS & GYR	MX	C446883	01-24-07	100.1	100.2	99.8
KUE	LANDIS & GYR	MX	C446884	01-24-07	100.0	100.1	100.2
KUE	LANDIS & GYR	MX	C446885	01-24-07	100.0	100.0	99.9
KUE	LANDIS & GYR	MX	C446886	01-24-07	100.1	100.0	99.8
KUE	LANDIS & GYR	MX	C446887	01-24-07	100.0	100.2	99.6
KUE	LANDIS & GYR	MX	C446888	01-24-07	100.1	100.1	99.7
KUE	LANDIS & GYR	MX	C446889	01-24-07	100.1	100.2	99.9
KUE	LANDIS & GYR	MX	C446890	01-24-07	100.0	100.1	100.3
KUE	LANDIS & GYR	MX	C446891	01-24-07	100.0	100.1	100.4
KUE	LANDIS & GYR	MX	C446892	01-24-07	100.0	99.9	100.3
KUE	LANDIS & GYR	MX	C446893	01-24-07	100.1	100.1	100.3
KUE	LANDIS & GYR	MX	C446894	01-24-07	100.0	100.0	100.3
KUE	LANDIS & GYR	MX	C446895	01-24-07	100.0	99.9	100.3
KUE	LANDIS & GYR	MX	C446896	01-24-07	100.0	100.0	100.3
KUE	LANDIS & GYR	MX	C446897	01-24-07	99.9	100.0	100.3
KUE	LANDIS & GYR	MX	C446898	01-24-07	100.0	100.0	100.3
KUE	LANDIS & GYR	MX	C446899	01-24-07	100.0	100.0	100.3
KUE	LANDIS & GYR	MX	C446900	01-24-07	100.0	99.9	100.3
KUE	LANDIS & GYR	MX	C446901	01-24-07	100.1	100.1	100.0
KUE	LANDIS & GYR	MX	C446902	01-24-07	100.1	100.1	100.0
KUE	LANDIS & GYR	MX	C446903	01-24-07	100.1	100.1	100.0
KUE	LANDIS & GYR	MX	C446904	01-24-07	100.1	100.1	100.3
KUE	LANDIS & GYR	MX	C446905	01-24-07	100.1	100.2	100.3
KUE	LANDIS & GYR	MX	C446906	01-24-07	100.1	100.1	100.2
KUE	LANDIS & GYR	MX	C446907	01-24-07	100.0	100.1	99.8
KUE	LANDIS & GYR	MX	C446908	01-24-07	100.1	100.1	100.2
KUE	LANDIS & GYR	MX	C446909	01-24-07	100.1	100.1	100.2
KUE	LANDIS & GYR	MX	C446910	01-24-07	100.1	100.1	100.2

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

CO	MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
KUE	LANDIS & GYR	&	C446959	01-24-07	100.0	100.1	100.1
KUE	LANDIS &	&	C446960	01-24-07	100.1	100.2	100.5
KUE	LANDIS &	&	C446961	01-24-07	100.0	100.0	99.9
KUE	LANDIS &	&	C446962	01-24-07	100.0	100.0	99.9
KUE	LANDIS &	&	C446963	01-24-07	100.0	100.0	100.0
KUE	LANDIS &	&	C446964	01-24-07	100.1	100.1	99.9
KUE	LANDIS &	&	C446965	01-24-07	100.0	100.0	100.0
KUE	LANDIS &	&	C446966	01-24-07	100.0	100.0	99.9
KUE	LANDIS &	&	C446967	01-24-07	100.0	100.1	100.2
KUE	LANDIS &	&	C446968	01-24-07	100.1	100.1	100.5
KUE	LANDIS &	&	C446969	01-24-07	100.0	100.1	100.4
KUE	LANDIS &	&	C446970	01-24-07	100.0	100.1	100.1
KUE	LANDIS &	&	C446971	01-24-07	100.1	100.1	99.9
KUE	LANDIS &	&	C446972	01-24-07	100.0	100.1	100.0
KUE	LANDIS &	&	C446973	01-24-07	100.1	100.1	100.4
KUE	LANDIS &	&	C446974	01-24-07	100.1	100.1	100.1
KUE	LANDIS &	&	C446975	01-24-07	100.1	100.1	100.1
KUE	LANDIS &	&	C446976	01-24-07	100.1	100.1	99.9
KUE	LANDIS &	&	C446977	01-24-07	100.0	100.0	100.1
KUE	LANDIS &	&	C446978	01-24-07	100.1	100.0	100.0
KUE	LANDIS &	&	C446979	01-24-07	100.0	100.1	100.1
KUE	LANDIS &	&	C446980	01-24-07	100.0	100.0	100.0
KUE	LANDIS &	&	C446981	01-24-07	100.0	100.0	99.9
KUE	LANDIS &	&	C446982	01-24-07	100.0	100.0	100.1
KUE	LANDIS &	&	C446983	01-24-07	100.1	100.1	100.4
KUE	LANDIS &	&	C446984	01-24-07	100.0	100.1	100.1
KUE	LANDIS &	&	C446985	01-24-07	100.1	100.1	100.0
KUE	LANDIS &	&	C446986	01-24-07	100.0	100.0	100.0
KUE	LANDIS &	&	C446987	01-24-07	100.0	100.0	100.0
KUE	LANDIS &	&	C446988	01-24-07	100.0	100.1	100.1
KUE	LANDIS &	&	C446989	01-24-07	100.1	100.1	99.9
KUE	LANDIS &	&	C446990	01-24-07	100.1	100.1	100.0
KUE	LANDIS &	&	C446991	01-24-07	100.1	100.1	100.1
KUE	LANDIS &	&	C446992	01-24-07	100.1	100.1	100.1
KUE	LANDIS &	&	C446993	01-24-07	100.0	100.1	100.3
KUE	LANDIS &	&	C446994	01-24-07	100.0	100.0	100.0
KUE	LANDIS &	&	C446995	01-24-07	100.0	100.0	100.0
KUE	LANDIS &	&	C446996	01-24-07	100.0	100.0	100.0
KUE	LANDIS &	&	C446997	01-24-07	100.1	100.1	100.0
KUE	LANDIS &	&	C446998	01-24-07	100.1	100.0	100.0
KUE	LANDIS &	&	C446999	01-24-07	100.0	100.0	100.0
KUE	LANDIS &	&	C447000	01-24-07	100.0	100.0	100.0
KUE	LANDIS &	&	C447001	01-24-07	100.0	100.0	100.4
KUE	LANDIS &	&	C447002	01-24-07	100.0	100.0	99.9
KUE	LANDIS &	&	C447003	01-24-07	100.1	100.0	100.0
KUE	LANDIS &	&	C447004	01-24-07	100.0	100.0	100.0
KUE	LANDIS &	&	C447005	01-24-07	100.1	100.1	100.2
KUE	LANDIS &	&	C447006	01-24-07	100.0	100.0	100.4
KUE	LANDIS &	&	C447007	01-24-07	100.1	100.1	100.2
KUE	LANDIS &	&	C447008	01-24-07	100.0	100.0	100.0

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

CO	MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
KUE	LANDIS & GYR	MX	C447061	01-24-07	100.0	100.1	100.1
KUE	LANDIS & GYR	MX	C447062	01-24-07	100.1	100.2	100.5
KUE	LANDIS & GYR	MX	C447063	01-24-07	100.1	100.1	99.8
KUE	LANDIS & GYR	MX	C447064	01-24-07	100.1	100.0	100.4
KUE	LANDIS & GYR	MX	C447065	01-24-07	100.1	99.9	99.9
KUE	LANDIS & GYR	MX	C447066	01-24-07	100.0	100.2	100.2
KUE	LANDIS & GYR	MX	C447067	01-24-07	100.1	100.4	100.4
KUE	LANDIS & GYR	MX	C447068	01-24-07	100.0	100.1	100.2
KUE	LANDIS & GYR	MX	C447069	01-24-07	100.0	99.9	100.3
KUE	LANDIS & GYR	MX	C447070	01-24-07	100.1	99.9	100.1
KUE	LANDIS & GYR	MX	C447071	01-24-07	100.1	100.0	100.1
KUE	LANDIS & GYR	MX	C447072	01-24-07	100.0	100.0	99.9
KUE	LANDIS & GYR	MX	C447073	01-24-07	100.0	100.0	99.9
KUE	LANDIS & GYR	MX	C447074	01-24-07	100.1	100.1	100.2
KUE	LANDIS & GYR	MX	C447075	01-24-07	100.0	100.0	100.0
KUE	LANDIS & GYR	MX	C447076	01-24-07	100.1	100.1	100.2
KUE	LANDIS & GYR	MX	C447077	01-24-07	100.1	100.0	99.9
KUE	LANDIS & GYR	MX	C447078	01-24-07	100.0	100.0	100.2
KUE	LANDIS & GYR	MX	C447079	01-24-07	100.0	100.0	99.8
KUE	LANDIS & GYR	MX	C447080	01-24-07	100.0	99.9	99.8
KUE	LANDIS & GYR	MX	C447081	01-24-07	100.1	100.0	100.3
KUE	LANDIS & GYR	MX	C447082	01-24-07	100.1	100.1	100.1
KUE	LANDIS & GYR	MX	C447083	01-24-07	100.1	100.1	100.3
KUE	LANDIS & GYR	MX	C447084	01-24-07	100.1	100.1	100.0
KUE	LANDIS & GYR	MX	C447085	01-24-07	100.1	100.1	100.4
KUE	LANDIS & GYR	MX	C447086	01-24-07	100.0	99.9	100.4
KUE	LANDIS & GYR	MX	C447087	01-24-07	100.1	100.1	99.8
KUE	LANDIS & GYR	MX	C447088	01-24-07	100.1	100.2	100.2
KUE	LANDIS & GYR	MX	C447089	01-24-07	100.1	100.1	100.4
KUE	LANDIS & GYR	MX	C447090	01-24-07	100.1	100.1	100.0
KUE	LANDIS & GYR	MX	C447091	01-24-07	100.1	99.9	100.3
KUE	LANDIS & GYR	MX	C447092	01-24-07	100.0	100.0	100.1
KUE	LANDIS & GYR	MX	C447093	01-24-07	100.1	100.1	100.1
KUE	LANDIS & GYR	MX	C447094	01-24-07	100.1	100.1	100.4
KUE	LANDIS & GYR	MX	C447095	01-25-07	100.0	99.9	100.1
KUE	LANDIS & GYR	MX	C447096	01-24-07	100.0	100.1	100.2
KUE	LANDIS & GYR	MX	C447097	01-25-07	100.0	99.9	100.2
KUE	LANDIS & GYR	MX	C447098	01-25-07	100.0	100.1	100.0
KUE	LANDIS & GYR	MX	C447099	01-25-07	100.1	100.1	100.0
KUE	LANDIS & GYR	MX	C447100	01-25-07	100.1	100.4	100.4
KUE	LANDIS & GYR	MX	C447101	01-25-07	100.0	100.2	100.2
KUE	LANDIS & GYR	MX	C447102	01-25-07	100.1	100.2	100.2
KUE	LANDIS & GYR	MX	C447103	01-25-07	100.0	100.1	100.3
KUE	LANDIS & GYR	MX	C447104	01-25-07	100.0	100.1	99.8
KUE	LANDIS & GYR	MX	C447105	01-25-07	100.1	100.1	100.4
KUE	LANDIS & GYR	MX	C447106	01-25-07	100.1	100.0	100.3
KUE	LANDIS & GYR	MX	C447107	01-25-07	99.9	100.0	99.9
KUE	LANDIS & GYR	MX	C447108	01-25-07	99.9	100.1	100.2
KUE	LANDIS & GYR	MX	C447109	01-25-07	100.0	100.1	100.2
KUE	LANDIS & GYR	MX	C447110	01-24-07	100.1	100.0	100.2
KUE	LANDIS & GYR	MX	C447111	01-25-07	100.1	100.0	100.2

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

CO	MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
KUE	LANDIS & GYR	MX	C4471163	01-24-07	100.1	100.1	100.0
KUE	LANDIS & GYR	MX	C4471164	01-24-07	100.0	100.0	100.1
KUE	LANDIS & GYR	MX	C4471165	01-24-07	100.0	100.0	100.1
KUE	LANDIS & GYR	MX	C4471166	01-25-07	100.0	100.0	99.8
KUE	LANDIS & GYR	MX	C4471167	01-25-07	99.9	99.9	99.8
KUE	LANDIS & GYR	MX	C4471168	01-25-07	100.0	100.0	100.1
KUE	LANDIS & GYR	MX	C4471169	01-25-07	100.0	99.9	100.0
KUE	LANDIS & GYR	MX	C4471170	01-25-07	100.0	99.9	100.0
KUE	LANDIS & GYR	MX	C4471171	01-25-07	100.1	100.2	99.8
KUE	LANDIS & GYR	MX	C4471172	01-24-07	100.1	100.2	100.2
KUE	LANDIS & GYR	MX	C4471173	01-25-07	100.1	100.1	100.0
KUE	LANDIS & GYR	MX	C4471174	01-25-07	100.1	100.2	100.1
KUE	LANDIS & GYR	MX	C4471175	01-24-07	100.1	100.2	100.0
KUE	LANDIS & GYR	MX	C4471176	01-24-07	100.1	100.1	100.0
KUE	LANDIS & GYR	MX	C4471177	01-24-07	100.0	100.0	100.0
KUE	LANDIS & GYR	MX	C4471178	01-25-07	100.1	100.1	100.0
KUE	LANDIS & GYR	MX	C4471179	01-25-07	100.1	100.1	100.0
KUE	LANDIS & GYR	MX	C4471180	01-25-07	100.0	100.4	100.0
KUE	LANDIS & GYR	MX	C4471181	01-25-07	100.0	100.1	100.1
KUE	LANDIS & GYR	MX	C4471182	01-25-07	100.1	99.9	100.0
KUE	LANDIS & GYR	MX	C4471183	01-25-07	100.0	100.0	99.9
KUE	LANDIS & GYR	MX	C4471184	01-23-07	100.1	100.0	100.3
KUE	LANDIS & GYR	MX	C4471185	01-25-07	100.1	100.0	100.1
KUE	LANDIS & GYR	MX	C4471186	01-25-07	100.1	100.1	100.2
KUE	LANDIS & GYR	MX	C4471187	01-25-07	100.1	100.1	100.0
KUE	LANDIS & GYR	MX	C4471188	01-25-07	99.9	99.9	99.9
KUE	LANDIS & GYR	MX	C4471189	01-25-07	100.0	99.9	100.0
KUE	LANDIS & GYR	MX	C4471190	01-25-07	100.0	99.9	100.2
KUE	LANDIS & GYR	MX	C4471191	01-25-07	100.1	100.0	100.2
KUE	LANDIS & GYR	MX	C4471192	01-25-07	100.1	100.1	100.2
KUE	LANDIS & GYR	MX	C4471193	01-25-07	100.1	100.1	100.2
KUE	LANDIS & GYR	MX	C4471194	01-25-07	100.1	100.1	100.3
KUE	LANDIS & GYR	MX	C4471195	01-25-07	100.1	100.2	100.5
KUE	LANDIS & GYR	MX	C4471196	01-25-07	100.0	99.9	100.2
KUE	LANDIS & GYR	MX	C4471197	01-25-07	100.1	100.1	99.9
KUE	LANDIS & GYR	MX	C4471198	01-25-07	100.1	100.1	100.0
KUE	LANDIS & GYR	MX	C4471199	01-24-07	100.1	100.0	99.9
KUE	LANDIS & GYR	MX	C447200	01-24-07	100.0	100.0	100.2
KUE	LANDIS & GYR	MX	C447201	01-24-07	100.1	99.9	100.1
KUE	LANDIS & GYR	MX	C447202	01-24-07	100.1	100.2	100.1
KUE	LANDIS & GYR	MX	C447203	01-25-07	100.1	100.1	100.0
KUE	LANDIS & GYR	MX	C447204	01-24-07	100.0	100.0	100.6
KUE	LANDIS & GYR	MX	C447205	01-25-07	100.0	100.0	100.4
KUE	LANDIS & GYR	MX	C447206	01-25-07	100.1	100.0	100.2
KUE	LANDIS & GYR	MX	C447207	01-25-07	100.0	100.1	99.9
KUE	LANDIS & GYR	MX	C447208	01-24-07	100.1	100.1	100.3
KUE	LANDIS & GYR	MX	C447209	01-25-07	100.1	100.1	100.2
KUE	LANDIS & GYR	MX	C447210	01-25-07	99.9	100.1	99.7
KUE	LANDIS & GYR	MX	C447211	01-25-07	100.0	100.0	100.2
KUE	LANDIS & GYR	MX	C447212	01-25-07	100.0	100.0	100.2
KUE	LANDIS & GYR	MX	C447213	01-25-07	100.1	100.0	100.2

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

CO	MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
KUE	LANDIS & GYR	MX	C447265	01-25-07	100.0	100.0	100.0
KUE	LANDIS & GYR	MX	C447266	01-25-07	100.1	100.0	100.0
KUE	LANDIS & GYR	MX	C447267	01-25-07	100.0	100.0	100.0
KUE	LANDIS & GYR	MX	C447268	01-25-07	100.1	100.1	99.9
KUE	LANDIS & GYR	MX	C447269	01-25-07	99.9	100.0	99.8
KUE	LANDIS & GYR	MX	C447270	01-25-07	100.0	100.0	99.7
KUE	LANDIS & GYR	MX	C447271	01-25-07	100.1	100.1	100.3
KUE	LANDIS & GYR	MX	C447272	01-25-07	100.0	99.9	100.2
KUE	LANDIS & GYR	MX	C447273	01-25-07	100.1	100.1	100.0
KUE	LANDIS & GYR	MX	C447274	01-25-07	100.1	100.2	100.2
KUE	LANDIS & GYR	MX	C447275	01-25-07	100.1	100.1	100.0
KUE	LANDIS & GYR	MX	C447276	01-25-07	100.0	100.1	100.1
KUE	LANDIS & GYR	MX	C447277	01-25-07	100.1	100.0	100.1
KUE	LANDIS & GYR	MX	C447278	01-25-07	100.0	100.0	100.3
KUE	LANDIS & GYR	MX	C447279	01-25-07	100.1	100.0	100.2
KUE	LANDIS & GYR	MX	C447280	01-25-07	100.0	100.0	100.4
KUE	LANDIS & GYR	MX	C447281	01-25-07	100.1	100.1	100.1
KUE	LANDIS & GYR	MX	C447282	01-25-07	100.1	100.1	99.9
KUE	LANDIS & GYR	MX	C447283	01-25-07	100.0	100.1	100.0
KUE	LANDIS & GYR	MX	C447284	01-25-07	100.0	100.0	100.2
KUE	LANDIS & GYR	MX	C447285	01-25-07	100.1	100.0	100.3
KUE	LANDIS & GYR	MX	C447286	01-25-07	100.1	100.1	100.3
KUE	LANDIS & GYR	MX	C447287	01-25-07	100.1	100.1	100.2
KUE	LANDIS & GYR	MX	C447288	01-25-07	100.0	100.1	100.1
KUE	LANDIS & GYR	MX	C447289	01-25-07	100.1	100.1	100.1
KUE	LANDIS & GYR	MX	C447290	01-25-07	100.1	100.1	100.1
KUE	LANDIS & GYR	MX	C447291	01-25-07	100.0	100.1	99.6
KUE	LANDIS & GYR	MX	C447292	01-25-07	100.0	100.0	100.1
KUE	LANDIS & GYR	MX	C447293	01-25-07	100.0	99.9	99.9
KUE	LANDIS & GYR	MX	C447294	01-25-07	100.0	100.1	100.2
KUE	LANDIS & GYR	MX	C447295	01-25-07	100.1	100.1	100.4
KUE	LANDIS & GYR	MX	C447296	01-25-07	99.9	100.0	100.0
KUE	LANDIS & GYR	MX	C447297	01-25-07	100.0	100.0	100.3
KUE	LANDIS & GYR	MX	C447298	01-25-07	100.0	100.0	100.2
KUE	LANDIS & GYR	MX	C447299	01-25-07	100.1	100.1	100.2
KUE	LANDIS & GYR	MX	C447300	01-25-07	100.0	100.0	100.3
KUE	LANDIS & GYR	MX	C447301	01-25-07	100.0	100.1	100.2
KUE	LANDIS & GYR	MX	C447302	01-25-07	100.1	99.9	100.2
KUE	LANDIS & GYR	MX	C447303	01-25-07	100.1	100.0	100.1
KUE	LANDIS & GYR	MX	C447304	01-25-07	100.1	99.9	100.2
KUE	LANDIS & GYR	MX	C447305	01-25-07	100.1	99.9	100.2
KUE	LANDIS & GYR	MX	C447306	01-25-07	100.0	100.1	100.1
KUE	LANDIS & GYR	MX	C447307	01-25-07	100.0	99.9	100.2
KUE	LANDIS & GYR	MX	C447308	01-25-07	100.0	99.9	100.2
KUE	LANDIS & GYR	MX	C447309	01-25-07	100.1	100.0	100.4
KUE	LANDIS & GYR	MX	C447310	01-25-07	100.1	100.0	99.9
KUE	LANDIS & GYR	MX	C447311	01-25-07	100.1	100.2	100.2
KUE	LANDIS & GYR	MX	C447312	01-25-07	100.0	99.9	100.4
KUE	LANDIS & GYR	MX	C447313	01-25-07	100.0	99.9	100.1
KUE	LANDIS & GYR	MX	C447314	01-25-07	100.0	99.9	100.3
KUE	LANDIS & GYR	MX	C447315	01-25-07	100.1	100.0	100.4

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

CO	MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
KUE	& GYR	MX	C447367	01-25-07	100.1	100.0	100.0
KUE	& GYR	MX	C447368	01-25-07	100.0	99.9	99.9
KUE	& GYR	MX	C447369	01-25-07	100.1	100.0	100.5
KUE	& GYR	MX	C447370	01-25-07	100.1	100.1	100.1
KUE	& GYR	MX	C447371	01-25-07	100.1	99.9	99.9
KUE	& GYR	MX	C447372	01-25-07	100.1	99.9	100.1
KUE	& GYR	MX	C447373	01-25-07	100.1	100.0	100.0
KUE	& GYR	MX	C447374	01-25-07	100.0	99.9	99.9
KUE	& GYR	MX	C447375	01-22-07	100.0	99.9	100.2
KUE	& GYR	MX	C447376	01-25-07	100.1	100.0	100.1
KUE	& GYR	MX	C447377	01-25-07	100.1	100.1	100.2
KUE	& GYR	MX	C447378	01-25-07	100.0	100.1	100.1
KUE	& GYR	MX	C447379	01-25-07	100.1	100.0	100.2
KUE	& GYR	MX	C447380	01-25-07	100.0	100.1	100.3
KUE	& GYR	MX	C447381	01-25-07	100.0	100.1	100.0
KUE	& GYR	MX	C447382	01-25-07	100.0	100.0	100.1
KUE	& GYR	MX	C447383	01-25-07	100.0	100.2	100.5
KUE	& GYR	MX	C447384	01-25-07	100.0	100.1	99.9
KUE	& GYR	MX	C447385	01-25-07	100.1	100.2	100.5
KUE	& GYR	MX	C447386	01-25-07	100.1	100.0	100.5
KUE	& GYR	MX	C447387	01-25-07	100.1	100.1	100.2
KUE	& GYR	MX	C447388	01-25-07	100.1	100.2	100.4
KUE	& GYR	MX	C447389	01-25-07	100.0	100.0	100.4
KUE	& GYR	MX	C447390	01-25-07	100.1	100.1	100.2
KUE	& GYR	MX	C447391	01-25-07	100.0	100.0	99.6
KUE	& GYR	MX	C447392	01-22-07	100.0	100.0	99.8
KUE	& GYR	MX	C447393	01-23-07	100.1	100.2	100.2
KUE	& GYR	MX	C447394	01-23-07	100.0	99.9	99.9
KUE	& GYR	MX	C447395	01-23-07	100.1	100.0	100.2
KUE	& GYR	MX	C447396	01-23-07	100.1	100.0	100.2
KUE	& GYR	MX	C447397	01-25-07	100.0	100.0	100.3
KUE	& GYR	MX	C447398	01-22-07	100.1	100.0	99.8
KUE	& GYR	MX	C447399	01-25-07	100.1	100.2	100.4
KUE	& GYR	MX	C447400	01-25-07	100.1	100.1	100.1
KUE	& GYR	MX	C447401	01-25-07	100.1	100.1	100.0
KUE	& GYR	MX	C447402	01-25-07	100.1	100.1	100.5
KUE	& GYR	MX	C447403	01-22-07	100.0	99.9	100.2
KUE	& GYR	MX	C447404	01-22-07	100.1	100.1	100.2
KUE	& GYR	MX	C447405	01-23-07	100.1	100.1	100.1
KUE	& GYR	MX	C447406	01-22-07	100.0	100.0	100.0
KUE	& GYR	MX	C447407	01-25-07	100.0	99.9	99.8
KUE	& GYR	MX	C447408	01-25-07	100.1	100.1	100.2
KUE	& GYR	MX	C447409	01-25-07	100.1	100.1	100.6
KUE	& GYR	MX	C447410	01-25-07	100.1	100.2	100.4
KUE	& GYR	MX	C447411	01-22-07	100.0	100.0	100.2
KUE	& GYR	MX	C447412	01-22-07	100.1	100.1	99.9
KUE	& GYR	MX	C447413	01-22-07	100.1	100.2	99.8
KUE	& GYR	MX	C447414	01-22-07	100.0	99.9	99.9
KUE	& GYR	MX	C447415	01-25-07	100.0	99.9	100.4
KUE	& GYR	MX	C447416	01-25-07	100.1	100.0	99.9
KUE	& GYR	MX	C447417	01-25-07	99.9	99.9	99.5

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

CO	MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PF FACTOR
KUE	LANDIS & GYR	MX	C447469	01-25-07	100.0	100.0	100.2
KUE	LANDIS & GYR	MX	C447470	01-25-07	100.1	100.0	100.3
KUE	LANDIS & GYR	MX	C447471	01-25-07	100.0	100.0	100.2
KUE	LANDIS & GYR	MX	C447472	01-25-07	100.0	99.9	99.8
KUE	LANDIS & GYR	MX	C447473	01-25-07	100.1	100.1	100.1
KUE	LANDIS & GYR	MX	C447474	01-25-07	100.0	100.1	100.0
KUE	LANDIS & GYR	MX	C447475	01-25-07	100.0	100.1	100.1
KUE	LANDIS & GYR	MX	C447476	01-25-07	100.1	100.1	99.8
KUE	LANDIS & GYR	MX	C447477	01-25-07	100.1	100.1	100.3
KUE	LANDIS & GYR	MX	C447478	01-25-07	100.0	99.9	100.0
KUE	LANDIS & GYR	MX	C447479	01-25-07	100.1	100.0	100.1
KUE	LANDIS & GYR	MX	C447480	01-25-07	100.1	100.0	100.4
KUE	LANDIS & GYR	MX	C447481	01-25-07	99.9	100.0	100.0
KUE	LANDIS & GYR	MX	C447482	01-25-07	100.0	100.1	100.0
KUE	LANDIS & GYR	MX	C447483	01-25-07	100.1	100.1	100.1
KUE	LANDIS & GYR	MX	C447484	01-25-07	100.1	99.9	100.3
KUE	LANDIS & GYR	MX	C447485	01-25-07	100.0	100.1	100.0
KUE	LANDIS & GYR	MX	C447486	01-25-07	100.1	100.1	100.0
KUE	LANDIS & GYR	MX	C447487	01-25-07	100.1	100.1	100.2
KUE	LANDIS & GYR	MX	C447488	01-25-07	100.0	100.1	100.0
KUE	LANDIS & GYR	MX	C447489	01-25-07	100.0	100.1	100.0
KUE	LANDIS & GYR	MX	C447490	01-25-07	100.1	100.0	100.4
KUE	LANDIS & GYR	MX	C447491	01-25-07	100.0	100.1	100.1
KUE	LANDIS & GYR	MX	C447492	01-25-07	100.0	99.9	100.2
KUE	LANDIS & GYR	MX	C447493	01-25-07	100.0	100.0	99.9
KUE	LANDIS & GYR	MX	C447494	01-25-07	100.1	100.1	100.1
KUE	LANDIS & GYR	MX	C447495	01-25-07	100.0	100.0	100.0
KUE	LANDIS & GYR	MX	C447496	01-25-07	100.0	100.0	99.9
KUE	LANDIS & GYR	MX	C447497	01-25-07	100.0	100.0	100.0
KUE	LANDIS & GYR	MX	C447498	01-25-07	100.0	100.0	100.0
KUE	LANDIS & GYR	MX	C447499	01-25-07	100.1	100.1	100.3
KUE	LANDIS & GYR	MX	C447500	01-25-07	100.0	100.0	99.9
KUE	LANDIS & GYR	MX	C447501	01-25-07	100.1	100.0	100.2
KUE	LANDIS & GYR	MX	C447502	01-25-07	100.1	100.1	100.2
KUE	LANDIS & GYR	MX	C447503	01-25-07	100.1	99.9	100.1
KUE	LANDIS & GYR	MX	C447504	01-25-07	100.1	100.0	100.1
KUE	LANDIS & GYR	MX	C447505	01-25-07	100.0	100.0	100.1
KUE	LANDIS & GYR	MX	C447506	01-25-07	100.0	100.2	100.1
KUE	LANDIS & GYR	MX	C447507	01-25-07	100.1	100.0	100.0
KUE	LANDIS & GYR	MX	C447508	01-25-07	100.0	100.0	100.3
KUE	LANDIS & GYR	MX	C447509	01-25-07	100.0	100.0	100.0
KUE	LANDIS & GYR	MX	C447510	01-25-07	100.1	100.0	100.4
KUE	LANDIS & GYR	MX	C447511	01-25-07	100.0	99.9	100.0
KUE	LANDIS & GYR	MX	C447512	01-25-07	100.1	99.9	100.2
KUE	LANDIS & GYR	MX	C447513	01-25-07	100.1	99.9	100.3
KUE	LANDIS & GYR	MX	C447514	01-25-07	100.0	99.9	99.9
KUE	LANDIS & GYR	MX	C447515	01-25-07	100.1	100.1	100.2
KUE	LANDIS & GYR	MX	C447516	01-25-07	100.1	100.1	100.3
KUE	LANDIS & GYR	MX	C447517	01-25-07	100.1	100.1	99.8
KUE	LANDIS & GYR	MX	C447518	01-25-07	100.1	100.1	100.2
KUE	LANDIS & GYR	MX	C447519	01-25-07	100.1	100.2	100.4

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

PAGE 53
 RUN DATE: 1/15/08
 RUN TIME: 22.00.58

CO	MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
KUE	LANDIS & GYR	MX	C447571	01-25-07	100.0	100.1	100.2
KUE	LANDIS & GYR	MX	C447572	01-25-07	100.1	100.1	100.0
KUE	LANDIS & GYR	MX	C447573	01-25-07	100.0	100.0	99.8
KUE	LANDIS & GYR	MX	C447574	01-25-07	100.0	100.1	99.8
KUE	LANDIS & GYR	MX	C447575	01-25-07	100.1	100.2	100.2
KUE	LANDIS & GYR	MX	C447576	01-25-07	100.0	100.0	100.2
KUE	LANDIS & GYR	MX	C447577	01-25-07	100.1	100.1	100.1
KUE	LANDIS & GYR	MX	C447578	01-25-07	99.9	99.9	99.7
KUE	LANDIS & GYR	MX	C447579	01-25-07	100.1	100.1	100.1
KUE	LANDIS & GYR	MX	C447580	01-25-07	100.0	100.1	99.7
KUE	LANDIS & GYR	MX	C447581	01-25-07	100.0	100.1	100.2
KUE	LANDIS & GYR	MX	C447582	01-25-07	100.1	100.0	100.0
KUE	LANDIS & GYR	MX	C447583	01-25-07	100.1	100.0	100.1
KUE	LANDIS & GYR	MX	C447584	01-25-07	100.0	100.2	100.1
KUE	LANDIS & GYR	MX	C447585	01-25-07	100.0	100.1	99.9
KUE	LANDIS & GYR	MX	C447586	01-25-07	100.1	100.1	100.4
KUE	LANDIS & GYR	MX	C447587	01-25-07	100.1	100.1	100.4
KUE	LANDIS & GYR	MX	C447588	01-25-07	100.1	99.9	100.2
KUE	LANDIS & GYR	MX	C447589	01-25-07	100.0	100.1	99.6
KUE	LANDIS & GYR	MX	C447590	01-25-07	100.1	100.1	100.1
KUE	LANDIS & GYR	MX	C447591	01-25-07	100.1	100.1	100.2
KUE	LANDIS & GYR	MX	C447592	01-25-07	100.1	100.2	100.1
KUE	LANDIS & GYR	MX	C447593	01-25-07	100.1	100.1	100.4
KUE	LANDIS & GYR	MX	C447594	01-25-07	100.0	99.9	100.2
KUE	LANDIS & GYR	MX	C447595	01-25-07	100.1	100.1	100.2
KUE	LANDIS & GYR	MX	C447596	01-25-07	100.1	100.1	99.9
KUE	LANDIS & GYR	MX	C447597	01-25-07	100.0	100.0	100.1
KUE	LANDIS & GYR	MX	C447598	01-25-07	100.1	100.0	100.0
KUE	LANDIS & GYR	MX	C447599	01-25-07	100.0	99.9	99.8
KUE	LANDIS & GYR	MX	C447600	01-25-07	100.0	99.9	99.8
KUE	LANDIS & GYR	MX	C447601	01-25-07	100.1	100.1	100.0
KUE	LANDIS & GYR	MX	C447602	01-25-07	100.1	100.1	99.9
KUE	LANDIS & GYR	MX	C447603	01-25-07	100.0	100.0	100.0
KUE	LANDIS & GYR	MX	C447604	01-25-07	100.1	100.0	100.1
KUE	LANDIS & GYR	MX	C447605	01-25-07	100.0	100.0	99.5
KUE	LANDIS & GYR	MX	C447606	01-25-07	100.1	100.0	100.0
KUE	LANDIS & GYR	MX	C447607	01-25-07	100.1	100.0	100.0
KUE	LANDIS & GYR	MX	C447608	01-25-07	99.9	100.1	99.9
KUE	LANDIS & GYR	MX	C447609	01-25-07	100.1	100.1	100.2
KUE	LANDIS & GYR	MX	C447610	01-25-07	100.1	100.0	99.9
KUE	LANDIS & GYR	MX	C447611	01-25-07	100.0	100.0	100.0
KUE	LANDIS & GYR	MX	C447612	01-25-07	100.0	100.1	100.2
KUE	LANDIS & GYR	MX	C447613	01-25-07	100.1	100.0	100.0
KUE	LANDIS & GYR	MX	C447614	01-25-07	100.0	100.1	99.7
KUE	LANDIS & GYR	MX	C447615	01-25-07	100.0	100.1	100.0
KUE	LANDIS & GYR	MX	C447616	01-25-07	100.0	100.0	100.2
KUE	LANDIS & GYR	MX	C447617	01-25-07	100.1	100.1	100.0
KUE	LANDIS & GYR	MX	C447618	01-25-07	100.0	100.0	99.9
KUE	LANDIS & GYR	MX	C447619	01-25-07	100.1	100.0	100.3
KUE	LANDIS & GYR	MX	C447620	01-25-07	100.0	100.1	100.5
KUE	LANDIS & GYR	MX	C447621	01-25-07	100.0	100.0	99.9

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY

MANUFACTURER TESTS ADDED LAST YEAR

REPORT NO. MD8880

CO	MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACOR
KUE	LANDIS & GYR	MX	C447673	01-25-07	100.1	100.0	100.0
KUE	LANDIS & GYR	MX	C447674	01-25-07	100.0	99.9	100.0
KUE	LANDIS & GYR	MX	C447675	01-25-07	100.1	99.9	100.0
KUE	LANDIS & GYR	MX	C447676	01-25-07	100.0	100.1	100.0
KUE	LANDIS & GYR	MX	C447677	01-25-07	100.1	100.2	100.0
KUE	LANDIS & GYR	MX	C447678	01-25-07	100.1	100.2	100.0
KUE	LANDIS & GYR	MX	C447679	01-25-07	100.1	100.1	100.0
KUE	LANDIS & GYR	MX	C447680	01-25-07	100.0	100.0	100.0
KUE	LANDIS & GYR	MX	C447681	01-25-07	100.1	100.1	100.0
KUE	LANDIS & GYR	MX	C447682	01-25-07	100.1	100.0	100.0
KUE	LANDIS & GYR	MX	C447683	01-25-07	100.0	100.1	100.0
KUE	LANDIS & GYR	MX	C447684	01-25-07	100.0	99.9	100.0
KUE	LANDIS & GYR	MX	C447685	01-25-07	99.9	100.1	100.0
KUE	LANDIS & GYR	MX	C447686	01-25-07	100.0	100.0	100.0
KUE	LANDIS & GYR	MX	C447687	01-25-07	100.1	100.1	100.0
KUE	LANDIS & GYR	MX	C447688	01-25-07	100.1	100.1	100.0
KUE	LANDIS & GYR	MX	C447689	01-25-07	100.1	100.1	100.0
KUE	LANDIS & GYR	MX	C447690	01-25-07	100.1	100.1	100.0
KUE	LANDIS & GYR	MX	C447691	01-25-07	100.0	100.0	100.0
KUE	LANDIS & GYR	MX	C447692	01-25-07	100.0	100.0	100.0
KUE	LANDIS & GYR	MX	C447693	01-25-07	100.1	100.1	100.0
KUE	LANDIS & GYR	MX	C447694	01-25-07	100.1	100.2	100.0
KUE	LANDIS & GYR	MX	C447695	01-25-07	100.1	100.2	100.0
KUE	LANDIS & GYR	MX	C447696	01-25-07	100.1	100.1	100.0
KUE	LANDIS & GYR	MX	C447697	01-25-07	100.0	100.0	100.0
KUE	LANDIS & GYR	MX	C447698	01-25-07	100.1	100.1	100.0
KUE	LANDIS & GYR	MX	C447699	01-25-07	100.0	100.0	100.0
KUE	LANDIS & GYR	MX	C447700	01-25-07	100.1	100.1	100.0
KUE	LANDIS & GYR	MX	C447701	01-25-07	100.1	99.9	100.0
KUE	LANDIS & GYR	MX	C447702	01-25-07	100.1	99.9	100.0
KUE	LANDIS & GYR	MX	C447703	01-25-07	100.0	100.0	100.0
KUE	LANDIS & GYR	MX	C447704	01-25-07	100.0	100.0	100.0
KUE	LANDIS & GYR	MX	C447705	01-25-07	100.1	99.9	100.0
KUE	LANDIS & GYR	MX	C447706	01-25-07	100.1	100.0	100.0
KUE	LANDIS & GYR	MX	C447707	01-25-07	100.1	100.0	100.0
KUE	LANDIS & GYR	MX	C447708	01-25-07	100.1	100.1	100.0
KUE	LANDIS & GYR	MX	C447709	01-25-07	100.0	100.0	100.0
KUE	LANDIS & GYR	MX	C447710	01-25-07	100.0	100.0	100.0
KUE	LANDIS & GYR	MX	C447711	01-25-07	100.1	100.2	100.0
KUE	LANDIS & GYR	MX	C447712	01-25-07	100.0	99.9	100.0
KUE	LANDIS & GYR	MX	C447713	01-25-07	100.0	99.9	100.0
KUE	LANDIS & GYR	MX	C447714	01-25-07	100.0	100.0	100.0
KUE	LANDIS & GYR	MX	C447715	01-25-07	100.0	100.1	100.0
KUE	LANDIS & GYR	MX	C447716	01-25-07	100.0	100.1	100.0
KUE	LANDIS & GYR	MX	C447717	01-25-07	100.0	100.1	100.0
KUE	LANDIS & GYR	MX	C447718	01-25-07	100.0	100.0	100.0
KUE	LANDIS & GYR	MX	C447719	01-25-07	100.0	100.0	100.0
KUE	LANDIS & GYR	MX	C447720	01-25-07	100.0	100.0	100.0
KUE	LANDIS & GYR	MX	C447721	01-25-07	100.0	100.0	100.0
KUE	LANDIS & GYR	MX	C447722	01-25-07	100.1	100.1	100.0
KUE	LANDIS & GYR	MX	C447723	01-25-07	100.1	100.1	100.0

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

CO	MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
KUE	LANDIS & GYR	MX	C447775	01-26-07	100.0	100.0	100.1
KUE	LANDIS & GYR	MX	C447776	01-26-07	100.1	100.2	100.1
KUE	LANDIS & GYR	MX	C447777	01-26-07	100.1	100.0	100.2
KUE	LANDIS & GYR	MX	C447778	01-26-07	100.1	100.1	100.1
KUE	LANDIS & GYR	MX	C447779	01-26-07	100.0	100.2	100.2
KUE	LANDIS & GYR	MX	C447780	01-26-07	100.1	100.0	100.2
KUE	LANDIS & GYR	MX	C447781	01-26-07	100.1	100.2	100.1
KUE	LANDIS & GYR	MX	C447782	01-26-07	100.1	100.1	100.3
KUE	LANDIS & GYR	MX	C447783	01-26-07	100.1	100.1	100.1
KUE	LANDIS & GYR	MX	C447784	01-26-07	100.0	100.2	100.1
KUE	LANDIS & GYR	MX	C447785	01-26-07	100.0	100.1	100.1
KUE	LANDIS & GYR	MX	C447786	01-26-07	100.0	100.0	100.0
KUE	LANDIS & GYR	MX	C447787	01-26-07	100.1	99.9	100.0
KUE	LANDIS & GYR	MX	C447788	01-26-07	100.0	100.1	100.3
KUE	LANDIS & GYR	MX	C447789	01-26-07	100.1	100.0	100.1
KUE	LANDIS & GYR	MX	C447790	01-26-07	100.0	100.1	100.0
KUE	LANDIS & GYR	MX	C447791	01-26-07	100.1	100.0	100.1
KUE	LANDIS & GYR	MX	C447792	01-26-07	100.1	100.0	100.1
KUE	LANDIS & GYR	MX	C447793	01-26-07	100.0	100.2	100.3
KUE	LANDIS & GYR	MX	C447794	01-26-07	100.0	100.0	100.3
KUE	LANDIS & GYR	MX	C447795	01-26-07	100.1	100.0	100.1
KUE	LANDIS & GYR	MX	C447796	01-26-07	100.1	100.1	100.4
KUE	LANDIS & GYR	MX	C447797	01-26-07	100.1	100.1	100.4
KUE	LANDIS & GYR	MX	C447798	01-26-07	100.1	100.1	99.9
KUE	LANDIS & GYR	MX	C447799	01-26-07	100.1	100.1	99.9
KUE	LANDIS & GYR	MX	C447800	01-26-07	100.0	100.0	99.9
KUE	LANDIS & GYR	MX	C447801	01-26-07	100.1	100.0	100.1
KUE	LANDIS & GYR	MX	C447802	01-26-07	100.1	100.0	100.1
KUE	LANDIS & GYR	MX	C447803	01-26-07	100.1	100.2	100.2
KUE	LANDIS & GYR	MX	C447804	01-26-07	100.1	100.0	100.3
KUE	LANDIS & GYR	MX	C447805	01-26-07	100.1	99.9	100.0
KUE	LANDIS & GYR	MX	C447806	01-26-07	100.1	100.2	100.4
KUE	LANDIS & GYR	MX	C447807	01-26-07	100.0	100.0	100.0
KUE	LANDIS & GYR	MX	C447808	01-26-07	100.1	100.1	100.3
KUE	LANDIS & GYR	MX	C447809	01-26-07	100.0	100.0	100.2
KUE	LANDIS & GYR	MX	C447810	01-26-07	100.0	99.9	100.1
KUE	LANDIS & GYR	MX	C447811	01-26-07	100.0	100.0	100.0
KUE	LANDIS & GYR	MX	C447812	01-26-07	100.1	100.0	100.1
KUE	LANDIS & GYR	MX	C447813	01-26-07	100.1	100.1	100.0
KUE	LANDIS & GYR	MX	C447814	01-26-07	100.0	100.1	100.0
KUE	LANDIS & GYR	MX	C447815	01-26-07	100.1	100.0	100.15
KUE	LANDIS & GYR	MX	C447816	01-26-07	100.1	100.1	100.2
KUE	LANDIS & GYR	MX	C447817	01-26-07	100.0	100.2	100.2
KUE	LANDIS & GYR	MX	C447818	01-26-07	100.0	100.0	100.2
KUE	LANDIS & GYR	MX	C447819	01-26-07	100.1	100.0	100.15
KUE	LANDIS & GYR	MX	C447820	01-26-07	100.0	100.2	100.4
KUE	LANDIS & GYR	MX	C447821	01-26-07	100.1	100.2	100.4
KUE	LANDIS & GYR	MX	C447822	01-26-07	100.0	99.9	100.0
KUE	LANDIS & GYR	MX	C447823	01-26-07	100.0	99.9	100.1
KUE	LANDIS & GYR	MX	C447824	01-26-07	100.0	100.0	100.1
KUE	LANDIS & GYR	MX	C447825	01-26-07	100.0	100.0	99.8

CO	MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
KUE	LANDIS & GYR	MX	C447877	01-26-07	100.1	99.9	99.7
KUE	LANDIS & GYR	MX	C447878	01-26-07	100.0	100.0	100.4
KUE	LANDIS & GYR	MX	C447879	01-26-07	100.1	100.2	100.4
KUE	LANDIS & GYR	MX	C447880	01-26-07	100.1	100.1	99.9
KUE	LANDIS & GYR	MX	C447881	01-26-07	100.1	100.1	100.2
KUE	LANDIS & GYR	MX	C447882	01-26-07	100.1	100.2	99.9
KUE	LANDIS & GYR	MX	C447883	01-26-07	100.0	100.0	100.4
KUE	LANDIS & GYR	MX	C447884	01-26-07	100.0	99.9	100.2
KUE	LANDIS & GYR	MX	C447885	01-26-07	100.0	100.0	100.1
KUE	LANDIS & GYR	MX	C447886	01-26-07	100.0	100.0	100.1
KUE	LANDIS & GYR	MX	C447887	01-26-07	100.0	100.0	99.9
KUE	LANDIS & GYR	MX	C447888	01-26-07	100.1	100.0	100.2
KUE	LANDIS & GYR	MX	C447889	01-26-07	100.0	100.1	99.9
KUE	LANDIS & GYR	MX	C447890	01-26-07	100.0	100.1	100.2
KUE	LANDIS & GYR	MX	C447891	01-26-07	100.0	100.1	100.2
KUE	LANDIS & GYR	MX	C447892	01-26-07	100.0	100.1	100.0
KUE	LANDIS & GYR	MX	C447893	01-26-07	100.1	100.2	99.9
KUE	LANDIS & GYR	MX	C447894	01-26-07	100.1	100.0	100.2
KUE	LANDIS & GYR	MX	C447895	01-26-07	100.1	100.2	100.2
KUE	LANDIS & GYR	MX	C447896	01-26-07	100.1	100.2	100.2
KUE	LANDIS & GYR	MX	C447897	01-26-07	100.0	100.0	100.2
KUE	LANDIS & GYR	MX	C447898	01-26-07	100.1	100.1	100.1
KUE	LANDIS & GYR	MX	C447899	01-26-07	100.0	100.0	99.9
KUE	LANDIS & GYR	MX	C447900	01-26-07	100.0	100.0	100.2
KUE	LANDIS & GYR	MX	C447901	01-26-07	100.1	100.1	100.0
KUE	LANDIS & GYR	MX	C447902	01-26-07	100.1	100.1	100.2
KUE	LANDIS & GYR	MX	C447903	01-26-07	100.1	100.1	100.2
KUE	LANDIS & GYR	MX	C447904	01-26-07	100.1	100.1	99.8
KUE	LANDIS & GYR	MX	C447905	01-26-07	100.0	100.2	100.2
KUE	LANDIS & GYR	MX	C447906	01-26-07	100.0	99.9	100.1
KUE	LANDIS & GYR	MX	C447907	01-26-07	100.1	100.0	99.7
KUE	LANDIS & GYR	MX	C447908	01-26-07	100.1	100.0	100.0
KUE	LANDIS & GYR	MX	C447909	01-26-07	100.1	100.0	100.1
KUE	LANDIS & GYR	MX	C447910	01-26-07	100.1	100.0	100.2
KUE	LANDIS & GYR	MX	C447911	01-26-07	100.0	100.0	100.1
KUE	LANDIS & GYR	MX	C447912	01-26-07	100.1	100.1	100.3
KUE	LANDIS & GYR	MX	C447913	01-26-07	100.1	99.9	100.2
KUE	LANDIS & GYR	MX	C447914	01-26-07	100.1	99.9	100.3
KUE	LANDIS & GYR	MX	C447915	01-26-07	100.1	100.1	100.0
KUE	LANDIS & GYR	MX	C447916	01-26-07	100.1	100.1	100.3
KUE	LANDIS & GYR	MX	C447917	01-25-07	100.0	100.0	100.0
KUE	LANDIS & GYR	MX	C447918	01-26-07	100.1	100.1	100.4
KUE	LANDIS & GYR	MX	C447919	01-25-07	100.1	100.2	99.5
KUE	LANDIS & GYR	MX	C447920	01-25-07	100.1	100.0	100.5
KUE	LANDIS & GYR	MX	C447921	01-25-07	100.0	100.1	99.9
KUE	LANDIS & GYR	MX	C447922	01-25-07	100.1	100.1	100.2
KUE	LANDIS & GYR	MX	C447923	01-25-07	100.1	100.0	100.0
KUE	LANDIS & GYR	MX	C447924	01-25-07	100.1	100.1	100.1
KUE	LANDIS & GYR	MX	C447925	01-25-07	100.0	100.0	100.1
KUE	LANDIS & GYR	MX	C447926	01-25-07	100.0	100.0	100.2
KUE	LANDIS & GYR	MX	C447927	01-25-07	100.1	100.0	100.4

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

CO	MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
KUE	LANDIS & GYR	MX	C447979	01-25-07	100.0	100.1	100.0
KUE	LANDIS & GYR	MX	C447980	01-25-07	100.0	100.1	100.3
KUE	LANDIS & GYR	MX	C447981	01-25-07	100.1	100.1	100.1
KUE	LANDIS & GYR	MX	C447982	01-25-07	100.1	100.0	100.1
KUE	LANDIS & GYR	MX	C447983	01-25-07	100.1	100.1	99.9
KUE	LANDIS & GYR	MX	C447984	01-25-07	100.0	100.0	100.3
KUE	LANDIS & GYR	MX	C447985	01-25-07	100.0	100.0	100.0
KUE	LANDIS & GYR	MX	C447986	01-25-07	100.1	100.1	100.3
KUE	LANDIS & GYR	MX	C447987	01-25-07	100.1	100.1	100.3
KUE	LANDIS & GYR	MX	C447988	01-25-07	100.0	100.1	100.1
KUE	LANDIS & GYR	MX	C447989	01-25-07	100.0	100.0	100.1
KUE	LANDIS & GYR	MX	C447990	01-25-07	100.1	100.2	100.3
KUE	LANDIS & GYR	MX	C447991	01-26-07	100.1	100.0	100.1
KUE	LANDIS & GYR	MX	C447992	01-25-07	100.1	100.1	100.0
KUE	LANDIS & GYR	MX	C447993	01-25-07	100.0	100.1	100.3
KUE	LANDIS & GYR	MX	C447994	01-25-07	100.0	99.9	100.3
KUE	LANDIS & GYR	MX	C447995	01-25-07	100.1	99.9	100.3
KUE	LANDIS & GYR	MX	C447996	01-25-07	100.1	100.1	100.1
KUE	LANDIS & GYR	MX	C447997	01-25-07	100.1	100.1	100.4
KUE	LANDIS & GYR	MX	C447998	01-25-07	100.1	100.0	100.3
KUE	LANDIS & GYR	MX	C447999	01-25-07	100.0	99.9	99.9
KUE	LANDIS & GYR	MX	C448000	01-25-07	100.0	99.9	99.9
KUE	LANDIS & GYR	MX	C448001	01-25-07	100.1	100.1	100.1
KUE	LANDIS & GYR	MX	C448002	01-25-07	100.1	100.1	100.4
KUE	LANDIS & GYR	MX	C448003	01-25-07	100.1	100.1	100.5
KUE	LANDIS & GYR	MX	C448004	01-25-07	100.1	100.1	100.4
KUE	LANDIS & GYR	MX	C448005	01-25-07	100.0	99.9	100.3
KUE	LANDIS & GYR	MX	C448006	01-25-07	100.0	100.0	99.6
KUE	LANDIS & GYR	MX	C448007	01-26-07	100.0	99.9	100.10
KUE	LANDIS & GYR	MX	C448008	01-25-07	100.1	100.1	100.2
KUE	LANDIS & GYR	MX	C448009	01-26-07	100.1	100.1	100.2
KUE	LANDIS & GYR	MX	C448010	01-26-07	100.1	100.2	100.2
KUE	LANDIS & GYR	MX	C448011	01-26-07	100.1	99.9	100.7
KUE	LANDIS & GYR	MX	C448012	01-26-07	100.0	100.0	100.0
KUE	LANDIS & GYR	MX	C448013	01-26-07	99.9	100.0	100.4
KUE	LANDIS & GYR	MX	C448014	01-26-07	100.1	100.1	99.9
KUE	LANDIS & GYR	MX	C448015	01-26-07	100.1	100.0	99.9
KUE	LANDIS & GYR	MX	C448016	01-26-07	100.0	100.0	99.9
KUE	LANDIS & GYR	MX	C448017	01-26-07	100.0	100.0	100.3
KUE	LANDIS & GYR	MX	C448018	01-26-07	100.0	100.0	100.18
KUE	LANDIS & GYR	MX	C448019	01-26-07	100.0	100.0	99.1
KUE	LANDIS & GYR	MX	C448020	01-26-07	100.1	100.0	100.1
KUE	LANDIS & GYR	MX	C448021	01-26-07	100.0	100.0	100.3
KUE	LANDIS & GYR	MX	C448022	01-26-07	100.0	100.2	100.1
KUE	LANDIS & GYR	MX	C448023	01-26-07	100.1	100.0	100.0
KUE	LANDIS & GYR	MX	C448024	01-26-07	100.1	99.19	100.48
KUE	LANDIS & GYR	MX	C448025	01-26-07	100.1	100.1	100.4
KUE	LANDIS & GYR	MX	C448026	01-26-07	100.0	100.0	99.9
KUE	LANDIS & GYR	MX	C448027	01-26-07	100.0	100.0	100.2
KUE	LANDIS & GYR	MX	C448028	01-26-07	100.0	99.9	100.3
KUE	LANDIS & GYR	MX	C448029	01-26-07	100.0	100.1	100.2

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

CO	MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
KUE	LANDIS & GYR	MX	C448081	01-26-07	100.0	99.9	100.2
KUE	LANDIS & GYR	MX	C448082	01-25-07	100.0	100.0	99.5
KUE	LANDIS & GYR	MX	C448083	01-26-07	100.0	100.1	100.0
KUE	LANDIS & GYR	MX	C448084	01-26-07	100.1	100.0	100.3
KUE	LANDIS & GYR	MX	C448085	01-26-07	100.0	100.0	100.1
KUE	LANDIS & GYR	MX	C448086	01-26-07	100.0	99.9	100.1
KUE	LANDIS & GYR	MX	C448087	01-26-07	100.1	100.2	100.5
KUE	LANDIS & GYR	MX	C448088	01-26-07	100.0	100.2	100.0
KUE	LANDIS & GYR	MX	C448089	01-26-07	100.1	100.1	100.3
KUE	LANDIS & GYR	MX	C448090	01-26-07	100.1	100.1	100.0
KUE	LANDIS & GYR	MX	C448091	01-26-07	100.0	99.9	100.1
KUE	LANDIS & GYR	MX	C448092	01-26-07	100.1	100.0	100.2
KUE	LANDIS & GYR	MX	C448093	01-26-07	100.1	99.9	100.1
KUE	LANDIS & GYR	MX	C448094	01-26-07	100.0	100.0	100.1
KUE	LANDIS & GYR	MX	C448095	01-26-07	100.1	100.1	100.1
KUE	LANDIS & GYR	MX	C448096	01-26-07	100.0	100.1	100.3
KUE	LANDIS & GYR	MX	C448097	01-26-07	100.1	99.9	100.2
KUE	LANDIS & GYR	MX	C448098	01-26-07	100.0	100.0	99.9
KUE	LANDIS & GYR	MX	C448099	01-26-07	100.1	100.0	100.2
KUE	LANDIS & GYR	MX	C448100	01-26-07	100.1	100.2	100.6
KUE	LANDIS & GYR	MX	C448101	01-26-07	100.0	100.1	100.3
KUE	LANDIS & GYR	MX	C448102	01-26-07	100.1	100.0	99.6
KUE	LANDIS & GYR	MX	C448103	01-26-07	100.1	100.1	100.2
KUE	LANDIS & GYR	MX	C448104	01-26-07	100.1	100.0	100.4
KUE	LANDIS & GYR	MX	C448105	01-26-07	100.1	100.1	100.1
KUE	LANDIS & GYR	MX	C448106	01-26-07	100.0	100.1	100.4
KUE	LANDIS & GYR	MX	C448107	01-26-07	100.0	99.9	100.2
KUE	LANDIS & GYR	MX	C448108	01-26-07	100.0	100.0	99.8
KUE	LANDIS & GYR	MX	C448109	01-26-07	100.0	100.1	100.3
KUE	LANDIS & GYR	MX	C448110	01-26-07	100.0	100.1	100.0
KUE	LANDIS & GYR	MX	C448111	01-26-07	100.0	100.1	99.7
KUE	LANDIS & GYR	MX	C448112	01-26-07	100.0	100.1	100.0
KUE	LANDIS & GYR	MX	C448113	01-26-07	100.1	100.0	99.7
KUE	LANDIS & GYR	MX	C448114	01-26-07	100.0	100.1	99.9
KUE	LANDIS & GYR	MX	C448115	01-26-07	100.1	100.1	99.9
KUE	LANDIS & GYR	MX	C448116	01-26-07	100.0	100.1	100.3
KUE	LANDIS & GYR	MX	C448117	01-26-07	100.0	100.1	99.8
KUE	LANDIS & GYR	MX	C448118	01-26-07	100.1	100.1	100.0
KUE	LANDIS & GYR	MX	C448119	01-26-07	100.1	100.1	100.3
KUE	LANDIS & GYR	MX	C448120	01-26-07	100.0	100.2	100.3
KUE	LANDIS & GYR	MX	C448121	01-26-07	100.1	100.2	100.3
KUE	LANDIS & GYR	MX	C448122	01-26-07	100.1	100.0	100.1
KUE	LANDIS & GYR	MX	C448123	01-26-07	100.1	100.0	100.1
KUE	LANDIS & GYR	MX	C448124	01-26-07	100.1	100.1	100.2
KUE	LANDIS & GYR	MX	C448125	01-26-07	100.1	100.1	99.7
KUE	LANDIS & GYR	MX	C448126	01-26-07	100.1	100.0	100.1
KUE	LANDIS & GYR	MX	C448127	01-26-07	100.1	100.1	100.1
KUE	LANDIS & GYR	MX	C448128	01-26-07	100.1	100.1	100.1
KUE	LANDIS & GYR	MX	C448129	01-26-07	100.0	99.9	100.2
KUE	LANDIS & GYR	MX	C448130	01-26-07	100.1	100.1	100.1
KUE	LANDIS & GYR	MX	C448131	01-26-07	100.1	100.1	100.2

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

CO	MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
KUE	LANDIS & GYR	MX	C448183	01-26-07	100.0	100.0	100.3
KUE	LANDIS & GYR	MX	C448184	01-26-07	100.0	100.0	100.0
KUE	LANDIS & GYR	MX	C448185	01-26-07	100.0	99.9	100.0
KUE	LANDIS & GYR	MX	C448186	01-26-07	100.1	100.0	99.9
KUE	LANDIS & GYR	MX	C448187	01-26-07	100.1	100.0	100.0
KUE	LANDIS & GYR	MX	C448188	01-26-07	100.1	100.2	100.4
KUE	LANDIS & GYR	MX	C448189	01-25-07	100.1	100.0	100.5
KUE	LANDIS & GYR	MX	C448190	01-26-07	100.1	99.9	99.8
KUE	LANDIS & GYR	MX	C448191	01-25-07	100.1	100.1	100.4
KUE	LANDIS & GYR	MX	C448192	01-26-07	100.0	99.9	100.0
KUE	LANDIS & GYR	MX	C448193	01-26-07	100.1	100.1	100.3
KUE	LANDIS & GYR	MX	C448194	01-26-07	99.9	100.1	100.0
KUE	LANDIS & GYR	MX	C448195	01-26-07	100.0	100.1	100.1
KUE	LANDIS & GYR	MX	C448196	01-25-07	100.1	100.2	100.2
KUE	LANDIS & GYR	MX	C448197	01-25-07	100.0	100.0	100.0
KUE	LANDIS & GYR	MX	C448198	01-25-07	100.1	100.0	100.5
KUE	LANDIS & GYR	MX	C448199	01-25-07	100.1	99.9	100.0
KUE	LANDIS & GYR	MX	C448200	01-25-07	100.1	100.2	100.2
KUE	LANDIS & GYR	MX	C448201	01-25-07	100.1	100.2	100.5
KUE	LANDIS & GYR	MX	C448202	01-25-07	100.0	100.0	100.1
KUE	LANDIS & GYR	MX	C448203	01-26-07	100.0	100.0	99.9
KUE	LANDIS & GYR	MX	C448204	01-26-07	100.0	100.1	100.1
KUE	LANDIS & GYR	MX	C448205	01-26-07	100.1	100.0	99.5
KUE	LANDIS & GYR	MX	C448206	01-26-07	100.1	100.0	100.3
KUE	LANDIS & GYR	MX	C448207	01-26-07	100.1	100.0	100.2
KUE	LANDIS & GYR	MX	C448208	01-26-07	100.1	100.2	100.3
KUE	LANDIS & GYR	MX	C448209	01-26-07	100.1	100.2	99.9
KUE	LANDIS & GYR	MX	C448210	01-26-07	100.0	100.1	100.1
KUE	LANDIS & GYR	MX	C448211	01-25-07	100.0	100.1	100.1
KUE	LANDIS & GYR	MX	C448212	01-26-07	100.0	100.2	99.9
KUE	LANDIS & GYR	MX	C448213	01-23-07	100.0	100.2	99.9
KUE	LANDIS & GYR	MX	C448214	01-26-07	100.1	100.1	100.1
KUE	LANDIS & GYR	MX	C448215	01-26-07	100.0	99.9	100.0
KUE	LANDIS & GYR	MX	C448216	01-25-07	100.0	100.0	100.0
KUE	LANDIS & GYR	MX	C448217	01-26-07	100.1	100.0	99.9
KUE	LANDIS & GYR	MX	C448218	01-26-07	100.1	100.1	100.0
KUE	LANDIS & GYR	MX	C448219	01-25-07	100.1	100.1	100.4
KUE	LANDIS & GYR	MX	C448220	01-26-07	100.0	99.9	100.2
KUE	LANDIS & GYR	MX	C448221	01-25-07	100.1	100.0	100.1
KUE	LANDIS & GYR	MX	C448222	01-26-07	99.9	100.2	100.1
KUE	LANDIS & GYR	MX	C448223	01-26-07	100.1	99.9	100.2
KUE	LANDIS & GYR	MX	C448224	01-26-07	100.1	100.2	100.1
KUE	LANDIS & GYR	MX	C448225	01-26-07	100.1	100.2	100.2
KUE	LANDIS & GYR	MX	C448226	01-26-07	100.1	99.9	99.8
KUE	LANDIS & GYR	MX	C448227	01-26-07	100.0	100.0	100.0
KUE	LANDIS & GYR	MX	C448228	01-26-07	100.0	100.0	99.9
KUE	LANDIS & GYR	MX	C448229	01-26-07	100.1	99.9	100.3
KUE	LANDIS & GYR	MX	C448230	01-26-07	100.0	100.2	99.9
KUE	LANDIS & GYR	MX	C448231	01-26-07	100.1	100.0	100.0
KUE	LANDIS & GYR	MX	C448232	01-26-07	100.0	99.9	100.1
KUE	LANDIS & GYR	MX	C448233	01-26-07	100.1	99.9	100.0

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

PAGE 67
 RUN DATE: 1/15/08
 RUN TIME: 22.00.58

CO	MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
KUE	LANDIS & GYR	MX	C448285	03-17-07	100.0	99.9	99.7
KUE	LANDIS & GYR	MX	C448286	03-17-07	100.0	100.0	99.8
KUE	LANDIS & GYR	MX	C448287	03-17-07	100.1	100.1	99.8
KUE	LANDIS & GYR	MX	C448288	03-17-07	100.0	100.1	100.0
KUE	LANDIS & GYR	MX	C448289	03-17-07	100.1	100.0	100.0
KUE	LANDIS & GYR	MX	C448290	03-17-07	100.0	100.0	99.9
KUE	LANDIS & GYR	MX	C448291	03-17-07	100.1	100.1	100.1
KUE	LANDIS & GYR	MX	C448292	03-17-07	100.0	100.0	100.2
KUE	LANDIS & GYR	MX	C448293	03-17-07	100.0	100.0	100.1
KUE	LANDIS & GYR	MX	C448294	03-17-07	100.1	100.0	100.0
KUE	LANDIS & GYR	MX	C448295	03-17-07	100.0	100.0	99.8
KUE	LANDIS & GYR	MX	C448296	03-17-07	100.0	99.9	100.0
KUE	LANDIS & GYR	MX	C448297	03-17-07	100.1	100.0	99.7
KUE	LANDIS & GYR	MX	C448298	03-17-07	100.0	100.0	99.7
KUE	LANDIS & GYR	MX	C448299	03-17-07	100.0	99.9	99.9
KUE	LANDIS & GYR	MX	C448300	03-17-07	100.0	100.2	99.9
KUE	LANDIS & GYR	MX	C448301	03-17-07	100.1	100.2	100.1
KUE	LANDIS & GYR	MX	C448302	03-17-07	100.1	100.2	100.1
KUE	LANDIS & GYR	MX	C448303	03-17-07	100.0	100.0	100.1
KUE	LANDIS & GYR	MX	C448304	03-17-07	100.1	100.1	100.1
KUE	LANDIS & GYR	MX	C448305	03-17-07	100.1	100.1	99.9
KUE	LANDIS & GYR	MX	C448306	03-17-07	100.1	99.9	99.5
KUE	LANDIS & GYR	MX	C448307	03-17-07	100.0	100.1	100.1
KUE	LANDIS & GYR	MX	C448308	03-17-07	100.0	100.1	100.0
KUE	LANDIS & GYR	MX	C448309	03-17-07	100.1	100.1	99.9
KUE	LANDIS & GYR	MX	C448310	03-17-07	100.0	100.1	99.9
KUE	LANDIS & GYR	MX	C448311	03-17-07	100.1	100.1	100.1
KUE	LANDIS & GYR	MX	C448312	03-17-07	100.0	100.0	100.0
KUE	LANDIS & GYR	MX	C448313	03-17-07	100.1	100.1	100.1
KUE	LANDIS & GYR	MX	C448314	03-17-07	100.1	99.9	100.1
KUE	LANDIS & GYR	MX	C448315	03-17-07	100.1	100.1	100.1
KUE	LANDIS & GYR	MX	C448316	03-17-07	100.1	100.2	100.0
KUE	LANDIS & GYR	MX	C448317	03-17-07	100.0	100.1	99.8
KUE	LANDIS & GYR	MX	C448318	03-17-07	100.0	100.1	99.6
KUE	LANDIS & GYR	MX	C448319	03-17-07	100.0	100.2	100.2
KUE	LANDIS & GYR	MX	C448320	03-17-07	100.0	100.0	99.9
KUE	LANDIS & GYR	MX	C448321	03-17-07	100.1	100.2	100.1
KUE	LANDIS & GYR	MX	C448322	03-17-07	100.1	100.1	99.8
KUE	LANDIS & GYR	MX	C448323	03-17-07	100.1	100.3	100.3
KUE	LANDIS & GYR	MX	C448324	03-17-07	100.0	99.9	100.0
KUE	LANDIS & GYR	MX	C448325	03-17-07	100.1	100.0	99.6
KUE	LANDIS & GYR	MX	C448326	03-17-07	100.1	100.1	99.7
KUE	LANDIS & GYR	MX	C448327	03-17-07	100.1	100.0	99.8
KUE	LANDIS & GYR	MX	C448328	03-17-07	100.1	100.2	100.1
KUE	LANDIS & GYR	MX	C448329	03-17-07	100.0	100.0	99.9
KUE	LANDIS & GYR	MX	C448330	03-17-07	100.0	100.0	99.9
KUE	LANDIS & GYR	MX	C448331	03-17-07	100.0	100.0	100.0
KUE	LANDIS & GYR	MX	C448332	03-17-07	100.1	100.1	100.1
KUE	LANDIS & GYR	MX	C448333	03-17-07	100.1	99.9	100.3
KUE	LANDIS & GYR	MX	C448334	03-17-07	100.1	100.0	100.0
KUE	LANDIS & GYR	MX	C448335	03-17-07	100.0	99.9	99.9

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

CO	MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
KUE	LANDIS & GYR	MX	C448387	03-17-07	100.0	100.1	100.0
KUE	LANDIS & GYR	MX	C448388	03-17-07	100.0	100.0	99.8
KUE	LANDIS & GYR	MX	C448389	03-17-07	100.1	100.1	100.0
KUE	LANDIS & GYR	MX	C448390	03-17-07	100.0	100.0	99.8
KUE	LANDIS & GYR	MX	C448391	03-17-07	100.1	100.2	100.0
KUE	LANDIS & GYR	MX	C448392	03-17-07	100.1	100.0	100.0
KUE	LANDIS & GYR	MX	C448393	03-17-07	100.1	100.0	100.1
KUE	LANDIS & GYR	MX	C448394	03-15-07	100.0	100.0	99.7
KUE	LANDIS & GYR	MX	C448395	03-17-07	100.1	100.0	99.8
KUE	LANDIS & GYR	MX	C448396	03-17-07	100.0	100.1	100.2
KUE	LANDIS & GYR	MX	C448397	03-17-07	100.0	100.1	100.1
KUE	LANDIS & GYR	MX	C448398	03-17-07	100.0	100.1	100.0
KUE	LANDIS & GYR	MX	C448399	03-17-07	99.9	100.0	100.1
KUE	LANDIS & GYR	MX	C448400	03-17-07	100.1	100.1	100.2
KUE	LANDIS & GYR	MX	C448401	03-09-07	100.1	100.1	99.9
KUE	LANDIS & GYR	MX	C448402	03-17-07	99.9	100.0	99.8
KUE	LANDIS & GYR	MX	C448403	03-17-07	100.1	99.9	100.1
KUE	LANDIS & GYR	MX	C448404	03-17-07	100.0	100.1	100.2
KUE	LANDIS & GYR	MX	C448405	03-09-07	100.0	99.9	100.0
KUE	LANDIS & GYR	MX	C448406	03-17-07	100.0	100.0	99.6
KUE	LANDIS & GYR	MX	C448407	03-17-07	100.1	100.1	100.0
KUE	LANDIS & GYR	MX	C448408	03-17-07	100.0	100.1	100.0
KUE	LANDIS & GYR	MX	C448409	03-17-07	100.1	100.1	100.0
KUE	LANDIS & GYR	MX	C448410	03-17-07	100.0	100.1	99.9
KUE	LANDIS & GYR	MX	C448411	03-17-07	100.1	100.0	100.0
KUE	LANDIS & GYR	MX	C448412	03-17-07	100.1	100.1	100.0
KUE	LANDIS & GYR	MX	C448413	03-17-07	100.1	100.2	100.2
KUE	LANDIS & GYR	MX	C448414	03-17-07	100.1	100.1	100.1
KUE	LANDIS & GYR	MX	C448415	03-17-07	100.1	99.9	100.3
KUE	LANDIS & GYR	MX	C448416	03-17-07	100.0	99.9	99.9
KUE	LANDIS & GYR	MX	C448417	03-17-07	100.1	99.9	100.2
KUE	LANDIS & GYR	MX	C448418	03-17-07	100.0	100.0	99.8
KUE	LANDIS & GYR	MX	C448419	03-17-07	100.0	100.0	99.9
KUE	LANDIS & GYR	MX	C448420	03-17-07	100.1	100.2	99.8
KUE	LANDIS & GYR	MX	C448421	03-17-07	100.0	100.0	99.7
KUE	LANDIS & GYR	MX	C448422	03-17-07	100.0	100.0	99.9
KUE	LANDIS & GYR	MX	C448423	03-17-07	100.1	100.0	99.7
KUE	LANDIS & GYR	MX	C448424	03-17-07	100.1	100.1	100.1
KUE	LANDIS & GYR	MX	C448425	03-17-07	100.1	100.0	100.1
KUE	LANDIS & GYR	MX	C448426	03-17-07	99.9	100.0	99.8
KUE	LANDIS & GYR	MX	C448427	03-17-07	100.0	100.0	100.0
KUE	LANDIS & GYR	MX	C448428	03-17-07	100.1	100.2	100.1
KUE	LANDIS & GYR	MX	C448429	03-17-07	100.0	100.0	99.8
KUE	LANDIS & GYR	MX	C448430	03-17-07	100.1	99.9	100.0
KUE	LANDIS & GYR	MX	C448431	03-09-07	100.1	99.9	100.0
KUE	LANDIS & GYR	MX	C448432	03-17-07	100.1	100.1	100.2
KUE	LANDIS & GYR	MX	C448433	03-17-07	100.1	100.1	100.4
KUE	LANDIS & GYR	MX	C448434	03-09-07	100.0	100.0	100.0
KUE	LANDIS & GYR	MX	C448435	03-17-07	100.1	100.0	100.0
KUE	LANDIS & GYR	MX	C448436	03-17-07	99.9	100.1	100.1
KUE	LANDIS & GYR	MX	C448437	03-17-07	99.9	100.0	100.2

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

CO	MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
KUE	LANDIS & GYR	MX	C448489	03-17-07	100.1	100.0	100.2
KUE	LANDIS & GYR	MX	C448490	03-17-07	100.0	100.0	100.3
KUE	LANDIS & GYR	MX	C448491	03-17-07	100.1	100.1	100.0
KUE	LANDIS & GYR	MX	C448492	03-17-07	100.0	100.1	99.9
KUE	LANDIS & GYR	MX	C448493	03-17-07	100.0	100.0	99.9
KUE	LANDIS & GYR	MX	C448494	03-17-07	100.0	100.0	100.2
KUE	LANDIS & GYR	MX	C448495	03-17-07	100.1	100.0	100.3
KUE	LANDIS & GYR	MX	C448496	03-17-07	100.0	99.9	100.1
KUE	LANDIS & GYR	MX	C448497	03-17-07	99.9	100.0	99.8
KUE	LANDIS & GYR	MX	C448498	03-17-07	100.0	100.0	100.2
KUE	LANDIS & GYR	MX	C448499	03-17-07	100.0	100.2	100.0
KUE	LANDIS & GYR	MX	C448500	03-17-07	100.0	100.0	100.1
KUE	LANDIS & GYR	MX	C448501	03-17-07	100.0	100.1	99.9
KUE	LANDIS & GYR	MX	C448502	03-17-07	100.0	100.0	100.0
KUE	LANDIS & GYR	MX	C448503	03-17-07	100.1	100.1	100.0
KUE	LANDIS & GYR	MX	C448504	03-17-07	100.1	100.0	100.2
KUE	LANDIS & GYR	MX	C448505	03-17-07	100.0	100.0	99.9
KUE	LANDIS & GYR	MX	C448506	03-17-07	100.0	100.1	100.0
KUE	LANDIS & GYR	MX	C448507	03-17-07	100.0	100.1	99.7
KUE	LANDIS & GYR	MX	C448508	03-17-07	100.1	100.1	100.3
KUE	LANDIS & GYR	MX	C448509	03-17-07	100.1	100.0	100.4
KUE	LANDIS & GYR	MX	C448510	03-17-07	100.0	100.1	100.2
KUE	LANDIS & GYR	MX	C448511	03-17-07	100.1	99.9	100.5
KUE	LANDIS & GYR	MX	C448512	03-17-07	100.0	100.0	100.3
KUE	LANDIS & GYR	MX	C448513	03-17-07	100.1	100.0	100.1
KUE	LANDIS & GYR	MX	C448514	03-17-07	100.1	100.0	100.0
KUE	LANDIS & GYR	MX	C448515	03-17-07	100.1	99.9	100.0
KUE	LANDIS & GYR	MX	C448516	03-17-07	100.1	100.0	100.3
KUE	LANDIS & GYR	MX	C448517	03-17-07	100.1	100.1	100.5
KUE	LANDIS & GYR	MX	C448518	03-17-07	100.1	100.1	100.0
KUE	LANDIS & GYR	MX	C448519	03-17-07	100.1	100.1	100.2
KUE	LANDIS & GYR	MX	C448520	03-17-07	100.0	100.1	100.3
KUE	LANDIS & GYR	MX	C448521	03-17-07	100.1	100.0	100.3
KUE	LANDIS & GYR	MX	C448522	03-17-07	100.0	100.1	100.3
KUE	LANDIS & GYR	MX	C448523	03-17-07	100.0	100.0	100.3
KUE	LANDIS & GYR	MX	C448524	03-17-07	100.0	99.9	100.0
KUE	LANDIS & GYR	MX	C448525	03-17-07	100.1	100.1	100.2
KUE	LANDIS & GYR	MX	C448526	03-17-07	100.0	99.9	100.0
KUE	LANDIS & GYR	MX	C448527	03-17-07	100.1	100.2	100.2
KUE	LANDIS & GYR	MX	C448528	03-17-07	100.1	100.1	100.3
KUE	LANDIS & GYR	MX	C448529	03-17-07	100.0	100.0	99.9
KUE	LANDIS & GYR	MX	C448530	03-17-07	100.1	100.1	100.3
KUE	LANDIS & GYR	MX	C448531	03-17-07	100.1	100.1	100.0
KUE	LANDIS & GYR	MX	C448532	03-17-07	100.0	100.0	100.3
KUE	LANDIS & GYR	MX	C448533	03-17-07	100.0	100.1	100.1
KUE	LANDIS & GYR	MX	C448534	03-17-07	99.9	100.1	100.1
KUE	LANDIS & GYR	MX	C448535	03-17-07	100.0	100.0	100.1
KUE	LANDIS & GYR	MX	C448536	03-17-07	100.0	100.1	100.1
KUE	LANDIS & GYR	MX	C448537	03-17-07	100.1	100.0	100.2
KUE	LANDIS & GYR	MX	C448538	03-17-07	100.1	100.0	100.2
KUE	LANDIS & GYR	MX	C448539	03-17-07	100.0	100.0	100.2

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

CO	MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
KUE	LANDIS & GYR	MX	C448591	03-17-07	100.1	100.1	99.8
KUE	LANDIS & GYR	MX	C448592	03-17-07	100.0	100.0	100.1
KUE	LANDIS & GYR	MX	C448593	03-17-07	100.0	99.9	99.8
KUE	LANDIS & GYR	MX	C448594	03-17-07	100.0	100.0	100.1
KUE	LANDIS & GYR	MX	C448595	03-19-07	100.0	100.0	99.6
KUE	LANDIS & GYR	MX	C448596	03-19-07	100.1	100.1	100.4
KUE	LANDIS & GYR	MX	C448597	03-19-07	100.1	100.1	100.3
KUE	LANDIS & GYR	MX	C448598	03-19-07	100.1	100.1	100.1
KUE	LANDIS & GYR	MX	C448599	03-19-07	100.1	100.1	100.2
KUE	LANDIS & GYR	MX	C448600	03-19-07	100.0	100.1	100.2
KUE	LANDIS & GYR	MX	C448601	03-19-07	100.1	100.2	100.3
KUE	LANDIS & GYR	MX	C448602	03-19-07	100.0	100.0	99.9
KUE	LANDIS & GYR	MX	C448603	03-19-07	100.0	100.0	100.1
KUE	LANDIS & GYR	MX	C448604	03-19-07	100.1	100.0	100.4
KUE	LANDIS & GYR	MX	C448605	03-19-07	100.1	100.1	100.4
KUE	LANDIS & GYR	MX	C448606	03-19-07	100.0	100.0	100.0
KUE	LANDIS & GYR	MX	C448607	03-19-07	100.1	100.0	100.2
KUE	LANDIS & GYR	MX	C448608	03-19-07	100.0	100.0	100.2
KUE	LANDIS & GYR	MX	C448609	03-19-07	100.0	100.1	99.9
KUE	LANDIS & GYR	MX	C448610	03-19-07	100.1	99.9	100.4
KUE	LANDIS & GYR	MX	C448611	03-19-07	100.0	100.0	100.0
KUE	LANDIS & GYR	MX	C448612	03-19-07	100.1	100.0	100.1
KUE	LANDIS & GYR	MX	C448613	03-19-07	100.1	100.0	100.2
KUE	LANDIS & GYR	MX	C448614	03-19-07	100.1	100.0	100.4
KUE	LANDIS & GYR	MX	C448615	03-19-07	100.0	100.0	99.8
KUE	LANDIS & GYR	MX	C448616	03-19-07	100.0	100.2	100.1
KUE	LANDIS & GYR	MX	C448617	03-19-07	100.0	100.2	100.1
KUE	LANDIS & GYR	MX	C448618	03-19-07	100.1	100.0	99.9
KUE	LANDIS & GYR	MX	C448619	03-19-07	100.1	100.2	100.0
KUE	LANDIS & GYR	MX	C448620	03-19-07	100.1	99.9	100.2
KUE	LANDIS & GYR	MX	C448621	03-19-07	99.9	100.1	99.9
KUE	LANDIS & GYR	MX	C448622	03-19-07	100.0	100.1	100.1
KUE	LANDIS & GYR	MX	C448623	03-19-07	100.0	100.0	100.2
KUE	LANDIS & GYR	MX	C448624	03-19-07	100.1	100.0	100.2
KUE	LANDIS & GYR	MX	C448625	03-19-07	100.1	100.0	100.2
KUE	LANDIS & GYR	MX	C448626	03-19-07	100.1	100.0	100.3
KUE	LANDIS & GYR	MX	C448627	03-19-07	100.1	100.1	100.2
KUE	LANDIS & GYR	MX	C448628	03-19-07	100.1	100.1	100.5
KUE	LANDIS & GYR	MX	C448629	03-19-07	100.1	100.1	100.1
KUE	LANDIS & GYR	MX	C448630	03-19-07	100.1	100.1	100.3
KUE	LANDIS & GYR	MX	C448631	03-19-07	100.0	100.0	100.2
KUE	LANDIS & GYR	MX	C448632	03-19-07	100.1	100.0	100.4
KUE	LANDIS & GYR	MX	C448633	03-19-07	100.0	100.0	100.1
KUE	LANDIS & GYR	MX	C448634	03-19-07	100.0	100.0	100.0
KUE	LANDIS & GYR	MX	C448635	03-19-07	100.1	100.2	100.2
KUE	LANDIS & GYR	MX	C448636	03-19-07	100.0	100.1	100.3
KUE	LANDIS & GYR	MX	C448637	03-19-07	100.1	100.1	100.2
KUE	LANDIS & GYR	MX	C448638	03-19-07	100.1	100.1	100.1
KUE	LANDIS & GYR	MX	C448639	03-19-07	100.1	100.1	100.2
KUE	LANDIS & GYR	MX	C448640	03-19-07	100.1	100.1	100.1
KUE	LANDIS & GYR	MX	C448641	03-19-07	100.1	100.0	99.9

CO	MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACOR
KUE	LANDIS & GYR	MX	C448693	03-19-07	100.1	100.1	100.5
KUE	LANDIS & GYR	MX	C448694	03-19-07	100.0	100.0	100.1
KUE	LANDIS & GYR	MX	C448695	03-19-07	100.0	100.0	100.1
KUE	LANDIS & GYR	MX	C448696	03-19-07	100.0	100.0	100.1
KUE	LANDIS & GYR	MX	C448697	03-19-07	100.1	100.1	100.4
KUE	LANDIS & GYR	MX	C448698	03-19-07	100.1	100.1	100.4
KUE	LANDIS & GYR	MX	C448699	03-19-07	100.1	100.1	100.4
KUE	LANDIS & GYR	MX	C448700	03-19-07	100.0	100.0	100.5
KUE	LANDIS & GYR	MX	C448701	03-19-07	100.0	100.0	100.5
KUE	LANDIS & GYR	MX	C448702	03-19-07	100.1	100.1	100.5
KUE	LANDIS & GYR	MX	C448703	03-19-07	100.0	100.0	100.5
KUE	LANDIS & GYR	MX	C448704	03-19-07	100.0	100.0	100.5
KUE	LANDIS & GYR	MX	C448705	03-19-07	100.1	100.1	100.5
KUE	LANDIS & GYR	MX	C448706	03-19-07	100.0	100.0	100.5
KUE	LANDIS & GYR	MX	C448707	03-19-07	100.0	100.0	100.5
KUE	LANDIS & GYR	MX	C448708	03-19-07	100.0	100.0	100.5
KUE	LANDIS & GYR	MX	C448709	03-19-07	100.1	100.1	100.5
KUE	LANDIS & GYR	MX	C448710	03-19-07	100.0	100.0	100.5
KUE	LANDIS & GYR	MX	C448711	03-19-07	100.0	100.0	100.5
KUE	LANDIS & GYR	MX	C448712	03-19-07	100.1	100.1	100.5
KUE	LANDIS & GYR	MX	C448713	03-19-07	100.0	100.0	100.5
KUE	LANDIS & GYR	MX	C448714	03-19-07	100.1	100.1	100.5
KUE	LANDIS & GYR	MX	C448715	03-19-07	100.0	100.0	100.5
KUE	LANDIS & GYR	MX	C448716	03-19-07	100.0	100.0	100.5
KUE	LANDIS & GYR	MX	C448717	03-19-07	100.1	100.1	100.5
KUE	LANDIS & GYR	MX	C448718	03-19-07	100.0	100.0	100.5
KUE	LANDIS & GYR	MX	C448719	03-19-07	100.1	100.1	100.5
KUE	LANDIS & GYR	MX	C448720	03-19-07	100.1	100.1	100.5
KUE	LANDIS & GYR	MX	C448721	03-19-07	100.1	100.1	100.5
KUE	LANDIS & GYR	MX	C448722	03-19-07	100.1	100.1	100.5
KUE	LANDIS & GYR	MX	C448723	03-19-07	100.0	100.0	100.5
KUE	LANDIS & GYR	MX	C448724	03-19-07	100.1	100.1	100.5
KUE	LANDIS & GYR	MX	C448725	03-19-07	100.0	100.0	100.5
KUE	LANDIS & GYR	MX	C448726	03-19-07	100.1	100.1	100.5
KUE	LANDIS & GYR	MX	C448727	03-19-07	99.9	99.9	100.5
KUE	LANDIS & GYR	MX	C448728	03-19-07	100.0	100.0	100.5
KUE	LANDIS & GYR	MX	C448729	03-19-07	100.0	100.0	100.5
KUE	LANDIS & GYR	MX	C448730	03-19-07	100.1	100.1	100.5
KUE	LANDIS & GYR	MX	C448731	03-19-07	100.0	100.0	100.5
KUE	LANDIS & GYR	MX	C448732	03-19-07	100.1	100.1	100.5
KUE	LANDIS & GYR	MX	C448733	03-19-07	100.0	100.0	100.5
KUE	LANDIS & GYR	MX	C448734	03-19-07	100.0	100.0	100.5
KUE	LANDIS & GYR	MX	C448735	03-19-07	100.0	100.0	100.5
KUE	LANDIS & GYR	MX	C448736	03-19-07	100.1	100.1	100.5
KUE	LANDIS & GYR	MX	C448737	03-19-07	100.0	100.0	100.5
KUE	LANDIS & GYR	MX	C448738	03-19-07	100.0	100.0	100.5
KUE	LANDIS & GYR	MX	C448739	03-19-07	100.0	100.0	100.5
KUE	LANDIS & GYR	MX	C448740	03-19-07	100.0	100.0	100.5
KUE	LANDIS & GYR	MX	C448741	03-19-07	100.0	100.0	100.5
KUE	LANDIS & GYR	MX	C448742	03-19-07	100.1	100.1	100.5
KUE	LANDIS & GYR	MX	C448743	03-19-07	100.0	100.0	100.5

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

CO	MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
KUE	LANDIS & GYR	MX	C448795	03-17-07	100.0	100.0	99.9
KUE	LANDIS & GYR	MX	C448796	03-17-07	100.0	100.1	99.8
KUE	LANDIS & GYR	MX	C448797	03-17-07	100.1	100.1	100.0
KUE	LANDIS & GYR	MX	C448798	03-17-07	100.0	99.9	100.0
KUE	LANDIS & GYR	MX	C448799	03-17-07	100.0	100.0	100.1
KUE	LANDIS & GYR	MX	C448800	03-17-07	100.0	100.0	100.0
KUE	LANDIS & GYR	MX	C448801	03-17-07	100.1	100.1	100.1
KUE	LANDIS & GYR	MX	C448802	03-17-07	100.1	100.1	100.0
KUE	LANDIS & GYR	MX	C448803	03-17-07	100.1	100.0	99.9
KUE	LANDIS & GYR	MX	C448804	03-17-07	100.1	100.0	100.0
KUE	LANDIS & GYR	MX	C448805	03-17-07	100.1	100.1	100.0
KUE	LANDIS & GYR	MX	C448806	03-17-07	100.1	100.1	100.1
KUE	LANDIS & GYR	MX	C448807	03-17-07	100.1	100.0	100.1
KUE	LANDIS & GYR	MX	C448808	03-17-07	100.0	100.0	99.5
KUE	LANDIS & GYR	MX	C448809	03-17-07	100.1	100.1	100.0
KUE	LANDIS & GYR	MX	C448810	03-17-07	100.1	100.1	100.1
KUE	LANDIS & GYR	MX	C448811	03-17-07	100.0	100.0	100.1
KUE	LANDIS & GYR	MX	C448812	03-17-07	99.9	99.9	100.1
KUE	LANDIS & GYR	MX	C448813	03-17-07	100.1	100.1	99.7
KUE	LANDIS & GYR	MX	C448814	03-17-07	100.0	100.0	99.9
KUE	LANDIS & GYR	MX	C448815	03-17-07	100.0	99.9	99.7
KUE	LANDIS & GYR	MX	C448816	03-17-07	100.0	99.9	99.7
KUE	LANDIS & GYR	MX	C448817	03-17-07	100.0	100.0	100.0
KUE	LANDIS & GYR	MX	C448818	03-17-07	100.0	99.9	100.0
KUE	LANDIS & GYR	MX	C448819	03-17-07	100.1	100.0	100.0
KUE	LANDIS & GYR	MX	C448820	03-17-07	100.1	99.9	99.8
KUE	LANDIS & GYR	MX	C448821	03-17-07	100.1	100.1	99.8
KUE	LANDIS & GYR	MX	C448822	03-17-07	100.1	100.1	99.9
KUE	LANDIS & GYR	MX	C448823	03-19-07	100.1	100.1	99.9
KUE	LANDIS & GYR	MX	C448824	03-17-07	100.0	100.1	99.9
KUE	LANDIS & GYR	MX	C448825	03-17-07	100.1	100.2	100.0
KUE	LANDIS & GYR	MX	C448826	03-17-07	100.1	100.1	100.0
KUE	LANDIS & GYR	MX	C448827	03-17-07	100.0	99.9	100.6
KUE	LANDIS & GYR	MX	C448828	03-17-07	100.0	100.1	100.1
KUE	LANDIS & GYR	MX	C448829	03-17-07	100.1	100.1	99.9
KUE	LANDIS & GYR	MX	C448830	03-17-07	100.1	100.1	99.9
KUE	LANDIS & GYR	MX	C448831	03-17-07	100.1	100.1	100.0
KUE	LANDIS & GYR	MX	C448832	03-17-07	100.1	100.0	100.0
KUE	LANDIS & GYR	MX	C448833	03-17-07	100.0	99.9	99.8
KUE	LANDIS & GYR	MX	C448834	03-17-07	100.0	100.0	99.8
KUE	LANDIS & GYR	MX	C448835	03-17-07	100.0	100.0	99.8
KUE	LANDIS & GYR	MX	C448836	03-17-07	100.0	100.1	100.1
KUE	LANDIS & GYR	MX	C448837	03-17-07	100.0	99.9	99.7
KUE	LANDIS & GYR	MX	C448838	03-17-07	100.1	100.1	100.0
KUE	LANDIS & GYR	MX	C448839	03-17-07	100.0	100.1	100.1
KUE	LANDIS & GYR	MX	C448840	03-17-07	100.1	100.0	99.8
KUE	LANDIS & GYR	MX	C448841	03-17-07	100.0	100.0	100.0
KUE	LANDIS & GYR	MX	C448842	03-17-07	100.0	100.0	99.8
KUE	LANDIS & GYR	MX	C448843	03-17-07	100.1	100.0	99.8
KUE	LANDIS & GYR	MX	C448844	03-17-07	100.1	100.1	100.2
KUE	LANDIS & GYR	MX	C448845	03-17-07	100.1	99.9	99.7

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

CO	MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
KUE	LANDIS & GYR	MX	C448897	03-17-07	100.0	99.9	99.7
KUE	LANDIS & GYR	MX	C448898	03-17-07	100.0	99.9	100.1
KUE	LANDIS & GYR	MX	C448899	03-17-07	100.0	100.0	100.0
KUE	LANDIS & GYR	MX	C448900	03-17-07	100.0	100.0	100.0
KUE	LANDIS & GYR	MX	C448901	03-17-07	100.0	99.9	100.1
KUE	LANDIS & GYR	MX	C448902	03-17-07	100.0	100.1	99.9
KUE	LANDIS & GYR	MX	C448903	03-19-07	100.0	100.0	100.0
KUE	LANDIS & GYR	MX	C448904	03-17-07	99.9	100.0	99.7
KUE	LANDIS & GYR	MX	C448905	03-17-07	100.0	100.0	100.0
KUE	LANDIS & GYR	MX	C448906	03-17-07	100.0	99.9	100.0
KUE	LANDIS & GYR	MX	C448907	03-17-07	100.0	100.0	99.7
KUE	LANDIS & GYR	MX	C448908	03-17-07	100.1	100.0	100.2
KUE	LANDIS & GYR	MX	C448909	03-17-07	100.1	100.1	100.1
KUE	LANDIS & GYR	MX	C448910	03-17-07	100.1	100.2	100.0
KUE	LANDIS & GYR	MX	C448911	03-17-07	100.0	100.1	99.8
KUE	LANDIS & GYR	MX	C448912	03-17-07	100.1	100.1	100.1
KUE	LANDIS & GYR	MX	C448913	03-17-07	100.1	100.0	100.1
KUE	LANDIS & GYR	MX	C448914	03-17-07	100.0	100.0	99.7
KUE	LANDIS & GYR	MX	C448915	03-17-07	100.1	100.2	100.2
KUE	LANDIS & GYR	MX	C448916	03-17-07	100.1	100.1	100.2
KUE	LANDIS & GYR	MX	C448917	03-17-07	100.1	100.1	100.1
KUE	LANDIS & GYR	MX	C448918	03-17-07	100.0	100.1	99.8
KUE	LANDIS & GYR	MX	C448919	03-17-07	100.0	100.0	100.0
KUE	LANDIS & GYR	MX	C448920	03-17-07	100.1	100.1	100.0
KUE	LANDIS & GYR	MX	C448921	03-17-07	100.0	100.2	99.7
KUE	LANDIS & GYR	MX	C448922	03-17-07	100.0	99.9	99.9
KUE	LANDIS & GYR	MX	C448923	03-17-07	100.1	100.0	99.8
KUE	LANDIS & GYR	MX	C448924	03-17-07	100.1	99.9	99.9
KUE	LANDIS & GYR	MX	C448925	03-17-07	100.1	100.0	99.9
KUE	LANDIS & GYR	MX	C448926	03-17-07	100.0	100.2	100.1
KUE	LANDIS & GYR	MX	C448927	03-17-07	100.0	100.1	99.9
KUE	LANDIS & GYR	MX	C448928	03-17-07	100.0	100.1	100.0
KUE	LANDIS & GYR	MX	C448929	03-17-07	100.1	100.1	99.9
KUE	LANDIS & GYR	MX	C448930	03-17-07	100.1	100.0	99.8
KUE	LANDIS & GYR	MX	C448931	03-17-07	100.1	100.1	99.8
KUE	LANDIS & GYR	MX	C448932	03-17-07	100.1	100.0	100.0
KUE	LANDIS & GYR	MX	C448933	03-17-07	100.0	100.0	100.0
KUE	LANDIS & GYR	MX	C448934	03-17-07	100.1	100.0	99.5
KUE	LANDIS & GYR	MX	C448935	03-17-07	100.0	100.1	100.0
KUE	LANDIS & GYR	MX	C448936	03-17-07	100.1	100.2	100.0
KUE	LANDIS & GYR	MX	C448937	03-17-07	100.1	100.0	100.0
KUE	LANDIS & GYR	MX	C448938	03-17-07	100.0	99.9	99.7
KUE	LANDIS & GYR	MX	C448939	03-17-07	100.0	99.9	99.6
KUE	LANDIS & GYR	MX	C448940	03-17-07	100.0	100.0	100.0
KUE	LANDIS & GYR	MX	C448941	03-17-07	100.0	99.9	100.3
KUE	LANDIS & GYR	MX	C448942	03-17-07	100.0	100.1	100.0
KUE	LANDIS & GYR	MX	C448943	03-17-07	100.0	100.1	100.0
KUE	LANDIS & GYR	MX	C448944	03-17-07	100.0	100.0	99.8
KUE	LANDIS & GYR	MX	C448945	03-17-07	100.0	99.9	100.0
KUE	LANDIS & GYR	MX	C448946	03-17-07	100.1	100.2	100.2
KUE	LANDIS & GYR	MX	C448947	03-17-07	100.1	100.2	100.0

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

CO	MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
KUE	LANDIS & GYR	MX	C448999	03-19-07	100.1	100.0	100.1
KUE	LANDIS & GYR	MX	C449000	03-19-07	100.1	100.1	100.0
KUE	LANDIS & GYR	MX	C449001	03-19-07	100.1	100.0	99.8
KUE	LANDIS & GYR	MX	C449002	03-19-07	100.0	99.9	99.8
KUE	LANDIS & GYR	MX	C449003	03-17-07	100.0	100.0	100.3
KUE	LANDIS & GYR	MX	C449004	03-17-07	100.1	100.0	100.0
KUE	LANDIS & GYR	MX	C449005	03-19-07	100.0	100.1	99.9
KUE	LANDIS & GYR	MX	C449006	03-19-07	100.0	100.0	100.2
KUE	LANDIS & GYR	MX	C449007	03-16-07	100.0	99.9	100.1
KUE	LANDIS & GYR	MX	C449008	03-19-07	100.1	99.9	100.0
KUE	LANDIS & GYR	MX	C449009	03-19-07	100.1	99.9	100.0
KUE	LANDIS & GYR	MX	C449010	03-19-07	100.0	100.1	100.1
KUE	LANDIS & GYR	MX	C449011	03-19-07	100.1	100.2	100.4
KUE	LANDIS & GYR	MX	C449012	03-19-07	100.0	100.1	99.8
KUE	LANDIS & GYR	MX	C449013	03-19-07	100.1	100.1	100.3
KUE	LANDIS & GYR	MX	C449014	03-19-07	100.0	100.0	100.0
KUE	LANDIS & GYR	MX	C449015	03-19-07	100.0	100.1	100.1
KUE	LANDIS & GYR	MX	C449016	03-19-07	100.1	100.1	99.9
KUE	LANDIS & GYR	MX	C449017	03-19-07	100.1	100.0	100.1
KUE	LANDIS & GYR	MX	C449018	03-19-07	100.1	100.0	100.1
KUE	LANDIS & GYR	MX	C449019	03-19-07	100.1	99.9	100.2
KUE	LANDIS & GYR	MX	C449020	03-19-07	100.1	100.0	100.0
KUE	LANDIS & GYR	MX	C449021	03-19-07	100.0	100.0	99.8
KUE	LANDIS & GYR	MX	C449022	03-19-07	100.1	100.2	99.9
KUE	LANDIS & GYR	MX	C449023	03-19-07	100.1	100.1	100.1
KUE	LANDIS & GYR	MX	C449024	03-19-07	100.1	100.0	100.1
KUE	LANDIS & GYR	MX	C449025	03-19-07	100.1	100.2	99.9
KUE	LANDIS & GYR	MX	C449026	03-19-07	100.0	100.2	99.7
KUE	LANDIS & GYR	MX	C449027	03-19-07	100.1	100.2	100.2
KUE	LANDIS & GYR	MX	C449028	03-19-07	100.1	100.1	99.8
KUE	LANDIS & GYR	MX	C449029	03-19-07	100.1	100.0	99.8
KUE	LANDIS & GYR	MX	C449030	03-19-07	100.0	100.0	100.0
KUE	LANDIS & GYR	MX	C449031	03-19-07	100.1	100.1	100.0
KUE	LANDIS & GYR	MX	C449032	03-19-07	100.1	100.1	99.8
KUE	LANDIS & GYR	MX	C449033	03-19-07	100.0	100.0	100.0
KUE	LANDIS & GYR	MX	C449034	03-19-07	100.1	100.1	99.9
KUE	LANDIS & GYR	MX	C449035	03-19-07	100.0	100.1	100.2
KUE	LANDIS & GYR	MX	C449036	03-19-07	100.0	100.0	99.8
KUE	LANDIS & GYR	MX	C449037	03-19-07	100.0	99.9	100.0
KUE	LANDIS & GYR	MX	C449038	03-19-07	100.0	100.0	99.9
KUE	LANDIS & GYR	MX	C449039	03-17-07	100.0	99.9	100.0
KUE	LANDIS & GYR	MX	C449040	03-17-07	100.0	100.0	99.6
KUE	LANDIS & GYR	MX	C449041	03-19-07	100.1	100.1	100.0
KUE	LANDIS & GYR	MX	C449042	03-19-07	100.0	99.9	100.0
KUE	LANDIS & GYR	MX	C449043	03-19-07	100.1	100.1	99.7
KUE	LANDIS & GYR	MX	C449044	03-19-07	100.1	100.0	99.7
KUE	LANDIS & GYR	MX	C449045	03-19-07	100.0	100.0	99.9
KUE	LANDIS & GYR	MX	C449046	03-19-07	100.1	100.1	100.1
KUE	LANDIS & GYR	MX	C449047	03-19-07	100.1	100.1	100.3
KUE	LANDIS & GYR	MX	C449048	03-19-07	100.0	100.0	100.1
KUE	LANDIS & GYR	MX	C449049	03-19-07	100.0	100.0	100.2

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

CO	MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PPFACTOR
KUE	LANDIS & GYR	MX	C449101	03-17-07	100.1	100.0	100.0
KUE	LANDIS & GYR	MX	C449102	03-17-07	100.0	99.9	99.8
KUE	LANDIS & GYR	MX	C449103	03-19-07	100.0	100.0	100.3
KUE	LANDIS & GYR	MX	C449104	03-19-07	100.0	100.1	100.3
KUE	LANDIS & GYR	MX	C449105	03-19-07	100.1	100.2	100.2
KUE	LANDIS & GYR	MX	C449106	03-19-07	100.0	100.0	99.7
KUE	LANDIS & GYR	MX	C449107	03-19-07	100.1	100.2	100.4
KUE	LANDIS & GYR	MX	C449108	03-19-07	100.1	100.2	99.8
KUE	LANDIS & GYR	MX	C449109	03-17-07	100.1	100.0	100.2
KUE	LANDIS & GYR	MX	C449110	03-17-07	100.0	100.0	99.8
KUE	LANDIS & GYR	MX	C449111	03-19-07	100.1	100.1	99.7
KUE	LANDIS & GYR	MX	C449112	03-17-07	100.0	100.2	99.6
KUE	LANDIS & GYR	MX	C449113	03-17-07	100.0	100.0	100.1
KUE	LANDIS & GYR	MX	C449114	03-19-07	100.0	100.0	100.0
KUE	LANDIS & GYR	MX	C449115	03-17-07	100.0	100.0	100.0
KUE	LANDIS & GYR	MX	C449116	03-19-07	100.1	100.1	100.0
KUE	LANDIS & GYR	MX	C449117	03-19-07	100.1	100.1	100.1
KUE	LANDIS & GYR	MX	C449118	03-17-07	100.0	100.0	100.1
KUE	LANDIS & GYR	MX	C449119	03-19-07	100.1	100.1	100.1
KUE	LANDIS & GYR	MX	C449120	03-19-07	100.1	100.1	100.2
KUE	LANDIS & GYR	MX	C449121	03-19-07	100.0	100.1	100.1
KUE	LANDIS & GYR	MX	C449122	03-19-07	100.0	100.1	99.9
KUE	LANDIS & GYR	MX	C449123	03-19-07	100.0	99.9	99.9
KUE	LANDIS & GYR	MX	C449124	03-19-07	100.0	100.0	99.9
KUE	LANDIS & GYR	MX	C449125	03-19-07	100.1	100.0	99.8
KUE	LANDIS & GYR	MX	C449126	03-19-07	100.1	100.1	100.1
KUE	LANDIS & GYR	MX	C449127	03-19-07	99.9	100.0	99.9
KUE	LANDIS & GYR	MX	C449128	03-19-07	100.0	100.0	99.9
KUE	LANDIS & GYR	MX	C449129	03-19-07	100.0	100.0	99.9
KUE	LANDIS & GYR	MX	C449130	03-19-07	100.0	100.0	99.7
KUE	LANDIS & GYR	MX	C449131	03-19-07	100.0	100.0	100.2
KUE	LANDIS & GYR	MX	C449132	03-19-07	100.1	99.9	100.1
KUE	LANDIS & GYR	MX	C449133	03-19-07	100.0	100.0	99.9
KUE	LANDIS & GYR	MX	C449134	03-19-07	100.0	100.0	99.9
KUE	LANDIS & GYR	MX	C449135	03-19-07	100.0	100.0	99.9
KUE	LANDIS & GYR	MX	C449136	03-19-07	100.1	100.0	99.9
KUE	LANDIS & GYR	MX	C449137	03-19-07	100.0	99.9	100.2
KUE	LANDIS & GYR	MX	C449138	03-19-07	100.0	99.9	99.8
KUE	LANDIS & GYR	MX	C449139	03-19-07	100.1	100.0	100.2
KUE	LANDIS & GYR	MX	C449140	03-19-07	100.1	99.9	99.8
KUE	LANDIS & GYR	MX	C449141	03-19-07	100.0	100.0	100.2
KUE	LANDIS & GYR	MX	C449142	03-19-07	100.1	100.0	100.3
KUE	LANDIS & GYR	MX	C449143	03-19-07	100.0	100.0	100.0
KUE	LANDIS & GYR	MX	C449144	03-19-07	100.0	100.2	100.2
KUE	LANDIS & GYR	MX	C449145	03-19-07	100.0	100.2	99.8
KUE	LANDIS & GYR	MX	C449146	03-19-07	100.0	100.2	100.1
KUE	LANDIS & GYR	MX	C449147	03-19-07	100.0	100.2	100.1
KUE	LANDIS & GYR	MX	C449148	03-19-07	100.1	100.1	100.1
KUE	LANDIS & GYR	MX	C449149	03-19-07	100.0	100.0	100.0
KUE	LANDIS & GYR	MX	C449150	03-19-07	100.0	100.0	99.9
KUE	LANDIS & GYR	MX	C449151	03-19-07	100.0	100.1	100.1

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

CO	MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
KUE	LANDIS & GYR	MX	C449203	03-19-07	100.0	100.0	100.2
KUE	LANDIS & GYR	MX	C449204	03-19-07	100.0	100.0	100.1
KUE	LANDIS & GYR	MX	C449205	03-19-07	100.0	100.0	100.1
KUE	LANDIS & GYR	MX	C449206	03-19-07	100.0	100.0	100.1
KUE	LANDIS & GYR	MX	C449207	03-19-07	100.0	100.0	100.1
KUE	LANDIS & GYR	MX	C449208	03-19-07	100.0	100.0	100.1
KUE	LANDIS & GYR	MX	C449209	03-19-07	100.0	100.0	100.1
KUE	LANDIS & GYR	MX	C449210	03-19-07	100.0	100.0	100.1
KUE	LANDIS & GYR	MX	C449211	03-19-07	100.0	100.0	100.1
KUE	LANDIS & GYR	MX	C449212	03-19-07	100.0	100.0	100.1
KUE	LANDIS & GYR	MX	C449213	03-19-07	100.0	100.0	100.0
KUE	LANDIS & GYR	MX	C449214	03-19-07	100.0	100.0	100.0
KUE	LANDIS & GYR	MX	C449215	03-19-07	100.0	100.0	100.0
KUE	LANDIS & GYR	MX	C449216	03-19-07	100.0	100.0	100.0
KUE	LANDIS & GYR	MX	C449217	03-19-07	100.0	100.0	100.0
KUE	LANDIS & GYR	MX	C449218	03-19-07	100.0	100.0	100.0
KUE	LANDIS & GYR	MX	C449219	03-19-07	100.0	100.0	100.0
KUE	LANDIS & GYR	MX	C449220	03-19-07	100.0	100.0	100.0
KUE	LANDIS & GYR	MX	C449221	03-19-07	100.0	100.0	100.0
KUE	LANDIS & GYR	MX	C449222	03-19-07	100.0	100.0	100.0
KUE	LANDIS & GYR	MX	C449223	03-19-07	100.0	100.0	100.0
KUE	LANDIS & GYR	MX	C449224	03-19-07	100.0	100.0	100.0
KUE	LANDIS & GYR	MX	C449225	03-19-07	100.0	100.0	100.0
KUE	LANDIS & GYR	MX	C449226	03-19-07	100.0	100.0	100.0
KUE	LANDIS & GYR	MX	C449227	03-19-07	100.0	100.0	100.0
KUE	LANDIS & GYR	MX	C449228	03-19-07	100.0	100.0	100.0
KUE	LANDIS & GYR	MX	C449229	03-19-07	100.0	100.0	100.0
KUE	LANDIS & GYR	MX	C449230	03-19-07	100.0	100.0	100.0
KUE	LANDIS & GYR	MX	C449231	03-19-07	100.0	100.0	100.0
KUE	LANDIS & GYR	MX	C449232	03-19-07	100.0	100.0	100.0
KUE	LANDIS & GYR	MX	C449233	03-19-07	100.0	100.0	100.0
KUE	LANDIS & GYR	MX	C449234	03-19-07	100.0	100.0	100.0
KUE	LANDIS & GYR	MX	C449235	03-19-07	100.0	100.0	100.0
KUE	LANDIS & GYR	MX	C449236	03-19-07	100.0	100.0	100.0
KUE	LANDIS & GYR	MX	C449237	03-19-07	100.0	100.0	100.0
KUE	LANDIS & GYR	MX	C449238	03-19-07	100.0	100.0	100.0
KUE	LANDIS & GYR	MX	C449239	03-17-07	100.0	100.0	100.0
KUE	LANDIS & GYR	MX	C449240	03-17-07	100.0	100.0	100.0
KUE	LANDIS & GYR	MX	C449241	03-17-07	100.0	100.0	100.0
KUE	LANDIS & GYR	MX	C449242	03-17-07	100.0	100.0	100.0
KUE	LANDIS & GYR	MX	C449243	03-17-07	100.0	100.0	100.0
KUE	LANDIS & GYR	MX	C449244	03-17-07	100.0	100.0	100.0
KUE	LANDIS & GYR	MX	C449245	03-17-07	100.0	100.0	100.0
KUE	LANDIS & GYR	MX	C449246	03-17-07	100.0	100.0	100.0
KUE	LANDIS & GYR	MX	C449247	03-17-07	100.0	100.0	100.0
KUE	LANDIS & GYR	MX	C449248	03-17-07	100.0	100.0	100.0
KUE	LANDIS & GYR	MX	C449249	03-17-07	100.0	100.0	100.0
KUE	LANDIS & GYR	MX	C449250	03-17-07	100.0	100.0	100.0
KUE	LANDIS & GYR	MX	C449251	03-19-07	100.0	100.0	100.0
KUE	LANDIS & GYR	MX	C449252	03-19-07	100.0	100.0	100.0
KUE	LANDIS & GYR	MX	C449253	03-19-07	100.0	100.0	100.0

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

CO	MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
KUE	& GYR	MX	C449305	03-19-07	100.1	100.0	100.0
KUE	LANDIS & GYR	MX	C449306	03-19-07	100.1	100.0	99.8
KUE	LANDIS & GYR	MX	C449307	03-19-07	100.0	100.0	99.9
KUE	LANDIS & GYR	MX	C449308	03-19-07	100.1	100.1	99.9
KUE	LANDIS & GYR	MX	C449309	03-19-07	100.0	100.0	99.8
KUE	LANDIS & GYR	MX	C449310	03-19-07	100.0	100.0	99.8
KUE	LANDIS & GYR	MX	C449311	03-19-07	100.0	99.9	99.8
KUE	LANDIS & GYR	MX	C449312	03-19-07	100.1	100.0	100.0
KUE	LANDIS & GYR	MX	C449313	03-19-07	100.0	100.0	99.8
KUE	LANDIS & GYR	MX	C449314	03-19-07	100.1	99.9	100.1
KUE	LANDIS & GYR	MX	C449315	03-19-07	100.0	100.1	99.8
KUE	LANDIS & GYR	MX	C449316	03-19-07	100.1	100.0	100.3
KUE	LANDIS & GYR	MX	C449317	03-19-07	100.1	100.0	100.1
KUE	LANDIS & GYR	MX	C449318	03-19-07	100.0	100.0	100.1
KUE	LANDIS & GYR	MX	C449319	03-19-07	100.0	100.1	99.9
KUE	LANDIS & GYR	MX	C449320	03-19-07	100.1	100.1	100.1
KUE	LANDIS & GYR	MX	C449321	03-19-07	100.0	99.9	100.2
KUE	LANDIS & GYR	MX	C449322	03-19-07	100.1	100.2	100.0
KUE	LANDIS & GYR	MX	C449323	03-19-07	100.0	100.0	99.8
KUE	LANDIS & GYR	MX	C449324	03-19-07	100.0	100.1	99.7
KUE	LANDIS & GYR	MX	C449325	03-19-07	100.0	100.0	100.0
KUE	LANDIS & GYR	MX	C449326	03-19-07	100.0	100.0	100.0
KUE	LANDIS & GYR	MX	C449327	03-19-07	99.9	99.9	100.0
KUE	LANDIS & GYR	MX	C449328	03-19-07	100.1	100.0	99.9
KUE	LANDIS & GYR	MX	C449329	03-19-07	100.1	100.0	100.1
KUE	LANDIS & GYR	MX	C449330	03-19-07	100.0	100.0	100.0
KUE	LANDIS & GYR	MX	C449331	03-19-07	100.0	99.9	99.9
KUE	LANDIS & GYR	MX	C449332	03-19-07	100.1	100.1	100.1
KUE	LANDIS & GYR	MX	C449333	03-19-07	100.0	100.0	100.0
KUE	LANDIS & GYR	MX	C449334	03-19-07	100.0	100.1	100.2
KUE	LANDIS & GYR	MX	C449335	03-19-07	100.0	100.0	100.2
KUE	LANDIS & GYR	MX	C449336	03-19-07	100.0	99.9	100.2
KUE	LANDIS & GYR	MX	C449337	03-19-07	100.0	100.0	99.7
KUE	LANDIS & GYR	MX	C449338	03-19-07	100.1	100.1	100.5
KUE	LANDIS & GYR	MX	C449339	03-19-07	100.0	100.0	100.3
KUE	LANDIS & GYR	MX	C449340	03-19-07	100.1	100.1	99.9
KUE	LANDIS & GYR	MX	C449341	03-19-07	100.0	100.1	100.1
KUE	LANDIS & GYR	MX	C449342	03-19-07	100.1	100.0	99.8
KUE	LANDIS & GYR	MX	C449343	03-19-07	100.0	100.0	99.9
KUE	LANDIS & GYR	MX	C449344	03-19-07	100.1	100.1	100.1
KUE	LANDIS & GYR	MX	C449345	03-19-07	100.0	100.1	100.2
KUE	LANDIS & GYR	MX	C449346	03-19-07	100.0	100.0	99.9
KUE	LANDIS & GYR	MX	C449347	03-19-07	100.0	100.0	100.1
KUE	LANDIS & GYR	MX	C449348	03-19-07	100.1	100.1	100.0
KUE	LANDIS & GYR	MX	C449349	03-19-07	100.0	100.0	100.0
KUE	LANDIS & GYR	MX	C449350	03-19-07	100.0	100.0	100.2
KUE	LANDIS & GYR	MX	C449351	03-19-07	100.1	100.1	100.3
KUE	LANDIS & GYR	MX	C449352	03-19-07	100.0	100.0	100.2
KUE	LANDIS & GYR	MX	C449353	03-19-07	100.1	99.9	100.2
KUE	LANDIS & GYR	MX	C449354	03-19-07	100.1	100.1	99.8
KUE	LANDIS & GYR	MX	C449355	03-19-07	100.1	100.1	100.0

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

CO	MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
KUE	LANDIS	& GYR	C449407	03-19-07	100.0	100.1	100.0
KUE	LANDIS	& GYR	C449408	03-19-07	100.1	100.0	100.2
KUE	LANDIS	& GYR	C449409	03-19-07	100.1	100.1	100.1
KUE	LANDIS	& GYR	C449410	03-19-07	100.0	100.1	99.9
KUE	LANDIS	& GYR	C449411	03-19-07	100.0	100.2	100.1
KUE	LANDIS	& GYR	C449412	03-19-07	100.1	100.1	100.0
KUE	LANDIS	& GYR	C449413	03-19-07	100.0	100.0	99.8
KUE	LANDIS	& GYR	C449414	03-19-07	100.1	100.1	99.7
KUE	LANDIS	& GYR	C449415	03-19-07	100.0	100.1	99.8
KUE	LANDIS	& GYR	C449416	03-19-07	100.0	100.0	100.1
KUE	LANDIS	& GYR	C449417	03-19-07	100.1	100.1	100.0
KUE	LANDIS	& GYR	C449418	03-19-07	100.0	100.1	99.8
KUE	LANDIS	& GYR	C449419	03-19-07	100.0	100.2	99.9
KUE	LANDIS	& GYR	C449420	03-19-07	100.0	100.1	99.8
KUE	LANDIS	& GYR	C449421	03-19-07	100.0	100.1	99.8
KUE	LANDIS	& GYR	C449422	03-19-07	100.1	99.9	100.0
KUE	LANDIS	& GYR	C449423	03-19-07	100.0	100.0	100.1
KUE	LANDIS	& GYR	C449424	03-19-07	100.1	99.9	100.0
KUE	LANDIS	& GYR	C449425	03-19-07	100.0	100.1	99.7
KUE	LANDIS	& GYR	C449426	03-19-07	100.0	100.1	100.0
KUE	LANDIS	& GYR	C449427	03-19-07	100.0	100.0	100.5
KUE	LANDIS	& GYR	C449428	03-19-07	100.1	100.1	99.9
KUE	LANDIS	& GYR	C449429	03-19-07	100.0	100.0	100.1
KUE	LANDIS	& GYR	C449430	03-19-07	100.0	100.0	100.3
KUE	LANDIS	& GYR	C449431	03-19-07	100.1	100.1	100.0
KUE	LANDIS	& GYR	C449432	03-19-07	100.1	100.0	99.9
KUE	LANDIS	& GYR	C449433	03-19-07	100.0	99.9	99.9
KUE	LANDIS	& GYR	C449434	03-19-07	100.0	100.2	100.1
KUE	LANDIS	& GYR	C449435	03-19-07	100.0	100.0	100.1
KUE	LANDIS	& GYR	C449436	03-19-07	100.0	100.0	100.2
KUE	LANDIS	& GYR	C449437	03-19-07	100.1	100.1	100.2
KUE	LANDIS	& GYR	C449438	03-19-07	100.0	100.0	100.0
KUE	LANDIS	& GYR	C449439	03-19-07	100.0	100.0	100.2
KUE	LANDIS	& GYR	C449440	03-19-07	100.0	99.9	100.0
KUE	LANDIS	& GYR	C449441	03-19-07	100.0	100.1	100.0
KUE	LANDIS	& GYR	C449442	03-19-07	100.0	100.1	100.1
KUE	LANDIS	& GYR	C449443	03-19-07	100.1	99.9	99.9
KUE	LANDIS	& GYR	C449444	03-19-07	100.1	100.1	100.2
KUE	LANDIS	& GYR	C449445	03-19-07	100.1	100.1	100.1
KUE	LANDIS	& GYR	C449446	03-19-07	100.1	100.1	100.3
KUE	LANDIS	& GYR	C449447	03-19-07	100.1	100.1	99.9
KUE	LANDIS	& GYR	C449448	03-19-07	100.0	100.0	99.8
KUE	LANDIS	& GYR	C449449	03-19-07	100.0	100.0	100.0
KUE	LANDIS	& GYR	C449450	03-19-07	100.0	100.0	100.0
KUE	LANDIS	& GYR	C449451	03-19-07	100.0	100.0	99.9
KUE	LANDIS	& GYR	C449452	03-19-07	100.0	100.0	100.3
KUE	LANDIS	& GYR	C449453	03-19-07	100.0	100.0	100.1
KUE	LANDIS	& GYR	C449454	03-19-07	100.0	100.2	100.0
KUE	LANDIS	& GYR	C449455	03-19-07	100.0	100.1	100.2
KUE	LANDIS	& GYR	C449456	03-19-07	100.0	100.1	99.8
KUE	LANDIS	& GYR	C449457	03-19-07	100.0	100.2	100.0

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

CO	MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PF FACTOR
KUE	LANDIS & GYR	MX	C449509	03-19-07	100.1	100.1	99.8
KUE	LANDIS & GYR	MX	C449510	03-17-07	100.0	99.9	99.8
KUE	LANDIS & GYR	MX	C449511	03-19-07	100.1	100.1	100.0
KUE	LANDIS & GYR	MX	C449512	03-17-07	100.1	100.1	99.9
KUE	LANDIS & GYR	MX	C449513	03-17-07	100.0	100.0	99.8
KUE	LANDIS & GYR	MX	C449514	03-17-07	100.1	100.0	100.0
KUE	LANDIS & GYR	MX	C449515	03-17-07	100.0	100.0	99.8
KUE	LANDIS & GYR	MX	C449516	03-17-07	100.0	100.1	99.7
KUE	LANDIS & GYR	MX	C449517	03-17-07	100.0	100.0	100.4
KUE	LANDIS & GYR	MX	C449518	03-17-07	100.1	100.1	99.9
KUE	LANDIS & GYR	MX	C449519	03-17-07	100.0	100.0	99.6
KUE	LANDIS & GYR	MX	C449520	03-17-07	100.0	99.9	99.8
KUE	LANDIS & GYR	MX	C449521	03-17-07	100.1	100.1	100.1
KUE	LANDIS & GYR	MX	C449522	03-17-07	100.0	100.2	99.9
KUE	LANDIS & GYR	MX	C449523	03-17-07	100.0	100.1	100.1
KUE	LANDIS & GYR	MX	C449524	03-17-07	100.1	100.1	100.0
KUE	LANDIS & GYR	MX	C449525	03-17-07	100.0	100.0	99.8
KUE	LANDIS & GYR	MX	C449526	03-17-07	100.0	100.0	99.9
KUE	LANDIS & GYR	MX	C449527	03-17-07	100.0	100.0	99.7
KUE	LANDIS & GYR	MX	C449528	03-17-07	100.0	100.0	100.0
KUE	LANDIS & GYR	MX	C449529	03-17-07	100.1	100.1	100.1
KUE	LANDIS & GYR	MX	C449530	03-17-07	100.1	100.1	99.9
KUE	LANDIS & GYR	MX	C449531	03-17-07	100.1	100.1	99.9
KUE	LANDIS & GYR	MX	C449532	03-17-07	100.0	99.9	100.0
KUE	LANDIS & GYR	MX	C449533	03-17-07	100.1	100.0	100.0
KUE	LANDIS & GYR	MX	C449534	03-17-07	100.0	100.1	100.2
KUE	LANDIS & GYR	MX	C449535	03-17-07	100.0	100.1	100.2
KUE	LANDIS & GYR	MX	C449536	03-17-07	100.0	100.0	99.8
KUE	LANDIS & GYR	MX	C449537	03-17-07	100.1	100.1	100.0
KUE	LANDIS & GYR	MX	C449538	03-17-07	100.0	100.0	99.9
KUE	LANDIS & GYR	MX	C449539	03-17-07	100.1	100.0	100.2
KUE	LANDIS & GYR	MX	C449540	03-17-07	100.0	100.1	99.7
KUE	LANDIS & GYR	MX	C449541	03-17-07	100.1	100.1	100.2
KUE	LANDIS & GYR	MX	C449542	03-17-07	100.1	100.1	100.0
KUE	LANDIS & GYR	MX	C449543	03-17-07	100.1	100.0	99.7
KUE	LANDIS & GYR	MX	C449544	03-17-07	100.1	100.0	99.8
KUE	LANDIS & GYR	MX	C449545	03-17-07	100.0	99.9	100.0
KUE	LANDIS & GYR	MX	C449546	03-17-07	100.0	100.1	99.8
KUE	LANDIS & GYR	MX	C449547	03-19-07	100.1	100.1	100.1
KUE	LANDIS & GYR	MX	C449548	03-17-07	100.0	100.0	100.0
KUE	LANDIS & GYR	MX	C449549	03-17-07	100.0	100.1	99.9
KUE	LANDIS & GYR	MX	C449550	03-17-07	100.0	100.0	100.0
KUE	LANDIS & GYR	MX	C449551	03-19-07	100.1	100.1	100.1
KUE	LANDIS & GYR	MX	C449552	03-17-07	100.0	100.1	100.0
KUE	LANDIS & GYR	MX	C449553	03-17-07	100.1	100.1	99.8
KUE	LANDIS & GYR	MX	C449554	03-17-07	100.0	99.9	100.3
KUE	LANDIS & GYR	MX	C449555	03-17-07	100.0	100.0	100.0
KUE	LANDIS & GYR	MX	C449556	03-17-07	100.0	99.9	99.8
KUE	LANDIS & GYR	MX	C449557	03-17-07	100.0	100.0	100.0
KUE	LANDIS & GYR	MX	C449558	03-17-07	100.1	100.1	100.1
KUE	LANDIS & GYR	MX	C449559	03-17-07	100.1	100.1	99.8

CO	MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PF FACTOR
KUE	LANDIS & GYR	MX	C449611	03-19-07	100.0	100.1	100.0
KUE	LANDIS & GYR	MX	C449612	03-19-07	100.0	100.0	100.0
KUE	LANDIS & GYR	MX	C449613	03-19-07	100.0	100.0	100.0
KUE	LANDIS & GYR	MX	C449614	03-19-07	100.1	100.0	100.3
KUE	LANDIS & GYR	MX	C449615	03-17-07	100.0	99.9	100.1
KUE	LANDIS & GYR	MX	C449616	03-19-07	100.1	100.1	100.0
KUE	LANDIS & GYR	MX	C449617	03-19-07	100.0	99.9	100.0
KUE	LANDIS & GYR	MX	C449618	03-19-07	100.1	100.1	100.1
KUE	LANDIS & GYR	MX	C449619	03-19-07	100.0	99.9	99.7
KUE	LANDIS & GYR	MX	C449620	03-19-07	100.1	100.2	100.0
KUE	LANDIS & GYR	MX	C449621	03-19-07	100.0	100.0	100.1
KUE	LANDIS & GYR	MX	C449622	03-19-07	100.0	100.1	99.9
KUE	LANDIS & GYR	MX	C449623	03-19-07	100.1	100.1	100.0
KUE	LANDIS & GYR	MX	C449624	03-19-07	100.0	100.2	99.9
KUE	LANDIS & GYR	MX	C449625	03-19-07	100.0	100.0	100.0
KUE	LANDIS & GYR	MX	C449626	03-19-07	100.1	100.0	100.1
KUE	LANDIS & GYR	MX	C449627	03-17-07	100.1	100.2	100.1
KUE	LANDIS & GYR	MX	C449628	03-17-07	100.1	100.2	100.3
KUE	LANDIS & GYR	MX	C449629	03-19-07	100.1	100.0	100.3
KUE	LANDIS & GYR	MX	C449630	03-19-07	100.0	100.0	100.0
KUE	LANDIS & GYR	MX	C449631	03-17-07	100.0	100.0	99.8
KUE	LANDIS & GYR	MX	C449632	03-19-07	100.1	99.9	100.4
KUE	LANDIS & GYR	MX	C449633	03-19-07	100.1	100.1	99.8
KUE	LANDIS & GYR	MX	C449634	03-19-07	100.1	100.1	100.1
KUE	LANDIS & GYR	MX	C449635	03-19-07	100.1	100.0	99.7
KUE	LANDIS & GYR	MX	C449636	03-19-07	100.1	100.1	100.0
KUE	LANDIS & GYR	MX	C449637	03-17-07	100.0	100.0	99.7
KUE	LANDIS & GYR	MX	C449638	03-19-07	100.1	100.0	100.1
KUE	LANDIS & GYR	MX	C449639	03-19-07	100.1	100.1	100.0
KUE	LANDIS & GYR	MX	C449640	03-19-07	100.1	100.2	100.0
KUE	LANDIS & GYR	MX	C449641	03-19-07	100.1	100.0	99.7
KUE	LANDIS & GYR	MX	C449642	03-19-07	100.1	100.0	100.1
KUE	LANDIS & GYR	MX	C449643	03-19-07	100.1	100.1	100.2
KUE	LANDIS & GYR	MX	C449644	03-19-07	100.1	99.9	100.0
KUE	LANDIS & GYR	MX	C449645	03-19-07	100.0	99.9	99.9
KUE	LANDIS & GYR	MX	C449646	03-19-07	100.1	100.0	99.9
KUE	LANDIS & GYR	MX	C449647	03-19-07	100.1	100.0	99.8
KUE	LANDIS & GYR	MX	C449648	03-19-07	100.1	100.0	99.8
KUE	LANDIS & GYR	MX	C449649	03-19-07	100.1	100.0	100.2
KUE	LANDIS & GYR	MX	C449650	03-19-07	100.0	100.0	99.9
KUE	LANDIS & GYR	MX	C449651	03-19-07	100.1	100.1	100.0
KUE	LANDIS & GYR	MX	C449652	03-19-07	100.1	100.0	100.1
KUE	LANDIS & GYR	MX	C449653	03-19-07	100.0	100.0	99.8
KUE	LANDIS & GYR	MX	C449654	03-19-07	100.1	100.0	100.2
KUE	LANDIS & GYR	MX	C449655	03-19-07	100.1	100.2	100.0
KUE	LANDIS & GYR	MX	C449656	03-19-07	100.1	100.0	100.0
KUE	LANDIS & GYR	MX	C449657	03-19-07	100.1	100.0	100.3
KUE	LANDIS & GYR	MX	C449658	03-19-07	100.1	100.0	99.8
KUE	LANDIS & GYR	MX	C449659	03-19-07	100.1	100.0	100.5
KUE	LANDIS & GYR	MX	C449660	03-19-07	100.1	100.0	99.8
KUE	LANDIS & GYR	MX	C449661	03-19-07	100.0	100.0	99.9

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

CO	MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
KUE	LANDIS	MX	C449713	03-19-07	100.0	100.0	100.1
KUE	LANDIS	MX	C449714	03-19-07	100.0	100.0	100.2
KUE	LANDIS	MX	C449715	03-19-07	100.0	100.0	99.8
KUE	LANDIS	MX	C449716	03-19-07	100.0	100.0	100.0
KUE	LANDIS	MX	C449717	03-19-07	100.0	100.0	99.5
KUE	LANDIS	MX	C449718	03-19-07	100.1	100.1	100.1
KUE	LANDIS	MX	C449719	03-19-07	100.0	100.1	100.2
KUE	LANDIS	MX	C449720	03-19-07	100.0	99.9	99.8
KUE	LANDIS	MX	C449721	03-19-07	100.0	100.0	100.1
KUE	LANDIS	MX	C449722	03-19-07	100.1	100.1	100.0
KUE	LANDIS	MX	C449723	03-19-07	100.0	100.1	99.8
KUE	LANDIS	MX	C449724	03-19-07	100.0	100.0	100.2
KUE	LANDIS	MX	C449725	03-19-07	100.1	100.0	100.0
KUE	LANDIS	MX	C449726	03-19-07	100.1	100.0	99.6
KUE	LANDIS	MX	C449727	03-19-07	100.0	100.0	100.2
KUE	LANDIS	MX	C449728	03-19-07	100.1	100.1	100.5
KUE	LANDIS	MX	C449729	03-19-07	100.1	100.1	100.0
KUE	LANDIS	MX	C449730	03-19-07	100.1	100.1	99.7
KUE	LANDIS	MX	C449731	03-19-07	100.1	100.1	99.9
KUE	LANDIS	MX	C449732	03-19-07	100.0	100.1	99.8
KUE	LANDIS	MX	C449733	03-19-07	100.0	100.0	100.1
KUE	LANDIS	MX	C449734	03-19-07	100.0	100.2	100.1
KUE	LANDIS	MX	C449735	03-19-07	99.9	100.1	100.0
KUE	LANDIS	MX	C449736	03-19-07	100.0	100.1	100.1
KUE	LANDIS	MX	C449737	03-19-07	100.0	100.0	100.1
KUE	LANDIS	MX	C449738	03-19-07	100.1	100.1	99.7
KUE	LANDIS	MX	C449739	03-19-07	100.1	100.1	100.2
KUE	LANDIS	MX	C449740	03-19-07	100.0	99.9	100.0
KUE	LANDIS	MX	C449741	03-19-07	100.1	100.1	100.1
KUE	LANDIS	MX	C449742	03-19-07	100.1	100.1	100.0
KUE	LANDIS	MX	C449743	03-19-07	100.1	100.2	100.0
KUE	LANDIS	MX	C449744	03-19-07	100.1	100.1	100.0
KUE	LANDIS	MX	C449745	03-19-07	100.0	100.1	99.9
KUE	LANDIS	MX	C449746	03-19-07	100.1	100.1	99.9
KUE	LANDIS	MX	C449747	03-19-07	100.1	99.9	100.0
KUE	LANDIS	MX	C449748	03-19-07	100.0	100.1	100.1
KUE	LANDIS	MX	C449749	03-19-07	100.0	100.0	100.1
KUE	LANDIS	MX	C449750	03-19-07	100.1	100.0	100.1
KUE	LANDIS	MX	C449751	03-19-07	100.1	99.9	99.7
KUE	LANDIS	MX	C449752	03-19-07	100.1	100.0	100.1
KUE	LANDIS	MX	C449753	03-19-07	100.1	100.0	100.0
KUE	LANDIS	MX	C449754	03-19-07	100.0	100.1	99.7
KUE	LANDIS	MX	C449755	03-19-07	100.1	100.1	100.3
KUE	LANDIS	MX	C449756	03-19-07	100.0	99.9	100.0
KUE	LANDIS	MX	C449757	03-19-07	100.1	100.1	100.1
KUE	LANDIS	MX	C449758	03-19-07	100.0	99.9	99.9
KUE	LANDIS	MX	C449759	03-19-07	100.0	100.0	99.8
KUE	LANDIS	MX	C449760	03-19-07	100.1	100.1	100.2
KUE	LANDIS	MX	C449761	03-19-07	100.0	100.1	100.1
KUE	LANDIS	MX	C449762	03-19-07	100.1	100.1	100.1
KUE	LANDIS	MX	C449763	03-19-07	100.0	100.0	100.0

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

PAGE 97
 RUN DATE: 1/15/08
 RUN TIME: 22.00.58

CO	MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
KUE	LANDIS & GYR	MX	C449815	03-17-07	100.1	100.1	100.3
KUE	LANDIS & GYR	MX	C449816	03-17-07	100.0	100.0	100.0
KUE	LANDIS & GYR	MX	C449817	03-17-07	100.0	100.0	100.2
KUE	LANDIS & GYR	MX	C449818	03-17-07	100.1	99.9	99.8
KUE	LANDIS & GYR	MX	C449819	03-17-07	100.0	100.0	99.9
KUE	LANDIS & GYR	MX	C449820	03-17-07	100.0	100.1	99.6
KUE	LANDIS & GYR	MX	C449821	03-17-07	100.1	100.1	100.1
KUE	LANDIS & GYR	MX	C449822	03-17-07	100.0	100.0	100.0
KUE	LANDIS & GYR	MX	C449823	03-17-07	100.0	100.0	100.3
KUE	LANDIS & GYR	MX	C449824	03-17-07	100.0	100.0	99.6
KUE	LANDIS & GYR	MX	C449825	03-17-07	100.1	100.1	100.1
KUE	LANDIS & GYR	MX	C449826	03-17-07	100.0	100.0	99.7
KUE	LANDIS & GYR	MX	C449827	03-17-07	100.1	100.1	99.7
KUE	LANDIS & GYR	MX	C449828	03-17-07	100.0	100.0	100.0
KUE	LANDIS & GYR	MX	C449829	03-17-07	100.1	100.2	99.8
KUE	LANDIS & GYR	MX	C449830	03-17-07	100.0	100.2	99.9
KUE	LANDIS & GYR	MX	C449831	03-17-07	100.1	100.2	100.1
KUE	LANDIS & GYR	MX	C449832	03-17-07	100.0	100.1	100.1
KUE	LANDIS & GYR	MX	C449833	03-17-07	100.0	99.9	100.2
KUE	LANDIS & GYR	MX	C449834	03-17-07	100.0	100.0	100.2
KUE	LANDIS & GYR	MX	C449835	03-17-07	100.0	100.0	99.8
KUE	LANDIS & GYR	MX	C449836	03-17-07	100.0	100.0	100.0
KUE	LANDIS & GYR	MX	C449837	03-17-07	100.0	99.9	100.1
KUE	LANDIS & GYR	MX	C449838	03-19-07	100.1	100.2	100.1
KUE	LANDIS & GYR	MX	C449839	03-17-07	100.0	99.9	99.8
KUE	LANDIS & GYR	MX	C449840	03-17-07	100.1	100.1	100.0
KUE	LANDIS & GYR	MX	C449841	03-19-07	100.0	100.1	99.9
KUE	LANDIS & GYR	MX	C449842	03-19-07	100.0	100.0	100.1
KUE	LANDIS & GYR	MX	C449843	03-19-07	100.1	100.2	100.0
KUE	LANDIS & GYR	MX	C449844	03-19-07	100.1	100.1	100.1
KUE	LANDIS & GYR	MX	C449845	03-19-07	100.0	99.9	99.9
KUE	LANDIS & GYR	MX	C449846	03-19-07	100.0	100.0	100.2
KUE	LANDIS & GYR	MX	C449847	03-19-07	100.1	100.0	99.8
KUE	LANDIS & GYR	MX	C449848	03-19-07	100.1	100.2	99.8
KUE	LANDIS & GYR	MX	C449849	03-19-07	100.1	100.2	99.9
KUE	LANDIS & GYR	MX	C449850	03-19-07	100.1	100.2	99.9
KUE	LANDIS & GYR	MX	C449851	03-19-07	100.0	100.0	100.0
KUE	LANDIS & GYR	MX	C449852	03-19-07	100.0	100.2	100.1
KUE	LANDIS & GYR	MX	C449853	03-17-07	100.0	100.0	100.1
KUE	LANDIS & GYR	MX	C449854	03-19-07	100.0	100.0	99.9
KUE	LANDIS & GYR	MX	C449855	03-19-07	100.0	100.0	100.1
KUE	LANDIS & GYR	MX	C449856	03-17-07	100.0	100.1	100.0
KUE	LANDIS & GYR	MX	C449857	03-17-07	100.1	100.0	99.9
KUE	LANDIS & GYR	MX	C449858	03-17-07	100.0	99.9	99.9
KUE	LANDIS & GYR	MX	C449859	03-17-07	100.0	100.0	99.9
KUE	LANDIS & GYR	MX	C449860	03-17-07	100.0	100.1	99.6
KUE	LANDIS & GYR	MX	C449861	03-19-07	100.1	100.0	99.9
KUE	LANDIS & GYR	MX	C449862	03-19-07	100.0	100.0	99.9
KUE	LANDIS & GYR	MX	C449863	03-19-07	100.0	100.1	99.8
KUE	LANDIS & GYR	MX	C449864	03-19-07	100.1	100.1	100.0
KUE	LANDIS & GYR	MX	C449865	03-17-07	100.1	99.9	99.8

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

CO	MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
KUE	LANDIS & GYR	MX	C449917	03-19-07	100.1	100.1	100.2
KUE	LANDIS & GYR	MX	C449918	03-19-07	100.0	100.0	99.9
KUE	LANDIS & GYR	MX	C449919	03-19-07	100.0	100.0	100.0
KUE	LANDIS & GYR	MX	C449920	03-19-07	100.1	100.2	100.4
KUE	LANDIS & GYR	MX	C449921	03-19-07	100.1	100.1	99.9
KUE	LANDIS & GYR	MX	C449922	03-19-07	100.1	100.1	100.3
KUE	LANDIS & GYR	MX	C449923	03-19-07	100.1	100.0	100.2
KUE	LANDIS & GYR	MX	C449924	03-19-07	100.1	100.0	100.1
KUE	LANDIS & GYR	MX	C449925	03-19-07	100.0	100.0	100.0
KUE	LANDIS & GYR	MX	C449926	03-19-07	100.0	100.0	99.8
KUE	LANDIS & GYR	MX	C449927	03-19-07	100.1	100.1	100.0
KUE	LANDIS & GYR	MX	C449928	03-19-07	100.1	100.1	100.1
KUE	LANDIS & GYR	MX	C449929	03-19-07	100.0	100.0	99.9
KUE	LANDIS & GYR	MX	C449930	03-19-07	100.1	100.0	100.2
KUE	LANDIS & GYR	MX	C449931	03-19-07	100.1	100.0	100.0
KUE	LANDIS & GYR	MX	C449932	03-19-07	100.0	100.0	99.8
KUE	LANDIS & GYR	MX	C449933	03-19-07	100.0	100.0	100.0
KUE	LANDIS & GYR	MX	C449934	03-19-07	100.1	100.0	100.3
KUE	LANDIS & GYR	MX	C449935	03-19-07	100.0	100.0	100.0
KUE	LANDIS & GYR	MX	C449936	03-19-07	100.1	100.0	100.1
KUE	LANDIS & GYR	MX	C449937	03-19-07	100.1	100.0	100.1
KUE	LANDIS & GYR	MX	C449938	03-19-07	100.0	100.0	100.2
KUE	LANDIS & GYR	MX	C449939	03-19-07	99.9	99.9	100.1
KUE	LANDIS & GYR	MX	C449940	03-19-07	100.1	100.1	100.3
KUE	LANDIS & GYR	MX	C449941	03-19-07	100.0	100.1	100.1
KUE	LANDIS & GYR	MX	C449942	03-17-07	100.1	100.0	100.0
KUE	LANDIS & GYR	MX	C449943	03-19-07	100.1	100.2	100.0
KUE	LANDIS & GYR	MX	C449944	03-19-07	100.0	99.9	100.0
KUE	LANDIS & GYR	MX	C449945	03-19-07	100.0	99.9	99.9
KUE	LANDIS & GYR	MX	C449946	03-19-07	100.0	99.9	99.9
KUE	LANDIS & GYR	MX	C449947	03-19-07	100.1	100.1	100.1
KUE	LANDIS & GYR	MX	C449948	03-19-07	100.1	100.2	100.0
KUE	LANDIS & GYR	MX	C449949	03-19-07	100.1	100.2	100.0
KUE	LANDIS & GYR	MX	C449950	03-19-07	100.1	100.1	99.7
KUE	LANDIS & GYR	MX	C449951	03-19-07	100.1	100.1	99.9
KUE	LANDIS & GYR	MX	C449952	03-19-07	100.1	99.9	99.9
KUE	LANDIS & GYR	MX	C449953	03-19-07	100.0	100.0	99.8
KUE	LANDIS & GYR	MX	C449954	03-19-07	100.1	100.1	100.3
KUE	LANDIS & GYR	MX	C449955	03-19-07	99.9	100.0	99.9
KUE	LANDIS & GYR	MX	C449956	03-19-07	100.0	99.9	99.9
KUE	LANDIS & GYR	MX	C449957	03-19-07	100.0	100.2	100.2
KUE	LANDIS & GYR	MX	C449958	03-19-07	100.1	100.2	100.2
KUE	LANDIS & GYR	MX	C449959	03-19-07	100.0	100.0	100.2
KUE	LANDIS & GYR	MX	C449960	03-19-07	100.1	100.2	100.2
KUE	LANDIS & GYR	MX	C449961	03-19-07	100.0	100.1	99.8
KUE	LANDIS & GYR	MX	C449962	03-19-07	100.0	100.1	100.1
KUE	LANDIS & GYR	MX	C449963	03-19-07	100.1	100.1	100.3
KUE	LANDIS & GYR	MX	C449964	03-19-07	100.1	100.1	100.0
KUE	LANDIS & GYR	MX	C449965	03-19-07	100.0	100.0	100.0
KUE	LANDIS & GYR	MX	C449966	03-19-07	100.1	100.2	100.0
KUE	LANDIS & GYR	MX	C449967	03-19-07	100.0	100.0	100.1

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

CO	MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
KUE	LANDIS & GYR	MX	C450019	03-19-07	100.0	100.1	100.0
KUE	LANDIS & GYR	MX	C450020	03-19-07	100.1	100.2	99.8
KUE	LANDIS & GYR	MX	C450021	03-19-07	100.1	100.1	99.9
KUE	LANDIS & GYR	MX	C450022	03-19-07	100.0	100.1	99.9
KUE	LANDIS & GYR	MX	C450023	03-19-07	100.0	100.1	100.3
KUE	LANDIS & GYR	MX	C450024	03-19-07	100.1	100.1	100.1
KUE	LANDIS & GYR	MX	C450025	03-19-07	100.0	100.0	100.1
KUE	LANDIS & GYR	MX	C450026	03-19-07	100.1	100.2	99.9
KUE	LANDIS & GYR	MX	C450027	03-19-07	100.0	100.0	100.1
KUE	LANDIS & GYR	MX	C450028	03-19-07	100.0	100.1	100.0
KUE	LANDIS & GYR	MX	C450029	03-19-07	100.0	100.0	99.8
KUE	LANDIS & GYR	MX	C450030	03-19-07	100.0	100.0	99.5
KUE	LANDIS & GYR	MX	C450031	03-19-07	100.1	100.1	99.9
KUE	LANDIS & GYR	MX	C450032	03-19-07	100.0	100.1	99.8
KUE	LANDIS & GYR	MX	C450033	03-19-07	100.0	99.9	100.1
KUE	LANDIS & GYR	MX	C450034	03-19-07	100.0	100.0	100.1
KUE	LANDIS & GYR	MX	C450035	03-19-07	100.1	100.1	100.0
KUE	LANDIS & GYR	MX	C450036	03-19-07	100.0	99.9	99.9
KUE	LANDIS & GYR	MX	C450037	03-19-07	100.0	100.0	99.9
KUE	LANDIS & GYR	MX	C450038	03-19-07	100.0	100.0	100.0
KUE	LANDIS & GYR	MX	C450039	03-19-07	100.0	99.9	100.0
KUE	LANDIS & GYR	MX	C450040	03-19-07	100.1	100.0	100.0
KUE	LANDIS & GYR	MX	C450041	03-19-07	100.0	100.1	99.9
KUE	LANDIS & GYR	MX	C450042	03-19-07	100.0	100.1	99.9
KUE	LANDIS & GYR	MX	C450043	03-19-07	100.0	100.0	99.9
KUE	LANDIS & GYR	MX	C450044	03-19-07	100.1	100.0	99.8
KUE	LANDIS & GYR	MX	C450045	03-19-07	100.1	100.1	100.1
KUE	LANDIS & GYR	MX	C450046	03-19-07	100.0	100.0	99.9
KUE	LANDIS & GYR	MX	C450047	03-19-07	100.0	100.0	100.0
KUE	LANDIS & GYR	MX	C450048	03-19-07	100.1	100.0	100.1
KUE	LANDIS & GYR	MX	C450049	03-19-07	100.1	100.2	99.5
KUE	LANDIS & GYR	MX	C450050	03-19-07	100.1	100.0	100.0
KUE	LANDIS & GYR	MX	C450051	03-19-07	100.1	99.9	99.9
KUE	LANDIS & GYR	MX	C450052	03-19-07	100.0	100.0	99.7
KUE	LANDIS & GYR	MX	C450053	03-19-07	100.1	100.1	99.9
KUE	LANDIS & GYR	MX	C450054	03-19-07	100.1	100.2	100.0
KUE	LANDIS & GYR	MX	C450055	03-19-07	100.1	100.1	99.9
KUE	LANDIS & GYR	MX	C450056	03-19-07	100.0	100.0	100.0
KUE	LANDIS & GYR	MX	C450057	03-19-07	100.0	100.1	99.6
KUE	LANDIS & GYR	MX	C450058	03-19-07	100.1	100.1	99.9
KUE	LANDIS & GYR	MX	C450059	03-19-07	100.0	99.9	99.8
KUE	LANDIS & GYR	MX	C450060	03-19-07	100.0	100.0	100.0
KUE	LANDIS & GYR	MX	C450061	03-19-07	100.1	100.1	99.9
KUE	LANDIS & GYR	MX	C450062	03-19-07	100.0	100.1	100.3
KUE	LANDIS & GYR	MX	C450063	03-19-07	100.0	99.9	99.6
KUE	LANDIS & GYR	MX	C450064	03-19-07	100.1	100.0	99.8
KUE	LANDIS & GYR	MX	C450065	03-19-07	100.1	99.9	100.2
KUE	LANDIS & GYR	MX	C450066	03-19-07	100.1	100.1	100.1
KUE	LANDIS & GYR	MX	C450067	03-19-07	100.0	100.0	99.9
KUE	LANDIS & GYR	MX	C450068	03-19-07	100.0	100.1	99.9
KUE	LANDIS & GYR	MX	C450069	03-19-07	100.0	100.0	99.7

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

CO	MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
KUE	LANDIS & GYR	MX	C450121	03-19-07	100.0	100.0	100.1
KUE	LANDIS & GYR	MX	C450122	03-19-07	100.1	100.2	100.0
KUE	LANDIS & GYR	MX	C450123	03-19-07	100.1	100.0	99.9
KUE	LANDIS & GYR	MX	C450124	03-19-07	100.0	99.9	99.8
KUE	LANDIS & GYR	MX	C450125	03-19-07	100.0	100.1	100.1
KUE	LANDIS & GYR	MX	C450126	03-19-07	100.0	100.0	100.1
KUE	LANDIS & GYR	MX	C450127	03-19-07	100.0	100.0	99.8
KUE	LANDIS & GYR	MX	C450128	03-19-07	100.0	100.1	100.1
KUE	LANDIS & GYR	MX	C450129	03-19-07	100.1	100.0	99.9
KUE	LANDIS & GYR	MX	C450130	03-19-07	100.1	100.0	100.0
KUE	LANDIS & GYR	MX	C450131	03-19-07	100.0	100.1	99.8
KUE	LANDIS & GYR	MX	C450132	03-19-07	100.0	100.0	99.9
KUE	LANDIS & GYR	MX	C450133	03-19-07	100.1	100.0	99.9
KUE	LANDIS & GYR	MX	C450134	03-19-07	100.0	100.0	99.6
KUE	LANDIS & GYR	MX	C450135	03-19-07	100.0	99.9	100.0
KUE	LANDIS & GYR	MX	C450136	03-19-07	100.0	100.0	100.0
KUE	LANDIS & GYR	MX	C450137	03-19-07	100.1	100.2	100.0
KUE	LANDIS & GYR	MX	C450138	03-19-07	100.1	100.1	100.0
KUE	LANDIS & GYR	MX	C450139	03-19-07	100.0	100.1	100.1
KUE	LANDIS & GYR	MX	C450140	03-19-07	100.1	100.1	99.9
KUE	LANDIS & GYR	MX	C450141	03-19-07	100.1	100.1	100.0
KUE	LANDIS & GYR	MX	C450142	03-19-07	100.0	100.1	100.0
KUE	LANDIS & GYR	MX	C450143	03-19-07	100.1	100.0	99.9
KUE	LANDIS & GYR	MX	C450144	03-19-07	100.0	100.0	100.0
KUE	LANDIS & GYR	MX	C450145	03-19-07	100.1	100.0	100.0
KUE	LANDIS & GYR	MX	C450146	03-19-07	100.1	100.2	99.9
KUE	LANDIS & GYR	MX	C450147	03-19-07	100.0	99.9	99.8
KUE	LANDIS & GYR	MX	C450148	03-19-07	100.1	100.0	100.0
KUE	LANDIS & GYR	MX	C450149	03-19-07	100.1	100.0	99.6
KUE	LANDIS & GYR	MX	C450150	03-19-07	100.1	100.0	100.2
KUE	LANDIS & GYR	MX	C450151	03-19-07	100.1	100.0	100.0
KUE	LANDIS & GYR	MX	C450152	03-19-07	100.1	100.2	100.0
KUE	LANDIS & GYR	MX	C450153	03-19-07	100.0	100.0	99.7
KUE	LANDIS & GYR	MX	C450154	03-19-07	100.1	100.0	100.0
KUE	LANDIS & GYR	MX	C450155	03-19-07	100.1	100.1	99.5
KUE	LANDIS & GYR	MX	C450156	03-19-07	100.0	100.0	99.5
KUE	LANDIS & GYR	MX	C450157	03-19-07	100.1	100.2	100.0
KUE	LANDIS & GYR	MX	C450158	03-19-07	100.0	100.0	99.9
KUE	LANDIS & GYR	MX	C450159	03-19-07	100.0	100.0	99.9
KUE	LANDIS & GYR	MX	C450160	03-19-07	100.1	100.0	100.3
KUE	LANDIS & GYR	MX	C450161	03-19-07	100.0	100.0	100.1
KUE	LANDIS & GYR	MX	C450162	03-19-07	100.0	100.1	100.1
KUE	LANDIS & GYR	MX	C450163	03-19-07	100.0	100.0	99.9
KUE	LANDIS & GYR	MX	C450164	03-19-07	100.1	100.0	99.9
KUE	LANDIS & GYR	MX	C450165	03-19-07	100.1	100.1	100.1
KUE	LANDIS & GYR	MX	C450166	03-19-07	100.0	100.0	100.1
KUE	LANDIS & GYR	MX	C450167	03-19-07	100.1	100.1	100.0
KUE	LANDIS & GYR	MX	C450168	03-19-07	100.0	99.9	100.0
KUE	LANDIS & GYR	MX	C450169	03-19-07	100.1	100.1	99.7
KUE	LANDIS & GYR	MX	C450170	03-19-07	100.1	100.1	99.9
KUE	LANDIS & GYR	MX	C450171	03-19-07	100.1	100.1	99.9

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

CO	MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
KUE	LANDIS & GYR	MX	C450223	05-17-07	100.1	100.1	99.8
KUE	LANDIS & GYR	MX	C450224	05-17-07	100.0	100.1	100.0
KUE	LANDIS & GYR	MX	C450225	05-17-07	100.1	100.1	100.3
KUE	LANDIS & GYR	MX	C450226	05-17-07	100.0	100.1	99.9
KUE	LANDIS & GYR	MX	C450227	05-17-07	100.1	100.0	100.1
KUE	LANDIS & GYR	MX	C450228	05-17-07	100.0	100.0	99.9
KUE	LANDIS & GYR	MX	C450229	05-17-07	100.0	99.9	100.2
KUE	LANDIS & GYR	MX	C450230	05-17-07	100.1	100.1	100.3
KUE	LANDIS & GYR	MX	C450231	05-17-07	100.1	100.1	99.9
KUE	LANDIS & GYR	MX	C450232	05-17-07	100.1	100.1	99.9
KUE	LANDIS & GYR	MX	C450233	05-17-07	100.0	100.0	100.2
KUE	LANDIS & GYR	MX	C450234	05-17-07	100.1	100.2	99.9
KUE	LANDIS & GYR	MX	C450235	05-17-07	100.1	100.2	100.3
KUE	LANDIS & GYR	MX	C450236	05-17-07	100.1	100.1	100.1
KUE	LANDIS & GYR	MX	C450237	05-16-07	100.0	99.9	99.8
KUE	LANDIS & GYR	MX	C450238	05-17-07	100.1	100.1	100.1
KUE	LANDIS & GYR	MX	C450239	05-17-07	100.0	100.1	99.9
KUE	LANDIS & GYR	MX	C450240	05-17-07	100.0	100.0	99.5
KUE	LANDIS & GYR	MX	C450241	05-16-07	100.0	100.0	100.1
KUE	LANDIS & GYR	MX	C450242	05-17-07	100.1	99.9	100.0
KUE	LANDIS & GYR	MX	C450243	05-17-07	100.0	99.9	99.9
KUE	LANDIS & GYR	MX	C450244	05-17-07	100.1	99.9	100.0
KUE	LANDIS & GYR	MX	C450245	05-17-07	100.0	99.9	100.0
KUE	LANDIS & GYR	MX	C450246	05-17-07	100.0	100.1	99.9
KUE	LANDIS & GYR	MX	C450247	05-17-07	100.1	100.0	100.5
KUE	LANDIS & GYR	MX	C450248	05-17-07	100.1	100.2	99.7
KUE	LANDIS & GYR	MX	C450249	05-17-07	100.1	100.1	99.9
KUE	LANDIS & GYR	MX	C450250	05-17-07	100.0	100.1	100.0
KUE	LANDIS & GYR	MX	C450251	05-17-07	100.0	100.0	100.0
KUE	LANDIS & GYR	MX	C450252	05-17-07	100.0	100.1	100.0
KUE	LANDIS & GYR	MX	C450253	05-17-07	100.0	100.0	100.0
KUE	LANDIS & GYR	MX	C450254	05-17-07	100.1	100.0	100.2
KUE	LANDIS & GYR	MX	C450255	05-17-07	100.1	100.0	100.0
KUE	LANDIS & GYR	MX	C450256	05-17-07	100.0	100.1	99.9
KUE	LANDIS & GYR	MX	C450257	05-17-07	100.1	100.0	100.0
KUE	LANDIS & GYR	MX	C450258	05-17-07	100.1	99.9	100.2
KUE	LANDIS & GYR	MX	C450259	05-17-07	100.1	100.0	100.0
KUE	LANDIS & GYR	MX	C450260	05-17-07	100.1	100.0	100.0
KUE	LANDIS & GYR	MX	C450261	05-17-07	100.1	100.1	100.1
KUE	LANDIS & GYR	MX	C450262	05-17-07	100.1	100.1	100.3
KUE	LANDIS & GYR	MX	C450263	05-17-07	100.0	100.0	99.9
KUE	LANDIS & GYR	MX	C450264	05-16-07	100.0	100.2	99.9
KUE	LANDIS & GYR	MX	C450265	05-16-07	100.1	100.1	99.9
KUE	LANDIS & GYR	MX	C450266	05-17-07	100.0	100.0	100.0
KUE	LANDIS & GYR	MX	C450267	05-17-07	100.1	100.1	99.8
KUE	LANDIS & GYR	MX	C450268	05-17-07	100.0	100.0	99.9
KUE	LANDIS & GYR	MX	C450269	05-17-07	100.1	100.1	100.1
KUE	LANDIS & GYR	MX	C450270	05-16-07	100.0	99.9	99.6
KUE	LANDIS & GYR	MX	C450271	05-17-07	100.0	100.2	100.1
KUE	LANDIS & GYR	MX	C450272	05-17-07	100.1	99.9	100.0
KUE	LANDIS & GYR	MX	C450273	05-17-07	100.0	100.1	100.2

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

CO	MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
KUE	LANDIS & GYR	MX	C450325	05-17-07	100.0	100.0	99.8
KUE	LANDIS & GYR	MX	C450326	05-17-07	100.0	100.1	100.1
KUE	LANDIS & GYR	MX	C450327	05-17-07	100.0	100.0	99.8
KUE	LANDIS & GYR	MX	C450328	05-17-07	100.1	100.1	100.1
KUE	LANDIS & GYR	MX	C450329	05-17-07	100.1	100.1	100.1
KUE	LANDIS & GYR	MX	C450330	05-17-07	100.0	99.9	99.8
KUE	LANDIS & GYR	MX	C450331	05-17-07	100.1	99.9	99.9
KUE	LANDIS & GYR	MX	C450332	05-17-07	100.0	100.0	100.0
KUE	LANDIS & GYR	MX	C450333	05-17-07	100.1	100.0	100.0
KUE	LANDIS & GYR	MX	C450334	05-17-07	100.1	100.0	100.2
KUE	LANDIS & GYR	MX	C450335	05-17-07	100.0	99.9	100.0
KUE	LANDIS & GYR	MX	C450336	05-17-07	100.0	100.1	100.1
KUE	LANDIS & GYR	MX	C450337	05-17-07	100.0	99.9	99.8
KUE	LANDIS & GYR	MX	C450338	05-17-07	100.0	100.0	100.2
KUE	LANDIS & GYR	MX	C450339	05-17-07	100.0	100.0	100.1
KUE	LANDIS & GYR	MX	C450340	05-17-07	100.1	100.1	99.8
KUE	LANDIS & GYR	MX	C450341	05-17-07	100.0	100.0	100.1
KUE	LANDIS & GYR	MX	C450342	05-17-07	100.0	99.9	99.8
KUE	LANDIS & GYR	MX	C450343	05-17-07	100.0	100.0	100.1
KUE	LANDIS & GYR	MX	C450344	05-17-07	100.0	100.0	100.0
KUE	LANDIS & GYR	MX	C450345	05-17-07	100.0	100.0	99.9
KUE	LANDIS & GYR	MX	C450346	05-17-07	100.0	99.9	100.3
KUE	LANDIS & GYR	MX	C450347	05-17-07	100.1	99.9	99.6
KUE	LANDIS & GYR	MX	C450348	05-17-07	100.1	100.2	100.0
KUE	LANDIS & GYR	MX	C450349	05-17-07	100.1	100.1	100.1
KUE	LANDIS & GYR	MX	C450350	05-17-07	100.1	100.0	100.2
KUE	LANDIS & GYR	MX	C450351	05-17-07	100.1	100.0	100.2
KUE	LANDIS & GYR	MX	C450352	05-17-07	100.1	100.1	99.6
KUE	LANDIS & GYR	MX	C450353	05-17-07	100.1	100.0	99.9
KUE	LANDIS & GYR	MX	C450354	05-17-07	100.1	100.1	100.3
KUE	LANDIS & GYR	MX	C450355	05-17-07	100.0	100.0	100.2
KUE	LANDIS & GYR	MX	C450356	05-17-07	100.1	100.1	99.8
KUE	LANDIS & GYR	MX	C450357	05-17-07	100.1	100.1	100.4
KUE	LANDIS & GYR	MX	C450358	05-17-07	100.0	100.1	100.1
KUE	LANDIS & GYR	MX	C450359	05-17-07	100.0	99.9	99.8
KUE	LANDIS & GYR	MX	C450360	05-17-07	100.0	100.1	99.9
KUE	LANDIS & GYR	MX	C450361	05-17-07	100.0	100.0	99.9
KUE	LANDIS & GYR	MX	C450362	05-17-07	100.1	99.9	99.2
KUE	LANDIS & GYR	MX	C450363	05-16-07	100.1	100.0	100.1
KUE	LANDIS & GYR	MX	C450364	05-17-07	100.0	100.1	100.2
KUE	LANDIS & GYR	MX	C450365	05-17-07	100.0	100.1	99.8
KUE	LANDIS & GYR	MX	C450366	05-17-07	100.1	100.0	99.9
KUE	LANDIS & GYR	MX	C450367	05-17-07	100.1	100.1	99.9
KUE	LANDIS & GYR	MX	C450368	05-17-07	100.1	100.0	100.6
KUE	LANDIS & GYR	MX	C450369	05-17-07	100.1	100.0	99.9
KUE	LANDIS & GYR	MX	C450370	05-17-07	100.0	100.0	100.2
KUE	LANDIS & GYR	MX	C450371	05-17-07	100.0	100.1	100.0
KUE	LANDIS & GYR	MX	C450372	05-17-07	100.1	100.0	100.3
KUE	LANDIS & GYR	MX	C450373	05-17-07	100.0	100.0	100.1
KUE	LANDIS & GYR	MX	C450374	05-17-07	100.1	100.0	100.1
KUE	LANDIS & GYR	MX	C450375	05-17-07	100.0	100.0	100.2

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

CO	MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
KUE	LANDIS & GYR	MX	C450427	05-17-07	100.1	100.1	99.9
KUE	LANDIS & GYR	MX	C450428	05-16-07	100.0	100.2	99.8
KUE	LANDIS & GYR	MX	C450429	05-17-07	100.0	100.0	100.0
KUE	LANDIS & GYR	MX	C450430	05-17-07	100.1	100.0	100.0
KUE	LANDIS & GYR	MX	C450431	05-16-07	100.0	100.1	100.1
KUE	LANDIS & GYR	MX	C450432	05-16-07	100.0	100.0	100.0
KUE	LANDIS & GYR	MX	C450433	05-17-07	100.0	100.0	100.3
KUE	LANDIS & GYR	MX	C450434	05-17-07	100.1	100.0	100.3
KUE	LANDIS & GYR	MX	C450435	05-17-07	100.1	100.1	99.9
KUE	LANDIS & GYR	MX	C450436	05-17-07	100.0	100.1	100.3
KUE	LANDIS & GYR	MX	C450437	05-17-07	100.0	100.2	100.3
KUE	LANDIS & GYR	MX	C450438	05-17-07	100.1	100.1	100.1
KUE	LANDIS & GYR	MX	C450439	05-17-07	100.0	100.0	100.3
KUE	LANDIS & GYR	MX	C450440	05-17-07	100.1	100.2	100.1
KUE	LANDIS & GYR	MX	C450441	05-17-07	100.0	100.0	100.1
KUE	LANDIS & GYR	MX	C450442	05-17-07	100.1	100.1	99.9
KUE	LANDIS & GYR	MX	C450443	05-17-07	100.0	100.0	100.0
KUE	LANDIS & GYR	MX	C450444	05-17-07	100.0	100.0	99.9
KUE	LANDIS & GYR	MX	C450445	05-17-07	100.0	100.0	100.2
KUE	LANDIS & GYR	MX	C450446	05-17-07	100.1	100.2	100.2
KUE	LANDIS & GYR	MX	C450447	05-17-07	100.0	100.2	100.1
KUE	LANDIS & GYR	MX	C450448	05-17-07	100.0	100.1	100.0
KUE	LANDIS & GYR	MX	C450449	05-17-07	100.1	100.1	100.3
KUE	LANDIS & GYR	MX	C450450	05-17-07	100.0	100.0	100.0
KUE	LANDIS & GYR	MX	C450451	05-17-07	100.0	100.2	100.1
KUE	LANDIS & GYR	MX	C450452	05-17-07	100.0	100.1	99.9
KUE	LANDIS & GYR	MX	C450453	05-17-07	100.1	100.0	100.0
KUE	LANDIS & GYR	MX	C450454	05-17-07	100.1	100.1	100.3
KUE	LANDIS & GYR	MX	C450455	05-17-07	100.0	100.0	99.9
KUE	LANDIS & GYR	MX	C450456	05-17-07	100.0	100.0	100.5
KUE	LANDIS & GYR	MX	C450457	05-17-07	100.1	100.1	100.2
KUE	LANDIS & GYR	MX	C450458	05-17-07	100.1	99.9	100.3
KUE	LANDIS & GYR	MX	C450459	05-17-07	100.1	100.1	99.9
KUE	LANDIS & GYR	MX	C450460	05-17-07	100.1	100.0	100.3
KUE	LANDIS & GYR	MX	C450461	05-17-07	100.0	100.0	100.2
KUE	LANDIS & GYR	MX	C450462	05-17-07	100.1	100.2	100.1
KUE	LANDIS & GYR	MX	C450463	05-17-07	100.1	100.0	100.1
KUE	LANDIS & GYR	MX	C450464	05-17-07	100.0	100.0	100.1
KUE	LANDIS & GYR	MX	C450465	05-17-07	100.0	99.9	100.1
KUE	LANDIS & GYR	MX	C450466	05-17-07	100.1	100.1	100.0
KUE	LANDIS & GYR	MX	C450467	05-17-07	100.0	99.9	100.1
KUE	LANDIS & GYR	MX	C450468	05-17-07	100.1	100.1	100.3
KUE	LANDIS & GYR	MX	C450469	05-17-07	100.1	100.1	99.8
KUE	LANDIS & GYR	MX	C450470	05-17-07	100.1	100.2	100.2
KUE	LANDIS & GYR	MX	C450471	05-17-07	100.1	100.1	100.0
KUE	LANDIS & GYR	MX	C450472	05-17-07	100.1	100.2	100.2
KUE	LANDIS & GYR	MX	C450473	05-17-07	100.0	100.0	100.0
KUE	LANDIS & GYR	MX	C450474	05-17-07	100.0	100.1	100.1
KUE	LANDIS & GYR	MX	C450475	05-17-07	100.0	100.0	100.3
KUE	LANDIS & GYR	MX	C450476	05-17-07	100.0	100.1	100.1
KUE	LANDIS & GYR	MX	C450477	05-17-07	100.1	100.1	100.0

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

PAGE 111
 RUN DATE: 1/15/08
 RUN TIME: 22.00.58

CO	MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
KUE	LANDIS & GYR	MX	C450529	05-17-07	100.1	99.9	100.2
KUE	LANDIS & GYR	MX	C450530	05-16-07	100.0	100.1	99.9
KUE	LANDIS & GYR	MX	C450531	05-17-07	100.1	100.2	100.1
KUE	LANDIS & GYR	MX	C450532	05-17-07	100.1	100.2	99.7
KUE	LANDIS & GYR	MX	C450533	05-17-07	100.1	100.2	100.3
KUE	LANDIS & GYR	MX	C450534	05-17-07	100.1	100.2	100.3
KUE	LANDIS & GYR	MX	C450535	05-17-07	100.1	100.2	100.3
KUE	LANDIS & GYR	MX	C450536	05-17-07	100.0	100.1	100.3
KUE	LANDIS & GYR	MX	C450537	05-17-07	100.1	100.0	99.5
KUE	LANDIS & GYR	MX	C450538	05-17-07	100.0	100.1	99.9
KUE	LANDIS & GYR	MX	C450539	05-17-07	100.1	100.2	100.1
KUE	LANDIS & GYR	MX	C450540	05-17-07	100.0	100.0	99.7
KUE	LANDIS & GYR	MX	C450541	05-17-07	100.0	100.1	99.8
KUE	LANDIS & GYR	MX	C450542	05-17-07	100.0	100.1	99.8
KUE	LANDIS & GYR	MX	C450543	05-17-07	100.0	99.9	100.0
KUE	LANDIS & GYR	MX	C450544	05-16-07	100.1	100.0	100.0
KUE	LANDIS & GYR	MX	C450545	05-17-07	100.0	100.0	100.1
KUE	LANDIS & GYR	MX	C450546	05-17-07	100.0	99.9	99.9
KUE	LANDIS & GYR	MX	C450547	05-16-07	100.0	100.1	99.8
KUE	LANDIS & GYR	MX	C450548	05-17-07	100.0	100.0	99.7
KUE	LANDIS & GYR	MX	C450549	05-17-07	100.1	100.1	100.1
KUE	LANDIS & GYR	MX	C450550	05-17-07	100.0	100.2	99.8
KUE	LANDIS & GYR	MX	C450551	05-17-07	100.0	100.1	100.1
KUE	LANDIS & GYR	MX	C450552	05-17-07	100.1	100.0	100.2
KUE	LANDIS & GYR	MX	C450553	05-17-07	100.0	100.0	99.9
KUE	LANDIS & GYR	MX	C450554	05-17-07	100.0	100.1	99.6
KUE	LANDIS & GYR	MX	C450555	05-17-07	100.0	100.1	100.1
KUE	LANDIS & GYR	MX	C450556	05-17-07	100.0	100.1	100.0
KUE	LANDIS & GYR	MX	C450557	05-17-07	100.0	100.1	100.1
KUE	LANDIS & GYR	MX	C450558	05-16-07	100.0	100.0	99.7
KUE	LANDIS & GYR	MX	C450559	05-17-07	100.1	100.1	100.1
KUE	LANDIS & GYR	MX	C450560	05-17-07	100.0	99.9	100.1
KUE	LANDIS & GYR	MX	C450561	05-17-07	100.1	99.9	100.0
KUE	LANDIS & GYR	MX	C450562	05-17-07	100.1	100.0	100.1
KUE	LANDIS & GYR	MX	C450563	05-17-07	100.0	100.0	99.9
KUE	LANDIS & GYR	MX	C450564	05-17-07	99.9	100.1	99.8
KUE	LANDIS & GYR	MX	C450565	05-17-07	100.0	100.0	100.2
KUE	LANDIS & GYR	MX	C450566	05-17-07	100.0	100.1	100.1
KUE	LANDIS & GYR	MX	C450567	05-17-07	100.0	100.0	100.1
KUE	LANDIS & GYR	MX	C450568	05-17-07	100.0	100.0	100.0
KUE	LANDIS & GYR	MX	C450569	05-17-07	100.0	100.1	100.0
KUE	LANDIS & GYR	MX	C450570	05-17-07	100.0	100.1	99.7
KUE	LANDIS & GYR	MX	C450571	05-17-07	100.0	100.0	99.7
KUE	LANDIS & GYR	MX	C450572	05-17-07	100.1	100.1	100.1
KUE	LANDIS & GYR	MX	C450573	05-17-07	100.1	100.0	100.0
KUE	LANDIS & GYR	MX	C450574	05-17-07	100.1	100.0	100.0
KUE	LANDIS & GYR	MX	C450575	05-17-07	100.0	99.9	100.0
KUE	LANDIS & GYR	MX	C450576	05-17-07	100.0	100.0	100.1
KUE	LANDIS & GYR	MX	C450577	05-17-07	100.0	100.0	100.1
KUE	LANDIS & GYR	MX	C450578	05-17-07	100.1	100.0	100.1
KUE	LANDIS & GYR	MX	C450579	05-17-07	100.1	100.2	100.1

CO	MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
KUE	LANDIS & GYR	MX	C450631	05-17-07	100.0	100.1	100.0
KUE	LANDIS & GYR	MX	C450632	05-17-07	100.0	100.1	99.8
KUE	LANDIS & GYR	MX	C450633	05-17-07	100.0	99.9	100.2
KUE	LANDIS & GYR	MX	C450634	05-17-07	100.0	100.0	99.5
KUE	LANDIS & GYR	MX	C450635	05-17-07	100.0	100.0	100.0
KUE	LANDIS & GYR	MX	C450636	05-17-07	100.1	99.9	99.9
KUE	LANDIS & GYR	MX	C450637	05-16-07	100.0	100.1	100.2
KUE	LANDIS & GYR	MX	C450638	05-17-07	100.0	100.0	99.9
KUE	LANDIS & GYR	MX	C450639	05-17-07	100.0	100.0	100.1
KUE	LANDIS & GYR	MX	C450640	05-17-07	100.1	100.1	100.2
KUE	LANDIS & GYR	MX	C450641	05-17-07	100.1	100.1	100.3
KUE	LANDIS & GYR	MX	C450642	05-17-07	100.1	100.0	100.3
KUE	LANDIS & GYR	MX	C450643	05-17-07	100.0	100.0	99.9
KUE	LANDIS & GYR	MX	C450644	05-17-07	100.0	100.0	99.6
KUE	LANDIS & GYR	MX	C450645	05-17-07	100.0	100.0	99.8
KUE	LANDIS & GYR	MX	C450646	05-17-07	100.1	100.0	100.0
KUE	LANDIS & GYR	MX	C450647	05-17-07	100.1	100.1	100.1
KUE	LANDIS & GYR	MX	C450648	05-17-07	100.1	100.1	99.6
KUE	LANDIS & GYR	MX	C450649	05-17-07	100.1	100.1	99.9
KUE	LANDIS & GYR	MX	C450650	05-17-07	100.1	100.1	100.0
KUE	LANDIS & GYR	MX	C450651	05-17-07	100.1	100.1	99.9
KUE	LANDIS & GYR	MX	C450652	05-17-07	100.0	99.9	99.5
KUE	LANDIS & GYR	MX	C450653	05-17-07	100.0	100.0	100.4
KUE	LANDIS & GYR	MX	C450654	05-17-07	100.1	100.1	100.2
KUE	LANDIS & GYR	MX	C450655	05-17-07	100.0	100.1	100.1
KUE	LANDIS & GYR	MX	C450656	05-17-07	100.0	99.9	100.2
KUE	LANDIS & GYR	MX	C450657	05-17-07	100.0	100.0	99.7
KUE	LANDIS & GYR	MX	C450658	05-17-07	100.1	100.0	99.9
KUE	LANDIS & GYR	MX	C450659	05-17-07	100.1	100.1	100.0
KUE	LANDIS & GYR	MX	C450660	05-17-07	100.1	100.1	99.8
KUE	LANDIS & GYR	MX	C450661	05-17-07	100.0	100.0	99.8
KUE	LANDIS & GYR	MX	C450662	05-17-07	100.0	100.0	100.0
KUE	LANDIS & GYR	MX	C450663	05-17-07	100.0	100.1	99.8
KUE	LANDIS & GYR	MX	C450664	05-17-07	100.0	100.2	99.5
KUE	LANDIS & GYR	MX	C450665	05-17-07	100.1	99.9	99.5
KUE	LANDIS & GYR	MX	C450666	05-17-07	100.1	100.1	100.1
KUE	LANDIS & GYR	MX	C450667	05-17-07	100.0	100.2	99.8
KUE	LANDIS & GYR	MX	C450668	05-17-07	100.0	100.1	100.1
KUE	LANDIS & GYR	MX	C450669	05-17-07	100.0	100.1	99.9
KUE	LANDIS & GYR	MX	C450670	05-17-07	100.1	100.1	100.0
KUE	LANDIS & GYR	MX	C450671	05-17-07	100.1	100.1	100.2
KUE	LANDIS & GYR	MX	C450672	05-17-07	100.1	100.1	100.3
KUE	LANDIS & GYR	MX	C450673	05-17-07	100.1	100.1	99.8
KUE	LANDIS & GYR	MX	C450674	05-17-07	100.0	100.1	100.2
KUE	LANDIS & GYR	MX	C450675	05-17-07	100.1	100.1	100.2
KUE	LANDIS & GYR	MX	C450676	05-17-07	100.1	100.1	99.7
KUE	LANDIS & GYR	MX	C450677	05-17-07	100.1	100.1	99.6
KUE	LANDIS & GYR	MX	C450678	05-17-07	100.1	100.0	99.9
KUE	LANDIS & GYR	MX	C450679	05-17-07	100.0	100.0	100.2
KUE	LANDIS & GYR	MX	C450680	05-17-07	100.1	100.0	100.1
KUE	LANDIS & GYR	MX	C450681	05-17-07	100.1	100.2	100.4

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

CO	MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
KUE	LANDIS & GYR	MX	C450733	05-17-07	100.1	100.0	100.0
KUE	LANDIS & GYR	MX	C450734	05-17-07	100.1	100.1	100.1
KUE	LANDIS & GYR	MX	C450735	05-17-07	100.0	100.0	100.0
KUE	LANDIS & GYR	MX	C450736	05-17-07	99.9	99.9	99.8
KUE	LANDIS & GYR	MX	C450737	05-17-07	99.9	99.9	100.3
KUE	LANDIS & GYR	MX	C450738	05-17-07	100.1	100.3	100.3
KUE	LANDIS & GYR	MX	C450739	05-17-07	100.1	100.1	100.5
KUE	LANDIS & GYR	MX	C450740	05-17-07	100.0	100.0	100.3
KUE	LANDIS & GYR	MX	C450741	05-17-07	100.1	100.0	99.9
KUE	LANDIS & GYR	MX	C450742	05-17-07	100.1	100.1	99.8
KUE	LANDIS & GYR	MX	C450743	05-17-07	100.0	100.1	100.3
KUE	LANDIS & GYR	MX	C450744	05-17-07	100.1	100.1	100.2
KUE	LANDIS & GYR	MX	C450745	05-17-07	100.1	100.0	100.3
KUE	LANDIS & GYR	MX	C450746	05-17-07	100.1	99.9	100.2
KUE	LANDIS & GYR	MX	C450747	05-17-07	100.0	100.1	100.1
KUE	LANDIS & GYR	MX	C450748	05-17-07	100.0	100.0	100.2
KUE	LANDIS & GYR	MX	C450749	05-17-07	100.0	100.0	100.0
KUE	LANDIS & GYR	MX	C450750	05-17-07	100.1	99.9	100.1
KUE	LANDIS & GYR	MX	C450751	05-17-07	100.1	100.1	100.2
KUE	LANDIS & GYR	MX	C450752	05-17-07	100.1	99.9	100.1
KUE	LANDIS & GYR	MX	C450753	05-17-07	100.0	100.1	100.0
KUE	LANDIS & GYR	MX	C450754	05-17-07	100.0	100.0	100.0
KUE	LANDIS & GYR	MX	C450755	05-17-07	100.1	100.0	100.2
KUE	LANDIS & GYR	MX	C450756	05-17-07	100.1	100.1	99.9
KUE	LANDIS & GYR	MX	C450757	05-17-07	100.1	100.1	98.5
KUE	LANDIS & GYR	MX	C450758	05-17-07	100.1	100.2	100.3
KUE	LANDIS & GYR	MX	C450759	05-17-07	100.1	100.1	99.9
KUE	LANDIS & GYR	MX	C450760	05-17-07	100.1	100.1	100.3
KUE	LANDIS & GYR	MX	C450761	05-17-07	100.0	100.1	99.8
KUE	LANDIS & GYR	MX	C450762	05-17-07	100.0	100.1	100.2
KUE	LANDIS & GYR	MX	C450763	05-17-07	100.1	100.0	100.0
KUE	LANDIS & GYR	MX	C450764	05-17-07	100.0	100.0	100.2
KUE	LANDIS & GYR	MX	C450765	05-17-07	100.0	100.1	100.3
KUE	LANDIS & GYR	MX	C450766	05-17-07	100.1	100.1	100.3
KUE	LANDIS & GYR	MX	C450767	05-17-07	100.0	100.1	100.1
KUE	LANDIS & GYR	MX	C450768	05-17-07	100.1	100.1	100.2
KUE	LANDIS & GYR	MX	C450769	05-17-07	100.0	100.0	99.9
KUE	LANDIS & GYR	MX	C450770	05-17-07	100.1	100.0	100.2
KUE	LANDIS & GYR	MX	C450771	05-17-07	100.1	100.0	100.2
KUE	LANDIS & GYR	MX	C450772	05-17-07	100.0	100.0	100.3
KUE	LANDIS & GYR	MX	C450773	05-17-07	100.1	100.1	100.2
KUE	LANDIS & GYR	MX	C450774	05-17-07	100.1	99.9	99.2
KUE	LANDIS & GYR	MX	C450775	05-17-07	100.0	100.1	100.2
KUE	LANDIS & GYR	MX	C450776	05-17-07	100.0	100.1	100.2
KUE	LANDIS & GYR	MX	C450777	05-17-07	100.1	100.1	100.3
KUE	LANDIS & GYR	MX	C450778	05-17-07	100.1	100.2	100.1
KUE	LANDIS & GYR	MX	C450779	05-17-07	100.1	100.0	100.2
KUE	LANDIS & GYR	MX	C450780	05-17-07	100.1	100.1	100.1
KUE	LANDIS & GYR	MX	C450781	05-17-07	100.0	100.0	100.2
KUE	LANDIS & GYR	MX	C450782	05-17-07	100.0	100.0	100.0
KUE	LANDIS & GYR	MX	C450783	05-17-07	100.1	100.1	99.9

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

CO	MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
KUE	LANDIS & GYR	MX	C450835	05-17-07	100.0	100.1	100.4
KUE	LANDIS & GYR	MX	C450836	05-17-07	100.0	100.1	100.0
KUE	LANDIS & GYR	MX	C450837	05-17-07	100.1	100.1	100.1
KUE	LANDIS & GYR	MX	C450838	05-17-07	100.1	100.1	100.0
KUE	LANDIS & GYR	MX	C450839	05-17-07	100.1	100.1	100.4
KUE	LANDIS & GYR	MX	C450840	05-17-07	100.1	99.9	99.6
KUE	LANDIS & GYR	MX	C450841	05-17-07	100.1	100.1	100.2
KUE	LANDIS & GYR	MX	C450842	05-17-07	100.1	100.2	100.2
KUE	LANDIS & GYR	MX	C450843	05-17-07	100.0	99.9	100.0
KUE	LANDIS & GYR	MX	C450844	05-17-07	100.0	100.1	99.8
KUE	LANDIS & GYR	MX	C450845	05-17-07	100.1	100.1	100.1
KUE	LANDIS & GYR	MX	C450846	05-17-07	100.1	100.0	100.1
KUE	LANDIS & GYR	MX	C450847	05-17-07	100.0	100.1	100.2
KUE	LANDIS & GYR	MX	C450848	05-17-07	100.1	100.1	100.1
KUE	LANDIS & GYR	MX	C450849	05-17-07	100.1	100.1	100.1
KUE	LANDIS & GYR	MX	C450850	05-17-07	100.1	100.1	100.2
KUE	LANDIS & GYR	MX	C450851	05-17-07	100.1	100.1	100.3
KUE	LANDIS & GYR	MX	C450852	05-17-07	100.1	100.2	100.3
KUE	LANDIS & GYR	MX	C450853	05-17-07	100.1	100.1	99.9
KUE	LANDIS & GYR	MX	C450854	05-17-07	100.0	100.1	99.8
KUE	LANDIS & GYR	MX	C450855	05-17-07	100.0	100.0	100.2
KUE	LANDIS & GYR	MX	C450856	05-17-07	100.1	100.1	99.9
KUE	LANDIS & GYR	MX	C450857	05-17-07	100.1	100.0	99.7
KUE	LANDIS & GYR	MX	C450858	05-17-07	100.1	100.0	100.1
KUE	LANDIS & GYR	MX	C450859	05-17-07	100.0	99.9	99.9
KUE	LANDIS & GYR	MX	C450860	05-17-07	100.1	100.1	100.3
KUE	LANDIS & GYR	MX	C450861	05-17-07	100.0	99.9	100.2
KUE	LANDIS & GYR	MX	C450862	05-17-07	100.1	100.1	100.2
KUE	LANDIS & GYR	MX	C450863	05-17-07	99.9	99.9	99.9
KUE	LANDIS & GYR	MX	C450864	05-17-07	100.1	100.0	100.1
KUE	LANDIS & GYR	MX	C450865	05-17-07	100.0	100.1	100.0
KUE	LANDIS & GYR	MX	C450866	05-16-07	100.0	100.1	99.8
KUE	LANDIS & GYR	MX	C450867	05-16-07	100.0	100.1	99.9
KUE	LANDIS & GYR	MX	C450868	05-17-07	100.0	100.0	100.1
KUE	LANDIS & GYR	MX	C450869	05-16-07	100.0	99.9	100.1
KUE	LANDIS & GYR	MX	C450870	05-16-07	100.0	100.2	100.1
KUE	LANDIS & GYR	MX	C450871	05-17-07	100.1	100.0	100.3
KUE	LANDIS & GYR	MX	C450872	05-16-07	100.0	100.0	100.0
KUE	LANDIS & GYR	MX	C450873	05-16-07	100.1	100.1	99.9
KUE	LANDIS & GYR	MX	C450874	05-17-07	100.0	100.0	100.3
KUE	LANDIS & GYR	MX	C450875	05-17-07	100.0	100.0	100.2
KUE	LANDIS & GYR	MX	C450876	05-17-07	100.0	100.2	100.1
KUE	LANDIS & GYR	MX	C450877	05-17-07	100.0	100.1	99.9
KUE	LANDIS & GYR	MX	C450878	05-17-07	100.0	100.1	100.1
KUE	LANDIS & GYR	MX	C450879	05-17-07	100.1	100.0	100.1
KUE	LANDIS & GYR	MX	C450880	05-17-07	100.0	100.1	100.3
KUE	LANDIS & GYR	MX	C450881	05-17-07	100.0	100.0	100.1
KUE	LANDIS & GYR	MX	C450882	05-17-07	100.1	100.1	100.1
KUE	LANDIS & GYR	MX	C450883	05-17-07	100.1	100.1	100.1
KUE	LANDIS & GYR	MX	C450884	05-17-07	100.1	100.0	100.1
KUE	LANDIS & GYR	MX	C450885	05-17-07	100.1	100.0	100.0

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

CO	MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
KUE	LANDIS & GYR	MX	C450937	05-17-07	100.1	100.1	100.1
KUE	LANDIS & GYR	MX	C450938	05-17-07	100.0	100.0	100.1
KUE	LANDIS & GYR	MX	C450939	05-17-07	100.1	100.1	100.4
KUE	LANDIS & GYR	MX	C450940	05-17-07	100.0	100.1	100.1
KUE	LANDIS & GYR	MX	C450941	05-17-07	100.1	100.2	99.6
KUE	LANDIS & GYR	MX	C450942	05-17-07	100.1	100.1	100.0
KUE	LANDIS & GYR	MX	C450943	05-17-07	100.0	100.0	100.1
KUE	LANDIS & GYR	MX	C450944	05-17-07	100.1	100.1	100.5
KUE	LANDIS & GYR	MX	C450945	05-17-07	100.1	100.0	100.3
KUE	LANDIS & GYR	MX	C450946	05-17-07	100.1	100.0	100.2
KUE	LANDIS & GYR	MX	C450947	05-17-07	100.1	100.0	100.5
KUE	LANDIS & GYR	MX	C450948	05-17-07	100.0	99.9	100.2
KUE	LANDIS & GYR	MX	C450949	05-17-07	100.0	100.0	100.2
KUE	LANDIS & GYR	MX	C450950	05-17-07	100.0	100.1	100.6
KUE	LANDIS & GYR	MX	C450951	05-17-07	100.1	100.1	100.2
KUE	LANDIS & GYR	MX	C450952	05-17-07	100.1	100.0	100.0
KUE	LANDIS & GYR	MX	C450953	05-17-07	100.1	100.1	100.2
KUE	LANDIS & GYR	MX	C450954	05-17-07	100.0	100.1	99.8
KUE	LANDIS & GYR	MX	C450955	05-17-07	100.0	100.1	100.2
KUE	LANDIS & GYR	MX	C450956	05-17-07	100.1	100.2	100.3
KUE	LANDIS & GYR	MX	C450957	05-17-07	100.0	100.1	100.2
KUE	LANDIS & GYR	MX	C450958	05-17-07	100.1	100.0	100.1
KUE	LANDIS & GYR	MX	C450959	05-17-07	100.1	100.2	100.0
KUE	LANDIS & GYR	MX	C450960	05-17-07	100.1	100.1	99.9
KUE	LANDIS & GYR	MX	C450961	05-17-07	100.0	100.0	99.9
KUE	LANDIS & GYR	MX	C450962	05-17-07	100.0	99.9	100.5
KUE	LANDIS & GYR	MX	C450963	05-17-07	100.0	100.0	100.1
KUE	LANDIS & GYR	MX	C450964	05-17-07	100.0	100.1	100.2
KUE	LANDIS & GYR	MX	C450965	05-17-07	100.0	100.0	100.4
KUE	LANDIS & GYR	MX	C450966	05-17-07	100.1	100.1	100.2
KUE	LANDIS & GYR	MX	C450967	05-17-07	100.1	99.9	100.1
KUE	LANDIS & GYR	MX	C450968	05-17-07	100.0	100.1	100.1
KUE	LANDIS & GYR	MX	C450969	05-17-07	100.1	100.1	100.1
KUE	LANDIS & GYR	MX	C450970	05-17-07	100.1	100.1	100.1
KUE	LANDIS & GYR	MX	C450971	05-17-07	100.1	99.9	100.0
KUE	LANDIS & GYR	MX	C450972	05-17-07	100.1	100.0	100.1
KUE	LANDIS & GYR	MX	C450973	05-17-07	100.1	100.1	100.1
KUE	LANDIS & GYR	MX	C450974	05-17-07	100.1	100.1	99.8
KUE	LANDIS & GYR	MX	C450975	05-17-07	100.1	100.1	99.9
KUE	LANDIS & GYR	MX	C450976	05-17-07	100.1	100.1	99.8
KUE	LANDIS & GYR	MX	C450977	05-17-07	100.1	100.1	100.2
KUE	LANDIS & GYR	MX	C450978	05-17-07	100.0	99.9	100.1
KUE	LANDIS & GYR	MX	C450979	05-17-07	100.1	99.9	100.1
KUE	LANDIS & GYR	MX	C450980	05-17-07	100.1	100.1	99.9
KUE	LANDIS & GYR	MX	C450981	05-17-07	100.1	99.9	99.9
KUE	LANDIS & GYR	MX	C450982	05-17-07	100.1	100.1	99.8
KUE	LANDIS & GYR	MX	C450983	05-17-07	100.1	100.1	100.1
KUE	LANDIS & GYR	MX	C450984	05-17-07	100.0	100.0	99.9
KUE	LANDIS & GYR	MX	C450985	05-17-07	100.1	100.0	99.8
KUE	LANDIS & GYR	MX	C450986	05-17-07	100.1	100.0	99.8
KUE	LANDIS & GYR	MX	C450987	05-17-07	100.1	100.1	100.2

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

PAGE 121
 RUN DATE: 1/15/08
 RUN TIME: 22.00.58

CO	MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
KUE	LANDIS & GYR	MX	C451039	05-17-07	100.0	100.1	100.0
KUE	LANDIS & GYR	MX	C451040	05-17-07	100.1	99.9	99.9
KUE	LANDIS & GYR	MX	C451041	05-17-07	100.0	99.9	99.7
KUE	LANDIS & GYR	MX	C451042	05-17-07	100.0	100.1	99.8
KUE	LANDIS & GYR	MX	C451043	05-17-07	100.1	100.1	99.7
KUE	LANDIS & GYR	MX	C451044	05-17-07	100.0	100.1	100.1
KUE	LANDIS & GYR	MX	C451045	05-17-07	100.0	100.0	100.0
KUE	LANDIS & GYR	MX	C451046	05-17-07	100.1	100.0	100.0
KUE	LANDIS & GYR	MX	C451047	05-17-07	100.0	100.0	99.8
KUE	LANDIS & GYR	MX	C451048	05-17-07	100.1	100.0	100.0
KUE	LANDIS & GYR	MX	C451049	05-17-07	100.0	99.9	100.0
KUE	LANDIS & GYR	MX	C451050	05-17-07	100.0	99.9	100.2
KUE	LANDIS & GYR	MX	C451051	05-17-07	100.1	99.9	99.9
KUE	LANDIS & GYR	MX	C451052	05-17-07	100.1	100.1	100.3
KUE	LANDIS & GYR	MX	C451053	05-17-07	100.1	100.1	99.8
KUE	LANDIS & GYR	MX	C451054	05-17-07	100.1	100.1	100.1
KUE	LANDIS & GYR	MX	C451055	05-17-07	100.1	100.0	100.1
KUE	LANDIS & GYR	MX	C451056	05-17-07	100.0	100.1	100.3
KUE	LANDIS & GYR	MX	C451057	05-17-07	100.0	99.9	100.1
KUE	LANDIS & GYR	MX	C451058	05-17-07	100.0	99.9	99.8
KUE	LANDIS & GYR	MX	C451059	05-17-07	100.0	100.1	100.2
KUE	LANDIS & GYR	MX	C451060	05-17-07	100.1	100.1	100.2
KUE	LANDIS & GYR	MX	C451061	05-17-07	100.1	100.0	100.0
KUE	LANDIS & GYR	MX	C451062	05-17-07	100.0	100.1	100.2
KUE	LANDIS & GYR	MX	C451063	05-17-07	100.1	100.1	100.2
KUE	LANDIS & GYR	MX	C451064	05-17-07	100.1	100.0	100.3
KUE	LANDIS & GYR	MX	C451065	05-17-07	100.1	100.0	100.2
KUE	LANDIS & GYR	MX	C451066	05-17-07	100.1	100.0	100.0
KUE	LANDIS & GYR	MX	C451067	05-18-07	100.1	100.2	100.0
KUE	LANDIS & GYR	MX	C451068	05-18-07	100.0	100.0	100.0
KUE	LANDIS & GYR	MX	C451069	05-18-07	100.0	100.0	99.7
KUE	LANDIS & GYR	MX	C451070	05-18-07	100.1	100.2	100.3
KUE	LANDIS & GYR	MX	C451071	05-17-07	100.0	99.9	100.1
KUE	LANDIS & GYR	MX	C451072	05-17-07	100.1	100.0	99.9
KUE	LANDIS & GYR	MX	C451073	05-17-07	100.0	100.0	100.1
KUE	LANDIS & GYR	MX	C451074	05-17-07	100.0	99.9	100.1
KUE	LANDIS & GYR	MX	C451075	05-17-07	100.0	100.0	100.3
KUE	LANDIS & GYR	MX	C451076	05-17-07	100.0	100.1	100.3
KUE	LANDIS & GYR	MX	C451077	05-17-07	100.0	100.1	100.1
KUE	LANDIS & GYR	MX	C451078	05-17-07	100.0	99.9	100.1
KUE	LANDIS & GYR	MX	C451079	05-17-07	100.0	99.9	99.8
KUE	LANDIS & GYR	MX	C451080	05-17-07	100.0	99.9	100.2
KUE	LANDIS & GYR	MX	C451081	05-17-07	100.0	100.1	100.1
KUE	LANDIS & GYR	MX	C451082	05-17-07	100.0	100.0	99.5
KUE	LANDIS & GYR	MX	C451083	05-17-07	100.1	100.2	99.8
KUE	LANDIS & GYR	MX	C451084	05-17-07	100.1	100.2	100.2
KUE	LANDIS & GYR	MX	C451085	05-17-07	100.0	100.1	99.5
KUE	LANDIS & GYR	MX	C451086	05-17-07	100.1	100.1	100.0
KUE	LANDIS & GYR	MX	C451087	05-17-07	100.0	100.2	100.4
KUE	LANDIS & GYR	MX	C451088	05-17-07	100.1	100.1	99.8
KUE	LANDIS & GYR	MX	C451089	05-17-07	100.0	99.9	99.6

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

CO	MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
KUE	LANDIS & GYR	MX	C451141	05-17-07	100.1	100.1	100.2
KUE	LANDIS & GYR	MX	C451142	05-17-07	100.1	100.1	100.3
KUE	LANDIS & GYR	MX	C451143	05-17-07	100.1	100.0	100.2
KUE	LANDIS & GYR	MX	C451144	05-17-07	100.1	100.2	100.2
KUE	LANDIS & GYR	MX	C451145	05-17-07	100.0	99.9	99.9
KUE	LANDIS & GYR	MX	C451146	05-17-07	100.0	100.0	100.0
KUE	LANDIS & GYR	MX	C451147	05-17-07	100.1	99.9	100.2
KUE	LANDIS & GYR	MX	C451148	05-17-07	100.1	100.1	100.4
KUE	LANDIS & GYR	MX	C451149	05-17-07	100.0	100.0	100.2
KUE	LANDIS & GYR	MX	C451150	05-17-07	100.0	100.1	100.3
KUE	LANDIS & GYR	MX	C451151	05-17-07	100.1	100.2	100.1
KUE	LANDIS & GYR	MX	C451152	05-17-07	100.1	100.0	100.1
KUE	LANDIS & GYR	MX	C451153	05-17-07	100.1	99.9	100.3
KUE	LANDIS & GYR	MX	C451154	05-17-07	100.1	100.1	100.3
KUE	LANDIS & GYR	MX	C451155	05-17-07	100.1	100.0	100.3
KUE	LANDIS & GYR	MX	C451156	05-17-07	100.1	100.2	100.4
KUE	LANDIS & GYR	MX	C451157	05-17-07	100.1	100.0	100.5
KUE	LANDIS & GYR	MX	C451158	05-17-07	100.0	100.0	100.0
KUE	LANDIS & GYR	MX	C451159	05-17-07	100.0	100.1	100.2
KUE	LANDIS & GYR	MX	C451160	05-17-07	100.0	100.0	100.0
KUE	LANDIS & GYR	MX	C451161	05-17-07	100.0	100.0	100.3
KUE	LANDIS & GYR	MX	C451162	05-17-07	100.0	100.0	100.3
KUE	LANDIS & GYR	MX	C451163	05-17-07	100.0	100.0	99.9
KUE	LANDIS & GYR	MX	C451164	05-17-07	100.1	100.1	100.3
KUE	LANDIS & GYR	MX	C451165	05-17-07	100.1	100.1	100.3
KUE	LANDIS & GYR	MX	C451166	05-17-07	100.1	100.1	100.4
KUE	LANDIS & GYR	MX	C451167	05-17-07	100.1	100.1	100.3
KUE	LANDIS & GYR	MX	C451168	05-17-07	100.1	100.2	100.1
KUE	LANDIS & GYR	MX	C451169	05-17-07	100.1	100.1	100.3
KUE	LANDIS & GYR	MX	C451170	05-17-07	100.0	100.0	100.2
KUE	LANDIS & GYR	MX	C451171	05-17-07	100.0	99.9	100.0
KUE	LANDIS & GYR	MX	C451172	05-17-07	100.0	100.0	100.0
KUE	LANDIS & GYR	MX	C451173	05-17-07	100.1	99.9	100.4
KUE	LANDIS & GYR	MX	C451174	05-17-07	100.1	100.0	100.2
KUE	LANDIS & GYR	MX	C451175	05-17-07	100.0	100.0	99.8
KUE	LANDIS & GYR	MX	C451176	05-17-07	100.0	99.9	100.3
KUE	LANDIS & GYR	MX	C451177	05-17-07	100.0	99.9	100.1
KUE	LANDIS & GYR	MX	C451178	05-17-07	100.0	100.0	100.0
KUE	LANDIS & GYR	MX	C451179	05-17-07	100.0	100.1	100.1
KUE	LANDIS & GYR	MX	C451180	05-17-07	100.0	100.0	100.0
KUE	LANDIS & GYR	MX	C451181	05-17-07	100.1	100.1	100.6
KUE	LANDIS & GYR	MX	C451182	05-17-07	100.1	99.9	100.2
KUE	LANDIS & GYR	MX	C451183	05-17-07	100.1	100.1	100.4
KUE	LANDIS & GYR	MX	C451184	05-17-07	100.1	100.1	100.2
KUE	LANDIS & GYR	MX	C451185	05-17-07	100.0	100.1	100.3
KUE	LANDIS & GYR	MX	C451186	05-17-07	100.0	100.1	100.4
KUE	LANDIS & GYR	MX	C451187	05-17-07	100.1	100.1	100.2
KUE	LANDIS & GYR	MX	C451188	05-17-07	100.1	100.1	100.3
KUE	LANDIS & GYR	MX	C451189	05-17-07	100.1	100.2	100.4
KUE	LANDIS & GYR	MX	C451190	05-17-07	100.1	100.1	99.9
KUE	LANDIS & GYR	MX	C451191	05-17-07	100.1	100.1	100.0

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

CO	MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
KUE	LANDIS & GYR	MX	C451243	05-17-07	100.1	99.9	100.1
KUE	LANDIS & GYR	MX	C451244	05-17-07	100.1	100.2	100.4
KUE	LANDIS & GYR	MX	C451245	05-17-07	100.1	100.2	100.3
KUE	LANDIS & GYR	MX	C451246	05-18-07	100.1	100.0	100.3
KUE	LANDIS & GYR	MX	C451247	05-17-07	100.1	100.1	100.2
KUE	LANDIS & GYR	MX	C451248	05-18-07	100.1	100.1	100.4
KUE	LANDIS & GYR	MX	C451249	05-17-07	100.0	100.0	100.2
KUE	LANDIS & GYR	MX	C451250	05-18-07	100.0	100.1	100.2
KUE	LANDIS & GYR	MX	C451251	05-17-07	100.0	99.9	100.1
KUE	LANDIS & GYR	MX	C451252	05-17-07	100.0	100.0	100.3
KUE	LANDIS & GYR	MX	C451253	05-18-07	100.1	100.0	100.3
KUE	LANDIS & GYR	MX	C451254	05-17-07	100.1	100.1	100.2
KUE	LANDIS & GYR	MX	C451255	05-18-07	100.1	99.9	100.3
KUE	LANDIS & GYR	MX	C451256	05-17-07	100.1	100.0	100.2
KUE	LANDIS & GYR	MX	C451257	05-17-07	100.0	99.9	100.2
KUE	LANDIS & GYR	MX	C451258	05-18-07	100.1	100.2	100.3
KUE	LANDIS & GYR	MX	C451259	05-18-07	100.1	100.0	100.5
KUE	LANDIS & GYR	MX	C451260	05-18-07	100.1	100.0	100.4
KUE	LANDIS & GYR	MX	C451261	05-17-07	100.0	100.1	100.2
KUE	LANDIS & GYR	MX	C451262	05-18-07	100.1	100.2	100.5
KUE	LANDIS & GYR	MX	C451263	05-17-07	100.0	100.1	100.2
KUE	LANDIS & GYR	MX	C451264	05-17-07	100.1	100.0	100.1
KUE	LANDIS & GYR	MX	C451265	05-17-07	100.0	100.1	99.9
KUE	LANDIS & GYR	MX	C451266	05-17-07	100.1	100.1	100.4
KUE	LANDIS & GYR	MX	C451267	05-17-07	100.0	100.1	100.2
KUE	LANDIS & GYR	MX	C451268	05-17-07	100.1	100.1	100.4
KUE	LANDIS & GYR	MX	C451269	05-17-07	100.0	99.9	100.1
KUE	LANDIS & GYR	MX	C451270	05-17-07	100.1	100.0	100.3
KUE	LANDIS & GYR	MX	C451271	05-17-07	99.9	100.1	100.4
KUE	LANDIS & GYR	MX	C451272	05-17-07	100.1	100.2	100.4
KUE	LANDIS & GYR	MX	C451273	05-17-07	100.1	100.1	100.4
KUE	LANDIS & GYR	MX	C451274	05-17-07	100.1	99.9	100.4
KUE	LANDIS & GYR	MX	C451275	05-17-07	100.1	100.0	100.2
KUE	LANDIS & GYR	MX	C451276	05-17-07	100.0	100.0	100.2
KUE	LANDIS & GYR	MX	C451277	05-17-07	100.0	99.9	100.0
KUE	LANDIS & GYR	MX	C451278	05-17-07	100.1	100.1	100.3
KUE	LANDIS & GYR	MX	C451279	05-17-07	100.1	100.1	100.4
KUE	LANDIS & GYR	MX	C451280	05-17-07	100.1	100.0	100.3
KUE	LANDIS & GYR	MX	C451281	05-17-07	100.1	100.1	100.4
KUE	LANDIS & GYR	MX	C451282	05-17-07	100.1	100.2	100.4
KUE	LANDIS & GYR	MX	C451283	05-17-07	100.0	100.1	100.3
KUE	LANDIS & GYR	MX	C451284	05-17-07	100.1	100.1	100.0
KUE	LANDIS & GYR	MX	C451285	05-18-07	100.0	99.9	100.1
KUE	LANDIS & GYR	MX	C451286	05-18-07	100.1	100.0	99.8
KUE	LANDIS & GYR	MX	C451287	05-18-07	100.0	100.0	100.3
KUE	LANDIS & GYR	MX	C451288	05-18-07	100.1	100.1	100.4
KUE	LANDIS & GYR	MX	C451289	05-18-07	100.1	100.1	100.3
KUE	LANDIS & GYR	MX	C451290	05-18-07	100.0	100.1	100.4
KUE	LANDIS & GYR	MX	C451291	05-18-07	100.1	100.2	100.4
KUE	LANDIS & GYR	MX	C451292	05-17-07	100.0	100.0	100.4
KUE	LANDIS & GYR	MX	C451293	05-18-07	100.0	100.0	100.3

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

CO	MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
KUE	LANDIS & GYR	MX	C4511345	05-17-07	100.1	100.1	100.0
KUE	LANDIS & GYR	MX	C4511346	05-17-07	100.0	100.0	100.3
KUE	LANDIS & GYR	MX	C4511347	05-17-07	100.1	100.1	100.3
KUE	LANDIS & GYR	MX	C4511348	05-17-07	100.0	100.0	99.8
KUE	LANDIS & GYR	MX	C4511349	05-17-07	100.0	99.9	100.0
KUE	LANDIS & GYR	MX	C4511350	05-17-07	100.1	100.1	99.9
KUE	LANDIS & GYR	MX	C4511351	05-18-07	100.0	100.0	100.2
KUE	LANDIS & GYR	MX	C4511352	05-17-07	100.0	100.0	100.1
KUE	LANDIS & GYR	MX	C4511353	05-18-07	100.0	99.9	99.9
KUE	LANDIS & GYR	MX	C4511354	05-18-07	100.0	100.2	100.3
KUE	LANDIS & GYR	MX	C4511355	05-18-07	100.1	100.2	100.3
KUE	LANDIS & GYR	MX	C4511356	05-18-07	100.0	100.0	100.3
KUE	LANDIS & GYR	MX	C4511357	05-18-07	100.0	100.0	100.4
KUE	LANDIS & GYR	MX	C4511358	05-18-07	100.1	100.2	100.3
KUE	LANDIS & GYR	MX	C4511359	05-18-07	100.1	100.1	100.3
KUE	LANDIS & GYR	MX	C4511360	05-18-07	100.1	100.0	100.1
KUE	LANDIS & GYR	MX	C4511361	05-18-07	100.1	100.0	100.4
KUE	LANDIS & GYR	MX	C4511362	05-18-07	100.0	99.9	100.2
KUE	LANDIS & GYR	MX	C4511363	05-18-07	100.0	100.1	100.0
KUE	LANDIS & GYR	MX	C4511364	05-18-07	100.1	100.2	100.5
KUE	LANDIS & GYR	MX	C4511365	05-18-07	100.1	100.2	100.2
KUE	LANDIS & GYR	MX	C4511366	05-18-07	100.0	100.0	100.2
KUE	LANDIS & GYR	MX	C4511367	05-18-07	100.1	99.9	100.4
KUE	LANDIS & GYR	MX	C4511368	05-18-07	100.1	100.2	100.2
KUE	LANDIS & GYR	MX	C4511369	05-18-07	100.1	100.2	100.2
KUE	LANDIS & GYR	MX	C4511370	05-18-07	100.1	99.9	100.2
KUE	LANDIS & GYR	MX	C4511371	05-18-07	100.0	100.0	100.4
KUE	LANDIS & GYR	MX	C4511372	05-18-07	100.1	100.1	100.1
KUE	LANDIS & GYR	MX	C4511373	05-18-07	100.0	100.0	100.2
KUE	LANDIS & GYR	MX	C4511374	05-18-07	100.1	100.1	100.2
KUE	LANDIS & GYR	MX	C4511375	05-18-07	100.1	99.9	100.2
KUE	LANDIS & GYR	MX	C4511376	05-18-07	100.1	100.1	100.2
KUE	LANDIS & GYR	MX	C4511377	05-18-07	100.1	100.1	100.3
KUE	LANDIS & GYR	MX	C4511378	05-18-07	100.1	100.1	100.3
KUE	LANDIS & GYR	MX	C4511379	05-18-07	100.1	100.0	100.2
KUE	LANDIS & GYR	MX	C4511380	05-18-07	100.1	100.1	100.6
KUE	LANDIS & GYR	MX	C4511381	05-18-07	100.1	100.1	100.3
KUE	LANDIS & GYR	MX	C4511382	05-18-07	100.0	100.0	100.3
KUE	LANDIS & GYR	MX	C4511383	05-18-07	100.0	100.0	100.5
KUE	LANDIS & GYR	MX	C4511384	05-18-07	100.1	100.1	100.3
KUE	LANDIS & GYR	MX	C4511385	05-18-07	100.1	100.1	100.5
KUE	LANDIS & GYR	MX	C4511386	05-18-07	100.0	100.1	100.4
KUE	LANDIS & GYR	MX	C4511387	05-18-07	100.1	100.0	100.4
KUE	LANDIS & GYR	MX	C4511388	05-18-07	100.0	100.1	100.3
KUE	LANDIS & GYR	MX	C4511389	05-18-07	100.0	100.0	100.3
KUE	LANDIS & GYR	MX	C4511390	05-18-07	100.0	100.0	100.2
KUE	LANDIS & GYR	MX	C4511391	05-18-07	100.0	100.0	100.4
KUE	LANDIS & GYR	MX	C4511392	05-18-07	100.1	100.1	100.5
KUE	LANDIS & GYR	MX	C4511393	05-18-07	100.1	100.1	100.0
KUE	LANDIS & GYR	MX	C4511394	05-18-07	100.1	99.9	100.0
KUE	LANDIS & GYR	MX	C4511395	05-18-07	100.0	100.0	100.2

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

CO	MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
KUE	LANDIS & GYR	MX	C451447	05-18-07	100.1	100.1	100.3
KUE	LANDIS & GYR	MX	C451448	05-18-07	100.0	100.1	100.1
KUE	LANDIS & GYR	MX	C451449	05-18-07	100.0	100.0	100.5
KUE	LANDIS & GYR	MX	C451450	05-18-07	100.0	100.1	100.3
KUE	LANDIS & GYR	MX	C451451	05-18-07	100.0	100.2	100.2
KUE	LANDIS & GYR	MX	C451452	05-18-07	100.1	100.1	100.6
KUE	LANDIS & GYR	MX	C451453	05-18-07	100.0	100.1	100.3
KUE	LANDIS & GYR	MX	C451454	05-18-07	100.0	100.1	100.4
KUE	LANDIS & GYR	MX	C451455	05-18-07	100.0	99.9	99.8
KUE	LANDIS & GYR	MX	C451456	05-18-07	100.1	100.2	100.5
KUE	LANDIS & GYR	MX	C451457	05-18-07	100.0	99.9	99.9
KUE	LANDIS & GYR	MX	C451458	05-18-07	100.1	100.2	100.3
KUE	LANDIS & GYR	MX	C451459	05-18-07	100.0	100.2	100.1
KUE	LANDIS & GYR	MX	C451460	05-18-07	100.1	100.0	100.0
KUE	LANDIS & GYR	MX	C451461	05-18-07	100.1	100.1	100.3
KUE	LANDIS & GYR	MX	C451462	05-18-07	100.0	100.2	99.8
KUE	LANDIS & GYR	MX	C451463	05-18-07	100.0	100.0	100.0
KUE	LANDIS & GYR	MX	C451464	05-18-07	100.1	100.1	100.2
KUE	LANDIS & GYR	MX	C451465	05-18-07	100.0	99.9	100.3
KUE	LANDIS & GYR	MX	C451466	05-18-07	100.1	100.1	100.0
KUE	LANDIS & GYR	MX	C451467	05-18-07	100.1	99.9	100.0
KUE	LANDIS & GYR	MX	C451468	05-18-07	100.0	100.0	100.0
KUE	LANDIS & GYR	MX	C451469	05-18-07	100.0	100.0	100.2
KUE	LANDIS & GYR	MX	C451470	05-18-07	100.1	100.1	100.1
KUE	LANDIS & GYR	MX	C451471	05-18-07	100.1	100.1	100.0
KUE	LANDIS & GYR	MX	C451472	05-18-07	100.0	99.9	100.1
KUE	LANDIS & GYR	MX	C451473	05-18-07	100.1	100.1	100.2
KUE	LANDIS & GYR	MX	C451474	05-18-07	100.0	99.9	99.8
KUE	LANDIS & GYR	MX	C451475	05-18-07	100.0	100.0	99.6
KUE	LANDIS & GYR	MX	C451476	05-18-07	100.0	100.1	99.8
KUE	LANDIS & GYR	MX	C451477	05-18-07	100.0	99.9	100.1
KUE	LANDIS & GYR	MX	C451478	05-18-07	100.1	100.0	100.4
KUE	LANDIS & GYR	MX	C451479	05-18-07	100.1	100.0	100.4
KUE	LANDIS & GYR	MX	C451480	05-18-07	100.1	100.1	100.3
KUE	LANDIS & GYR	MX	C451481	05-18-07	100.0	100.1	100.3
KUE	LANDIS & GYR	MX	C451482	05-18-07	100.1	100.0	99.8
KUE	LANDIS & GYR	MX	C451483	05-18-07	100.1	100.1	100.1
KUE	LANDIS & GYR	MX	C451484	05-18-07	100.1	100.2	100.0
KUE	LANDIS & GYR	MX	C451485	05-18-07	100.0	100.0	100.3
KUE	LANDIS & GYR	MX	C451486	05-18-07	100.1	100.0	100.6
KUE	LANDIS & GYR	MX	C451487	05-21-07	100.1	100.0	100.0
KUE	LANDIS & GYR	MX	C451488	05-18-07	100.1	100.0	100.2
KUE	LANDIS & GYR	MX	C451489	05-18-07	100.0	100.0	100.0
KUE	LANDIS & GYR	MX	C451490	05-18-07	100.1	100.1	100.2
KUE	LANDIS & GYR	MX	C451491	05-18-07	100.1	100.2	99.9
KUE	LANDIS & GYR	MX	C451492	05-18-07	100.1	100.1	100.1
KUE	LANDIS & GYR	MX	C451493	05-18-07	100.0	99.9	99.7
KUE	LANDIS & GYR	MX	C451494	05-18-07	100.0	100.1	100.1
KUE	LANDIS & GYR	MX	C451495	05-18-07	100.1	100.1	100.4
KUE	LANDIS & GYR	MX	C451496	05-18-07	100.1	100.1	100.0
KUE	LANDIS & GYR	MX	C451497	05-18-07	100.1	100.1	100.1

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

PAGE 131
 RUN DATE: 1/15/08
 RUN TIME: 22.00.58

CO	MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
KUE	& GYR	MX	C451549	05-18-07	100.0	100.0	100.2
KUE	LANDIS	MX	C451550	05-18-07	100.1	100.0	100.1
KUE	LANDIS	MX	C451551	05-18-07	100.1	100.0	100.1
KUE	LANDIS	MX	C451552	05-18-07	100.1	100.1	100.0
KUE	LANDIS	MX	C451553	05-18-07	100.1	100.0	100.2
KUE	LANDIS	MX	C451554	05-18-07	100.1	100.1	100.1
KUE	LANDIS	MX	C451555	05-18-07	100.0	100.1	100.0
KUE	LANDIS	MX	C451556	05-18-07	100.1	100.0	100.4
KUE	LANDIS	MX	C451557	05-18-07	100.1	100.0	100.2
KUE	LANDIS	MX	C451558	05-18-07	100.0	100.1	100.1
KUE	LANDIS	MX	C451559	05-18-07	100.1	100.0	100.5
KUE	LANDIS	MX	C451560	05-18-07	100.0	100.0	100.0
KUE	LANDIS	MX	C451561	05-18-07	100.0	100.0	100.1
KUE	LANDIS	MX	C451562	05-18-07	100.1	100.1	100.4
KUE	LANDIS	MX	C451563	05-18-07	100.0	100.1	99.9
KUE	LANDIS	MX	C451564	05-18-07	100.0	100.2	100.0
KUE	LANDIS	MX	C451565	05-18-07	100.1	100.2	100.4
KUE	LANDIS	MX	C451566	05-18-07	100.1	100.2	100.2
KUE	LANDIS	MX	C451567	05-18-07	100.1	100.1	100.2
KUE	LANDIS	MX	C451568	05-18-07	100.0	100.0	100.3
KUE	LANDIS	MX	C451569	05-18-07	100.0	100.0	100.2
KUE	LANDIS	MX	C451570	05-18-07	100.1	100.0	100.1
KUE	LANDIS	MX	C451571	05-17-07	100.0	100.1	99.9
KUE	LANDIS	MX	C451572	05-18-07	100.1	100.1	99.9
KUE	LANDIS	MX	C451573	05-18-07	100.1	99.9	100.2
KUE	LANDIS	MX	C451574	05-18-07	100.1	100.1	100.1
KUE	LANDIS	MX	C451575	05-18-07	100.1	100.1	99.9
KUE	LANDIS	MX	C451576	05-17-07	100.0	100.0	100.0
KUE	LANDIS	MX	C451577	05-18-07	100.1	100.1	100.1
KUE	LANDIS	MX	C451578	05-18-07	100.1	99.9	100.1
KUE	LANDIS	MX	C451579	05-17-07	100.1	100.1	100.2
KUE	LANDIS	MX	C451580	05-17-07	100.1	100.1	100.3
KUE	LANDIS	MX	C451581	05-18-07	100.0	100.0	100.0
KUE	LANDIS	MX	C451582	05-17-07	100.1	100.1	100.2
KUE	LANDIS	MX	C451583	05-17-07	100.0	100.0	100.2
KUE	LANDIS	MX	C451584	05-18-07	100.1	100.0	100.0
KUE	LANDIS	MX	C451585	05-18-07	100.1	100.1	100.1
KUE	LANDIS	MX	C451586	05-18-07	100.1	99.9	100.1
KUE	LANDIS	MX	C451587	05-18-07	100.1	100.1	100.0
KUE	LANDIS	MX	C451588	05-18-07	100.0	99.9	99.7
KUE	LANDIS	MX	C451589	05-18-07	100.0	100.2	100.0
KUE	LANDIS	MX	C451590	05-18-07	100.1	100.0	99.8
KUE	LANDIS	MX	C451591	05-18-07	100.0	100.2	100.0
KUE	LANDIS	MX	C451592	05-17-07	100.1	100.0	99.6
KUE	LANDIS	MX	C451593	05-18-07	100.1	100.1	100.2
KUE	LANDIS	MX	C451594	05-18-07	100.1	100.0	100.2
KUE	LANDIS	MX	C451595	05-18-07	100.1	100.0	99.8
KUE	LANDIS	MX	C451596	05-18-07	100.1	100.1	100.1
KUE	LANDIS	MX	C451597	05-18-07	100.1	100.0	100.1
KUE	LANDIS	MX	C451598	05-18-07	100.0	100.0	100.1
KUE	LANDIS	MX	C451599	05-18-07	100.1	100.1	100.3

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

CO	MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
KUE	LANDIS & GYR	MX	C451651	05-19-07	100.0	100.1	100.1
KUE	LANDIS & GYR	MX	C451652	05-19-07	100.0	100.0	99.6
KUE	LANDIS & GYR	MX	C451653	05-19-07	100.1	100.0	100.3
KUE	LANDIS & GYR	MX	C451654	05-18-07	100.1	100.1	100.2
KUE	LANDIS & GYR	MX	C451655	05-19-07	100.0	100.1	100.3
KUE	LANDIS & GYR	MX	C451656	05-18-07	100.1	100.0	100.2
KUE	LANDIS & GYR	MX	C451657	05-18-07	100.1	100.0	100.1
KUE	LANDIS & GYR	MX	C451658	05-19-07	100.1	100.0	100.1
KUE	LANDIS & GYR	MX	C451659	05-19-07	99.9	99.9	100.3
KUE	LANDIS & GYR	MX	C451660	05-18-07	99.9	99.9	100.4
KUE	LANDIS & GYR	MX	C451661	05-18-07	100.0	100.1	100.4
KUE	LANDIS & GYR	MX	C451662	05-19-07	100.0	100.0	100.3
KUE	LANDIS & GYR	MX	C451663	05-19-07	100.1	100.2	100.4
KUE	LANDIS & GYR	MX	C451664	05-18-07	100.1	100.1	100.2
KUE	LANDIS & GYR	MX	C451665	05-18-07	100.1	100.0	100.2
KUE	LANDIS & GYR	MX	C451666	05-18-07	100.1	100.0	100.3
KUE	LANDIS & GYR	MX	C451667	05-19-07	100.1	100.1	100.4
KUE	LANDIS & GYR	MX	C451668	05-19-07	100.1	99.9	100.1
KUE	LANDIS & GYR	MX	C451669	05-19-07	100.0	100.0	99.8
KUE	LANDIS & GYR	MX	C451670	05-18-07	100.0	100.1	100.1
KUE	LANDIS & GYR	MX	C451671	05-19-07	100.1	100.0	100.3
KUE	LANDIS & GYR	MX	C451672	05-19-07	100.1	100.0	100.0
KUE	LANDIS & GYR	MX	C451673	05-19-07	100.1	100.1	100.3
KUE	LANDIS & GYR	MX	C451674	05-18-07	100.0	100.0	99.7
KUE	LANDIS & GYR	MX	C451675	05-19-07	100.1	100.0	100.0
KUE	LANDIS & GYR	MX	C451676	05-19-07	100.1	100.1	100.2
KUE	LANDIS & GYR	MX	C451677	05-18-07	100.1	100.2	100.0
KUE	LANDIS & GYR	MX	C451678	05-18-07	100.0	100.0	100.2
KUE	LANDIS & GYR	MX	C451679	05-19-07	100.1	100.0	100.4
KUE	LANDIS & GYR	MX	C451680	05-19-07	100.1	100.1	100.1
KUE	LANDIS & GYR	MX	C451681	05-19-07	100.1	100.1	100.4
KUE	LANDIS & GYR	MX	C451682	05-19-07	100.1	100.2	100.1
KUE	LANDIS & GYR	MX	C451683	05-19-07	100.1	100.2	100.2
KUE	LANDIS & GYR	MX	C451684	05-19-07	100.0	100.1	100.3
KUE	LANDIS & GYR	MX	C451685	05-19-07	100.1	100.0	100.3
KUE	LANDIS & GYR	MX	C451686	05-19-07	100.1	99.9	100.4
KUE	LANDIS & GYR	MX	C451687	05-19-07	100.1	100.0	100.4
KUE	LANDIS & GYR	MX	C451688	05-19-07	100.1	100.0	100.4
KUE	LANDIS & GYR	MX	C451689	05-19-07	100.1	100.1	100.1
KUE	LANDIS & GYR	MX	C451690	05-19-07	100.1	100.1	100.3
KUE	LANDIS & GYR	MX	C451691	05-18-07	100.1	100.0	100.3
KUE	LANDIS & GYR	MX	C451692	05-19-07	100.1	100.0	100.5
KUE	LANDIS & GYR	MX	C451693	05-19-07	100.1	100.1	100.5
KUE	LANDIS & GYR	MX	C451694	05-19-07	100.0	100.0	99.8
KUE	LANDIS & GYR	MX	C451695	05-19-07	100.1	100.0	100.4
KUE	LANDIS & GYR	MX	C451696	05-18-07	100.1	100.0	100.3
KUE	LANDIS & GYR	MX	C451697	05-19-07	100.0	100.0	100.1
KUE	LANDIS & GYR	MX	C451698	05-19-07	100.1	100.0	100.2
KUE	LANDIS & GYR	MX	C451699	05-19-07	100.0	100.0	100.3
KUE	LANDIS & GYR	MX	C451700	05-18-07	100.0	100.1	100.3
KUE	LANDIS & GYR	MX	C451701	05-19-07	100.0	100.1	100.4

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

CO	MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
KUE	LANDIS & GYR	MX	C451753	05-19-07	100.1	100.0	100.5
KUE	LANDIS & GYR	MX	C451754	05-19-07	100.0	100.0	99.9
KUE	LANDIS & GYR	MX	C451755	05-19-07	100.0	100.0	100.2
KUE	LANDIS & GYR	MX	C451756	05-18-07	100.0	100.0	99.7
KUE	LANDIS & GYR	MX	C451757	05-19-07	100.0	100.0	100.0
KUE	LANDIS & GYR	MX	C451758	05-19-07	100.1	100.0	100.2
KUE	LANDIS & GYR	MX	C451759	05-19-07	100.0	100.1	100.3
KUE	LANDIS & GYR	MX	C451760	05-19-07	100.0	100.0	99.8
KUE	LANDIS & GYR	MX	C451761	05-19-07	100.0	100.1	99.9
KUE	LANDIS & GYR	MX	C451762	05-19-07	100.1	100.2	99.9
KUE	LANDIS & GYR	MX	C451763	05-18-07	100.1	100.0	100.3
KUE	LANDIS & GYR	MX	C451764	05-18-07	100.0	99.9	100.0
KUE	LANDIS & GYR	MX	C451765	05-18-07	100.0	100.1	100.3
KUE	LANDIS & GYR	MX	C451766	05-19-07	100.0	100.0	99.8
KUE	LANDIS & GYR	MX	C451767	05-19-07	100.1	100.2	100.3
KUE	LANDIS & GYR	MX	C451768	05-19-07	100.0	100.1	100.3
KUE	LANDIS & GYR	MX	C451769	05-19-07	100.0	99.9	100.1
KUE	LANDIS & GYR	MX	C451770	05-18-07	99.9	99.9	100.1
KUE	LANDIS & GYR	MX	C451771	05-19-07	100.0	100.0	100.4
KUE	LANDIS & GYR	MX	C451772	05-19-07	100.0	100.0	99.9
KUE	LANDIS & GYR	MX	C451773	05-18-07	100.0	100.1	100.3
KUE	LANDIS & GYR	MX	C451774	05-19-07	100.0	100.0	100.1
KUE	LANDIS & GYR	MX	C451775	05-19-07	100.0	100.0	100.3
KUE	LANDIS & GYR	MX	C451776	05-18-07	100.1	100.1	100.3
KUE	LANDIS & GYR	MX	C451777	05-18-07	100.1	100.1	100.3
KUE	LANDIS & GYR	MX	C451778	05-18-07	100.0	100.0	100.1
KUE	LANDIS & GYR	MX	C451779	05-19-07	100.1	100.0	100.1
KUE	LANDIS & GYR	MX	C451780	05-18-07	100.1	100.0	100.1
KUE	LANDIS & GYR	MX	C451781	05-19-07	100.0	100.0	100.2
KUE	LANDIS & GYR	MX	C451782	05-19-07	100.1	100.1	100.0
KUE	LANDIS & GYR	MX	C451783	05-19-07	100.1	100.2	100.3
KUE	LANDIS & GYR	MX	C451784	05-19-07	100.1	100.0	100.3
KUE	LANDIS & GYR	MX	C451785	05-19-07	100.0	100.0	99.9
KUE	LANDIS & GYR	MX	C451786	05-19-07	100.1	100.2	100.3
KUE	LANDIS & GYR	MX	C451787	05-19-07	100.1	100.1	99.7
KUE	LANDIS & GYR	MX	C451788	05-19-07	100.0	100.1	100.3
KUE	LANDIS & GYR	MX	C451789	05-19-07	100.0	99.9	100.3
KUE	LANDIS & GYR	MX	C451790	05-19-07	99.9	100.1	99.8
KUE	LANDIS & GYR	MX	C451791	05-19-07	100.0	100.0	100.0
KUE	LANDIS & GYR	MX	C451792	05-19-07	100.1	100.0	99.9
KUE	LANDIS & GYR	MX	C451793	05-19-07	100.1	100.0	100.5
KUE	LANDIS & GYR	MX	C451794	05-19-07	100.0	100.1	100.0
KUE	LANDIS & GYR	MX	C451795	05-18-07	100.1	99.9	100.3
KUE	LANDIS & GYR	MX	C451796	05-19-07	100.0	99.9	100.0
KUE	LANDIS & GYR	MX	C451797	05-19-07	100.1	100.2	99.8
KUE	LANDIS & GYR	MX	C451798	05-19-07	100.0	100.1	100.0
KUE	LANDIS & GYR	MX	C451799	05-19-07	100.0	100.0	99.9
KUE	LANDIS & GYR	MX	C451800	05-19-07	100.1	100.1	100.0
KUE	LANDIS & GYR	MX	C451801	05-19-07	100.0	100.0	99.9
KUE	LANDIS & GYR	MX	C451802	05-18-07	100.1	100.1	100.1
KUE	LANDIS & GYR	MX	C451803	05-19-07	100.1	100.1	100.1

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

CO	MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
KUE	LANDIS & GYR	MX	C451855	05-19-07	100.1	100.2	100.2
KUE	LANDIS & GYR	MX	C451856	05-19-07	100.0	99.9	99.7
KUE	LANDIS & GYR	MX	C451857	05-19-07	100.0	100.0	100.3
KUE	LANDIS & GYR	MX	C451858	05-19-07	100.0	100.2	100.4
KUE	LANDIS & GYR	MX	C451859	05-18-07	100.0	99.9	100.1
KUE	LANDIS & GYR	MX	C451860	05-19-07	100.1	100.1	100.3
KUE	LANDIS & GYR	MX	C451861	05-19-07	100.0	99.9	100.2
KUE	LANDIS & GYR	MX	C451862	05-19-07	100.0	100.2	99.9
KUE	LANDIS & GYR	MX	C451863	05-19-07	100.0	100.1	100.2
KUE	LANDIS & GYR	MX	C451864	05-19-07	100.0	100.0	100.2
KUE	LANDIS & GYR	MX	C451865	05-19-07	100.1	100.1	100.4
KUE	LANDIS & GYR	MX	C451866	05-18-07	100.0	99.9	100.1
KUE	LANDIS & GYR	MX	C451867	05-18-07	100.1	100.0	100.1
KUE	LANDIS & GYR	MX	C451868	05-19-07	100.1	100.1	100.2
KUE	LANDIS & GYR	MX	C451869	05-19-07	100.1	100.0	100.2
KUE	LANDIS & GYR	MX	C451870	05-19-07	100.0	99.9	100.1
KUE	LANDIS & GYR	MX	C451871	05-19-07	100.1	100.1	100.1
KUE	LANDIS & GYR	MX	C451872	05-19-07	100.1	100.1	100.1
KUE	LANDIS & GYR	MX	C451873	05-18-07	100.1	100.1	100.3
KUE	LANDIS & GYR	MX	C451874	05-19-07	100.1	100.0	100.3
KUE	LANDIS & GYR	MX	C451875	05-19-07	100.1	99.9	100.3
KUE	LANDIS & GYR	MX	C451876	05-18-07	99.9	100.0	99.6
KUE	LANDIS & GYR	MX	C451877	05-19-07	100.0	100.0	100.1
KUE	LANDIS & GYR	MX	C451878	05-18-07	100.0	100.0	100.0
KUE	LANDIS & GYR	MX	C451879	05-18-07	100.0	100.1	100.2
KUE	LANDIS & GYR	MX	C451880	05-19-07	100.1	100.0	100.2
KUE	LANDIS & GYR	MX	C451881	05-19-07	100.1	100.1	100.4
KUE	LANDIS & GYR	MX	C451882	05-19-07	100.0	100.0	100.1
KUE	LANDIS & GYR	MX	C451883	05-19-07	100.1	100.1	100.3
KUE	LANDIS & GYR	MX	C451884	05-19-07	100.0	100.0	100.2
KUE	LANDIS & GYR	MX	C451885	05-19-07	100.1	100.0	100.3
KUE	LANDIS & GYR	MX	C451886	05-18-07	100.0	100.2	100.0
KUE	LANDIS & GYR	MX	C451887	05-18-07	100.0	100.0	100.2
KUE	LANDIS & GYR	MX	C451888	05-18-07	100.1	100.0	100.1
KUE	LANDIS & GYR	MX	C451889	05-19-07	100.0	99.9	100.2
KUE	LANDIS & GYR	MX	C451890	05-18-07	100.1	100.0	100.0
KUE	LANDIS & GYR	MX	C451891	05-19-07	100.1	100.1	100.2
KUE	LANDIS & GYR	MX	C451892	05-18-07	100.1	100.1	100.0
KUE	LANDIS & GYR	MX	C451893	05-19-07	100.1	100.0	100.0
KUE	LANDIS & GYR	MX	C451894	05-19-07	100.0	100.0	100.1
KUE	LANDIS & GYR	MX	C451895	05-19-07	100.0	100.0	99.9
KUE	LANDIS & GYR	MX	C451896	05-19-07	100.1	100.2	100.1
KUE	LANDIS & GYR	MX	C451897	05-19-07	100.0	99.9	100.3
KUE	LANDIS & GYR	MX	C451898	05-19-07	100.1	100.0	100.1
KUE	LANDIS & GYR	MX	C451899	05-19-07	100.1	100.0	100.2
KUE	LANDIS & GYR	MX	C451900	05-19-07	100.1	100.1	100.4
KUE	LANDIS & GYR	MX	C451901	05-19-07	100.1	99.9	100.3
KUE	LANDIS & GYR	MX	C451902	05-19-07	100.1	100.1	100.4
KUE	LANDIS & GYR	MX	C451903	05-19-07	100.1	100.0	100.0
KUE	LANDIS & GYR	MX	C451904	05-19-07	100.0	100.0	100.3
KUE	LANDIS & GYR	MX	C451905	05-19-07	100.1	100.1	100.0

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

PAGE 139
 RUN DATE: 1/15/08
 RUN TIME: 22.00.58

CO	MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
KUE	LANDIS & GYR	MX	C451957	05-19-07	100.1	99.9	99.7
KUE	LANDIS & GYR	MX	C451958	05-19-07	100.0	100.0	100.2
KUE	LANDIS & GYR	MX	C451959	05-19-07	100.1	100.0	100.1
KUE	LANDIS & GYR	MX	C451960	05-19-07	100.0	100.0	100.0
KUE	LANDIS & GYR	MX	C451961	05-19-07	100.0	100.1	100.2
KUE	LANDIS & GYR	MX	C451962	05-19-07	100.0	99.9	100.2
KUE	LANDIS & GYR	MX	C451963	05-19-07	100.0	100.0	100.3
KUE	LANDIS & GYR	MX	C451964	05-19-07	100.1	100.0	100.2
KUE	LANDIS & GYR	MX	C451965	05-19-07	100.1	100.2	100.2
KUE	LANDIS & GYR	MX	C451966	05-18-07	100.0	99.9	99.7
KUE	LANDIS & GYR	MX	C451967	05-19-07	100.1	100.1	100.2
KUE	LANDIS & GYR	MX	C451968	05-19-07	100.1	100.0	99.9
KUE	LANDIS & GYR	MX	C451969	05-19-07	100.1	100.1	100.1
KUE	LANDIS & GYR	MX	C451970	05-19-07	100.1	100.1	100.4
KUE	LANDIS & GYR	MX	C451971	05-19-07	100.1	100.0	99.6
KUE	LANDIS & GYR	MX	C451972	05-19-07	100.1	100.1	100.3
KUE	LANDIS & GYR	MX	C451973	05-18-07	100.1	100.0	100.4
KUE	LANDIS & GYR	MX	C451974	05-19-07	100.0	99.9	100.2
KUE	LANDIS & GYR	MX	C451975	05-19-07	100.1	100.0	100.1
KUE	LANDIS & GYR	MX	C451976	05-19-07	100.1	100.0	100.3
KUE	LANDIS & GYR	MX	C451977	05-19-07	100.0	99.9	100.3
KUE	LANDIS & GYR	MX	C451978	05-19-07	100.1	99.9	100.1
KUE	LANDIS & GYR	MX	C451979	05-19-07	100.1	100.0	99.7
KUE	LANDIS & GYR	MX	C451980	05-19-07	100.1	100.0	100.1
KUE	LANDIS & GYR	MX	C451981	05-19-07	100.1	100.1	100.1
KUE	LANDIS & GYR	MX	C451982	05-19-07	100.1	100.0	100.2
KUE	LANDIS & GYR	MX	C451983	05-19-07	100.0	100.0	100.2
KUE	LANDIS & GYR	MX	C451984	05-18-07	100.0	99.9	99.7
KUE	LANDIS & GYR	MX	C451985	05-19-07	100.0	100.1	100.3
KUE	LANDIS & GYR	MX	C451986	05-18-07	100.1	100.0	100.3
KUE	LANDIS & GYR	MX	C451987	05-19-07	100.0	100.0	100.3
KUE	LANDIS & GYR	MX	C451988	05-19-07	100.1	99.9	100.4
KUE	LANDIS & GYR	MX	C451989	05-18-07	100.0	100.0	99.8
KUE	LANDIS & GYR	MX	C451990	05-18-07	100.0	100.0	100.0
KUE	LANDIS & GYR	MX	C451991	05-19-07	100.1	99.9	100.0
KUE	LANDIS & GYR	MX	C451992	05-19-07	100.1	100.2	100.0
KUE	LANDIS & GYR	MX	C451993	05-18-07	100.0	100.0	100.2
KUE	LANDIS & GYR	MX	C451994	05-19-07	100.0	100.1	100.3
KUE	LANDIS & GYR	MX	C451995	05-18-07	100.0	100.0	99.5
KUE	LANDIS & GYR	MX	C451996	05-19-07	100.0	100.1	100.0
KUE	LANDIS & GYR	MX	C451997	05-18-07	100.1	100.1	100.3
KUE	LANDIS & GYR	MX	C451998	05-19-07	100.0	100.0	100.2
KUE	LANDIS & GYR	MX	C451999	05-19-07	99.9	100.0	100.2
KUE	LANDIS & GYR	MX	C452000	05-19-07	100.1	100.1	100.3
KUE	LANDIS & GYR	MX	C452001	05-18-07	100.1	100.2	99.9
KUE	LANDIS & GYR	MX	C452002	05-19-07	100.1	100.1	100.0
KUE	LANDIS & GYR	MX	C452003	05-19-07	100.1	100.1	100.3
KUE	LANDIS & GYR	MX	C452004	05-19-07	100.0	100.0	100.2
KUE	LANDIS & GYR	MX	C452005	05-19-07	100.1	100.0	100.2
KUE	LANDIS & GYR	MX	C452006	05-19-07	100.1	99.9	100.3
KUE	LANDIS & GYR	MX	C452007	05-19-07	100.1	100.1	100.0

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

PAGE 141
 RUN DATE: 1/15/08
 RUN TIME: 22.00.58

CO	MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
KUE	LANDIS & GYR	MX	C452059	05-19-07	100.1	100.2	100.5
KUE	LANDIS & GYR	MX	C452060	05-19-07	100.1	100.0	100.3
KUE	LANDIS & GYR	MX	C452061	05-18-07	100.1	99.9	100.1
KUE	LANDIS & GYR	MX	C452062	05-19-07	100.1	100.0	100.0
KUE	LANDIS & GYR	MX	C452063	05-19-07	100.0	100.1	100.1
KUE	LANDIS & GYR	MX	C452064	05-18-07	100.0	100.0	100.3
KUE	LANDIS & GYR	MX	C452065	05-19-07	100.0	100.0	100.0
KUE	LANDIS & GYR	MX	C452066	05-18-07	100.1	100.1	100.2
KUE	LANDIS & GYR	MX	C452067	05-19-07	100.1	100.0	100.3
KUE	LANDIS & GYR	MX	C452068	05-18-07	100.0	99.9	100.1
KUE	LANDIS & GYR	MX	C452069	05-18-07	100.0	99.9	99.9
KUE	LANDIS & GYR	MX	C452070	05-19-07	100.1	100.2	100.5
KUE	LANDIS & GYR	MX	C452071	05-19-07	100.1	100.0	100.0
KUE	LANDIS & GYR	MX	C452072	05-18-07	100.0	100.0	100.2
KUE	LANDIS & GYR	MX	C452073	05-18-07	100.1	99.9	100.1
KUE	LANDIS & GYR	MX	C452074	05-18-07	100.0	100.0	100.3
KUE	LANDIS & GYR	MX	C452075	05-19-07	100.0	100.0	100.1
KUE	LANDIS & GYR	MX	C452076	05-18-07	100.1	99.9	100.3
KUE	LANDIS & GYR	MX	C452077	05-18-07	100.0	99.9	100.2
KUE	LANDIS & GYR	MX	C452078	05-18-07	100.1	99.9	100.2
KUE	LANDIS & GYR	MX	C452079	05-18-07	100.0	99.9	100.2
KUE	LANDIS & GYR	MX	C452080	05-18-07	100.1	99.9	100.2
KUE	LANDIS & GYR	MX	C452081	05-18-07	100.0	99.9	100.2
KUE	LANDIS & GYR	MX	C452082	05-19-07	100.1	100.1	100.4
KUE	LANDIS & GYR	MX	C452083	05-18-07	100.1	100.0	100.1
KUE	LANDIS & GYR	MX	C452084	05-19-07	100.1	100.1	100.0
KUE	LANDIS & GYR	MX	C452085	05-18-07	100.0	99.9	100.1
KUE	LANDIS & GYR	MX	C452086	05-18-07	100.0	100.1	100.3
KUE	LANDIS & GYR	MX	C452087	05-18-07	100.1	99.9	99.5
KUE	LANDIS & GYR	MX	C452088	05-18-07	100.0	99.9	99.6
KUE	LANDIS & GYR	MX	C452089	05-18-07	100.0	100.0	99.7
KUE	LANDIS & GYR	MX	C452090	05-18-07	100.0	100.1	100.0
KUE	LANDIS & GYR	MX	C452091	05-18-07	100.0	100.1	100.2
KUE	LANDIS & GYR	MX	C452092	05-18-07	100.0	100.0	100.2
KUE	LANDIS & GYR	MX	C452093	05-18-07	100.1	99.9	100.0
KUE	LANDIS & GYR	MX	C452094	05-19-07	100.0	99.9	100.0
KUE	LANDIS & GYR	MX	C452095	05-19-07	100.0	100.0	100.3
KUE	LANDIS & GYR	MX	C452096	05-19-07	100.1	99.9	100.2
KUE	LANDIS & GYR	MX	C452097	05-18-07	100.1	100.0	100.1
KUE	LANDIS & GYR	MX	C452098	05-18-07	100.0	100.0	100.1
KUE	LANDIS & GYR	MX	C452099	05-18-07	100.0	100.0	100.2
KUE	LANDIS & GYR	MX	C452100	05-18-07	100.0	100.0	100.2
KUE	LANDIS & GYR	MX	C452101	05-18-07	100.1	100.0	100.3
KUE	LANDIS & GYR	MX	C452102	05-18-07	100.0	100.0	100.1
KUE	LANDIS & GYR	MX	C452103	05-18-07	100.0	99.9	100.1
KUE	LANDIS & GYR	MX	C452104	05-18-07	100.0	99.9	100.3
KUE	LANDIS & GYR	MX	C452105	05-18-07	100.1	100.4	100.4
KUE	LANDIS & GYR	MX	C452106	05-18-07	100.0	100.0	100.5
KUE	LANDIS & GYR	MX	C452107	07-16-07	100.1	100.1	100.3
KUE	LANDIS & GYR	MX	C452108	07-16-07	100.0	100.0	100.4
KUE	LANDIS & GYR	MX	C452109	07-16-07	100.1	100.2	100.4

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

CO	MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
KUE	LANDIS & GYR	MX	C452161	07-16-07	100.1	100.0	100.1
KUE	LANDIS & GYR	MX	C452162	07-16-07	100.1	100.0	100.2
KUE	LANDIS & GYR	MX	C452163	07-16-07	100.0	99.9	99.7
KUE	LANDIS & GYR	MX	C452164	07-16-07	100.0	99.9	99.6
KUE	LANDIS & GYR	MX	C452165	07-16-07	100.1	100.1	100.1
KUE	LANDIS & GYR	MX	C452166	07-16-07	100.1	100.1	100.0
KUE	LANDIS & GYR	MX	C452167	07-16-07	100.1	100.1	100.2
KUE	LANDIS & GYR	MX	C452168	07-16-07	100.0	100.1	100.2
KUE	LANDIS & GYR	MX	C452169	07-16-07	100.1	100.1	100.2
KUE	LANDIS & GYR	MX	C452170	07-16-07	100.0	100.0	99.7
KUE	LANDIS & GYR	MX	C452171	07-16-07	100.1	100.1	100.0
KUE	LANDIS & GYR	MX	C452172	07-16-07	100.1	100.1	99.6
KUE	LANDIS & GYR	MX	C452173	07-16-07	100.1	100.2	100.0
KUE	LANDIS & GYR	MX	C452174	07-16-07	100.0	100.0	100.1
KUE	LANDIS & GYR	MX	C452175	07-16-07	100.0	99.9	100.0
KUE	LANDIS & GYR	MX	C452176	07-16-07	100.0	100.1	100.0
KUE	LANDIS & GYR	MX	C452177	07-16-07	100.0	100.0	100.0
KUE	LANDIS & GYR	MX	C452178	07-16-07	100.0	100.0	100.1
KUE	LANDIS & GYR	MX	C452179	07-16-07	100.0	100.0	100.1
KUE	LANDIS & GYR	MX	C452180	07-16-07	100.0	100.2	100.4
KUE	LANDIS & GYR	MX	C452181	07-16-07	100.0	100.1	100.2
KUE	LANDIS & GYR	MX	C452182	07-16-07	100.1	100.1	99.5
KUE	LANDIS & GYR	MX	C452183	07-16-07	100.0	100.0	100.2
KUE	LANDIS & GYR	MX	C452184	07-16-07	100.0	100.1	99.8
KUE	LANDIS & GYR	MX	C452185	07-16-07	100.0	100.1	99.8
KUE	LANDIS & GYR	MX	C452186	07-16-07	100.1	100.0	99.6
KUE	LANDIS & GYR	MX	C452187	07-16-07	100.1	100.1	100.0
KUE	LANDIS & GYR	MX	C452188	07-16-07	100.1	100.0	99.9
KUE	LANDIS & GYR	MX	C452189	07-16-07	100.0	100.0	99.9
KUE	LANDIS & GYR	MX	C452190	07-16-07	100.0	100.1	100.0
KUE	LANDIS & GYR	MX	C452191	07-16-07	100.0	100.0	100.1
KUE	LANDIS & GYR	MX	C452192	07-16-07	100.0	100.0	100.1
KUE	LANDIS & GYR	MX	C452193	07-16-07	100.1	100.1	100.2
KUE	LANDIS & GYR	MX	C452194	07-16-07	100.1	100.2	100.4
KUE	LANDIS & GYR	MX	C452195	07-16-07	100.1	100.0	100.0
KUE	LANDIS & GYR	MX	C452196	07-16-07	100.1	100.0	100.1
KUE	LANDIS & GYR	MX	C452197	07-16-07	100.1	100.0	100.3
KUE	LANDIS & GYR	MX	C452198	07-16-07	100.0	100.0	99.9
KUE	LANDIS & GYR	MX	C452199	07-16-07	100.1	100.1	100.0
KUE	LANDIS & GYR	MX	C452200	07-16-07	100.1	100.1	100.0
KUE	LANDIS & GYR	MX	C452201	07-16-07	100.0	100.2	99.8
KUE	LANDIS & GYR	MX	C452202	07-16-07	100.0	100.2	99.9
KUE	LANDIS & GYR	MX	C452203	07-16-07	100.1	100.2	100.0
KUE	LANDIS & GYR	MX	C452204	07-16-07	100.0	100.1	99.9
KUE	LANDIS & GYR	MX	C452205	07-16-07	100.0	99.9	100.0
KUE	LANDIS & GYR	MX	C452206	07-16-07	100.1	100.1	100.2
KUE	LANDIS & GYR	MX	C452207	07-16-07	100.1	100.0	100.0
KUE	LANDIS & GYR	MX	C452208	07-16-07	100.0	99.9	100.0
KUE	LANDIS & GYR	MX	C452209	07-16-07	100.1	100.1	99.9
KUE	LANDIS & GYR	MX	C452210	07-16-07	100.1	100.0	99.8
KUE	LANDIS & GYR	MX	C452211	07-16-07	100.1	100.1	100.1

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

CO	MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
KUE	LANDIS & GYR	MX	C452263	07-16-07	100.0	100.0	99.8
KUE	LANDIS & GYR	MX	C452264	07-16-07	100.0	100.0	100.0
KUE	LANDIS & GYR	MX	C452265	07-16-07	100.0	100.0	100.4
KUE	LANDIS & GYR	MX	C452266	07-16-07	100.1	100.1	100.2
KUE	LANDIS & GYR	MX	C452267	07-16-07	100.1	100.1	99.7
KUE	LANDIS & GYR	MX	C452268	07-16-07	100.0	99.9	99.8
KUE	LANDIS & GYR	MX	C452269	07-16-07	100.0	100.0	100.1
KUE	LANDIS & GYR	MX	C452270	07-16-07	100.1	100.1	99.8
KUE	LANDIS & GYR	MX	C452271	07-16-07	100.1	99.9	99.7
KUE	LANDIS & GYR	MX	C452272	07-16-07	100.1	100.0	99.8
KUE	LANDIS & GYR	MX	C452273	07-16-07	100.0	100.0	100.0
KUE	LANDIS & GYR	MX	C452274	07-16-07	100.1	100.1	100.0
KUE	LANDIS & GYR	MX	C452275	07-16-07	100.0	100.1	99.8
KUE	LANDIS & GYR	MX	C452276	07-16-07	100.1	100.1	100.1
KUE	LANDIS & GYR	MX	C452277	07-16-07	100.0	100.2	100.1
KUE	LANDIS & GYR	MX	C452278	07-16-07	100.0	100.0	100.1
KUE	LANDIS & GYR	MX	C452279	07-16-07	100.0	100.0	100.2
KUE	LANDIS & GYR	MX	C452280	07-16-07	100.1	100.1	99.6
KUE	LANDIS & GYR	MX	C452281	07-16-07	100.1	100.2	100.0
KUE	LANDIS & GYR	MX	C452282	07-16-07	100.1	100.1	100.2
KUE	LANDIS & GYR	MX	C452283	07-16-07	100.0	99.9	100.2
KUE	LANDIS & GYR	MX	C452284	07-16-07	100.1	100.0	99.8
KUE	LANDIS & GYR	MX	C452285	07-16-07	100.1	100.1	100.1
KUE	LANDIS & GYR	MX	C452286	07-16-07	100.0	99.9	99.9
KUE	LANDIS & GYR	MX	C452287	07-16-07	100.1	100.0	100.4
KUE	LANDIS & GYR	MX	C452288	07-16-07	100.0	100.0	100.1
KUE	LANDIS & GYR	MX	C452289	07-16-07	100.1	100.0	100.2
KUE	LANDIS & GYR	MX	C452290	07-16-07	100.0	100.0	99.9
KUE	LANDIS & GYR	MX	C452291	07-16-07	100.1	100.1	100.1
KUE	LANDIS & GYR	MX	C452292	07-16-07	100.1	100.0	100.1
KUE	LANDIS & GYR	MX	C452293	07-16-07	100.1	100.1	100.1
KUE	LANDIS & GYR	MX	C452294	07-16-07	100.1	99.9	100.2
KUE	LANDIS & GYR	MX	C452295	07-16-07	100.0	100.1	100.3
KUE	LANDIS & GYR	MX	C452296	07-16-07	100.1	100.1	100.3
KUE	LANDIS & GYR	MX	C452297	07-16-07	100.0	100.2	100.3
KUE	LANDIS & GYR	MX	C452298	07-16-07	100.1	100.2	100.2
KUE	LANDIS & GYR	MX	C452299	07-16-07	100.1	100.1	100.2
KUE	LANDIS & GYR	MX	C452300	07-16-07	100.1	100.1	99.8
KUE	LANDIS & GYR	MX	C452301	07-16-07	100.0	100.1	99.8
KUE	LANDIS & GYR	MX	C452302	07-16-07	100.1	100.0	100.0
KUE	LANDIS & GYR	MX	C452303	07-16-07	100.1	100.2	100.0
KUE	LANDIS & GYR	MX	C452304	07-16-07	100.1	100.1	100.2
KUE	LANDIS & GYR	MX	C452305	07-16-07	100.1	100.1	99.8
KUE	LANDIS & GYR	MX	C452306	07-16-07	100.0	100.0	100.0
KUE	LANDIS & GYR	MX	C452307	07-16-07	100.1	100.1	100.0
KUE	LANDIS & GYR	MX	C452308	07-16-07	100.1	100.1	99.9
KUE	LANDIS & GYR	MX	C452309	07-16-07	100.1	100.1	100.0
KUE	LANDIS & GYR	MX	C452310	07-16-07	100.1	100.2	99.8
KUE	LANDIS & GYR	MX	C452311	07-16-07	100.0	100.1	99.9
KUE	LANDIS & GYR	MX	C452312	07-16-07	100.0	100.1	100.3
KUE	LANDIS & GYR	MX	C452313	07-16-07	100.1	100.1	100.6

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

CO	MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
KUE	LANDIS & GYR	MX	C452365	07-16-07	100.1	100.0	99.9
KUE	LANDIS & GYR	MX	C452366	07-16-07	100.0	100.0	100.2
KUE	LANDIS & GYR	MX	C452367	07-16-07	100.1	100.1	100.1
KUE	LANDIS & GYR	MX	C452368	07-16-07	100.0	99.9	100.1
KUE	LANDIS & GYR	MX	C452369	07-16-07	100.0	100.1	100.3
KUE	LANDIS & GYR	MX	C452370	07-16-07	100.0	100.0	99.7
KUE	LANDIS & GYR	MX	C452371	07-16-07	100.0	100.0	100.0
KUE	LANDIS & GYR	MX	C452372	07-16-07	100.0	100.2	100.2
KUE	LANDIS & GYR	MX	C452373	07-16-07	100.1	100.1	100.0
KUE	LANDIS & GYR	MX	C452374	07-16-07	100.0	100.0	100.0
KUE	LANDIS & GYR	MX	C452375	07-16-07	100.0	100.0	100.0
KUE	LANDIS & GYR	MX	C452376	07-16-07	100.1	100.1	99.9
KUE	LANDIS & GYR	MX	C452377	07-16-07	100.0	100.1	99.9
KUE	LANDIS & GYR	MX	C452378	07-16-07	100.1	100.0	100.2
KUE	LANDIS & GYR	MX	C452379	07-16-07	100.1	100.1	100.0
KUE	LANDIS & GYR	MX	C452380	07-16-07	100.0	99.9	100.4
KUE	LANDIS & GYR	MX	C452381	07-16-07	100.0	100.1	100.1
KUE	LANDIS & GYR	MX	C452382	07-16-07	100.0	99.9	100.1
KUE	LANDIS & GYR	MX	C452383	07-16-07	100.0	99.9	100.4
KUE	LANDIS & GYR	MX	C452384	07-16-07	100.0	99.9	100.3
KUE	LANDIS & GYR	MX	C452385	07-16-07	99.9	100.0	100.0
KUE	LANDIS & GYR	MX	C452386	07-16-07	100.0	100.0	99.8
KUE	LANDIS & GYR	MX	C452387	07-16-07	100.1	100.2	100.2
KUE	LANDIS & GYR	MX	C452388	07-16-07	100.1	100.0	99.8
KUE	LANDIS & GYR	MX	C452389	07-16-07	100.0	100.0	100.3
KUE	LANDIS & GYR	MX	C452390	07-16-07	100.0	100.0	99.9
KUE	LANDIS & GYR	MX	C452391	07-16-07	100.0	100.0	100.2
KUE	LANDIS & GYR	MX	C452392	07-16-07	100.0	100.0	100.3
KUE	LANDIS & GYR	MX	C452393	07-16-07	100.1	100.1	99.9
KUE	LANDIS & GYR	MX	C452394	07-16-07	100.1	100.0	100.3
KUE	LANDIS & GYR	MX	C452395	07-16-07	100.0	100.0	100.2
KUE	LANDIS & GYR	MX	C452396	07-16-07	100.0	100.1	100.4
KUE	LANDIS & GYR	MX	C452397	07-16-07	100.0	99.9	100.2
KUE	LANDIS & GYR	MX	C452398	07-16-07	100.0	100.1	100.1
KUE	LANDIS & GYR	MX	C452399	07-16-07	100.0	99.9	99.7
KUE	LANDIS & GYR	MX	C452400	07-16-07	100.1	100.0	100.1
KUE	LANDIS & GYR	MX	C452401	07-16-07	100.0	100.0	100.2
KUE	LANDIS & GYR	MX	C452402	07-16-07	100.0	100.1	100.2
KUE	LANDIS & GYR	MX	C452403	07-16-07	100.0	100.1	100.5
KUE	LANDIS & GYR	MX	C452404	07-16-07	100.0	100.2	99.8
KUE	LANDIS & GYR	MX	C452405	07-16-07	100.0	100.0	100.0
KUE	LANDIS & GYR	MX	C452406	07-16-07	100.0	100.2	100.2
KUE	LANDIS & GYR	MX	C452407	07-16-07	100.0	100.0	100.3
KUE	LANDIS & GYR	MX	C452408	07-16-07	100.0	99.9	99.6
KUE	LANDIS & GYR	MX	C452409	07-16-07	100.0	99.9	100.3
KUE	LANDIS & GYR	MX	C452410	07-16-07	100.1	100.2	100.4
KUE	LANDIS & GYR	MX	C452411	07-16-07	100.0	100.0	99.8
KUE	LANDIS & GYR	MX	C452412	07-16-07	100.0	100.0	100.1
KUE	LANDIS & GYR	MX	C452413	07-16-07	100.1	100.0	100.4
KUE	LANDIS & GYR	MX	C452414	07-16-07	100.1	100.1	100.0
KUE	LANDIS & GYR	MX	C452415	07-16-07	100.0	100.2	100.0
KUE	LANDIS & GYR	MX	C452415	07-16-07	100.0	100.0	100.3

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

CO	MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
KUE	LANDIS & GYR	MX	C452467	07-16-07	100.0	100.2	100.1
KUE	LANDIS & GYR	MX	C452468	07-16-07	100.1	100.1	100.1
KUE	LANDIS & GYR	MX	C452469	07-16-07	100.1	100.1	100.2
KUE	LANDIS & GYR	MX	C452470	07-16-07	100.0	100.0	99.7
KUE	LANDIS & GYR	MX	C452471	07-16-07	100.0	100.1	100.2
KUE	LANDIS & GYR	MX	C452472	07-16-07	100.1	100.0	99.8
KUE	LANDIS & GYR	MX	C452473	07-16-07	100.0	100.1	100.1
KUE	LANDIS & GYR	MX	C452474	07-16-07	100.0	100.0	100.1
KUE	LANDIS & GYR	MX	C452475	07-16-07	100.0	100.0	100.4
KUE	LANDIS & GYR	MX	C452476	07-16-07	100.1	100.0	100.5
KUE	LANDIS & GYR	MX	C452477	07-16-07	100.0	100.0	100.0
KUE	LANDIS & GYR	MX	C452478	07-16-07	100.1	100.2	100.0
KUE	LANDIS & GYR	MX	C452479	07-16-07	100.1	100.1	100.1
KUE	LANDIS & GYR	MX	C452480	07-16-07	100.1	100.0	100.3
KUE	LANDIS & GYR	MX	C452481	07-16-07	100.0	100.1	100.3
KUE	LANDIS & GYR	MX	C452482	07-16-07	100.0	100.0	100.3
KUE	LANDIS & GYR	MX	C452483	07-16-07	100.1	100.0	100.3
KUE	LANDIS & GYR	MX	C452484	07-16-07	100.0	100.1	100.3
KUE	LANDIS & GYR	MX	C452485	07-16-07	100.1	100.1	99.9
KUE	LANDIS & GYR	MX	C452486	07-16-07	100.1	100.0	99.9
KUE	LANDIS & GYR	MX	C452487	07-16-07	100.1	100.0	100.0
KUE	LANDIS & GYR	MX	C452488	07-16-07	100.1	100.0	100.2
KUE	LANDIS & GYR	MX	C452489	07-16-07	100.1	99.9	99.8
KUE	LANDIS & GYR	MX	C452490	07-16-07	100.1	100.2	100.1
KUE	LANDIS & GYR	MX	C452491	07-16-07	99.9	100.2	100.3
KUE	LANDIS & GYR	MX	C452492	07-16-07	100.0	100.1	99.9
KUE	LANDIS & GYR	MX	C452493	07-16-07	100.1	100.1	99.6
KUE	LANDIS & GYR	MX	C452494	07-16-07	100.0	100.0	100.1
KUE	LANDIS & GYR	MX	C452495	07-16-07	100.1	100.1	100.2
KUE	LANDIS & GYR	MX	C452496	07-16-07	100.0	100.1	100.3
KUE	LANDIS & GYR	MX	C452497	07-16-07	100.0	100.0	100.2
KUE	LANDIS & GYR	MX	C452498	07-16-07	100.0	100.0	100.2
KUE	LANDIS & GYR	MX	C452499	07-16-07	100.1	100.1	100.3
KUE	LANDIS & GYR	MX	C452500	07-16-07	100.0	99.9	100.0
KUE	LANDIS & GYR	MX	C452501	07-16-07	100.0	99.9	99.9
KUE	LANDIS & GYR	MX	C452502	07-16-07	100.1	100.0	100.5
KUE	LANDIS & GYR	MX	C452503	07-16-07	100.0	100.2	100.0
KUE	LANDIS & GYR	MX	C452504	07-16-07	100.0	99.9	99.6
KUE	LANDIS & GYR	MX	C452505	07-16-07	100.0	100.1	100.2
KUE	LANDIS & GYR	MX	C452506	07-16-07	100.0	99.9	100.6
KUE	LANDIS & GYR	MX	C452507	07-16-07	100.1	100.0	100.6
KUE	LANDIS & GYR	MX	C452508	07-16-07	100.1	100.0	100.0
KUE	LANDIS & GYR	MX	C452509	07-16-07	100.0	100.0	100.0
KUE	LANDIS & GYR	MX	C452510	07-16-07	100.1	99.9	100.0
KUE	LANDIS & GYR	MX	C452511	07-16-07	100.0	100.1	100.0
KUE	LANDIS & GYR	MX	C452512	07-16-07	100.0	100.0	99.9
KUE	LANDIS & GYR	MX	C452513	07-16-07	100.1	100.0	100.1
KUE	LANDIS & GYR	MX	C452514	07-16-07	100.0	100.2	100.0
KUE	LANDIS & GYR	MX	C452515	07-16-07	100.1	100.1	100.2
KUE	LANDIS & GYR	MX	C452516	07-16-07	100.1	100.1	100.2
KUE	LANDIS & GYR	MX	C452517	07-16-07	100.1	100.1	100.2

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

CO	MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACOR
KUE	LANDIS & GYR	MX	C452569	07-16-07	100.1	100.1	99.7
KUE	LANDIS & GYR	MX	C452570	07-16-07	100.0	100.0	99.7
KUE	LANDIS & GYR	MX	C452571	07-16-07	100.0	100.0	100.2
KUE	LANDIS & GYR	MX	C452572	07-16-07	100.1	100.1	100.2
KUE	LANDIS & GYR	MX	C452573	07-16-07	100.0	100.0	100.2
KUE	LANDIS & GYR	MX	C452574	07-16-07	100.0	100.0	100.1
KUE	LANDIS & GYR	MX	C452575	07-16-07	100.1	100.1	100.3
KUE	LANDIS & GYR	MX	C452576	07-16-07	100.0	100.0	100.2
KUE	LANDIS & GYR	MX	C452577	07-16-07	100.0	100.0	100.1
KUE	LANDIS & GYR	MX	C452578	07-16-07	100.1	100.1	99.9
KUE	LANDIS & GYR	MX	C452579	07-16-07	100.1	100.1	99.9
KUE	LANDIS & GYR	MX	C452580	07-16-07	100.1	100.1	99.7
KUE	LANDIS & GYR	MX	C452581	07-16-07	100.0	100.0	100.1
KUE	LANDIS & GYR	MX	C452582	07-16-07	100.1	100.1	99.9
KUE	LANDIS & GYR	MX	C452583	07-16-07	100.1	100.1	99.9
KUE	LANDIS & GYR	MX	C452584	07-16-07	100.0	100.0	100.1
KUE	LANDIS & GYR	MX	C452585	07-16-07	100.1	100.1	100.4
KUE	LANDIS & GYR	MX	C452586	07-16-07	100.0	100.0	100.1
KUE	LANDIS & GYR	MX	C452587	07-16-07	100.0	100.0	100.1
KUE	LANDIS & GYR	MX	C452588	07-16-07	100.0	100.0	100.0
KUE	LANDIS & GYR	MX	C452589	07-16-07	100.1	100.1	99.9
KUE	LANDIS & GYR	MX	C452590	07-16-07	100.0	100.0	100.2
KUE	LANDIS & GYR	MX	C452591	07-16-07	100.1	100.1	100.2
KUE	LANDIS & GYR	MX	C452592	07-16-07	100.1	100.1	100.2
KUE	LANDIS & GYR	MX	C452593	07-16-07	100.1	100.1	99.9
KUE	LANDIS & GYR	MX	C452594	07-16-07	100.1	100.1	99.9
KUE	LANDIS & GYR	MX	C452595	07-16-07	100.1	100.1	99.9
KUE	LANDIS & GYR	MX	C452596	07-16-07	100.1	100.1	99.9
KUE	LANDIS & GYR	MX	C452597	07-16-07	100.1	100.1	100.0
KUE	LANDIS & GYR	MX	C452598	07-16-07	100.1	100.1	100.0
KUE	LANDIS & GYR	MX	C452599	07-16-07	100.0	100.0	99.8
KUE	LANDIS & GYR	MX	C452600	07-16-07	100.1	100.1	100.1
KUE	LANDIS & GYR	MX	C452601	07-16-07	100.1	100.1	100.0
KUE	LANDIS & GYR	MX	C452602	07-16-07	100.0	100.0	100.0
KUE	LANDIS & GYR	MX	C452603	07-16-07	100.1	100.1	100.0
KUE	LANDIS & GYR	MX	C452604	07-16-07	100.0	100.0	100.0
KUE	LANDIS & GYR	MX	C452605	07-16-07	100.0	100.0	99.9
KUE	LANDIS & GYR	MX	C452606	07-16-07	100.1	100.1	100.0
KUE	LANDIS & GYR	MX	C452607	07-16-07	100.1	100.1	100.0
KUE	LANDIS & GYR	MX	C452608	07-16-07	100.1	100.1	100.0
KUE	LANDIS & GYR	MX	C452609	07-16-07	100.1	100.1	100.0
KUE	LANDIS & GYR	MX	C452610	07-16-07	100.1	100.1	100.0
KUE	LANDIS & GYR	MX	C452611	07-16-07	100.0	100.0	100.0
KUE	LANDIS & GYR	MX	C452612	07-16-07	100.1	100.1	99.9
KUE	LANDIS & GYR	MX	C452613	07-16-07	100.0	100.0	99.9
KUE	LANDIS & GYR	MX	C452614	07-16-07	100.1	100.1	99.9
KUE	LANDIS & GYR	MX	C452615	07-16-07	100.1	100.1	99.7
KUE	LANDIS & GYR	MX	C452616	07-16-07	100.1	100.1	100.0
KUE	LANDIS & GYR	MX	C452617	07-16-07	100.1	100.1	100.0
KUE	LANDIS & GYR	MX	C452618	07-16-07	100.0	100.0	100.0
KUE	LANDIS & GYR	MX	C452619	07-16-07	100.1	100.1	100.0

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

CO	MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
KUE	LANDIS & GYR	MX	C452671	07-17-07	100.0	100.0	99.7
KUE	LANDIS & GYR	MX	C452672	07-17-07	100.1	100.1	99.6
KUE	LANDIS & GYR	MX	C452673	07-17-07	100.1	100.1	100.2
KUE	LANDIS & GYR	MX	C452674	07-17-07	100.0	100.0	100.4
KUE	LANDIS & GYR	MX	C452675	07-17-07	100.1	100.1	100.0
KUE	LANDIS & GYR	MX	C452676	07-17-07	100.0	100.1	100.3
KUE	LANDIS & GYR	MX	C452677	07-17-07	100.0	99.9	100.0
KUE	LANDIS & GYR	MX	C452678	07-17-07	100.1	100.1	100.2
KUE	LANDIS & GYR	MX	C452679	07-17-07	100.1	100.1	99.7
KUE	LANDIS & GYR	MX	C452680	07-17-07	100.1	100.1	99.9
KUE	LANDIS & GYR	MX	C452681	07-17-07	100.0	100.0	99.8
KUE	LANDIS & GYR	MX	C452682	07-17-07	100.1	100.1	99.9
KUE	LANDIS & GYR	MX	C452683	07-17-07	100.1	100.1	100.2
KUE	LANDIS & GYR	MX	C452684	07-17-07	100.0	100.0	100.2
KUE	LANDIS & GYR	MX	C452685	07-17-07	100.0	100.1	99.9
KUE	LANDIS & GYR	MX	C452686	07-17-07	100.0	100.1	99.9
KUE	LANDIS & GYR	MX	C452687	07-17-07	100.1	100.1	99.9
KUE	LANDIS & GYR	MX	C452688	07-17-07	100.0	100.0	100.2
KUE	LANDIS & GYR	MX	C452689	07-17-07	100.0	100.0	100.2
KUE	LANDIS & GYR	MX	C452690	07-17-07	100.1	100.1	99.8
KUE	LANDIS & GYR	MX	C452691	07-17-07	100.0	100.0	100.0
KUE	LANDIS & GYR	MX	C452692	07-17-07	100.1	100.2	100.2
KUE	LANDIS & GYR	MX	C452693	07-17-07	100.1	100.0	100.2
KUE	LANDIS & GYR	MX	C452694	07-17-07	100.0	100.0	100.2
KUE	LANDIS & GYR	MX	C452695	07-17-07	100.0	100.0	100.2
KUE	LANDIS & GYR	MX	C452696	07-17-07	100.0	99.9	99.7
KUE	LANDIS & GYR	MX	C452697	07-17-07	100.1	100.2	100.3
KUE	LANDIS & GYR	MX	C452698	07-17-07	100.1	100.1	100.1
KUE	LANDIS & GYR	MX	C452699	07-17-07	100.1	100.1	99.9
KUE	LANDIS & GYR	MX	C452700	07-17-07	100.1	100.0	100.3
KUE	LANDIS & GYR	MX	C452701	07-17-07	100.0	100.2	99.8
KUE	LANDIS & GYR	MX	C452702	07-17-07	100.1	100.1	100.1
KUE	LANDIS & GYR	MX	C452703	07-17-07	100.0	100.0	100.0
KUE	LANDIS & GYR	MX	C452704	07-17-07	100.0	100.0	99.9
KUE	LANDIS & GYR	MX	C452705	07-17-07	100.0	100.2	100.1
KUE	LANDIS & GYR	MX	C452706	07-17-07	100.0	99.9	100.1
KUE	LANDIS & GYR	MX	C452707	07-17-07	100.1	100.0	100.0
KUE	LANDIS & GYR	MX	C452708	07-17-07	100.0	100.1	100.1
KUE	LANDIS & GYR	MX	C452709	07-17-07	100.1	100.0	100.2
KUE	LANDIS & GYR	MX	C452710	07-17-07	100.1	100.0	100.2
KUE	LANDIS & GYR	MX	C452711	07-17-07	100.0	100.0	100.3
KUE	LANDIS & GYR	MX	C452712	07-17-07	100.1	100.1	99.9
KUE	LANDIS & GYR	MX	C452713	07-17-07	100.0	100.0	99.8
KUE	LANDIS & GYR	MX	C452714	07-17-07	100.1	100.0	99.1
KUE	LANDIS & GYR	MX	C452715	07-17-07	100.0	100.1	99.8
KUE	LANDIS & GYR	MX	C452716	07-17-07	100.1	99.9	100.1
KUE	LANDIS & GYR	MX	C452717	07-17-07	100.1	100.1	100.2
KUE	LANDIS & GYR	MX	C452718	07-17-07	100.1	100.1	100.3
KUE	LANDIS & GYR	MX	C452719	07-17-07	100.0	100.2	99.8
KUE	LANDIS & GYR	MX	C452720	07-17-07	100.1	100.0	99.9
KUE	LANDIS & GYR	MX	C452721	07-17-07	100.0	100.1	100.1

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

CO	MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
KUE	LANDIS & GYR	MX	C452875	07-17-07	100.0	100.1	100.3
KUE	LANDIS & GYR	MX	C452876	07-17-07	100.0	100.0	99.8
KUE	LANDIS & GYR	MX	C452877	07-17-07	100.0	100.0	100.0
KUE	LANDIS & GYR	MX	C452878	07-17-07	100.0	100.0	100.1
KUE	LANDIS & GYR	MX	C452879	07-17-07	100.0	99.9	100.1
KUE	LANDIS & GYR	MX	C452880	07-17-07	100.1	100.1	100.3
KUE	LANDIS & GYR	MX	C452881	07-17-07	100.0	99.9	100.1
KUE	LANDIS & GYR	MX	C452882	07-17-07	100.1	100.1	100.1
KUE	LANDIS & GYR	MX	C452883	07-17-07	100.0	100.0	99.19
KUE	LANDIS & GYR	MX	C452884	07-17-07	100.0	100.0	100.1
KUE	LANDIS & GYR	MX	C452885	07-17-07	99.9	100.0	100.1
KUE	LANDIS & GYR	MX	C452886	07-17-07	100.1	100.2	100.1
KUE	LANDIS & GYR	MX	C452887	07-17-07	100.1	100.2	100.4
KUE	LANDIS & GYR	MX	C452888	07-17-07	100.1	100.1	99.8
KUE	LANDIS & GYR	MX	C452889	07-17-07	100.1	100.0	100.1
KUE	LANDIS & GYR	MX	C452890	07-17-07	100.0	100.0	100.2
KUE	LANDIS & GYR	MX	C452891	07-17-07	100.0	100.2	100.2
KUE	LANDIS & GYR	MX	C452892	07-17-07	100.1	100.1	99.9
KUE	LANDIS & GYR	MX	C452893	07-17-07	100.0	100.0	100.4
KUE	LANDIS & GYR	MX	C452894	07-17-07	100.0	100.0	100.3
KUE	LANDIS & GYR	MX	C452895	07-17-07	100.1	100.1	100.0
KUE	LANDIS & GYR	MX	C452896	07-17-07	100.0	100.2	100.0
KUE	LANDIS & GYR	MX	C452897	07-17-07	100.1	100.0	100.2
KUE	LANDIS & GYR	MX	C452898	07-17-07	100.1	100.1	99.5
KUE	LANDIS & GYR	MX	C452899	07-17-07	100.1	100.1	99.9
KUE	LANDIS & GYR	MX	C452900	07-17-07	100.1	100.1	99.8
KUE	LANDIS & GYR	MX	C452901	07-17-07	100.1	100.1	100.1
KUE	LANDIS & GYR	MX	C452902	07-17-07	100.1	100.1	99.8
KUE	LANDIS & GYR	MX	C452903	07-17-07	100.1	100.1	100.0
KUE	LANDIS & GYR	MX	C452904	07-17-07	100.1	100.0	99.9
KUE	LANDIS & GYR	MX	C452905	07-17-07	100.0	99.9	100.0
KUE	LANDIS & GYR	MX	C452906	07-17-07	100.0	100.2	99.9
KUE	LANDIS & GYR	MX	C452907	07-17-07	100.0	100.0	99.6
KUE	LANDIS & GYR	MX	C452908	07-17-07	100.0	100.2	99.7
KUE	LANDIS & GYR	MX	C452909	07-17-07	100.1	99.9	99.7
KUE	LANDIS & GYR	MX	C452910	07-17-07	100.0	100.1	100.1
KUE	LANDIS & GYR	MX	C452911	07-17-07	100.1	100.1	99.8
KUE	LANDIS & GYR	MX	C452912	07-17-07	100.0	100.0	100.3
KUE	LANDIS & GYR	MX	C452913	07-17-07	100.1	100.0	100.3
KUE	LANDIS & GYR	MX	C452914	07-17-07	100.1	100.1	100.3
KUE	LANDIS & GYR	MX	C452915	07-17-07	100.0	99.9	100.1
KUE	LANDIS & GYR	MX	C452916	07-17-07	100.1	100.0	99.7
KUE	LANDIS & GYR	MX	C452917	07-17-07	100.1	100.0	100.2
KUE	LANDIS & GYR	MX	C452918	07-17-07	100.0	99.9	99.6
KUE	LANDIS & GYR	MX	C452919	07-17-07	100.0	99.9	100.1
KUE	LANDIS & GYR	MX	C452920	07-17-07	100.1	100.1	99.9
KUE	LANDIS & GYR	MX	C452921	07-17-07	100.0	100.0	99.8
KUE	LANDIS & GYR	MX	C452922	07-17-07	100.0	100.0	99.8
KUE	LANDIS & GYR	MX	C452923	07-17-07	100.1	100.0	100.3
KUE	LANDIS & GYR	MX	C452924	07-17-07	100.1	100.2	100.6
KUE	LANDIS & GYR	MX	C452925	07-17-07	100.0	100.2	100.1

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

CO	MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
KUE	LANDIS & GYR	MX	C452977	07-17-07	100.1	100.0	100.3
KUE	LANDIS & GYR	MX	C452978	07-17-07	100.1	100.1	100.2
KUE	LANDIS & GYR	MX	C452979	07-17-07	100.1	99.9	100.6
KUE	LANDIS & GYR	MX	C452980	07-17-07	100.0	99.9	99.9
KUE	LANDIS & GYR	MX	C452981	07-17-07	100.1	100.0	99.9
KUE	LANDIS & GYR	MX	C452982	07-17-07	100.0	100.0	100.0
KUE	LANDIS & GYR	MX	C452983	07-17-07	100.0	100.0	100.2
KUE	LANDIS & GYR	MX	C452984	07-17-07	100.0	100.0	99.7
KUE	LANDIS & GYR	MX	C452985	07-17-07	100.0	100.1	100.1
KUE	LANDIS & GYR	MX	C452986	07-17-07	100.1	100.1	100.1
KUE	LANDIS & GYR	MX	C452987	07-17-07	100.0	100.0	100.2
KUE	LANDIS & GYR	MX	C452988	07-17-07	100.1	100.2	100.2
KUE	LANDIS & GYR	MX	C452989	07-17-07	100.1	100.1	99.9
KUE	LANDIS & GYR	MX	C452990	07-17-07	100.1	100.0	100.4
KUE	LANDIS & GYR	MX	C452991	07-17-07	100.1	100.0	100.3
KUE	LANDIS & GYR	MX	C452992	07-17-07	100.0	100.0	100.4
KUE	LANDIS & GYR	MX	C452993	07-17-07	100.1	100.2	100.0
KUE	LANDIS & GYR	MX	C452994	07-17-07	100.1	100.2	100.0
KUE	LANDIS & GYR	MX	C452995	07-17-07	100.0	100.0	99.9
KUE	LANDIS & GYR	MX	C452996	07-17-07	100.1	100.2	100.3
KUE	LANDIS & GYR	MX	C452997	07-17-07	100.1	100.2	100.1
KUE	LANDIS & GYR	MX	C452998	07-17-07	100.1	100.2	100.3
KUE	LANDIS & GYR	MX	C452999	07-17-07	100.1	100.1	100.4
KUE	LANDIS & GYR	MX	C453000	07-17-07	100.0	100.0	100.2
KUE	LANDIS & GYR	MX	C453001	07-17-07	100.1	100.0	100.5
KUE	LANDIS & GYR	MX	C453002	07-17-07	100.0	100.0	99.9
KUE	LANDIS & GYR	MX	C453003	07-17-07	100.1	100.0	99.9
KUE	LANDIS & GYR	MX	C453004	07-17-07	100.1	100.1	100.0
KUE	LANDIS & GYR	MX	C453005	07-17-07	100.0	100.0	100.1
KUE	LANDIS & GYR	MX	C453006	07-17-07	100.1	99.9	100.2
KUE	LANDIS & GYR	MX	C453007	07-17-07	100.1	100.0	100.4
KUE	LANDIS & GYR	MX	C453008	07-17-07	100.0	100.0	100.2
KUE	LANDIS & GYR	MX	C453009	07-17-07	100.0	100.1	100.6
KUE	LANDIS & GYR	MX	C453010	07-17-07	100.1	100.0	100.3
KUE	LANDIS & GYR	MX	C453011	07-17-07	100.1	99.9	100.3
KUE	LANDIS & GYR	MX	C453012	07-17-07	100.1	100.1	99.9
KUE	LANDIS & GYR	MX	C453013	07-17-07	100.1	99.9	100.3
KUE	LANDIS & GYR	MX	C453014	07-17-07	100.0	100.0	100.1
KUE	LANDIS & GYR	MX	C453015	07-17-07	100.0	100.0	100.1
KUE	LANDIS & GYR	MX	C453016	07-17-07	100.0	100.2	100.1
KUE	LANDIS & GYR	MX	C453017	07-17-07	100.1	100.1	100.3
KUE	LANDIS & GYR	MX	C453018	07-17-07	100.1	100.1	100.3
KUE	LANDIS & GYR	MX	C453019	07-17-07	100.1	100.0	100.1
KUE	LANDIS & GYR	MX	C453020	07-17-07	100.1	100.1	100.1
KUE	LANDIS & GYR	MX	C453021	07-17-07	100.1	100.2	100.3
KUE	LANDIS & GYR	MX	C453022	07-17-07	100.0	100.1	100.1
KUE	LANDIS & GYR	MX	C453023	07-17-07	100.1	100.0	100.2
KUE	LANDIS & GYR	MX	C453024	07-17-07	100.1	100.1	100.3
KUE	LANDIS & GYR	MX	C453025	07-17-07	100.1	100.1	100.0
KUE	LANDIS & GYR	MX	C453026	07-17-07	100.1	100.0	100.1
KUE	LANDIS & GYR	MX	C453027	07-17-07	100.1	100.0	100.2

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

CO	MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
KUE	LANDIS & GYR	MX	C453079	07-17-07	100.1	100.0	100.3
KUE	LANDIS & GYR	MX	C453080	07-17-07	100.0	99.9	99.9
KUE	LANDIS & GYR	MX	C453081	07-17-07	100.0	100.0	100.1
KUE	LANDIS & GYR	MX	C453082	07-17-07	100.0	100.0	99.7
KUE	LANDIS & GYR	MX	C453083	07-17-07	100.1	99.9	100.1
KUE	LANDIS & GYR	MX	C453084	07-17-07	100.0	100.0	100.0
KUE	LANDIS & GYR	MX	C453085	07-17-07	100.0	100.0	99.8
KUE	LANDIS & GYR	MX	C453086	07-17-07	100.0	100.0	100.2
KUE	LANDIS & GYR	MX	C453087	07-17-07	100.1	100.1	100.1
KUE	LANDIS & GYR	MX	C453088	07-17-07	100.0	100.0	100.1
KUE	LANDIS & GYR	MX	C453089	07-17-07	100.0	100.2	100.4
KUE	LANDIS & GYR	MX	C453090	07-17-07	100.1	99.9	100.1
KUE	LANDIS & GYR	MX	C453091	07-17-07	100.1	100.1	99.7
KUE	LANDIS & GYR	MX	C453092	07-17-07	100.0	100.0	100.1
KUE	LANDIS & GYR	MX	C453093	07-17-07	100.0	100.2	100.3
KUE	LANDIS & GYR	MX	C453094	07-17-07	100.0	100.0	100.2
KUE	LANDIS & GYR	MX	C453095	07-17-07	100.1	100.1	100.2
KUE	LANDIS & GYR	MX	C453096	07-17-07	100.1	100.1	100.1
KUE	LANDIS & GYR	MX	C453097	07-17-07	100.0	100.0	99.9
KUE	LANDIS & GYR	MX	C453098	07-17-07	100.1	100.1	100.4
KUE	LANDIS & GYR	MX	C453099	07-17-07	100.1	100.1	100.1
KUE	LANDIS & GYR	MX	C453100	07-17-07	100.0	99.9	99.9
KUE	LANDIS & GYR	MX	C453101	07-17-07	100.0	100.0	100.2
KUE	LANDIS & GYR	MX	C453102	07-17-07	100.1	100.0	100.2
KUE	LANDIS & GYR	MX	C453103	07-17-07	100.0	100.1	100.1
KUE	LANDIS & GYR	MX	C453104	07-17-07	100.1	100.1	99.6
KUE	LANDIS & GYR	MX	C453105	07-17-07	100.0	100.1	100.0
KUE	LANDIS & GYR	MX	C453106	07-17-07	100.1	100.1	100.5
KUE	LANDIS & GYR	MX	C453107	07-17-07	100.0	100.0	100.0
KUE	LANDIS & GYR	MX	C453108	07-17-07	100.0	99.9	99.6
KUE	LANDIS & GYR	MX	C453109	07-17-07	100.0	99.9	100.1
KUE	LANDIS & GYR	MX	C453110	07-17-07	100.0	99.9	100.1
KUE	LANDIS & GYR	MX	C453111	07-17-07	100.0	100.0	100.2
KUE	LANDIS & GYR	MX	C453112	07-17-07	100.1	100.1	99.7
KUE	LANDIS & GYR	MX	C453113	07-17-07	100.1	100.1	100.1
KUE	LANDIS & GYR	MX	C453114	07-17-07	100.1	100.0	99.8
KUE	LANDIS & GYR	MX	C453115	07-17-07	100.0	100.0	100.1
KUE	LANDIS & GYR	MX	C453116	07-17-07	100.0	100.0	100.1
KUE	LANDIS & GYR	MX	C453117	07-17-07	100.1	99.9	99.8
KUE	LANDIS & GYR	MX	C453118	07-17-07	100.0	99.9	100.2
KUE	LANDIS & GYR	MX	C453119	07-17-07	100.1	100.0	100.3
KUE	LANDIS & GYR	MX	C453120	07-17-07	100.0	100.0	100.5
KUE	LANDIS & GYR	MX	C453121	07-17-07	100.0	100.0	100.0
KUE	LANDIS & GYR	MX	C453122	07-17-07	100.1	100.2	100.0
KUE	LANDIS & GYR	MX	C453123	07-17-07	100.0	100.1	100.2
KUE	LANDIS & GYR	MX	C453124	07-17-07	100.1	100.1	99.6
KUE	LANDIS & GYR	MX	C453125	07-17-07	100.1	100.0	100.3
KUE	LANDIS & GYR	MX	C453126	07-17-07	100.0	100.0	100.1
KUE	LANDIS & GYR	MX	C453127	07-17-07	100.1	100.0	99.7
KUE	LANDIS & GYR	MX	C453128	07-17-07	100.0	100.0	99.6
KUE	LANDIS & GYR	MX	C453129	07-17-07	100.0	99.9	99.9
KUE	LANDIS & GYR	MX	C453129	07-17-07	100.0	100.0	100.1

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

CO	MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
KUE	LANDIS & GYR	MX	C453181	07-17-07	100.0	100.1	99.5
KUE	LANDIS & GYR	MX	C453182	07-17-07	100.1	100.1	99.8
KUE	LANDIS & GYR	MX	C453183	07-17-07	100.0	99.9	100.1
KUE	LANDIS & GYR	MX	C453184	07-17-07	100.0	99.9	99.9
KUE	LANDIS & GYR	MX	C453185	07-17-07	100.1	100.0	100.0
KUE	LANDIS & GYR	MX	C453186	07-17-07	100.1	100.1	100.3
KUE	LANDIS & GYR	MX	C453187	07-17-07	100.1	100.0	99.9
KUE	LANDIS & GYR	MX	C453188	07-17-07	100.0	99.9	100.1
KUE	LANDIS & GYR	MX	C453189	07-17-07	100.1	100.0	100.0
KUE	LANDIS & GYR	MX	C453190	07-17-07	100.1	100.1	100.1
KUE	LANDIS & GYR	MX	C453191	07-17-07	100.0	99.9	100.4
KUE	LANDIS & GYR	MX	C453192	07-17-07	100.0	99.9	99.9
KUE	LANDIS & GYR	MX	C453193	07-17-07	100.0	100.0	100.1
KUE	LANDIS & GYR	MX	C453194	07-17-07	100.0	100.1	99.8
KUE	LANDIS & GYR	MX	C453195	07-17-07	100.1	100.0	99.7
KUE	LANDIS & GYR	MX	C453196	07-17-07	100.1	100.0	100.0
KUE	LANDIS & GYR	MX	C453197	07-17-07	100.0	100.1	99.9
KUE	LANDIS & GYR	MX	C453198	07-17-07	100.1	100.0	99.6
KUE	LANDIS & GYR	MX	C453199	07-17-07	100.0	100.1	99.7
KUE	LANDIS & GYR	MX	C453200	07-17-07	99.9	100.0	99.9
KUE	LANDIS & GYR	MX	C453201	07-17-07	100.0	100.1	100.1
KUE	LANDIS & GYR	MX	C453202	07-17-07	100.0	100.0	99.7
KUE	LANDIS & GYR	MX	C453203	07-17-07	100.1	100.0	99.8
KUE	LANDIS & GYR	MX	C453204	07-17-07	100.1	100.2	100.4
KUE	LANDIS & GYR	MX	C453205	07-17-07	100.0	100.0	100.1
KUE	LANDIS & GYR	MX	C453206	07-17-07	100.0	100.0	100.0
KUE	LANDIS & GYR	MX	C453207	07-17-07	100.0	100.0	99.9
KUE	LANDIS & GYR	MX	C453208	07-17-07	100.1	100.1	99.9
KUE	LANDIS & GYR	MX	C453209	07-17-07	100.1	100.1	99.9
KUE	LANDIS & GYR	MX	C453210	07-17-07	100.0	100.1	100.1
KUE	LANDIS & GYR	MX	C453211	07-17-07	100.1	99.9	100.0
KUE	LANDIS & GYR	MX	C453212	07-17-07	100.0	100.0	100.0
KUE	LANDIS & GYR	MX	C453213	07-17-07	100.1	100.1	100.2
KUE	LANDIS & GYR	MX	C453214	07-17-07	100.1	100.0	100.3
KUE	LANDIS & GYR	MX	C453215	07-17-07	100.0	100.1	99.9
KUE	LANDIS & GYR	MX	C453216	07-17-07	100.0	100.1	100.0
KUE	LANDIS & GYR	MX	C453217	07-17-07	100.0	100.1	100.2
KUE	LANDIS & GYR	MX	C453218	07-17-07	100.1	100.0	100.0
KUE	LANDIS & GYR	MX	C453219	07-17-07	100.0	100.1	100.1
KUE	LANDIS & GYR	MX	C453220	07-17-07	100.1	100.1	100.5
KUE	LANDIS & GYR	MX	C453221	07-17-07	100.0	100.0	100.1
KUE	LANDIS & GYR	MX	C453222	07-17-07	100.1	99.9	100.1
KUE	LANDIS & GYR	MX	C453223	07-17-07	100.0	100.1	99.8
KUE	LANDIS & GYR	MX	C453224	07-17-07	100.1	100.0	100.3
KUE	LANDIS & GYR	MX	C453225	07-17-07	100.0	100.0	100.2
KUE	LANDIS & GYR	MX	C453226	07-17-07	100.0	99.9	99.7
KUE	LANDIS & GYR	MX	C453227	07-17-07	100.0	99.9	100.0
KUE	LANDIS & GYR	MX	C453228	07-17-07	100.1	100.1	100.2
KUE	LANDIS & GYR	MX	C453229	07-17-07	100.0	100.0	100.2
KUE	LANDIS & GYR	MX	C453230	07-17-07	100.0	100.0	99.6
KUE	LANDIS & GYR	MX	C453231	07-17-07	100.1	100.1	100.4

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

CO	MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
KUE	LANDIS & GYR	MX	C453283	07-17-07	99.9	99.9	100.0
KUE	LANDIS & GYR	MX	C453284	07-17-07	100.0	100.1	100.1
KUE	LANDIS & GYR	MX	C453285	07-17-07	100.0	100.0	100.1
KUE	LANDIS & GYR	MX	C453286	07-17-07	100.0	100.0	100.3
KUE	LANDIS & GYR	MX	C453287	07-17-07	100.0	99.9	100.5
KUE	LANDIS & GYR	MX	C453288	07-17-07	100.0	100.2	100.1
KUE	LANDIS & GYR	MX	C453289	07-17-07	100.0	100.0	100.0
KUE	LANDIS & GYR	MX	C453290	07-17-07	100.0	100.0	99.7
KUE	LANDIS & GYR	MX	C453291	07-17-07	100.0	100.1	100.2
KUE	LANDIS & GYR	MX	C453292	07-17-07	100.0	100.1	100.1
KUE	LANDIS & GYR	MX	C453293	07-17-07	100.0	100.1	100.1
KUE	LANDIS & GYR	MX	C453294	07-17-07	100.0	100.2	100.4
KUE	LANDIS & GYR	MX	C453295	07-17-07	100.0	100.1	100.0
KUE	LANDIS & GYR	MX	C453296	07-17-07	100.0	100.0	99.9
KUE	LANDIS & GYR	MX	C453297	07-17-07	100.0	100.1	100.2
KUE	LANDIS & GYR	MX	C453298	07-17-07	100.0	100.1	100.4
KUE	LANDIS & GYR	MX	C453299	07-17-07	100.0	100.2	100.3
KUE	LANDIS & GYR	MX	C453300	07-17-07	100.0	100.2	100.0
KUE	LANDIS & GYR	MX	C453301	07-17-07	100.0	100.0	100.3
KUE	LANDIS & GYR	MX	C453302	07-17-07	100.0	100.0	100.3
KUE	LANDIS & GYR	MX	C453303	07-17-07	100.0	99.9	100.4
KUE	LANDIS & GYR	MX	C453304	07-17-07	100.0	99.9	100.3
KUE	LANDIS & GYR	MX	C453305	07-17-07	100.0	100.0	100.3
KUE	LANDIS & GYR	MX	C453306	07-17-07	100.0	100.0	100.1
KUE	LANDIS & GYR	MX	C453307	07-17-07	100.0	99.9	100.4
KUE	LANDIS & GYR	MX	C453308	07-17-07	100.0	100.2	100.3
KUE	LANDIS & GYR	MX	C453309	07-17-07	100.0	99.9	99.9
KUE	LANDIS & GYR	MX	C453310	07-17-07	100.0	100.1	100.4
KUE	LANDIS & GYR	MX	C453311	07-17-07	100.0	100.0	100.4
KUE	LANDIS & GYR	MX	C453312	07-17-07	100.0	99.9	100.2
KUE	LANDIS & GYR	MX	C453313	07-17-07	100.0	100.0	100.0
KUE	LANDIS & GYR	MX	C453314	07-17-07	100.0	100.0	99.9
KUE	LANDIS & GYR	MX	C453315	07-17-07	100.0	100.0	99.8
KUE	LANDIS & GYR	MX	C453316	07-17-07	100.0	100.1	100.1
KUE	LANDIS & GYR	MX	C453317	07-17-07	100.0	99.9	100.3
KUE	LANDIS & GYR	MX	C453318	07-17-07	100.0	99.9	100.0
KUE	LANDIS & GYR	MX	C453319	07-17-07	100.0	100.0	100.0
KUE	LANDIS & GYR	MX	C453320	07-17-07	100.0	100.2	100.1
KUE	LANDIS & GYR	MX	C453321	07-17-07	100.0	100.0	100.3
KUE	LANDIS & GYR	MX	C453322	07-17-07	100.0	100.0	100.0
KUE	LANDIS & GYR	MX	C453323	07-17-07	100.0	99.9	100.2
KUE	LANDIS & GYR	MX	C453324	07-17-07	100.0	100.1	100.3
KUE	LANDIS & GYR	MX	C453325	07-17-07	100.0	100.1	100.0
KUE	LANDIS & GYR	MX	C453326	07-17-07	100.0	100.2	100.0
KUE	LANDIS & GYR	MX	C453327	07-17-07	100.0	100.0	99.9
KUE	LANDIS & GYR	MX	C453328	07-17-07	100.0	100.1	100.3
KUE	LANDIS & GYR	MX	C453329	07-17-07	100.0	100.0	100.4
KUE	LANDIS & GYR	MX	C453330	07-17-07	100.0	100.1	100.2
KUE	LANDIS & GYR	MX	C453331	07-17-07	100.0	100.1	99.8
KUE	LANDIS & GYR	MX	C453332	07-17-07	100.0	100.1	99.6
KUE	LANDIS & GYR	MX	C453333	07-17-07	100.0	100.1	100.2

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

CO	MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
KUE	LANDIS & GYR	MX	C453385	07-17-07	100.1	99.9	100.2
KUE	LANDIS & GYR	MX	C453386	07-17-07	100.0	99.9	99.8
KUE	LANDIS & GYR	MX	C453387	07-17-07	100.0	100.0	100.0
KUE	LANDIS & GYR	MX	C453388	07-17-07	100.1	100.0	99.9
KUE	LANDIS & GYR	MX	C453389	07-17-07	100.1	100.1	100.0
KUE	LANDIS & GYR	MX	C453390	07-17-07	100.1	100.1	100.0
KUE	LANDIS & GYR	MX	C453391	07-17-07	100.0	99.9	100.2
KUE	LANDIS & GYR	MX	C453392	07-17-07	100.1	100.0	99.7
KUE	LANDIS & GYR	MX	C453393	07-17-07	100.0	99.9	100.2
KUE	LANDIS & GYR	MX	C453394	07-17-07	100.0	100.1	100.2
KUE	LANDIS & GYR	MX	C453395	07-17-07	100.1	100.0	99.7
KUE	LANDIS & GYR	MX	C453396	07-17-07	100.0	100.0	100.2
KUE	LANDIS & GYR	MX	C453397	07-17-07	100.1	100.2	99.8
KUE	LANDIS & GYR	MX	C453398	07-17-07	99.9	99.9	100.1
KUE	LANDIS & GYR	MX	C453399	07-17-07	100.1	100.1	100.1
KUE	LANDIS & GYR	MX	C453400	07-17-07	100.1	100.0	99.9
KUE	LANDIS & GYR	MX	C453401	07-17-07	100.1	100.1	100.2
KUE	LANDIS & GYR	MX	C453402	07-17-07	100.1	100.1	100.0
KUE	LANDIS & GYR	MX	C453403	07-17-07	100.0	100.1	100.0
KUE	LANDIS & GYR	MX	C453404	07-17-07	100.1	100.1	100.0
KUE	LANDIS & GYR	MX	C453405	07-17-07	100.1	100.1	100.1
KUE	LANDIS & GYR	MX	C453406	07-17-07	100.1	100.0	100.3
KUE	LANDIS & GYR	MX	C453407	07-17-07	100.1	100.0	100.2
KUE	LANDIS & GYR	MX	C453408	07-17-07	100.1	100.2	100.2
KUE	LANDIS & GYR	MX	C453409	07-17-07	100.0	99.9	100.0
KUE	LANDIS & GYR	MX	C453410	07-17-07	100.1	100.2	99.8
KUE	LANDIS & GYR	MX	C453411	07-17-07	100.0	100.1	100.0
KUE	LANDIS & GYR	MX	C453412	07-17-07	100.1	100.0	100.2
KUE	LANDIS & GYR	MX	C453413	07-17-07	100.0	99.9	100.2
KUE	LANDIS & GYR	MX	C453414	07-17-07	100.1	100.4	100.2
KUE	LANDIS & GYR	MX	C453415	07-17-07	100.0	99.9	99.9
KUE	LANDIS & GYR	MX	C453416	07-17-07	100.1	100.0	100.2
KUE	LANDIS & GYR	MX	C453417	07-17-07	100.1	100.2	100.1
KUE	LANDIS & GYR	MX	C453418	07-17-07	100.1	100.1	99.9
KUE	LANDIS & GYR	MX	C453419	07-17-07	100.1	100.0	99.8
KUE	LANDIS & GYR	MX	C453420	07-17-07	100.1	100.1	100.1
KUE	LANDIS & GYR	MX	C453421	07-17-07	100.0	100.1	100.1
KUE	LANDIS & GYR	MX	C453422	07-17-07	99.9	100.0	99.8
KUE	LANDIS & GYR	MX	C453423	07-17-07	100.1	100.2	99.8
KUE	LANDIS & GYR	MX	C453424	07-17-07	100.0	100.2	100.2
KUE	LANDIS & GYR	MX	C453425	07-17-07	100.0	99.9	99.8
KUE	LANDIS & GYR	MX	C453426	07-17-07	100.0	100.1	100.2
KUE	LANDIS & GYR	MX	C453427	07-17-07	100.0	100.1	100.1
KUE	LANDIS & GYR	MX	C453428	07-17-07	100.0	100.0	100.0
KUE	LANDIS & GYR	MX	C453429	07-17-07	100.1	99.9	100.1
KUE	LANDIS & GYR	MX	C453430	07-17-07	100.0	100.1	99.8
KUE	LANDIS & GYR	MX	C453431	07-17-07	100.0	100.1	100.1
KUE	LANDIS & GYR	MX	C453432	07-17-07	100.1	100.1	100.1
KUE	LANDIS & GYR	MX	C453433	07-17-07	100.0	100.0	100.0
KUE	LANDIS & GYR	MX	C453434	07-17-07	100.0	100.1	100.3
KUE	LANDIS & GYR	MX	C453435	07-17-07	100.0	100.0	99.8

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

CO	MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PF FACTOR
KUE	& GYR	MX	C453487	07-17-07	100.1	100.2	100.5
KUE	& GYR	MX	C453488	07-17-07	100.0	100.0	99.7
KUE	& GYR	MX	C453489	07-17-07	100.1	100.0	100.2
KUE	& GYR	MX	C453490	07-17-07	100.1	100.1	100.1
KUE	& GYR	MX	C453491	07-17-07	100.0	99.9	99.7
KUE	& GYR	MX	C453492	07-17-07	100.1	100.2	100.0
KUE	& GYR	MX	C453493	07-17-07	100.1	100.0	100.0
KUE	& GYR	MX	C453494	07-17-07	100.1	100.0	100.0
KUE	& GYR	MX	C453495	07-17-07	100.0	100.0	100.1
KUE	& GYR	MX	C453496	07-17-07	100.1	100.0	100.0
KUE	& GYR	MX	C453497	07-17-07	100.1	100.1	100.2
KUE	& GYR	MX	C453498	07-17-07	100.1	100.0	100.3
KUE	& GYR	MX	C453499	07-17-07	100.1	100.1	99.8
KUE	& GYR	MX	C453500	07-17-07	100.1	100.1	100.4
KUE	& GYR	MX	C453501	07-17-07	100.0	100.0	99.6
KUE	& GYR	MX	C453502	07-17-07	100.0	100.1	100.1
KUE	& GYR	MX	C453503	07-17-07	100.0	100.0	100.0
KUE	& GYR	MX	C453504	07-17-07	100.1	100.1	100.1
KUE	& GYR	MX	C453505	07-17-07	100.1	100.1	100.3
KUE	& GYR	MX	C453506	07-17-07	100.1	100.1	99.8
KUE	& GYR	MX	C453507	07-17-07	100.1	100.0	100.4
KUE	& GYR	MX	C453508	07-17-07	100.0	100.2	99.9
KUE	& GYR	MX	C453509	07-17-07	100.1	100.1	100.1
KUE	& GYR	MX	C453510	07-17-07	100.1	100.1	100.0
KUE	& GYR	MX	C453511	07-17-07	100.1	100.1	100.5
KUE	& GYR	MX	C453512	07-17-07	100.1	100.0	99.8
KUE	& GYR	MX	C453513	07-17-07	100.0	100.2	100.2
KUE	& GYR	MX	C453514	07-17-07	100.1	100.1	100.0
KUE	& GYR	MX	C453515	07-17-07	100.0	100.0	100.4
KUE	& GYR	MX	C453516	07-17-07	100.0	100.1	99.9
KUE	& GYR	MX	C453517	07-17-07	99.9	99.9	100.0
KUE	& GYR	MX	C453518	07-17-07	100.0	100.2	100.3
KUE	& GYR	MX	C453519	07-17-07	100.0	100.2	100.2
KUE	& GYR	MX	C453520	07-17-07	100.1	100.0	99.8
KUE	& GYR	MX	C453521	07-17-07	100.1	100.1	99.9
KUE	& GYR	MX	C453522	07-17-07	100.0	100.0	100.0
KUE	& GYR	MX	C453523	07-17-07	100.1	99.9	99.8
KUE	& GYR	MX	C453524	07-17-07	100.1	100.0	100.1
KUE	& GYR	MX	C453525	07-17-07	100.1	100.0	100.4
KUE	& GYR	MX	C453526	07-17-07	100.0	99.9	100.3
KUE	& GYR	MX	C453527	07-17-07	100.1	100.1	100.4
KUE	& GYR	MX	C453528	07-17-07	100.1	100.0	100.3
KUE	& GYR	MX	C453529	07-17-07	100.0	100.0	100.3
KUE	& GYR	MX	C453530	07-17-07	100.1	99.9	99.9
KUE	& GYR	MX	C453531	07-17-07	100.1	99.9	100.4
KUE	& GYR	MX	C453532	07-17-07	100.0	99.9	100.2
KUE	& GYR	MX	C453533	07-17-07	100.1	99.9	100.4
KUE	& GYR	MX	C453534	07-17-07	100.0	100.1	100.0
KUE	& GYR	MX	C453535	07-17-07	100.0	100.0	99.9
KUE	& GYR	MX	C453536	07-17-07	100.0	100.1	100.0
KUE	& GYR	MX	C453537	07-17-07	100.1	100.2	99.8

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

CO	MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
KUE	LANDIS & GYR	MX	C453589	07-17-07	100.0	99.9	100.1
KUE	LANDIS & GYR	MX	C453590	07-17-07	100.1	100.1	100.1
KUE	LANDIS & GYR	MX	C453591	07-17-07	100.1	99.9	100.1
KUE	LANDIS & GYR	MX	C453592	07-17-07	100.1	100.0	100.2
KUE	LANDIS & GYR	MX	C453593	07-17-07	100.1	100.2	100.4
KUE	LANDIS & GYR	MX	C453594	07-17-07	100.0	100.0	99.7
KUE	LANDIS & GYR	MX	C453595	07-18-07	100.1	100.1	100.1
KUE	LANDIS & GYR	MX	C453596	07-18-07	100.1	100.1	100.3
KUE	LANDIS & GYR	MX	C453597	07-18-07	100.0	99.9	99.9
KUE	LANDIS & GYR	MX	C453598	07-18-07	100.1	100.1	100.3
KUE	LANDIS & GYR	MX	C453599	07-18-07	100.0	100.0	100.3
KUE	LANDIS & GYR	MX	C453600	07-18-07	100.1	100.0	99.9
KUE	LANDIS & GYR	MX	C453601	07-18-07	100.0	100.0	99.6
KUE	LANDIS & GYR	MX	C453602	07-18-07	100.0	100.1	100.0
KUE	LANDIS & GYR	MX	C453603	07-18-07	100.1	100.0	100.3
KUE	LANDIS & GYR	MX	C453604	07-18-07	100.0	100.0	100.1
KUE	LANDIS & GYR	MX	C453605	07-18-07	100.1	100.0	99.9
KUE	LANDIS & GYR	MX	C453606	07-18-07	100.0	100.0	99.6
KUE	LANDIS & GYR	MX	C453607	07-17-07	100.0	100.1	100.2
KUE	LANDIS & GYR	MX	C453608	07-18-07	100.0	100.0	99.9
KUE	LANDIS & GYR	MX	C453609	07-18-07	100.0	99.9	99.9
KUE	LANDIS & GYR	MX	C453610	07-18-07	100.1	100.1	100.0
KUE	LANDIS & GYR	MX	C453611	07-18-07	100.1	100.1	100.2
KUE	LANDIS & GYR	MX	C453612	07-18-07	100.1	100.0	100.3
KUE	LANDIS & GYR	MX	C453613	07-18-07	100.1	100.1	100.3
KUE	LANDIS & GYR	MX	C453614	07-18-07	100.0	100.1	100.0
KUE	LANDIS & GYR	MX	C453615	07-18-07	100.1	100.1	99.8
KUE	LANDIS & GYR	MX	C453616	07-18-07	100.0	100.0	99.7
KUE	LANDIS & GYR	MX	C453617	07-18-07	100.0	100.0	99.5
KUE	LANDIS & GYR	MX	C453618	07-18-07	100.1	100.0	99.9
KUE	LANDIS & GYR	MX	C453619	07-18-07	100.0	100.2	99.5
KUE	LANDIS & GYR	MX	C453620	07-18-07	100.0	100.2	100.4
KUE	LANDIS & GYR	MX	C453621	07-18-07	100.0	100.0	100.0
KUE	LANDIS & GYR	MX	C453622	07-18-07	100.0	100.2	100.2
KUE	LANDIS & GYR	MX	C453623	07-18-07	100.1	100.1	100.2
KUE	LANDIS & GYR	MX	C453624	07-18-07	100.0	100.0	99.7
KUE	LANDIS & GYR	MX	C453625	07-18-07	100.0	100.2	99.6
KUE	LANDIS & GYR	MX	C453626	07-18-07	100.1	100.0	99.7
KUE	LANDIS & GYR	MX	C453627	07-18-07	100.0	100.1	100.0
KUE	LANDIS & GYR	MX	C453628	07-18-07	100.0	100.2	100.0
KUE	LANDIS & GYR	MX	C453629	07-18-07	100.1	99.9	100.0
KUE	LANDIS & GYR	MX	C453630	07-18-07	100.1	100.1	100.3
KUE	LANDIS & GYR	MX	C453631	07-18-07	100.1	100.2	99.9
KUE	LANDIS & GYR	MX	C453632	07-18-07	100.0	100.1	100.3
KUE	LANDIS & GYR	MX	C453633	07-18-07	100.0	100.1	99.7
KUE	LANDIS & GYR	MX	C453634	07-18-07	100.1	100.1	99.9
KUE	LANDIS & GYR	MX	C453635	07-18-07	100.0	100.0	100.1
KUE	LANDIS & GYR	MX	C453636	07-18-07	100.0	100.0	99.9
KUE	LANDIS & GYR	MX	C453637	07-18-07	100.0	100.1	100.1
KUE	LANDIS & GYR	MX	C453638	07-18-07	100.1	100.0	99.9
KUE	LANDIS & GYR	MX	C453639	07-18-07	100.1	100.1	99.9

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

CO	MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
KUE	LANDIS & GYR	MX	C453691	07-18-07	100.1	100.1	99.8
KUE	LANDIS & GYR	MX	C453692	07-18-07	100.0	100.0	99.6
KUE	LANDIS & GYR	MX	C453693	07-17-07	100.1	100.1	100.5
KUE	LANDIS & GYR	MX	C453694	07-18-07	100.0	100.1	100.3
KUE	LANDIS & GYR	MX	C453695	07-18-07	100.1	100.0	100.1
KUE	LANDIS & GYR	MX	C453696	07-18-07	100.1	100.1	100.0
KUE	LANDIS & GYR	MX	C453697	07-18-07	100.1	100.1	99.9
KUE	LANDIS & GYR	MX	C453698	07-18-07	100.0	100.0	100.0
KUE	LANDIS & GYR	MX	C453699	07-18-07	100.1	99.9	100.1
KUE	LANDIS & GYR	MX	C453700	07-18-07	100.0	99.9	99.6
KUE	LANDIS & GYR	MX	C453701	07-18-07	100.1	100.2	100.3
KUE	LANDIS & GYR	MX	C453702	07-18-07	100.1	99.9	100.0
KUE	LANDIS & GYR	MX	C453703	07-18-07	100.0	100.0	100.2
KUE	LANDIS & GYR	MX	C453704	07-18-07	100.0	100.0	100.0
KUE	LANDIS & GYR	MX	C453705	07-18-07	100.1	100.0	99.8
KUE	LANDIS & GYR	MX	C453706	07-18-07	100.1	100.1	100.0
KUE	LANDIS & GYR	MX	C453707	07-18-07	100.1	100.1	99.8
KUE	LANDIS & GYR	MX	C453708	07-18-07	100.1	100.2	99.7
KUE	LANDIS & GYR	MX	C453709	07-18-07	100.1	100.0	99.9
KUE	LANDIS & GYR	MX	C453710	07-18-07	100.0	100.0	99.7
KUE	LANDIS & GYR	MX	C453711	07-18-07	100.0	100.2	99.7
KUE	LANDIS & GYR	MX	C453712	07-18-07	100.1	100.0	100.0
KUE	LANDIS & GYR	MX	C453713	07-18-07	100.1	100.1	99.8
KUE	LANDIS & GYR	MX	C453714	07-18-07	100.1	99.9	100.3
KUE	LANDIS & GYR	MX	C453715	07-18-07	100.0	100.2	100.2
KUE	LANDIS & GYR	MX	C453716	07-18-07	100.1	100.1	99.9
KUE	LANDIS & GYR	MX	C453717	07-18-07	99.9	100.1	100.3
KUE	LANDIS & GYR	MX	C453718	07-18-07	100.0	100.0	100.1
KUE	LANDIS & GYR	MX	C453719	07-18-07	100.0	100.0	100.5
KUE	LANDIS & GYR	MX	C453720	07-18-07	100.1	100.0	100.3
KUE	LANDIS & GYR	MX	C453721	07-18-07	100.0	99.9	100.1
KUE	LANDIS & GYR	MX	C453722	07-18-07	100.1	100.2	100.1
KUE	LANDIS & GYR	MX	C453723	07-18-07	100.1	100.1	100.3
KUE	LANDIS & GYR	MX	C453724	07-18-07	100.1	100.1	99.8
KUE	LANDIS & GYR	MX	C453725	07-18-07	100.1	100.1	100.2
KUE	LANDIS & GYR	MX	C453726	07-18-07	100.0	99.9	100.2
KUE	LANDIS & GYR	MX	C453727	07-18-07	100.0	100.1	99.9
KUE	LANDIS & GYR	MX	C453728	07-18-07	100.1	100.1	100.0
KUE	LANDIS & GYR	MX	C453729	07-18-07	100.0	100.1	100.2
KUE	LANDIS & GYR	MX	C453730	07-18-07	100.1	100.2	100.2
KUE	LANDIS & GYR	MX	C453731	07-18-07	99.9	100.1	99.7
KUE	LANDIS & GYR	MX	C453732	07-18-07	100.1	100.2	100.2
KUE	LANDIS & GYR	MX	C453733	07-18-07	100.1	100.2	100.2
KUE	LANDIS & GYR	MX	C453734	07-18-07	100.0	100.1	99.8
KUE	LANDIS & GYR	MX	C453735	07-18-07	100.0	100.1	99.6
KUE	LANDIS & GYR	MX	C453736	07-18-07	100.0	100.1	99.5
KUE	LANDIS & GYR	MX	C453737	07-18-07	100.0	100.2	99.5
KUE	LANDIS & GYR	MX	C453738	07-18-07	100.0	100.0	100.0
KUE	LANDIS & GYR	MX	C453739	07-18-07	100.1	99.9	99.9
KUE	LANDIS & GYR	MX	C453740	07-18-07	100.0	100.0	100.4
KUE	LANDIS & GYR	MX	C453741	07-18-07	100.1	100.1	99.9

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

CO	MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
KUE	LANDIS & GYR	MX	C453793	07-18-07	100.1	100.2	100.2
KUE	LANDIS & GYR	MX	C453794	07-18-07	100.1	100.1	100.2
KUE	LANDIS & GYR	MX	C453795	07-18-07	100.0	100.0	100.3
KUE	LANDIS & GYR	MX	C453796	07-18-07	100.1	99.9	99.7
KUE	LANDIS & GYR	MX	C453797	07-18-07	100.1	100.1	100.1
KUE	LANDIS & GYR	MX	C453798	07-18-07	100.1	100.1	100.1
KUE	LANDIS & GYR	MX	C453799	07-18-07	100.0	100.0	99.6
KUE	LANDIS & GYR	MX	C453800	07-18-07	99.9	100.2	99.6
KUE	LANDIS & GYR	MX	C453801	07-18-07	100.0	100.0	99.9
KUE	LANDIS & GYR	MX	C453802	07-18-07	100.0	100.1	99.6
KUE	LANDIS & GYR	MX	C453803	07-18-07	100.0	100.0	100.0
KUE	LANDIS & GYR	MX	C453804	07-18-07	100.1	100.0	100.0
KUE	LANDIS & GYR	MX	C453805	07-18-07	100.1	99.9	100.0
KUE	LANDIS & GYR	MX	C453806	07-18-07	100.0	100.1	99.8
KUE	LANDIS & GYR	MX	C453807	07-18-07	100.1	100.2	100.1
KUE	LANDIS & GYR	MX	C453808	07-18-07	100.0	100.2	100.2
KUE	LANDIS & GYR	MX	C453809	07-18-07	100.0	100.0	99.8
KUE	LANDIS & GYR	MX	C453810	07-18-07	100.0	100.0	100.2
KUE	LANDIS & GYR	MX	C453811	07-18-07	100.0	100.1	100.0
KUE	LANDIS & GYR	MX	C453812	07-18-07	100.1	100.0	99.5
KUE	LANDIS & GYR	MX	C453813	07-18-07	100.1	99.9	100.1
KUE	LANDIS & GYR	MX	C453814	07-18-07	100.0	100.0	100.2
KUE	LANDIS & GYR	MX	C453815	07-18-07	100.0	100.0	100.3
KUE	LANDIS & GYR	MX	C453816	07-18-07	100.0	100.0	100.0
KUE	LANDIS & GYR	MX	C453817	07-18-07	100.0	99.9	99.8
KUE	LANDIS & GYR	MX	C453818	07-18-07	100.0	99.9	99.6
KUE	LANDIS & GYR	MX	C453819	07-18-07	100.0	100.0	99.9
KUE	LANDIS & GYR	MX	C453820	07-18-07	100.1	100.1	100.3
KUE	LANDIS & GYR	MX	C453821	07-18-07	100.0	99.9	100.1
KUE	LANDIS & GYR	MX	C453822	07-18-07	100.0	100.0	99.8
KUE	LANDIS & GYR	MX	C453823	07-18-07	100.1	99.9	99.9
KUE	LANDIS & GYR	MX	C453824	07-18-07	100.1	100.0	100.3
KUE	LANDIS & GYR	MX	C453825	07-18-07	100.1	100.0	100.5
KUE	LANDIS & GYR	MX	C453826	07-18-07	100.1	100.0	100.1
KUE	LANDIS & GYR	MX	C453827	07-18-07	100.1	100.1	99.7
KUE	LANDIS & GYR	MX	C453828	07-18-07	100.0	99.9	99.9
KUE	LANDIS & GYR	MX	C453829	07-18-07	100.1	100.1	99.9
KUE	LANDIS & GYR	MX	C453830	07-18-07	100.0	100.1	99.6
KUE	LANDIS & GYR	MX	C453831	07-18-07	100.1	100.0	99.6
KUE	LANDIS & GYR	MX	C453832	07-18-07	100.0	99.9	99.8
KUE	LANDIS & GYR	MX	C453833	07-18-07	100.1	100.0	100.0
KUE	LANDIS & GYR	MX	C453834	07-18-07	100.1	100.0	100.1
KUE	LANDIS & GYR	MX	C453835	07-18-07	100.1	100.1	100.0
KUE	LANDIS & GYR	MX	C453836	07-18-07	100.0	100.0	99.5
KUE	LANDIS & GYR	MX	C453837	07-18-07	100.0	100.1	100.3
KUE	LANDIS & GYR	MX	C453838	07-18-07	100.0	100.0	99.7
KUE	LANDIS & GYR	MX	C453839	07-18-07	100.0	100.0	100.2
KUE	LANDIS & GYR	MX	C453840	07-18-07	100.1	100.1	99.8
KUE	LANDIS & GYR	MX	C453841	07-18-07	100.0	100.1	99.9
KUE	LANDIS & GYR	MX	C453842	07-18-07	100.0	100.1	100.3
KUE	LANDIS & GYR	MX	C453843	07-18-07	100.1	100.0	100.2

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

CO	MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
KUE	LANDIS & GYR	MX	C453895	07-18-07	100.0	100.0	99.6
KUE	LANDIS & GYR	MX	C453896	07-18-07	100.0	100.0	100.0
KUE	LANDIS & GYR	MX	C453897	07-18-07	100.0	100.0	99.7
KUE	LANDIS & GYR	MX	C453898	07-18-07	100.1	100.0	100.0
KUE	LANDIS & GYR	MX	C453899	07-18-07	100.0	100.1	100.2
KUE	LANDIS & GYR	MX	C453900	07-18-07	100.0	100.2	99.8
KUE	LANDIS & GYR	MX	C453901	07-18-07	100.0	99.9	100.0
KUE	LANDIS & GYR	MX	C453902	07-18-07	100.1	100.4	100.4
KUE	LANDIS & GYR	MX	C453903	07-18-07	100.0	100.1	100.0
KUE	LANDIS & GYR	MX	C453904	07-18-07	100.1	100.2	99.9
KUE	LANDIS & GYR	MX	C453905	07-18-07	100.1	99.9	99.9
KUE	LANDIS & GYR	MX	C453906	07-18-07	100.1	100.1	100.2
KUE	LANDIS & GYR	MX	C453907	07-18-07	100.0	100.0	100.2
KUE	LANDIS & GYR	MX	C453908	07-18-07	100.1	100.1	100.2
KUE	LANDIS & GYR	MX	C453909	07-18-07	100.1	100.1	99.9
KUE	LANDIS & GYR	MX	C453910	07-18-07	99.9	100.0	100.2
KUE	LANDIS & GYR	MX	C453911	07-18-07	100.0	100.0	99.9
KUE	LANDIS & GYR	MX	C453912	07-18-07	100.0	100.0	100.0
KUE	LANDIS & GYR	MX	C453913	07-18-07	100.0	99.9	99.8
KUE	LANDIS & GYR	MX	C453914	07-18-07	100.0	100.0	99.7
KUE	LANDIS & GYR	MX	C453915	07-18-07	100.0	100.0	100.3
KUE	LANDIS & GYR	MX	C453916	07-18-07	100.0	100.1	100.2
KUE	LANDIS & GYR	MX	C453917	07-18-07	100.0	100.0	99.7
KUE	LANDIS & GYR	MX	C453918	07-18-07	100.1	100.1	100.3
KUE	LANDIS & GYR	MX	C453919	07-18-07	100.0	100.0	100.0
KUE	LANDIS & GYR	MX	C453920	07-18-07	100.1	99.9	100.5
KUE	LANDIS & GYR	MX	C453921	07-18-07	100.0	99.9	99.5
KUE	LANDIS & GYR	MX	C453922	07-18-07	100.1	100.1	100.1
KUE	LANDIS & GYR	MX	C453923	07-18-07	100.1	100.1	100.0
KUE	LANDIS & GYR	MX	C453924	07-18-07	100.1	100.1	99.9
KUE	LANDIS & GYR	MX	C453925	07-18-07	100.1	99.7	99.7
KUE	LANDIS & GYR	MX	C453926	07-18-07	100.1	100.4	100.4
KUE	LANDIS & GYR	MX	C453927	07-18-07	100.0	99.7	99.7
KUE	LANDIS & GYR	MX	C453928	07-18-07	100.0	100.0	100.2
KUE	LANDIS & GYR	MX	C453929	07-18-07	100.1	100.1	99.8
KUE	LANDIS & GYR	MX	C453930	07-18-07	100.0	100.1	100.2
KUE	LANDIS & GYR	MX	C453931	07-18-07	100.0	100.1	100.3
KUE	LANDIS & GYR	MX	C453932	07-18-07	100.1	99.9	99.8
KUE	LANDIS & GYR	MX	C453933	07-18-07	100.1	100.2	99.8
KUE	LANDIS & GYR	MX	C453934	07-18-07	100.1	100.1	100.0
KUE	LANDIS & GYR	MX	C453935	07-18-07	100.1	100.1	100.1
KUE	LANDIS & GYR	MX	C453936	07-18-07	100.1	100.2	100.4
KUE	LANDIS & GYR	MX	C453937	07-18-07	100.0	100.0	100.4
KUE	LANDIS & GYR	MX	C453938	07-18-07	100.0	100.1	100.2
KUE	LANDIS & GYR	MX	C453939	07-18-07	100.1	100.1	100.0
KUE	LANDIS & GYR	MX	C453940	07-18-07	100.1	100.1	99.7
KUE	LANDIS & GYR	MX	C453941	07-18-07	100.1	100.0	100.0
KUE	LANDIS & GYR	MX	C453942	07-18-07	100.1	100.1	100.1
KUE	LANDIS & GYR	MX	C453943	07-18-07	100.1	100.0	100.4
KUE	LANDIS & GYR	MX	C453944	07-18-07	100.0	100.0	100.0
KUE	LANDIS & GYR	MX	C453945	07-18-07	100.0	100.1	100.3

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

PAGE 179
 RUN DATE: 1/15/08
 RUN TIME: 22.00.58

CO	MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
KUE	LANDIS & GYR	MX	C453997	07-18-07	100.1	100.2	99.9
KUE	LANDIS & GYR	MX	C453998	07-18-07	100.1	100.0	100.2
KUE	LANDIS & GYR	MX	C453999	07-18-07	100.0	100.1	100.2
KUE	LANDIS & GYR	MX	C454000	07-18-07	100.1	99.9	100.5
KUE	LANDIS & GYR	MX	C454001	07-18-07	100.1	100.1	100.3
KUE	LANDIS & GYR	MX	C454002	07-18-07	100.1	100.0	99.7
KUE	LANDIS & GYR	MX	C454003	07-18-07	100.0	100.0	99.8
KUE	LANDIS & GYR	MX	C454004	07-18-07	100.0	100.1	99.9
KUE	LANDIS & GYR	MX	C454005	07-18-07	100.0	100.1	99.7
KUE	LANDIS & GYR	MX	C454006	07-18-07	100.0	100.1	99.8
KUE	LANDIS & GYR	MX	C454007	07-18-07	100.1	100.0	99.8
KUE	LANDIS & GYR	MX	C454008	07-18-07	100.1	100.1	99.8
KUE	LANDIS & GYR	MX	C454009	07-18-07	100.0	100.1	100.2
KUE	LANDIS & GYR	MX	C454010	07-18-07	100.1	100.0	100.2
KUE	LANDIS & GYR	MX	C454011	07-18-07	100.0	100.0	99.7
KUE	LANDIS & GYR	MX	C454012	07-18-07	100.0	100.1	99.8
KUE	LANDIS & GYR	MX	C454013	07-18-07	100.0	100.1	100.2
KUE	LANDIS & GYR	MX	C454014	07-18-07	100.1	100.0	100.3
KUE	LANDIS & GYR	MX	C454015	07-18-07	100.1	100.1	100.0
KUE	LANDIS & GYR	MX	C454016	07-18-07	100.0	99.9	100.2
KUE	LANDIS & GYR	MX	C454017	07-18-07	100.0	100.0	99.9
KUE	LANDIS & GYR	MX	C454018	07-18-07	100.1	100.0	100.2
KUE	LANDIS & GYR	MX	C454019	07-18-07	100.1	100.0	100.2
KUE	LANDIS & GYR	MX	C454020	07-18-07	100.1	100.1	100.2
KUE	LANDIS & GYR	MX	C454021	07-18-07	100.1	100.1	100.2
KUE	LANDIS & GYR	MX	C454022	07-18-07	100.1	100.1	100.2
KUE	LANDIS & GYR	MX	C454023	07-18-07	100.1	100.2	100.0
KUE	LANDIS & GYR	MX	C454024	07-18-07	100.1	100.0	99.7
KUE	LANDIS & GYR	MX	C454025	07-18-07	100.1	100.1	100.1
KUE	LANDIS & GYR	MX	C454026	07-18-07	100.1	100.1	100.1
KUE	LANDIS & GYR	MX	C454027	10-11-07	100.1	99.9	100.2
KUE	LANDIS & GYR	MX	C454028	10-11-07	100.1	100.2	100.4
KUE	LANDIS & GYR	MX	C454029	10-11-07	100.1	100.1	100.2
KUE	LANDIS & GYR	MX	C454030	10-11-07	100.0	99.9	100.0
KUE	LANDIS & GYR	MX	C454031	10-11-07	100.1	100.1	100.1
KUE	LANDIS & GYR	MX	C454032	10-11-07	100.0	100.0	100.1
KUE	LANDIS & GYR	MX	C454033	10-11-07	100.0	99.9	100.0
KUE	LANDIS & GYR	MX	C454034	10-11-07	100.1	100.1	100.1
KUE	LANDIS & GYR	MX	C454035	10-11-07	100.0	99.9	100.1
KUE	LANDIS & GYR	MX	C454036	10-11-07	100.0	99.9	100.2
KUE	LANDIS & GYR	MX	C454037	10-11-07	100.1	100.0	100.1
KUE	LANDIS & GYR	MX	C454038	10-11-07	100.1	99.9	99.8
KUE	LANDIS & GYR	MX	C454039	10-11-07	100.1	100.1	100.4
KUE	LANDIS & GYR	MX	C454040	10-11-07	100.1	100.2	100.1
KUE	LANDIS & GYR	MX	C454041	10-11-07	100.1	100.1	100.5
KUE	LANDIS & GYR	MX	C454042	10-11-07	100.1	100.2	100.2
KUE	LANDIS & GYR	MX	C454043	10-11-07	100.0	100.0	100.1
KUE	LANDIS & GYR	MX	C454044	10-11-07	100.0	100.1	100.3
KUE	LANDIS & GYR	MX	C454045	10-11-07	100.0	100.1	99.8
KUE	LANDIS & GYR	MX	C454046	10-11-07	100.1	100.1	100.2
KUE	LANDIS & GYR	MX	C454047	10-11-07	100.0	99.9	100.0

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

CO	MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
KUE	LANDIS & GYR	MX	C454099	10-11-07	100.0	99.9	99.6
KUE	LANDIS & GYR	MX	C454100	10-11-07	100.1	100.0	100.2
KUE	LANDIS & GYR	MX	C454101	10-11-07	100.1	100.1	100.1
KUE	LANDIS & GYR	MX	C454102	10-11-07	100.0	100.1	100.0
KUE	LANDIS & GYR	MX	C454103	10-11-07	100.1	100.1	100.0
KUE	LANDIS & GYR	MX	C454104	10-11-07	99.9	99.9	99.5
KUE	LANDIS & GYR	MX	C454105	10-11-07	100.0	100.0	100.1
KUE	LANDIS & GYR	MX	C454106	10-11-07	100.1	100.0	100.2
KUE	LANDIS & GYR	MX	C454107	10-11-07	100.0	99.9	99.6
KUE	LANDIS & GYR	MX	C454108	10-11-07	100.0	100.1	99.5
KUE	LANDIS & GYR	MX	C454109	10-11-07	100.0	99.9	99.9
KUE	LANDIS & GYR	MX	C454110	10-11-07	100.1	100.1	100.2
KUE	LANDIS & GYR	MX	C454111	10-11-07	100.0	100.0	100.1
KUE	LANDIS & GYR	MX	C454112	10-11-07	100.0	100.2	99.9
KUE	LANDIS & GYR	MX	C454113	10-11-07	100.0	100.0	100.3
KUE	LANDIS & GYR	MX	C454114	10-11-07	100.0	100.0	99.8
KUE	LANDIS & GYR	MX	C454115	10-11-07	100.0	100.0	99.6
KUE	LANDIS & GYR	MX	C454116	10-11-07	100.1	100.1	100.0
KUE	LANDIS & GYR	MX	C454117	10-11-07	100.0	100.0	99.5
KUE	LANDIS & GYR	MX	C454118	10-11-07	99.9	100.0	99.8
KUE	LANDIS & GYR	MX	C454119	10-11-07	100.0	100.0	100.0
KUE	LANDIS & GYR	MX	C454120	10-11-07	100.1	100.0	100.0
KUE	LANDIS & GYR	MX	C454121	10-11-07	100.1	100.2	99.9
KUE	LANDIS & GYR	MX	C454122	10-11-07	100.1	100.0	100.0
KUE	LANDIS & GYR	MX	C454123	10-11-07	100.0	100.1	100.0
KUE	LANDIS & GYR	MX	C454124	10-11-07	100.1	100.1	99.9
KUE	LANDIS & GYR	MX	C454125	10-11-07	100.1	100.1	100.2
KUE	LANDIS & GYR	MX	C454126	10-11-07	100.1	100.0	100.0
KUE	LANDIS & GYR	MX	C454127	10-11-07	100.0	100.0	99.9
KUE	LANDIS & GYR	MX	C454128	10-11-07	100.0	100.0	100.2
KUE	LANDIS & GYR	MX	C454129	10-11-07	100.1	100.2	100.2
KUE	LANDIS & GYR	MX	C454130	10-11-07	100.1	100.0	100.4
KUE	LANDIS & GYR	MX	C454131	10-11-07	100.0	100.0	100.0
KUE	LANDIS & GYR	MX	C454132	10-11-07	100.0	100.1	100.1
KUE	LANDIS & GYR	MX	C454133	10-11-07	100.0	100.2	99.8
KUE	LANDIS & GYR	MX	C454134	10-11-07	100.0	100.2	100.0
KUE	LANDIS & GYR	MX	C454135	10-11-07	100.0	100.1	100.1
KUE	LANDIS & GYR	MX	C454136	10-11-07	100.0	100.0	99.7
KUE	LANDIS & GYR	MX	C454137	10-11-07	100.1	100.1	100.0
KUE	LANDIS & GYR	MX	C454138	10-11-07	100.0	100.0	100.0
KUE	LANDIS & GYR	MX	C454139	10-11-07	100.0	100.0	100.2
KUE	LANDIS & GYR	MX	C454140	10-11-07	100.0	99.9	99.8
KUE	LANDIS & GYR	MX	C454141	10-11-07	100.0	99.9	99.8
KUE	LANDIS & GYR	MX	C454142	10-11-07	100.1	100.1	100.0
KUE	LANDIS & GYR	MX	C454143	10-11-07	100.1	100.0	100.2
KUE	LANDIS & GYR	MX	C454144	10-11-07	100.1	100.0	100.1
KUE	LANDIS & GYR	MX	C454145	10-11-07	100.1	100.0	100.0
KUE	LANDIS & GYR	MX	C454146	10-11-07	100.1	100.1	100.1
KUE	LANDIS & GYR	MX	C454147	10-11-07	100.1	100.0	100.0
KUE	LANDIS & GYR	MX	C454148	10-11-07	100.1	100.0	100.1
KUE	LANDIS & GYR	MX	C454149	10-11-07	100.0	100.1	100.1

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

CO	MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
KUE	LANDIS & GYR	MX	C454201	10-11-07	100.1	100.1	100.1
KUE	LANDIS & GYR	MX	C454202	10-11-07	100.0	100.0	99.9
KUE	LANDIS & GYR	MX	C454203	10-11-07	100.1	100.1	100.3
KUE	LANDIS & GYR	MX	C454204	10-11-07	100.0	100.0	100.1
KUE	LANDIS & GYR	MX	C454205	10-11-07	100.1	100.2	100.2
KUE	LANDIS & GYR	MX	C454206	10-11-07	100.0	100.0	100.2
KUE	LANDIS & GYR	MX	C454207	10-11-07	100.0	100.0	99.9
KUE	LANDIS & GYR	MX	C454208	10-11-07	100.0	100.0	100.3
KUE	LANDIS & GYR	MX	C454209	10-11-07	100.1	100.0	100.0
KUE	LANDIS & GYR	MX	C454210	10-11-07	100.1	99.9	99.8
KUE	LANDIS & GYR	MX	C454211	10-11-07	100.1	100.2	100.2
KUE	LANDIS & GYR	MX	C454212	10-11-07	100.0	100.0	100.1
KUE	LANDIS & GYR	MX	C454213	10-11-07	100.0	99.9	99.9
KUE	LANDIS & GYR	MX	C454214	10-11-07	100.1	100.1	100.1
KUE	LANDIS & GYR	MX	C454215	10-11-07	100.1	100.1	99.9
KUE	LANDIS & GYR	MX	C454216	10-11-07	100.1	100.1	100.1
KUE	LANDIS & GYR	MX	C454217	10-11-07	100.0	99.9	100.0
KUE	LANDIS & GYR	MX	C454218	10-11-07	100.0	100.1	100.2
KUE	LANDIS & GYR	MX	C454219	10-11-07	100.0	100.1	100.1
KUE	LANDIS & GYR	MX	C454220	10-11-07	100.0	99.9	99.9
KUE	LANDIS & GYR	MX	C454221	10-11-07	100.0	100.0	100.0
KUE	LANDIS & GYR	MX	C454222	10-11-07	100.0	100.0	100.2
KUE	LANDIS & GYR	MX	C454223	10-11-07	100.0	100.1	100.3
KUE	LANDIS & GYR	MX	C454224	10-11-07	100.1	100.1	100.3
KUE	LANDIS & GYR	MX	C454225	10-11-07	100.1	100.0	100.2
KUE	LANDIS & GYR	MX	C454226	10-11-07	100.0	99.9	99.9
KUE	LANDIS & GYR	MX	C454227	10-11-07	100.1	100.0	100.1
KUE	LANDIS & GYR	MX	C454228	10-11-07	100.1	99.9	99.7
KUE	LANDIS & GYR	MX	C454229	10-11-07	100.0	99.9	100.0
KUE	LANDIS & GYR	MX	C454230	10-11-07	100.0	100.1	99.8
KUE	LANDIS & GYR	MX	C454231	10-12-07	100.1	100.1	100.6
KUE	LANDIS & GYR	MX	C454232	10-12-07	100.1	100.0	100.4
KUE	LANDIS & GYR	MX	C454233	10-12-07	100.0	100.1	100.1
KUE	LANDIS & GYR	MX	C454234	10-12-07	100.0	100.1	100.6
KUE	LANDIS & GYR	MX	C454235	10-12-07	100.1	100.1	99.8
KUE	LANDIS & GYR	MX	C454236	10-12-07	100.0	99.9	100.3
KUE	LANDIS & GYR	MX	C454237	10-12-07	100.0	100.0	99.6
KUE	LANDIS & GYR	MX	C454238	10-12-07	100.1	100.0	99.6
KUE	LANDIS & GYR	MX	C454239	10-12-07	100.1	100.0	100.1
KUE	LANDIS & GYR	MX	C454240	10-12-07	100.1	100.1	100.5
KUE	LANDIS & GYR	MX	C454241	10-12-07	100.0	100.0	99.6
KUE	LANDIS & GYR	MX	C454242	10-12-07	100.0	100.0	100.0
KUE	LANDIS & GYR	MX	C454243	10-12-07	100.0	99.9	99.7
KUE	LANDIS & GYR	MX	C454244	10-12-07	99.9	100.2	100.0
KUE	LANDIS & GYR	MX	C454245	10-12-07	100.1	99.9	99.5
KUE	LANDIS & GYR	MX	C454246	10-12-07	100.1	100.1	99.9
KUE	LANDIS & GYR	MX	C454247	10-12-07	100.0	100.0	100.4
KUE	LANDIS & GYR	MX	C454248	10-12-07	100.1	100.1	100.0
KUE	LANDIS & GYR	MX	C454249	10-11-07	100.0	99.9	100.2
KUE	LANDIS & GYR	MX	C454250	10-11-07	100.1	100.1	99.9
KUE	LANDIS & GYR	MX	C454251	10-12-07	100.1	100.0	100.1

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

CO	MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
KUE	LANDIS & GYR	MX	C4543303	10-12-07	100.0	100.0	100.2
KUE	LANDIS & GYR	MX	C4543304	10-12-07	100.0	100.0	100.4
KUE	LANDIS & GYR	MX	C4543305	10-12-07	100.1	100.2	100.1
KUE	LANDIS & GYR	MX	C4543306	10-12-07	100.1	100.1	100.0
KUE	LANDIS & GYR	MX	C4543307	10-12-07	100.0	100.0	100.1
KUE	LANDIS & GYR	MX	C4543308	10-12-07	100.0	100.0	100.2
KUE	LANDIS & GYR	MX	C4543309	10-12-07	100.0	99.9	100.2
KUE	LANDIS & GYR	MX	C4543310	10-12-07	100.1	100.1	100.1
KUE	LANDIS & GYR	MX	C4543311	10-12-07	100.1	100.2	100.1
KUE	LANDIS & GYR	MX	C4543312	10-12-07	100.0	100.0	100.1
KUE	LANDIS & GYR	MX	C4543313	10-12-07	100.0	100.0	99.8
KUE	LANDIS & GYR	MX	C4543314	10-12-07	100.0	100.0	100.1
KUE	LANDIS & GYR	MX	C4543315	10-12-07	100.1	100.0	100.2
KUE	LANDIS & GYR	MX	C4543316	10-12-07	100.0	100.1	100.0
KUE	LANDIS & GYR	MX	C4543317	10-12-07	100.1	100.1	100.4
KUE	LANDIS & GYR	MX	C4543318	10-12-07	100.1	100.1	100.1
KUE	LANDIS & GYR	MX	C4543319	10-12-07	100.1	100.2	100.1
KUE	LANDIS & GYR	MX	C4543320	10-12-07	100.1	100.0	100.0
KUE	LANDIS & GYR	MX	C4543321	10-12-07	100.1	100.1	100.2
KUE	LANDIS & GYR	MX	C4543322	10-12-07	99.9	99.9	100.2
KUE	LANDIS & GYR	MX	C4543323	10-12-07	100.1	100.2	100.1
KUE	LANDIS & GYR	MX	C4543324	10-12-07	100.1	100.1	100.1
KUE	LANDIS & GYR	MX	C4543325	10-12-07	100.0	100.1	100.2
KUE	LANDIS & GYR	MX	C4543326	10-12-07	100.1	100.0	100.0
KUE	LANDIS & GYR	MX	C4543327	10-12-07	100.0	100.0	100.1
KUE	LANDIS & GYR	MX	C4543328	10-12-07	100.0	100.1	100.3
KUE	LANDIS & GYR	MX	C4543329	10-12-07	100.0	100.0	100.1
KUE	LANDIS & GYR	MX	C4543330	10-12-07	100.1	99.9	99.9
KUE	LANDIS & GYR	MX	C4543331	10-12-07	100.1	100.2	100.1
KUE	LANDIS & GYR	MX	C4543332	10-12-07	100.1	100.2	100.1
KUE	LANDIS & GYR	MX	C4543333	10-12-07	100.0	100.0	99.6
KUE	LANDIS & GYR	MX	C4543334	10-12-07	100.0	99.9	100.1
KUE	LANDIS & GYR	MX	C4543335	10-12-07	100.0	100.0	99.9
KUE	LANDIS & GYR	MX	C4543336	10-12-07	100.0	100.1	99.9
KUE	LANDIS & GYR	MX	C4543337	10-12-07	100.1	100.0	99.8
KUE	LANDIS & GYR	MX	C4543338	10-12-07	100.1	100.1	100.1
KUE	LANDIS & GYR	MX	C4543339	10-12-07	100.0	99.9	99.9
KUE	LANDIS & GYR	MX	C4543340	10-12-07	100.0	100.0	100.2
KUE	LANDIS & GYR	MX	C4543341	10-12-07	100.0	100.1	99.9
KUE	LANDIS & GYR	MX	C4543342	10-12-07	100.0	100.0	100.0
KUE	LANDIS & GYR	MX	C4543343	10-12-07	100.0	100.0	99.9
KUE	LANDIS & GYR	MX	C4543344	10-12-07	100.0	100.2	99.9
KUE	LANDIS & GYR	MX	C4543345	10-12-07	100.0	99.9	100.2
KUE	LANDIS & GYR	MX	C4543346	10-12-07	100.1	100.1	100.1
KUE	LANDIS & GYR	MX	C4543347	10-12-07	99.9	100.0	99.9
KUE	LANDIS & GYR	MX	C4543348	10-12-07	100.1	100.2	99.9
KUE	LANDIS & GYR	MX	C4543349	10-12-07	100.1	100.2	100.2
KUE	LANDIS & GYR	MX	C4543350	10-12-07	100.1	100.0	100.1
KUE	LANDIS & GYR	MX	C4543351	10-12-07	100.0	99.9	99.8
KUE	LANDIS & GYR	MX	C4543352	10-12-07	100.1	100.1	100.0
KUE	LANDIS & GYR	MX	C4543353	10-12-07	100.0	100.1	99.4

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

CO	MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
KUE	LANDIS & GYR	MX	C454405	10-12-07	100.0	100.0	99.9
KUE	LANDIS & GYR	MX	C454406	10-12-07	100.0	100.0	100.1
KUE	LANDIS & GYR	MX	C454407	10-12-07	100.0	100.0	99.5
KUE	LANDIS & GYR	MX	C454408	10-12-07	100.1	100.0	100.1
KUE	LANDIS & GYR	MX	C454409	10-12-07	100.0	100.0	99.9
KUE	LANDIS & GYR	MX	C454410	10-12-07	100.1	100.1	99.9
KUE	LANDIS & GYR	MX	C454411	10-12-07	100.1	100.0	100.2
KUE	LANDIS & GYR	MX	C454412	10-12-07	100.0	100.1	100.1
KUE	LANDIS & GYR	MX	C454413	10-12-07	100.1	100.0	99.9
KUE	LANDIS & GYR	MX	C454414	10-12-07	100.0	100.0	99.7
KUE	LANDIS & GYR	MX	C454415	10-12-07	100.1	100.0	99.8
KUE	LANDIS & GYR	MX	C454416	10-12-07	100.1	100.0	99.9
KUE	LANDIS & GYR	MX	C454417	10-12-07	100.0	100.0	99.8
KUE	LANDIS & GYR	MX	C454418	10-12-07	100.1	100.2	100.3
KUE	LANDIS & GYR	MX	C454419	10-12-07	100.0	100.1	99.4
KUE	LANDIS & GYR	MX	C454420	10-12-07	100.0	100.0	100.1
KUE	LANDIS & GYR	MX	C454421	10-12-07	99.9	99.9	99.8
KUE	LANDIS & GYR	MX	C454422	10-12-07	100.1	100.1	99.7
KUE	LANDIS & GYR	MX	C454423	10-12-07	100.1	100.1	99.9
KUE	LANDIS & GYR	MX	C454424	10-12-07	100.1	100.1	100.2
KUE	LANDIS & GYR	MX	C454425	10-12-07	100.1	99.9	100.1
KUE	LANDIS & GYR	MX	C454426	10-12-07	100.1	100.0	100.1
KUE	LANDIS & GYR	MX	C454427	10-12-07	100.1	100.0	99.8
KUE	LANDIS & GYR	MX	C454428	10-12-07	100.0	100.1	99.9
KUE	LANDIS & GYR	MX	C454429	10-12-07	100.1	100.2	100.0
KUE	LANDIS & GYR	MX	C454430	10-12-07	100.1	100.0	100.0
KUE	LANDIS & GYR	MX	C454431	10-12-07	100.1	100.2	100.0
KUE	LANDIS & GYR	MX	C454432	10-12-07	100.1	100.2	100.2
KUE	LANDIS & GYR	MX	C454433	10-12-07	100.1	100.1	100.0
KUE	LANDIS & GYR	MX	C454434	10-12-07	100.0	100.0	100.2
KUE	LANDIS & GYR	MX	C454435	10-12-07	100.1	100.0	100.1
KUE	LANDIS & GYR	MX	C454436	10-12-07	100.1	100.2	100.0
KUE	LANDIS & GYR	MX	C454437	10-12-07	100.1	100.1	100.2
KUE	LANDIS & GYR	MX	C454438	10-12-07	100.0	100.0	99.9
KUE	LANDIS & GYR	MX	C454439	10-12-07	100.0	99.9	99.6
KUE	LANDIS & GYR	MX	C454440	10-12-07	99.9	100.0	100.1
KUE	LANDIS & GYR	MX	C454441	10-12-07	100.1	100.1	100.2
KUE	LANDIS & GYR	MX	C454442	10-12-07	100.1	100.1	100.4
KUE	LANDIS & GYR	MX	C454443	10-12-07	100.1	100.1	99.7
KUE	LANDIS & GYR	MX	C454444	10-12-07	100.0	100.0	99.9
KUE	LANDIS & GYR	MX	C454445	10-12-07	100.0	99.9	99.9
KUE	LANDIS & GYR	MX	C454446	10-12-07	100.0	100.2	100.3
KUE	LANDIS & GYR	MX	C454447	10-12-07	99.9	100.0	100.0
KUE	LANDIS & GYR	MX	C454448	10-12-07	100.1	100.0	100.6
KUE	LANDIS & GYR	MX	C454449	10-12-07	100.1	100.0	100.0
KUE	LANDIS & GYR	MX	C454450	10-12-07	100.1	100.2	100.3
KUE	LANDIS & GYR	MX	C454451	10-12-07	100.1	100.0	100.1
KUE	LANDIS & GYR	MX	C454452	10-12-07	100.0	100.2	100.0
KUE	LANDIS & GYR	MX	C454453	10-12-07	100.0	100.0	100.1
KUE	LANDIS & GYR	MX	C454454	10-12-07	100.0	100.2	100.1
KUE	LANDIS & GYR	MX	C454455	10-12-07	100.0	100.1	100.1

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

CO	MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
KUE	LANDIS & GYR	MX	C454507	10-12-07	100.1	100.1	100.2
KUE	LANDIS & GYR	MX	C454508	10-12-07	100.1	100.0	100.5
KUE	LANDIS & GYR	MX	C454509	10-12-07	100.1	99.9	100.1
KUE	LANDIS & GYR	MX	C454510	10-12-07	100.0	100.0	99.9
KUE	LANDIS & GYR	MX	C454511	10-12-07	100.1	100.1	100.2
KUE	LANDIS & GYR	MX	C454512	10-12-07	100.0	100.0	100.0
KUE	LANDIS & GYR	MX	C454513	10-12-07	100.1	100.1	100.2
KUE	LANDIS & GYR	MX	C454514	10-12-07	100.0	100.0	100.0
KUE	LANDIS & GYR	MX	C454515	10-12-07	100.1	99.9	99.9
KUE	LANDIS & GYR	MX	C454516	10-12-07	100.1	100.1	100.1
KUE	LANDIS & GYR	MX	C454517	10-12-07	100.1	100.1	100.2
KUE	LANDIS & GYR	MX	C454518	10-12-07	100.1	100.1	100.2
KUE	LANDIS & GYR	MX	C454519	10-12-07	100.0	100.1	100.0
KUE	LANDIS & GYR	MX	C454520	10-12-07	100.0	100.0	100.2
KUE	LANDIS & GYR	MX	C454521	10-12-07	100.1	99.9	100.2
KUE	LANDIS & GYR	MX	C454522	10-12-07	100.0	100.0	100.0
KUE	LANDIS & GYR	MX	C454523	10-12-07	100.0	100.0	100.0
KUE	LANDIS & GYR	MX	C454524	10-12-07	100.1	100.1	100.3
KUE	LANDIS & GYR	MX	C454525	10-12-07	100.1	100.2	100.1
KUE	LANDIS & GYR	MX	C454526	10-12-07	100.0	99.9	100.2
KUE	LANDIS & GYR	MX	C454527	10-12-07	100.0	100.0	100.1
KUE	LANDIS & GYR	MX	C454528	10-12-07	100.1	100.0	100.0
KUE	LANDIS & GYR	MX	C454529	10-12-07	100.0	99.9	99.9
KUE	LANDIS & GYR	MX	C454530	10-12-07	100.0	100.0	99.9
KUE	LANDIS & GYR	MX	C454531	10-12-07	100.1	100.0	99.9
KUE	LANDIS & GYR	MX	C454532	10-12-07	100.0	100.0	99.9
KUE	LANDIS & GYR	MX	C454533	10-12-07	100.0	100.0	100.0
KUE	LANDIS & GYR	MX	C454534	10-12-07	100.0	100.0	99.5
KUE	LANDIS & GYR	MX	C454535	10-12-07	100.0	100.0	99.8
KUE	LANDIS & GYR	MX	C454536	10-12-07	100.0	100.2	100.0
KUE	LANDIS & GYR	MX	C454537	10-12-07	100.0	100.0	100.1
KUE	LANDIS & GYR	MX	C454538	10-12-07	100.1	100.1	100.2
KUE	LANDIS & GYR	MX	C454539	10-12-07	100.1	100.1	99.9
KUE	LANDIS & GYR	MX	C454540	10-12-07	100.0	100.1	99.9
KUE	LANDIS & GYR	MX	C454541	10-12-07	100.0	100.1	100.0
KUE	LANDIS & GYR	MX	C454542	10-12-07	100.0	100.1	100.0
KUE	LANDIS & GYR	MX	C454543	10-12-07	100.0	100.0	100.0
KUE	LANDIS & GYR	MX	C454544	10-12-07	100.0	100.0	99.9
KUE	LANDIS & GYR	MX	C454545	10-12-07	100.1	100.2	100.1
KUE	LANDIS & GYR	MX	C454546	10-12-07	100.1	100.1	100.1
KUE	LANDIS & GYR	MX	C454547	10-12-07	100.1	100.1	99.9
KUE	LANDIS & GYR	MX	C454548	10-12-07	100.0	100.1	99.6
KUE	LANDIS & GYR	MX	C454549	10-12-07	100.0	100.0	100.0
KUE	LANDIS & GYR	MX	C454550	10-12-07	100.1	100.1	99.8
KUE	LANDIS & GYR	MX	C454551	10-12-07	100.1	100.0	100.3
KUE	LANDIS & GYR	MX	C454552	10-12-07	100.1	100.0	100.1
KUE	LANDIS & GYR	MX	C454553	10-12-07	100.1	100.2	100.1
KUE	LANDIS & GYR	MX	C454554	10-12-07	100.1	100.1	100.0
KUE	LANDIS & GYR	MX	C454555	10-12-07	100.1	99.9	100.0
KUE	LANDIS & GYR	MX	C454556	10-12-07	100.1	100.1	100.4
KUE	LANDIS & GYR	MX	C454557	10-12-07	100.1	100.1	100.1

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

CO	MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
KUE	LANDIS & GYR	MX	C454609	10-12-07	100.1	100.0	100.3
KUE	LANDIS & GYR	MX	C454610	10-12-07	100.1	99.9	100.4
KUE	LANDIS & GYR	MX	C454611	10-12-07	100.0	100.0	99.9
KUE	LANDIS & GYR	MX	C454612	10-12-07	100.1	100.1	100.3
KUE	LANDIS & GYR	MX	C454613	10-12-07	100.0	100.0	99.9
KUE	LANDIS & GYR	MX	C454614	10-12-07	100.1	100.1	100.0
KUE	LANDIS & GYR	MX	C454615	10-12-07	100.0	100.0	100.0
KUE	LANDIS & GYR	MX	C454616	10-12-07	100.0	100.0	100.0
KUE	LANDIS & GYR	MX	C454617	10-12-07	100.0	100.1	99.9
KUE	LANDIS & GYR	MX	C454618	10-12-07	100.0	100.1	99.9
KUE	LANDIS & GYR	MX	C454619	10-12-07	100.1	100.0	100.0
KUE	LANDIS & GYR	MX	C454620	10-12-07	100.0	100.2	100.0
KUE	LANDIS & GYR	MX	C454621	10-12-07	100.0	100.1	100.1
KUE	LANDIS & GYR	MX	C454622	10-12-07	100.1	100.2	100.2
KUE	LANDIS & GYR	MX	C454623	10-12-07	100.0	100.0	100.0
KUE	LANDIS & GYR	MX	C454624	10-12-07	100.0	100.1	100.0
KUE	LANDIS & GYR	MX	C454625	10-12-07	100.1	100.1	99.9
KUE	LANDIS & GYR	MX	C454626	10-12-07	100.0	100.0	100.3
KUE	LANDIS & GYR	MX	C454627	10-12-07	100.0	100.2	100.0
KUE	LANDIS & GYR	MX	C454628	10-12-07	100.1	100.2	100.4
KUE	LANDIS & GYR	MX	C454629	10-12-07	100.1	99.9	100.1
KUE	LANDIS & GYR	MX	C454630	10-12-07	100.0	100.1	100.3
KUE	LANDIS & GYR	MX	C454631	10-12-07	100.0	100.1	99.8
KUE	LANDIS & GYR	MX	C454632	10-12-07	100.0	100.0	99.9
KUE	LANDIS & GYR	MX	C454633	10-12-07	100.1	100.0	100.1
KUE	LANDIS & GYR	MX	C454634	10-12-07	100.1	100.1	99.9
KUE	LANDIS & GYR	MX	C454635	10-12-07	100.0	100.0	100.2
KUE	LANDIS & GYR	MX	C454636	10-12-07	100.1	100.0	99.9
KUE	LANDIS & GYR	MX	C454637	10-12-07	100.1	100.1	100.0
KUE	LANDIS & GYR	MX	C454638	10-12-07	100.1	100.0	99.9
KUE	LANDIS & GYR	MX	C454639	10-12-07	100.1	100.1	100.0
KUE	LANDIS & GYR	MX	C454640	10-12-07	100.1	100.2	99.9
KUE	LANDIS & GYR	MX	C454641	10-12-07	100.1	100.0	100.0
KUE	LANDIS & GYR	MX	C454642	10-12-07	100.1	100.2	100.0
KUE	LANDIS & GYR	MX	C454643	10-12-07	100.1	100.1	99.9
KUE	LANDIS & GYR	MX	C454644	10-12-07	100.0	100.0	100.2
KUE	LANDIS & GYR	MX	C454645	10-12-07	100.0	100.0	100.5
KUE	LANDIS & GYR	MX	C454646	10-12-07	100.1	100.0	100.2
KUE	LANDIS & GYR	MX	C454647	10-12-07	100.1	100.1	100.2
KUE	LANDIS & GYR	MX	C454648	10-12-07	100.1	100.0	99.9
KUE	LANDIS & GYR	MX	C454649	10-12-07	100.1	100.0	100.0
KUE	LANDIS & GYR	MX	C454650	10-12-07	100.1	100.2	100.0
KUE	LANDIS & GYR	MX	C454651	10-12-07	100.0	100.0	100.2
KUE	LANDIS & GYR	MX	C454652	10-12-07	100.1	100.0	100.6
KUE	LANDIS & GYR	MX	C454653	10-12-07	100.1	99.9	100.0
KUE	LANDIS & GYR	MX	C454654	10-12-07	100.0	100.1	100.0
KUE	LANDIS & GYR	MX	C454655	10-12-07	100.0	100.0	100.1
KUE	LANDIS & GYR	MX	C454656	10-12-07	100.0	100.0	99.9
KUE	LANDIS & GYR	MX	C454657	10-12-07	100.0	100.1	100.0
KUE	LANDIS & GYR	MX	C454658	10-12-07	100.0	100.0	99.9
KUE	LANDIS & GYR	MX	C454659	10-12-07	100.1	100.0	100.0

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

CO	MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
KUE	LANDIS & GYR	MX	C454711	10-12-07	100.0	100.0	100.2
KUE	LANDIS & GYR	MX	C454712	10-12-07	100.0	100.0	99.9
KUE	LANDIS & GYR	MX	C454713	10-12-07	100.1	100.2	100.0
KUE	LANDIS & GYR	MX	C454714	10-12-07	100.0	99.9	100.0
KUE	LANDIS & GYR	MX	C454715	10-12-07	100.1	100.0	100.1
KUE	LANDIS & GYR	MX	C454716	10-12-07	100.1	100.0	100.1
KUE	LANDIS & GYR	MX	C454717	10-12-07	100.1	100.0	100.2
KUE	LANDIS & GYR	MX	C454718	10-12-07	100.0	100.0	100.2
KUE	LANDIS & GYR	MX	C454719	10-12-07	100.0	100.0	99.9
KUE	LANDIS & GYR	MX	C454720	10-12-07	100.1	100.1	100.1
KUE	LANDIS & GYR	MX	C454721	10-12-07	100.0	100.0	100.1
KUE	LANDIS & GYR	MX	C454722	10-12-07	100.0	100.2	100.2
KUE	LANDIS & GYR	MX	C454723	10-12-07	100.1	100.2	100.2
KUE	LANDIS & GYR	MX	C454724	10-12-07	100.1	100.0	100.1
KUE	LANDIS & GYR	MX	C454725	10-12-07	100.0	100.1	100.1
KUE	LANDIS & GYR	MX	C454726	10-12-07	100.0	100.2	100.1
KUE	LANDIS & GYR	MX	C454727	10-12-07	99.9	100.1	100.1
KUE	LANDIS & GYR	MX	C454728	10-12-07	100.1	100.1	100.1
KUE	LANDIS & GYR	MX	C454729	10-12-07	100.0	100.0	100.2
KUE	LANDIS & GYR	MX	C454730	10-12-07	100.0	100.2	100.2
KUE	LANDIS & GYR	MX	C454731	10-12-07	100.1	100.1	100.0
KUE	LANDIS & GYR	MX	C454732	10-12-07	100.0	100.0	99.9
KUE	LANDIS & GYR	MX	C454733	10-12-07	100.1	100.0	100.3
KUE	LANDIS & GYR	MX	C454734	10-12-07	100.1	100.1	100.3
KUE	LANDIS & GYR	MX	C454735	10-12-07	100.1	100.1	100.3
KUE	LANDIS & GYR	MX	C454736	10-12-07	100.0	100.1	100.2
KUE	LANDIS & GYR	MX	C454737	10-12-07	100.0	100.2	100.4
KUE	LANDIS & GYR	MX	C454738	10-12-07	100.0	100.0	100.0
KUE	LANDIS & GYR	MX	C454739	10-12-07	100.0	100.0	100.1
KUE	LANDIS & GYR	MX	C454740	10-12-07	100.0	100.1	100.2
KUE	LANDIS & GYR	MX	C454741	10-12-07	100.1	100.0	100.1
KUE	LANDIS & GYR	MX	C454742	10-12-07	100.1	100.1	100.0
KUE	LANDIS & GYR	MX	C454743	10-12-07	100.0	100.1	100.1
KUE	LANDIS & GYR	MX	C454744	10-12-07	100.1	100.1	99.7
KUE	LANDIS & GYR	MX	C454745	10-12-07	100.0	99.9	100.5
KUE	LANDIS & GYR	MX	C454746	10-12-07	100.0	100.0	100.5
KUE	LANDIS & GYR	MX	C454747	10-12-07	100.1	99.9	100.1
KUE	LANDIS & GYR	MX	C454748	10-12-07	100.0	100.0	100.2
KUE	LANDIS & GYR	MX	C454749	10-12-07	100.1	100.2	100.1
KUE	LANDIS & GYR	MX	C454750	10-12-07	100.1	100.1	100.0
KUE	LANDIS & GYR	MX	C454751	10-12-07	100.0	99.9	100.1
KUE	LANDIS & GYR	MX	C454752	10-12-07	100.1	100.1	100.1
KUE	LANDIS & GYR	MX	C454753	10-12-07	100.0	100.1	100.2
KUE	LANDIS & GYR	MX	C454754	10-12-07	100.1	100.0	100.4
KUE	LANDIS & GYR	MX	C454755	10-12-07	100.0	100.0	100.0
KUE	LANDIS & GYR	MX	C454756	10-12-07	100.1	100.0	100.1
KUE	LANDIS & GYR	MX	C454757	10-12-07	100.0	99.9	100.2
KUE	LANDIS & GYR	MX	C454758	10-12-07	100.0	100.0	100.2
KUE	LANDIS & GYR	MX	C454759	10-12-07	100.1	100.1	100.1
KUE	LANDIS & GYR	MX	C454760	10-12-07	100.0	100.0	100.1
KUE	LANDIS & GYR	MX	C454761	10-12-07	100.1	100.2	100.0

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

CO	MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
KUE	LANDIS & GYR	MX	C454813	10-15-07	100.1	100.1	100.2
KUE	LANDIS & GYR	MX	C454814	10-13-07	100.0	100.1	100.1
KUE	LANDIS & GYR	MX	C454815	10-13-07	100.0	100.1	99.9
KUE	LANDIS & GYR	MX	C454816	10-13-07	100.0	99.9	99.8
KUE	LANDIS & GYR	MX	C454817	10-13-07	100.1	99.9	100.2
KUE	LANDIS & GYR	MX	C454818	10-15-07	100.0	99.9	100.0
KUE	LANDIS & GYR	MX	C454819	10-13-07	100.0	100.1	100.1
KUE	LANDIS & GYR	MX	C454820	10-13-07	100.1	100.0	100.1
KUE	LANDIS & GYR	MX	C454821	10-13-07	100.1	100.1	100.2
KUE	LANDIS & GYR	MX	C454822	10-13-07	100.0	100.0	100.2
KUE	LANDIS & GYR	MX	C454823	10-13-07	100.0	100.0	100.1
KUE	LANDIS & GYR	MX	C454824	10-13-07	100.0	100.1	100.0
KUE	LANDIS & GYR	MX	C454825	10-13-07	100.0	99.9	100.0
KUE	LANDIS & GYR	MX	C454826	10-13-07	100.1	100.1	100.3
KUE	LANDIS & GYR	MX	C454827	10-13-07	100.0	100.0	100.3
KUE	LANDIS & GYR	MX	C454828	10-13-07	100.1	100.1	100.0
KUE	LANDIS & GYR	MX	C454829	10-13-07	100.0	100.0	99.7
KUE	LANDIS & GYR	MX	C454830	10-13-07	100.0	100.1	100.1
KUE	LANDIS & GYR	MX	C454831	10-13-07	100.1	100.0	100.1
KUE	LANDIS & GYR	MX	C454832	10-13-07	100.0	100.0	100.2
KUE	LANDIS & GYR	MX	C454833	10-13-07	100.1	100.1	98.5
KUE	LANDIS & GYR	MX	C454834	10-13-07	100.1	100.1	100.1
KUE	LANDIS & GYR	MX	C454835	10-13-07	100.1	100.1	100.1
KUE	LANDIS & GYR	MX	C454836	10-13-07	100.0	100.0	99.8
KUE	LANDIS & GYR	MX	C454837	10-13-07	100.1	100.0	100.3
KUE	LANDIS & GYR	MX	C454838	10-13-07	100.0	100.0	100.0
KUE	LANDIS & GYR	MX	C454839	10-13-07	100.1	100.0	99.9
KUE	LANDIS & GYR	MX	C454840	10-13-07	100.1	100.0	100.1
KUE	LANDIS & GYR	MX	C454841	10-13-07	100.1	100.1	100.0
KUE	LANDIS & GYR	MX	C454842	10-13-07	100.1	100.1	99.8
KUE	LANDIS & GYR	MX	C454843	10-13-07	100.1	100.0	100.1
KUE	LANDIS & GYR	MX	C454844	10-13-07	100.0	100.0	100.1
KUE	LANDIS & GYR	MX	C454845	10-13-07	100.0	100.1	100.1
KUE	LANDIS & GYR	MX	C454846	10-13-07	100.0	100.2	99.9
KUE	LANDIS & GYR	MX	C454847	10-13-07	100.0	100.1	100.0
KUE	LANDIS & GYR	MX	C454848	10-13-07	100.1	100.1	99.9
KUE	LANDIS & GYR	MX	C454849	10-13-07	100.1	100.1	100.3
KUE	LANDIS & GYR	MX	C454850	10-13-07	100.1	100.0	100.3
KUE	LANDIS & GYR	MX	C454851	10-13-07	100.0	100.0	100.1
KUE	LANDIS & GYR	MX	C454852	10-13-07	100.1	100.1	100.1
KUE	LANDIS & GYR	MX	C454853	10-13-07	100.1	100.1	100.1
KUE	LANDIS & GYR	MX	C454854	10-13-07	100.1	100.1	100.1
KUE	LANDIS & GYR	MX	C454855	10-15-07	100.0	100.0	99.7
KUE	LANDIS & GYR	MX	C454856	10-13-07	100.1	100.2	100.0
KUE	LANDIS & GYR	MX	C454857	10-13-07	100.1	100.1	100.1
KUE	LANDIS & GYR	MX	C454858	10-13-07	100.1	100.1	99.18
KUE	LANDIS & GYR	MX	C454859	10-15-07	100.0	100.0	100.1
KUE	LANDIS & GYR	MX	C454860	10-13-07	100.1	100.0	100.3
KUE	LANDIS & GYR	MX	C454861	10-15-07	100.1	100.0	99.9
KUE	LANDIS & GYR	MX	C454862	10-13-07	100.1	100.1	100.3
KUE	LANDIS & GYR	MX	C454863	10-15-07	100.0	100.1	100.2

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

CO	MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
KUE	LANDIS & GYR	MX	C454915	10-15-07	100.0	99.9	100.2
KUE	LANDIS & GYR	MX	C454916	10-15-07	100.1	100.0	100.2
KUE	LANDIS & GYR	MX	C454917	10-15-07	100.1	100.1	100.3
KUE	LANDIS & GYR	MX	C454918	10-15-07	100.0	100.0	100.1
KUE	LANDIS & GYR	MX	C454919	10-15-07	100.0	99.9	100.2
KUE	LANDIS & GYR	MX	C454920	10-15-07	100.0	100.0	100.1
KUE	LANDIS & GYR	MX	C454921	10-15-07	100.1	100.0	99.7
KUE	LANDIS & GYR	MX	C454922	10-15-07	100.1	100.1	100.4
KUE	LANDIS & GYR	MX	C454923	10-15-07	100.1	100.1	100.4
KUE	LANDIS & GYR	MX	C454924	10-15-07	100.1	100.1	100.3
KUE	LANDIS & GYR	MX	C454925	10-15-07	100.1	100.1	100.1
KUE	LANDIS & GYR	MX	C454926	10-15-07	100.0	100.1	100.1
KUE	LANDIS & GYR	MX	C454927	10-15-07	100.0	99.9	100.2
KUE	LANDIS & GYR	MX	C454928	10-15-07	100.0	100.0	99.8
KUE	LANDIS & GYR	MX	C454929	10-15-07	100.1	100.2	100.2
KUE	LANDIS & GYR	MX	C454930	10-15-07	100.1	100.0	100.1
KUE	LANDIS & GYR	MX	C454931	10-15-07	100.0	100.1	99.5
KUE	LANDIS & GYR	MX	C454932	10-15-07	100.0	100.0	100.2
KUE	LANDIS & GYR	MX	C454933	10-15-07	100.1	100.1	100.2
KUE	LANDIS & GYR	MX	C454934	10-15-07	100.1	100.1	100.1
KUE	LANDIS & GYR	MX	C454935	10-15-07	100.0	100.0	99.9
KUE	LANDIS & GYR	MX	C454936	10-15-07	100.0	99.9	100.1
KUE	LANDIS & GYR	MX	C454937	10-15-07	100.1	100.0	99.9
KUE	LANDIS & GYR	MX	C454938	10-15-07	100.1	100.1	100.1
KUE	LANDIS & GYR	MX	C454939	10-15-07	100.1	100.0	100.0
KUE	LANDIS & GYR	MX	C454940	10-15-07	100.1	100.1	100.1
KUE	LANDIS & GYR	MX	C454941	10-15-07	100.0	100.1	100.3
KUE	LANDIS & GYR	MX	C454942	10-15-07	100.1	100.0	99.8
KUE	LANDIS & GYR	MX	C454943	10-15-07	100.0	100.1	100.1
KUE	LANDIS & GYR	MX	C454944	10-15-07	100.0	100.0	100.0
KUE	LANDIS & GYR	MX	C454945	10-15-07	100.0	100.0	100.0
KUE	LANDIS & GYR	MX	C454946	10-15-07	100.0	99.9	100.4
KUE	LANDIS & GYR	MX	C454947	10-15-07	100.0	100.1	100.1
KUE	LANDIS & GYR	MX	C454948	10-15-07	100.0	99.9	100.1
KUE	LANDIS & GYR	MX	C454949	10-15-07	99.9	100.1	99.3
KUE	LANDIS & GYR	MX	C454950	10-15-07	100.0	99.9	100.0
KUE	LANDIS & GYR	MX	C454951	10-15-07	100.0	99.9	100.2
KUE	LANDIS & GYR	MX	C454952	10-15-07	100.0	100.1	100.1
KUE	LANDIS & GYR	MX	C454953	10-15-07	100.1	100.0	99.8
KUE	LANDIS & GYR	MX	C454954	10-15-07	100.1	100.2	100.3
KUE	LANDIS & GYR	MX	C454955	10-15-07	100.1	100.0	100.2
KUE	LANDIS & GYR	MX	C454956	10-15-07	100.1	100.1	100.1
KUE	LANDIS & GYR	MX	C454957	10-15-07	100.1	100.0	100.1
KUE	LANDIS & GYR	MX	C454958	10-15-07	100.0	100.0	100.2
KUE	LANDIS & GYR	MX	C454959	10-15-07	100.1	100.0	100.0
KUE	LANDIS & GYR	MX	C454960	10-15-07	100.1	99.9	99.9
KUE	LANDIS & GYR	MX	C454961	10-15-07	100.1	100.1	100.2
KUE	LANDIS & GYR	MX	C454962	10-15-07	100.0	100.0	100.1
KUE	LANDIS & GYR	MX	C454963	10-15-07	100.0	100.0	100.1
KUE	LANDIS & GYR	MX	C454964	10-15-07	100.1	99.9	100.1
KUE	LANDIS & GYR	MX	C454965	10-15-07	100.1	100.2	100.0

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

CO	MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
KUE	LANDIS & GYR	MX	C455017	10-15-07	100.1	99.9	100.0
KUE	LANDIS & GYR	MX	C455018	10-15-07	100.1	100.0	100.0
KUE	LANDIS & GYR	MX	C455019	10-15-07	100.1	100.0	99.9
KUE	LANDIS & GYR	MX	C455020	10-15-07	100.1	100.2	99.8
KUE	LANDIS & GYR	MX	C455021	10-15-07	100.1	100.2	100.0
KUE	LANDIS & GYR	MX	C455022	10-15-07	100.1	100.0	100.2
KUE	LANDIS & GYR	MX	C455023	10-15-07	100.0	100.0	99.9
KUE	LANDIS & GYR	MX	C455024	10-15-07	100.1	100.1	100.0
KUE	LANDIS & GYR	MX	C455025	10-15-07	100.1	100.1	100.2
KUE	LANDIS & GYR	MX	C455026	10-15-07	100.0	100.0	99.8
KUE	LANDIS & GYR	MX	C455027	10-15-07	100.0	100.0	99.9
KUE	LANDIS & GYR	MX	C455028	10-15-07	100.0	100.1	100.1
KUE	LANDIS & GYR	MX	C455029	10-15-07	100.1	100.1	100.0
KUE	LANDIS & GYR	MX	C455030	10-15-07	100.1	100.1	100.2
KUE	LANDIS & GYR	MX	C455031	10-15-07	100.1	100.1	100.3
KUE	LANDIS & GYR	MX	C455032	10-15-07	100.1	100.1	100.2
KUE	LANDIS & GYR	MX	C455033	10-15-07	100.0	100.0	99.8
KUE	LANDIS & GYR	MX	C455034	10-15-07	100.0	99.9	100.3
KUE	LANDIS & GYR	MX	C455035	10-15-07	100.1	100.1	100.2
KUE	LANDIS & GYR	MX	C455036	10-15-07	100.0	100.1	99.9
KUE	LANDIS & GYR	MX	C455037	10-15-07	100.1	99.9	100.3
KUE	LANDIS & GYR	MX	C455038	10-15-07	100.1	99.9	99.9
KUE	LANDIS & GYR	MX	C455039	10-15-07	100.0	100.1	100.0
KUE	LANDIS & GYR	MX	C455040	10-15-07	100.0	100.1	100.4
KUE	LANDIS & GYR	MX	C455041	10-15-07	100.1	100.1	100.2
KUE	LANDIS & GYR	MX	C455042	10-15-07	100.1	100.1	100.0
KUE	LANDIS & GYR	MX	C455043	10-15-07	100.1	100.1	99.9
KUE	LANDIS & GYR	MX	C455044	10-15-07	100.0	100.0	100.3
KUE	LANDIS & GYR	MX	C455045	10-15-07	100.0	99.9	100.4
KUE	LANDIS & GYR	MX	C455046	10-15-07	100.1	100.0	99.9
KUE	LANDIS & GYR	MX	C455047	10-15-07	100.1	100.0	99.9
KUE	LANDIS & GYR	MX	C455048	10-15-07	100.1	100.2	100.5
KUE	LANDIS & GYR	MX	C455049	10-15-07	100.0	100.0	100.3
KUE	LANDIS & GYR	MX	C455050	10-15-07	100.1	100.1	100.3
KUE	LANDIS & GYR	MX	C455051	10-15-07	100.0	100.1	99.8
KUE	LANDIS & GYR	MX	C455052	10-15-07	100.1	100.0	100.0
KUE	LANDIS & GYR	MX	C455053	10-15-07	100.1	100.2	100.3
KUE	LANDIS & GYR	MX	C455054	10-15-07	100.1	100.2	100.3
KUE	LANDIS & GYR	MX	C455055	10-15-07	100.1	100.1	100.1
KUE	LANDIS & GYR	MX	C455056	10-15-07	100.0	100.1	100.3
KUE	LANDIS & GYR	MX	C455057	10-15-07	100.1	100.0	100.1
KUE	LANDIS & GYR	MX	C455058	10-15-07	100.0	100.0	100.3
KUE	LANDIS & GYR	MX	C455059	10-15-07	100.0	99.9	100.2
KUE	LANDIS & GYR	MX	C455060	10-15-07	100.1	100.0	100.3
KUE	LANDIS & GYR	MX	C455061	10-15-07	100.0	100.0	100.4
KUE	LANDIS & GYR	MX	C455062	10-15-07	100.0	100.2	100.2
KUE	LANDIS & GYR	MX	C455063	10-15-07	100.1	100.0	100.1
KUE	LANDIS & GYR	MX	C455064	10-15-07	100.1	100.1	99.9
KUE	LANDIS & GYR	MX	C455065	10-15-07	100.0	100.1	100.2
KUE	LANDIS & GYR	MX	C455066	10-15-07	100.1	100.1	100.2
KUE	LANDIS & GYR	MX	C455067	10-15-07	100.0	100.1	100.1

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

CO	MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
KUE	LANDIS & GYR	MX	C455119	10-15-07	100.0	100.1	99.7
KUE	LANDIS & GYR	MX	C455120	10-15-07	100.1	99.9	99.8
KUE	LANDIS & GYR	MX	C455121	10-15-07	100.1	100.2	99.8
KUE	LANDIS & GYR	MX	C455122	10-15-07	100.1	100.0	100.2
KUE	LANDIS & GYR	MX	C455123	10-15-07	100.0	100.0	99.8
KUE	LANDIS & GYR	MX	C455124	10-15-07	100.1	100.1	100.2
KUE	LANDIS & GYR	MX	C455125	10-15-07	100.0	100.0	100.1
KUE	LANDIS & GYR	MX	C455126	10-15-07	100.0	100.0	99.5
KUE	LANDIS & GYR	MX	C455127	10-15-07	100.0	100.0	99.9
KUE	LANDIS & GYR	MX	C455128	10-15-07	100.0	100.2	100.2
KUE	LANDIS & GYR	MX	C455129	10-15-07	100.1	100.1	99.8
KUE	LANDIS & GYR	MX	C455130	10-15-07	100.1	99.9	99.6
KUE	LANDIS & GYR	MX	C455131	10-15-07	100.1	99.9	100.2
KUE	LANDIS & GYR	MX	C455132	10-15-07	100.0	99.9	100.1
KUE	LANDIS & GYR	MX	C455133	10-15-07	100.0	100.0	99.5
KUE	LANDIS & GYR	MX	C455134	10-15-07	100.0	100.0	100.1
KUE	LANDIS & GYR	MX	C455135	10-15-07	100.1	100.0	99.7
KUE	LANDIS & GYR	MX	C455136	10-15-07	100.1	100.1	100.1
KUE	LANDIS & GYR	MX	C455137	10-15-07	100.0	100.0	100.2
KUE	LANDIS & GYR	MX	C455138	10-15-07	100.1	100.0	100.2
KUE	LANDIS & GYR	MX	C455139	10-15-07	100.0	100.1	99.6
KUE	LANDIS & GYR	MX	C455140	10-15-07	100.1	100.1	100.0
KUE	LANDIS & GYR	MX	C455141	10-15-07	100.1	99.9	100.1
KUE	LANDIS & GYR	MX	C455142	10-15-07	100.0	100.0	99.7
KUE	LANDIS & GYR	MX	C455143	10-15-07	100.1	100.0	99.8
KUE	LANDIS & GYR	MX	C455144	10-15-07	100.1	100.1	100.0
KUE	LANDIS & GYR	MX	C455145	10-15-07	100.1	100.1	100.1
KUE	LANDIS & GYR	MX	C455146	10-15-07	100.0	100.0	100.2
KUE	LANDIS & GYR	MX	C455147	10-15-07	100.1	100.1	100.2
KUE	LANDIS & GYR	MX	C455148	10-15-07	100.0	99.9	99.9
KUE	LANDIS & GYR	MX	C455149	10-15-07	100.0	100.2	100.2
KUE	LANDIS & GYR	MX	C455150	10-15-07	100.0	99.9	100.0
KUE	LANDIS & GYR	MX	C455151	10-15-07	100.0	100.0	100.1
KUE	LANDIS & GYR	MX	C455152	10-15-07	100.0	100.0	100.2
KUE	LANDIS & GYR	MX	C455153	10-15-07	100.0	100.0	100.1
KUE	LANDIS & GYR	MX	C455154	10-15-07	100.1	100.1	100.2
KUE	LANDIS & GYR	MX	C455155	10-15-07	100.1	100.1	100.4
KUE	LANDIS & GYR	MX	C455156	10-15-07	100.1	99.9	100.1
KUE	LANDIS & GYR	MX	C455157	10-15-07	100.0	100.0	99.8
KUE	LANDIS & GYR	MX	C455158	10-15-07	100.1	100.0	100.0
KUE	LANDIS & GYR	MX	C455159	10-15-07	100.1	100.1	100.1
KUE	LANDIS & GYR	MX	C455160	10-15-07	100.0	100.0	100.0
KUE	LANDIS & GYR	MX	C455161	10-15-07	100.1	100.1	100.1
KUE	LANDIS & GYR	MX	C455162	10-15-07	100.1	100.2	100.4
KUE	LANDIS & GYR	MX	C455163	10-15-07	100.0	100.1	99.9
KUE	LANDIS & GYR	MX	C455164	10-15-07	100.1	100.1	100.0
KUE	LANDIS & GYR	MX	C455165	10-15-07	100.1	99.9	100.0
KUE	LANDIS & GYR	MX	C455166	10-15-07	100.1	100.1	100.3
KUE	LANDIS & GYR	MX	C455167	10-15-07	100.1	100.1	100.2
KUE	LANDIS & GYR	MX	C455168	10-15-07	100.0	99.9	100.0
KUE	LANDIS & GYR	MX	C455169	10-15-07	100.1	100.1	100.2

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

CO	MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
KUE	LANDIS & GYR	MX	C455221	10-15-07	100.1	100.1	100.0
KUE	LANDIS & GYR	MX	C455222	10-15-07	100.0	100.2	100.1
KUE	LANDIS & GYR	MX	C455223	10-15-07	100.1	100.1	100.3
KUE	LANDIS & GYR	MX	C455224	10-15-07	100.1	100.1	100.3
KUE	LANDIS & GYR	MX	C455225	10-15-07	100.1	100.1	100.1
KUE	LANDIS & GYR	MX	C455226	10-15-07	100.1	100.2	100.1
KUE	LANDIS & GYR	MX	C455227	10-15-07	100.1	100.1	100.2
KUE	LANDIS & GYR	MX	C455228	10-15-07	100.1	100.1	100.4
KUE	LANDIS & GYR	MX	C455229	10-15-07	100.1	100.2	100.1
KUE	LANDIS & GYR	MX	C455230	10-15-07	100.0	100.1	100.1
KUE	LANDIS & GYR	MX	C455231	10-15-07	100.1	100.1	100.3
KUE	LANDIS & GYR	MX	C455232	10-15-07	100.0	100.1	100.0
KUE	LANDIS & GYR	MX	C455233	10-15-07	100.0	100.1	100.0
KUE	LANDIS & GYR	MX	C455234	10-15-07	100.0	100.1	100.0
KUE	LANDIS & GYR	MX	C455235	10-15-07	100.1	100.1	100.0
KUE	LANDIS & GYR	MX	C455236	10-15-07	100.1	100.1	100.0
KUE	LANDIS & GYR	MX	C455237	10-15-07	100.0	100.2	100.0
KUE	LANDIS & GYR	MX	C455238	10-15-07	100.0	100.0	100.0
KUE	LANDIS & GYR	MX	C455239	10-15-07	100.0	100.1	100.0
KUE	LANDIS & GYR	MX	C455240	10-15-07	100.0	100.0	100.0
KUE	LANDIS & GYR	MX	C455241	10-15-07	100.0	100.0	99.9
KUE	LANDIS & GYR	MX	C455242	10-15-07	100.1	100.2	100.1
KUE	LANDIS & GYR	MX	C455243	10-15-07	100.0	100.1	100.2
KUE	LANDIS & GYR	MX	C455244	10-15-07	100.1	100.2	99.9
KUE	LANDIS & GYR	MX	C455245	10-15-07	100.0	99.9	99.7
KUE	LANDIS & GYR	MX	C455246	10-15-07	100.0	100.0	100.6
KUE	LANDIS & GYR	MX	C455247	10-15-07	100.0	100.0	100.2
KUE	LANDIS & GYR	MX	C455248	10-15-07	100.1	100.1	100.2
KUE	LANDIS & GYR	MX	C455249	10-15-07	100.1	100.1	100.3
KUE	LANDIS & GYR	MX	C455250	10-15-07	100.0	100.0	99.6
KUE	LANDIS & GYR	MX	C455251	10-15-07	100.0	100.1	99.9
KUE	LANDIS & GYR	MX	C455252	10-15-07	100.0	100.0	100.1
KUE	LANDIS & GYR	MX	C455253	10-15-07	100.1	100.1	100.2
KUE	LANDIS & GYR	MX	C455254	10-15-07	100.0	100.0	99.7
KUE	LANDIS & GYR	MX	C455255	10-15-07	100.1	100.1	99.9
KUE	LANDIS & GYR	MX	C455256	10-15-07	100.1	100.1	99.9
KUE	LANDIS & GYR	MX	C455257	10-15-07	99.9	100.2	100.0
KUE	LANDIS & GYR	MX	C455258	10-15-07	100.1	100.0	100.1
KUE	LANDIS & GYR	MX	C455259	10-15-07	100.1	99.9	100.0
KUE	LANDIS & GYR	MX	C455260	10-15-07	100.0	100.1	100.1
KUE	LANDIS & GYR	MX	C455261	10-15-07	100.0	100.0	100.0
KUE	LANDIS & GYR	MX	C455262	10-15-07	100.0	100.0	100.0
KUE	LANDIS & GYR	MX	C455263	10-15-07	100.1	99.9	99.9
KUE	LANDIS & GYR	MX	C455264	10-15-07	100.0	100.1	100.0
KUE	LANDIS & GYR	MX	C455265	10-15-07	100.1	100.1	100.0
KUE	LANDIS & GYR	MX	C455266	10-15-07	100.1	100.1	100.2
KUE	LANDIS & GYR	MX	C455267	10-15-07	100.1	100.1	100.2
KUE	LANDIS & GYR	MX	C455268	10-15-07	100.1	100.1	100.2
KUE	LANDIS & GYR	MX	C455269	10-15-07	100.0	99.9	99.8
KUE	LANDIS & GYR	MX	C455270	10-15-07	100.0	100.0	100.1
KUE	LANDIS & GYR	MX	C455271	10-15-07	100.0	100.2	100.4

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

CO	MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
KUE	LANDIS & GYR	MX	C455323	10-15-07	100.0	100.1	99.8
KUE	LANDIS & GYR	MX	C455324	10-15-07	100.1	100.0	100.3
KUE	LANDIS & GYR	MX	C455325	10-15-07	100.0	100.2	100.3
KUE	LANDIS & GYR	MX	C455326	10-15-07	100.1	100.1	100.1
KUE	LANDIS & GYR	MX	C455327	10-15-07	100.1	100.1	99.8
KUE	LANDIS & GYR	MX	C455328	10-15-07	100.1	100.2	100.0
KUE	LANDIS & GYR	MX	C455329	10-15-07	100.1	100.1	100.0
KUE	LANDIS & GYR	MX	C455330	10-15-07	100.0	100.1	99.9
KUE	LANDIS & GYR	MX	C455331	10-15-07	100.0	99.9	100.0
KUE	LANDIS & GYR	MX	C455332	10-15-07	100.1	100.0	99.9
KUE	LANDIS & GYR	MX	C455333	10-15-07	99.9	99.9	99.8
KUE	LANDIS & GYR	MX	C455334	10-15-07	100.1	100.1	100.1
KUE	LANDIS & GYR	MX	C455335	10-15-07	99.9	99.9	100.1
KUE	LANDIS & GYR	MX	C455336	10-15-07	100.0	100.1	100.1
KUE	LANDIS & GYR	MX	C455337	10-15-07	100.1	100.1	100.0
KUE	LANDIS & GYR	MX	C455338	10-15-07	100.1	100.0	100.0
KUE	LANDIS & GYR	MX	C455339	10-15-07	100.1	100.0	100.0
KUE	LANDIS & GYR	MX	C455340	10-15-07	100.1	100.2	99.9
KUE	LANDIS & GYR	MX	C455341	10-15-07	100.1	100.0	100.2
KUE	LANDIS & GYR	MX	C455342	10-15-07	100.0	100.0	100.0
KUE	LANDIS & GYR	MX	C455343	10-15-07	100.0	100.0	100.1
KUE	LANDIS & GYR	MX	C455344	10-15-07	100.0	100.0	100.1
KUE	LANDIS & GYR	MX	C455345	10-15-07	100.1	100.0	100.1
KUE	LANDIS & GYR	MX	C455346	10-15-07	100.1	100.2	99.9
KUE	LANDIS & GYR	MX	C455347	10-15-07	100.0	100.1	100.1
KUE	LANDIS & GYR	MX	C455348	10-15-07	100.0	100.1	100.0
KUE	LANDIS & GYR	MX	C455349	10-15-07	100.0	100.0	100.1
KUE	LANDIS & GYR	MX	C455350	10-15-07	100.0	100.0	100.3
KUE	LANDIS & GYR	MX	C455351	10-15-07	100.0	100.0	99.9
KUE	LANDIS & GYR	MX	C455352	10-15-07	100.0	99.9	100.2
KUE	LANDIS & GYR	MX	C455353	10-15-07	100.0	100.1	99.9
KUE	LANDIS & GYR	MX	C455354	10-15-07	100.0	100.0	99.9
KUE	LANDIS & GYR	MX	C455355	10-15-07	100.0	99.9	100.0
KUE	LANDIS & GYR	MX	C455356	10-15-07	100.0	100.0	100.0
KUE	LANDIS & GYR	MX	C455357	10-15-07	100.0	100.0	1
KUE	LANDIS & GYR	MX	C455358	10-15-07	100.0	100.0	99.8
KUE	LANDIS & GYR	MX	C455359	10-15-07	100.1	100.1	99.7
KUE	LANDIS & GYR	MX	C455360	10-15-07	100.0	100.1	99.9
KUE	LANDIS & GYR	MX	C455361	10-15-07	100.0	100.1	99.8
KUE	LANDIS & GYR	MX	C455362	10-15-07	100.1	100.1	100.1
KUE	LANDIS & GYR	MX	C455363	10-15-07	100.1	100.0	100.2
KUE	LANDIS & GYR	MX	C455364	10-15-07	100.1	100.0	100.3
KUE	LANDIS & GYR	MX	C455365	10-15-07	100.1	100.1	100.3
KUE	LANDIS & GYR	MX	C455366	10-15-07	100.1	100.1	1
KUE	LANDIS & GYR	MX	C455367	10-15-07	100.0	100.1	100.0
KUE	LANDIS & GYR	MX	C455368	10-15-07	100.0	100.0	99.8
KUE	LANDIS & GYR	MX	C455369	10-15-07	100.0	100.1	99.9
KUE	LANDIS & GYR	MX	C455370	10-15-07	100.1	100.1	99.6
KUE	LANDIS & GYR	MX	C455371	10-15-07	100.1	99.9	99.9
KUE	LANDIS & GYR	MX	C455372	10-15-07	100.0	100.1	100.0
KUE	LANDIS & GYR	MX	C455373	10-15-07	100.0	100.0	100.0

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

PAGE 207
 RUN DATE: 1/15/08
 RUN TIME: 22.00.58

CO	MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
KUE	LANDIS & GYR	MX	C455425	10-15-07	100.1	100.1	99.9
KUE	LANDIS & GYR	MX	C455426	10-15-07	100.1	100.0	99.5
KUE	LANDIS & GYR	MX	C455427	10-15-07	100.1	100.0	100.5
KUE	LANDIS & GYR	MX	C455428	10-15-07	100.1	100.0	100.0
KUE	LANDIS & GYR	MX	C455429	10-15-07	100.0	100.0	100.2
KUE	LANDIS & GYR	MX	C455430	10-15-07	100.0	100.0	100.0
KUE	LANDIS & GYR	MX	C455431	10-15-07	100.0	100.1	100.2
KUE	LANDIS & GYR	MX	C455432	10-15-07	100.1	100.1	100.1
KUE	LANDIS & GYR	MX	C455433	10-15-07	100.1	100.0	100.2
KUE	LANDIS & GYR	MX	C455434	10-15-07	100.0	100.1	100.1
KUE	LANDIS & GYR	MX	C455435	10-15-07	100.1	100.1	100.1
KUE	LANDIS & GYR	MX	C455436	10-15-07	100.1	100.1	100.2
KUE	LANDIS & GYR	MX	C455437	10-15-07	100.1	100.0	100.2
KUE	LANDIS & GYR	MX	C455438	10-15-07	100.1	100.0	100.5
KUE	LANDIS & GYR	MX	C455439	10-15-07	100.0	100.1	99.7
KUE	LANDIS & GYR	MX	C455440	10-15-07	100.1	100.1	100.0
KUE	LANDIS & GYR	MX	C455441	10-15-07	100.1	100.1	99.6
KUE	LANDIS & GYR	MX	C455442	10-15-07	100.0	100.1	99.8
KUE	LANDIS & GYR	MX	C455443	10-15-07	100.0	99.9	99.9
KUE	LANDIS & GYR	MX	C455444	10-15-07	100.0	100.0	100.2
KUE	LANDIS & GYR	MX	C455445	10-15-07	100.0	100.1	100.2
KUE	LANDIS & GYR	MX	C455446	10-15-07	100.1	100.1	100.1
KUE	LANDIS & GYR	MX	C455447	10-15-07	100.1	100.0	100.2
KUE	LANDIS & GYR	MX	C455448	10-15-07	100.1	100.2	100.1
KUE	LANDIS & GYR	MX	C455449	10-15-07	100.0	100.0	100.0
KUE	LANDIS & GYR	MX	C455450	10-15-07	100.1	100.0	100.4
KUE	LANDIS & GYR	MX	C455451	10-15-07	100.1	100.2	100.0
KUE	LANDIS & GYR	MX	C455452	10-15-07	100.0	100.1	100.0
KUE	LANDIS & GYR	MX	C455453	10-15-07	100.0	100.0	99.9
KUE	LANDIS & GYR	MX	C455454	10-15-07	100.0	100.1	99.9
KUE	LANDIS & GYR	MX	C455455	10-15-07	100.1	100.2	99.9
KUE	LANDIS & GYR	MX	C455456	10-15-07	100.0	100.0	100.1
KUE	LANDIS & GYR	MX	C455457	10-15-07	100.1	100.1	99.9
KUE	LANDIS & GYR	MX	C455458	10-15-07	100.1	100.0	100.1
KUE	LANDIS & GYR	MX	C455459	10-15-07	100.1	100.0	100.1
KUE	LANDIS & GYR	MX	C455460	10-15-07	100.1	99.9	100.1
KUE	LANDIS & GYR	MX	C455461	10-15-07	100.0	100.0	99.7
KUE	LANDIS & GYR	MX	C455462	10-15-07	100.1	100.2	100.1
KUE	LANDIS & GYR	MX	C455463	10-15-07	100.1	100.1	100.0
KUE	LANDIS & GYR	MX	C455464	10-15-07	100.0	100.0	99.9
KUE	LANDIS & GYR	MX	C455465	10-15-07	100.1	100.1	100.2
KUE	LANDIS & GYR	MX	C455466	10-15-07	100.1	100.0	100.3
KUE	LANDIS & GYR	MX	C455467	10-15-07	100.1	100.1	100.0
KUE	LANDIS & GYR	MX	C455468	10-15-07	100.0	100.0	99.9
KUE	LANDIS & GYR	MX	C455469	10-15-07	100.0	100.0	99.9
KUE	LANDIS & GYR	MX	C455470	10-15-07	100.1	100.1	99.9
KUE	LANDIS & GYR	MX	C455471	10-15-07	100.1	100.1	100.2
KUE	LANDIS & GYR	MX	C455472	10-15-07	100.0	99.9	100.1
KUE	LANDIS & GYR	MX	C455473	10-15-07	100.1	100.1	100.0
KUE	LANDIS & GYR	MX	C455474	10-15-07	100.0	100.0	99.8
KUE	LANDIS & GYR	MX	C455475	10-15-07	100.0	100.0	99.8

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

PAGE 209
 RUN DATE: 1/15/08
 RUN TIME: 22.00.58

CO	MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
KUE	LANDIS & GYR	MX	C455527	10-15-07	100.1	100.1	99.5
KUE	LANDIS & GYR	MX	C455528	10-15-07	100.0	100.1	100.0
KUE	LANDIS & GYR	MX	C455529	10-15-07	100.0	100.1	99.6
KUE	LANDIS & GYR	MX	C455530	10-15-07	100.1	100.1	100.1
KUE	LANDIS & GYR	MX	C455531	10-15-07	100.1	100.1	100.2
KUE	LANDIS & GYR	MX	C455532	10-15-07	100.1	99.9	100.0
KUE	LANDIS & GYR	MX	C455533	10-15-07	100.0	99.9	100.1
KUE	LANDIS & GYR	MX	C455534	10-15-07	100.1	100.0	100.5
KUE	LANDIS & GYR	MX	C455535	10-15-07	100.0	100.0	100.0
KUE	LANDIS & GYR	MX	C455536	10-15-07	100.0	100.2	99.8
KUE	LANDIS & GYR	MX	C455537	10-15-07	100.0	100.0	99.8
KUE	LANDIS & GYR	MX	C455538	10-15-07	100.1	99.9	99.9
KUE	LANDIS & GYR	MX	C455539	10-15-07	100.1	100.1	100.3
KUE	LANDIS & GYR	MX	C455540	10-15-07	100.1	100.2	100.2
KUE	LANDIS & GYR	MX	C455541	10-15-07	100.0	99.9	99.9
KUE	LANDIS & GYR	MX	C455542	10-15-07	100.1	100.0	100.1
KUE	LANDIS & GYR	MX	C455543	10-15-07	100.0	99.9	100.1
KUE	LANDIS & GYR	MX	C455544	10-15-07	100.1	100.1	100.1
KUE	LANDIS & GYR	MX	C455545	10-15-07	100.0	100.0	99.7
KUE	LANDIS & GYR	MX	C455546	10-15-07	100.1	99.9	99.8
KUE	LANDIS & GYR	MX	C455547	10-15-07	100.1	100.1	100.1
KUE	LANDIS & GYR	MX	C455548	10-15-07	100.1	100.1	100.0
KUE	LANDIS & GYR	MX	C455549	10-15-07	100.1	100.1	100.2
KUE	LANDIS & GYR	MX	C455550	10-15-07	100.0	99.9	99.7
KUE	LANDIS & GYR	MX	C455551	10-15-07	100.1	99.9	100.2
KUE	LANDIS & GYR	MX	C455552	10-15-07	100.1	100.1	100.2
KUE	LANDIS & GYR	MX	C455553	10-15-07	100.1	100.2	100.1
KUE	LANDIS & GYR	MX	C455554	10-15-07	100.0	100.0	100.1
KUE	LANDIS & GYR	MX	C455555	10-15-07	100.1	100.1	100.1
KUE	LANDIS & GYR	MX	C455556	10-15-07	100.1	100.0	100.1
KUE	LANDIS & GYR	MX	C455557	10-15-07	100.1	100.0	100.2
KUE	LANDIS & GYR	MX	C455558	10-15-07	100.0	100.1	100.2
KUE	LANDIS & GYR	MX	C455559	10-15-07	100.0	100.0	99.9
KUE	LANDIS & GYR	MX	C455560	10-15-07	100.0	100.1	100.2
KUE	LANDIS & GYR	MX	C455561	10-15-07	100.1	100.1	99.9
KUE	LANDIS & GYR	MX	C455562	10-15-07	100.1	99.9	100.1
KUE	LANDIS & GYR	MX	C455563	10-15-07	100.0	99.9	100.2
KUE	LANDIS & GYR	MX	C455564	10-15-07	100.0	99.9	100.3
KUE	LANDIS & GYR	MX	C455565	10-15-07	100.0	99.9	99.9
KUE	LANDIS & GYR	MX	C455566	10-15-07	100.0	99.9	100.0
KUE	LANDIS & GYR	MX	C455567	10-15-07	100.1	100.0	100.0
KUE	LANDIS & GYR	MX	C455568	10-15-07	100.1	100.2	100.2
KUE	LANDIS & GYR	MX	C455569	10-15-07	100.0	100.1	100.2
KUE	LANDIS & GYR	MX	C455570	10-15-07	100.0	100.1	100.1
KUE	LANDIS & GYR	MX	C455571	10-15-07	100.1	100.0	100.5
KUE	LANDIS & GYR	MX	C455572	10-15-07	100.0	100.1	100.2
KUE	LANDIS & GYR	MX	C455573	10-15-07	100.0	100.2	100.1
KUE	LANDIS & GYR	MX	C455574	10-15-07	100.1	100.0	100.0
KUE	LANDIS & GYR	MX	C455575	10-15-07	100.0	100.1	100.1
KUE	LANDIS & GYR	MX	C455576	10-15-07	100.1	100.2	100.2
KUE	LANDIS & GYR	MX	C455577	10-15-07	100.1	100.0	99.8

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

CO	MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
KUE	LANDIS & GYR	MX	C455629	10-16-07	99.9	99.9	100.4
KUE	LANDIS & GYR	MX	C455630	10-16-07	100.1	100.1	100.3
KUE	LANDIS & GYR	MX	C455631	10-16-07	100.0	100.1	100.2
KUE	LANDIS & GYR	MX	C455632	10-16-07	100.1	100.1	100.3
KUE	LANDIS & GYR	MX	C455633	10-16-07	100.0	100.1	100.2
KUE	LANDIS & GYR	MX	C455634	10-16-07	100.1	100.1	100.2
KUE	LANDIS & GYR	MX	C455635	10-16-07	100.0	100.1	100.4
KUE	LANDIS & GYR	MX	C455636	10-16-07	100.0	100.1	99.8
KUE	LANDIS & GYR	MX	C455637	10-16-07	100.1	100.1	100.3
KUE	LANDIS & GYR	MX	C455638	10-16-07	100.0	100.0	99.9
KUE	LANDIS & GYR	MX	C455639	10-16-07	100.0	100.1	100.4
KUE	LANDIS & GYR	MX	C455640	10-16-07	100.1	100.1	100.3
KUE	LANDIS & GYR	MX	C455641	10-16-07	100.0	100.1	100.2
KUE	LANDIS & GYR	MX	C455642	10-16-07	100.1	100.1	100.3
KUE	LANDIS & GYR	MX	C455643	10-16-07	100.1	100.1	99.8
KUE	LANDIS & GYR	MX	C455644	10-16-07	100.1	100.1	100.0
KUE	LANDIS & GYR	MX	C455645	10-16-07	100.1	100.1	100.2
KUE	LANDIS & GYR	MX	C455646	10-16-07	99.9	100.1	100.3
KUE	LANDIS & GYR	MX	C455647	10-16-07	99.9	100.0	100.2
KUE	LANDIS & GYR	MX	C455648	10-16-07	100.1	100.1	100.4
KUE	LANDIS & GYR	MX	C455649	10-16-07	100.0	100.2	100.5
KUE	LANDIS & GYR	MX	C455650	10-16-07	100.0	99.9	99.8
KUE	LANDIS & GYR	MX	C455651	10-16-07	100.0	100.1	100.1
KUE	LANDIS & GYR	MX	C455652	10-16-07	100.0	100.1	100.2
KUE	LANDIS & GYR	MX	C455653	10-16-07	100.1	99.9	100.0
KUE	LANDIS & GYR	MX	C455654	10-16-07	100.1	100.1	100.6
KUE	LANDIS & GYR	MX	C455655	10-16-07	100.1	100.1	100.2
KUE	LANDIS & GYR	MX	C455656	10-16-07	100.0	100.1	100.1
KUE	LANDIS & GYR	MX	C455657	10-16-07	100.0	100.1	100.1
KUE	LANDIS & GYR	MX	C455658	10-16-07	100.0	100.1	100.2
KUE	LANDIS & GYR	MX	C455659	10-16-07	100.1	100.1	100.2
KUE	LANDIS & GYR	MX	C455660	10-16-07	100.1	100.1	100.1
KUE	LANDIS & GYR	MX	C455661	10-16-07	100.1	100.0	99.8
KUE	LANDIS & GYR	MX	C455662	10-16-07	100.0	100.1	100.0
KUE	LANDIS & GYR	MX	C455663	10-16-07	100.0	99.9	100.1
KUE	LANDIS & GYR	MX	C455664	10-16-07	100.1	100.1	100.1
KUE	LANDIS & GYR	MX	C455665	10-16-07	100.0	100.0	100.4
KUE	LANDIS & GYR	MX	C455666	10-16-07	100.0	99.9	99.9
KUE	LANDIS & GYR	MX	C455667	10-16-07	100.0	100.0	99.9
KUE	LANDIS & GYR	MX	C455668	10-16-07	100.1	100.0	99.9
KUE	LANDIS & GYR	MX	C455669	10-16-07	100.1	100.0	100.4
KUE	LANDIS & GYR	MX	C455670	10-16-07	100.0	100.0	100.2
KUE	LANDIS & GYR	MX	C455671	10-16-07	100.1	100.0	100.1
KUE	LANDIS & GYR	MX	C455672	10-16-07	100.1	99.9	100.3
KUE	LANDIS & GYR	MX	C455673	10-16-07	100.1	100.2	100.0
KUE	LANDIS & GYR	MX	C455674	10-16-07	100.1	99.9	100.1
KUE	LANDIS & GYR	MX	C455675	10-16-07	100.1	100.2	100.1
KUE	LANDIS & GYR	MX	C455676	10-16-07	100.1	100.0	100.2
KUE	LANDIS & GYR	MX	C455677	10-16-07	100.1	100.0	99.8
KUE	LANDIS & GYR	MX	C455678	10-16-07	100.1	99.9	99.9
KUE	LANDIS & GYR	MX	C455679	10-16-07	99.9	99.9	100.1

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

CO	MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
KUE	LANDIS & GYR	MX	C455731	10-16-07	100.0	100.1	100.2
KUE	LANDIS & GYR	MX	C455732	10-16-07	100.1	100.0	100.2
KUE	LANDIS & GYR	MX	C455733	10-16-07	100.0	100.2	99.8
KUE	LANDIS & GYR	MX	C455734	10-16-07	100.0	100.1	99.6
KUE	LANDIS & GYR	MX	C455735	10-15-07	100.0	100.1	99.6
KUE	LANDIS & GYR	MX	C455736	10-16-07	100.1	100.1	100.1
KUE	LANDIS & GYR	MX	C455737	10-15-07	100.1	100.1	100.2
KUE	LANDIS & GYR	MX	C455738	10-15-07	100.1	100.1	100.0
KUE	LANDIS & GYR	MX	C455739	10-15-07	100.0	99.9	100.0
KUE	LANDIS & GYR	MX	C455740	10-15-07	100.1	100.1	100.0
KUE	LANDIS & GYR	MX	C455741	10-15-07	100.0	100.0	99.8
KUE	LANDIS & GYR	MX	C455742	10-16-07	100.0	100.0	99.6
KUE	LANDIS & GYR	MX	C455743	10-15-07	100.1	100.1	100.2
KUE	LANDIS & GYR	MX	C455744	10-15-07	100.0	100.0	100.1
KUE	LANDIS & GYR	MX	C455745	10-16-07	100.0	100.0	99.9
KUE	LANDIS & GYR	MX	C455746	10-16-07	100.0	99.9	100.2
KUE	LANDIS & GYR	MX	C455747	10-16-07	100.1	100.1	100.5
KUE	LANDIS & GYR	MX	C455748	10-15-07	100.1	100.2	100.0
KUE	LANDIS & GYR	MX	C455749	10-15-07	100.1	100.0	100.0
KUE	LANDIS & GYR	MX	C455750	10-15-07	100.1	100.1	100.0
KUE	LANDIS & GYR	MX	C455751	10-15-07	100.0	100.1	100.2
KUE	LANDIS & GYR	MX	C455752	10-15-07	100.1	100.0	100.1
KUE	LANDIS & GYR	MX	C455753	10-15-07	100.1	100.0	99.9
KUE	LANDIS & GYR	MX	C455754	10-15-07	99.9	99.9	100.0
KUE	LANDIS & GYR	MX	C455755	10-15-07	100.1	100.0	99.8
KUE	LANDIS & GYR	MX	C455756	10-15-07	100.1	100.1	100.1
KUE	LANDIS & GYR	MX	C455757	10-15-07	100.0	100.1	99.7
KUE	LANDIS & GYR	MX	C455758	10-16-07	100.0	99.9	99.9
KUE	LANDIS & GYR	MX	C455759	10-16-07	100.1	100.1	100.2
KUE	LANDIS & GYR	MX	C455760	10-15-07	100.1	100.0	100.2
KUE	LANDIS & GYR	MX	C455761	10-15-07	100.0	100.0	99.9
KUE	LANDIS & GYR	MX	C455762	10-16-07	100.0	100.2	99.7
KUE	LANDIS & GYR	MX	C455763	10-15-07	100.1	100.1	100.1
KUE	LANDIS & GYR	MX	C455764	10-15-07	100.1	99.9	100.1
KUE	LANDIS & GYR	MX	C455765	10-16-07	100.1	100.1	100.1
KUE	LANDIS & GYR	MX	C455766	10-16-07	100.1	100.1	99.9
KUE	LANDIS & GYR	MX	C455767	10-15-07	100.0	100.0	99.9
KUE	LANDIS & GYR	MX	C455768	10-15-07	100.0	100.1	99.8
KUE	LANDIS & GYR	MX	C455769	10-15-07	100.1	100.2	100.2
KUE	LANDIS & GYR	MX	C455770	10-15-07	100.1	100.0	100.2
KUE	LANDIS & GYR	MX	C455771	10-16-07	100.0	100.0	100.2
KUE	LANDIS & GYR	MX	C455772	10-15-07	100.0	100.1	100.2
KUE	LANDIS & GYR	MX	C455773	10-15-07	100.1	100.0	99.8
KUE	LANDIS & GYR	MX	C455774	10-15-07	100.1	100.1	100.0
KUE	LANDIS & GYR	MX	C455775	10-15-07	100.0	99.9	100.0
KUE	LANDIS & GYR	MX	C455776	10-15-07	100.1	100.1	99.8
KUE	LANDIS & GYR	MX	C455777	10-15-07	100.1	100.1	100.0
KUE	LANDIS & GYR	MX	C455778	10-15-07	100.0	100.0	100.0
KUE	LANDIS & GYR	MX	C455779	10-15-07	100.1	100.1	100.3
KUE	LANDIS & GYR	MX	C455780	10-15-07	100.1	100.1	100.2
KUE	LANDIS & GYR	MX	C455781	10-15-07	100.1	100.0	99.9

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

CO	MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
KUE	LANDIS & GYR	MX	C455833	10-16-07	100.0	100.0	99.8
KUE	LANDIS & GYR	MX	C455834	10-16-07	100.1	100.1	100.4
KUE	LANDIS & GYR	MX	C455835	10-16-07	100.0	100.2	99.8
KUE	LANDIS & GYR	MX	C455836	10-16-07	100.0	100.0	99.4
KUE	LANDIS & GYR	MX	C455837	10-16-07	100.0	100.1	99.8
KUE	LANDIS & GYR	MX	C455838	10-16-07	100.0	100.0	100.2
KUE	LANDIS & GYR	MX	C455839	10-16-07	100.1	100.1	100.1
KUE	LANDIS & GYR	MX	C455840	10-16-07	100.1	100.0	100.6
KUE	LANDIS & GYR	MX	C455841	10-16-07	100.0	100.2	100.1
KUE	LANDIS & GYR	MX	C455842	10-16-07	100.1	99.9	100.2
KUE	LANDIS & GYR	MX	C455843	10-16-07	100.1	100.1	99.6
KUE	LANDIS & GYR	MX	C455844	10-16-07	100.0	99.9	99.9
KUE	LANDIS & GYR	MX	C455845	10-16-07	100.1	100.0	99.7
KUE	LANDIS & GYR	MX	C455846	10-16-07	100.1	99.9	99.8
KUE	LANDIS & GYR	MX	C455847	10-16-07	100.0	99.9	99.9
KUE	LANDIS & GYR	MX	C455848	10-16-07	100.0	99.9	99.9
KUE	LANDIS & GYR	MX	C455849	10-16-07	100.1	99.9	99.9
KUE	LANDIS & GYR	MX	C455850	10-16-07	99.9	100.0	99.6
KUE	LANDIS & GYR	MX	C455851	10-16-07	100.0	100.1	100.0
KUE	LANDIS & GYR	MX	C455852	10-16-07	100.0	100.0	99.9
KUE	LANDIS & GYR	MX	C455853	10-16-07	100.0	100.0	100.3
KUE	LANDIS & GYR	MX	C455854	10-16-07	100.1	100.0	99.8
KUE	LANDIS & GYR	MX	C455855	10-16-07	100.1	100.2	100.2
KUE	LANDIS & GYR	MX	C455856	10-16-07	100.1	100.1	100.1
KUE	LANDIS & GYR	MX	C455857	10-16-07	100.1	100.2	100.2
KUE	LANDIS & GYR	MX	C455858	10-16-07	100.1	100.1	100.1
KUE	LANDIS & GYR	MX	C455859	10-16-07	100.1	100.1	100.2
KUE	LANDIS & GYR	MX	C455860	10-16-07	100.1	100.1	100.3
KUE	LANDIS & GYR	MX	C455861	10-16-07	100.0	100.0	99.9
KUE	LANDIS & GYR	MX	C455862	10-16-07	100.1	100.1	99.9
KUE	LANDIS & GYR	MX	C455863	10-16-07	100.1	100.0	100.0
KUE	LANDIS & GYR	MX	C455864	10-16-07	100.0	99.9	100.0
KUE	LANDIS & GYR	MX	C455865	10-16-07	100.1	100.1	100.2
KUE	LANDIS & GYR	MX	C455866	10-16-07	100.1	99.9	100.0
KUE	LANDIS & GYR	MX	C455867	10-16-07	100.0	100.1	100.0
KUE	LANDIS & GYR	MX	C455868	10-16-07	100.0	100.1	99.9
KUE	LANDIS & GYR	MX	C455869	10-16-07	100.0	100.1	100.1
KUE	LANDIS & GYR	MX	C455870	10-16-07	100.1	100.2	100.3
KUE	LANDIS & GYR	MX	C455871	10-16-07	100.1	100.1	100.3
KUE	LANDIS & GYR	MX	C455872	10-16-07	100.0	100.1	100.3
KUE	LANDIS & GYR	MX	C455873	10-16-07	100.0	100.0	100.0
KUE	LANDIS & GYR	MX	C455874	10-16-07	100.1	100.1	100.1
KUE	LANDIS & GYR	MX	C455875	10-16-07	100.1	100.1	99.8
KUE	LANDIS & GYR	MX	C455876	10-16-07	100.1	100.2	100.3
KUE	LANDIS & GYR	MX	C455877	10-16-07	100.1	100.2	100.3
KUE	LANDIS & GYR	MX	C455878	10-16-07	100.0	100.0	99.9
KUE	LANDIS & GYR	MX	C455879	10-16-07	100.1	100.1	100.0
KUE	LANDIS & GYR	MX	C455880	10-16-07	100.1	100.0	100.0
KUE	LANDIS & GYR	MX	C455881	10-16-07	100.1	100.1	100.3
KUE	LANDIS & GYR	MX	C455882	10-16-07	100.1	100.0	99.9
KUE	LANDIS & GYR	MX	C455883	10-16-07	100.1	100.1	100.0

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

CO	MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
KUE	LANDIS & GYR	MX	C455935	10-16-07	100.1	100.1	100.1
KUE	LANDIS & GYR	MX	C455936	10-16-07	100.0	100.1	100.0
KUE	LANDIS & GYR	MX	C455937	10-16-07	100.0	99.9	100.3
KUE	LANDIS & GYR	MX	C455938	10-16-07	100.0	100.0	99.8
KUE	LANDIS & GYR	MX	C455939	10-16-07	100.0	99.9	99.9
KUE	LANDIS & GYR	MX	C455940	10-16-07	100.1	100.1	100.0
KUE	LANDIS & GYR	MX	C455941	10-16-07	100.1	100.2	100.1
KUE	LANDIS & GYR	MX	C455942	10-16-07	100.1	100.1	100.5
KUE	LANDIS & GYR	MX	C455943	10-16-07	100.1	100.1	100.0
KUE	LANDIS & GYR	MX	C455944	10-16-07	100.1	100.1	99.8
KUE	LANDIS & GYR	MX	C455945	10-16-07	100.1	100.1	100.3
KUE	LANDIS & GYR	MX	C455946	10-16-07	100.0	100.1	99.8

MFG TYPE TOTAL 9,600

COMPANY TOTAL 11,000

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

PAGE 2
 RUN DATE: 1/15/08
 RUN TIME: 22.00.58

CO	MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
ODP	D084386	I210	D084386	07-17-07	100.1	100.1	99.9
ODP	D084387	I210	D084387	07-17-07	100.0	100.0	100.0
ODP	D084388	I210	D084388	07-17-07	100.0	100.1	100.0
ODP	D084389	I210	D084389	07-17-07	100.0	100.0	100.0
ODP	D084390	I210	D084390	07-17-07	100.0	100.0	100.0
ODP	D084391	I210	D084391	07-17-07	100.0	100.1	100.0
ODP	D084392	I210	D084392	07-17-07	100.0	100.0	100.0
ODP	D084393	I210	D084393	07-17-07	100.1	100.1	100.0
ODP	D084394	I210	D084394	07-17-07	100.0	100.0	100.0
ODP	D084395	I210	D084395	07-17-07	100.0	100.0	100.0
ODP	D084396	I210	D084396	07-17-07	100.0	100.0	100.0
ODP	D084397	I210	D084397	07-17-07	100.0	100.1	100.0
ODP	D084398	I210	D084398	07-17-07	100.0	100.0	100.0
ODP	D084399	I210	D084399	07-17-07	100.0	100.0	100.1
ODP	D084400	I210	D084400	07-17-07	100.0	100.0	100.0
ODP	D084401	I210	D084401	07-17-07	100.0	100.0	100.0
ODP	D084402	I210	D084402	07-17-07	100.0	100.0	100.0
ODP	D084403	I210	D084403	07-17-07	100.1	100.1	99.9
ODP	D084404	I210	D084404	07-17-07	100.0	100.0	100.0
ODP	D084405	I210	D084405	07-17-07	100.0	100.0	100.0
ODP	D084406	I210	D084406	07-17-07	100.0	100.0	100.0
ODP	D084407	I210	D084407	07-17-07	100.0	100.0	100.1
ODP	D084408	I210	D084408	07-17-07	100.0	100.1	100.0
ODP	D084409	I210	D084409	07-17-07	99.9	99.9	100.0
ODP	D084410	I210	D084410	07-17-07	100.0	99.9	100.0
ODP	D084411	I210	D084411	07-17-07	100.0	100.0	100.0
ODP	D084412	I210	D084412	07-17-07	100.0	100.0	100.0
ODP	D084413	I210	D084413	07-17-07	100.0	100.0	100.0
ODP	D084414	I210	D084414	07-17-07	100.0	100.0	100.1
ODP	D084415	I210	D084415	07-17-07	100.0	99.9	100.1
ODP	D084416	I210	D084416	07-17-07	100.0	100.0	100.0
ODP	D084417	I210	D084417	07-17-07	100.0	100.0	100.1
ODP	D084418	I210	D084418	07-17-07	100.0	100.0	100.0
ODP	D084419	I210	D084419	07-17-07	100.0	100.0	100.0
ODP	D084420	I210	D084420	07-17-07	100.1	100.1	100.0
ODP	D084421	I210	D084421	07-17-07	100.0	100.0	100.1
ODP	D084422	I210	D084422	07-17-07	100.1	100.0	99.9
ODP	D084423	I210	D084423	07-17-07	100.1	100.1	100.0
ODP	D084424	I210	D084424	07-17-07	100.0	100.1	100.0
ODP	D084425	I210	D084425	07-17-07	100.1	100.1	100.1
ODP	D084426	I210	D084426	07-17-07	100.0	100.0	100.0
ODP	D084427	I210	D084427	07-17-07	100.0	100.0	99.9
ODP	D084428	I210	D084428	07-17-07	100.0	100.0	100.0
ODP	D084429	I210	D084429	07-17-07	100.0	100.0	100.1
ODP	D084430	I210	D084430	07-17-07	100.0	100.0	100.0

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

CO	MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
ODP	LANDIS & GYR	MX	D083794	01-26-07	100.0	100.0	100.4
ODP	LANDIS & GYR	MX	D083795	01-26-07	100.0	100.0	100.1
ODP	LANDIS & GYR	MX	D083796	01-26-07	100.0	100.1	100.4
ODP	LANDIS & GYR	MX	D083797	01-26-07	100.1	100.1	100.0
ODP	LANDIS & GYR	MX	D083798	01-26-07	100.0	100.0	99.9
ODP	LANDIS & GYR	MX	D083799	01-26-07	100.0	100.0	99.7
ODP	LANDIS & GYR	MX	D083800	01-26-07	100.0	99.9	100.3
ODP	LANDIS & GYR	MX	D083801	01-26-07	100.0	100.0	100.1
ODP	LANDIS & GYR	MX	D083802	01-26-07	100.0	100.1	100.0
ODP	LANDIS & GYR	MX	D083803	01-26-07	100.1	100.0	100.1
ODP	LANDIS & GYR	MX	D083804	01-26-07	100.0	99.9	99.7
ODP	LANDIS & GYR	MX	D083805	01-26-07	100.1	100.1	100.2
ODP	LANDIS & GYR	MX	D083806	01-26-07	100.0	100.1	99.9
ODP	LANDIS & GYR	MX	D083807	01-26-07	100.0	100.0	100.3
ODP	LANDIS & GYR	MX	D083808	01-26-07	100.0	100.1	99.9
ODP	LANDIS & GYR	MX	D083809	01-26-07	100.0	100.1	99.9
ODP	LANDIS & GYR	MX	D083810	01-26-07	100.1	100.0	100.3
ODP	LANDIS & GYR	MX	D083811	01-26-07	100.1	99.9	100.1
ODP	LANDIS & GYR	MX	D083812	01-26-07	100.1	100.2	100.4
ODP	LANDIS & GYR	MX	D083813	01-26-07	100.1	100.1	100.1
ODP	LANDIS & GYR	MX	D083814	01-26-07	100.1	100.0	100.0
ODP	LANDIS & GYR	MX	D083815	01-26-07	100.0	100.0	100.3
ODP	LANDIS & GYR	MX	D083816	01-26-07	100.0	100.1	100.2
ODP	LANDIS & GYR	MX	D083817	01-26-07	100.0	100.1	100.1
ODP	LANDIS & GYR	MX	D083818	01-26-07	100.0	100.0	100.3
ODP	LANDIS & GYR	MX	D083819	01-26-07	100.0	100.1	100.3
ODP	LANDIS & GYR	MX	D083820	01-26-07	100.0	100.1	100.0
ODP	LANDIS & GYR	MX	D083821	01-26-07	100.0	100.1	99.6
ODP	LANDIS & GYR	MX	D083822	01-26-07	100.0	100.1	100.2
ODP	LANDIS & GYR	MX	D083823	01-26-07	100.1	100.0	100.3
ODP	LANDIS & GYR	MX	D083824	01-26-07	100.1	100.1	100.1
ODP	LANDIS & GYR	MX	D083825	01-26-07	100.1	99.9	100.4
ODP	LANDIS & GYR	MX	D083826	01-26-07	100.0	99.9	100.4
ODP	LANDIS & GYR	MX	D083827	01-26-07	100.0	100.0	100.2
ODP	LANDIS & GYR	MX	D083828	01-26-07	100.0	100.2	100.2
ODP	LANDIS & GYR	MX	D083829	01-26-07	100.0	100.0	100.1
ODP	LANDIS & GYR	MX	D083830	01-26-07	100.1	100.2	100.5
ODP	LANDIS & GYR	MX	D083831	01-26-07	100.1	100.0	100.2
ODP	LANDIS & GYR	MX	D083832	01-26-07	100.1	100.0	100.2
ODP	LANDIS & GYR	MX	D083833	01-26-07	100.0	99.9	100.0
ODP	LANDIS & GYR	MX	D083834	01-26-07	100.0	100.0	100.3
ODP	LANDIS & GYR	MX	D083835	01-26-07	100.1	100.1	100.2
ODP	LANDIS & GYR	MX	D083836	01-26-07	100.1	100.2	99.9
ODP	LANDIS & GYR	MX	D083837	01-26-07	100.0	100.0	99.9
ODP	LANDIS & GYR	MX	D083838	01-26-07	100.1	100.0	100.0
ODP	LANDIS & GYR	MX	D083839	01-26-07	100.1	99.9	99.9
ODP	LANDIS & GYR	MX	D083840	01-26-07	100.0	99.9	100.1
ODP	LANDIS & GYR	MX	D083841	01-26-07	100.1	100.0	100.2
ODP	LANDIS & GYR	MX	D083842	01-26-07	100.1	100.1	99.8
ODP	LANDIS & GYR	MX	D083843	01-26-07	100.1	100.0	100.5
ODP	LANDIS & GYR	MX	D083844	01-26-07	100.0	100.0	99.9

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

CO	MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
ODP	LANDIS & GYR	MX	D083896	01-26-07	100.1	100.0	99.9
ODP	LANDIS & GYR	MX	D083897	01-26-07	100.0	100.0	100.3
ODP	LANDIS & GYR	MX	D083898	01-26-07	100.0	100.0	100.1
ODP	LANDIS & GYR	MX	D083899	01-26-07	99.9	100.2	100.3
ODP	LANDIS & GYR	MX	D083900	01-26-07	100.0	100.1	100.2
ODP	LANDIS & GYR	MX	D083901	01-26-07	100.1	100.0	100.4
ODP	LANDIS & GYR	MX	D083902	01-26-07	100.0	100.0	100.1
ODP	LANDIS & GYR	MX	D083903	01-26-07	100.1	100.1	100.4
ODP	LANDIS & GYR	MX	D083904	01-26-07	100.1	100.1	100.1
ODP	LANDIS & GYR	MX	D083905	01-26-07	100.1	100.1	100.1
ODP	LANDIS & GYR	MX	D083906	01-26-07	100.0	99.9	100.0
ODP	LANDIS & GYR	MX	D083907	01-26-07	100.0	100.1	100.0
ODP	LANDIS & GYR	MX	D083908	01-26-07	100.1	100.1	100.2
ODP	LANDIS & GYR	MX	D083909	01-26-07	100.0	99.9	100.2
ODP	LANDIS & GYR	MX	D083910	01-26-07	100.0	99.9	100.3
ODP	LANDIS & GYR	MX	D083911	01-26-07	100.1	100.2	100.0
ODP	LANDIS & GYR	MX	D083912	01-26-07	100.0	100.0	100.0
ODP	LANDIS & GYR	MX	D083913	01-26-07	100.0	100.0	100.0
ODP	LANDIS & GYR	MX	D083914	01-26-07	100.1	100.2	100.3
ODP	LANDIS & GYR	MX	D083915	01-26-07	100.1	100.1	99.9
ODP	LANDIS & GYR	MX	D083916	01-26-07	100.0	100.0	100.0
ODP	LANDIS & GYR	MX	D083917	01-26-07	100.1	100.1	100.1
ODP	LANDIS & GYR	MX	D083918	01-26-07	100.0	100.1	100.2
ODP	LANDIS & GYR	MX	D083919	01-26-07	100.0	100.2	100.1
ODP	LANDIS & GYR	MX	D083920	01-26-07	100.1	100.1	100.1
ODP	LANDIS & GYR	MX	D083921	01-26-07	100.1	100.0	100.1
ODP	LANDIS & GYR	MX	D083922	01-26-07	100.1	99.9	100.4
ODP	LANDIS & GYR	MX	D083923	01-26-07	99.9	100.1	99.9
ODP	LANDIS & GYR	MX	D083924	01-26-07	100.0	100.1	100.0
ODP	LANDIS & GYR	MX	D083925	01-26-07	100.0	99.9	100.0
ODP	LANDIS & GYR	MX	D083926	01-26-07	100.1	99.9	100.2
ODP	LANDIS & GYR	MX	D083927	01-26-07	100.1	100.2	100.0
ODP	LANDIS & GYR	MX	D083928	01-26-07	100.1	99.9	100.0
ODP	LANDIS & GYR	MX	D083929	01-26-07	100.1	100.0	100.3
ODP	LANDIS & GYR	MX	D083930	01-26-07	100.1	100.1	100.0
ODP	LANDIS & GYR	MX	D083931	01-26-07	100.1	100.1	100.2
ODP	LANDIS & GYR	MX	D083932	01-26-07	100.1	100.1	100.4
ODP	LANDIS & GYR	MX	D083933	01-26-07	100.0	100.1	100.1
ODP	LANDIS & GYR	MX	D083934	01-26-07	100.0	99.9	100.1
ODP	LANDIS & GYR	MX	D083935	01-26-07	100.0	99.9	99.7
ODP	LANDIS & GYR	MX	D083936	01-26-07	100.0	100.0	100.0
ODP	LANDIS & GYR	MX	D083937	01-26-07	100.0	100.2	100.0
ODP	LANDIS & GYR	MX	D083938	01-26-07	100.0	100.1	100.0
ODP	LANDIS & GYR	MX	D083939	01-26-07	100.0	99.9	100.3
ODP	LANDIS & GYR	MX	D083940	01-26-07	100.1	100.0	100.0
ODP	LANDIS & GYR	MX	D083941	01-26-07	100.0	100.1	100.0
ODP	LANDIS & GYR	MX	D083942	01-26-07	100.0	100.0	99.9
ODP	LANDIS & GYR	MX	D083943	01-26-07	100.1	100.0	100.0
ODP	LANDIS & GYR	MX	D083944	01-26-07	100.1	100.0	100.0
ODP	LANDIS & GYR	MX	D083945	01-26-07	100.1	99.9	100.0
ODP	LANDIS & GYR	MX	D083946	01-26-07	100.0	100.0	99.7

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

CO	MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
ODP	LANDIS & GYR	MX	D083998	01-26-07	100.0	100.1	100.2
ODP	LANDIS & GYR	MX	D083999	01-26-07	100.1	99.9	100.1
ODP	LANDIS & GYR	MX	D084000	01-26-07	100.1	99.9	100.3
ODP	LANDIS & GYR	MX	D084001	01-26-07	100.1	99.9	100.2
ODP	LANDIS & GYR	MX	D084002	01-26-07	100.0	100.0	100.4
ODP	LANDIS & GYR	MX	D084003	01-26-07	100.0	100.2	100.1
ODP	LANDIS & GYR	MX	D084004	01-26-07	100.1	100.1	100.2
ODP	LANDIS & GYR	MX	D084005	01-26-07	100.0	100.0	100.2
ODP	LANDIS & GYR	MX	D084006	01-26-07	100.1	100.1	100.1
ODP	LANDIS & GYR	MX	D084007	01-26-07	100.0	100.0	100.1
ODP	LANDIS & GYR	MX	D084008	01-26-07	100.0	99.9	100.1
ODP	LANDIS & GYR	MX	D084009	01-26-07	100.0	100.2	99.8
ODP	LANDIS & GYR	MX	D084010	01-26-07	100.0	100.1	100.1
ODP	LANDIS & GYR	MX	D084011	01-26-07	100.0	100.2	99.5
ODP	LANDIS & GYR	MX	D084012	01-26-07	100.0	100.1	99.9
ODP	LANDIS & GYR	MX	D084013	01-26-07	100.0	100.1	99.9
ODP	LANDIS & GYR	MX	D084014	01-26-07	100.1	100.1	99.4
ODP	LANDIS & GYR	MX	D084015	01-26-07	100.0	100.0	99.8
ODP	LANDIS & GYR	MX	D084016	01-26-07	100.0	100.0	100.1
ODP	LANDIS & GYR	MX	D084017	01-26-07	100.0	99.9	100.2
ODP	LANDIS & GYR	MX	D084018	01-26-07	100.1	100.1	99.9
ODP	LANDIS & GYR	MX	D084019	01-26-07	100.0	99.9	100.0
ODP	LANDIS & GYR	MX	D084020	01-26-07	100.0	100.0	100.0
ODP	LANDIS & GYR	MX	D084021	01-26-07	100.1	100.1	100.0
ODP	LANDIS & GYR	MX	D084022	01-26-07	100.1	100.0	100.3
ODP	LANDIS & GYR	MX	D084023	01-26-07	100.1	100.0	100.3
ODP	LANDIS & GYR	MX	D084024	01-26-07	100.0	99.9	100.1
ODP	LANDIS & GYR	MX	D084025	01-26-07	100.0	99.9	99.8
ODP	LANDIS & GYR	MX	D084026	01-26-07	100.0	100.0	100.2
ODP	LANDIS & GYR	MX	D084027	01-26-07	100.1	100.0	100.1
ODP	LANDIS & GYR	MX	D084028	01-26-07	100.0	100.0	100.0
ODP	LANDIS & GYR	MX	D084029	01-26-07	100.1	100.0	99.9
ODP	LANDIS & GYR	MX	D084030	01-26-07	100.0	100.1	100.2
ODP	LANDIS & GYR	MX	D084031	01-26-07	100.1	100.0	100.2
ODP	LANDIS & GYR	MX	D084032	01-26-07	100.1	100.1	100.3
ODP	LANDIS & GYR	MX	D084033	01-26-07	100.1	100.1	99.9
ODP	LANDIS & GYR	MX	D084034	01-26-07	100.0	100.0	100.3
ODP	LANDIS & GYR	MX	D084035	01-26-07	100.1	100.1	100.2
ODP	LANDIS & GYR	MX	D084036	01-26-07	100.1	100.1	99.9
ODP	LANDIS & GYR	MX	D084037	01-26-07	100.1	100.0	99.9
ODP	LANDIS & GYR	MX	D084038	01-26-07	99.9	100.0	100.1
ODP	LANDIS & GYR	MX	D084039	01-26-07	100.0	100.0	100.2
ODP	LANDIS & GYR	MX	D084040	01-26-07	100.0	99.9	99.9
ODP	LANDIS & GYR	MX	D084041	01-26-07	100.1	100.1	100.1
ODP	LANDIS & GYR	MX	D084042	01-26-07	100.1	100.0	100.1
ODP	LANDIS & GYR	MX	D084043	01-26-07	100.1	100.2	100.3
ODP	LANDIS & GYR	MX	D084044	01-26-07	100.1	100.0	100.2
ODP	LANDIS & GYR	MX	D084045	01-26-07	100.1	100.2	100.3
ODP	LANDIS & GYR	MX	D084046	01-26-07	100.0	100.1	100.1
ODP	LANDIS & GYR	MX	D084047	01-26-07	100.0	100.0	100.0
ODP	LANDIS & GYR	MX	D084048	01-26-07	100.1	99.9	99.8

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

CO	MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
ODP	LANDIS & GYR	MX	D0841100	01-26-07	100.1	100.0	100.2
ODP	LANDIS & GYR	MX	D0841101	01-26-07	100.1	100.2	100.0
ODP	LANDIS & GYR	MX	D0841102	01-26-07	100.0	100.0	100.0
ODP	LANDIS & GYR	MX	D0841103	01-26-07	100.1	100.0	100.0
ODP	LANDIS & GYR	MX	D0841104	01-26-07	100.1	100.1	100.1
ODP	LANDIS & GYR	MX	D0841105	01-26-07	100.1	100.0	100.2
ODP	LANDIS & GYR	MX	D0841106	01-26-07	100.1	100.0	99.8
ODP	LANDIS & GYR	MX	D0841107	01-26-07	100.0	100.1	100.0
ODP	LANDIS & GYR	MX	D0841108	01-26-07	100.0	100.1	100.0
ODP	LANDIS & GYR	MX	D0841109	01-26-07	100.1	99.9	99.8
ODP	LANDIS & GYR	MX	D0841110	01-26-07	100.0	99.9	100.1
ODP	LANDIS & GYR	MX	D0841111	01-26-07	100.1	100.0	100.3
ODP	LANDIS & GYR	MX	D0841112	01-26-07	100.0	100.1	100.6
ODP	LANDIS & GYR	MX	D0841113	01-26-07	100.0	100.0	100.2
ODP	LANDIS & GYR	MX	D0841114	01-26-07	100.0	99.9	100.1
ODP	LANDIS & GYR	MX	D0841115	01-26-07	100.1	100.1	100.1
ODP	LANDIS & GYR	MX	D0841116	01-26-07	100.1	100.1	100.1
ODP	LANDIS & GYR	MX	D0841117	01-26-07	100.1	100.0	99.9
ODP	LANDIS & GYR	MX	D0841118	01-26-07	100.1	100.1	100.1
ODP	LANDIS & GYR	MX	D0841119	01-26-07	100.1	100.1	100.15
ODP	LANDIS & GYR	MX	D0841120	01-26-07	100.0	100.1	100.1
ODP	LANDIS & GYR	MX	D0841121	01-26-07	100.1	100.1	100.2
ODP	LANDIS & GYR	MX	D0841122	01-26-07	100.0	99.9	100.1
ODP	LANDIS & GYR	MX	D0841123	01-26-07	100.0	100.0	100.6
ODP	LANDIS & GYR	MX	D0841124	01-26-07	100.0	100.1	100.9
ODP	LANDIS & GYR	MX	D0841125	01-26-07	100.0	100.0	100.2
ODP	LANDIS & GYR	MX	D0841126	01-26-07	100.0	100.0	100.2
ODP	LANDIS & GYR	MX	D0841127	01-26-07	100.0	99.9	100.1
ODP	LANDIS & GYR	MX	D0841128	01-26-07	100.0	100.0	100.0
ODP	LANDIS & GYR	MX	D0841129	01-26-07	100.0	100.0	100.0
ODP	LANDIS & GYR	MX	D0841130	01-26-07	100.1	99.9	100.1
ODP	LANDIS & GYR	MX	D0841131	01-26-07	100.0	99.9	100.1
ODP	LANDIS & GYR	MX	D0841132	01-26-07	100.0	100.0	100.1
ODP	LANDIS & GYR	MX	D0841133	01-26-07	100.1	100.0	100.1
ODP	LANDIS & GYR	MX	D0841134	01-26-07	100.1	99.9	100.0
ODP	LANDIS & GYR	MX	D0841135	01-26-07	100.0	100.0	99.8
ODP	LANDIS & GYR	MX	D0841136	01-26-07	100.1	100.1	99.9
ODP	LANDIS & GYR	MX	D0841137	01-26-07	100.1	100.1	100.5
ODP	LANDIS & GYR	MX	D0841138	01-26-07	100.1	100.1	100.0
ODP	LANDIS & GYR	MX	D0841139	01-26-07	100.0	100.0	100.0
ODP	LANDIS & GYR	MX	D0841140	01-26-07	100.0	100.0	100.1
ODP	LANDIS & GYR	MX	D0841141	01-26-07	100.1	100.1	100.1
ODP	LANDIS & GYR	MX	D0841142	01-26-07	100.1	100.0	99.8
ODP	LANDIS & GYR	MX	D0841143	01-26-07	100.0	99.9	100.1
ODP	LANDIS & GYR	MX	D0841144	01-26-07	100.1	100.0	100.3
ODP	LANDIS & GYR	MX	D0841145	01-26-07	100.1	100.0	100.0
ODP	LANDIS & GYR	MX	D0841146	01-26-07	100.0	100.0	100.2
ODP	LANDIS & GYR	MX	D0841147	01-26-07	100.0	100.0	99.9
ODP	LANDIS & GYR	MX	D0841148	01-26-07	100.0	99.9	100.0
ODP	LANDIS & GYR	MX	D0841149	01-26-07	100.1	100.1	99.9
ODP	LANDIS & GYR	MX	D0841150	01-26-07	100.1	100.1	99.9

KENTUCKY UTILITIES / OLD DOMINION POWER COMPANY
 MANUFACTURER TESTS ADDED LAST YEAR
 REPORT NO. MD8880

CO	MANUFACTURER	TYPE	METER NUMBER	TEST DATE	FULL LOAD	LIGHT LOAD	PFACTOR
ODP	LANDIS & GYR	MX	D084202	01-26-07	100.0	99.9	99.9
ODP	LANDIS & GYR	MX	D084203	01-26-07	100.0	100.0	100.2
ODP	LANDIS & GYR	MX	D084204	01-26-07	100.0	100.0	100.4
ODP	LANDIS & GYR	MX	D084205	01-26-07	100.0	100.1	100.0
ODP	LANDIS & GYR	MX	D084206	01-26-07	100.1	99.9	100.0
ODP	LANDIS & GYR	MX	D084207	01-26-07	100.0	99.9	99.9
ODP	LANDIS & GYR	MX	D084208	01-26-07	100.1	100.2	99.9
ODP	LANDIS & GYR	MX	D084209	01-26-07	100.1	100.0	100.0
ODP	LANDIS & GYR	MX	D084210	01-26-07	100.0	100.0	100.2
ODP	LANDIS & GYR	MX	D084211	01-26-07	100.0	100.0	100.0
ODP	LANDIS & GYR	MX	D084212	01-26-07	100.1	99.9	100.2
ODP	LANDIS & GYR	MX	D084213	01-26-07	100.0	100.0	99.8
ODP	LANDIS & GYR	MX	D084214	01-26-07	100.1	99.9	99.9
ODP	LANDIS & GYR	MX	D084215	01-26-07	100.0	100.0	99.9
ODP	LANDIS & GYR	MX	D084216	01-26-07	100.1	100.1	100.2
ODP	LANDIS & GYR	MX	D084217	01-26-07	100.0	99.9	100.7
ODP	LANDIS & GYR	MX	D084218	01-26-07	100.0	99.9	100.2
ODP	LANDIS & GYR	MX	D084219	01-26-07	100.1	100.0	100.1
ODP	LANDIS & GYR	MX	D084220	01-26-07	100.0	99.9	100.5
ODP	LANDIS & GYR	MX	D084221	01-26-07	100.1	100.2	100.0
ODP	LANDIS & GYR	MX	D084222	01-26-07	100.1	99.9	100.2

MFG TYPE TOTAL 480

COMPANY TOTAL 576

GRAND TOTAL 11,576

**ATTACHMENT
B**

Sampling Test Results

KU
2007 SAMPLE
ELECTRIC METER SUMMARY

SAMPLE

In-Service Population	474,150	Divided into 60 Lots
Sample Quantity	4,129	
Meters Tested	4,129	
Meters Not Tested	0	
Failed Lots	1	D-1
Failed Lot Meters	371	

KENTUCKY UTILITIES COMPANY

2007 SAMPLE TEST PROGRAM (JANUARY 1, 2007 TO DECEMBER 31, 2007)
METERS TESTED 75
METERS PASS/Fail 75
POPULATION 10,000
METER-TYPE AB AB1
GROUP--NAME AB1 001 AB AB1

TEST RESULTS PER ANSI/ASQC Z1.9-1993

DOUBLE SPECIFICATION LIMIT - VARIABILITY UNKNOWN - STANDARD DEVIATION METHOD
ONE AQL VALUE FOR BOTH UPPER AND LOWER SPECIFICATION LIMIT COMBINED
AQL = 2.5% - INSPECTION LEVEL II "L" - NORMAL INSPECTION

***** DEVICE NUMBER AND FULL LOAD TEST ACCURACY DATA *****

Table with 3 columns: Device ID (e.g., C331729, W148781), Value (e.g., 100.0, 100.1), and Status (e.g., PASS, FAIL).

INFORMATION NEEDED

VALUE OBTAINED

- 1 SAMPLE SIZE: N
2 SUM OF MEASUREMENTS
3 SUM OF SQUARED MEASUREMENTS
4 CORRECTION FACTOR (CF): SUM OF X SQUARED / N
5 CORRECTED SUM OF SQUARES (SS):
6 VARIANCE (V): SS/(N-1)
7 ESTIMATE OF LOT STANDARD DEVIATION S: SR OF V
8 SAMPLE MEAN X BAR: SUM X/N
9 UPPER SPECIFICATION LIMIT: U
10 LOWER SPECIFICATION LIMIT: L
11 QUALITY INDEX: QU=(U-XBAR)/S
12 QUALITY INDEX: QL=(XBAR-L)/S
13 ESTIMATE OF LOT PERCENT NCF. ABOVE U: PU
14 ESTIMATE OF LOT PERCENT NCF. BELOW L: PL
15 TOTAL ESTIMATE PERCENT NCF. IN LOT: P=PU+PL
16 MAXIMUM ALLOWABLE PERCENT NCF: M
17 ACCEPTABILITY CRITERION: COMPARE P=PU+PL WITH M
18 PASS: THE LOT MEETS THE ACCEPTABILITY CRITERION, IF P=PU+PL IS EQUAL TO OR LESS THAN M
19 FAIL: THE LOT FAILS THE ACCEPTABILITY CRITERION, IF P=PU+PL IS GREATER THAN M.

KENTUCKY UTILITIES COMPANY
 2007 SAMPLE TEST PROGRAM (JANUARY 1, 2007 TO DECEMBER 31, 2007)
 IN-SERVICE SAMPLE METERS PASS/
 POPULATION QUANTITY TESTED FAIL
 D4 001 METER-TYPE WE D4 10,000 QUANTITY TESTED 75 75
 PASS

TEST RESULTS PER ANSI/ASQC Z1.9-1993
 DOUBLE SPECIFICATION LIMIT - VARIABILITY UNKNOWN - STANDARD DEVIATION METHOD
 ONE AQL VALUE FOR BOTH UPPER AND LOWER SPECIFICATION LIMIT COMBINED
 AQL = 2.5% - INSPECTION LEVEL II "L" - NORMAL INSPECTION

DEVIANCE	TEST ACCURACY DATA	TEST ACCURACY DATA	TEST ACCURACY DATA	TEST ACCURACY DATA	TEST ACCURACY DATA
100.0	C223779	100.3	C225317	99.5	C226423
100.0	C226480	100.3	C227663	99.9	C227959
100.0	C228470	99.6	C229702	99.8	C229865
100.1	C230072	100.1	C230558	100.1	C230643
100.2	C232396	100.3	C233995	100.4	C236053
100.1	C236315	100.1	C236725	99.9	C236744
100.1	C236921	100.1	L140822	100.2	L140885
99.8	M345570	100.1	M345677	100.6	M345980
100.1	M350597	100.2	M351900	100.4	M352660
100.3	M353865	100.0	M354005	100.1	M354642
100.1	M367301	100.1	M367434	99.6	M375641
99.8	M375788	100.2	M375822	100.0	M375641
99.9	W102588	99.9	W102604	100.4	W102673
99.7	W102849	99.9	W104569	100.0	W104885
99.9	W105137	100.3	W106248	100.0	W108310

VALUE OBTAINED

75	7,502.5
750,505.03	750,505.08
04.95	0.0669
0.2586	100.03
102.00	102.00
7.62	98.00
7.85	7.62
0.00	7.85
0.00	0.00
0.00	0.00
04.83	0.00
PASS	04.83

PASS
 P=PU+PL WITH M
 ABOVE U:PU
 BELOW L:PL
 IN LOT: P=PU+PL
 COMPARE P=PU+PL WITH M
 THE LOT MEETS THE ACCEPTABILITY CRITERION, IF P=PU+PL IS EQUAL TO OR LESS THAN M
 THE LOT FAILS THE ACCEPTABILITY CRITERION, IF P=PU+PL IS GREATER THAN M.

- 1 SAMPLE SIZE: N
- 2 SUM OF MEASUREMENTS
- 3 SUM OF SQUARED MEASUREMENTS
- 4 CORRECTION FACTOR (CF): SUM OF X SQUARED / N
- 5 CORRECTED SUM OF SQUARES (SS):
- 6 VARIANCE (V): SS/(N-1)
- 7 ESTIMATE OF LOT STANDARD DEVIATION S: SR OF V
- 8 SAMPLE MEAN X BAR: SUM X/N
- 9 UPPER SPECIFICATION LIMIT: U
- 10 LOWER SPECIFICATION LIMIT: L
- 11 QUALITY INDEX: QU=(U-XBAR)/S
- 12 QUALITY INDEX: QL=(XBAR-L)/S
- 13 ESTIMATE OF LOT PERCENT NCF: ABOVE U:PU
- 14 ESTIMATE OF LOT PERCENT NCF: BELOW L:PL
- 15 TOTAL ESTIMATE PERCENT NCF: IN LOT: P=PU+PL
- 16 MAXIMUM ALLOWABLE PERCENT NCF: M
- 17 ACCEPTABILITY CRITERION: COMPARE P=PU+PL WITH M
- 18 PASS: THE LOT MEETS THE ACCEPTABILITY CRITERION, IF P=PU+PL IS EQUAL TO OR LESS THAN M
- 19 FAIL: THE LOT FAILS THE ACCEPTABILITY CRITERION, IF P=PU+PL IS GREATER THAN M.

KENTUCKY UTILITIES COMPANY
 2007 SAMPLE TEST PROGRAM (JANUARY 1, 2007 TO DECEMBER 31, 2007)
 IN-SERVICE SAMPLE METERS PASS/
 POPULATION QUANTITY TESTED FAIL
 D4 003 WE D4 9,558 75 75 PASS

TEST RESULTS PER ANSI/ASQC Z1.9-1993
 DOUBLE SPECIFICATION LIMIT - VARIABILITY UNKNOWN - STANDARD DEVIATION METHOD
 ONE AQL VALUE FOR BOTH UPPER AND LOWER SPECIFICATION LIMIT COMBINED
 AQL = 2.5% - INSPECTION LEVEL II "L" - NORMAL INSPECTION

*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****
99.7	100.1	100.0	100.0	100.0	100.4	100.1	100.0	100.1	100.1	100.4	100.7	100.2
*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****
C250194	C250271	C255151	C257735	L216544	L219144	L221892	L223942	L224814	L228217	M394758	M395897	M398470
C255039	C255151	C257735	L216544	L219144	L221892	L223942	L224814	L228217	M394758	M395897	M398470	M401267
C256937	C257735	L216544	L219144	L221892	L223942	L224814	L228217	M394758	M395897	M398470	M401267	M401528
L216488	L219144	L221892	L223942	L224814	L228217	M394758	M395897	M398470	M401267	M401528	W119770	W120174
L219053	L221892	L223942	L224814	L228217	M394758	M395897	M398470	M401267	M401528	W119770	W120174	W120652
L221840	L223942	L224814	L228217	M394758	M395897	M398470	M401267	M401528	W119770	W120174	W120652	W120652
L223894	L224814	L228217	M394758	M395897	M398470	M401267	M401528	W119770	W120174	W120652	W120652	W120652
L224804	L228217	M394758	M395897	M398470	M401267	M401528	W119770	W120174	W120652	W120652	W120652	W120652
L227961	M394758	M395897	M398470	M401267	M401528	W119770	W120174	W120652	W120652	W120652	W120652	W120652
L228887	M395897	M398470	M401267	M401528	W119770	W120174	W120652	W120652	W120652	W120652	W120652	W120652
M395721	M398419	M399320	M401528	W119770	W120174	W120652	W120652	W120652	W120652	W120652	W120652	W120652
M398419	M399320	M401528	W119770	W120174	W120652	W120652	W120652	W120652	W120652	W120652	W120652	W120652
M401528	W119770	W120174	W120652	W120652	W120652	W120652	W120652	W120652	W120652	W120652	W120652	W120652
W119770	W120174	W120652	W120652	W120652	W120652	W120652	W120652	W120652	W120652	W120652	W120652	W120652

VALUE OBTAINED

1 SAMPLE SIZE: N	75
2 SUM OF MEASUREMENTS	7,505.5
3 SUM OF SQUARED MEASUREMENTS	751,105.27
4 CORRECTION FACTOR (CF): SUM OF X SQUARED / N	751,104.87
5 CORRECTED SUM OF SQUARES (SS):	0.0658
6 VARIANCE (V): SS/(N-1)	0.2565
7 ESTIMATE OF LOT STANDARD DEVIATION S: SR OF V	100.07
8 SAMPLE MEAN X BAR: SUM X/N	102.00
9 UPPER SPECIFICATION LIMIT: U	98.00
10 LOWER SPECIFICATION LIMIT: L	7.52
11 QUALITY INDEX: QU=(U-XBAR)/S	8.07
12 QUALITY INDEX: QL=(XBAR-L)/S	0.00
13 ESTIMATE OF LOT PERCENT NCF: ABOVE U:PU	0.00
14 ESTIMATE OF LOT PERCENT NCF: BELOW L:PL	0.00
15 TOTAL ESTIMATE PERCENT NCF: IN LOT: P=PU+PL	0.00
16 MAXIMUM ALLOWABLE PERCENT NCF: M	04.83
17 ACCEPTABILITY CRITERION: COMPARE P=PU+PL WITH M	PASS
18 PASS: THE LOT MEETS THE ACCEPTABILITY CRITERION, IF P=PU+PL IS EQUAL TO OR LESS THAN M	
19 FAIL: THE LOT FAILS THE ACCEPTABILITY CRITERION, IF P=PU+PL IS GREATER THAN M.	

KENTUCKY UTILITIES COMPANY

2007 SAMPLE TEST PROGRAM (JANUARY 1, 2007 TO DECEMBER 31, 2007)

IN-SERVICE SAMPLE METERS TESTED PASS/FAIL

RUN DATE 1/02/08
RUN TIME 14.37.04

TEST RESULTS PER ANSI/ASQC Z1.9-1993
DOUBLE SPECIFICATION LIMIT - VARIABILITY UNKNOWN - STANDARD DEVIATION METHOD
ONE AQL VALUE FOR BOTH UPPER AND LOWER SPECIFICATION LIMIT COMBINED
AQL = 2.5% - - INSPECTION LEVEL II "K" - NORMAL INSPECTION

GROUP--NAME	METER-TYPE	POPULATION	QUANTITY	SAMPLE METERS	TESTED	PASS	FAIL
C432005	100.0	C432051	100.0	C432105	100.0	100.0	100.1
C432272	100.1	C432276	100.0	C432310	100.0	100.0	100.0
C432371	99.9	C432375	100.0	C432378	100.0	100.0	100.0
C432414	99.9	C432524	100.0	C432546	99.9	100.0	100.0
C432567	100.0	C432573	100.0	C432575	100.0	100.0	100.0
C432760	100.0	C432762	99.9	C432775	100.0	100.0	100.0
C432880	100.0	C432888	100.1	C432925	100.0	100.0	100.0
C433050	99.9	C433078	99.9	C433119	100.0	100.0	100.0
C433172	100.0	C433197	100.0	C433261	101.5	100.2	100.0
C433378	100.0	C445646	100.0	C445994	100.0	100.0	100.0
C432005	100.0	C432051	100.0	C432105	100.0	100.0	100.1
C432272	100.1	C432276	100.0	C432310	100.0	100.0	100.0
C432371	99.9	C432375	100.0	C432378	100.0	100.0	100.0
C432414	99.9	C432524	100.0	C432546	99.9	100.0	100.0
C432567	100.0	C432573	100.0	C432575	100.0	100.0	100.0
C432760	100.0	C432762	99.9	C432775	100.0	100.0	100.0
C432880	100.0	C432888	100.1	C432925	100.0	100.0	100.0
C433050	99.9	C433078	99.9	C433119	100.0	100.0	100.0
C433172	100.0	C433197	100.0	C433261	101.5	100.2	100.0
C433378	100.0	C445646	100.0	C445994	100.0	100.0	100.0
C432005	100.0	C432051	100.0	C432105	100.0	100.0	100.1
C432272	100.1	C432276	100.0	C432310	100.0	100.0	100.0
C432371	99.9	C432375	100.0	C432378	100.0	100.0	100.0
C432409	100.0	C432409	100.0	C432390	100.0	100.0	100.0
C432363	99.9	C432363	100.0	C432358	100.0	100.0	100.0
C432162	99.9	C432162	100.1	C432157	100.0	100.0	100.1
C432854	100.0	C432854	100.0	C432819	100.0	100.0	100.0
C432598	100.0	C432598	100.0	C432583	100.0	100.0	100.0
C432552	100.0	C432552	100.0	C432550	99.9	100.0	100.0
C432031	100.0	C432031	100.0	C433009	100.0	100.0	100.0
C433160	100.0	C433160	100.0	C433151	100.0	100.0	100.0
C433307	100.0	C433307	100.2	C433290	100.0	100.0	100.0
C446144	100.0	C446144	100.0	C446082	100.0	100.0	100.0

VALUE OBTAINED

INFORMATION NEEDED

1	SAMPLE SIZE: N	50
2	SUM OF MEASUREMENTS	5,001.2
3	SUM OF SQUARED MEASUREMENTS	500,242.40
4	CORRECTION FACTOR (CF): SUM OF X SQUARED / N	500,240.03
5	CORRECTED SUM OF SQUARES (SS):	0.2200
6	VARIANCE (V): SS/(N-1)	0.0484
7	ESTIMATE OF LOT STANDARD DEVIATION S: SR OF V	0.0484
8	SAMPLE MEAN X BAR: SUM X/N	100.02
9	UPPER SPECIFICATION LIMIT: U	102.00
10	LOWER SPECIFICATION LIMIT: L	98.00
11	QUALITY INDEX: QU=(U-XBAR)/S	9.00
12	QUALITY INDEX: QL=(XBAR-L)/S	9.18
13	ESTIMATE OF LOT PERCENT NCF. ABOVE U:PU	0.00
14	ESTIMATE OF LOT PERCENT NCF. BELOW L:PL	0.00
15	TOTAL ESTIMATE PERCENT NCF. IN LOT: P=PU+PL	0.00
16	MAXIMUM ALLOWABLE PERCENT NCF: M	05.21
17	ACCEPTABILITY CRITERION: COMPARE P=PU+PL WITH M	PASS
18	PASS: THE LOT MEETS THE ACCEPTABILITY CRITERION, IF P=PU+PL IS EQUAL TO OR LESS THAN M	
19	FAIL: THE LOT FAILS THE ACCEPTABILITY CRITERION, IF P=PU+PL IS GREATER THAN M.	

2007 SAMPLE TEST PROGRAM (JANUARY 1, 2007 TO DECEMBER 31, 2007)
IN-SERVICE SAMPLE METERS TESTED PASS/
POPULATION QUANTITY 50 50 FAIL
METER-TYPE GE I55 1,643 50 PASS

TEST RESULTS PER ANSI/ASQC Z1.9-1993
DOUBLE SPECIFICATION LIMIT - VARIABILITY UNKNOWN - STANDARD DEVIATION METHOD
ONE AQL VALUE FOR BOTH UPPER AND LOWER SPECIFICATION LIMIT COMBINED
AQL = 2.5% - INSPECTION LEVEL II "K" - NORMAL INSPECTION

*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****				
*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****			
*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****		
C190729	100.1	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	
L076235	99.7	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****
L077647	100.2	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****
L079285	100.2	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****
L080508	99.7	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****
L080763	99.8	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****
L081994	99.9	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****
L083390	100.0	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****
L085843	99.8	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****
L089575	99.1	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****

INFORMATION NEEDED

- SAMPLE SIZE: N
- SUM OF MEASUREMENTS
- SUM OF SQUARED MEASUREMENTS
- CORRECTION FACTOR (CF): SUM OF X SQUARED / N
- CORRECTED SUM OF SQUARES (SS)
- VARIANCE (V): SS/(N-1)
- ESTIMATE OF LOT STANDARD DEVIATION S: SR OF V
- SAMPLE MEAN X BAR: SUM X/N
- UPPER SPECIFICATION LIMIT: U
- LOWER SPECIFICATION LIMIT: L
- QUALITY INDEX: QU=(U-XBAR)/S
- QUALITY INDEX: QL=(XBAR-L)/S
- ESTIMATE OF LOT PERCENT NCF: ABOVE U*PU
- ESTIMATE OF LOT PERCENT NCF: BELOW L*PL
- TOTAL ESTIMATE PERCENT NCF: IN LOT: P=PU+PL
- MAXIMUM ALLOWABLE PERCENT NCF: M
- ACCEPTABILITY CRITERION: COMPARE P=PU+PL WITH M
- PASS: THE LOT MEETS THE ACCEPTABILITY CRITERION, IF P=PU+PL IS EQUAL TO OR LESS THAN M
- FAIL: THE LOT FAILS THE ACCEPTABILITY CRITERION, IF P=PU+PL IS GREATER THAN M.

VALUE OBTAINED

50
4,993.9
498,784.87
498,780.74
04.13
0.0843
0.2903
99.88
102.00
98.00
7.30
6.48
0.00
0.00
0.00
0.00
05.21
PASS

2007 SAMPLE TEST PROGRAM (JANUARY 1, 2007 TO DECEMBER 31, 2007)
KENTUCKY UTILITIES COMPANY
IN-SERVICE SAMPLE METERS PASS/
POPULATION QUANTITY TESTED FAIL
METER-TYPE QUANTITY TESTED PASS
160 004 GE I60 5,342 75 75

TEST RESULTS PER ANSI/ASQC Z1.9-1993
DOUBLE SPECIFICATION LIMIT - VARIABILITY UNKNOWN - STANDARD DEVIATION METHOD
ONE AQL VALUE FOR BOTH UPPER AND LOWER SPECIFICATION LIMIT COMBINED
AQL = 2.5% - INSPECTION LEVEL II "L" - NORMAL INSPECTION

DEVICE NUMBER	FULL LOAD	TEST ACCURACY DATA	TEST ACCURACY DATA
C218784	100.5	C218818	C218829
C219033	100.0	C220084	L004863
L011074	99.9	L011747	L014308
L021401	100.3	L025057	L039500
L088473	100.1	L090134	L091893
L100423	100.0	L103264	L123666
L123786	99.9	L123873	L123920
L124278	100.1	L124545	L124655
L124904	100.1	L124907	L125146
L125612	99.9	L125803	L125858
L126066	100.3	L126137	L126210
L126590	99.7	L126641	L126682
L127126	100.2	L127163	L127243
L127599	100.0	L127686	L127693
L268386	99.9	L268395	L268421
C218718	100.5	C218818	C218890
C219026	100.0	C220084	L006740
L009221	99.8	L011074	L015718
L019268	100.1	L021401	L040230
L064107	100.3	L088473	L093393
L095087	99.7	L100423	L123709
L123749	100.4	L123786	L124204
L124241	100.0	L124278	L124685
L124740	99.8	L124904	L125340
L125347	100.0	L125612	L125866
L126014	99.8	L126066	L126450
L126460	99.9	L126590	L126811
L127107	100.2	L127126	L127275
L127368	100.1	L127599	L127716
L127847	99.9	L268386	L268451

VALUE OBTAINED

1 SAMPLE SIZE: N	75
2 SUM OF MEASUREMENTS	7,507.3
3 SUM OF SQUARED MEASUREMENTS	751,465.71
4 CORRECTION FACTOR (CF): SUM OF X SQUARED / N	751,460.71
5 CORRECTED SUM OF SQUARES (SS):	05.00
6 VARIANCE (V): SS/(N-1)	0.0676
7 ESTIMATE OF LOT STANDARD DEVIATION S: SR OF V	0.2600
8 SAMPLE MEAN X BAR: SUM X/N	100.10
9 UPPER SPECIFICATION LIMIT: U	102.00
10 LOWER SPECIFICATION LIMIT: L	98.00
11 QUALITY INDEX: QU=(U-XBAR)/S	7.31
12 QUALITY INDEX: QL=(XBAR-L)/S	8.08
13 ESTIMATE OF LOT PERCENT NCF: ABOVE U:PU	0.00
14 ESTIMATE OF LOT PERCENT NCF: BELOW L:PL	0.00
15 TOTAL ESTIMATE PERCENT NCF: IN LOT: P=PU+PL	0.00
16 MAXIMUM ALLOWABLE PERCENT NCF: M	04.83
17 ACCEPTABILITY CRITERION: COMPARE P=PU+PL WITH M	PASS
18 PASS: THE LOT MEETS THE ACCEPTABILITY CRITERION, IF P=PU+PL IS EQUAL TO OR LESS THAN M	
19 FAIL: THE LOT FAILS THE ACCEPTABILITY CRITERION, IF P=PU+PL IS GREATER THAN M.	

2007 SAMPLE TEST PROGRAM (JANUARY 1, 2007 TO DECEMBER 31, 2007)
 KENTUCKY UTILITIES COMPANY
 GROUP - -NAME METER-TYPE QUANTITY TESTED METERS TESTED PASS/FAIL
 I70 004 GE I70 10,000 75 75

TEST RESULTS PER ANSI/ASQC Z1.9-1993
 DOUBLE SPECIFICATION LIMIT - VARIABILITY UNKNOWN - STANDARD DEVIATION METHOD
 ONE AQL VALUE FOR BOTH UPPER AND LOWER SPECIFICATION LIMIT COMBINED
 AQL = 2.5% - INSPECTION LEVEL II "L" - NORMAL INSPECTION

DEVIANCE	DEVIATION	TEST ACCURACY DATA	TEST ACCURACY DATA	TEST ACCURACY DATA	TEST ACCURACY DATA
100.4	100.2	C221654	100.3	100.4	100.4
100.4	100.7	C239136	100.3	100.5	100.0
100.4	100.1	C243034	100.4	100.2	100.1
100.2	99.7	C243551	100.0	100.0	100.2
99.7	100.4	L180749	99.8	100.2	100.2
100.2	99.8	L181325	100.2	100.1	99.9
100.3	100.0	L182506	100.3	100.3	100.2
99.9	99.5	L182825	100.1	99.8	99.9
100.0	100.2	L184915	99.9	99.9	100.1
99.7	99.9	L186971	99.7	99.8	99.8
100.2	99.7	L187331	100.1	99.9	100.0
100.2	99.8	L188818	100.5	99.9	100.0
99.7	100.1	L190268	99.5	100.0	99.8
99.9	100.3	L191291	100.2	99.9	100.3
100.0	100.0	L192600	99.6	99.7	100.1
100.1	100.0	L195059	100.3	100.3	100.1
100.4	100.2	C221654	100.3	100.4	100.4
100.4	100.7	C239136	100.3	100.5	100.0
100.4	100.1	C243034	100.4	100.2	100.1
100.2	99.7	L180749	100.0	100.0	100.2
99.7	100.4	L181325	99.8	100.2	100.2
100.2	99.8	L182506	100.2	100.1	99.9
100.3	100.0	L182825	100.3	100.3	100.2
99.9	99.5	L184915	100.1	99.8	99.9
100.0	100.2	L186971	99.9	99.9	100.1
99.7	99.9	L187331	99.7	99.8	99.8
100.2	99.8	L188818	100.1	99.9	100.0
99.7	100.1	L190268	99.5	100.0	99.8
99.9	100.3	L191291	100.2	99.9	100.3
100.0	100.0	L192600	99.6	99.7	100.1
100.1	100.0	L195059	100.3	100.3	100.1

VALUE OBTAINED

1	SAMPLE SIZE: N	75
2	SUM OF MEASUREMENTS	7,504.6
3	SUM OF SQUARED MEASUREMENTS	750,924.82
4	CORRECTION FACTOR (CF): SUM OF X SQUARED / N	750,920.28
5	CORRECTED SUM OF SQUARES (SS)	04.54
6	VARIANCE (V): SS/(N-1)	0.0614
7	ESTIMATE OF LOT STANDARD DEVIATION S: SR OF V	0.2478
8	SAMPLE MEAN X BAR: SUM X/N	100.06
9	UPPER SPECIFICATION LIMIT: U	102.00
10	LOWER SPECIFICATION LIMIT: L	98.00
11	QUALITY INDEX: QU=(U-XBAR)/S	7.83
12	QUALITY INDEX: QL=(XBAR-L)/S	8.31
13	ESTIMATE OF LOT PERCENT NCF. ABOVE U:PU	0.00
14	ESTIMATE OF LOT PERCENT NCF. BELOW L:PL	0.00
15	TOTAL ESTIMATE PERCENT NCF. IN LOT: P=PU+PL	0.00
16	MAXIMUM ALLOWABLE PERCENT NCF: M	04.83
17	ACCEPTABILITY CRITERION: COMPARE P=PU+PL WITH M	PASS
18	PASS: THE LOT MEETS THE ACCEPTABILITY CRITERION, IF P=PU+PL IS EQUAL TO OR LESS THAN M	
19	FAIL: THE LOT FAILS THE ACCEPTABILITY CRITERION, IF P=PU+PL IS GREATER THAN M.	

INFORMATION NEEDED

1	SAMPLE SIZE: N	75
2	SUM OF MEASUREMENTS	7,504.6
3	SUM OF SQUARED MEASUREMENTS	750,924.82
4	CORRECTION FACTOR (CF): SUM OF X SQUARED / N	750,920.28
5	CORRECTED SUM OF SQUARES (SS)	04.54
6	VARIANCE (V): SS/(N-1)	0.0614
7	ESTIMATE OF LOT STANDARD DEVIATION S: SR OF V	0.2478
8	SAMPLE MEAN X BAR: SUM X/N	100.06
9	UPPER SPECIFICATION LIMIT: U	102.00
10	LOWER SPECIFICATION LIMIT: L	98.00
11	QUALITY INDEX: QU=(U-XBAR)/S	7.83
12	QUALITY INDEX: QL=(XBAR-L)/S	8.31
13	ESTIMATE OF LOT PERCENT NCF. ABOVE U:PU	0.00
14	ESTIMATE OF LOT PERCENT NCF. BELOW L:PL	0.00
15	TOTAL ESTIMATE PERCENT NCF. IN LOT: P=PU+PL	0.00
16	MAXIMUM ALLOWABLE PERCENT NCF: M	04.83
17	ACCEPTABILITY CRITERION: COMPARE P=PU+PL WITH M	PASS
18	PASS: THE LOT MEETS THE ACCEPTABILITY CRITERION, IF P=PU+PL IS EQUAL TO OR LESS THAN M	
19	FAIL: THE LOT FAILS THE ACCEPTABILITY CRITERION, IF P=PU+PL IS GREATER THAN M.	

MD8885A

2007 SAMPLE TEST PROGRAM (JANUARY 1, 2007 TO DECEMBER 31, 2007)
KENTUCKY UTILITIES COMPANY
IN-SERVICE SAMPLE METERS PASS/
POPULATION QUANTITY TESTED FAIL
I70 010 GE I70 METER-TYPE QUANTITY TESTED PASS
10,000 75 75

PAGE 25
RUN DATE 1/02/08
RUN TIME 14.37.04

TEST RESULTS PER ANSI/ASQC Z1.9-1993

DOUBLE SPECIFICATION LIMIT - VARIABILITY UNKNOWN - STANDARD DEVIATION METHOD
ONE AQL VALUE FOR BOTH UPPER AND LOWER SPECIFICATION LIMIT COMBINED
AQL = 2.5% - INSPECTION LEVEL II "L" - NORMAL INSPECTION

*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****
*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****
*****	100.3	*****	100.3	*****	100.3	*****	100.3	*****	100.3	*****	100.3	*****	100.1
*****	100.1	*****	100.7	*****	100.4	*****	100.4	*****	99.9	*****	99.9	*****	100.1
*****	100.4	*****	100.3	*****	100.1	*****	100.1	*****	100.3	*****	100.3	*****	100.4
*****	99.9	*****	100.0	*****	100.0	*****	100.4	*****	100.3	*****	100.3	*****	99.8
*****	100.0	*****	99.8	*****	100.3	*****	100.3	*****	100.2	*****	100.2	*****	99.9
*****	100.0	*****	100.3	*****	100.0	*****	100.0	*****	100.2	*****	100.2	*****	100.1
*****	100.3	*****	100.1	*****	99.9	*****	99.9	*****	100.2	*****	100.2	*****	100.2
*****	100.1	*****	100.1	*****	100.1	*****	100.1	*****	100.3	*****	100.3	*****	100.4
*****	100.2	*****	100.3	*****	100.3	*****	100.2	*****	100.0	*****	100.0	*****	99.9
*****	99.8	*****	99.7	*****	99.9	*****	99.9	*****	99.8	*****	99.8	*****	100.1
*****	100.2	*****	99.8	*****	100.2	*****	100.2	*****	100.0	*****	100.0	*****	99.7
*****	99.8	*****	100.2	*****	100.1	*****	100.1	*****	100.0	*****	100.0	*****	100.0
*****	100.0	*****	100.0	*****	100.0	*****	100.0	*****	100.1	*****	100.1	*****	100.3
*****	100.3	*****	100.0	*****	100.0	*****	100.3	*****	100.2	*****	100.2	*****	100.2
*****	100.0	*****	100.5	*****	100.5	*****	100.5	*****	100.0	*****	100.0	*****	100.0

VALUE OBTAINED

1	SAMPLE SIZE: N	75
2	SUM OF MEASUREMENTS	7,508.7
3	SUM OF SQUARED MEASUREMENTS	751,743.99
4	CORRECTION FACTOR (CF): SUM OF X SQUARED / N	751,741.01
5	CORRECTED SUM OF SQUARES (SS)	02.98
6	VARIANCE (V): SS/(N-1)	0.0403
7	ESTIMATE OF LOT STANDARD DEVIATION S:	0.2007
8	SAMPLE MEAN X BAR: SUM X/N	100.12
9	UPPER SPECIFICATION LIMIT: U	102.00
10	LOWER SPECIFICATION LIMIT: L	98.00
11	QUALITY INDEX: QU=(U-XBAR)/S	9.37
12	QUALITY INDEX: QL=(XBAR-L)/S	10.56
13	ESTIMATE OF LOT PERCENT NCF: ABOVE U:PU	0.00
14	ESTIMATE OF LOT PERCENT NCF: BELOW L:PL	0.00
15	TOTAL ESTIMATE PERCENT NCF: IN LOT: P=PU+PL	0.00
16	MAXIMUM ALLOWABLE PERCENT NCF: M	04.83
17	ACCEPTABILITY CRITERION: COMPARE P=PU+PL WITH M	PASS
18	PASS: THE LOT MEETS THE ACCEPTABILITY CRITERION, IF P=PU+PL IS EQUAL TO OR LESS THAN M	
19	FAIL: THE LOT FAILS THE ACCEPTABILITY CRITERION, IF P=PU+PL IS GREATER THAN M.	

INFORMATION NEEDED

1 SAMPLE SIZE: N
2 SUM OF MEASUREMENTS
3 SUM OF SQUARED MEASUREMENTS
4 CORRECTION FACTOR (CF): SUM OF X SQUARED / N
5 CORRECTED SUM OF SQUARES (SS)
6 VARIANCE (V): SS/(N-1)
7 ESTIMATE OF LOT STANDARD DEVIATION S: SR OF V

KENTUCKY UTILITIES COMPANY
 2007 SAMPLE TEST PROGRAM (JANUARY 1, 2007 TO DECEMBER 31, 2007)
 IN-SERVICE SAMPLE METERS PASS/
 POPULATION QUANTITY TESTED FAIL
 GROUP --NAME METER-TYPE QUANTITY TESTED PASS
 J 001 SA J 71 07 07 07

TEST RESULTS PER ANSI/ASQC Z1.9-1993
 DOUBLE SPECIFICATION LIMIT - VARIABILITY UNKNOWN - STANDARD DEVIATION METHOD
 ONE AQL VALUE FOR BOTH UPPER AND LOWER SPECIFICATION LIMIT COMBINED
 AQL = 2.5% - INSPECTION LEVEL II "E" - NORMAL INSPECTION

***** DEVIATION DATA ***** W053807 ***** W098310 ***** 99.6
 ***** DEVICE NUMBER AND FULL LOAD TEST ACCURACY DATA ***** W053047 ***** W098321 ***** 100.1
 ***** W046139 ***** W098321 ***** 100.2
 ***** W098314 *****

INFORMATION NEEDED

ITEM	DESCRIPTION	VALUE	OBTAINED
1	SAMPLE SIZE: N	700	4
2	SUM OF MEASUREMENTS	70,082	10
3	SUM OF SQUARED MEASUREMENTS	70,080	02
4	CORRECTION FACTOR (CF): SUM OF X SQUARED / N	02	08
5	CORRECTED SUM OF SQUARES (SS):	0	3467
6	VARIANCE (V): SS/(N-1)	0	5888
7	ESTIMATE OF LOT STANDARD DEVIATION S: SR OF V	100	06
8	SAMPLE MEAN X BAR: SUM X/N	102	00
9	UPPER SPECIFICATION LIMIT: U	98	00
10	LOWER SPECIFICATION LIMIT: L	3	29
11	QUALITY INDEX: QU=(U-XBAR)/S	3	50
12	QUALITY INDEX: QL=(XBAR-L)/S	0	00
13	ESTIMATE OF LOT PERCENT NCF. ABOVE U:PU	0	00
14	ESTIMATE OF LOT PERCENT NCF. BELOW L:PL	0	00
15	TOTAL ESTIMATE PERCENT NCF. IN LOT: P=PU+PL	08	40
16	MAXIMUM ALLOWABLE PERCENT NCF: M		PASS
17	ACCEPTABILITY CRITERION: COMPARE P=PU+PL WITH M		
18	PASS: THE LOT MEETS THE ACCEPTABILITY CRITERION, IF P=PU+PL IS EQUAL TO OR LESS THAN M		
19	FAIL: THE LOT FAILS THE ACCEPTABILITY CRITERION, IF P=PU+PL IS GREATER THAN M.		

KENTUCKY UTILITIES COMPANY
 2007 SAMPLE TEST PROGRAM (JANUARY 1, 2007 TO DECEMBER 31, 2007)
 IN-SERVICE SAMPLE METERS
 POPULATION QUANTITY TESTED
 METER-TYPE QUANTITY TESTED
 SA J5 004 10,000 75
 SA J5 004 10,000 75

TEST RESULTS PER ANSI/ASQC Z1.9-1993
 DOUBLE SPECIFICATION LIMIT - VARIABILITY UNKNOWN - STANDARD DEVIATION METHOD
 ONE AQL VALUE FOR BOTH UPPER AND LOWER SPECIFICATION LIMIT COMBINED
 AQL = 2.5% - INSPECTION LEVEL II "L" - NORMAL INSPECTION

DEVIANCE (V)	SS/(N-1)	ESTIMATE OF LOT STANDARD DEVIATION S:	SR	OF	V	TEST ACCURACY DATA	TEST ACCURACY DATA
100.4	100.2	100.2	100.2	100.2	100.2	C303140	C303348
99.8	100.0	100.0	100.0	100.0	100.0	C303657	C303809
100.2	100.0	100.0	99.6	100.3	100.3	L267087	L267155
99.9	100.0	100.0	100.3	100.0	100.0	L267605	L267636
99.5	99.5	100.0	100.1	99.9	99.9	L269644	L269666
99.7	100.2	100.2	100.2	100.2	100.2	L270567	L270581
100.1	99.9	100.2	99.8	100.3	100.3	L271040	L271089
100.1	99.8	100.1	99.8	100.3	100.3	L271192	L2711351
99.7	99.9	100.1	99.6	99.9	99.9	L271475	L271876
99.9	99.9	100.2	99.6	100.5	100.5	L272085	L272446
99.8	100.0	100.2	99.9	100.0	100.0	L272746	L273137
100.1	100.2	100.2	99.9	100.0	100.0	L273174	L273477
100.2	100.1	100.2	100.2	99.9	99.9	L273789	L274016
99.9	100.0	100.0	99.9	100.3	100.3	L274734	L275312
99.8	100.0	100.0	99.9	99.8	99.8	L275849	L276139

VALUE OBTAINED

75	7,499.9
749,984.27	749,984.27
0.0577	0.0577
0.2402	0.2402
100.00	100.00
198.00	198.00
8.33	8.33
8.33	8.33
0.00	0.00
0.00	0.00
0.00	0.00
04.83	04.83
PASS	PASS

17 ACCEPTABILITY CRITERION: COMPARE P=PU+PL WITH M
 18 PASS: THE LOT MEETS THE ACCEPTABILITY CRITERION, IF P=PU+PL IS EQUAL TO OR LESS THAN M
 19 FAIL: THE LOT FAILS THE ACCEPTABILITY CRITERION, IF P=PU+PL IS GREATER THAN M.

INFORMATION NEEDED

- 1 SAMPLE SIZE: N
- 2 SUM OF MEASUREMENTS
- 3 SUM OF SQUARED MEASUREMENTS
- 4 CORRECTION FACTOR (CF): SUM OF X SQUARED / N
- 5 CORRECTED SUM OF SQUARES (SS)
- 6 VARIANCE (V): SS/(N-1)
- 7 ESTIMATE OF LOT STANDARD DEVIATION S:
- 8 SAMPLE MEAN X BAR: SUM X/N
- 9 UPPER SPECIFICATION LIMIT: U
- 10 LOWER SPECIFICATION LIMIT: L
- 11 QUALITY INDEX: QU=(U-XBAR)/S
- 12 QUALITY INDEX: QL=(XBAR-L)/S
- 13 ESTIMATE OF LOT PERCENT NCF: ABOVE U:PU
- 14 ESTIMATE OF LOT PERCENT NCF: BELOW L:PL
- 15 TOTAL ESTIMATE PERCENT NCF: IN LOT: P=PU+PL
- 16 MAXIMUM ALLOWABLE PERCENT NCF: M
- 17 ACCEPTABILITY CRITERION: COMPARE P=PU+PL WITH M
- 18 PASS: THE LOT MEETS THE ACCEPTABILITY CRITERION, IF P=PU+PL IS EQUAL TO OR LESS THAN M
- 19 FAIL: THE LOT FAILS THE ACCEPTABILITY CRITERION, IF P=PU+PL IS GREATER THAN M.

KENTUCKY UTILITIES COMPANY
 2007 SAMPLE TEST PROGRAM (JANUARY 1, 2007 TO DECEMBER 31, 2007)
 GROUP--NAME METER-TYPE POPULATION QUANTITY TESTED PASS/
 FAIL
 RUN DATE 1/02/08 RUN TIME 14.37.04
 PAGE 41

TEST RESULTS PER ANSI/ASQC Z1.9-1993
 DOUBLE SPECIFICATION LIMIT - VARIABILITY UNKNOWN - STANDARD DEVIATION METHOD
 ONE AQL VALUE FOR BOTH UPPER AND LOWER SPECIFICATION LIMIT COMBINED
 AQL = 2.5% - INSPECTION LEVEL II "L" - NORMAL INSPECTION

DEVICE NUMBER AND FULL LOAD TEST ACCURACY DATA	VALUE OBTAINED	INFORMATION NEEDED
C326018	100.3	100.3
W145999	100.6	100.6
W145100	100.2	100.2
W145226	100.2	100.2
W1446276	100.2	100.2
M443348	99.9	100.2
L296185	99.7	100.2
L295295	99.6	100.1
L295062	99.6	100.1
L294312	100.4	100.3
L293870	100.1	100.3
L293506	99.9	100.1
L292836	100.7	100.2
L291799	99.8	100.1
C327924	100.1	100.1
C327509	100.1	100.1
C327184	101.8	100.4
C326680	99.9	100.3
C326999	100.2	100.2
W146325	100.1	100.1
W145618	100.0	100.0
W144691	100.1	100.1
L296281	100.7	100.7
L295433	100.0	100.0
L295137	100.2	100.2
L294435	99.8	100.3
L294258	99.7	99.8
L293581	100.1	100.1
L293293	100.3	100.3
L292417	100.0	100.0
L291506	99.8	99.8
L291509	99.7	100.3
L292434	100.0	100.0
L293312	99.8	99.8
L293747	100.5	100.5
L294289	100.0	100.0
L294721	100.2	100.2
L295141	101.6	101.6
L295742	99.6	99.6
L296387	100.1	100.1
L295938	99.9	99.9
L295217	99.8	99.8
L294797	100.4	100.4
L294302	100.0	100.0
L293792	100.3	100.3
L293450	99.9	99.9
L292637	100.0	100.0
L291778	100.0	100.0
C327842	100.3	100.3
C327479	100.4	100.4
C327034	100.1	100.1
W146469	99.7	99.7
W145887	99.9	99.9
W144976	100.3	100.3
M442986	100.1	100.1
L295938	99.6	99.6
L295217	101.6	101.6
L294797	100.2	100.2
L294302	100.0	100.0
L293792	100.5	100.5
L293450	99.8	99.8
L292637	100.0	100.0
L291778	100.0	100.0
C327842	100.3	100.3
C327479	100.4	100.4
C327034	100.1	100.1

1 SAMPLE SIZE: N
 2 SUM OF MEASUREMENTS
 3 SUM OF SQUARED MEASUREMENTS
 4 CORRECTION FACTOR (CF): SUM OF X SQUARED / N
 5 CORRECTED SUM OF SQUARES (SS):
 6 VARIANCE (V): SS/(N-1)
 7 ESTIMATE OF LOT STANDARD DEVIATION S: SR OF V
 8 SAMPLE MEAN X BAR: SUM X/N
 9 UPPER SPECIFICATION LIMIT: U
 10 LOWER SPECIFICATION LIMIT: L
 11 QUALITY INDEX: QU=(U-XBAR)/S
 12 QUALITY INDEX: QL=(XBAR-L)/S
 13 ESTIMATE OF LOT PERCENT NCF. ABOVE U:PU
 14 ESTIMATE OF LOT PERCENT NCF. BELOW L:PL
 15 TOTAL ESTIMATE PERCENT NCF. IN LOT: P=PU+PL
 16 MAXIMUM ALLOWABLE PERCENT NCF: M
 17 ACCEPTABILITY CRITERION: COMPARE P=PU+PL WITH M
 18 PASS: THE LOT MEETS THE ACCEPTABILITY CRITERION, IF P=PU+PL IS EQUAL TO OR LESS THAN M
 19 FAIL: THE LOT FAILS THE ACCEPTABILITY CRITERION, IF P=PU+PL IS GREATER THAN M.

KENTUCKY UTILITIES COMPANY

2007 SAMPLE TEST PROGRAM (JANUARY 1, 2007 TO DECEMBER 31, 2007)

IN-SERVICE METERS PASS/FAIL TESTED 75

GROUP--NAME METER-TYPE POPULATION QUANTITY SAMPLE TESTED 75

M0

001 DU M0

5,044

TEST RESULTS PER ANSI/ASQC Z1.9-1993

DOUBLE SPECIFICATION LIMIT - VARIABILITY UNKNOWN - STANDARD DEVIATION METHOD

ONE AQL VALUE FOR BOTH UPPER AND LOWER SPECIFICATION LIMIT COMBINED

AQL = 2.5% - - INSPECTION LEVEL II "L" - NORMAL INSPECTION

***** DEVICE NUMBER AND FULL LOAD TEST ACCURACY DATA *****

TEST NO	TEST NAME	TEST VALUE	TEST RESULT	TEST UNIT	TEST DATE	TEST TIME
99.7	C208054	99.8	100.0	100.0	100.0	100.0
100.3	C209432	100.3	100.3	100.3	100.3	100.3
100.4	C211235	100.5	100.5	100.5	100.5	100.5
100.1	C212176	100.3	100.3	100.3	100.3	100.3
100.4	C214699	100.3	100.3	100.3	100.3	100.3
99.9	C217858	100.3	100.3	100.3	100.3	100.3
100.0	C220872	99.9	99.9	99.9	99.9	99.9
100.0	C222670	100.5	100.5	100.5	100.5	100.5
100.8	M387061	100.4	100.4	100.4	100.4	100.4
99.6	W094003	100.4	100.4	100.4	100.4	100.4
98.9	W094594	100.2	100.2	100.2	100.2	100.2
100.4	W095174	100.4	100.4	100.4	100.4	100.4
100.1	W097270	100.8	100.8	100.8	100.8	100.8
100.1	W101414	100.0	100.0	100.0	100.0	100.0
100.0	W101904	100.0	100.0	100.0	100.0	100.0

INFORMATION NEEDED

VALUE OBTAINED

1 SAMPLE SIZE: N 75

2 SUM OF MEASUREMENTS 7,509.3

3 SUM OF SQUARED MEASUREMENTS 751,870.83

4 CORRECTION FACTOR (CF): SUM OF X SQUARED / N 751,861.15

5 CORRECTED SUM OF SQUARES (SS): 09.68

6 VARIANCE (V): SS/(N-1) 0.1308

7 ESTIMATE OF LOT STANDARD DEVIATION S: SR OF V 0.3616

8 SAMPLE MEAN X BAR: SUM X/N 100.12

9 UPPER SPECIFICATION LIMIT: U 102.00

10 LOWER SPECIFICATION LIMIT: L 98.00

11 QUALITY INDEX: QU=(U-XBAR)/S 5.20

12 QUALITY INDEX: QL=(XBAR-L)/S 5.86

13 ESTIMATE OF LOT PERCENT NCF ABOVE U:PU 0.00

14 ESTIMATE OF LOT PERCENT NCF BELOW L:PL 0.00

15 TOTAL ESTIMATE PERCENT NCF IN LOT: P=PU+PL 0.00

16 MAXIMUM ALLOWABLE PERCENT NCF: M 04.83

17 ACCEPTABILITY CRITERION: COMPARE P=PU+PL WITH M PASS

18 PASS: THE LOT MEETS THE ACCEPTABILITY CRITERION, IF P=PU+PL IS EQUAL TO OR LESS THAN M

19 FAIL: THE LOT FAILS THE ACCEPTABILITY CRITERION, IF P=PU+PL IS GREATER THAN M.

KENTUCKY UTILITIES COMPANY

PAGE 59
RUN DATE 1/02/08
RUN TIME 14.37.04

2007 SAMPLE TEST PROGRAM (JANUARY 1, 2007 TO DECEMBER 31, 2007)
METERS PASS/
IN-SERVICE Meters TESTED 75
POPULATION QUANTITY 10,000
LG MX 002
METER-TYPE LG MX

TEST RESULTS PER ANSI/ASQC Z1.9-1993
DOUBLE SPECIFICATION LIMIT - VARIABILITY UNKNOWN - STANDARD DEVIATION METHOD
ONE AQL VALUE FOR BOTH UPPER AND LOWER SPECIFICATION LIMIT COMBINED
AQL = 2.5% - INSPECTION LEVEL II "L" - NORMAL INSPECTION

***** DEVICE NUMBER AND FULL LOAD TEST ACCURACY DATA *****

TEST NUMBER	TEST VALUE	TEST VALUE	TEST VALUE	TEST VALUE	TEST VALUE	TEST VALUE	TEST VALUE
C324947	100.1	C325244	99.8	C325260	99.9	C325680	100.1
C390662	100.1	C390833	100.0	C390857	100.0	C390907	99.7
C391066	100.3	C391115	100.2	C391339	100.0	C391341	100.1
C426019	99.9	C426146	99.8	C426671	99.5	C426728	100.0
C426924	100.0	C427075	99.7	C427234	100.2	C427264	100.0
C427551	99.9	C427705	99.8	C427811	100.0	C428308	100.4
C428428	99.9	C428637	100.1	C428794	100.1	C428898	99.3
C429168	99.7	C429220	100.0	C429338	100.0	C429454	100.2
C430560	99.0	C430572	99.7	C430659	99.8	C430244	99.6
C430971	99.6	C431154	100.0	C431188	99.8	C431365	99.9
C431576	99.7	C431628	99.7	C431702	99.5	C431747	100.4
C435527	99.5	C435751	99.6	C435796	100.0	C435797	100.1
C436411	99.8	C436574	99.8	C436748	99.9	C437044	99.7
L292199	100.0	L292273	99.8	W143928	100.6	W143990	99.9

INFORMATION NEEDED

VALUE OBTAINED

- 1 SAMPLE SIZE: N
- 2 SUM OF MEASUREMENTS
- 3 SUM OF SQUARED MEASUREMENTS
- 4 CORRECTION FACTOR (CF): SUM OF X SQUARED / N
- 5 CORRECTED SUM OF SQUARES (SS):
- 6 VARIANCE (V): SS/(N-1)
- 7 ESTIMATE OF LOT STANDARD DEVIATION S: SR OF V
- 8 SAMPLE MEAN X BAR: SUM X/N
- 9 UPPER SPECIFICATION LIMIT: U
- 10 LOWER SPECIFICATION LIMIT: L
- 11 QUALITY INDEX: QU=(U-XBAR)/S
- 12 QUALITY INDEX: QL=(XBAR-L)/S
- 13 ESTIMATE OF LOT NCF: ABOVE U:PU
- 14 ESTIMATE OF LOT PERCENT NCF: BELOW L:PL
- 15 TOTAL ESTIMATE PERCENT NCF: IN LOT: P=PU+PL
- 16 MAXIMUM ALLOWABLE PERCENT NCF: M
- 17 ACCEPTABILITY CRITERION: COMPARE P=PU+PL WITH M
- 18 PASS: THE LOT MEETS THE ACCEPTABILITY CRITERION, IF P=PU+PL IS EQUAL TO OR LESS THAN M
- 19 FAIL: THE LOT FAILS THE ACCEPTABILITY CRITERION, IF P=PU+PL IS GREATER THAN M.

2007 GROUP	2007 SAMPLE	KENTUCKY UTILITIES PROGRAM (JANUARY 1, IN-SERVICE POPULATION	UTILITY IN-SERVICE POPULATION	COMPANY 2007 TO DECEMBER 31, SAMPLE QUANTITY	MEASUREMENT METERS TESTED	STATUS PASS/ FAIL
AB1	001	10,000	10,000	75	75	PASS
AB1	002	6,451	6,451	75	75	PASS
AB1	001	6,124	6,124	20	20	FAIL
CI	001	371	371	75	75	PASS
D	001	10,000	10,000	75	75	PASS
D4	001	10,000	10,000	75	75	PASS
D4	002	9,558	9,558	75	75	PASS
D4	003	559	559	35	35	PASS
D5	001	1,578	1,578	50	50	PASS
I210	001	1,816	1,816	50	50	PASS
I50	001	1,643	1,643	75	75	PASS
I55	001	10,000	10,000	75	75	PASS
I60	001	10,000	10,000	75	75	PASS
I60	002	10,000	10,000	75	75	PASS
I60	003	5,342	5,342	75	75	PASS
I60	004	10,000	10,000	75	75	PASS
I70	001	10,000	10,000	75	75	PASS
I70	002	10,000	10,000	75	75	PASS
I70	003	10,000	10,000	75	75	PASS
I70	004	10,000	10,000	75	75	PASS
I70	005	10,000	10,000	75	75	PASS
I70	006	10,000	10,000	75	75	PASS
I70	007	10,000	10,000	75	75	PASS
I70	008	10,000	10,000	75	75	PASS
I70	009	10,000	10,000	75	75	PASS
I70	010	10,000	10,000	75	75	PASS
I70	011	10,000	10,000	75	75	PASS
I70	012	10,000	10,000	75	75	PASS
I70	013	4,389	4,389	75	75	PASS
J	001	71	71	07	07	PASS
J2	001	71	71	07	07	PASS
J3	001	6,711	6,711	75	75	PASS
J4	001	10,000	10,000	75	75	PASS
J4	002	5,123	5,123	75	75	PASS
J5	001	10,000	10,000	75	75	PASS
J5	002	10,000	10,000	75	75	PASS
J5	003	10,000	10,000	75	75	PASS
J5	004	10,000	10,000	75	75	PASS
J5	005	10,000	10,000	75	75	PASS
J5	006	10,000	10,000	75	75	PASS
J5	007	10,000	10,000	75	75	PASS
J5	008	10,000	10,000	75	75	PASS
J5	009	10,000	10,000	75	75	PASS
J5	010	10,000	10,000	75	75	PASS
J5	011	10,000	10,000	75	75	PASS
J5	012	10,000	10,000	75	75	PASS
J5	013	10,000	10,000	75	75	PASS
J5	014	10,000	10,000	75	75	PASS
J5	015	10,000	10,000	75	75	PASS
J5	016	3,557	3,557	75	75	PASS
MK	001	863	863	35	35	PASS
MQ	001	5,044	5,044	75	75	PASS