



**Ernie Fletcher**  
Governor

**LaJuana S. Wilcher, Secretary**  
Environmental and Public  
Protection Cabinet

**Christopher L. Lilly**  
Commissioner  
Department of Public Protection

Ronald Fuller  
Vice President Eng. & Operations  
Jackson Energy Cooperative  
P. O. Box 307  
U. S. Highway 421S  
McKee, KY 40447

Commonwealth of Kentucky  
**Public Service Commission**  
211 Sower Blvd.  
P.O. Box 615  
Frankfort, Kentucky 40602-0615  
Telephone: (502) 564-3940  
Fax: (502) 564-3460  
psc.ky.gov

**Mark David Goss**  
Chairman

**Teresa J. Hill**  
Vice Chairman

**Gregory Coker**  
Commissioner

October 7, 2005

CERTIFICATE OF SERVICE

RE: Case No. 2005-00305  
Jackson Energy Cooperative

I, Beth O'Donnell, Executive Director of the Public Service Commission, hereby certify that the enclosed attested copy of the Commission's Order in the above case was served upon the addressee by U.S. Mail on October 7, 2005.

A handwritten signature in black ink, appearing to read "Beth O'Donnell", written over a horizontal line.

Executive Director

BOD/jc  
Enclosure

COMMONWEALTH OF KENTUCKY  
BEFORE THE PUBLIC SERVICE COMMISSION

In the Matter of:

APPLICATION OF JACKSON ENERGY COOPERATIVE ) FOR A CERTIFICATE OF CONVENIENCE AND ) NECESSITY PURSUANT TO KRS 278.020(1) AND ) 807 KAR 5:001, SECTION 9 AND RELATED SECTIONS, ) AUTHORIZING CERTAIN PROPOSED CONSTRUCTION ) IDENTIFIED AS THE 2005-2007 CONSTRUCTIONWORK ) PLAN )	) CASE NO. ) 2005-00305
--	----------------------------

O R D E R

Jackson Energy Cooperative (“Jackson Energy”) filed its application on July 18, 2005 for a Certificate of Public Convenience and Necessity (“CPCN”) to construct certain improvements and additions to its existing plant at an estimated cost of \$22,341,483. In support of its application Jackson Energy filed its 2005-2007 Work Plan, which describes in detail the improvements and additions to its plant that are required over the next 2 years to serve its load.

Jackson Energy seeks authorization to construct extensions and additions to its plant as follows:

1.	New Services	\$ 5,988,711
2.	Distribution Line Conversions	6,447,250
3.	Substation Equipment	500,000
4.	Transformers and Meters	6,001,602
5.	Service Upgrades	181,900
6.	Sectionalizing	15,800
7.	Regulators	156,000
8.	Pole Replacements	837,750
9.	Lightning Arrester Replacement	425,000
10.	Air Break Switches	450,000
11.	Line Fuse Cutouts	250,000
12.	Security Lights	540,090

13.	SCADA	57,280
14.	AMR	240,100
15.	McKee Warehouse	<u>250,000</u>
TOTAL		\$22,341,483

The proposed construction will enable Jackson Energy to continue to provide adequate and dependable electric service to its customers. The system improvements recommended in this Work Plan will not duplicate existing facilities and are needed to correct voltage problems, improve phase balance, and provide for improved service reliability.

Based on the application, the supporting 2005-2007 Work Plan, and being otherwise sufficiently advised, the Commission finds that the proposed improvements and additions to be constructed by Jackson Energy are necessary to provide adequate, reliable electric service to existing customers and anticipated new customers.

IT IS THEREFORE ORDERED that Jackson Energy is granted a CPCN to construct the facilities described in its 2005-2007 Work Plan.

Done at Frankfort, Kentucky, this 7<sup>th</sup> day of October, 2005.

By the Commission

ATTEST:

  
 Executive Director