



ERNIE FLETCHER
GOVERNOR

ENVIRONMENTAL AND PUBLIC PROTECTION CABINET

TERESA J. HILL
SECRETARY

DEPARTMENT FOR ENVIRONMENTAL PROTECTION

DIVISION OF WATER

14 REILLY ROAD

FRANKFORT, KENTUCKY 40601

www.kentucky.gov

RECEIVED

MAR 02 2007

PUBLIC SERVICE
COMMISSION

February 20, 2007

*Case
2006-00209C
2006-00028*

Mr. Robert C. Moore, Attorney
Hazelrigg & Cox, LLP
P. O. Box 676
Frankfort, KY 40602

Re: Farmdale Wastewater Treatment Plant
Franklin County, Kentucky
Lift station replacement

Dear Mr. Moore:

This letter is in response to your letter of inquiry dated February 8, 2007 and your follow-up letter dated February 16, 2007. The February 16, 2007 letter addressed our previous phone discussions. Based on our phone conversations and the information you provided with your letter, the Division of Water has determined that a construction permit will not be necessary to replace the pump station at Farmdale wastewater treatment plant.

The lift station shall be installed in accordance with the requirements of Regulation 401 KAR 5:005 and Ten States Standards, 1990 Edition.

If we can be of further assistance or should you wish to discuss this correspondence, please do not hesitate to contact me at 502/564-2225, extension 513.

Sincerely,

Harold Sparks

Harold L. Sparks, P.E., Supervisor
Wastewater Facilities Review Section
Facilities Construction Branch
Division of Water

HLS

c: Bob Robards, Public Service Commission

Attachment