

COMMONWEALTH OF KENTUCKY
BEFORE THE PUBLIC SERVICE COMMISSION

RECEIVED

DEC 04 2006

PUBLIC SERVICE
COMMISSION

IN THE MATTER OF:

In the Matter of:

APPLICATION OF FARMDALE DEVELOPMENT)
CORPORATION FOR A CERTIFICATE OF)
CONVENIENCE AND NECESSITY, AUTHORITY)
TO MAKE REPAIRS AND SURCHARGE FOR SAME)

CASE NO. 2006-00209

NOTICE OF FILING


Comes the Applicant, Farmdale Development Corporation ("Farmdale"), by counsel, and pursuant to the direction of the Honorable Howell Brady, Jr., Hearing Officer at the October 26, 2006 Hearing conducted in the above-styled case, hereby files the additional quotes of the cost of the Remote Lift Station (uninstalled) that is the subject of this Application.

1) The September 27, 2005 quote provided by Smither Consulting Company reflected that the cost to replace the Remote Lift Station is \$30,425.00, which includes the cost to install same. Attached to the quote of Smither Consulting Company is Kentucky Service Company's quote in the amount of \$15,301.00 provided to Smither Consulting Company for the cost of the Remote Lift Station itself, prior to installation. This quote was attached as Attachment A to the Prefiled Testimony of Carroll Cogan. (See Attachment A).

2) The November 22, 2006 quote provided by D & F Distributors, Inc., for the cost of the Remote Lift Station of \$14,140.00, plus freight costs of \$400.00. This quote did not include the cost to install the Remote Lift Station.

3) The October 11, 2006 quote provided by Staeffler Pump & Supply, Inc., for the cost of the Remote Lift Station of \$14,890.00, plus freight costs. This quote did not include the cost to install the Remote Lift Station.


Respectfully Submitted,



Robert C. Moore
Hazelrigg & Cox, LLP
415 West Main Street, 1st Floor
P.O. Box 676
Frankfort, Kentucky 40602-0676

CERTIFICATE OF SERVICE

I hereby certify that a true and correct copy of the foregoing was served by first class mail, postage prepaid on David Edward Spenard, Assistant Attorney General, 1024 Capital Center Drive, Suite 200, Frankfort, Ky., 40601-8204, and by first class mail, postage prepaid on Beverly J. Hunt, 304 Peachtree Road, Frankfort, Kentucky 40601-8141, Kenny and Marilyn Glass, 223 Briarwood Drive, Frankfort, Kentucky 40601 and Mary Pennington, 210 Cherry Lane, Frankfort, Kentucky 40601, on this the 30th day of November, 2006.



Robert C. Moore

ATTACHMENT A

**Smither Consulting Company
P. O. Box 1077
Louisville, KY 40014**

September 27, 2005

Revised Quote

Mr. Carroll Cogan
Farmdale Utilities
1706 Bardstown Road
Louisville, KY 40205

Re: Farmdale WWTP

Dear Mr. Cogan:

For your information, the following items of repair or replacement need to be considered for the very near future at the referenced facility:

1. The old grating on top of the lift station at the plant is deteriorated to the point that it is unsafe to step on. New grating needs to be installed.

\$1,405.00 Installed

2. The larger plant needs new diffuser drop pipes complete with diffusers. There are fourteen (14) drops in all.

\$4,120.00 Installed

3. The small plant needs to be cleaned, scraped and painted outside and to the water line on the inside.

\$3,050.00

4. The small plant also needs a standby blower motor assembly. If the existing blower, which is quite old, should need repair there would then be nothing to aerate that plant. A new Roots 45 UR4I blower-motor assembly, complete with mounting base, all accessories, duplex control panel and installation would cost

\$9,320.00

5. The existing chlorine contact tank is in very bad condition and needs to be replaced with a new 1700 gallon steel tank.

\$17,225.00 Installed

Note: I would recommend that this be done after the tertiary lagoon is pumped down and cleaned out and before the secondary effluent is routed back into the lagoon.

6. The remote lift station, which consists of a 60" x 10' fiberglass basin, two (2) 5 H.P. 230 volt 3 phase grinder pumps, guide rail assemblies and control panel, is also in very bad condition and needs to be completely replaced.

\$30,425.00

Note: This price includes taking down the fence, removing trees, excavating around the existing station, furnishing the new fiberglass basin, pumps, control panel, taking out the old station, installing the new, making external piping connections, electric connections, back fill, finish grade, and reinstall the fence. Does not include tank truck expense to haul sewage away while station is out of service.

The above pricing is good to the end of 2005. After that some increase may be necessary. Steel prices keep going up and the supplier of the lift station will probably have an increase of about 3 to 4% after the first of the year.

No sales tax has been included.

If you have any questions or need additional information, please let me know.

Sincerely,

Lawrence W. Smither

ATTACHMENT B

PROPOSAL

D & F Distributors, Inc.

914 Ulrich Avenue
Louisville KY 40219

Ph 502-968-0107
Fax 502-968-0538

November 22, 2006

Linda Wood
Covered Bridge Utilities
Louisville, KY

RE: Farndale Subdivision

Dear Linda:

Per your FAX request I am pleased to offer the following for your review:

DUPLEX GRINDER PUMP STATION

Duty Point: unknown

1(one) Duplex submersible sewage grinder pump station composed of the following;

- 2(two) Hydromatic model HPGH500 submersible grinder pumps, 2" discharge. Pumps shall be standard equipped with 25' cord and standard seals. Pump shall be powered by a 230/3/60 3450 RPM oil filled 5 HP motor.
- 1(one) 60" X 120" fiberglass basin with steel cover, junction box and 2" vent.
- 2(two) Quick disconnect rail systems (pre-installed in basin)
- 2(two) lifting chains, galvanized
- 4(four) float switches
- 1(one) Hydromatic duplex control panel with high water alarm light, horn, lightning arrester, seal failure indicator, phase monitor (phase failure protection) and anti-condensation heater. Panel shall be enclosed in NEMA 4X enclosure for wall/post mounting. Panel is for 230/3/30 operation.

Your NET cost excluding freight/taxes.....\$ 14,140.00 each

Estimated freight of \$400.00


Terms of sale are NET 30 days. Delivery of the above items in 4-6 weeks ARO, submittals 1-2 days.

NOTES:

- Pumps are equipped with standard mechanical seals, if carbide mechanical seals are required please add \$ 120.00 per pump (\$240 total)
- Standard power cable lengths are 25'
- Phase monitor is listed in you FAX and is include in above price, if not required please deduct above price by \$250.00
- If exterior mounted run lights and HOA switches are required please add \$ 185.00 to above price.
- If stainless steel chains are required (in lieu of galvanized included above) please add \$200 to above price.
- Start-up is not include in above price.

If you have any questions please let me know.

Sincerely,


Robert K. Embry
Louisville, KY

ATTACHMENT C



Straeffer Pump & Supply, Inc.

Since 1967

October 11, 2006

Ms. Linda Wood
Covered Bridge Utilities
1706 Bardstown Rd.
Louisville, Ky 40205

Straeffer Quote #WHS-14152

Page 1 of 2

Subject: Sewage Lift Station - Fairdale Subdivision
WGH50-23, 5 HP Grinder Pump Station

We are pleased to offer the following factory assembled duplex grinder pump station inclusive of the following equipment.

- Two (2) - Myers WG50H-23-25 grinder pumps, with 25' of power and control cord; double mechanical carbon/ceramic seals with seal leak feature; heat sensor on motor winding; and driven by a 5 H.P., 3450 RPM, 3/230 volt oil filled submersible motor.
- One (1) - Myers Basin package, 60 " x 120" fiberglass basin with: anti-floatation collar; RWGB rail system with lift out check valve and all items necessary for guide rail removal of pumps. Basin to include 2" brass shutoff valves with extension handles, stainless steel rail pipe, stainless steel lifting cable, stainless steel float bracket, aluminum hinged cover with 2" mushroom vent, and 2" PVC schedule 80 discharge pipe module (single 2" line exits the basin). Basin to include a junction box where all float and pump cords will be landed.
- One (1) - 4" inlet grommet to be field installed by others on the basin at the desired location.
- Four (4) - Float switches with stabilizing weight.
- One (1) - Duplex control panel, pre-wired in NEMA 4X fiberglass outdoor rated enclosure with: alarm light, IEC rated starters, seal failure and pump running lights, HOA switches, alternator selector switch, overload relays, primary & control fuse blocks, alarm test switch, alternator lead-lag switch, condensation heater with thermostat, and UL label. Panel will also include a 4 float level system control, and phase monitor. Panel is remote mounted - wall mount type enclosure (mounted by others).

Your cost F.O.B. Shipping Point (freight excluded).....14,890.00

NOTES:

1. We **EXCLUDE** the following equipment: startup services (see note 3); freight; installation, electrical conduit and wire; nothing on service pole; spare parts; and pressure gauges.
2. Estimated delivery on this equipment, 4-6 weeks after receipt of approved shop drawings. Please allow 2-4 weeks for shop drawing completion if required.
3. Start-up services are excluded in the quoted price. If start-up services are required, please add \$500. per trip. Please notify our service department 2-3 weeks before startup event to schedule.
4. The design conditions are missing. We have quoted a pump model whose performance is closest to Ebara model given to us.
5. Concrete required to properly anchor the basin (to prevent flotation) is excluded. The pumps will NOT ship inside the basin to prevent damage. Thus, these need to be installed in the field. Likewise, the floats are not hung on the float bracket and will need to be field installed.
6. **MYERS published 5 year prorated warranty applies.**
7. **VALUE ADDED CONSIDERATIONS:** Note that we include a hinged aluminum cover which is non corrosive whereas our competition has quoted steel which is corrosive. We also include stainless steel guide rail pipes. Our competition did not indicate the alloy of their guide rail pipes. Finally, our pumps carry a 5 year prorated warranty versus Ebara one year.

Our terms with approved credit are net 30 days with 1.5% interest per month added to past due accounts, as well as all costs and expenses incurred in collecting any amounts due, including reasonable attorney's and collection fees. We also accept, for your convenience, MasterCard, Visa, Discover, and American Express credit cards.

All taxes are excluded from our prices and must be added if applicable. Our price is protected for 30 days from the quote date. If a letter of intent is issued during the 30 days, we will hold our prices for an additional 45 days.

We appreciate the opportunity of offering you this proposal. If questions arise, please feel free to contact us.

Sincerely yours,
STRAEFFER PUMP & SUPPLY, INC.

W. H. Straefffer
President

cc: Scott Kuhn is your regional outside sales engineer. Feel free to contact him at 859-333-3365 cell