

RECEIVED

AUG 23 2007  
PUBLIC SERVICE  
COMMISSION

August 23, 2007

Ms. Elizabeth O'Donnell  
Executive Director  
Commonwealth of Kentucky  
Public Service Commission  
211 Sower Boulevard  
PO Box 615  
Frankfort, KY 40602-0615


RE: The Application of East Kentucky Power Cooperative, Inc. for a  
Certificate of Public Convenience and Necessity for the construction  
Of a 345 kV Electric Transmission Project in Clark, Madison, and Garrard  
Counties, Kentucky. PSC Case No. 2006-00463

Dear Ms. O'Donnell:

Enclosed please find an original and ten (10) complete paper copies of EKPC's Second  
Amendment to Application in the above referenced case.

Should you have any questions, please feel free to contact me. Thank you for your  
assistance.

Very truly yours,



Sherman Goodpaster III  
Senior Corporate Counsel

SG/ti

**COMMONWEALTH OF KENTUCKY**  
**BEFORE THE PUBLIC SERVICE COMMISSION**

RECEIVED  
AUG 23 2007  
PUBLIC SERVICE  
COMMISSION

In the Matter of:

THE APPLICATION OF EAST KENTUCKY POWER )  
COOPERATIVE, INC. FOR A CERTIFICATE OF )  
PUBLIC CONVENIENCE AND NECESSITY FOR ) **CASE NO**  
THE CONSTRUCTION OF A 345 kV ELECTRIC ) **2006-00463**  
TRANSMISSION PROJECT IN CLARK, MADISON, )  
AND GARRARD COUNTIES, KENTUCKY )

**SECOND AMENDMENT TO APPLICATION**

The Applicant, East Kentucky Power Cooperative, Inc., hereby amends Exhibit 8.07 to its Original Application filed herein on May 22, 2007, by superceding such exhibit with Exhibit 8.07 Revised as attached hereto.

It is necessary to revise Exhibit 8.07 because it is necessary to increase the centerline to centerline separation on a portion of the co-located sections of the Project from the seventy-five (75) feet as depicted on the original Exhibit 8.07 to as much as one hundred and twenty five (125) feet as shown on Exhibit 8.07 Revised. During the design process it was discovered that due to blow-out calculations, as per the 2007 National Electric Safety Code, RUS, and EKPC Design Standards, the original separation of seventy-five (75) feet was too close in some areas to avoid conductor-to-structure contact during certain high wind conditions. The proposed centerline displayed on the Exhibit 8.07 Revised varies in distance, from seventy five (75) to one hundred twenty five (125) feet from the existing centerline in order to meet these safety and design standards. No

properties other than those identified on Exhibit 14 to the Original Application were affected.

The Applicant hereby adopts, restates and reiterates each and every other paragraph, statement and Exhibit contained in its Original Application.

Respectfully submitted,


DAVID A. SMART



SHERMAN GOODPASTER III  
ROGER R. COWDEN  
ATTORNEYS FOR EAST KENTUCKY  
POWER COOPERATIVE, INC.  
PO BOX 707  
WINCHESTER, KY 40392-0707  
859-744-4812

### **CERTIFICATE OF SERVICE**

This is to certify that an original and 10 copies of the foregoing Second Amendment to Application in the above-styled case were hand delivered to the office of the Public Service Commission, 211 Sower Boulevard, Frankfort, Kentucky 40601, and one copy was mailed to each party of record, this 23rd day of August, 2007.




SHERMAN GOODPASTER III

VERIFICATION

STATE OF KENTUCKY    )  
  ) SCT.  
COUNTY OF CLARK     )

The affiant, Mary Jane Warner, states that she is the Manager of Power Delivery Expansion for the Plaintiff, East Kentucky Power Cooperative, Inc., and that this affiant has read the foregoing Second Amended Application and that the statements contained therein are true to the best of her knowledge and belief.

  
\_\_\_\_\_  
MARY JANE WARNER

Subscribed and sworn to before me in the aforesaid state and county by  
Mary Jane Warner this the 23<sup>rd</sup> day of August 2007.

My notarial commission expires: 12/20/08

  
\_\_\_\_\_  
NOTARY PUBLIC, KY  
STATE-AT-LARGE.