

Rattlesnake Ridge Water District

Serving Areas of Carter, Elliott and Lawrence Counties

P.O. Box 475, Grayson, Kentucky 41143-0475

Phone (606) 474-7570, Fax (606) 474-8531

E-Mail: rrwd@windstream.net

February 16, 2009

RECEIVED

FEB 18 2009

PUBLIC SERVICE
COMMISSION

Mr. Brent Kirtley
Tariff Branch Manager
KY Public Service Commission
P. O. Box 615
Frankfort, KY 40602

Dear Mr. Kirtley:

RE: Case No. 2007-00484

Enclosed please find corrected pages 8 and 12 of our Rate Increase Request.
If you have any questions or need additional information, please contact me.

Sincerely,



Chris Stamper
Office Manager

RATTLESNAKE RIDGE WATER DISTRICT
(Name of Utility)

RULES AND REGULATIONS

any underpayment and shall refund any overpayment by check or credit to the customer's bill. No refund will be made if the customer's bill is delinquent at the time of the recalculation.

Upon the payment of such deposits, the District shall issue to such customer a certificate of deposit, showing the name of the customer, the location of the initial premises occupied by the customer, and the date and amount of the deposit.

- H. All meters shall be installed, renewed, and maintained at the expense of the District, and the District reserves the right to determine the size and type of meter used.

- I. It shall be the policy of the District to test each water meter in accordance with 807 KAR 5:066, Section 16. In addition, upon written request of any customer, the meter serving such customer shall be tested by the District. Such test will be made without charge to the customer if the meter has not been tested within 12 months preceding the requested test; otherwise, a charge of \$50.00 will be assessed if the test shows the meter less than two (2) percent fast.

If a meter is inaccurate in excess of 2%, whether upon periodic testing or upon requested testing, additional tests shall be made at once to determine the average error of the meter, and the adjustment shall be made in the customer's water bills as follows:

- 1. If the result of such tests shows an average error greater than 2% fast, the customer's bill for the period during which the meter error is known to have existed shall be recomputed and the account adjusted on the basis of the test. If the period during which the meter error existed cannot be determined, the customer's bill shall be recomputed on one-half (1/2) of the elapsed time since the last previous test, but in no event to exceed 12 months; provided, however, that if time for the periodic test has overrun to the extent of 1/2 of the time elapsed since the last previous test exceed 12 months, the refund shall be for 12 months, specified above, plus those months exceeding the periodic test period; provided, further, that such refund may be limited to the 12 month period if failure to make the periodic test was due to causes beyond the control of the District.

DATE OF ISSUE MARCH 12, 2008
MONTH/DATE/YEAR

DATE EFFECTIVE JANUARY 1, 2008
MONTH/DATE/YEAR

ISSUE BY Billy A. Dillett
TITLE CHAIRMAN

BY AUTHORITY OF ORDER OF THE PUBLIC SERVICE COMMISSION
In case no. 2007-00484 DATED MARCH 7, 2008

RATTLESNAKE RIDGE WATER DISTRICT
(Name of Utility)

RULES AND REGULATIONS

4. As a service to the public within its service area and for the protection of the public welfare, the Water District will furnish water to fight a fire from a fire hydrant connected directly to the Water District's water main at each fire location free of charge for a period not to exceed a total of 4 hours of usage – as defined below in Section V-8-b. In the event that more than 4 hours of usage occurs in fighting a fire, the owner of the property where the fire occurs shall pay for all of the water used in excess of 4 hours of usage, in accordance with the Water District's standard water rate as in effect on the date of the fire and approved by the PSC.
5. Fire hydrants shall not be used by any contractor, property owner, governmental agency, individual, corporation, or others to secure water for any purpose. The use of a fire hydrant by anyone other than properly authorized fire department personnel for fighting a fire shall be considered a "theft of service" and prosecuted in accordance with the laws of the Commonwealth of Kentucky. The user shall pay the Water District for, any damages to the Water District's property, and the full cost of the services fraudulently obtained along with all other applicable costs of the Water District allowed under the laws of the Commonwealth of Kentucky. If the Water District is required to inspect a fire hydrant or otherwise investigate improper use of a fire hydrant and a user is found to have used water from a fire hydrant for improper purposes, the user shall also be assessed a special investigation charge of \$45.
6. The fire departments utilizing fire hydrants connected to the Water District's water main shall maintain a record of any water used, including the date, location, the time that the fire department began pumping water, the time that the fire department discontinued pumping water, the approximate rate(s) of flow, the length of any interruptions in pumping water, the causes of the fire, and property owner for whom the water was used and shall file a report with the Water District monthly. The record of the fire department in conjunction with the Water District's daily master meter readings and normal daily water usage for the service zone will be used in determining the amount of water used to fight a fire. Any fire department that fails to submit its monthly report for water usage as required by this rule shall be assessed a penalty of \$100.00 for each failure.
7. The District does not guarantee a water supply including the supply to the Customer's fire protection system at any particular flow rate or pressure. The fire flow may vary depending on other water demands on the system, various water facility limitations, or other circumstances (including but not

DATE OF ISSUE MARCH 12, 2008
MONTH/DATE/YEAR

DATE EFFECTIVE JANUARY 1, 2008
MONTH/DATE/YEAR

ISSUE BY Bobby A. Elliott

TITLE CHAIRMAN

BY AUTHORITY OF ORDER OF THE PUBLIC SERVICE COMMISSION

In case no. 007-00484 DATED MARCH 7, 2008