



RECEIVED

FEB 13 2009

PUBLIC SERVICE
COMMISSION

February 13, 2009

Mr. Jeff Derouen
Executive Director
Public Service Commission
211 Sower Boulevard
Frankfort, Kentucky 40602

HAND DELIVERED

Re: PSC Case No. 2008-00409

Dear Mr. Derouen:

On February 6, 2009, East Kentucky Power Cooperative, Inc. ("EKPC") filed with the Commission in the above-referenced case an original and ten copies of the responses of EKPC to the Commission Staff's Third Data Request, dated January 23, 2009. Also on February 6, 2009, EKPC filed an original and ten redacted copies of EKPC's Responses to the Second Data Request of Kentucky Industrial Utility Customers, Inc. ("KIUC"), and an original and ten copies of the Supplemental Data Request of the Attorney General ("AG"), both dated January 23, 2009.

The response to Request 9 of Commission Staff's Third Data Request contained an error on the Attachment, Page 1 of 1. The "Annual Fixed O&M Expenses" line reflected \$6.5 per kW; this line should reflect \$16.5 per kW. An original and ten copies of the corrected Attachment are enclosed. Please note that this did not change the substance of the response, meaning the "Monthly Cost" of \$4.30 per kW is accurate.

Very truly yours,

A handwritten signature in black ink that reads "Ann F. Wood".

Ann F. Wood
Manager, Regulatory Services

Enclosures

Cc: Parties of Record

Seelye Exhibit 8

East Kentucky Power Cooperative, Inc.
Avoided Cost Estimate of Interruptible Power

Estimated Installed Cost of a CT	\$ 550	per kW
Estimated Cost of Capital	4.00%	
Depreciation	4.00%	
ASL for CT	25	Years
Annual Capacity Cost	\$35.21	per kW
Annual Fixed O&M Expenses	\$16.50	per kW
Total Annual Cost	\$51.71	per kW
Monthly Cost	\$4.30	per kW