



Mr. Jeff Derouen
Executive Director
Kentucky Public Service Commission
211 Sower Boulevard
Frankfort, KY 40602

RECEIVED

MAR 16 2009

**PUBLIC SERVICE
COMMISSION**

Kentucky Utilities Company
State Regulation and Rates
220 West Main Street
PO Box 32010
Louisville, Kentucky 40232
www.eon-us.com

Robert M. Conroy
Director - Rates
T 502-627-3324
F 502-627-3213
robert.conroy@eon-us.com

March 16, 2009

**RE: *AN EXAMINATION OF THE APPLICATION OF THE FUEL
ADJUSTMENT CLAUSE OF KENTUCKY UTILITIES COMPANY
FROM NOVEMBER 1, 2006 THROUGH OCTOBER 31, 2008
CASE NO. 2008-00520***

Dear Mr. Derouen:

On February 11, 2009, Kentucky Utilities Company (“KU”) filed its Response to the Information Requested in Appendix B of the Commission’s Order dated January 23, 2009, in the above-referenced matter.


Since the filing on February 11, it has been discovered that pages 3, 14, 15, and 20 of KU’s Response to Question No. 14, which contain scheduled, actual and forced outages for E. W. Brown Unit 3, Ghent Unit 4, Green River Unit 3, and Tyrone Unit 3, respectively, for the period May 2008 through October 2008, inadvertently contained incorrect scheduled dates and length of duration. The error occurs only for the month of May for Brown Unit 3, Green River Unit 3, and Tyrone Unit 3. The error occurs only for the month of June for Ghent Unit 4.

Enclosed are an original and five copies of revised pages 3, 14, 15, and 20 of KU’s response to Question No. 14 reflecting the correct duration data.

Mr. Jeff Derouen
Executive Director
Kentucky Public Service Commission
March 16, 2009
Page Two

Should you have any questions concerning the enclosed, please contact me at your convenience.

Sincerely,

A handwritten signature in black ink, appearing to read "R. M. Conroy". The signature is stylized with a large, looped "C" at the end and a horizontal line crossing through the middle of the letters.


Robert M. Conroy

Enclosures


VERIFICATION

COMMONWEALTH OF KENTUCKY)
) SS:
COUNTY OF JEFFERSON)

The undersigned, **Frederick D. Jackson**, being duly sworn, deposes and says that he is the Director of Generation Services for E.ON U.S. Services Inc., that he has personal knowledge of the matters set forth in the responses for which he is identified as the witness, and the answers contained therein are true and correct to the best of his information, knowledge and belief.


FREDERICK D. JACKSON

Subscribed and sworn to before me, a Notary Public in and before said County and State, this 16th day of March 2009.


(SEAL)
Notary Public

My Commission Expires:
Sept 20, 2010

Kentucky Utilities Company
 E. W. Brown Unit 3 - Coal - 429 MW
 May 2008 through October 2008

Schedule vs. Actual

MONTH	MAINTENANCE				REASON FOR DEVIATION FROM SCHEDULED MAINTENANCE OR REASON FOR FORCED OUTAGE AS APPROPRIATE		
	Scheduled		Actual		HOURS OF DURATION		
	FROM	TO	FROM	TO	Scheduled	Actual	
May	S	5/11/2008 15:00	5/11/2008 10:15	255:00	250:15	Boiler inspection	
Jun	S	6/21/2008 23:42	6/22/2008 23:16	23:34	23:34	Deaerator	
Jul	No Outages > or = 6 Hours						
Aug	F		8/15/2008 3:41	8/16/2008 7:05	27:24	Turbine hydraulic system pipes and valves	
	F		8/16/2008 10:35	8/16/2008 19:39	9:04	Turbine hydraulic system pipes and valves	
Sep	No Outages > or = 6 Hours						
Oct	No Outages > or = 6 Hours						

Kentucky Utilities Company
 Ghent Unit 4 - Coal - 493 MW
 May 2008 through October 2008

Schedule vs. Actual

MONTH	MAINTENANCE				HOURS OF DURATION		REASON FOR DEVIATION FROM SCHEDULED MAINTENANCE OR REASON FOR FORCED OUTAGE AS APPROPRIATE
	Scheduled		Actual		Scheduled	Actual	
	FROM	TO	FROM	TO	Forced	Actual	
May	→	→	→	→	744:00	744:00	Major turbine overhaul
Jun	→	6/8/2008 15:00	→	6/2/2008 21:40	183:00	45:40	Major turbine overhaul
Jul	F		7/5/2008 20:20	7/8/2008 23:51		75:31	First reheater leaks
Aug	No Outages > or = 6 Hours						
Sep	No Outages > or = 6 Hours						
Oct	S	10/3/2008 21:59	10/6/2008 3:50	10/3/2008 21:59	53:51	53:51	Induced draft fan motors and drives
	S	10/11/2008 7:00	10/12/2008 6:41	10/11/2008 7:00	23:41	23:41	Air heater

Report dates of forced outage in columns headed Actual

Kentucky Utilities Company
 Green River Unit 3 - Coal - 68 MW
 May 2008 through October 2008

Schedule vs. Actual

MONTH	MAINTENANCE				REASON FOR DEVIATION FROM SCHEDULED MAINTENANCE OR REASON FOR FORCED OUTAGE AS APPROPRIATE			
	Scheduled		Actual		HOURS OF DURATION			
	FROM	TO	FROM	TO	Scheduled	Actual		
May	S	5/10/2008 0:00	6/1/2008 15:00	5/9/2008 22:55	5/25/2008 9:15	543:00	370:20	Minor boiler overhaul
	F			5/26/2008 15:53	5/27/2008 1:24	9:31	9:31	Boiler feed pump
	F			5/28/2008 3:47	5/29/2008 12:04	32:17	32:17	Induced draft fan motors and drives
	F			5/29/2008 17:40	5/30/2008 5:44	12:04	12:04	Throttle valve
	S	5/31/2008 21:50	→	5/31/2008 21:50	→	2:10	2:10	Main steam relief/safety valves off superheater
Jun	S	→	6/1/2008 14:14	→	6/1/2008 14:14	14:14	14:14	Main steam relief/safety valves off superheater
	F			6/11/2008 1:43	6/11/2008 14:32	12:49	12:49	Condenser loss of vacuum
Jul	F			7/28/2008 8:00	7/30/2008 6:36	46:36	46:36	Boiler tube waterwall leak
Aug	F			8/25/2008 0:35	8/27/2008 11:24	58:49	58:49	Boiler tube waterwall leak
Sep	F			9/2/2008 22:39	9/4/2008 5:00	30:21	30:21	Boiler tube waterwall leak
	S	9/27/2008 8:02	9/27/2008 22:20	9/27/2008 8:02	9/27/2008 22:20	14:18	14:18	Induced draft fan fouling
Oct	F			10/6/2008 7:47	10/7/2008 23:15	39:28	39:28	First superheater leaks
	F			10/11/2008 10:29	10/12/2008 11:24	24:55	24:55	Second superheater leaks
	S	10/20/2008 7:30	10/20/2008 19:00	10/20/2008 7:30	10/20/2008 19:00	11:30	11:30	Circulating water valves
	S	10/21/2008 9:07	10/21/2008 16:40	10/21/2008 9:07	10/21/2008 16:40	7:33	7:33	Circulating water valves
	S	10/24/2008 8:20	10/24/2008 14:40	10/24/2008 8:20	10/24/2008 14:40	6:20	6:20	Feedwater valves

Kentucky Utilities Company
 Tyrone Unit 3 - Coal - 71 MW
 May 2008 through October 2008

Schedule vs. Actual

MONTH	MAINTENANCE				HOURS OF DURATION		REASON FOR DEVIATION FROM SCHEDULED MAINTENANCE OR REASON FOR FORCED OUTAGE AS APPROPRIATE
	Scheduled FROM	Scheduled TO	Actual FROM	Actual TO	Scheduled	Actual	
May	S	5/10/2008 0:00	6/1/2008 15:00	5/2/2008 22:44	5/31/2008 13:18	543:00	686:34 Pulverizer overhaul
F			5/31/2008 13:37			10:23	Turbine governing system
Jun	F			6/4/2008 9:04		81:04	Turbine governing system
F			6/4/2008 9:38	6/6/2008 1:48		40:10	Turbine main stop valves
F			6/6/2008 4:55	6/8/2008 17:34		60:39	Feedwater chemistry
Jul							
Aug							
Sep	F			9/3/2008 7:54	9/5/2008 8:30	48:36	Turbine lube oil coolers
F			9/8/2008 5:47	9/10/2008 15:58		58:11	Main steam system
F			9/11/2008 10:20	9/12/2008 16:37		30:17	Main steam system
Oct	F		10/13/2008 16:15	10/14/2008 4:50		12:35	Forced draft fans

Report dates of forced outage in columns headed Actual