



139 East Fourth Street, R. 25 At II
P.O. Box 960
Cincinnati, Ohio 45201-0960
Tel: 513-419-1837
Fax: 513-419-1846
dianne.kuhnell@duke-energy.com

Dianne B. Kuhnell
Senior Paralegal

VIA OVERNIGHT DELIVERY

March 15, 2010

RECEIVED

MAR 16 2010

PUBLIC SERVICE
COMMISSION

Mr. Jeff Derouen
Executive Director
Kentucky Public Service Commission
211 Sower Blvd.
Frankfort, KY 40601

Re: Case No. 2009-509

Dear Mr. Derouen:

Enclosed please find an original and twelve copies of Duke Energy Kentucky Inc.'s Supplemental Response to Staff's First Set of Data Requests STAFF-DR-01-007 in the above captioned case.

The supplemental attachments to this data request were inadvertently omitted in our original responses sent to the Commission February 16, 2010.

Please date-stamp the two copies of the letter and the filings and return to me in the enclosed envelope.


Sincerely,

Dianne B. Kuhnell
Senior Paralegal

VERIFICATION

STATE OF OHIO)
) SS:
COUNTY OF HAMILTON)

The undersigned, John D. Swez, being duly sworn, deposes and says that he is employed by the Duke Energy Corporation affiliated companies as Director, Bulk Power Marketing and Trading for Duke Energy Business Services, LLC; that on behalf of Duke Energy Kentucky, Inc., he has supervised the preparation of the responses to the foregoing information requests; and that the matters set forth in the foregoing supplemental response to information requests are true and accurate to the best of his knowledge, information and belief after reasonable inquiry.


John D. Swez

Subscribed and sworn to before me by John D. Swez on this 15th day of March, 2010.


NOTARY PUBLIC

My Commission Expires:



ANITA M. SCHAFER
Notary Public, State of Ohio
My Commission Expires
November 4, 2014

Duke Energy Kentucky, Inc.
Case No. 2009-00509
First Set Staff Data Requests
Date Received: January 27, 2010

STAFF-DR-01-007 SUPPLEMENTAL

REQUEST:

List Duke Kentucky's scheduled, actual, and forced outages from May 1, 2009 through October 31, 2009.

RESPONSE:

See Attachment STAFF-DR-01-001 Supplemental.

PERSON RESPONSIBLE: John Swez

Duke Kentucky
 East Bend Unit 2
 May 2009 - Oct 2009

MONTH	MAINTENANCE		HOURS OF DURATION		REASON FOR DEVIATION FROM SCHEDULED MAINTENANCE OR REASON FOR FORCED OUTAGE AS APPROPRIATE
	FROM	TO	Scheduled	Actual	
May	4/24/2009	5/19/2009	583.97	583.97	2009 Spring Planned Outage Repair #5 Governor Valve Leak, In Tandem with PO Runback of Unit During DCS Upgrade 2-4 Mill Tripped Causing Furnace Pressure Swing Secondary Air Heater Plenum Pressure High
	5/19/2009	5/22/2009	85.97	85.97	
	5/24/2009	5/24/2009		4.55	
	5/27/2009	5/27/2009		2.87	
Jun	5/27/2009	5/27/2009		0.98	Repair Waterwall Tube Leaks Boiler Feed Pump Tripped During Test of Oil Pump
	6/11/2009	6/16/2009	101.15	101.15	
Jul					
Aug	8/28/2009	8/31/2009	71.80	71.80	Repair Reheat Tube Leak
Sep					
Oct					

Duke Kentucky
 Miami Fort 6
 May 2009 - Oct 2009

MONTH	MAINTENANCE		HOURS OF DURATION			REASON FOR DEVIATION FROM SCHEDULED MAINTENANCE OR REASON FOR FORCED OUTAGE AS APPROPRIATE
	FROM	TO	Actual	Scheduled	Actual	
				Forced	Actual	
May						
Jun	6/11/2009	6/15/2009		99.13		Repair Boiler Tube Leak
Jul	7/19/2009	7/21/2009		34.38		Repair Boiler Tube Leak
	7/21/2009	7/23/2009	55.53		55.53	Clean Condenser
Aug	8/25/2009	8/27/2009		51.13		Repair Boiler Tube Leak
	8/27/2009	8/31/2009	110.98		110.98	Apply Coating to Waterwall Tubes
Sep	9/1/2009	9/1/2009	4.57		4.57	Apply Coating to Waterwall Tubes
Oct	10/20/2009	10/23/2009	61.75		61.75	Repair Boiler Tube Leak