



**KEYED NOTES**

- 1 REMOVE EXISTING 12" DIA. BUTTERFLY VALVE. INSTALL NEW 12" DIA. BUTTERFLY VALVE WITH ELECTRIC OPERATOR (TYP. OF 3 EACH)
  - 2 REMOVE EXISTING 8" DIA. BUTTERFLY VALVE. INSTALL NEW 8" DIA. BUTTERFLY VALVE WITH ELECTRIC OPERATOR (TYP. OF 3 EACH)
  - 3 REMOVE EXISTING 24" DIA. BUTTERFLY VALVE. INSTALL NEW 24" DIA. BUTTERFLY VALVE WITH ELECTRIC OPERATOR (TYP. OF 3 EACH)
- ALL EXISTING PIPING AND NEW VALVES SHALL BE PAINTED IN THE PIPE GALLERY USING THE FOLLOWING COLORS:
- RAW WATER LINE - MEDIUM BLUE
  - BACKWASH SUPPLY LINE - LIGHT GRAY
  - BACKWASH WASTE LINE - LIGHT BROWN
  - REWASH WASTE LINE - DARK BLUE
  - FINISH WATER LINE - DARK BLUE
  - AIR SUPPLY LINE - DARK GREEN

**PLAN**  
3/16" = 1'-0"  
PROJECT NORTH

FOR CONTINUATION  
SEE DWG MP-D-131

FILENAME: MP-AD-001.dwg PLOT DATE: Dec 08, 2009



NO.	DATE	REVISION	BY	APVD

ADVANCED TREATMENT  
MEMORIAL PARKWAY TREATMENT PLANT  
NORTHERN KENTUCKY WATER DISTRICT  
FORT THOMAS, KENTUCKY

**CH2MHILL HDR**

PROCESS MECHANICAL  
FILTER BUILDING  
PLAN

AS NOTED
VERIFY SCALE
BARS ONE INCH ON ORIGINAL DRAWING.
DATE 12/08/09
PROJ 380723
DWG MP-AD-001
SHEET 168