

Balanced Voltage Drop Report
Source: Millers Creek

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
Millers Creek		ABC	SRC-Miller	7.50Y	125.0	0.00	0.00	266.62	0	5698	1876	95	0.00	0.0	0.000	0.000	0	0	0	1414
PL.20516	Millers Creek	ABC	336 MCM AC	7.50Y	125.0	0.00	0.00	81.87	16	1753	565	95	0.04	0.0	0.007	0.007	0	0	0	458
PL.28003	PL.20516	ABC	336 MCM AC	7.50Y	125.0	0.00	0.01	81.87	16	1753	565	95	0.01	0.0	0.008	0.002	0	0	0	458
----- Feeder No. 3 (Pryce F3) Beginning with Device PD.3873 -----																				
PD.3873	PL.28003	ABC	200VWE	7.50Y	125.0	0.00	0.01	81.87	0	1753	565	95	0.00	0.0	0.008	0.002	0	0	0	458
PL.28004	PD.3873	ABC	336 MCM AC	7.50Y	125.0	0.00	0.01	81.87	16	1753	565	95	0.03	0.0	0.013	0.005	0	0	0	458
PL.20770	PL.28004	ABC	336 MCM AC	7.50Y	124.9	0.06	0.07	81.87	16	1753	565	95	0.54	0.0	0.110	0.096	0	0	0	458
PL.21218	PL.20770	A	#1/0 ACSR	7.50Y	124.9	0.00	0.07	0.00	0	0	0	100	0.00	0.0	0.114	0.005	0	0	0	0
PD.3030	PL.21218	A	50T	7.50Y	124.9	0.00	0.07	0.00	0	0	0	100	0.00	0.0	0.114	0.005	0	0	0	0
PL.21217	PD.3030	A	#1/0 ACSR	7.50Y	124.9	0.00	0.07	0.00	0	0	0	100	0.00	0.0	0.143	0.029	0	0	0	0
PL.20771	PL.20770	ABC	336 MCM AC	7.49Y	124.9	0.07	0.14	81.87	16	1753	564	95	0.58	0.0	0.212	0.103	0	0	0	458
PL.20827	PL.20771	ABC	336 MCM AC	7.49Y	124.8	0.06	0.20	81.87	16	1752	562	95	0.56	0.0	0.312	0.099	0	0	0	458
PL.19885	PL.20827	B	6 A (CWC)	7.49Y	124.8	0.01	0.21	1.59	1	11	3	96	0.00	0.0	0.427	0.115	0	0	0	2
PL.21215	PL.19885	B	6 A (CWC)	7.49Y	124.8	0.00	0.21	1.59	1	11	3	96	0.00	0.0	0.432	0.005	0	0	0	2
PD.3029	PL.21215	B	50T	7.49Y	124.8	0.00	0.21	1.59	0	11	3	96	0.00	0.0	0.432	0.005	0	0	0	2
PL.21216	PD.3029	B	6 A (CWC)	7.49Y	124.8	0.01	0.21	1.59	1	11	3	96	0.00	0.0	0.524	0.093	0	0	0	2
PL.20828	PL.21216	B	6 A (CWC)	7.49Y	124.8	0.01	0.22	1.59	1	11	3	96	0.00	0.0	0.634	0.109	0	0	0	2
PL.20829	PL.20828	B	6 A (CWC)	7.49Y	124.8	0.01	0.24	1.59	1	11	3	96	0.00	0.0	0.814	0.181	0	0	0	2
PL.21142	PL.20829	B	6 A (CWC)	7.49Y	124.8	0.00	0.24	1.59	1	11	3	96	0.00	0.0	0.846	0.032	0	0	1	2
PL.21143	PL.21142	B	6 A (CWC)	7.49Y	124.8	0.00	0.24	1.59	1	11	3	96	0.00	0.0	0.937	0.091	11	3	1	1
PL.20772	PL.20827	ABC	336 MCM AC	7.49Y	124.8	0.04	0.24	81.34	16	1740	558	95	0.34	0.0	0.373	0.061	0	0	0	456
PL.19886	PL.20772	ABC	336 MCM AC	7.48Y	124.7	0.04	0.28	81.34	16	1740	557	95	0.33	0.0	0.433	0.060	0	0	0	456
PL.20773	PL.19886	ABC	336 MCM AC	7.48Y	124.7	0.03	0.31	81.34	16	1739	556	95	0.27	0.0	0.481	0.048	0	0	0	456
PL.20774	PL.20773	ABC	336 MCM AC	7.48Y	124.6	0.10	0.41	81.34	16	1739	556	95	0.89	0.1	0.642	0.161	0	0	0	456
PL.21135	PL.20774	ABC	336 MCM AC	7.47Y	124.6	0.04	0.44	81.34	16	1738	554	95	0.31	0.0	0.698	0.056	0	0	0	456
PL.21136	PL.21135	ABC	336 MCM AC	7.47Y	124.5	0.07	0.52	81.34	16	1738	553	95	0.65	0.0	0.815	0.116	0	0	0	456
PL.19887	PL.21136	ABC	336 MCM AC	7.47Y	124.4	0.06	0.58	81.34	16	1737	551	95	0.52	0.0	0.908	0.094	0	0	0	456
PL.20518	PL.19887	C	#1/0 ACSR	7.47Y	124.4	0.00	0.58	0.62	0	4	1	97	0.00	0.0	0.962	0.054	0	0	0	1
PL.21213	PL.20518	C	#1/0 ACSR	7.47Y	124.4	0.00	0.58	0.62	0	4	1	97	0.00	0.0	0.967	0.005	0	0	0	1
PD.3028	PL.21213	C	50T	7.47Y	124.4	0.00	0.58	0.62	0	4	1	97	0.00	0.0	0.967	0.005	0	0	0	1

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Millers Creek

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru

PL.21214	PD.3028	C	#1/0 ACSR	7.47Y	124.4	0.00	0.58	0.62	0	4	1	97	0.00	0.0	1.017	0.051	4	1	1	1
PL.20775	PL.19887	ABC	336 MCM AC	7.46Y	124.4	0.04	0.62	80.67	16	1722	546	95	0.36	0.0	0.974	0.066	0	0	0	453
PL.20520	PL.20775	ABC	336 MCM AC	7.46Y	124.3	0.07	0.69	80.67	16	1722	545	95	0.60	0.0	1.084	0.110	0	0	0	453
PL.20831	PL.20520	ABC	336 MCM AC	7.45Y	124.2	0.10	0.79	80.67	16	1721	544	95	0.87	0.1	1.243	0.159	0	0	0	453
PL.20832	PL.20831	ABC	336 MCM AC	7.45Y	124.1	0.09	0.88	80.67	16	1720	542	95	0.79	0.0	1.387	0.145	0	0	0	453
PL.20833	PL.20832	ABC	336 MCM AC	7.44Y	124.1	0.05	0.93	80.67	16	1720	540	95	0.43	0.0	1.467	0.079	0	0	0	453
PL.20521	PL.20833	B	#1/0 ACSR	7.44Y	124.1	0.00	0.93	0.18	0	1	0	100	0.00	0.0	1.495	0.029	0	0	0	1
PL.21207	PL.20521	B	#1/0 ACSR	7.44Y	124.1	0.00	0.93	0.18	0	1	0	100	0.00	0.0	1.500	0.005	0	0	0	1
PD.3025	PL.21207	B	50T	7.44Y	124.1	0.00	0.93	0.18	0	1	0	100	0.00	0.0	1.500	0.005	0	0	0	1
PL.21208	PD.3025	B	#1/0 ACSR	7.44Y	124.1	0.00	0.93	0.18	0	1	0	100	0.00	0.0	1.593	0.094	1	0	1	1
PL.20914	PL.20833	ABC	336 MCM AC	7.44Y	124.0	0.06	0.99	80.61	16	1718	539	95	0.55	0.0	1.568	0.102	5	1	2	452
PL.21130	PL.20914	ABC	336 MCM AC	7.44Y	124.0	0.02	1.01	79.03	15	1683	528	95	0.21	0.0	1.607	0.039	0	0	1	444
PL.21131	PL.21130	ABC	336 MCM AC	7.44Y	124.0	0.02	1.03	79.03	15	1683	527	95	0.17	0.0	1.639	0.032	0	0	0	443
PL.21115	PL.21131	ABC	336 MCM AC	7.43Y	123.9	0.05	1.08	79.03	15	1683	527	95	0.45	0.0	1.724	0.085	0	0	1	443
PL.21116	PL.21115	ABC	336 MCM AC	7.43Y	123.8	0.11	1.20	79.03	15	1682	526	95	0.96	0.1	1.907	0.183	0	0	0	442
PL.20522	PL.21116	ABC	336 MCM AC	7.43Y	123.8	0.04	1.24	79.03	15	1681	524	95	0.37	0.0	1.979	0.071	0	0	0	442
PL.21205	PL.20522	C	6 A (CWC)	7.43Y	123.8	0.00	1.24	0.94	1	7	2	96	0.00	0.0	1.983	0.005	0	0	0	2
PD.3024	PL.21205	C	50T	7.43Y	123.8	0.00	1.24	0.94	0	7	2	96	0.00	0.0	1.983	0.005	0	0	0	2
PL.21206	PD.3024	C	6 A (CWC)	7.43Y	123.8	0.00	1.24	0.94	1	7	2	96	0.00	0.0	2.021	0.038	7	2	1	2
PL.20523	PL.21206	C	#1/0 ACSR	7.43Y	123.8	0.00	1.24	0.00	0	0	0	100	0.00	0.0	2.059	0.037	0	0	1	1
PL.20776	PL.20522	ABC	336 MCM AC	7.42Y	123.7	0.08	1.32	78.72	15	1674	521	95	0.72	0.0	2.116	0.138	0	0	0	440
PL.20777	PL.20776	ABC	336 MCM AC	7.42Y	123.6	0.09	1.42	78.72	15	1674	519	96	0.80	0.0	2.270	0.154	0	0	0	440
PL.20834	PL.20777	ABC	336 MCM AC	7.41Y	123.5	0.06	1.48	78.72	15	1673	517	96	0.52	0.0	2.370	0.100	0	0	0	440
PL.20835	PL.20834	ABC	336 MCM AC	7.41Y	123.5	0.06	1.54	78.72	15	1672	516	96	0.53	0.0	2.472	0.102	0	0	0	440
PL.20778	PL.20835	ABC	336 MCM AC	7.40Y	123.4	0.06	1.60	74.74	14	1587	491	96	0.52	0.0	2.583	0.111	0	0	0	422
PL.21263	PL.20778	ABC	336 MCM AC	7.40Y	123.3	0.07	1.67	74.31	14	1577	487	96	0.56	0.0	2.703	0.120	0	0	0	421
PL.21264	PL.21263	ABC	336 MCM AC	7.40Y	123.3	0.01	1.68	74.31	14	1577	486	96	0.07	0.0	2.719	0.016	6	2	1	421
PL.21119	PL.21264	ABC	336 MCM AC	7.39Y	123.2	0.07	1.75	74.05	14	1571	484	96	0.59	0.0	2.846	0.127	0	0	0	420
PL.21239	PL.21119	ABC	336 MCM AC	7.39Y	123.2	0.08	1.83	74.05	14	1570	483	96	0.64	0.0	2.984	0.138	0	0	0	420
PD.3045-A	PL.21239	ABC	Closed	7.39Y	123.2	0.00	1.83	74.05	0	1570	481	96	0.00	0.0	2.984	0.138	0	0	0	420
PD.3045-B	PD.3045-A	ABC	Closed	7.39Y	123.2	0.00	1.83	74.05	0	1570	481	96	0.00	0.0	2.984	0.138	0	0	0	420

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Millers Creek

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru

PL.21240	PD.3045-B	ABC	336 MCM AC	7.39Y	123.1	0.03	1.86	74.05	14	1570	481	96	0.27	0.0	3.042	0.058	0	0	0	420
PL.21199	PL.21240	C	6 A (CWC)	7.39Y	123.1	0.00	1.86	0.75	1	5	1	98	0.00	0.0	3.046	0.005	0	0	0	3
PD.3021	PL.21199	C	50T	7.39Y	123.1	0.00	1.86	0.75	0	5	1	98	0.00	0.0	3.046	0.005	0	0	0	3
PL.21200	PD.3021	C	6 A (CWC)	7.39Y	123.1	0.00	1.87	0.75	1	5	1	98	0.00	0.0	3.155	0.109	0	0	0	3
PL.20842	PL.21200	C	6 A (CWC)	7.39Y	123.1	0.00	1.87	0.75	1	5	1	98	0.00	0.0	3.239	0.084	0	0	0	3
PL.21117	PL.20842	C	6 A (CWC)	7.39Y	123.1	0.00	1.87	0.75	1	5	1	98	0.00	0.0	3.347	0.108	1	0	1	3
PL.21118	PL.21117	C	6 A (CWC)	7.39Y	123.1	0.00	1.87	0.57	0	4	1	97	0.00	0.0	3.398	0.051	0	0	0	2
PL.21120	PL.21118	C	6 A (CWC)	7.39Y	123.1	0.00	1.88	0.57	0	4	1	97	0.00	0.0	3.539	0.141	0	0	1	2
PL.21121	PL.21120	C	6 A (CWC)	7.39Y	123.1	0.00	1.88	0.57	0	4	1	97	0.00	0.0	3.629	0.090	0	0	0	1
PL.20782	PL.21121	C	6 A (CWC)	7.39Y	123.1	0.00	1.88	0.00	0	0	0	100	0.00	0.0	3.700	0.071	0	0	0	0
PL.21203	PL.21121	C	1/0 AL URD	7.39Y	123.1	0.00	1.88	0.57	0	4	1	97	0.00	0.0	3.633	0.005	0	0	0	1
PD.3023	PL.21203	C	30T	7.39Y	123.1	0.00	1.88	0.57	0	4	1	97	0.00	0.0	3.633	0.005	0	0	0	1
PL.21204	PD.3023	C	1/0 AL URD	7.39Y	123.1	0.00	1.88	0.57	0	4	1	97	0.00	0.0	3.659	0.026	4	1	1	1
PL.20781	PL.21240	ABC	336 MCM AC	7.38Y	123.1	0.07	1.93	73.80	14	1564	479	96	0.55	0.0	3.162	0.121	0	0	0	417
PL.20843	PL.20781	ABC	336 MCM AC	7.38Y	123.0	0.07	2.00	73.80	14	1563	478	96	0.54	0.0	3.280	0.118	0	0	0	417
PL.20844	PL.20843	ABC	336 MCM AC	7.38Y	122.9	0.06	2.06	73.80	14	1563	477	96	0.52	0.0	3.394	0.114	0	0	0	417
PL.21265	PL.20844	ABC	336 MCM AC	7.37Y	122.8	0.10	2.16	73.33	14	1552	473	96	0.78	0.1	3.566	0.173	0	0	0	412
RG.27	PL.21265	ABC	76.2 KVA	7.46Y	124.4	-1.55	0.60	73.33	73	1551	471	96	percent Boost= 1.25 Tap= 2.0						412	
PL.21266	RG.27	ABC	336 MCM AC	7.46Y	124.3	0.08	0.68	72.41	14	1551	471	96	0.61	0.0	3.705	0.138	0	0	0	412
PL.20850	PL.21266	ABC	336 MCM AC	7.45Y	124.2	0.07	0.75	72.41	14	1551	469	96	0.55	0.0	3.830	0.125	0	0	0	412
PL.20894	PL.20850	ABC	336 MCM AC	7.45Y	124.2	0.06	0.81	72.41	14	1550	468	96	0.44	0.0	3.930	0.100	0	0	0	412
PL.20851	PL.20894	ABC	336 MCM AC	7.45Y	124.1	0.05	0.86	72.41	14	1550	467	96	0.43	0.0	4.028	0.098	0	0	0	412
PL.20852	PL.20851	ABC	336 MCM AC	7.44Y	124.1	0.08	0.94	72.41	14	1549	466	96	0.61	0.0	4.165	0.137	0	0	0	412
PL.21112	PL.20852	ABC	336 MCM AC	7.44Y	124.0	0.06	1.00	72.41	14	1549	465	96	0.50	0.0	4.278	0.112	0	0	0	412
PL.21113	PL.21112	ABC	336 MCM AC	7.44Y	123.9	0.09	1.08	72.41	14	1548	463	96	0.69	0.0	4.433	0.155	0	0	0	412
PL.21197	PL.21113	A	#4 ACSR	7.44Y	123.9	0.00	1.08	0.28	0	2	1	89	0.00	0.0	4.437	0.005	0	0	0	2
PD.3020	PL.21197	A	50T	7.44Y	123.9	0.00	1.08	0.28	0	2	1	89	0.00	0.0	4.437	0.005	0	0	0	2
PL.21198	PD.3020	A	#4 ACSR	7.43Y	123.9	0.00	1.09	0.28	0	2	1	89	0.00	0.0	4.576	0.139	0	0	0	2
PL.20678	PL.21198	A	#4 ACSR	7.43Y	123.9	0.00	1.09	0.28	0	2	1	89	0.00	0.0	4.721	0.144	2	1	2	2
PL.20784	PL.21113	ABC	336 MCM AC	7.43Y	123.9	0.05	1.13	72.32	14	1546	461	96	0.40	0.0	4.524	0.091	0	0	0	410
PL.21185	PL.20784	B	#1/0 ACSR	7.43Y	123.9	0.00	1.13	1.22	1	9	2	98	0.00	0.0	4.528	0.005	0	0	0	1

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Millers Creek

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PD.3014	PL.21185	B	50T	7.43Y	123.9	0.00	1.13	1.22	0	9	2	98	0.00	0.0	4.528	0.005	0	0	0	1
PL.21186	PD.3014	B	#1/0 ACSR	7.43Y	123.9	0.00	1.13	1.22	1	9	2	98	0.00	0.0	4.589	0.061	9	2	1	1
PL.20925	PL.20784	ABC	336 MCM AC	7.43Y	123.8	0.02	1.15	71.91	14	1536	458	96	0.16	0.0	4.560	0.036	0	0	1	409
PL.20972	PL.20925	ABC	336 MCM AC	7.42Y	123.7	0.10	1.26	71.89	14	1536	457	96	0.82	0.1	4.747	0.188	0	0	0	406
PL.21245	PL.20972	ABC	336 MCM AC	7.42Y	123.7	0.00	1.26	71.89	14	1535	456	96	0.01	0.0	4.750	0.003	0	0	0	406
PD.3048	PL.21245	ABC	100L	7.42Y	123.7	0.00	1.26	71.89	72	1535	455	96	0.00	0.0	4.750	0.003	0	0	0	406
PL.21246	PD.3048	ABC	336 MCM AC	7.42Y	123.7	0.06	1.31	71.89	14	1535	455	96	0.45	0.0	4.853	0.103	5	1	1	406
PL.20971	PL.21246	ABC	336 MCM AC	7.42Y	123.6	0.07	1.38	71.65	14	1530	453	96	0.57	0.0	4.985	0.132	0	0	0	405
PL.20856	PL.20971	ABC	336 MCM AC	7.41Y	123.6	0.06	1.45	71.65	14	1529	452	96	0.51	0.0	5.104	0.118	0	0	0	405
PL.20969	PL.20856	ABC	336 MCM AC	7.41Y	123.5	0.06	1.51	71.65	14	1528	450	96	0.45	0.0	5.208	0.104	0	0	1	405
PL.20970	PL.20969	ABC	336 MCM AC	7.41Y	123.4	0.08	1.58	71.63	14	1528	449	96	0.62	0.0	5.350	0.143	0	0	0	404
PL.20857	PL.20970	ABC	336 MCM AC	7.40Y	123.4	0.03	1.61	71.63	14	1527	448	96	0.21	0.0	5.399	0.049	0	0	0	404
PL.20604	PL.20857	A	#1/0 ACSR	7.40Y	123.4	0.00	1.61	1.33	1	9	3	95	0.00	0.0	5.404	0.005	0	0	0	2
PD.2985	PL.20604	A	40T	7.40Y	123.4	0.00	1.61	1.33	0	9	3	95	0.00	0.0	5.404	0.005	0	0	0	2
PL.20605	PD.2985	A	#1/0 ACSR	7.40Y	123.4	0.00	1.61	1.33	1	9	3	95	0.00	0.0	5.447	0.043	1	0	1	2
PL.20531	PL.20605	A	6 A (CWC)	7.40Y	123.4	0.00	1.62	1.16	1	8	2	97	0.00	0.0	5.631	0.183	8	2	1	1
PL.20785	PL.20531	ABC	336 MCM AC	7.40Y	123.3	0.04	1.65	71.19	14	1517	445	96	0.33	0.0	5.477	0.078	0	0	0	402
PL.20858	PL.20785	ABC	336 MCM AC	7.40Y	123.3	0.04	1.70	71.19	14	1517	444	96	0.35	0.0	5.560	0.083	0	0	0	402
PL.21241	PL.20858	ABC	336 MCM AC	7.40Y	123.3	0.04	1.74	71.19	14	1517	443	96	0.33	0.0	5.638	0.078	0	0	0	402
PD.3046-A	PL.21241	ABC	Closed	7.40Y	123.3	0.00	1.74	71.19	0	1516	442	96	0.00	0.0	5.638	0.078	0	0	0	402
PD.3046-B	PD.3046-A	ABC	Closed	7.40Y	123.3	0.00	1.74	71.19	0	1516	442	96	0.00	0.0	5.638	0.078	0	0	0	402
PL.21242	PD.3046-B	ABC	336 MCM AC	7.39Y	123.2	0.02	1.76	71.19	14	1516	442	96	0.16	0.0	5.676	0.038	0	0	0	402
PL.20786	PL.21242	ABC	336 MCM AC	7.39Y	123.2	0.03	1.79	54.77	11	1166	342	96	0.18	0.0	5.749	0.073	11	3	1	266
PL.20930	PL.20786	ABC	336 MCM AC	7.39Y	123.2	0.04	1.83	54.26	10	1155	339	96	0.27	0.0	5.857	0.108	4	1	3	265
PL.20602	PL.20930	C	#2 ACSR	7.39Y	123.2	0.00	1.83	0.01	0	0	0	100	0.00	0.0	5.862	0.005	0	0	0	1
PD.2984	PL.20602	C	40T	7.39Y	123.2	0.00	1.83	0.01	0	0	0	100	0.00	0.0	5.862	0.005	0	0	0	1
PL.20603	PD.2984	C	#2 ACSR	7.39Y	123.2	0.00	1.83	0.01	0	0	0	100	0.00	0.0	5.908	0.046	0	0	1	1
PL.20966	PL.20603	ABC	336 MCM AC	7.39Y	123.2	0.01	1.85	54.08	10	1151	337	96	0.08	0.0	5.889	0.032	4	1	1	261
PL.20967	PL.20966	ABC	336 MCM AC	7.39Y	123.1	0.04	1.89	53.88	10	1146	336	96	0.26	0.0	5.997	0.108	4	1	1	260
PL.20961	PL.20967	ABC	336 MCM AC	7.39Y	123.1	0.03	1.92	53.70	10	1142	334	96	0.15	0.0	6.061	0.064	1	0	1	259
PL.20929	PL.20961	ABC	336 MCM AC	7.38Y	123.1	0.01	1.93	53.13	10	1130	330	96	0.08	0.0	6.093	0.032	8	2	3	257

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Millers Creek

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.20696	PL.20929	ABC	336 MCM AC	7.38Y	123.1	0.02	1.95	52.77	10	1122	328	96	0.10	0.0	6.135	0.042	2	0	1	254
PL.20926	PL.20696	ABC	#1/0 ACSR	7.38Y	122.9	0.12	2.06	51.94	23	1104	323	96	0.90	0.1	6.259	0.125	0	0	0	249
PL.20596	PL.20926	C	6 A (CWC)	7.38Y	122.9	0.00	2.06	2.45	2	17	5	96	0.00	0.0	6.264	0.005	0	0	0	2
PD.2982	PL.20596	C	40T	7.38Y	122.9	0.00	2.06	2.45	0	17	5	96	0.00	0.0	6.264	0.005	0	0	0	2
PL.20597	PD.2982	C	6 A (CWC)	7.38Y	122.9	0.00	2.07	2.45	2	17	5	96	0.00	0.0	6.338	0.074	17	5	2	2
PL.20598	PL.20926	ABC	#1/0 ACSR	7.38Y	122.9	0.00	2.07	50.96	22	1082	316	96	0.03	0.0	6.263	0.004	0	0	0	245
PL.20599	PL.20598	ABC	#1/0 ACSR	7.37Y	122.9	0.06	2.13	50.96	22	1082	316	96	0.45	0.0	6.329	0.066	0	0	0	245
PL.20700	PL.20599	ABC	#1/0 ACSR	7.37Y	122.8	0.09	2.22	50.96	22	1082	316	96	0.71	0.1	6.431	0.103	0	0	0	245
PL.20795	PL.20700	ABC	#1/0 ACSR	7.36Y	122.7	0.04	2.27	50.87	22	1079	314	96	0.32	0.0	6.478	0.047	0	0	0	244
PL.20863	PL.20795	ABC	#1/0 ACSR	7.36Y	122.6	0.10	2.36	50.87	22	1079	314	96	0.72	0.1	6.583	0.105	0	0	0	244
PL.20864	PL.20863	ABC	#1/0 ACSR	7.35Y	122.5	0.11	2.47	50.87	22	1078	313	96	0.82	0.1	6.702	0.119	0	0	0	244
PL.20584	PL.20864	ABC	#1/0 ACSR	7.34Y	122.4	0.13	2.60	50.59	22	1071	311	96	0.97	0.1	6.845	0.143	0	0	0	243
PL.20585	PL.20584	ABC	#1/0 ACSR	7.34Y	122.4	0.00	2.61	50.59	22	1070	310	96	0.03	0.0	6.849	0.004	11	3	2	243
PL.21225	PL.20585	C	#2 ACSR	7.34Y	122.4	0.00	2.61	0.31	0	2	1	89	0.00	0.0	6.854	0.005	0	0	0	2
PD.3035	PL.21225	C	40T	7.34Y	122.4	0.00	2.61	0.31	0	2	1	89	0.00	0.0	6.854	0.005	0	0	0	2
PL.21226	PD.3035	C	#2 ACSR	7.34Y	122.4	0.00	2.61	0.31	0	2	1	89	0.00	0.0	6.892	0.038	2	1	2	2
PL.21227	PL.20585	ABC	#1/0 ACSR	7.34Y	122.4	0.00	2.61	49.82	22	1054	306	96	0.03	0.0	6.854	0.004	0	0	0	236
PL.21228	PL.21227	ABC	#1/0 ACSR	7.34Y	122.3	0.08	2.69	49.82	22	1054	305	96	0.57	0.1	6.940	0.086	0	0	0	236
PL.20865	PL.21228	ABC	#1/0 ACSR	7.33Y	122.2	0.15	2.84	49.82	22	1054	305	96	1.06	0.1	7.101	0.161	0	0	0	236
PL.20923	PL.20865	ABC	#1/0 ACSR	7.33Y	122.1	0.08	2.91	49.82	22	1053	304	96	0.58	0.1	7.189	0.088	10	3	3	236
PL.20618	PL.20923	B	#4 ACSR	7.33Y	122.1	0.00	2.91	2.39	2	17	5	96	0.00	0.0	7.193	0.005	0	0	0	2
PD.2992	PL.20618	B	15T	7.33Y	122.1	0.00	2.91	2.39	0	17	5	96	0.00	0.0	7.193	0.005	0	0	0	2
PL.20619	PD.2992	B	#4 ACSR	7.32Y	122.1	0.02	2.93	2.39	2	17	5	96	0.00	0.0	7.377	0.184	0	0	0	2
PL.21016	PL.20619	B	#4 ACSR	7.32Y	122.0	0.02	2.95	2.39	2	17	5	96	0.00	0.0	7.532	0.155	0	0	0	2
PL.20869	PL.21016	B	#4 ACSR	7.32Y	122.0	0.01	2.96	2.39	2	17	5	96	0.00	0.0	7.624	0.092	0	0	0	2
PL.20708	PL.20869	B	#4 ACSR	7.32Y	122.0	0.01	2.97	1.22	1	9	2	98	0.00	0.0	7.737	0.113	0	0	0	1
PL.20707	PL.20708	B	#4 ACSR	7.32Y	122.0	0.00	2.97	0.00	0	0	0	100	0.00	0.0	7.872	0.136	0	0	0	0
PL.20870	PL.20707	B	#4 ACSR	7.32Y	122.0	0.00	2.97	0.00	0	0	0	100	0.00	0.0	7.948	0.075	0	0	0	0
PL.20706	PL.20708	B	#4 ACSR	7.32Y	122.0	0.00	2.97	1.22	1	9	2	98	0.00	0.0	7.847	0.111	9	2	1	1
PL.20825	PL.20869	B	#4 ACSR	7.32Y	122.0	0.00	2.96	1.17	1	8	2	97	0.00	0.0	7.696	0.072	0	0	0	1
PL.20709	PL.20825	B	#2 ACSR	7.32Y	122.0	0.00	2.97	1.17	1	8	2	97	0.00	0.0	7.741	0.045	8	2	1	1

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Millers Creek

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.20924	PL.20923	ABC	#1/0 ACSR	7.32Y	122.1	0.02	2.93	48.53	21	1025	296	96	0.12	0.0	7.209	0.020	8	2	4	231
PL.20705	PL.20924	ABC	#1/0 ACSR	7.32Y	122.0	0.06	2.99	48.13	21	1016	293	96	0.41	0.0	7.277	0.068	10	3	1	227
PL.20922	PL.20705	ABC	#1/0 ACSR	7.32Y	121.9	0.08	3.07	47.67	21	1006	290	96	0.56	0.1	7.369	0.092	2	1	2	226
PL.21014	PL.20922	ABC	#1/0 ACSR	7.31Y	121.9	0.05	3.12	47.18	21	995	287	96	0.35	0.0	7.428	0.059	6	2	1	219
PL.21015	PL.21014	ABC	#1/0 ACSR	7.31Y	121.8	0.04	3.16	46.91	20	989	285	96	0.28	0.0	7.475	0.048	0	0	0	218
PL.20620	PL.21015	C	#4 ACSR	7.31Y	121.8	0.00	3.16	0.03	0	0	0	100	0.00	0.0	7.480	0.005	0	0	0	1
PD.2993	PL.20620	C	40T	7.31Y	121.8	0.00	3.16	0.03	0	0	0	100	0.00	0.0	7.480	0.005	0	0	0	1
PL.20621	PD.2993	C	#4 ACSR	7.31Y	121.8	0.00	3.16	0.03	0	0	0	100	0.00	0.0	7.530	0.050	0	0	1	1
PL.20797	PL.21015	ABC	#1/0 ACSR	7.31Y	121.8	0.06	3.22	46.90	20	988	284	96	0.43	0.0	7.549	0.073	0	0	0	217
PL.20624	PL.20797	A	6 A (CWC)	7.31Y	121.8	0.00	3.22	0.27	0	2	1	89	0.00	0.0	7.553	0.005	0	0	0	1
PD.2995	PL.20624	A	15T	7.31Y	121.8	0.00	3.22	0.27	0	2	1	89	0.00	0.0	7.553	0.005	0	0	0	1
PL.20625	PD.2995	A	6 A (CWC)	7.31Y	121.8	0.00	3.22	0.27	0	2	1	89	0.00	0.0	7.643	0.090	0	0	0	1
PL.21011	PL.20625	A	6 A (CWC)	7.31Y	121.8	0.00	3.23	0.27	0	2	1	89	0.00	0.0	7.814	0.171	0	0	0	1
PL.20710	PL.21011	A	6 A (CWC)	7.31Y	121.8	0.00	3.23	0.00	0	0	0	100	0.00	0.0	7.920	0.106	0	0	0	0
PL.20871	PL.20710	A	6 A (CWC)	7.31Y	121.8	0.00	3.23	0.00	0	0	0	100	0.00	0.0	8.012	0.092	0	0	0	0
PL.20799	PL.21011	A	6 A (CWC)	7.31Y	121.8	0.00	3.23	0.27	0	2	1	89	0.00	0.0	7.876	0.062	0	0	0	1
PL.21007	PL.20799	A	6 A (CWC)	7.31Y	121.8	0.00	3.23	0.27	0	2	1	89	0.00	0.0	7.889	0.013	0	0	0	1
PL.21008	PL.21007	A	6 A (CWC)	7.31Y	121.8	0.00	3.23	0.27	0	2	1	89	0.00	0.0	8.001	0.112	0	0	0	1
PL.21009	PL.21008	A	6 A (CWC)	7.31Y	121.8	0.00	3.23	0.27	0	2	1	89	0.00	0.0	8.133	0.132	0	0	0	1
PL.21010	PL.21009	A	6 A (CWC)	7.31Y	121.8	0.00	3.23	0.27	0	2	1	89	0.00	0.0	8.252	0.119	0	0	0	1
PL.20872	PL.21010	A	6 A (CWC)	7.31Y	121.8	0.00	3.23	0.27	0	2	1	89	0.00	0.0	8.371	0.118	0	0	0	1
PL.20712	PL.20872	A	#4 ACSR	7.31Y	121.8	0.00	3.23	0.00	0	0	0	100	0.00	0.0	8.408	0.037	0	0	0	0
PL.20800	PL.20872	A	6 A (CWC)	7.31Y	121.8	0.00	3.24	0.27	0	2	1	89	0.00	0.0	8.493	0.122	0	0	0	1
PL.20873	PL.20800	A	6 A (CWC)	7.31Y	121.8	0.00	3.24	0.27	0	2	1	89	0.00	0.0	8.586	0.094	2	1	1	1
PL.20711	PL.21008	A	6 A (CWC)	7.31Y	121.8	0.00	3.23	0.00	0	0	0	100	0.00	0.0	8.184	0.182	0	0	0	0
PL.20798	PL.20797	ABC	#1/0 ACSR	7.30Y	121.7	0.06	3.29	46.81	20	986	283	96	0.44	0.0	7.625	0.076	16	4	2	216
PL.20616	PL.20798	C	#1/0 ACSR	7.30Y	121.7	0.00	3.29	1.95	1	14	4	96	0.00	0.0	7.629	0.004	0	0	0	2
PD.2991	PL.20616	C	40T	7.30Y	121.7	0.00	3.29	1.95	0	14	4	96	0.00	0.0	7.629	0.004	0	0	0	2
PL.20617	PD.2991	C	#1/0 ACSR	7.30Y	121.7	0.00	3.29	1.95	1	14	4	96	0.00	0.0	7.683	0.054	8	2	1	2
PL.21012	PL.20617	C	#1/0 ACSR	7.30Y	121.7	0.00	3.29	0.85	0	6	2	95	0.00	0.0	7.710	0.027	6	2	1	1
PL.21017	PL.20798	ABC	#1/0 ACSR	7.30Y	121.7	0.06	3.34	45.40	20	956	275	96	0.37	0.0	7.694	0.069	15	4	3	212

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Millers Creek

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru

PL.21018	PL.21017	ABC	#1/0 ACSR	7.29Y	121.6	0.08	3.42	44.67	19	940	270	96	0.49	0.1	7.790	0.096	33	9	4	209
PL.21019	PL.21018	ABC	#1/0 ACSR	7.29Y	121.5	0.07	3.49	43.08	19	906	260	96	0.46	0.1	7.884	0.094	11	3	1	205
PL.20626	PL.21019	A	6 A (CWC)	7.29Y	121.5	0.00	3.49	0.29	0	2	1	89	0.00	0.0	7.889	0.005	0	0	0	3
PD.2996	PL.20626	A	40T	7.29Y	121.5	0.00	3.49	0.29	0	2	1	89	0.00	0.0	7.889	0.005	0	0	0	3
PL.20627	PD.2996	A	6 A (CWC)	7.29Y	121.5	0.00	3.49	0.29	0	2	1	89	0.00	0.0	7.944	0.055	2	0	1	3
PL.21020	PL.20627	A	6 A (CWC)	7.29Y	121.5	0.00	3.49	0.04	0	0	0	100	0.00	0.0	7.974	0.030	0	0	2	2
PL.21021	PL.21019	ABC	#1/0 ACSR	7.29Y	121.5	0.02	3.52	42.45	18	892	256	96	0.14	0.0	7.912	0.028	0	0	1	201
PL.21022	PL.21021	ABC	#1/0 ACSR	7.29Y	121.4	0.04	3.56	42.43	18	892	256	96	0.25	0.0	7.966	0.053	1	0	1	200
PL.21023	PL.21022	ABC	#1/0 ACSR	7.28Y	121.4	0.05	3.61	42.39	18	891	255	96	0.33	0.0	8.036	0.070	0	0	0	199
PL.20801	PL.21023	ABC	#1/0 ACSR	7.28Y	121.3	0.08	3.69	39.73	17	835	239	96	0.49	0.1	8.152	0.117	0	0	0	185
PL.20874	PL.20801	ABC	#1/0 ACSR	7.27Y	121.2	0.09	3.78	39.73	17	834	239	96	0.51	0.1	8.275	0.122	0	0	0	185
PL.21037	PL.20874	ABC	#1/0 ACSR	7.27Y	121.1	0.08	3.86	39.73	17	834	238	96	0.48	0.1	8.389	0.115	10	3	1	185
PL.21038	PL.21037	ABC	#1/0 ACSR	7.27Y	121.1	0.03	3.90	39.28	17	824	235	96	0.20	0.0	8.438	0.048	15	4	2	184
PL.21039	PL.21038	ABC	#1/0 ACSR	7.26Y	121.1	0.04	3.94	38.57	17	808	231	96	0.21	0.0	8.491	0.053	0	0	0	182
PL.21169	PL.21039	A	6 A (CWC)	7.26Y	121.1	0.00	3.94	2.13	2	15	4	97	0.00	0.0	8.495	0.005	0	0	0	2
PD.3007	PL.21169	A	40T	7.26Y	121.1	0.00	3.94	2.13	0	15	4	97	0.00	0.0	8.495	0.005	0	0	0	2
PL.21170	PD.3007	A	6 A (CWC)	7.26Y	121.1	0.00	3.94	2.13	2	15	4	97	0.00	0.0	8.513	0.017	5	1	1	2
PL.20724	PL.21170	A	#4 ACSR	7.26Y	121.1	0.00	3.94	1.46	1	10	3	96	0.00	0.0	8.595	0.083	10	3	1	1
PL.20806	PL.21039	ABC	#1/0 ACSR	7.26Y	121.0	0.02	3.95	37.86	16	793	227	96	0.09	0.0	8.513	0.023	0	0	0	180
PL.21040	PL.20806	ABC	#1/0 ACSR	7.26Y	121.0	0.03	3.98	37.86	16	793	226	96	0.18	0.0	8.560	0.046	0	0	0	180
PL.21041	PL.21040	ABC	#1/0 ACSR	7.26Y	121.0	0.05	4.03	37.86	16	793	226	96	0.27	0.0	8.629	0.069	0	0	0	180
PL.20875	PL.21041	ABC	#1/0 ACSR	7.25Y	120.9	0.06	4.09	37.86	16	793	226	96	0.34	0.0	8.717	0.088	0	0	0	180
PL.20876	PL.20875	ABC	#1/0 ACSR	7.25Y	120.9	0.05	4.14	37.86	16	793	226	96	0.28	0.0	8.791	0.074	0	0	0	180
PL.21027	PL.20876	ABC	#1/0 ACSR	7.25Y	120.8	0.06	4.20	37.86	16	792	225	96	0.33	0.0	8.880	0.089	20	6	3	180
PL.21028	PL.21027	ABC	#1/0 ACSR	7.24Y	120.7	0.07	4.27	36.91	16	772	220	96	0.38	0.0	8.984	0.104	9	2	1	177
PL.20918	PL.21028	ABC	#1/0 ACSR	7.24Y	120.7	0.07	4.34	35.04	15	732	208	96	0.38	0.1	9.100	0.116	1	0	1	170
PL.20727	PL.20918	A	#4 ACSR	7.24Y	120.7	0.00	4.35	6.99	5	49	14	96	0.00	0.0	9.105	0.005	0	0	0	7
PD.3002	PL.20727	A	40T	7.24Y	120.7	0.00	4.35	6.99	0	49	14	96	0.00	0.0	9.105	0.005	0	0	0	7
PL.20920	PD.3002	A	6 A (CWC)	7.24Y	120.7	0.00	4.35	3.95	3	28	8	96	0.00	0.0	9.110	0.006	0	0	0	5
PL.20921	PL.20920	A	6 A (CWC)	7.24Y	120.7	0.00	4.35	3.95	3	28	8	96	0.00	0.0	9.110	0.000	0	0	0	5
PL.20725	PL.20921	A	6 A (CWC)	7.24Y	120.6	0.01	4.36	3.95	3	28	8	96	0.00	0.0	9.217	0.107	28	8	5	5

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Millers Creek

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.20807	PD.3002	A	#4 ACSR	7.24Y	120.7	0.00	4.35	3.04	2	21	6	96	0.00	0.0	9.129	0.025	21	6	2	2
PL.20919	PL.20918	ABC	#1/0 ACSR	7.24Y	120.6	0.06	4.40	32.65	14	682	194	96	0.28	0.0	9.201	0.101	16	5	2	162
PL.21161	PL.20919	A	#4 ACSR	7.24Y	120.6	0.00	4.40	1.52	1	11	3	96	0.00	0.0	9.206	0.005	0	0	0	2
PD.3003	PL.21161	A	40T	7.24Y	120.6	0.00	4.40	1.52	0	11	3	96	0.00	0.0	9.206	0.005	0	0	0	2
PL.21162	PD.3003	A	#4 ACSR	7.24Y	120.6	0.00	4.40	1.52	1	11	3	96	0.00	0.0	9.243	0.037	11	3	2	2
PL.21029	PL.20919	ABC	#1/0 ACSR	7.23Y	120.6	0.02	4.42	31.37	14	655	186	96	0.08	0.0	9.231	0.030	0	0	1	158
PL.21030	PL.21029	ABC	#1/0 ACSR	7.23Y	120.6	0.03	4.45	31.37	14	655	186	96	0.12	0.0	9.278	0.047	9	3	2	157
PL.21163	PL.21030	C	6 A (CWC)	7.23Y	120.6	0.00	4.45	0.87	1	6	2	95	0.00	0.0	9.283	0.005	0	0	0	1
PD.3004	PL.21163	C	40T	7.23Y	120.6	0.00	4.45	0.87	0	6	2	95	0.00	0.0	9.283	0.005	0	0	0	1
PL.21164	PD.3004	C	6 A (CWC)	7.23Y	120.6	0.00	4.45	0.87	1	6	2	95	0.00	0.0	9.331	0.048	6	2	1	1
PL.20728	PL.21164	C	#4 ACSR	7.23Y	120.6	0.00	4.45	0.00	0	0	0	100	0.00	0.0	9.353	0.022	0	0	0	0
PL.20915	PL.21030	ABC	#1/0 ACSR	7.23Y	120.5	0.06	4.50	30.64	13	640	182	96	0.26	0.0	9.380	0.102	0	0	0	154
PL.20729	PL.20915	ABC	#1/0 ACSR	7.23Y	120.4	0.05	4.56	29.95	13	625	177	96	0.24	0.0	9.480	0.100	0	0	0	151
PL.20808	PL.20729	ABC	#1/0 ACSR	7.22Y	120.4	0.02	4.58	29.11	13	607	172	96	0.08	0.0	9.517	0.036	0	0	0	146
PL.20732	PL.20808	ABC	#1/0 ACSR	7.22Y	120.4	0.03	4.61	29.03	13	605	172	96	0.13	0.0	9.575	0.058	0	0	0	144
PL.20809	PL.20732	ABC	#1/0 ACSR	7.22Y	120.3	0.06	4.67	28.84	13	601	170	96	0.27	0.0	9.698	0.123	0	0	0	143
PL.20735	PL.20809	A	#1/0 ACSR	7.22Y	120.3	0.00	4.67	2.80	1	19	5	97	0.00	0.0	9.703	0.005	0	0	0	4
PD.3000	PL.20735	A	40T	7.22Y	120.3	0.00	4.67	2.80	0	19	5	97	0.00	0.0	9.703	0.005	0	0	0	4
PL.20908	PD.3000	A	#1/0 ACSR	7.22Y	120.3	0.00	4.67	1.61	1	11	3	96	0.00	0.0	9.712	0.009	0	0	0	2
PL.20909	PL.20908	A	#1/0 ACSR	7.22Y	120.3	0.00	4.67	1.61	1	11	3	96	0.00	0.0	9.712	0.000	0	0	0	2
PL.20767	PL.20909	A	#1/0 ACSR	7.22Y	120.3	0.00	4.67	1.61	1	11	3	96	0.00	0.0	9.725	0.012	0	0	0	2
PL.20812	PL.20767	A	#1/0 ACSR	7.22Y	120.3	0.00	4.67	0.78	0	5	2	93	0.00	0.0	9.816	0.092	5	2	1	1
PL.20734	PL.20767	A	#1/0 ACSR	7.22Y	120.3	0.00	4.67	0.83	0	6	2	95	0.00	0.0	9.773	0.049	6	2	1	1
PL.20811	PD.3000	A	#1/0 ACSR	7.22Y	120.3	0.00	4.67	1.18	1	8	2	97	0.00	0.0	9.739	0.036	8	2	2	2
PL.20810	PL.20809	ABC	#1/0 ACSR	7.22Y	120.3	0.03	4.70	27.91	12	582	165	96	0.11	0.0	9.749	0.051	0	0	0	139
PL.21159	PL.20810	A	#2 ACSR	7.22Y	120.3	0.00	4.70	0.96	1	7	2	96	0.00	0.0	9.753	0.004	0	0	0	1
PD.3001	PL.21159	A	40T	7.22Y	120.3	0.00	4.70	0.96	0	7	2	96	0.00	0.0	9.753	0.004	0	0	0	1
PL.21160	PD.3001	A	#2 ACSR	7.22Y	120.3	0.00	4.70	0.96	1	7	2	96	0.00	0.0	9.756	0.003	7	2	1	1
PL.20736	PL.20810	ABC	#1/0 ACSR	7.22Y	120.3	0.05	4.75	27.59	12	575	163	96	0.19	0.0	9.845	0.095	0	0	0	138
PL.20878	PL.20736	ABC	#1/0 ACSR	7.21Y	120.2	0.05	4.80	27.59	12	575	163	96	0.21	0.0	9.947	0.103	0	0	0	138
PL.21051	PL.20878	ABC	#1/0 ACSR	7.21Y	120.2	0.03	4.82	27.59	12	574	162	96	0.10	0.0	9.998	0.051	1	0	1	138

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Millers Creek

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru

PL.21052	PL.21051	ABC	#1/0 ACSR	7.21Y	120.2	0.02	4.84	27.56	12	574	162	96	0.07	0.0	10.032	0.034	0	0	0	137
PL.20813	PL.21052	ABC	#1/0 ACSR	7.21Y	120.1	0.06	4.90	26.17	11	545	154	96	0.23	0.0	10.157	0.125	0	0	0	130
PL.20879	PL.20813	ABC	#1/0 ACSR	7.20Y	120.1	0.05	4.94	26.17	11	544	154	96	0.18	0.0	10.255	0.098	0	0	0	130
PL.21173	PL.20879	C	#2 ACSR	7.20Y	120.1	0.00	4.94	0.48	0	3	1	95	0.00	0.0	10.260	0.005	0	0	0	1
PD.3009	PL.21173	C	40T	7.20Y	120.1	0.00	4.94	0.48	0	3	1	95	0.00	0.0	10.260	0.005	0	0	0	1
PL.21174	PD.3009	C	#2 ACSR	7.20Y	120.1	0.00	4.94	0.48	0	3	1	95	0.00	0.0	10.293	0.034	3	1	1	1
PL.21050	PL.21174	C	#2 ACSR	7.20Y	120.1	0.00	4.94	0.00	0	0	0	100	0.00	0.0	10.395	0.102	0	0	0	0
PL.21047	PL.20879	ABC	#1/0 ACSR	7.20Y	120.0	0.02	4.96	26.01	11	541	153	96	0.06	0.0	10.291	0.036	14	4	6	129
PL.21048	PL.21047	ABC	#1/0 ACSR	7.20Y	120.0	0.02	4.98	25.32	11	527	149	96	0.06	0.0	10.329	0.038	8	2	1	123
PL.21049	PL.21048	ABC	#1/0 ACSR	7.20Y	120.0	0.02	5.00	24.92	11	518	146	96	0.08	0.0	10.378	0.050	8	2	3	122
PL.21171	PL.21049	B	6 A (CWC)	7.20Y	120.0	0.00	5.00	1.31	1	9	3	95	0.00	0.0	10.383	0.005	0	0	0	2
PD.3008	PL.21171	B	40T	7.20Y	120.0	0.00	5.00	1.31	0	9	3	95	0.00	0.0	10.383	0.005	0	0	0	2
PL.21172	PD.3008	B	6 A (CWC)	7.20Y	120.0	0.00	5.00	1.31	1	9	3	95	0.00	0.0	10.438	0.055	9	3	2	2
PL.20906	PL.21049	ABC	#1/0 ACSR	7.20Y	120.0	0.01	5.01	24.13	10	502	141	96	0.05	0.0	10.410	0.031	3	1	1	117
PL.20737	PL.20906	C	#4 ACSR	7.20Y	120.0	0.02	5.03	37.51	29	260	73	96	0.04	0.0	10.422	0.012	0	0	0	63
PL.20738	PL.20737	C	#4 ACSR	7.20Y	119.9	0.04	5.07	34.60	27	240	68	96	0.07	0.0	10.446	0.024	0	0	0	58
PL.21247	PL.20738	C	6 A (CWC)	7.20Y	119.9	0.00	5.08	34.60	25	240	68	96	0.01	0.0	10.449	0.003	0	0	0	58
PD.3049	PL.21247	C	70L	7.20Y	119.9	0.00	5.08	34.60	49	240	68	96	0.00	0.0	10.449	0.003	0	0	0	58
PL.21248	PD.3049	C	6 A (CWC)	7.19Y	119.8	0.08	5.16	34.60	25	240	68	96	0.14	0.1	10.501	0.053	21	6	5	58
PL.20901	PL.21248	C	6 A (CWC)	7.19Y	119.8	0.05	5.20	31.50	23	218	62	96	0.08	0.0	10.534	0.033	0	0	0	51
PL.20902	PL.20901	C	6 A (CWC)	7.18Y	119.7	0.09	5.29	29.79	21	206	58	96	0.13	0.1	10.600	0.066	15	4	3	48
PL.21177	PL.20902	C	6 A (CWC)	7.18Y	119.7	0.01	5.30	6.67	5	46	13	96	0.00	0.0	10.625	0.024	0	0	0	15
PD.3011	PL.21177	C	15T	7.18Y	119.7	0.00	5.30	6.67	0	46	13	96	0.00	0.0	10.625	0.024	0	0	0	15
PL.21178	PD.3011	C	6 A (CWC)	7.18Y	119.7	0.02	5.32	6.67	5	46	13	96	0.01	0.0	10.702	0.078	0	0	0	15
PL.20762	PL.21178	C	6 A (CWC)	7.18Y	119.6	0.03	5.35	6.67	5	46	13	96	0.01	0.0	10.802	0.100	0	0	0	15
PL.20880	PL.20762	C	6 A (CWC)	7.18Y	119.6	0.03	5.38	6.67	5	46	13	96	0.01	0.0	10.902	0.100	0	0	0	15
PL.21055	PL.20880	C	6 A (CWC)	7.18Y	119.6	0.03	5.41	6.67	5	46	13	96	0.01	0.0	11.000	0.099	5	2	5	15
PL.21056	PL.21055	C	6 A (CWC)	7.17Y	119.6	0.01	5.42	5.88	4	41	11	97	0.00	0.0	11.033	0.033	0	0	1	10
PL.21057	PL.21056	C	6 A (CWC)	7.17Y	119.6	0.01	5.43	5.83	4	40	11	96	0.00	0.0	11.086	0.052	0	0	0	9
PL.20764	PL.21057	C	6 A (CWC)	7.17Y	119.6	0.00	5.43	0.00	0	0	0	100	0.00	0.0	11.145	0.059	0	0	0	1
PL.20816	PL.20764	C	6 A (CWC)	7.17Y	119.6	0.00	5.43	0.00	0	0	0	100	0.00	0.0	11.225	0.080	0	0	1	1

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Millers Creek

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru

PL.20765	PL.20764	C	6 A (CWC)	7.17Y	119.6	0.00	5.43	0.00	0	0	0	100	0.00	0.0	11.171	0.026	0	0	0	0
PL.20815	PL.21057	C	6 A (CWC)	7.17Y	119.6	0.01	5.44	5.80	4	40	11	96	0.00	0.0	11.109	0.023	0	0	0	7
PL.20817	PL.20815	C	6 A (CWC)	7.17Y	119.6	0.01	5.45	2.90	2	20	6	96	0.00	0.0	11.200	0.091	19	5	2	3
PL.21064	PL.20817	C	6 A (CWC)	7.17Y	119.6	0.00	5.45	0.11	0	1	0	100	0.00	0.0	11.249	0.049	1	0	1	1
PL.21065	PL.21064	C	6 A (CWC)	7.17Y	119.6	0.00	5.45	0.00	0	0	0	100	0.00	0.0	11.328	0.079	0	0	0	0
PL.20766	PL.20815	C	#1/0 ACSR	7.17Y	119.6	0.00	5.44	0.18	0	1	0	100	0.00	0.0	11.154	0.045	1	0	1	1
PL.21066	PL.20815	C	6 A (CWC)	7.17Y	119.6	0.01	5.44	2.71	2	19	5	97	0.00	0.0	11.152	0.043	0	0	2	3
PL.21067	PL.21066	C	6 A (CWC)	7.17Y	119.6	0.00	5.45	2.71	2	19	5	97	0.00	0.0	11.218	0.066	19	5	1	1
PL.20763	PL.21057	C	#1/0 ACSR	7.17Y	119.6	0.00	5.43	0.04	0	0	0	100	0.00	0.0	11.101	0.016	0	0	1	1
PL.21058	PL.20902	C	6 A (CWC)	7.18Y	119.6	0.11	5.40	20.92	15	145	41	96	0.12	0.1	10.719	0.118	7	2	2	30
PL.21059	PL.21058	C	6 A (CWC)	7.17Y	119.5	0.12	5.52	19.85	14	137	39	96	0.13	0.1	10.855	0.136	0	0	0	28
PL.20881	PL.21059	C	6 A (CWC)	7.16Y	119.4	0.11	5.64	19.85	14	137	39	96	0.12	0.1	10.977	0.122	0	0	0	28
PL.20882	PL.20881	C	6 A (CWC)	7.16Y	119.3	0.10	5.74	19.85	14	137	39	96	0.11	0.1	11.089	0.111	0	0	0	28
PL.20741	PL.20882	C	6 A (CWC)	7.16Y	119.3	0.00	5.74	0.00	0	0	0	100	0.00	0.0	11.145	0.056	0	0	0	0
PL.21062	PL.20882	C	6 A (CWC)	7.15Y	119.2	0.09	5.83	19.85	14	137	39	96	0.10	0.1	11.192	0.103	5	1	1	28
PL.21063	PL.21062	C	6 A (CWC)	7.14Y	119.0	0.14	5.97	19.17	14	132	37	96	0.14	0.1	11.350	0.158	0	0	0	27
PL.21060	PL.21063	C	6 A (CWC)	7.14Y	118.9	0.09	6.06	19.17	14	132	37	96	0.09	0.1	11.453	0.103	3	1	1	27
PL.21061	PL.21060	C	6 A (CWC)	7.13Y	118.8	0.09	6.15	18.78	13	129	36	96	0.09	0.1	11.563	0.110	0	0	0	26
PL.20883	PL.21061	C	6 A (CWC)	7.13Y	118.8	0.09	6.25	18.78	13	129	36	96	0.09	0.1	11.671	0.108	0	0	0	26
PL.20899	PL.20883	C	6 A (CWC)	7.12Y	118.7	0.10	6.34	18.78	13	129	36	96	0.10	0.1	11.784	0.113	0	0	0	26
PL.20884	PL.20899	C	6 A (CWC)	7.11Y	118.6	0.08	6.43	18.78	13	129	36	96	0.08	0.1	11.882	0.098	0	0	0	26
PL.20744	PL.20884	C	6 A (CWC)	7.11Y	118.6	0.01	6.44	4.39	3	30	8	97	0.00	0.0	11.930	0.048	12	3	2	4
PL.20742	PL.20744	C	#2 ACSR	7.11Y	118.6	0.00	6.44	1.88	1	13	4	96	0.00	0.0	12.007	0.077	13	4	1	1
PL.20743	PL.20744	C	#2 ACSR	7.11Y	118.6	0.00	6.44	0.81	0	6	2	95	0.00	0.0	11.977	0.047	6	2	1	1
PL.20818	PL.20884	C	6 A (CWC)	7.11Y	118.5	0.05	6.48	14.39	10	99	28	96	0.04	0.0	11.957	0.076	0	0	0	22
PL.20745	PL.20818	C	#4 ACSR	7.11Y	118.5	0.01	6.49	2.04	2	14	4	96	0.00	0.0	12.051	0.094	0	0	0	3
PL.20746	PL.20745	C	#1/0 ACSR	7.11Y	118.5	0.00	6.49	2.04	1	14	4	96	0.00	0.0	12.081	0.030	14	4	3	3
PL.20819	PL.20818	C	6 A (CWC)	7.11Y	118.5	0.05	6.52	12.35	9	85	24	96	0.03	0.0	12.040	0.082	0	0	0	19
PL.20826	PL.20819	C	6 A (CWC)	7.10Y	118.4	0.09	6.62	12.35	9	85	24	96	0.06	0.1	12.207	0.167	0	0	0	19
PL.20820	PL.20826	C	6 A (CWC)	7.10Y	118.3	0.05	6.67	9.83	7	67	19	96	0.03	0.0	12.325	0.118	5	1	1	17
PL.20748	PL.20820	C	#4 ACSR	7.10Y	118.3	0.01	6.68	2.41	2	16	5	95	0.00	0.0	12.461	0.136	9	3	3	4

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Millers Creek

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	Element KW	KVAR	Cons On	Cons Thru
PL.20749	PL.20748	C	#4 ACSR	7.10Y	118.3	0.00	6.68	1.08	1	7	2	96	0.00	0.0	12.531	0.070	7	2	1	1
PL.21042	PL.20820	C	6 A (CWC)	7.10Y	118.3	0.04	6.71	6.73	5	46	13	96	0.01	0.0	12.471	0.147	8	2	3	12
PL.21043	PL.21042	C	6 A (CWC)	7.10Y	118.3	0.02	6.73	5.57	4	38	11	96	0.01	0.0	12.554	0.083	3	1	1	9
PL.21044	PL.21043	C	6 A (CWC)	7.09Y	118.2	0.03	6.76	5.19	4	35	10	96	0.01	0.0	12.661	0.107	0	0	0	8
PL.20900	PL.21044	C	6 A (CWC)	7.09Y	118.2	0.02	6.78	5.19	4	35	10	96	0.01	0.0	12.749	0.088	0	0	0	8
PL.20885	PL.20900	C	6 A (CWC)	7.09Y	118.2	0.02	6.80	5.19	4	35	10	96	0.01	0.0	12.847	0.098	0	0	0	8
PL.20821	PL.20885	C	6 A (CWC)	7.09Y	118.2	0.02	6.82	4.03	3	27	8	96	0.00	0.0	12.954	0.107	0	0	0	5
PL.20912	PL.20821	C	6 A (CWC)	7.09Y	118.2	0.02	6.84	4.03	3	27	8	96	0.00	0.0	13.062	0.109	0	0	0	5
PL.20752	PL.20912	C	6 A (CWC)	7.09Y	118.2	0.00	6.84	0.44	0	3	1	95	0.00	0.0	13.226	0.164	0	0	0	1
PL.20886	PL.20752	C	6 A (CWC)	7.09Y	118.2	0.00	6.85	0.44	0	3	1	95	0.00	0.0	13.397	0.170	3	1	1	1
PL.65833	PL.20752	C	#1/0 ACSR	7.09Y	118.2	0.00	6.84	0.00	0	0	0	100	0.00	0.0	13.268	0.041	0	0	0	0
PL.20913	PL.20912	C	6 A (CWC)	7.09Y	118.1	0.02	6.86	3.58	3	24	7	96	0.00	0.0	13.173	0.111	0	0	0	4
PL.20916	PL.20913	C	6 A (CWC)	7.09Y	118.1	0.03	6.88	3.58	3	24	7	96	0.00	0.0	13.358	0.185	8	2	1	4
PL.20753	PL.20916	C	#4 ACSR	7.09Y	118.1	0.00	6.89	0.99	1	7	2	96	0.00	0.0	13.394	0.036	7	2	2	2
PL.20917	PL.20916	C	6 A (CWC)	7.09Y	118.1	0.01	6.89	1.48	1	10	3	96	0.00	0.0	13.546	0.188	10	3	1	1
PL.20751	PL.20885	C	#2 ACSR	7.09Y	118.2	0.00	6.80	1.16	1	8	2	97	0.00	0.0	12.872	0.025	0	0	0	3
PL.20750	PL.20751	C	#2 ACSR	7.09Y	118.2	0.00	6.80	0.57	0	4	1	97	0.00	0.0	12.919	0.047	4	1	1	1
PL.20822	PL.20751	C	#2 ACSR	7.09Y	118.2	0.00	6.80	0.59	0	4	1	97	0.00	0.0	12.884	0.012	4	1	2	2
PL.20747	PL.20826	C	6 A (CWC)	7.10Y	118.4	0.00	6.62	2.53	2	17	5	96	0.00	0.0	12.272	0.065	17	5	2	2
PL.21053	PL.20901	C	#1/0 ACSR	7.19Y	119.8	0.00	5.20	1.71	1	12	3	97	0.00	0.0	10.566	0.031	5	1	2	3
PL.21054	PL.21053	C	#1/0 ACSR	7.19Y	119.8	0.00	5.20	0.97	0	7	2	96	0.00	0.0	10.601	0.036	7	2	1	1
PL.20740	PL.21248	C	#2 ACSR	7.19Y	119.8	0.00	5.16	0.00	0	0	0	100	0.00	0.0	10.542	0.041	0	0	2	2
PL.20814	PL.20737	C	#4 ACSR	7.20Y	120.0	0.00	5.04	2.91	2	20	6	96	0.00	0.0	10.445	0.024	20	6	5	5
PL.20904	PL.20906	ABC	#1/0 ACSR	7.20Y	120.0	0.01	5.02	11.49	5	239	67	96	0.02	0.0	10.462	0.052	0	0	0	53
PL.20887	PL.20904	ABC	#1/0 ACSR	7.20Y	119.9	0.03	5.06	11.49	5	239	67	96	0.06	0.0	10.622	0.160	0	0	0	53
PL.20823	PL.20887	ABC	#1/0 ACSR	7.20Y	119.9	0.01	5.07	10.98	5	228	64	96	0.02	0.0	10.695	0.073	0	0	0	51
PL.20754	PL.20823	ABC	#1/0 ACSR	7.19Y	119.9	0.02	5.09	10.98	5	228	64	96	0.03	0.0	10.797	0.102	0	0	0	51
PL.20612	PL.20754	A	6 A (CWC)	7.19Y	119.9	0.00	5.09	5.82	4	40	11	96	0.00	0.0	10.802	0.005	0	0	0	9
PD.2989	PL.20612	A	40T	7.19Y	119.9	0.00	5.09	5.82	0	40	11	96	0.00	0.0	10.802	0.005	0	0	0	9
PL.20613	PD.2989	A	6 A (CWC)	7.19Y	119.9	0.02	5.11	5.82	4	40	11	96	0.01	0.0	10.877	0.075	4	1	1	9
PL.21000	PL.20613	A	6 A (CWC)	7.19Y	119.9	0.02	5.13	4.29	3	30	8	97	0.00	0.0	10.979	0.103	15	4	3	6

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Millers Creek

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.21001	PL.21000	A	6 A (CWC)	7.19Y	119.9	0.00	5.13	2.17	2	15	4	97	0.00	0.0	11.005	0.026	6	2	2	3
PL.20998	PL.21001	A	#2 ACSR	7.19Y	119.9	0.00	5.13	1.28	1	9	2	98	0.00	0.0	11.022	0.017	0	0	0	1
PL.20999	PL.20998	A	#2 ACSR	7.19Y	119.9	0.00	5.13	1.28	1	9	2	98	0.00	0.0	11.060	0.038	9	2	1	1
PL.21002	PL.20613	A	#4 ACSR	7.19Y	119.9	0.00	5.12	1.00	1	7	2	96	0.00	0.0	10.982	0.105	2	1	1	2
PL.21003	PL.21002	A	#4 ACSR	7.19Y	119.9	0.00	5.12	0.68	1	5	1	98	0.00	0.0	11.023	0.041	5	1	1	1
PL.21004	PL.21003	A	#4 ACSR	7.19Y	119.9	0.00	5.12	0.00	0	0	0	100	0.00	0.0	11.066	0.043	0	0	0	0
PL.20755	PL.21004	A	#2 ACSR	7.19Y	119.9	0.00	5.12	0.00	0	0	0	100	0.00	0.0	11.081	0.015	0	0	0	0
PL.21005	PL.20755	A	#2 ACSR	7.19Y	119.9	0.00	5.12	0.00	0	0	0	100	0.00	0.0	11.106	0.025	0	0	0	0
PL.21006	PL.21005	A	#2 ACSR	7.19Y	119.9	0.00	5.12	0.00	0	0	0	100	0.00	0.0	11.151	0.045	0	0	0	0
PL.20824	PL.20754	ABC	#1/0 ACSR	7.19Y	119.9	0.01	5.10	9.04	4	188	53	96	0.01	0.0	10.830	0.033	1	0	1	42
PL.20761	PL.20824	ABC	#1/0 ACSR	7.19Y	119.9	0.01	5.10	9.00	4	187	53	96	0.01	0.0	10.866	0.036	0	0	0	41
PL.20903	PL.20761	ABC	#1/0 ACSR	7.19Y	119.9	0.01	5.12	9.00	4	187	53	96	0.02	0.0	10.941	0.075	1	0	1	41
PL.20614	PL.20903	C	6 A (CWC)	7.19Y	119.9	0.00	5.12	0.71	1	5	1	98	0.00	0.0	10.945	0.005	0	0	0	1
PD.2990	PL.20614	C	40T	7.19Y	119.9	0.00	5.12	0.71	0	5	1	98	0.00	0.0	10.945	0.005	0	0	0	1
PL.20615	PD.2990	C	6 A (CWC)	7.19Y	119.9	0.00	5.12	0.71	1	5	1	98	0.00	0.0	10.980	0.034	5	1	1	1
PL.21231	PL.20903	A	6 A (CWC)	7.19Y	119.9	0.00	5.12	0.33	0	2	1	89	0.00	0.0	10.945	0.005	0	0	0	1
PD.3039	PL.21231	A	40T	7.19Y	119.9	0.00	5.12	0.33	0	2	1	89	0.00	0.0	10.945	0.005	0	0	0	1
PL.21232	PD.3039	A	6 A (CWC)	7.19Y	119.9	0.00	5.12	0.33	0	2	1	89	0.00	0.0	11.027	0.081	2	1	1	1
PL.20996	PL.20903	ABC	#1/0 ACSR	7.19Y	119.9	0.01	5.13	8.62	4	179	50	96	0.01	0.0	11.000	0.059	8	2	1	38
PL.20997	PL.20996	ABC	#1/0 ACSR	7.19Y	119.9	0.01	5.13	8.23	4	171	48	96	0.01	0.0	11.047	0.047	0	0	0	37
PL.20905	PL.20997	ABC	#1/0 ACSR	7.19Y	119.9	0.01	5.14	7.54	3	157	44	96	0.01	0.0	11.129	0.081	0	0	0	33
PL.20756	PL.20905	ABC	#1/0 ACSR	7.19Y	119.8	0.01	5.15	7.54	3	157	44	96	0.01	0.0	11.205	0.076	0	0	0	33
PL.21255	PL.20756	A	#4 ACSR	7.19Y	119.8	0.06	5.21	16.97	13	117	33	96	0.05	0.0	11.278	0.074	0	0	0	25
PD.3054	PL.21255	A	35L	7.19Y	119.8	0.00	5.21	16.97	48	117	33	96	0.00	0.0	11.278	0.074	0	0	0	25
PL.21256	PD.3054	A	#4 ACSR	7.19Y	119.8	0.01	5.22	16.97	13	117	33	96	0.01	0.0	11.298	0.020	9	2	1	25
PL.20907	PL.21256	A	#4 ACSR	7.18Y	119.7	0.03	5.25	14.66	11	101	28	96	0.02	0.0	11.343	0.045	0	0	1	23
PL.20991	PL.20907	A	#4 ACSR	7.18Y	119.7	0.05	5.30	13.43	10	93	26	96	0.03	0.0	11.422	0.079	4	1	1	20
PL.20992	PL.20991	A	#4 ACSR	7.18Y	119.7	0.03	5.33	12.85	10	89	25	96	0.02	0.0	11.474	0.052	9	3	1	19
PL.20989	PL.20992	A	#4 ACSR	7.18Y	119.7	0.00	5.33	1.05	1	7	2	96	0.00	0.0	11.528	0.054	1	0	1	2
PL.20990	PL.20989	A	#4 ACSR	7.18Y	119.7	0.00	5.33	0.85	1	6	2	95	0.00	0.0	11.568	0.040	6	2	1	1
PL.20987	PL.20992	A	#4 ACSR	7.18Y	119.6	0.03	5.36	10.47	8	72	20	96	0.02	0.0	11.538	0.064	2	0	1	16

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Millers Creek

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru

PL.20988	PL.20987	A	#4 ACSR	7.18Y	119.6	0.04	5.40	10.23	8	71	20	96	0.02	0.0	11.636	0.098	1	0	1	15
PL.20986	PL.20988	A	#4 ACSR	7.17Y	119.5	0.06	5.46	10.01	8	69	19	96	0.03	0.0	11.769	0.132	2	1	1	14
PL.20983	PL.20986	A	#4 ACSR	7.17Y	119.5	0.05	5.51	9.71	7	67	19	96	0.03	0.0	11.896	0.128	5	1	2	13
PL.20982	PL.20983	A	#4 ACSR	7.17Y	119.5	0.02	5.54	9.00	7	62	17	96	0.01	0.0	11.955	0.059	3	1	1	11
PL.20910	PL.20982	A	#4 ACSR	7.17Y	119.5	0.01	5.55	6.79	5	47	13	96	0.00	0.0	11.990	0.035	2	0	1	9
PL.20976	PL.20910	A	#1/0 ACSR	7.17Y	119.4	0.01	5.56	3.75	2	26	7	97	0.00	0.0	12.157	0.166	12	3	1	4
PL.20977	PL.20976	A	#1/0 ACSR	7.17Y	119.4	0.00	5.56	2.01	1	14	4	96	0.00	0.0	12.218	0.061	1	0	1	3
PL.20975	PL.20977	A	#1/0 ACSR	7.17Y	119.4	0.00	5.56	1.86	1	13	4	96	0.00	0.0	12.305	0.087	0	0	0	2
PL.20888	PL.20975	A	#1/0 ACSR	7.17Y	119.4	0.00	5.57	1.86	1	13	4	96	0.00	0.0	12.411	0.106	0	0	0	2
PL.20889	PL.20888	A	#1/0 ACSR	7.17Y	119.4	0.01	5.57	1.86	1	13	4	96	0.00	0.0	12.548	0.137	0	0	0	2
PL.20606	PL.20889	A	1/0 AL URD	7.17Y	119.4	0.00	5.58	1.86	1	13	4	96	0.00	0.0	12.552	0.005	0	0	0	2
PD.2986	PL.20606	A	15T	7.17Y	119.4	0.00	5.58	1.86	0	13	4	96	0.00	0.0	12.552	0.005	0	0	0	2
PL.20607	PD.2986	A	1/0 AL URD	7.17Y	119.4	0.00	5.58	1.86	1	13	4	96	0.00	0.0	12.629	0.077	7	2	1	2
PL.21148	PL.20607	A	1/0 AL URD	7.17Y	119.4	0.00	5.58	0.87	1	6	2	95	0.00	0.0	12.703	0.074	6	2	1	1
PL.20978	PL.20910	A	#4 ACSR	7.17Y	119.4	0.01	5.55	2.81	2	19	5	97	0.00	0.0	12.031	0.041	0	0	0	4
PL.20979	PL.20978	A	#4 ACSR	7.17Y	119.4	0.01	5.56	2.81	2	19	5	97	0.00	0.0	12.094	0.063	0	0	0	4
PL.20760	PL.20979	A	#1/0 ACSR	7.17Y	119.4	0.00	5.56	1.18	1	8	2	97	0.00	0.0	12.130	0.036	8	2	1	1
PL.20980	PL.20979	A	#4 ACSR	7.17Y	119.4	0.00	5.56	1.63	1	11	3	96	0.00	0.0	12.150	0.055	9	2	1	3
PL.20981	PL.20980	A	#4 ACSR	7.17Y	119.4	0.00	5.56	0.36	0	2	1	89	0.00	0.0	12.293	0.143	2	1	1	2
PL.20974	PL.20981	A	#4 ACSR	7.17Y	119.4	0.00	5.56	0.01	0	0	0	100	0.00	0.0	12.371	0.078	0	0	0	1
PL.20890	PL.20974	A	#4 ACSR	7.17Y	119.4	0.00	5.56	0.01	0	0	0	100	0.00	0.0	12.480	0.110	0	0	0	1
PL.20891	PL.20890	A	#4 ACSR	7.17Y	119.4	0.00	5.56	0.01	0	0	0	100	0.00	0.0	12.579	0.098	0	0	0	1
PL.20892	PL.20891	A	#4 ACSR	7.17Y	119.4	0.00	5.56	0.01	0	0	0	100	0.00	0.0	12.691	0.112	0	0	0	1
PL.20893	PL.20892	A	#4 ACSR	7.17Y	119.4	0.00	5.56	0.01	0	0	0	100	0.00	0.0	12.744	0.053	0	0	1	1
PL.20759	PL.20982	A	#1/0 ACSR	7.17Y	119.5	0.00	5.54	1.82	1	13	4	96	0.00	0.0	12.065	0.110	13	4	1	1
PL.20758	PL.20907	A	#1/0 ACSR	7.18Y	119.7	0.00	5.25	1.23	1	9	2	98	0.00	0.0	11.402	0.059	9	2	2	2
PL.20757	PL.21256	A	#1/0 ACSR	7.19Y	119.8	0.00	5.22	1.07	0	7	2	96	0.00	0.0	11.390	0.092	7	2	1	1
PL.20993	PL.20756	ABC	#1/0 ACSR	7.19Y	119.8	0.00	5.16	1.88	1	39	11	96	0.00	0.0	11.282	0.078	4	1	1	8
PL.20994	PL.20993	ABC	#1/0 ACSR	7.19Y	119.8	0.00	5.16	1.68	1	35	10	96	0.00	0.0	11.379	0.096	23	6	4	7
PL.20985	PL.20994	ABC	#1/0 ACSR	7.19Y	119.8	0.00	5.16	0.57	0	12	3	97	0.00	0.0	11.440	0.061	4	1	1	3
PL.20984	PL.20985	ABC	#1/0 ACSR	7.19Y	119.8	0.00	5.16	0.40	0	8	2	97	0.00	0.0	11.480	0.040	8	2	2	2

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Millers Creek

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.21237	PL.20984	ABC	#1/0 ACSR	7.19Y	119.8	0.00	5.16	0.00	0	0	0	100	0.00	0.0	11.501	0.021	0	0	0	0
PD.3044-A	PL.21237	ABC	Open	7.19Y	119.8	0.00	5.16	0.00	0	0	0	100	0.00	0.0	11.501	0.021	0	0	0	0
PL.20608	PL.20997	A	6 A (CWC)	7.19Y	119.9	0.00	5.13	2.06	1	14	4	96	0.00	0.0	11.052	0.005	0	0	0	4
PD.2987	PL.20608	A	40T	7.19Y	119.9	0.00	5.13	2.06	0	14	4	96	0.00	0.0	11.052	0.005	0	0	0	4
PL.20609	PD.2987	A	6 A (CWC)	7.19Y	119.9	0.00	5.14	2.06	1	14	4	96	0.00	0.0	11.118	0.066	13	4	3	4
PL.20995	PL.20609	A	6 A (CWC)	7.19Y	119.9	0.00	5.14	0.26	0	2	0	100	0.00	0.0	11.192	0.074	2	0	1	1
PL.20610	PL.20887	C	6 A (CWC)	7.20Y	119.9	0.00	5.06	1.53	1	11	3	96	0.00	0.0	10.626	0.005	0	0	0	2
PD.2988	PL.20610	C	40T	7.20Y	119.9	0.00	5.06	1.53	0	11	3	96	0.00	0.0	10.626	0.005	0	0	0	2
PL.20611	PD.2988	C	6 A (CWC)	7.20Y	119.9	0.00	5.06	1.53	1	11	3	96	0.00	0.0	10.739	0.113	9	2	1	2
PL.20739	PL.20611	C	#4 ACSR	7.20Y	119.9	0.00	5.06	0.25	0	2	0	100	0.00	0.0	10.805	0.066	2	0	1	1
PL.21229	PL.21052	C	#4 ACSR	7.21Y	120.2	0.00	4.84	1.47	1	10	3	96	0.00	0.0	10.036	0.005	0	0	0	2
PD.3038	PL.21229	C	40T	7.21Y	120.2	0.00	4.84	1.47	0	10	3	96	0.00	0.0	10.036	0.005	0	0	0	2
PL.21230	PD.3038	C	#4 ACSR	7.21Y	120.2	0.00	4.84	1.47	1	10	3	96	0.00	0.0	10.107	0.071	10	3	2	2
PL.21175	PL.21052	A	#4 ACSR	7.21Y	120.2	0.00	4.84	2.72	2	19	5	97	0.00	0.0	10.036	0.005	0	0	0	5
PD.3010	PL.21175	A	40T	7.21Y	120.2	0.00	4.84	2.72	0	19	5	97	0.00	0.0	10.036	0.005	0	0	0	5
PL.21176	PD.3010	A	#4 ACSR	7.21Y	120.1	0.02	4.86	2.72	2	19	5	97	0.00	0.0	10.187	0.151	0	0	0	5
PL.21045	PL.21176	A	6 A (CWC)	7.21Y	120.1	0.00	4.86	2.72	2	19	5	97	0.00	0.0	10.240	0.053	11	3	2	5
PL.21046	PL.21045	A	6 A (CWC)	7.21Y	120.1	0.01	4.87	1.17	1	8	2	97	0.00	0.0	10.405	0.165	4	1	2	3
PL.20973	PL.21046	A	6 A (CWC)	7.21Y	120.1	0.00	4.87	0.53	0	4	1	97	0.00	0.0	10.456	0.051	4	1	1	1
PL.21157	PL.20732	C	#4 ACSR	7.22Y	120.4	0.00	4.61	0.57	0	4	1	97	0.00	0.0	9.580	0.005	0	0	0	1
PD.2999	PL.21157	C	40T	7.22Y	120.4	0.00	4.61	0.57	0	4	1	97	0.00	0.0	9.580	0.005	0	0	0	1
PL.21158	PD.2999	C	#4 ACSR	7.22Y	120.4	0.00	4.61	0.57	0	4	1	97	0.00	0.0	9.618	0.039	4	1	1	1
PL.20630	PL.20808	B	#1/0 ACSR	7.23Y	120.4	0.00	4.58	0.24	0	2	0	100	0.00	0.0	9.521	0.005	0	0	0	2
PD.2998	PL.20630	B	40T	7.23Y	120.4	0.00	4.58	0.24	0	2	0	100	0.00	0.0	9.521	0.005	0	0	0	2
PL.21156	PD.2998	B	#1/0 ACSR	7.23Y	120.4	0.00	4.58	0.24	0	2	0	100	0.00	0.0	9.553	0.032	2	0	2	2
PL.20628	PL.20729	A	6 A (CWC)	7.23Y	120.4	0.00	4.56	2.53	2	18	5	96	0.00	0.0	9.485	0.005	0	0	0	5
PD.2997	PL.20628	A	40T	7.23Y	120.4	0.00	4.56	2.53	0	18	5	96	0.00	0.0	9.485	0.005	0	0	0	5
PL.20629	PD.2997	A	6 A (CWC)	7.23Y	120.4	0.01	4.57	2.53	2	18	5	96	0.00	0.0	9.639	0.154	9	2	1	5
PL.21025	PL.20629	A	#4 ACSR	7.23Y	120.4	0.01	4.58	1.28	1	9	2	98	0.00	0.0	9.760	0.121	1	0	1	4
PL.21026	PL.21025	A	#4 ACSR	7.22Y	120.4	0.01	4.59	1.12	1	8	2	97	0.00	0.0	9.922	0.162	2	0	1	3
PL.21024	PL.21026	A	#4 ACSR	7.22Y	120.4	0.00	4.59	0.87	1	6	2	95	0.00	0.0	10.039	0.117	0	0	0	2

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Millers Creek

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.20877	PL.21024	A	#4 ACSR	7.22Y	120.4	0.00	4.59	0.87	1	6	2	95	0.00	0.0	10.140	0.102	6	2	1	2
PL.20733	PL.20877	A	#4 ACSR	7.22Y	120.4	0.00	4.59	0.03	0	0	0	100	0.00	0.0	10.323	0.183	0	0	1	1
PL.21165	PL.20915	C	6 A (CWC)	7.23Y	120.5	0.00	4.50	2.08	1	14	4	96	0.00	0.0	9.385	0.005	0	0	0	3
PD.3005	PL.21165	C	40T	7.23Y	120.5	0.00	4.50	2.08	0	14	4	96	0.00	0.0	9.385	0.005	0	0	0	3
PL.21166	PD.3005	C	6 A (CWC)	7.23Y	120.5	0.00	4.51	2.08	1	14	4	96	0.00	0.0	9.426	0.042	4	1	1	3
PL.20730	PL.21166	C	#4 ACSR	7.23Y	120.5	0.00	4.51	0.50	0	4	1	97	0.00	0.0	9.503	0.076	4	1	1	1
PL.20911	PL.21166	C	6 A (CWC)	7.23Y	120.5	0.00	4.51	1.06	1	7	2	96	0.00	0.0	9.451	0.025	0	0	0	1
PL.20731	PL.20911	C	#4 ACSR	7.23Y	120.5	0.00	4.51	1.06	1	7	2	96	0.00	0.0	9.488	0.036	7	2	1	1
PL.21233	PL.21028	C	#1/0 ACSR	7.24Y	120.7	0.00	4.27	4.39	2	31	9	96	0.00	0.0	8.989	0.005	0	0	0	6
PD.3041	PL.21233	C	40T	7.24Y	120.7	0.00	4.27	4.39	0	31	9	96	0.00	0.0	8.989	0.005	0	0	0	6
PL.21234	PD.3041	C	#1/0 ACSR	7.24Y	120.7	0.00	4.27	4.39	2	31	9	96	0.00	0.0	9.013	0.025	3	1	1	6
PL.21031	PL.21234	C	#4 ACSR	7.24Y	120.7	0.00	4.28	3.96	3	28	8	96	0.00	0.0	9.028	0.014	12	3	3	5
PL.21032	PL.21031	C	#4 ACSR	7.24Y	120.7	0.00	4.28	2.27	2	16	4	97	0.00	0.0	9.084	0.056	9	3	1	2
PL.20726	PL.21032	C	#4 ACSR	7.24Y	120.7	0.00	4.28	0.94	1	7	2	96	0.00	0.0	9.157	0.073	7	2	1	1
PL.20714	PL.21023	C	#4 ACSR	7.28Y	121.4	0.00	3.61	0.51	0	4	1	97	0.00	0.0	8.040	0.005	0	0	0	2
PD.3037	PL.20714	C	40T	7.28Y	121.4	0.00	3.61	0.51	0	4	1	97	0.00	0.0	8.040	0.005	0	0	0	2
PL.20802	PD.3037	C	#4 ACSR	7.28Y	121.4	0.00	3.61	0.51	0	4	1	97	0.00	0.0	8.087	0.047	4	1	2	2
PL.20715	PL.21023	C	6 A (CWC)	7.28Y	121.4	0.00	3.61	7.31	5	51	14	96	0.00	0.0	8.040	0.005	0	0	0	11
PD.3042	PL.20715	C	40T	7.28Y	121.4	0.00	3.61	7.31	0	51	14	96	0.00	0.0	8.040	0.005	0	0	0	11
PL.20803	PD.3042	C	6 A (CWC)	7.28Y	121.4	0.03	3.64	7.31	5	51	14	96	0.01	0.0	8.135	0.095	0	0	0	11
PL.21033	PL.20803	C	6 A (CWC)	7.28Y	121.3	0.04	3.68	7.31	5	51	14	96	0.01	0.0	8.244	0.109	4	1	1	11
PL.21034	PL.21033	C	6 A (CWC)	7.28Y	121.3	0.05	3.73	6.75	5	47	13	96	0.02	0.0	8.419	0.175	0	0	0	10
PL.21035	PL.21034	C	6 A (CWC)	7.28Y	121.3	0.01	3.74	3.59	3	25	7	96	0.00	0.0	8.473	0.054	16	4	4	5
PL.21036	PL.21035	C	6 A (CWC)	7.28Y	121.3	0.01	3.75	1.31	1	9	3	95	0.00	0.0	8.635	0.162	0	0	0	1
PL.20723	PL.21036	C	#2 ACSR	7.28Y	121.3	0.00	3.75	1.31	1	9	3	95	0.00	0.0	8.660	0.025	9	3	1	1
PL.20805	PL.21034	C	6 A (CWC)	7.28Y	121.3	0.01	3.75	2.85	2	20	6	96	0.00	0.0	8.534	0.115	0	0	0	4
PL.20717	PL.20805	C	#4 ACSR	7.28Y	121.3	0.00	3.75	1.23	1	9	2	98	0.00	0.0	8.555	0.021	7	2	1	3
PL.21167	PL.20717	C	#1/0 ACSR	7.28Y	121.3	0.00	3.75	0.02	0	0	0	100	0.00	0.0	8.559	0.005	0	0	0	1
PD.3006	PL.21167	C	25T	7.28Y	121.3	0.00	3.75	0.02	0	0	0	100	0.00	0.0	8.559	0.005	0	0	0	1
PL.21168	PD.3006	C	#1/0 ACSR	7.28Y	121.3	0.00	3.75	0.02	0	0	0	100	0.00	0.0	8.609	0.050	0	0	1	1
PL.20716	PL.20717	C	#1/0 ACSR	7.28Y	121.3	0.00	3.75	0.22	0	2	0	100	0.00	0.0	8.696	0.142	2	0	1	1

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Millers Creek

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.20718	PL.20805	C	6 A (CWC)	7.27Y	121.2	0.01	3.76	1.62	1	11	3	96	0.00	0.0	8.706	0.172	0	0	0	1
PL.20721	PL.20718	C	#1/0 ACSR	7.27Y	121.2	0.00	3.76	1.62	1	11	3	96	0.00	0.0	8.892	0.187	11	3	1	1
PL.20722	PL.21034	C	#4 ACSR	7.28Y	121.3	0.00	3.73	0.32	0	2	1	89	0.00	0.0	8.471	0.051	2	1	1	1
PL.20713	PL.21023	A	#4 ACSR	7.28Y	121.4	0.00	3.61	0.14	0	1	0	100	0.00	0.0	8.040	0.005	0	0	0	1
PD.3036	PL.20713	A	40T	7.28Y	121.4	0.00	3.61	0.14	0	1	0	100	0.00	0.0	8.040	0.005	0	0	0	1
PL.20804	PD.3036	A	#4 ACSR	7.28Y	121.4	0.00	3.61	0.14	0	1	0	100	0.00	0.0	8.074	0.034	1	0	1	1
PL.20622	PL.20922	C	#4 ACSR	7.32Y	121.9	0.00	3.07	1.16	1	8	2	97	0.00	0.0	7.373	0.005	0	0	0	5
PD.2994	PL.20622	C	40T	7.32Y	121.9	0.00	3.07	1.16	0	8	2	97	0.00	0.0	7.373	0.005	0	0	0	5
PL.20623	PD.2994	C	#4 ACSR	7.32Y	121.9	0.00	3.07	1.16	1	8	2	97	0.00	0.0	7.433	0.060	8	2	5	5
PL.20582	PL.20585	C	#2 ACSR	7.34Y	122.4	0.00	2.61	0.48	0	3	1	95	0.00	0.0	6.854	0.005	0	0	0	3
PD.2976	PL.20582	C	40T	7.34Y	122.4	0.00	2.61	0.48	0	3	1	95	0.00	0.0	6.854	0.005	0	0	0	3
PL.20583	PD.2976	C	#2 ACSR	7.34Y	122.4	0.00	2.61	0.48	0	3	1	95	0.00	0.0	6.918	0.064	0	0	1	3
PL.20703	PL.20583	C	#2 ACSR	7.34Y	122.4	0.00	2.61	0.45	0	3	1	95	0.00	0.0	6.949	0.031	3	1	2	2
PL.20702	PL.20864	C	#1/0 ACSR	7.35Y	122.5	0.00	2.47	0.84	0	6	2	95	0.00	0.0	6.720	0.018	6	2	1	1
PL.20701	PL.20700	A	#1/0 ACSR	7.37Y	122.8	0.00	2.22	0.28	0	2	1	89	0.00	0.0	6.455	0.024	2	1	1	1
PL.20698	PL.20926	C	#2 ACSR	7.38Y	122.9	0.00	2.06	0.50	0	4	1	97	0.00	0.0	6.264	0.004	0	0	0	2
PD.3034	PL.20698	C	40T	7.38Y	122.9	0.00	2.06	0.50	0	4	1	97	0.00	0.0	6.264	0.004	0	0	0	2
PL.20927	PD.3034	C	#4 ACSR	7.38Y	122.9	0.00	2.06	0.21	0	2	0	100	0.00	0.0	6.268	0.005	0	0	0	1
PL.20928	PL.20927	C	#4 ACSR	7.38Y	122.9	0.00	2.06	0.21	0	2	0	100	0.00	0.0	6.268	0.000	0	0	0	1
PL.20699	PL.20928	C	#4 ACSR	7.38Y	122.9	0.00	2.06	0.21	0	2	0	100	0.00	0.0	6.308	0.040	2	0	1	1
PL.20794	PD.3034	C	#2 ACSR	7.38Y	122.9	0.00	2.06	0.29	0	2	1	89	0.00	0.0	6.279	0.015	2	1	1	1
PL.20963	PL.20696	ABC	6 A (CWC)	7.38Y	123.1	0.00	1.95	0.75	1	16	4	97	0.00	0.0	6.209	0.075	4	1	1	4
PL.20964	PL.20963	ABC	6 A (CWC)	7.38Y	123.1	0.00	1.95	0.57	0	12	3	97	0.00	0.0	6.265	0.055	0	0	1	3
PL.20962	PL.20964	ABC	6 A (CWC)	7.38Y	123.1	0.00	1.95	0.57	0	12	3	97	0.00	0.0	6.381	0.116	9	3	1	2
PL.21223	PL.20962	B	6 A (CWC)	7.38Y	123.0	0.00	1.95	0.45	0	3	1	95	0.00	0.0	6.386	0.004	0	0	0	1
PD.3033	PL.21223	B	40T	7.38Y	123.0	0.00	1.95	0.45	0	3	1	95	0.00	0.0	6.386	0.004	0	0	0	1
PL.21224	PD.3033	B	6 A (CWC)	7.38Y	123.0	0.00	1.95	0.45	0	3	1	95	0.00	0.0	6.459	0.073	0	0	0	1
PL.20697	PL.21224	B	6 A (CWC)	7.38Y	123.0	0.00	1.95	0.45	0	3	1	95	0.00	0.0	6.552	0.093	3	1	1	1
PL.20965	PL.20961	C	#2 ACSR	7.39Y	123.1	0.00	1.92	1.65	1	12	3	97	0.00	0.0	6.074	0.013	12	3	1	1
PL.20600	PL.20965	C	#2 ACSR	7.39Y	123.1	0.00	1.92	0.00	0	0	0	100	0.00	0.0	6.078	0.005	0	0	0	0
PD.2983	PL.20600	C	40T	7.39Y	123.1	0.00	1.92	0.00	0	0	0	100	0.00	0.0	6.078	0.005	0	0	0	0

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Millers Creek

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.20601	PD.2983	C	#2 ACSR	7.39Y	123.1	0.00	1.92	0.00	0	0	0	100	0.00	0.0	6.176	0.098	0	0	0	0
PL.20532	PL.21242	A C	6 A (CWC)	7.39Y	123.2	0.02	1.78	24.63	18	350	100	96	0.06	0.0	5.697	0.021	0	0	0	136
PL.21261	PL.20532	A C	6 A (CWC)	7.39Y	123.2	0.02	1.81	24.63	18	350	100	96	0.07	0.0	5.721	0.024	0	0	0	136
PD.3057	PL.21261	A C	50L	7.39Y	123.2	0.00	1.81	24.63	49	350	99	96	0.00	0.0	5.721	0.024	0	0	0	136
PL.21262	PD.3057	A C	6 A (CWC)	7.39Y	123.1	0.08	1.88	24.63	18	350	99	96	0.20	0.1	5.793	0.072	1	0	1	136
PL.20968	PL.21262	A C	6 A (CWC)	7.38Y	123.0	0.09	1.97	24.55	18	349	99	96	0.24	0.1	5.879	0.086	1	0	2	135
PL.20959	PL.20968	A C	6 A (CWC)	7.38Y	123.0	0.07	2.04	24.47	17	348	99	96	0.19	0.1	5.948	0.069	0	0	0	133
PL.20594	PL.20959	C	6 A (CWC)	7.38Y	123.0	0.00	2.04	1.13	1	8	2	97	0.00	0.0	5.952	0.004	0	0	0	3
PD.2981	PL.20594	C	20T	7.38Y	123.0	0.00	2.04	1.13	0	8	2	97	0.00	0.0	5.952	0.004	0	0	0	3
PL.20595	PD.2981	C	6 A (CWC)	7.38Y	123.0	0.00	2.05	1.13	1	8	2	97	0.00	0.0	6.008	0.056	2	0	2	3
PL.20960	PL.20595	C	6 A (CWC)	7.38Y	123.0	0.00	2.05	0.90	1	6	2	95	0.00	0.0	6.050	0.042	0	0	0	1
PL.20534	PL.20960	C	#1/0 ACSR	7.38Y	123.0	0.00	2.05	0.90	0	6	2	95	0.00	0.0	6.206	0.156	6	2	1	1
PL.20533	PL.20959	A C	6 A (CWC)	7.37Y	122.8	0.15	2.19	23.91	17	339	96	96	0.38	0.1	6.090	0.142	0	0	0	130
PL.20535	PL.20533	A C	6 A (CWC)	7.36Y	122.7	0.08	2.26	23.26	17	330	94	96	0.19	0.1	6.167	0.077	2	1	1	127
PL.20539	PL.20535	A C	6 A (CWC)	7.36Y	122.7	0.02	2.28	22.21	16	315	89	96	0.04	0.0	6.186	0.019	0	0	0	121
PL.20859	PL.20539	A C	6 A (CWC)	7.35Y	122.5	0.19	2.47	22.21	16	315	89	96	0.47	0.1	6.390	0.204	0	0	0	121
PL.20541	PL.20859	A C	6 A (CWC)	7.35Y	122.5	0.03	2.51	22.21	16	314	89	96	0.08	0.0	6.424	0.034	2	0	1	121
PL.20542	PL.20541	A C	6 A (CWC)	7.35Y	122.5	0.03	2.53	22.10	16	313	88	96	0.06	0.0	6.452	0.028	0	0	0	120
PL.20788	PL.20542	A C	6 A (CWC)	7.34Y	122.3	0.16	2.69	22.10	16	312	88	96	0.39	0.1	6.622	0.170	0	0	0	120
PL.20544	PL.20788	A C	6 A (CWC)	7.33Y	122.2	0.07	2.76	21.76	16	307	87	96	0.16	0.1	6.693	0.071	0	0	0	118
PL.20555	PL.20544	A C	6 A (CWC)	7.33Y	122.1	0.11	2.87	21.76	16	307	87	96	0.27	0.1	6.816	0.124	0	0	0	118
PL.20554	PL.20555	A C	6 A (CWC)	7.32Y	122.1	0.06	2.93	21.76	16	307	87	96	0.14	0.0	6.881	0.065	0	0	0	118
PL.20944	PL.20554	A C	6 A (CWC)	7.32Y	122.0	0.08	3.02	20.38	15	287	81	96	0.19	0.1	6.978	0.097	0	0	2	111
PL.21219	PL.20944	A	#1/0 ACSR	7.32Y	122.0	0.00	3.02	0.00	0	0	0	100	0.00	0.0	6.982	0.004	0	0	0	1
PD.3031	PL.21219	A	20T	7.32Y	122.0	0.00	3.02	0.00	0	0	0	100	0.00	0.0	6.982	0.004	0	0	0	1
PL.21220	PD.3031	A	#1/0 ACSR	7.32Y	122.0	0.00	3.02	0.00	0	0	0	100	0.00	0.0	7.005	0.023	0	0	1	1
PL.20945	PL.20944	A C	6 A (CWC)	7.32Y	121.9	0.06	3.08	20.38	15	287	81	96	0.13	0.0	7.046	0.068	2	1	1	108
PL.21155	PL.20945	C	#2 ACSR	7.32Y	121.9	0.00	3.08	0.00	0	0	0	100	0.00	0.0	7.051	0.005	0	0	0	0
PD.2974	PL.21155	C	20T	7.32Y	121.9	0.00	3.08	0.00	0	0	0	100	0.00	0.0	7.051	0.005	0	0	0	0
PL.20579	PD.2974	C	#2 ACSR	7.32Y	121.9	0.00	3.08	0.00	0	0	0	100	0.00	0.0	7.199	0.148	0	0	0	0
PL.20551	PL.20945	A C	6 A (CWC)	7.31Y	121.8	0.13	3.21	20.21	14	285	80	96	0.29	0.1	7.197	0.151	0	0	0	107

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Millers Creek

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru

PL.20556	PL.20551	A C	6 A (CWC)	7.30Y	121.7	0.11	3.32	20.21	14	284	80	96	0.24	0.1	7.324	0.128	2	1	1	107
PL.20552	PL.20556	C	6 A (CWC)	7.30Y	121.6	0.10	3.42	23.18	17	163	46	96	0.12	0.1	7.419	0.094	4	1	1	72
PL.20655	PL.20552	C	6 A (CWC)	7.29Y	121.5	0.12	3.53	22.52	16	158	45	96	0.14	0.1	7.536	0.118	5	1	1	70
PL.20656	PL.20655	C	6 A (CWC)	7.28Y	121.3	0.14	3.68	21.80	16	153	43	96	0.16	0.1	7.679	0.143	5	1	2	68
PL.20658	PL.20656	C	6 A (CWC)	7.27Y	121.2	0.14	3.82	21.06	15	148	42	96	0.16	0.1	7.828	0.148	0	0	0	66
PL.21179	PL.20658	C	6 A (CWC)	7.27Y	121.2	0.00	3.82	18.33	13	128	36	96	0.00	0.0	7.832	0.004	0	0	0	56
PL.21180	PL.21179	C	6 A (CWC)	7.26Y	121.1	0.12	3.94	18.33	13	128	36	96	0.12	0.1	7.979	0.147	5	1	2	56
PL.20663	PL.21180	C	6 A (CWC)	7.26Y	121.0	0.04	3.99	16.81	12	118	33	96	0.04	0.0	8.035	0.056	0	0	0	52
PL.21078	PL.20663	C	6 A (CWC)	7.26Y	121.0	0.05	4.03	16.30	12	114	32	96	0.04	0.0	8.105	0.070	14	4	3	50
PL.21079	PL.21078	C	6 A (CWC)	7.25Y	120.9	0.06	4.09	14.27	10	100	28	96	0.04	0.0	8.196	0.091	12	3	2	47
PL.21080	PL.21079	C	6 A (CWC)	7.25Y	120.9	0.05	4.14	12.50	9	87	25	96	0.03	0.0	8.284	0.089	3	1	1	45
PL.21081	PL.21080	C	6 A (CWC)	7.25Y	120.8	0.04	4.18	12.13	9	85	24	96	0.03	0.0	8.354	0.070	0	0	1	44
PL.20665	PL.21081	C	#2 ACSR	7.25Y	120.8	0.00	4.18	0.48	0	3	1	95	0.00	0.0	8.399	0.044	3	1	1	1
PL.20943	PL.21081	C	6 A (CWC)	7.24Y	120.7	0.07	4.25	11.65	8	81	23	96	0.04	0.1	8.489	0.135	0	0	0	42
PL.20942	PL.20943	C	6 A (CWC)	7.24Y	120.7	0.06	4.32	11.65	8	81	23	96	0.04	0.0	8.610	0.121	2	1	1	42
PL.21083	PL.20942	C	6 A (CWC)	7.24Y	120.6	0.05	4.37	10.76	8	75	21	96	0.03	0.0	8.721	0.110	2	1	1	37
PL.21084	PL.21083	C	6 A (CWC)	7.23Y	120.6	0.08	4.45	10.50	7	73	21	96	0.04	0.1	8.882	0.162	0	0	2	36
PL.20941	PL.21084	C	6 A (CWC)	7.23Y	120.5	0.01	4.45	5.20	4	36	10	96	0.00	0.0	8.915	0.033	0	0	0	18
PL.21249	PL.20941	C	6 A (CWC)	7.23Y	120.5	0.00	4.46	5.20	4	36	10	96	0.00	0.0	8.917	0.003	0	0	0	18
PD.3051	PL.21249	C	25H	7.23Y	120.5	0.00	4.46	5.20	21	36	10	96	0.00	0.0	8.917	0.003	0	0	0	18
PL.21250	PD.3051	C	6 A (CWC)	7.23Y	120.5	0.01	4.46	5.20	4	36	10	96	0.00	0.0	8.943	0.026	4	1	1	18
PL.20939	PL.21250	C	6 A (CWC)	7.23Y	120.5	0.03	4.49	4.56	3	32	9	96	0.01	0.0	9.074	0.131	4	1	2	17
PL.20693	PL.20939	C	#2 ACSR	7.23Y	120.5	0.00	4.49	0.00	0	0	0	100	0.00	0.0	9.149	0.075	0	0	0	0
PL.20562	PL.20693	C	#2 ACSR	7.23Y	120.5	0.00	4.49	0.00	0	0	0	100	0.00	0.0	9.287	0.138	0	0	0	0
PL.20563	PL.20562	C	#2 ACSR	7.23Y	120.5	0.00	4.49	0.00	0	0	0	100	0.00	0.0	9.450	0.163	0	0	0	0
PL.20564	PL.20563	C	#2 ACSR	7.23Y	120.5	0.00	4.49	0.00	0	0	0	100	0.00	0.0	9.552	0.103	0	0	0	0
PL.21092	PL.20564	C	#2 ACSR	7.23Y	120.5	0.00	4.49	0.00	0	0	0	100	0.00	0.0	9.608	0.055	0	0	0	0
PL.21093	PL.21092	C	#2 ACSR	7.23Y	120.5	0.00	4.49	0.00	0	0	0	100	0.00	0.0	9.650	0.042	0	0	0	0
PL.20940	PL.20939	C	6 A (CWC)	7.23Y	120.5	0.02	4.51	3.98	3	28	8	96	0.00	0.0	9.189	0.115	0	0	0	15
PL.20895	PL.20940	C	6 A (CWC)	7.23Y	120.5	0.02	4.52	3.98	3	28	8	96	0.00	0.0	9.276	0.087	0	0	0	15
PL.20565	PL.20895	C	6 A (CWC)	7.23Y	120.4	0.03	4.56	3.98	3	28	8	96	0.01	0.0	9.461	0.185	0	0	0	15

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Millers Creek

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru

PL.21090	PL.20565	C	6 A (CWC)	7.23Y	120.4	0.02	4.57	3.98	3	28	8	96	0.00	0.0	9.544	0.083	0	0	1	15
PL.21091	PL.21090	C	6 A (CWC)	7.22Y	120.4	0.02	4.59	3.95	3	27	8	96	0.00	0.0	9.659	0.115	0	0	0	14
PL.20793	PL.21091	C	6 A (CWC)	7.22Y	120.4	0.02	4.61	2.98	2	21	6	96	0.00	0.0	9.815	0.156	0	0	0	9
PL.21104	PL.20793	C	6 A (CWC)	7.22Y	120.4	0.02	4.63	2.37	2	17	5	96	0.00	0.0	9.993	0.178	0	0	0	8
PL.21105	PL.21104	C	6 A (CWC)	7.22Y	120.4	0.01	4.64	2.37	2	17	5	96	0.00	0.0	10.044	0.051	0	0	0	8
PL.21259	PL.21105	C	6 A (CWC)	7.22Y	120.4	0.00	4.64	0.76	1	5	1	98	0.00	0.0	10.046	0.003	0	0	0	2
PD.3056	PL.21259	C	20T	7.22Y	120.4	0.00	4.64	0.76	0	5	1	98	0.00	0.0	10.046	0.003	0	0	0	2
PL.21260	PD.3056	C	6 A (CWC)	7.22Y	120.4	0.00	4.64	0.76	1	5	1	98	0.00	0.0	10.149	0.102	0	0	0	2
PL.21107	PL.21260	C	6 A (CWC)	7.22Y	120.4	0.00	4.65	0.76	1	5	1	98	0.00	0.0	10.243	0.095	0	0	1	2
PL.21108	PL.21107	C	6 A (CWC)	7.22Y	120.4	0.00	4.65	0.75	1	5	1	98	0.00	0.0	10.352	0.108	0	0	0	1
PL.20573	PL.21108	C	6 A (CWC)	7.22Y	120.3	0.00	4.65	0.75	1	5	1	98	0.00	0.0	10.496	0.144	0	0	0	1
PL.20684	PL.20573	C	#4 ACSR	7.22Y	120.3	0.01	4.66	0.75	1	5	1	98	0.00	0.0	10.682	0.186	0	0	0	1
PL.20685	PL.20684	C	6 A (CWC)	7.22Y	120.3	0.00	4.66	0.75	1	5	1	98	0.00	0.0	10.748	0.066	0	0	0	1
PL.20574	PL.20685	C	6 A (CWC)	7.22Y	120.3	0.00	4.67	0.75	1	5	1	98	0.00	0.0	10.874	0.126	0	0	0	1
PL.21102	PL.20574	C	6 A (CWC)	7.22Y	120.3	0.00	4.67	0.75	1	5	1	98	0.00	0.0	10.940	0.067	0	0	0	1
PL.21103	PL.21102	C	#4 ACSR	7.22Y	120.3	0.01	4.68	0.75	1	5	1	98	0.00	0.0	11.099	0.159	0	0	0	1
PL.21100	PL.21103	C	#4 ACSR	7.22Y	120.3	0.00	4.68	0.75	1	5	1	98	0.00	0.0	11.178	0.079	0	0	0	1
PL.21101	PL.21100	C	#4 ACSR	7.22Y	120.3	0.00	4.68	0.75	1	5	1	98	0.00	0.0	11.234	0.056	0	0	0	1
PL.21098	PL.21101	C	6 A (CWC)	7.22Y	120.3	0.00	4.68	0.75	1	5	1	98	0.00	0.0	11.327	0.093	5	1	1	1
PL.20686	PL.21101	C	6 A (CWC)	7.22Y	120.3	0.00	4.68	0.00	0	0	0	100	0.00	0.0	11.286	0.052	0	0	0	0
PL.21257	PL.21105	C	6 A (CWC)	7.22Y	120.4	0.00	4.64	1.62	1	11	3	96	0.00	0.0	10.046	0.003	0	0	0	6
PD.3055	PL.21257	C	20T	7.22Y	120.4	0.00	4.64	1.62	0	11	3	96	0.00	0.0	10.046	0.003	0	0	0	6
PL.21258	PD.3055	C	6 A (CWC)	7.22Y	120.4	0.01	4.64	1.62	1	11	3	96	0.00	0.0	10.160	0.114	8	2	1	6
PL.21106	PL.21258	C	6 A (CWC)	7.22Y	120.4	0.00	4.65	0.43	0	3	1	95	0.00	0.0	10.297	0.137	0	0	0	5
PL.20937	PL.21106	C	6 A (CWC)	7.22Y	120.4	0.00	4.65	0.43	0	3	1	95	0.00	0.0	10.381	0.084	0	0	0	5
PL.20938	PL.20937	C	6 A (CWC)	7.22Y	120.3	0.00	4.65	0.43	0	3	1	95	0.00	0.0	10.428	0.047	0	0	0	5
PL.20576	PL.20938	C	6 A (CWC)	7.22Y	120.3	0.00	4.65	0.43	0	3	1	95	0.00	0.0	10.592	0.164	0	0	0	5
PL.21195	PL.20576	C	6 A (CWC)	7.22Y	120.3	0.00	4.66	0.31	0	2	1	89	0.00	0.0	10.755	0.163	0	0	0	3
PD.3019	PL.21195	C	8T	7.22Y	120.3	0.00	4.66	0.31	0	2	1	89	0.00	0.0	10.755	0.163	0	0	0	3
PL.21196	PD.3019	C	6 A (CWC)	7.22Y	120.3	0.00	4.66	0.31	0	2	1	89	0.00	0.0	10.873	0.118	0	0	0	3
PL.20577	PL.21196	C	6 A (CWC)	7.22Y	120.3	0.00	4.66	0.31	0	2	1	89	0.00	0.0	10.986	0.112	0	0	0	3

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Millers Creek

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.20578	PL.20577	C	6 A (CWC)	7.22Y	120.3	0.00	4.66	0.31	0	2	1	89	0.00	0.0	11.107	0.122	2	1	3	3
PL.20680	PL.20576	C	6 A (CWC)	7.22Y	120.3	0.00	4.65	0.12	0	1	0	100	0.00	0.0	10.620	0.028	1	0	2	2
PL.20682	PL.20937	C	6 A (CWC)	7.22Y	120.4	0.00	4.65	0.00	0	0	0	100	0.00	0.0	10.464	0.083	0	0	0	0
PL.21109	PL.20682	C	#4 ACSR	7.22Y	120.4	0.00	4.65	0.00	0	0	0	100	0.00	0.0	10.581	0.117	0	0	0	0
PL.21110	PL.21109	C	#4 ACSR	7.22Y	120.4	0.00	4.65	0.00	0	0	0	100	0.00	0.0	10.714	0.133	0	0	0	0
PL.21111	PL.21110	C	#4 ACSR	7.22Y	120.4	0.00	4.65	0.00	0	0	0	100	0.00	0.0	10.826	0.111	0	0	0	0
PL.20862	PL.21111	C	#4 ACSR	7.22Y	120.4	0.00	4.65	0.00	0	0	0	100	0.00	0.0	10.937	0.111	0	0	0	0
PL.20683	PL.20862	C	6 A (CWC)	7.22Y	120.4	0.00	4.65	0.00	0	0	0	100	0.00	0.0	11.121	0.184	0	0	0	0
PL.20681	PL.21106	C	6 A (CWC)	7.22Y	120.4	0.00	4.65	0.00	0	0	0	100	0.00	0.0	10.422	0.125	0	0	0	0
PL.20688	PL.20793	C	#4 ACSR	7.22Y	120.4	0.00	4.61	0.61	0	4	1	97	0.00	0.0	9.844	0.030	4	1	1	1
PL.21193	PL.21091	C	6 A (CWC)	7.22Y	120.4	0.00	4.59	0.97	1	7	2	96	0.00	0.0	9.663	0.005	0	0	0	5
PD.3018	PL.21193	C	10T	7.22Y	120.4	0.00	4.59	0.97	0	7	2	96	0.00	0.0	9.663	0.005	0	0	0	5
PL.21194	PD.3018	C	6 A (CWC)	7.22Y	120.4	0.00	4.60	0.97	1	7	2	96	0.00	0.0	9.769	0.106	0	0	0	5
PL.20896	PL.21194	C	6 A (CWC)	7.22Y	120.4	0.00	4.60	0.97	1	7	2	96	0.00	0.0	9.865	0.096	0	0	0	5
PL.20566	PL.20896	C	6 A (CWC)	7.22Y	120.4	0.01	4.61	0.97	1	7	2	96	0.00	0.0	10.012	0.147	0	0	0	5
PL.20567	PL.20566	C	6 A (CWC)	7.22Y	120.4	0.00	4.61	0.97	1	7	2	96	0.00	0.0	10.124	0.112	0	0	0	5
PL.20568	PL.20567	C	6 A (CWC)	7.22Y	120.4	0.00	4.62	0.97	1	7	2	96	0.00	0.0	10.234	0.110	0	0	0	5
PL.21075	PL.20568	C	6 A (CWC)	7.22Y	120.4	0.00	4.62	0.60	0	4	1	97	0.00	0.0	10.341	0.107	0	0	1	4
PL.21076	PL.21075	C	6 A (CWC)	7.22Y	120.4	0.01	4.63	0.60	0	4	1	97	0.00	0.0	10.529	0.188	0	0	0	3
PL.20569	PL.21076	C	6 A (CWC)	7.22Y	120.4	0.00	4.63	0.60	0	4	1	97	0.00	0.0	10.621	0.093	0	0	0	3
PL.20950	PL.20569	C	6 A (CWC)	7.22Y	120.4	0.00	4.63	0.60	0	4	1	97	0.00	0.0	10.732	0.110	0	0	1	3
PL.20951	PL.20950	C	6 A (CWC)	7.22Y	120.4	0.00	4.63	0.39	0	3	1	95	0.00	0.0	10.878	0.146	0	0	0	1
PL.20570	PL.20951	C	6 A (CWC)	7.22Y	120.4	0.00	4.64	0.39	0	3	1	95	0.00	0.0	10.972	0.094	0	0	0	1
PL.20689	PL.20570	C	#4 ACSR	7.22Y	120.4	0.00	4.64	0.39	0	3	1	95	0.00	0.0	11.079	0.106	0	0	0	1
PL.20572	PL.20689	C	#4 ACSR	7.22Y	120.4	0.00	4.64	0.39	0	3	1	95	0.00	0.0	11.174	0.095	0	0	0	1
PL.20571	PL.20572	C	#4 ACSR	7.22Y	120.4	0.00	4.64	0.39	0	3	1	95	0.00	0.0	11.253	0.079	3	1	1	1
PL.20690	PL.20950	C	#4 ACSR	7.22Y	120.4	0.00	4.63	0.21	0	1	0	100	0.00	0.0	10.777	0.046	1	0	1	1
PL.20691	PL.20568	C	6 A (CWC)	7.22Y	120.4	0.00	4.62	0.37	0	3	1	95	0.00	0.0	10.348	0.115	0	0	0	1
PL.20692	PL.20691	C	#2 ACSR	7.22Y	120.4	0.00	4.62	0.37	0	3	1	95	0.00	0.0	10.371	0.022	3	1	1	1
PL.20667	PL.21084	C	6 A (CWC)	7.23Y	120.6	0.00	4.45	2.86	2	20	6	96	0.00	0.0	8.903	0.021	0	0	0	12
PD.3050	PL.20667	C	25H	7.23Y	120.6	0.00	4.45	2.86	11	20	6	96	0.00	0.0	8.903	0.021	0	0	0	12

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Millers Creek

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.21086	PD.3050	C	6 A (CWC)	7.23Y	120.5	0.01	4.46	2.86	2	20	6	96	0.00	0.0	9.000	0.096	0	0	0	12
PL.21087	PL.21086	C	6 A (CWC)	7.23Y	120.5	0.01	4.47	2.86	2	20	6	96	0.00	0.0	9.085	0.085	0	0	0	12
PL.20560	PL.21087	C	6 A (CWC)	7.23Y	120.5	0.02	4.49	2.86	2	20	6	96	0.00	0.0	9.238	0.153	0	0	1	12
PL.20668	PL.20560	C	6 A (CWC)	7.23Y	120.5	0.00	4.49	0.44	0	3	1	95	0.00	0.0	9.351	0.114	3	1	2	2
PL.20669	PL.20560	C	6 A (CWC)	7.23Y	120.5	0.01	4.50	2.41	2	17	5	96	0.00	0.0	9.311	0.073	0	0	0	9
PL.20670	PL.20669	C	#4 ACSR	7.23Y	120.5	0.00	4.50	0.43	0	3	1	95	0.00	0.0	9.372	0.061	3	1	1	1
PL.21088	PL.20669	C	6 A (CWC)	7.23Y	120.5	0.01	4.52	1.98	1	14	4	96	0.00	0.0	9.466	0.155	0	0	0	8
PL.21089	PL.21088	C	6 A (CWC)	7.23Y	120.5	0.00	4.52	1.98	1	14	4	96	0.00	0.0	9.523	0.058	2	1	1	8
PL.20671	PL.21089	C	#4 ACSR	7.23Y	120.5	0.00	4.52	0.45	0	3	1	95	0.00	0.0	9.625	0.101	0	0	0	1
PL.20561	PL.20671	C	#4 ACSR	7.23Y	120.5	0.00	4.52	0.45	0	3	1	95	0.00	0.0	9.749	0.124	3	1	1	1
PL.20931	PL.21089	C	6 A (CWC)	7.23Y	120.5	0.01	4.53	1.21	1	8	2	97	0.00	0.0	9.646	0.122	3	1	1	6
PL.20932	PL.20931	C	6 A (CWC)	7.23Y	120.5	0.00	4.53	0.72	1	5	1	98	0.00	0.0	9.785	0.139	0	0	0	3
PL.20673	PL.20932	C	6 A (CWC)	7.23Y	120.5	0.00	4.53	0.72	1	5	1	98	0.00	0.0	9.864	0.079	0	0	0	3
PL.20792	PL.20673	C	6 A (CWC)	7.23Y	120.5	0.00	4.53	0.72	1	5	1	98	0.00	0.0	9.918	0.053	1	0	2	3
PL.20675	PL.20792	C	#4 ACSR	7.23Y	120.5	0.00	4.54	0.55	0	4	1	97	0.00	0.0	10.055	0.137	4	1	1	1
PL.20672	PL.20931	C	#2 ACSR	7.23Y	120.5	0.00	4.53	0.06	0	0	0	100	0.00	0.0	9.673	0.027	0	0	2	2
PL.21191	PL.21084	C	6 A (CWC)	7.23Y	120.6	0.00	4.45	2.41	2	17	5	96	0.00	0.0	8.887	0.005	0	0	0	4
PD.3017	PL.21191	C	20T	7.23Y	120.6	0.00	4.45	2.41	0	17	5	96	0.00	0.0	8.887	0.005	0	0	0	4
PL.21192	PD.3017	C	6 A (CWC)	7.23Y	120.5	0.00	4.45	2.41	2	17	5	96	0.00	0.0	8.914	0.027	3	1	1	4
PL.21085	PL.21192	C	6 A (CWC)	7.23Y	120.5	0.01	4.46	2.02	1	14	4	96	0.00	0.0	8.973	0.059	0	0	0	3
PL.20694	PL.21085	C	6 A (CWC)	7.23Y	120.5	0.00	4.46	2.02	1	14	4	96	0.00	0.0	9.022	0.049	14	4	3	3
PL.20695	PL.20694	C	#2 ACSR	7.23Y	120.5	0.00	4.46	0.00	0	0	0	100	0.00	0.0	9.130	0.108	0	0	0	0
PL.21189	PL.20942	C	6 A (CWC)	7.24Y	120.7	0.00	4.32	0.60	0	4	1	97	0.00	0.0	8.615	0.005	0	0	0	4
PD.3016	PL.21189	C	20T	7.24Y	120.7	0.00	4.32	0.60	0	4	1	97	0.00	0.0	8.615	0.005	0	0	0	4
PL.21190	PD.3016	C	6 A (CWC)	7.24Y	120.7	0.00	4.32	0.60	0	4	1	97	0.00	0.0	8.736	0.121	2	1	1	4
PL.21082	PL.21190	C	6 A (CWC)	7.24Y	120.7	0.00	4.32	0.28	0	2	1	89	0.00	0.0	8.755	0.018	0	0	0	3
PL.20666	PL.21082	C	#4 ACSR	7.24Y	120.7	0.00	4.32	0.00	0	0	0	100	0.00	0.0	8.807	0.052	0	0	0	0
PL.20791	PL.21082	C	6 A (CWC)	7.24Y	120.7	0.00	4.32	0.28	0	2	1	89	0.00	0.0	8.829	0.074	1	0	1	3
PL.32691	PL.20791	C	#1/0 ACSR	7.24Y	120.7	0.00	4.32	0.17	0	1	0	100	0.00	0.0	8.858	0.029	1	0	1	2
PL.32692	PL.32691	C	#1/0 ACSR	7.24Y	120.7	0.00	4.32	0.01	0	0	0	100	0.00	0.0	8.904	0.046	0	0	1	1
PL.21221	PL.20663	C	#4 ACSR	7.26Y	121.0	0.00	3.99	0.51	0	4	1	97	0.00	0.0	8.039	0.004	0	0	0	2

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Millers Creek

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PD.3032	PL.21221	C	20T	7.26Y	121.0	0.00	3.99	0.51	0	4	1	97	0.00	0.0	8.039	0.004	0	0	0	2
PL.21222	PD.3032	C	#4 ACSR	7.26Y	121.0	0.00	3.99	0.51	0	4	1	97	0.00	0.0	8.204	0.165	0	0	0	2
PL.20660	PL.21222	C	#4 ACSR	7.26Y	121.0	0.00	3.99	0.51	0	4	1	97	0.00	0.0	8.361	0.157	0	0	0	2
PL.20659	PL.20660	C	#4 ACSR	7.26Y	121.0	0.00	3.99	0.00	0	0	0	100	0.00	0.0	8.428	0.066	0	0	0	0
PL.20946	PL.20660	C	#4 ACSR	7.26Y	121.0	0.00	3.99	0.51	0	4	1	97	0.00	0.0	8.425	0.064	4	1	1	2
PL.20947	PL.20946	C	#4 ACSR	7.26Y	121.0	0.00	3.99	0.00	0	0	0	100	0.00	0.0	8.495	0.070	0	0	0	1
PL.20662	PL.20947	C	#4 ACSR	7.26Y	121.0	0.00	3.99	0.00	0	0	0	100	0.00	0.0	8.604	0.109	0	0	1	1
PL.21183	PL.21180	C	6 A (CWC)	7.26Y	121.1	0.00	3.94	0.77	1	5	2	93	0.00	0.0	7.984	0.005	0	0	0	2
PD.3013	PL.21183	C	20T	7.26Y	121.1	0.00	3.94	0.77	0	5	2	93	0.00	0.0	7.984	0.005	0	0	0	2
PL.21184	PD.3013	C	6 A (CWC)	7.26Y	121.1	0.00	3.95	0.77	1	5	2	93	0.00	0.0	8.078	0.094	1	0	1	2
PL.20664	PL.21184	C	#2 ACSR	7.26Y	121.1	0.00	3.95	0.68	0	5	1	98	0.00	0.0	8.096	0.018	5	1	1	1
PL.21181	PL.20658	C	6 A (CWC)	7.27Y	121.2	0.00	3.82	2.73	2	19	5	97	0.00	0.0	7.832	0.004	0	0	0	10
PD.3012	PL.21181	C	20T	7.27Y	121.2	0.00	3.82	2.73	0	19	5	97	0.00	0.0	7.832	0.004	0	0	0	10
PL.21182	PD.3012	C	6 A (CWC)	7.27Y	121.2	0.01	3.82	2.73	2	19	5	97	0.00	0.0	7.882	0.049	3	1	2	10
PL.21077	PL.21182	C	6 A (CWC)	7.27Y	121.2	0.00	3.83	2.34	2	16	5	95	0.00	0.0	7.923	0.042	2	1	2	8
PL.21068	PL.21077	C	6 A (CWC)	7.27Y	121.2	0.00	3.83	2.02	1	14	4	96	0.00	0.0	7.968	0.045	3	1	4	6
PL.21073	PL.21068	C	6 A (CWC)	7.27Y	121.2	0.00	3.83	1.62	1	11	3	96	0.00	0.0	7.987	0.019	9	3	1	2
PL.21074	PL.21073	C	6 A (CWC)	7.27Y	121.2	0.00	3.83	0.32	0	2	1	89	0.00	0.0	8.036	0.048	2	1	1	1
PL.20657	PL.20655	C	#4 ACSR	7.29Y	121.5	0.00	3.53	0.05	0	0	0	100	0.00	0.0	7.556	0.020	0	0	1	1
PL.21235	PL.20552	C	#4 ACSR	7.30Y	121.6	0.00	3.42	0.04	0	0	0	100	0.00	0.0	7.423	0.005	0	0	0	1
PD.3043	PL.21235	C	20T	7.30Y	121.6	0.00	3.42	0.04	0	0	0	100	0.00	0.0	7.423	0.005	0	0	0	1
PL.21236	PD.3043	C	#4 ACSR	7.30Y	121.6	0.00	3.42	0.04	0	0	0	100	0.00	0.0	7.452	0.029	0	0	1	1
PL.21146	PL.20556	A	6 A (CWC)	7.30Y	121.6	0.04	3.36	16.98	12	119	34	96	0.03	0.0	7.377	0.052	8	2	1	34
PL.21147	PL.21146	A	6 A (CWC)	7.30Y	121.6	0.01	3.37	15.82	11	111	31	96	0.01	0.0	7.395	0.018	4	1	1	33
PL.21244	PL.21147	A	6 A (CWC)	7.29Y	121.6	0.07	3.44	15.31	11	108	30	96	0.06	0.1	7.504	0.110	7	2	2	32
PL.20957	PL.21244	A	6 A (CWC)	7.29Y	121.5	0.09	3.53	14.27	10	100	28	96	0.06	0.1	7.643	0.139	9	3	1	30
PL.20958	PL.20957	A	6 A (CWC)	7.29Y	121.4	0.04	3.57	12.92	9	91	25	96	0.03	0.0	7.713	0.069	0	0	0	29
PL.20948	PL.20958	A	6 A (CWC)	7.28Y	121.3	0.09	3.66	12.92	9	91	25	96	0.06	0.1	7.869	0.156	1	0	3	29
PL.20955	PL.20948	A	#4 ACSR	7.28Y	121.3	0.03	3.69	10.39	8	73	20	96	0.02	0.0	7.935	0.067	11	3	2	19
PL.20956	PL.20955	A	#4 ACSR	7.28Y	121.3	0.04	3.73	8.87	7	62	17	96	0.02	0.0	8.028	0.093	2	1	1	17
PL.20637	PL.20956	A	#4 ACSR	7.28Y	121.3	0.02	3.75	8.60	7	60	17	96	0.01	0.0	8.079	0.051	4	1	1	16

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Millers Creek

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.20580	PL.20637	A	#4 ACSR	7.28Y	121.3	0.00	3.75	7.97	6	56	16	96	0.00	0.0	8.084	0.004	0	0	0	15
PD.2975	PL.20580	A	12T	7.28Y	121.3	0.00	3.75	7.97	0	56	16	96	0.00	0.0	8.084	0.004	0	0	0	15
PL.20581	PD.2975	A	#4 ACSR	7.27Y	121.2	0.01	3.76	7.97	6	56	16	96	0.00	0.0	8.109	0.025	5	2	2	15
PL.20952	PL.20581	A	#4 ACSR	7.27Y	121.2	0.02	3.77	6.66	5	47	13	96	0.01	0.0	8.165	0.056	5	1	1	11
PL.20639	PL.20952	A	#4 ACSR	7.27Y	121.2	0.00	3.77	0.77	1	5	2	93	0.00	0.0	8.233	0.068	0	0	0	1
PL.20654	PL.20639	A	#4 ACSR	7.27Y	121.2	0.00	3.78	0.77	1	5	2	93	0.00	0.0	8.315	0.081	5	2	1	1
PL.20640	PL.20952	A	#4 ACSR	7.27Y	121.2	0.02	3.80	5.21	4	36	10	96	0.01	0.0	8.270	0.105	0	0	0	9
PL.20558	PL.20640	A	#4 ACSR	7.27Y	121.2	0.02	3.82	5.21	4	36	10	96	0.01	0.0	8.374	0.104	0	0	0	9
PL.20641	PL.20558	A	#4 ACSR	7.27Y	121.2	0.00	3.82	0.40	0	3	1	95	0.00	0.0	8.469	0.095	3	1	2	2
PL.20642	PL.20558	A	#4 ACSR	7.27Y	121.2	0.02	3.84	4.81	4	34	9	97	0.01	0.0	8.487	0.113	0	0	0	7
PL.20643	PL.20642	A	#4 ACSR	7.27Y	121.1	0.01	3.86	4.81	4	34	9	97	0.00	0.0	8.554	0.067	0	0	1	7
PL.20646	PL.20643	A	#4 ACSR	7.27Y	121.1	0.00	3.86	0.89	1	6	2	95	0.00	0.0	8.647	0.093	6	2	1	1
PL.20644	PL.20643	A	#4 ACSR	7.27Y	121.1	0.00	3.86	3.87	3	27	8	96	0.00	0.0	8.565	0.011	0	0	0	5
PL.20645	PL.20644	A	#4 ACSR	7.27Y	121.1	0.00	3.86	0.81	1	6	2	95	0.00	0.0	8.676	0.110	6	2	1	1
PL.21069	PL.20644	A	#4 ACSR	7.27Y	121.1	0.00	3.86	3.06	2	21	6	96	0.00	0.0	8.589	0.024	15	4	2	4
PL.21070	PL.21069	A	#4 ACSR	7.27Y	121.1	0.01	3.87	0.87	1	6	2	95	0.00	0.0	8.755	0.166	0	0	0	2
PL.20559	PL.21070	A	#4 ACSR	7.27Y	121.1	0.01	3.88	0.87	1	6	2	95	0.00	0.0	8.930	0.176	0	0	0	2
PL.20647	PL.20559	A	#4 ACSR	7.27Y	121.1	0.01	3.88	0.87	1	6	2	95	0.00	0.0	9.109	0.179	0	0	0	2
PL.21071	PL.20647	A	#4 ACSR	7.27Y	121.1	0.00	3.89	0.87	1	6	2	95	0.00	0.0	9.249	0.140	5	2	1	2
PL.21072	PL.21071	A	#4 ACSR	7.27Y	121.1	0.00	3.89	0.09	0	1	0	100	0.00	0.0	9.399	0.150	1	0	1	1
PL.20638	PL.20581	A	#4 ACSR	7.27Y	121.2	0.00	3.76	0.52	0	4	1	97	0.00	0.0	8.176	0.067	4	1	2	2
PL.20949	PL.20948	A	6 A (CWC)	7.28Y	121.3	0.02	3.68	1.51	1	11	3	96	0.00	0.0	8.116	0.247	0	0	0	5
PL.21144	PL.20949	A	#4 ACSR	7.28Y	121.3	0.00	3.68	0.71	1	5	1	98	0.00	0.0	8.167	0.052	0	0	1	3
PL.21145	PL.21144	A	#4 ACSR	7.28Y	121.3	0.00	3.68	0.69	1	5	1	98	0.00	0.0	8.280	0.113	5	1	2	2
PL.20768	PL.20949	A	6 A (CWC)	7.28Y	121.3	0.01	3.68	0.81	1	6	2	95	0.00	0.0	8.349	0.233	4	1	1	2
PL.20648	PL.20768	A	#2 ACSR	7.28Y	121.3	0.00	3.68	0.26	0	2	1	89	0.00	0.0	8.364	0.015	2	1	1	1
PL.20649	PL.20768	A	#4 ACSR	7.28Y	121.3	0.00	3.68	0.00	0	0	0	100	0.00	0.0	8.528	0.179	0	0	0	0
PL.20652	PL.20649	A	6 A (CWC)	7.28Y	121.3	0.00	3.68	0.00	0	0	0	100	0.00	0.0	8.688	0.160	0	0	0	0
PL.20953	PL.20948	A	6 A (CWC)	7.28Y	121.3	0.00	3.66	0.44	0	3	1	95	0.00	0.0	7.964	0.095	0	0	0	1
PL.20954	PL.20953	A	6 A (CWC)	7.28Y	121.3	0.00	3.66	0.44	0	3	1	95	0.00	0.0	8.011	0.047	0	0	0	1
PL.20634	PL.20954	A	6 A (CWC)	7.28Y	121.3	0.00	3.67	0.44	0	3	1	95	0.00	0.0	8.127	0.116	0	0	0	1

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Millers Creek

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru

PL.20635	PL.20634	A	#4 ACSR	7.28Y	121.3	0.00	3.67	0.00	0	0	0	100	0.00	0.0	8.186	0.059	0	0	0	0
PL.20790	PL.20634	A	6 A (CWC)	7.28Y	121.3	0.00	3.67	0.44	0	3	1	95	0.00	0.0	8.263	0.137	0	0	0	1
PL.20557	PL.20790	A	6 A (CWC)	7.28Y	121.3	0.00	3.67	0.44	0	3	1	95	0.00	0.0	8.326	0.062	0	0	0	1
PL.20636	PL.20557	A	#4 ACSR	7.28Y	121.3	0.00	3.67	0.44	0	3	1	95	0.00	0.0	8.474	0.148	3	1	1	1
PL.20650	PL.20557	A	6 A (CWC)	7.28Y	121.3	0.00	3.67	0.00	0	0	0	100	0.00	0.0	8.363	0.038	0	0	0	0
PL.20631	PL.20948	A	#4 ACSR	7.28Y	121.3	0.00	3.66	0.42	0	3	1	95	0.00	0.0	7.998	0.129	0	0	0	1
PL.20632	PL.20631	A	#4 ACSR	7.28Y	121.3	0.00	3.67	0.42	0	3	1	95	0.00	0.0	8.142	0.145	3	1	1	1
PL.20590	PL.20554	A	6 A (CWC)	7.32Y	122.1	0.00	2.93	2.75	2	19	5	97	0.00	0.0	6.886	0.005	0	0	0	7
PD.2979	PL.20590	A	20T	7.32Y	122.1	0.00	2.93	2.75	0	19	5	97	0.00	0.0	6.886	0.005	0	0	0	7
PL.20591	PD.2979	A	6 A (CWC)	7.32Y	122.0	0.02	2.96	2.75	2	19	5	97	0.00	0.0	7.059	0.174	0	0	0	7
PL.20546	PL.20591	A	6 A (CWC)	7.32Y	122.0	0.00	2.96	0.60	0	4	1	97	0.00	0.0	7.140	0.080	3	1	1	4
PL.20550	PL.20546	A	#2 ACSR	7.32Y	122.0	0.00	2.96	0.19	0	1	0	100	0.00	0.0	7.164	0.024	1	0	3	3
PL.20548	PL.20591	A	#4 ACSR	7.32Y	122.0	0.00	2.96	2.15	2	15	4	97	0.00	0.0	7.096	0.037	0	0	0	3
PL.20789	PL.20548	A	#4 ACSR	7.32Y	122.0	0.00	2.96	1.15	1	8	2	97	0.00	0.0	7.183	0.087	0	0	0	2
PL.20549	PL.20789	A	#4 ACSR	7.32Y	122.0	0.00	2.97	1.15	1	8	2	97	0.00	0.0	7.280	0.097	3	1	1	2
PL.20769	PL.20549	A	#4 ACSR	7.32Y	122.0	0.00	2.97	0.72	1	5	1	98	0.00	0.0	7.378	0.098	5	1	1	1
PL.20586	PL.20548	A	#1/0 ACSR	7.32Y	122.0	0.00	2.96	1.00	0	7	2	96	0.00	0.0	7.101	0.005	0	0	0	1
PD.2977	PL.20586	A	12T	7.32Y	122.0	0.00	2.96	1.00	0	7	2	96	0.00	0.0	7.101	0.005	0	0	0	1
PL.20587	PD.2977	A	#1/0 ACSR	7.32Y	122.0	0.00	2.96	1.00	0	7	2	96	0.00	0.0	7.157	0.056	7	2	1	1
PL.20588	PL.20788	C	6 A (CWC)	7.34Y	122.3	0.00	2.69	0.68	0	5	1	98	0.00	0.0	6.627	0.005	0	0	0	2
PD.2978	PL.20588	C	20T	7.34Y	122.3	0.00	2.69	0.68	0	5	1	98	0.00	0.0	6.627	0.005	0	0	0	2
PL.20589	PD.2978	C	6 A (CWC)	7.34Y	122.3	0.00	2.70	0.68	0	5	1	98	0.00	0.0	6.705	0.078	2	0	1	2
PL.20545	PL.20589	C	#4 ACSR	7.34Y	122.3	0.00	2.70	0.44	0	3	1	95	0.00	0.0	6.813	0.108	0	0	0	1
PL.20861	PL.20545	C	#4 ACSR	7.34Y	122.3	0.00	2.70	0.44	0	3	1	95	0.00	0.0	6.929	0.116	0	0	0	1
PL.20553	PL.20861	C	#4 ACSR	7.34Y	122.3	0.00	2.70	0.44	0	3	1	95	0.00	0.0	6.971	0.042	3	1	1	1
PL.20537	PL.20535	C	#2 ACSR	7.36Y	122.7	0.00	2.26	1.81	1	13	4	96	0.00	0.0	6.172	0.005	0	0	0	5
PD.3040	PL.20537	C	20T	7.36Y	122.7	0.00	2.26	1.81	0	13	4	96	0.00	0.0	6.172	0.005	0	0	0	5
PL.20933	PD.3040	C	#1/0 ACSR	7.36Y	122.7	0.00	2.26	0.34	0	2	1	89	0.00	0.0	6.176	0.004	0	0	0	1
PL.20934	PL.20933	C	#1/0 ACSR	7.36Y	122.7	0.00	2.26	0.34	0	2	1	89	0.00	0.0	6.176	0.000	0	0	0	1
PL.20536	PL.20934	C	#1/0 ACSR	7.36Y	122.7	0.00	2.26	0.34	0	2	1	89	0.00	0.0	6.210	0.034	2	1	1	1
PL.20935	PD.3040	C	6 A (CWC)	7.36Y	122.7	0.00	2.26	0.50	0	4	1	97	0.00	0.0	6.182	0.010	0	0	0	3

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Millers Creek

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.20936	PL.20935	C	6 A (CWC)	7.36Y	122.7	0.00	2.26	0.50	0	4	1	97	0.00	0.0	6.182	0.000	0	0	0	3
PL.20538	PL.20936	C	6 A (CWC)	7.36Y	122.7	0.00	2.27	0.50	0	4	1	97	0.00	0.0	6.259	0.077	2	0	1	3
PL.20540	PL.20538	C	#4 ACSR	7.36Y	122.7	0.00	2.27	0.28	0	2	1	89	0.00	0.0	6.300	0.041	2	1	2	2
PL.20787	PD.3040	C	#2 ACSR	7.36Y	122.7	0.00	2.27	0.98	1	7	2	96	0.00	0.0	6.230	0.058	7	2	1	1
PL.20592	PL.20533	C	6 A (CWC)	7.37Y	122.8	0.00	2.19	1.29	1	9	3	95	0.00	0.0	6.095	0.004	0	0	0	3
PD.2980	PL.20592	C	20T	7.37Y	122.8	0.00	2.19	1.29	0	9	3	95	0.00	0.0	6.095	0.004	0	0	0	3
PL.20593	PD.2980	C	6 A (CWC)	7.37Y	122.8	0.00	2.19	1.29	1	9	3	95	0.00	0.0	6.142	0.047	9	3	3	3
PL.21187	PL.20925	C	6 A (CWC)	7.43Y	123.8	0.00	1.15	0.00	0	0	0	100	0.00	0.0	4.564	0.005	0	0	0	2
PD.3015	PL.21187	C	50T	7.43Y	123.8	0.00	1.15	0.00	0	0	0	100	0.00	0.0	4.564	0.005	0	0	0	2
PL.21188	PD.3015	C	6 A (CWC)	7.43Y	123.8	0.00	1.15	0.00	0	0	0	100	0.00	0.0	4.720	0.156	0	0	0	2
PL.20853	PL.21188	C	6 A (CWC)	7.43Y	123.8	0.00	1.15	0.00	0	0	0	100	0.00	0.0	4.858	0.138	0	0	0	2
PL.20854	PL.20853	C	6 A (CWC)	7.43Y	123.8	0.00	1.15	0.00	0	0	0	100	0.00	0.0	5.014	0.156	0	0	1	2
PL.20529	PL.20854	C	6 A (CWC)	7.43Y	123.8	0.00	1.15	0.00	0	0	0	100	0.00	0.0	5.217	0.203	0	0	0	1
PL.20855	PL.20529	C	6 A (CWC)	7.43Y	123.8	0.00	1.15	0.00	0	0	0	100	0.00	0.0	5.302	0.085	0	0	1	1
PL.21114	PL.20844	B	6 A (CWC)	7.38Y	122.9	0.01	2.07	1.41	1	10	3	96	0.00	0.0	3.555	0.161	2	1	1	5
PL.21251	PL.21114	B	6 A (CWC)	7.38Y	122.9	0.00	2.07	1.12	1	8	2	97	0.00	0.0	3.557	0.003	0	0	0	4
PD.3052	PL.21251	B	35L	7.38Y	122.9	0.00	2.07	1.12	3	8	2	97	0.00	0.0	3.557	0.003	0	0	0	4
PL.21252	PD.3052	B	6 A (CWC)	7.38Y	122.9	0.00	2.08	1.12	1	8	2	97	0.00	0.0	3.649	0.092	0	0	0	4
PL.19375	PL.21252	B	6 A (CWC)	7.38Y	122.9	0.01	2.08	1.12	1	8	2	97	0.00	0.0	3.752	0.103	0	0	0	4
PL.20845	PL.19375	B	6 A (CWC)	7.37Y	122.9	0.01	2.09	1.12	1	8	2	97	0.00	0.0	3.854	0.103	0	0	0	4
PL.20846	PL.20845	B	6 A (CWC)	7.37Y	122.9	0.00	2.09	1.12	1	8	2	97	0.00	0.0	3.948	0.094	0	0	0	4
PL.20783	PL.20846	B	6 A (CWC)	7.37Y	122.9	0.01	2.10	1.12	1	8	2	97	0.00	0.0	4.096	0.147	0	0	0	4
PL.20527	PL.20783	B	6 A (CWC)	7.37Y	122.9	0.00	2.10	1.12	1	8	2	97	0.00	0.0	4.172	0.076	4	1	3	4
PL.20528	PL.20527	B	6 A (CWC)	7.37Y	122.9	0.00	2.11	0.62	0	4	1	97	0.00	0.0	4.305	0.134	0	0	0	1
PL.20847	PL.20528	B	6 A (CWC)	7.37Y	122.9	0.00	2.11	0.62	0	4	1	97	0.00	0.0	4.437	0.132	0	0	0	1
PL.20848	PL.20847	B	6 A (CWC)	7.37Y	122.9	0.00	2.11	0.62	0	4	1	97	0.00	0.0	4.484	0.046	0	0	0	1
PL.20679	PL.20848	B	#4 ACSR	7.37Y	122.9	0.00	2.12	0.62	0	4	1	97	0.00	0.0	4.647	0.163	0	0	0	1
PL.21096	PL.20679	B	#4 ACSR	7.37Y	122.9	0.00	2.12	0.62	0	4	1	97	0.00	0.0	4.694	0.047	0	0	0	1
PL.21097	PL.21096	B	#4 ACSR	7.37Y	122.9	0.00	2.12	0.62	0	4	1	97	0.00	0.0	4.778	0.084	4	1	1	1
PL.20676	PL.21097	B	#4 ACSR	7.37Y	122.9	0.00	2.12	0.00	0	0	0	100	0.00	0.0	4.921	0.143	0	0	0	0
PL.20849	PL.20676	B	#4 ACSR	7.37Y	122.9	0.00	2.12	0.00	0	0	0	100	0.00	0.0	5.023	0.102	0	0	0	0

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Millers Creek

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.20677	PL.20849	B	#4 ACSR	7.37Y	122.9	0.00	2.12	0.00	0	0	0	100	0.00	0.0	5.082	0.059	0	0	0	0
PL.21094	PL.20527	B	6 A (CWC)	7.37Y	122.9	0.00	2.10	0.00	0	0	0	100	0.00	0.0	4.260	0.088	0	0	0	0
PL.21095	PL.21094	B	6 A (CWC)	7.37Y	122.9	0.00	2.10	0.00	0	0	0	100	0.00	0.0	4.429	0.169	0	0	0	0
CP.33	PL.21263	ABC	Cap (300)	7.40Y	123.3	0.00	1.67	0.00	0	0	0	100	0.00	0.0	2.703	0.169	0	0	0	0
PL.21201	PL.20778	C	#1/0 ACSR	7.40Y	123.4	0.00	1.60	1.28	1	9	3	95	0.00	0.0	2.588	0.004	0	0	0	1
PD.3022	PL.21201	C	50T	7.40Y	123.4	0.00	1.60	1.28	0	9	3	95	0.00	0.0	2.588	0.004	0	0	0	1
PL.21202	PD.3022	C	#1/0 ACSR	7.40Y	123.4	0.00	1.60	1.28	1	9	3	95	0.00	0.0	2.676	0.088	9	3	1	1
PL.20525	PL.20835	B	6 A (CWC)	7.41Y	123.4	0.04	1.58	11.94	9	85	24	96	0.02	0.0	2.540	0.068	0	0	0	18
PL.20526	PL.20525	B	#1/0 ACSR	7.41Y	123.4	0.00	1.58	0.04	0	0	0	100	0.00	0.0	2.571	0.031	0	0	1	1
PL.21127	PL.20525	B	6 A (CWC)	7.40Y	123.4	0.03	1.60	11.90	9	85	24	96	0.02	0.0	2.593	0.054	6	2	1	17
PL.21253	PL.21127	B	6 A (CWC)	7.40Y	123.4	0.03	1.63	11.04	8	79	22	96	0.02	0.0	2.650	0.056	0	0	0	16
PD.3053	PL.21253	B	35L	7.40Y	123.4	0.00	1.63	11.04	32	79	22	96	0.00	0.0	2.650	0.056	0	0	0	16
PL.21254	PD.3053	B	6 A (CWC)	7.40Y	123.4	0.00	1.63	11.04	8	79	22	96	0.00	0.0	2.652	0.003	8	2	1	16
PL.21132	PL.21254	B	6 A (CWC)	7.40Y	123.4	0.01	1.64	4.70	3	34	9	97	0.00	0.0	2.697	0.045	0	0	1	9
PL.21133	PL.21132	B	6 A (CWC)	7.40Y	123.3	0.01	1.65	4.65	3	33	9	96	0.00	0.0	2.736	0.039	8	2	1	8
PL.21134	PL.21133	B	6 A (CWC)	7.40Y	123.3	0.02	1.67	3.54	3	25	7	96	0.00	0.0	2.883	0.147	0	0	0	7
PL.21122	PL.21134	B	6 A (CWC)	7.40Y	123.3	0.02	1.69	3.54	3	25	7	96	0.00	0.0	2.983	0.099	1	0	1	7
PL.21123	PL.21122	B	6 A (CWC)	7.40Y	123.3	0.02	1.71	3.43	2	24	7	96	0.00	0.0	3.105	0.122	0	0	0	6
PL.20837	PL.21123	B	6 A (CWC)	7.40Y	123.3	0.03	1.74	3.43	2	24	7	96	0.00	0.0	3.272	0.167	0	0	0	6
PL.20838	PL.20837	B	6 A (CWC)	7.39Y	123.2	0.02	1.75	3.43	2	24	7	96	0.00	0.0	3.391	0.119	0	0	0	6
PL.21137	PL.20838	B	6 A (CWC)	7.39Y	123.2	0.01	1.77	3.43	2	24	7	96	0.00	0.0	3.465	0.074	0	0	0	6
PL.21138	PL.21137	B	6 A (CWC)	7.39Y	123.2	0.02	1.79	3.43	2	24	7	96	0.00	0.0	3.592	0.127	0	0	0	6
PL.20839	PL.21138	B	6 A (CWC)	7.39Y	123.2	0.01	1.80	3.43	2	24	7	96	0.00	0.0	3.680	0.088	0	0	1	6
PL.19365	PL.20839	B	6 A (CWC)	7.39Y	123.2	0.03	1.83	3.43	2	24	7	96	0.01	0.0	3.855	0.175	0	0	0	5
PL.21139	PL.19365	B	6 A (CWC)	7.39Y	123.2	0.01	1.84	3.43	2	24	7	96	0.00	0.0	3.936	0.081	6	2	1	5
PL.21140	PL.21139	B	6 A (CWC)	7.39Y	123.2	0.00	1.84	2.58	2	18	5	96	0.00	0.0	3.968	0.032	0	0	1	4
PL.21141	PL.21140	B	6 A (CWC)	7.39Y	123.2	0.00	1.85	2.58	2	18	5	96	0.00	0.0	4.009	0.041	0	0	0	3
PL.19366	PL.21141	B	6 A (CWC)	7.39Y	123.1	0.02	1.86	2.58	2	18	5	96	0.00	0.0	4.149	0.140	0	0	0	3
PL.20780	PL.19366	B	6 A (CWC)	7.39Y	123.1	0.01	1.88	1.95	1	14	4	96	0.00	0.0	4.287	0.138	0	0	0	2
PL.20840	PL.20780	B	6 A (CWC)	7.39Y	123.1	0.01	1.89	1.95	1	14	4	96	0.00	0.0	4.392	0.106	0	0	0	2
PL.20841	PL.20840	B	6 A (CWC)	7.39Y	123.1	0.01	1.90	1.95	1	14	4	96	0.00	0.0	4.518	0.125	0	0	0	2

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Millers Creek

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----			
																KW	KVAR	Cons On	Cons Thru	

PL.19368	PL.20841	B	#4 ACSR	7.39Y	123.1	0.01	1.91	1.95	1	14	4	96	0.00	0.0	4.680	0.162	2	1	1	2
PL.19374	PL.19368	B	#1/0 ACSR	7.39Y	123.1	0.00	1.91	1.64	1	12	3	97	0.00	0.0	4.826	0.146	12	3	1	1
PL.19367	PL.19366	B	#2 ACSR	7.39Y	123.1	0.00	1.86	0.63	0	5	1	98	0.00	0.0	4.197	0.048	5	1	1	1
PL.19364	PL.20839	B	#2 ACSR	7.39Y	123.2	0.00	1.80	0.00	0	0	0	100	0.00	0.0	3.717	0.037	0	0	0	0
PL.21128	PL.21254	B	6 A (CWC)	7.40Y	123.3	0.02	1.65	5.15	4	37	10	97	0.01	0.0	2.754	0.102	7	2	2	6
PL.21129	PL.21128	B	6 A (CWC)	7.40Y	123.3	0.01	1.66	4.10	3	29	8	96	0.00	0.0	2.787	0.033	0	0	0	4
PL.20779	PL.21129	B	6 A (CWC)	7.40Y	123.3	0.01	1.67	3.15	2	22	6	96	0.00	0.0	2.845	0.058	10	3	1	2
PL.19370	PL.20779	B	6 A (CWC)	7.40Y	123.3	0.00	1.67	1.69	1	12	3	97	0.00	0.0	2.898	0.053	0	0	0	1
PL.19371	PL.19370	B	#1/0 ACSR	7.40Y	123.3	0.00	1.67	1.69	1	12	3	97	0.00	0.0	2.939	0.041	12	3	1	1
PL.19369	PL.21129	B	#1/0 ACSR	7.40Y	123.3	0.00	1.66	0.94	0	7	2	96	0.00	0.0	2.821	0.034	7	2	2	2
PL.20524	PL.20776	ABC	#2 ACSR	7.42Y	123.7	0.00	1.32	0.00	0	0	0	100	0.00	0.0	2.181	0.065	0	0	0	0
PL.21209	PL.20914	C	6 A (CWC)	7.44Y	124.0	0.00	0.99	4.02	3	29	8	96	0.00	0.0	1.573	0.005	0	0	0	6
PD.3026	PL.21209	C	50T	7.44Y	124.0	0.00	0.99	4.02	0	29	8	96	0.00	0.0	1.573	0.005	0	0	0	6
PL.21210	PD.3026	C	6 A (CWC)	7.44Y	124.0	0.02	1.01	4.02	3	29	8	96	0.00	0.0	1.689	0.116	0	0	0	6
PL.21124	PL.21210	C	6 A (CWC)	7.44Y	124.0	0.02	1.03	4.02	3	29	8	96	0.00	0.0	1.779	0.090	3	1	1	6
PL.21125	PL.21124	C	6 A (CWC)	7.44Y	124.0	0.00	1.03	3.66	3	26	7	97	0.00	0.0	1.837	0.059	26	7	4	5
PL.21126	PL.21125	C	6 A (CWC)	7.44Y	124.0	0.00	1.03	0.00	0	0	0	100	0.00	0.0	1.914	0.076	0	0	1	1
PL.20519	PL.19887	A	#1/0 ACSR	7.47Y	124.4	0.00	0.58	1.38	1	10	3	96	0.00	0.0	0.982	0.074	0	0	1	2
PL.21211	PL.20519	A	#1/0 ACSR	7.47Y	124.4	0.00	0.58	1.37	1	10	3	96	0.00	0.0	0.987	0.004	0	0	0	1
PD.3027	PL.21211	A	50T	7.47Y	124.4	0.00	0.58	1.37	0	10	3	96	0.00	0.0	0.987	0.004	0	0	0	1
PL.21212	PD.3027	A	#1/0 ACSR	7.47Y	124.4	0.00	0.58	1.37	1	10	3	96	0.00	0.0	1.089	0.102	0	0	0	1
PL.20830	PL.21212	A	#1/0 ACSR	7.46Y	124.4	0.00	0.58	1.37	1	10	3	96	0.00	0.0	1.202	0.113	10	3	1	1
PL.19884	PL.28004	ABC	#1/0 ACSR	7.50Y	125.0	0.00	0.01	0.00	0	0	0	100	0.00	0.0	0.019	0.005	0	0	0	0
PL.21530	Millers Creek	ABC	#3/0 ACSR	7.50Y	125.0	0.01	0.01	101.13	34	2155	732	95	0.15	0.0	0.009	0.009	0	0	0	539
PL.28001	PL.21530	ABC	#3/0 ACSR	7.50Y	125.0	0.00	0.01	101.13	34	2154	732	95	0.03	0.0	0.010	0.002	0	0	0	539

----- Feeder No. 1 (Cobb Hill F1) Beginning with Device PD.3872 -----

PD.3872	PL.28001	ABC	200VWE	7.50Y	125.0	0.00	0.01	101.13	0	2154	732	95	0.00	0.0	0.010	0.002	0	0	0	539
PL.28002	PD.3872	ABC	#3/0 ACSR	7.49Y	124.8	0.23	0.24	101.13	34	2154	732	95	2.91	0.1	0.179	0.169	0	0	0	539
PL.23478	PL.28002	ABC	#3/0 ACSR	7.48Y	124.6	0.14	0.38	101.13	34	2151	727	95	1.83	0.1	0.286	0.107	0	0	0	539

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Millers Creek

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru

PL.23198	PL.23478	ABC	#3/0 ACSR	7.47Y	124.5	0.17	0.55	101.13	34	2150	725	95	2.17	0.1	0.412	0.126	0	0	0	539
PL.23199	PL.23198	ABC	#3/0 ACSR	7.45Y	124.2	0.21	0.76	101.13	34	2147	722	95	2.77	0.1	0.573	0.161	0	0	0	539
PL.23479	PL.23199	ABC	#3/0 ACSR	7.45Y	124.1	0.09	0.85	100.55	34	2132	714	95	1.16	0.1	0.641	0.068	2	1	1	536
PL.23480	PL.23479	ABC	#3/0 ACSR	7.43Y	123.9	0.23	1.09	100.46	33	2129	712	95	2.98	0.1	0.817	0.176	0	0	0	535
PL.23140	PL.23480	ABC	#3/0 ACSR	7.43Y	123.9	0.02	1.10	94.13	31	1990	669	95	0.18	0.0	0.829	0.012	0	0	0	495
PL.23143	PL.23140	ABC	#3/0 ACSR	7.43Y	123.8	0.13	1.23	94.13	31	1990	669	95	1.55	0.1	0.933	0.104	0	0	0	495
PL.23144	PL.23143	ABC	#3/0 ACSR	7.41Y	123.6	0.20	1.42	93.94	31	1984	665	95	2.34	0.1	1.091	0.158	0	0	0	494
PL.23211	PL.23144	ABC	#3/0 ACSR	7.41Y	123.5	0.11	1.54	93.94	31	1982	662	95	1.37	0.1	1.183	0.092	0	0	0	494
PL.23452	PL.23211	ABC	#3/0 ACSR	7.40Y	123.3	0.14	1.68	93.94	31	1981	660	95	1.67	0.1	1.296	0.112	0	0	1	494
PL.23663	PL.23452	C	#4 ACSR	7.40Y	123.3	0.00	1.68	1.43	1	10	3	96	0.00	0.0	1.300	0.004	0	0	0	1
PD.3261	PL.23663	C	50T	7.40Y	123.3	0.00	1.68	1.43	0	10	3	96	0.00	0.0	1.300	0.004	0	0	0	1
PL.23664	PD.3261	C	#4 ACSR	7.40Y	123.3	0.00	1.68	1.43	1	10	3	96	0.00	0.0	1.380	0.080	10	3	1	1
PL.23453	PL.23452	ABC	#3/0 ACSR	7.39Y	123.2	0.12	1.79	93.47	31	1969	655	95	1.39	0.1	1.391	0.095	0	0	0	492
PL.23657	PL.23453	C	6 A (CWC)	7.39Y	123.2	0.00	1.79	0.47	0	3	1	95	0.00	0.0	1.395	0.005	0	0	0	1
PD.3258	PL.23657	C	50T	7.39Y	123.2	0.00	1.79	0.47	0	3	1	95	0.00	0.0	1.395	0.005	0	0	0	1
PL.23658	PD.3258	C	6 A (CWC)	7.39Y	123.2	0.00	1.79	0.47	0	3	1	95	0.00	0.0	1.469	0.074	3	1	1	1
PL.23145	PL.23453	ABC	#3/0 ACSR	7.38Y	123.1	0.12	1.92	93.31	31	1964	652	95	1.48	0.1	1.492	0.101	0	0	0	491
PL.23485	PL.23145	ABC	#3/0 ACSR	7.38Y	123.0	0.06	1.97	70.11	23	1468	508	95	0.49	0.0	1.551	0.059	2	1	1	324
PL.23486	PL.23485	ABC	#3/0 ACSR	7.38Y	122.9	0.09	2.06	70.02	23	1465	507	95	0.77	0.1	1.644	0.093	0	0	0	323
PL.22849	PL.23486	ABC	#3/0 ACSR	7.37Y	122.9	0.05	2.11	70.02	23	1465	506	95	0.46	0.0	1.700	0.056	0	0	0	323
PL.22848	PL.22849	ABC	#3/0 ACSR	7.37Y	122.8	0.05	2.16	70.02	23	1464	505	95	0.48	0.0	1.758	0.058	0	0	0	323
PL.23450	PL.22848	ABC	#3/0 ACSR	7.36Y	122.7	0.15	2.31	70.02	23	1464	505	95	1.33	0.1	1.920	0.162	1	0	1	323
PL.23451	PL.23450	ABC	#3/0 ACSR	7.36Y	122.6	0.05	2.37	68.97	23	1440	496	95	0.47	0.0	1.979	0.059	0	0	0	316
PL.23667	PL.23451	C	#2 ACSR	7.36Y	122.6	0.00	2.37	1.94	1	14	4	96	0.00	0.0	1.984	0.005	0	0	0	2
PD.3263	PL.23667	C	50T	7.36Y	122.6	0.00	2.37	1.94	0	14	4	96	0.00	0.0	1.984	0.005	0	0	0	2
PL.23668	PD.3263	C	#2 ACSR	7.36Y	122.6	0.00	2.37	1.94	1	14	4	96	0.00	0.0	2.020	0.036	14	4	2	2
PL.23481	PL.23668	C	#2 ACSR	7.36Y	122.6	0.00	2.37	0.00	0	0	0	100	0.00	0.0	2.097	0.077	0	0	0	0
PL.23881	PL.23451	ABC	#3/0 ACSR	7.36Y	122.6	0.05	2.42	68.32	23	1426	492	95	0.41	0.0	2.031	0.052	0	0	0	314
PD.3373	PL.23881	ABC	100L	7.36Y	122.6	0.00	2.42	68.32	68	1425	491	95	0.00	0.0	2.031	0.052	0	0	0	314
PL.23882	PD.3373	ABC	#3/0 ACSR	7.35Y	122.5	0.07	2.49	68.32	23	1425	491	95	0.63	0.0	2.111	0.080	0	0	0	314
PL.23163	PL.23882	ABC	#3/0 ACSR	7.35Y	122.4	0.08	2.56	68.32	23	1425	490	95	0.65	0.0	2.195	0.083	0	0	0	313

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Millers Creek

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.23482	PL.23163	ABC	#3/0 ACSR	7.34Y	122.4	0.07	2.63	68.21	23	1422	489	95	0.57	0.0	2.268	0.073	0	0	1	312
PL.23483	PL.23482	ABC	#3/0 ACSR	7.34Y	122.3	0.08	2.71	68.21	23	1421	488	95	0.72	0.1	2.360	0.092	6	2	2	311
PL.23484	PL.23483	ABC	#3/0 ACSR	7.33Y	122.2	0.06	2.78	67.94	23	1415	485	95	0.55	0.0	2.432	0.072	0	0	0	309
PL.23164	PL.23484	ABC	#3/0 ACSR	7.32Y	122.1	0.15	2.93	67.80	23	1411	484	95	1.29	0.1	2.599	0.167	0	0	0	306
PL.23260	PL.23164	ABC	#3/0 ACSR	7.32Y	122.0	0.08	3.01	67.80	23	1410	482	95	0.70	0.0	2.689	0.091	0	0	0	306
PL.23262	PL.23260	ABC	#3/0 ACSR	7.31Y	121.9	0.09	3.10	67.80	23	1409	481	95	0.80	0.1	2.793	0.103	0	0	0	306
PL.23261	PL.23262	ABC	#3/0 ACSR	7.31Y	121.8	0.09	3.19	67.80	23	1408	479	95	0.78	0.1	2.893	0.100	0	0	0	306
PL.23489	PL.23261	ABC	#3/0 ACSR	7.31Y	121.8	0.03	3.22	67.80	23	1408	478	95	0.29	0.0	2.930	0.037	9	2	1	306
PL.23490	PL.23489	ABC	#3/0 ACSR	7.30Y	121.6	0.14	3.36	67.39	22	1399	476	95	1.16	0.1	3.082	0.152	0	0	0	305
PL.23865	PL.23490	ABC	#3/0 ACSR	7.29Y	121.6	0.07	3.43	67.39	22	1397	474	95	0.62	0.0	3.164	0.082	0	0	0	305
PD.3365-A	PL.23865	ABC	Closed	7.29Y	121.6	0.00	3.43	67.39	0	1397	473	95	0.00	0.0	3.164	0.082	0	0	0	305
PD.3365-B	PD.3365-A	ABC	Closed	7.29Y	121.6	0.00	3.43	67.39	0	1397	473	95	0.00	0.0	3.164	0.082	0	0	0	305
PL.23866	PD.3365-B	ABC	#3/0 ACSR	7.29Y	121.5	0.07	3.50	67.39	22	1397	473	95	0.61	0.0	3.244	0.080	7	2	2	305
PL.23491	PL.23866	ABC	#3/0 ACSR	7.28Y	121.4	0.09	3.59	67.08	22	1390	470	95	0.74	0.1	3.342	0.098	8	2	1	303
PL.23675	PL.23491	C	6 A (CWC)	7.28Y	121.4	0.00	3.59	0.00	0	0	0	100	0.00	0.0	3.347	0.005	0	0	0	0
PD.3267	PL.23675	C	30T	7.28Y	121.4	0.00	3.59	0.00	0	0	0	100	0.00	0.0	3.347	0.005	0	0	0	0
PL.23676	PD.3267	C	6 A (CWC)	7.28Y	121.4	0.00	3.59	0.00	0	0	0	100	0.00	0.0	3.378	0.031	0	0	0	0
PL.22850	PL.23676	C	#1/0 ACSR	7.28Y	121.4	0.00	3.59	0.00	0	0	0	100	0.00	0.0	3.443	0.065	0	0	0	0
PL.22851	PL.23676	C	6 A (CWC)	7.28Y	121.4	0.00	3.59	0.00	0	0	0	100	0.00	0.0	3.458	0.081	0	0	0	0
PL.23435	PL.23491	ABC	#3/0 ACSR	7.28Y	121.3	0.09	3.68	66.69	22	1381	467	95	0.75	0.1	3.443	0.101	6	2	1	302
PL.23492	PL.23435	ABC	#3/0 ACSR	7.28Y	121.3	0.07	3.75	66.37	22	1373	464	95	0.60	0.0	3.524	0.081	5	1	1	300
PL.23493	PL.23492	ABC	#3/0 ACSR	7.27Y	121.1	0.15	3.89	66.13	22	1368	462	95	1.22	0.1	3.691	0.167	0	0	0	299
PL.23518	PL.23493	ABC	#3/0 ACSR	7.26Y	121.0	0.11	4.01	66.13	22	1366	460	95	0.94	0.1	3.820	0.129	15	4	3	299
PL.23519	PL.23518	ABC	#3/0 ACSR	7.25Y	120.9	0.09	4.10	65.44	22	1351	454	95	0.76	0.1	3.925	0.105	0	0	0	296
PL.23263	PL.23519	ABC	#3/0 ACSR	7.25Y	120.8	0.09	4.19	65.44	22	1350	453	95	0.78	0.1	4.033	0.108	0	0	0	296
PL.23520	PL.23263	ABC	#3/0 ACSR	7.24Y	120.7	0.06	4.25	65.44	22	1349	452	95	0.54	0.0	4.109	0.075	0	0	1	296
PL.23521	PL.23520	ABC	#3/0 ACSR	7.24Y	120.7	0.07	4.33	65.43	22	1349	451	95	0.60	0.0	4.192	0.083	0	0	0	295
PL.23697	PL.23521	C	#4 ACSR	7.24Y	120.7	0.00	4.33	0.38	0	3	1	95	0.00	0.0	4.197	0.005	0	0	0	1
PD.3278	PL.23697	C	30T	7.24Y	120.7	0.00	4.33	0.38	0	3	1	95	0.00	0.0	4.197	0.005	0	0	0	1
PL.23698	PD.3278	C	#4 ACSR	7.24Y	120.7	0.00	4.33	0.38	0	3	1	95	0.00	0.0	4.240	0.043	3	1	1	1
PL.23165	PL.23521	ABC	#3/0 ACSR	7.24Y	120.6	0.08	4.41	65.30	22	1345	450	95	0.68	0.1	4.288	0.095	0	0	0	294

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Millers Creek

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru

PL.23264	PL.23165	ABC	#3/0 ACSR	7.23Y	120.5	0.10	4.51	65.30	22	1345	449	95	0.83	0.1	4.404	0.116	0	0	0	294
PL.23522	PL.23264	ABC	#3/0 ACSR	7.22Y	120.4	0.08	4.59	65.30	22	1344	447	95	0.71	0.1	4.503	0.099	3	1	1	294
PL.23523	PL.23522	ABC	#3/0 ACSR	7.22Y	120.3	0.10	4.70	65.18	22	1340	446	95	0.86	0.1	4.624	0.121	2	1	3	293
PL.22853	PL.23523	ABC	#3/0 ACSR	7.21Y	120.2	0.07	4.77	62.88	21	1292	431	95	0.60	0.0	4.714	0.091	0	0	0	277
PL.23267	PL.22853	ABC	#3/0 ACSR	7.21Y	120.1	0.09	4.86	62.88	21	1291	430	95	0.75	0.1	4.827	0.112	0	0	0	277
PL.23705	PL.23267	C	#4 ACSR	7.21Y	120.1	0.00	4.86	0.42	0	3	1	95	0.00	0.0	4.831	0.005	0	0	0	1
PD.3282	PL.23705	C	30T	7.21Y	120.1	0.00	4.86	0.42	0	3	1	95	0.00	0.0	4.831	0.005	0	0	0	1
PL.23706	PD.3282	C	#4 ACSR	7.21Y	120.1	0.00	4.86	0.42	0	3	1	95	0.00	0.0	4.863	0.032	3	1	1	1
PL.24517	PL.23267	ABC	#3/0 ACSR	7.21Y	120.1	0.01	4.87	62.74	21	1287	428	95	0.06	0.0	4.836	0.010	0	0	0	276
PL.24518	PL.24517	ABC	#3/0 ACSR	7.20Y	120.1	0.05	4.92	62.74	21	1287	428	95	0.40	0.0	4.896	0.060	0	0	0	276
RG.28	PL.24518	ABC	76.2 KVA	7.49Y	124.8	-4.68	0.24	62.74	63	1287	428	95	percent Boost= 3.75 Tap= 6.0						276	
PL.23528	RG.28	ABC	#3/0 ACSR	7.48Y	124.7	0.08	0.32	60.38	20	1287	428	95	0.62	0.0	4.997	0.101	2	1	1	276
PL.23529	PL.23528	ABC	#3/0 ACSR	7.48Y	124.6	0.09	0.41	60.30	20	1284	426	95	0.68	0.1	5.109	0.112	0	0	0	275
PL.22857	PL.23529	ABC	6 A (CWC)	7.48Y	124.6	0.00	0.41	1.76	1	36	15	92	0.00	0.0	5.138	0.029	3	1	1	3
PL.23861	PL.22857	ABC	6 A (CWC)	7.48Y	124.6	0.00	0.41	1.60	1	33	14	92	0.00	0.0	5.142	0.005	0	0	0	2
PD.3362	PL.23861	ABC	30T	7.48Y	124.6	0.00	0.41	1.60	0	33	14	92	0.00	0.0	5.142	0.005	0	0	0	2
PL.23862	PD.3362	ABC	6 A (CWC)	7.48Y	124.6	0.00	0.42	1.60	1	33	14	92	0.00	0.0	5.211	0.069	7	2	1	2
PL.23527	PL.23862	ABC	6 A (CWC)	7.47Y	124.6	0.00	0.42	1.26	1	26	12	91	0.00	0.0	5.293	0.082	0	0	0	1
PL.22972	PL.23527	ABC	#4 ACSR	7.47Y	124.6	0.01	0.43	1.26	1	26	12	91	0.00	0.0	5.405	0.112	0	0	0	1
PL.23268	PL.22972	ABC	#4 ACSR	7.47Y	124.6	0.01	0.43	1.26	1	26	12	91	0.00	0.0	5.524	0.119	0	0	0	1
PL.23269	PL.23268	ABC	#4 ACSR	7.47Y	124.6	0.01	0.44	1.26	1	26	12	91	0.00	0.0	5.649	0.125	0	0	0	1
PL.23270	PL.23269	ABC	#4 ACSR	7.47Y	124.6	0.00	0.44	1.26	1	26	12	91	0.00	0.0	5.750	0.101	0	0	0	1
PL.23272	PL.23270	ABC	#4 ACSR	7.47Y	124.6	0.01	0.45	1.26	1	26	12	91	0.00	0.0	5.857	0.107	0	0	0	1
PL.23271	PL.23272	ABC	#4 ACSR	7.47Y	124.6	0.00	0.45	1.26	1	26	12	91	0.00	0.0	5.928	0.071	26	12	1	1
PL.22858	PL.23529	ABC	#1/0 ACSR	7.47Y	124.4	0.16	0.57	58.55	25	1247	410	95	1.31	0.1	5.253	0.144	0	0	0	272
PL.23197	PL.22858	ABC	#1/0 ACSR	7.46Y	124.3	0.13	0.70	58.55	25	1246	409	95	1.10	0.1	5.374	0.121	0	0	0	272
PL.23273	PL.23197	ABC	#1/0 ACSR	7.45Y	124.2	0.15	0.84	58.55	25	1245	407	95	1.25	0.1	5.511	0.137	0	0	0	272
PL.23526	PL.23273	ABC	#1/0 ACSR	7.44Y	124.0	0.17	1.01	58.55	25	1244	406	95	1.42	0.1	5.666	0.156	0	0	1	272
PL.23889	PL.23526	ABC	#1/0 ACSR	7.44Y	123.9	0.06	1.08	58.54	25	1242	405	95	0.53	0.0	5.724	0.058	0	0	0	271
PL.23890	PL.23889	ABC	#1/0 ACSR	7.43Y	123.8	0.11	1.19	58.54	25	1242	404	95	0.94	0.1	5.828	0.103	4	1	1	271
PL.23833	PL.23890	A	6 A (CWC)	7.43Y	123.8	0.00	1.19	0.63	0	4	1	97	0.00	0.0	5.833	0.005	0	0	0	1

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Millers Creek

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PD.3348	PL.23833	A	30T	7.43Y	123.8	0.00	1.19	0.63	0	4	1	97	0.00	0.0	5.833	0.005	0	0	0	1
PL.23834	PD.3348	A	6 A (CWC)	7.43Y	123.8	0.00	1.19	0.63	0	4	1	97	0.00	0.0	5.898	0.065	4	1	1	1
PL.23509	PL.23890	ABC	#1/0 ACSR	7.42Y	123.7	0.08	1.27	57.85	25	1226	399	95	0.68	0.1	5.905	0.077	9	3	5	268
PL.23510	PL.23509	ABC	#1/0 ACSR	7.42Y	123.7	0.03	1.30	57.42	25	1216	396	95	0.25	0.0	5.934	0.029	0	0	0	263
PL.22859	PL.23510	ABC	#1/0 ACSR	7.42Y	123.6	0.08	1.38	34.92	15	733	259	94	0.42	0.1	6.062	0.128	0	0	0	135
PL.23286	PL.22859	ABC	#1/0 ACSR	7.41Y	123.5	0.09	1.47	34.92	15	733	258	94	0.42	0.1	6.193	0.131	0	0	0	135
PL.23180	PL.23286	ABC	#1/0 ACSR	7.41Y	123.4	0.11	1.58	34.92	15	732	258	94	0.54	0.1	6.361	0.168	0	0	0	135
PL.23885	PL.23180	ABC	#1/0 ACSR	7.40Y	123.4	0.01	1.59	34.92	15	732	257	94	0.04	0.0	6.373	0.013	0	0	0	135
PD.3375	PL.23885	ABC	50L	7.40Y	123.4	0.00	1.59	34.92	70	732	257	94	0.00	0.0	6.373	0.013	0	0	0	135
PL.23886	PD.3375	ABC	#1/0 ACSR	7.40Y	123.4	0.02	1.61	34.92	15	732	257	94	0.12	0.0	6.410	0.036	0	0	0	135
PL.23419	PL.23886	ABC	#1/0 ACSR	7.40Y	123.4	0.01	1.62	34.15	15	716	250	94	0.06	0.0	6.427	0.018	0	0	0	133
PL.23853	PL.23419	ABC	#4 ACSR	7.40Y	123.4	0.00	1.62	2.91	2	59	27	91	0.00	0.0	6.432	0.005	0	0	0	2
PD.3358	PL.23853	ABC	20T	7.40Y	123.4	0.00	1.62	2.91	0	59	27	91	0.00	0.0	6.432	0.005	0	0	0	2
PL.23854	PD.3358	ABC	#4 ACSR	7.40Y	123.4	0.01	1.63	2.91	2	59	27	91	0.00	0.0	6.482	0.050	0	0	0	2
PL.23855	PL.23854	ABC	#4 ACSR	7.40Y	123.4	0.00	1.63	0.00	0	0	0	100	0.00	0.0	6.487	0.005	0	0	0	0
PL.23511	PL.23854	ABC	#4 ACSR	7.40Y	123.4	0.00	1.63	2.91	2	59	27	91	0.00	0.0	6.506	0.024	6	2	1	2
PL.23512	PL.23511	ABC	#4 ACSR	7.40Y	123.4	0.02	1.65	2.61	2	52	25	90	0.01	0.0	6.692	0.186	0	0	0	1
PL.23183	PL.23512	ABC	#4 ACSR	7.40Y	123.3	0.01	1.66	2.61	2	52	25	90	0.00	0.0	6.781	0.089	0	0	0	1
PL.22975	PL.23183	ABC	#4 ACSR	7.40Y	123.3	0.00	1.66	2.61	2	52	25	90	0.00	0.0	6.783	0.002	52	25	1	1
PL.22974	PL.23512	C	#4 ACSR	7.40Y	123.4	0.00	1.65	0.00	0	0	0	100	0.00	0.0	6.807	0.115	0	0	0	0
PL.23182	PL.23419	ABC	#1/0 ACSR	7.40Y	123.3	0.07	1.69	31.26	14	658	222	95	0.32	0.0	6.550	0.123	2	1	1	131
PL.22976	PL.23182	ABC	6 A (CWC)	7.40Y	123.3	0.01	1.70	9.18	7	184	88	90	0.02	0.0	6.577	0.027	0	0	0	6
PL.23290	PL.22976	ABC	6 A (CWC)	7.39Y	123.2	0.08	1.78	9.18	7	184	88	90	0.12	0.1	6.797	0.219	0	0	0	6
PL.22977	PL.23290	ABC	6 A (CWC)	7.39Y	123.2	0.00	1.78	0.16	0	4	1	97	0.00	0.0	6.854	0.057	0	0	0	1
PL.23857	PL.22977	ABC	#4 ACSR	7.39Y	123.2	0.00	1.78	0.16	0	4	1	97	0.00	0.0	6.884	0.030	0	0	0	1
PD.3360	PL.23857	ABC	20T	7.39Y	123.2	0.00	1.78	0.16	0	4	1	97	0.00	0.0	6.884	0.030	0	0	0	1
PL.23858	PD.3360	ABC	#4 ACSR	7.39Y	123.2	0.00	1.78	0.16	0	4	1	97	0.00	0.0	6.898	0.014	4	1	1	1
PL.23504	PL.23858	ABC	#4 ACSR	7.39Y	123.2	0.00	1.78	0.00	0	0	0	100	0.00	0.0	7.037	0.140	0	0	0	0
PL.23643	PL.23290	ABC	6 A (CWC)	7.39Y	123.2	0.02	1.80	9.02	6	180	87	90	0.03	0.0	6.855	0.058	0	0	0	5
PL.23644	PL.23643	ABC	6 A (CWC)	7.39Y	123.2	0.00	1.81	9.02	6	180	87	90	0.01	0.0	6.870	0.015	32	16	1	5
PL.23505	PL.23644	ABC	6 A (CWC)	7.39Y	123.2	0.02	1.83	7.40	5	148	71	90	0.03	0.0	6.945	0.075	2	0	1	4

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Millers Creek

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.23506	PL.23505	ABC	6 A (CWC)	7.39Y	123.1	0.03	1.86	7.32	5	146	70	90	0.03	0.0	7.042	0.097	0	0	0	3
PL.23291	PL.23506	ABC	6 A (CWC)	7.39Y	123.1	0.03	1.89	7.32	5	146	70	90	0.04	0.0	7.162	0.120	0	0	0	3
PL.23507	PL.23291	ABC	6 A (CWC)	7.39Y	123.1	0.01	1.90	7.32	5	146	70	90	0.02	0.0	7.208	0.047	0	0	0	3
PL.23508	PL.23507	ABC	6 A (CWC)	7.38Y	123.1	0.02	1.92	7.32	5	146	70	90	0.02	0.0	7.275	0.067	0	0	0	3
PL.22978	PL.23508	ABC	6 A (CWC)	7.38Y	123.1	0.01	1.94	7.32	5	146	70	90	0.02	0.0	7.320	0.045	0	0	0	3
PL.23184	PL.22978	ABC	6 A (CWC)	7.38Y	123.0	0.03	1.96	4.24	3	85	41	90	0.02	0.0	7.481	0.160	0	0	0	2
PL.23294	PL.23184	ABC	6 A (CWC)	7.38Y	123.0	0.02	1.99	4.24	3	85	41	90	0.02	0.0	7.615	0.135	0	0	0	2
PL.23306	PL.23294	ABC	6 A (CWC)	7.38Y	123.0	0.01	2.00	4.24	3	85	41	90	0.01	0.0	7.676	0.061	0	0	0	2
PL.23295	PL.23306	ABC	6 A (CWC)	7.38Y	123.0	0.02	2.01	4.24	3	85	41	90	0.01	0.0	7.769	0.092	0	0	0	2
PL.25728	PL.23295	ABC	6 A (CWC)	7.38Y	123.0	0.00	2.01	4.24	3	85	41	90	0.00	0.0	7.797	0.028	83	40	1	2
PL.25729	PL.25728	ABC	6 A (CWC)	7.38Y	123.0	0.00	2.01	0.09	0	2	1	89	0.00	0.0	7.902	0.105	2	1	1	1
PL.22979	PL.22978	ABC	#4 ACSR	7.38Y	123.1	0.01	1.94	3.08	2	61	30	90	0.00	0.0	7.385	0.064	0	0	0	1
PL.22980	PL.22979	ABC	#1/0 ACSR	7.38Y	123.1	0.01	1.95	3.08	1	61	30	90	0.00	0.0	7.482	0.098	0	0	0	1
PL.23292	PL.22980	ABC	#1/0 ACSR	7.38Y	123.0	0.01	1.96	3.08	1	61	30	90	0.00	0.0	7.609	0.127	0	0	0	1
PL.23293	PL.23292	ABC	#1/0 ACSR	7.38Y	123.0	0.00	1.96	3.08	1	61	30	90	0.00	0.0	7.656	0.047	0	0	0	1
PL.22981	PL.23293	ABC	#1/0 ACSR	7.38Y	123.0	0.00	1.96	3.08	1	61	30	90	0.00	0.0	7.816	0.160	61	30	1	1
PL.23415	PL.23182	ABC	#1/0 ACSR	7.40Y	123.3	0.04	1.73	22.06	10	471	134	96	0.13	0.0	6.653	0.103	1	0	1	124
PL.23687	PL.23415	A	#4 ACSR	7.40Y	123.3	0.00	1.73	0.77	1	5	2	93	0.00	0.0	6.658	0.005	0	0	0	1
PD.3273	PL.23687	A	20T	7.40Y	123.3	0.00	1.73	0.77	0	5	2	93	0.00	0.0	6.658	0.005	0	0	0	1
PL.23688	PD.3273	A	#4 ACSR	7.40Y	123.3	0.00	1.73	0.77	1	5	2	93	0.00	0.0	6.682	0.025	5	2	1	1
PL.23416	PL.23415	ABC	#1/0 ACSR	7.39Y	123.2	0.03	1.76	21.78	9	465	132	96	0.09	0.0	6.727	0.074	2	1	1	122
PL.23413	PL.23416	ABC	#1/0 ACSR	7.39Y	123.2	0.02	1.79	21.29	9	454	129	96	0.08	0.0	6.792	0.065	13	4	3	120
PL.23414	PL.23413	ABC	#1/0 ACSR	7.39Y	123.2	0.04	1.83	20.36	9	434	123	96	0.12	0.0	6.898	0.106	6	2	3	115
PL.23695	PL.23414	A	#1/0 ACSR	7.39Y	123.2	0.00	1.83	0.17	0	1	0	100	0.00	0.0	6.903	0.005	0	0	0	1
PD.3277	PL.23695	A	20T	7.39Y	123.2	0.00	1.83	0.17	0	1	0	100	0.00	0.0	6.903	0.005	0	0	0	1
PL.23696	PD.3277	A	#1/0 ACSR	7.39Y	123.2	0.00	1.83	0.17	0	1	0	100	0.00	0.0	6.967	0.064	1	0	1	1
PL.23513	PL.23414	ABC	#1/0 ACSR	7.39Y	123.2	0.02	1.85	20.02	9	427	121	96	0.07	0.0	6.963	0.065	0	0	1	111
PL.23514	PL.23513	ABC	#1/0 ACSR	7.39Y	123.1	0.02	1.87	20.01	9	427	121	96	0.05	0.0	7.009	0.046	3	1	1	110
PL.23515	PL.23514	ABC	#1/0 ACSR	7.39Y	123.1	0.02	1.89	19.89	9	424	120	96	0.07	0.0	7.079	0.069	0	0	0	109
PL.23869	PL.23515	B	#4 ACSR	7.39Y	123.1	0.02	1.91	11.72	9	83	23	96	0.01	0.0	7.112	0.033	0	0	0	25
PD.3367	PL.23869	B	35L	7.39Y	123.1	0.00	1.91	11.72	33	83	23	96	0.00	0.0	7.112	0.033	0	0	0	25

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Millers Creek

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru

PL.23870	PD.3367	B	#4 ACSR	7.38Y	123.0	0.09	2.00	11.72	9	83	23	96	0.06	0.1	7.281	0.169	0	0	0	25
PL.22982	PL.23870	B	#4 ACSR	7.38Y	123.0	0.02	2.02	11.72	9	83	23	96	0.01	0.0	7.322	0.041	0	0	0	25
PL.23185	PL.22982	B	#4 ACSR	7.38Y	122.9	0.04	2.06	11.41	9	81	23	96	0.02	0.0	7.395	0.073	0	0	0	24
PL.22984	PL.23185	B	#4 ACSR	7.38Y	122.9	0.00	2.06	0.00	0	0	0	100	0.00	0.0	7.412	0.017	0	0	0	0
PL.23532	PL.23185	B	#4 ACSR	7.37Y	122.9	0.04	2.10	11.41	9	81	23	96	0.02	0.0	7.473	0.078	0	0	1	24
PL.23533	PL.23532	B	#4 ACSR	7.37Y	122.8	0.09	2.19	11.40	9	81	23	96	0.05	0.1	7.655	0.182	4	1	1	23
PL.23410	PL.23533	B	#4 ACSR	7.36Y	122.7	0.07	2.25	9.50	7	67	19	96	0.03	0.1	7.816	0.161	0	0	0	20
PL.23530	PL.23410	B	#4 ACSR	7.36Y	122.7	0.02	2.28	9.50	7	67	19	96	0.01	0.0	7.875	0.059	7	2	2	19
PL.23531	PL.23530	B	#4 ACSR	7.36Y	122.7	0.05	2.32	8.46	7	60	17	96	0.02	0.0	7.999	0.124	0	0	0	17
PL.22986	PL.23531	B	#4 ACSR	7.36Y	122.6	0.03	2.35	8.46	7	60	17	96	0.01	0.0	8.077	0.078	0	0	0	17
PL.23186	PL.22986	B	#4 ACSR	7.36Y	122.6	0.05	2.40	8.19	6	58	16	96	0.02	0.0	8.213	0.136	0	0	0	16
PL.21838	PL.23186	B	#4 ACSR	7.35Y	122.6	0.04	2.44	8.19	6	58	16	96	0.02	0.0	8.318	0.105	0	0	0	16
PL.21837	PL.21838	B	#4 ACSR	7.35Y	122.5	0.05	2.49	8.19	6	58	16	96	0.02	0.0	8.458	0.140	0	0	1	16
PL.22988	PL.21837	B	#1/0 ACSR	7.35Y	122.5	0.00	2.49	0.38	0	3	1	95	0.00	0.0	8.485	0.027	3	1	1	1
PL.22989	PL.21837	B	#4 ACSR	7.35Y	122.5	0.03	2.52	7.81	6	55	16	96	0.01	0.0	8.545	0.088	0	0	0	14
PL.21839	PL.22989	B	#4 ACSR	7.34Y	122.4	0.06	2.59	7.81	6	55	16	96	0.03	0.0	8.730	0.184	0	0	0	14
PL.23187	PL.21839	B	#4 ACSR	7.34Y	122.4	0.05	2.64	7.78	6	55	15	96	0.02	0.0	8.873	0.144	0	0	0	13
PL.21825	PL.23187	B	#4 ACSR	7.34Y	122.3	0.02	2.66	5.62	4	40	11	96	0.01	0.0	8.973	0.099	0	0	0	11
PL.21841	PL.21825	B	#4 ACSR	7.34Y	122.3	0.05	2.71	5.62	4	40	11	96	0.01	0.0	9.159	0.186	0	0	0	11
PL.21842	PL.21841	B	#4 ACSR	7.34Y	122.3	0.02	2.73	5.62	4	40	11	96	0.01	0.0	9.257	0.098	0	0	0	11
PL.23307	PL.21842	B	#4 ACSR	7.33Y	122.2	0.02	2.76	5.62	4	40	11	96	0.01	0.0	9.356	0.099	1	0	1	11
PL.21827	PL.23307	B	#4 ACSR	7.33Y	122.2	0.03	2.79	5.53	4	39	11	96	0.01	0.0	9.477	0.122	0	0	0	10
PL.21843	PL.21827	B	#4 ACSR	7.33Y	122.2	0.03	2.82	5.53	4	39	11	96	0.01	0.0	9.586	0.109	0	0	0	10
PL.23679	PL.21843	B	#4 ACSR	7.33Y	122.2	0.00	2.82	5.53	4	39	11	96	0.00	0.0	9.591	0.005	0	0	0	10
PD.3269	PL.23679	B	15T	7.33Y	122.2	0.00	2.82	5.53	0	39	11	96	0.00	0.0	9.591	0.005	0	0	0	10
PL.23680	PD.3269	B	#4 ACSR	7.33Y	122.2	0.03	2.85	5.53	4	39	11	96	0.01	0.0	9.710	0.119	0	0	0	10
PL.21844	PL.23680	B	#4 ACSR	7.33Y	122.1	0.04	2.89	5.53	4	39	11	96	0.01	0.0	9.870	0.160	0	0	0	10
PL.21845	PL.21844	B	#4 ACSR	7.32Y	122.1	0.04	2.92	5.53	4	39	11	96	0.01	0.0	10.024	0.154	0	0	0	10
PL.23496	PL.21845	B	#4 ACSR	7.32Y	122.0	0.04	2.96	5.53	4	39	11	96	0.01	0.0	10.194	0.170	8	2	2	10
PL.23497	PL.23496	B	#4 ACSR	7.32Y	122.0	0.03	2.99	4.44	3	31	9	96	0.01	0.0	10.363	0.169	0	0	0	8
PL.21828	PL.23497	B	#1/0 ACSR	7.32Y	122.0	0.00	3.00	1.14	0	8	2	97	0.00	0.0	10.390	0.026	8	2	1	1

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Millers Creek

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.23188	PL.23497	B	#4 ACSR	7.32Y	122.0	0.02	3.02	3.31	3	23	7	96	0.00	0.0	10.533	0.169	0	0	1	7
PL.23494	PL.23188	B	#4 ACSR	7.32Y	122.0	0.00	3.02	3.31	3	23	7	96	0.00	0.0	10.572	0.040	8	2	3	6
PL.23495	PL.23494	B	#4 ACSR	7.32Y	122.0	0.00	3.03	2.22	2	16	4	97	0.00	0.0	10.593	0.021	0	0	0	3
PL.21829	PL.23495	B	#4 ACSR	7.32Y	122.0	0.00	3.03	0.00	0	0	0	100	0.00	0.0	10.710	0.118	0	0	0	0
PL.23189	PL.23495	B	#4 ACSR	7.32Y	122.0	0.01	3.04	2.22	2	16	4	97	0.00	0.0	10.761	0.168	4	1	1	3
PL.21830	PL.23189	B	#4 ACSR	7.32Y	122.0	0.00	3.05	1.73	1	12	3	97	0.00	0.0	10.891	0.129	12	3	2	2
PL.21826	PL.23187	B	#1/0 ACSR	7.34Y	122.4	0.01	2.64	2.17	1	15	4	97	0.00	0.0	8.981	0.107	0	0	0	2
PL.21840	PL.21826	B	#1/0 ACSR	7.34Y	122.4	0.01	2.65	2.17	1	15	4	97	0.00	0.0	9.082	0.101	0	0	0	2
PL.23681	PL.21840	B	1/0 AL URD	7.34Y	122.4	0.00	2.65	2.17	1	15	4	97	0.00	0.0	9.086	0.005	0	0	0	2
PD.3270	PL.23681	B	15T	7.34Y	122.4	0.00	2.65	2.17	0	15	4	97	0.00	0.0	9.086	0.005	0	0	0	2
PL.23682	PD.3270	B	1/0 AL URD	7.34Y	122.3	0.00	2.65	2.17	1	15	4	97	0.00	0.0	9.219	0.133	15	4	2	2
PL.21824	PL.23187	B	#4 ACSR	7.34Y	122.4	0.00	2.64	0.00	0	0	0	100	0.00	0.0	8.931	0.057	0	0	0	0
PL.22990	PL.21839	B	#4 ACSR	7.34Y	122.4	0.00	2.59	0.02	0	0	0	100	0.00	0.0	8.788	0.058	0	0	1	1
PL.22987	PL.22986	B	#4 ACSR	7.36Y	122.6	0.00	2.36	0.27	0	2	1	89	0.00	0.0	8.215	0.137	2	1	1	1
PL.23711	PL.23410	B	#1/0 ACSR	7.36Y	122.7	0.00	2.25	0.00	0	0	0	100	0.00	0.0	7.820	0.004	0	0	0	1
PD.3285	PL.23711	B	15T	7.36Y	122.7	0.00	2.25	0.00	0	0	0	100	0.00	0.0	7.820	0.004	0	0	0	1
PL.23712	PD.3285	B	#1/0 ACSR	7.36Y	122.7	0.00	2.25	0.00	0	0	0	100	0.00	0.0	7.954	0.134	0	0	0	1
PL.23296	PL.23712	B	#1/0 ACSR	7.36Y	122.7	0.00	2.25	0.00	0	0	0	100	0.00	0.0	8.128	0.174	0	0	0	1
PL.23297	PL.23296	B	#1/0 ACSR	7.36Y	122.7	0.00	2.25	0.00	0	0	0	100	0.00	0.0	8.245	0.117	0	0	1	1
PL.22985	PL.23533	B	#4 ACSR	7.37Y	122.8	0.00	2.19	1.34	1	9	3	95	0.00	0.0	7.692	0.037	9	3	2	2
PL.22983	PL.22982	B	#4 ACSR	7.38Y	123.0	0.00	2.02	0.31	0	2	1	89	0.00	0.0	7.410	0.088	2	1	1	1
PL.23516	PL.23515	ABC	#1/0 ACSR	7.38Y	123.1	0.04	1.93	15.98	7	341	97	96	0.10	0.0	7.225	0.146	1	0	2	84
PL.23517	PL.23516	ABC	#1/0 ACSR	7.38Y	123.0	0.03	1.97	15.93	7	339	96	96	0.08	0.0	7.336	0.111	0	0	0	82
PL.21835	PL.23517	ABC	#1/0 ACSR	7.38Y	123.0	0.03	1.99	15.93	7	339	96	96	0.07	0.0	7.436	0.100	0	0	0	82
PL.21846	PL.21835	ABC	#1/0 ACSR	7.38Y	123.0	0.03	2.03	15.93	7	339	96	96	0.08	0.0	7.550	0.114	0	0	0	82
PL.23407	PL.21846	ABC	#1/0 ACSR	7.38Y	122.9	0.04	2.07	15.93	7	339	96	96	0.09	0.0	7.691	0.141	10	3	1	82
PL.23713	PL.23407	A	#1/0 ACSR	7.38Y	122.9	0.00	2.07	0.87	0	6	2	95	0.00	0.0	7.696	0.005	0	0	0	1
PD.3286	PL.23713	A	20T	7.38Y	122.9	0.00	2.07	0.87	0	6	2	95	0.00	0.0	7.696	0.005	0	0	0	1
PL.23714	PD.3286	A	#1/0 ACSR	7.38Y	122.9	0.00	2.07	0.87	0	6	2	95	0.00	0.0	7.884	0.188	6	2	1	1
PL.23408	PL.23407	ABC	#1/0 ACSR	7.37Y	122.9	0.03	2.10	15.19	7	323	92	96	0.06	0.0	7.793	0.102	0	0	0	80
PL.23717	PL.23408	C	#4 ACSR	7.37Y	122.9	0.00	2.10	3.40	3	24	7	96	0.00	0.0	7.797	0.005	0	0	0	5

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Millers Creek

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PD.3288	PL.23717	C	20T	7.37Y	122.9	0.00	2.10	3.40	0	24	7	96	0.00	0.0	7.797	0.005	0	0	0	5
PL.23718	PD.3288	C	#4 ACSR	7.37Y	122.9	0.00	2.10	3.40	3	24	7	96	0.00	0.0	7.847	0.050	24	7	5	5
PL.23534	PL.23408	ABC	#1/0 ACSR	7.37Y	122.9	0.02	2.11	14.05	6	299	85	96	0.04	0.0	7.870	0.077	14	4	3	75
PL.23535	PL.23534	ABC	#1/0 ACSR	7.37Y	122.9	0.02	2.14	13.42	6	286	81	96	0.05	0.0	7.971	0.101	0	0	0	72
PL.23715	PL.23535	A	#4 ACSR	7.37Y	122.9	0.00	2.14	0.16	0	1	0	100	0.00	0.0	7.976	0.005	0	0	0	1
PD.3287	PL.23715	A	20T	7.37Y	122.9	0.00	2.14	0.16	0	1	0	100	0.00	0.0	7.976	0.005	0	0	0	1
PL.23716	PD.3287	A	#4 ACSR	7.37Y	122.9	0.00	2.14	0.16	0	1	0	100	0.00	0.0	8.049	0.073	1	0	1	1
PL.21836	PL.23716	A	#1/0 ACSR	7.37Y	122.9	0.00	2.14	0.00	0	0	0	100	0.00	0.0	8.075	0.027	0	0	0	0
PL.23887	PL.23535	ABC	#1/0 ACSR	7.37Y	122.8	0.02	2.16	13.37	6	284	81	96	0.05	0.0	8.067	0.096	0	0	0	71
PD.3376	PL.23887	ABC	35L	7.37Y	122.8	0.00	2.16	13.37	38	284	81	96	0.00	0.0	8.067	0.096	0	0	0	71
PL.23888	PD.3376	ABC	#1/0 ACSR	7.37Y	122.8	0.02	2.19	13.37	6	284	81	96	0.05	0.0	8.163	0.096	0	0	0	71
PL.21847	PL.23888	ABC	#1/0 ACSR	7.37Y	122.8	0.03	2.22	13.37	6	284	81	96	0.06	0.0	8.289	0.127	0	0	0	71
PL.21848	PL.21847	ABC	#1/0 ACSR	7.36Y	122.7	0.04	2.25	13.37	6	284	80	96	0.07	0.0	8.440	0.150	0	0	0	71
PL.21849	PL.21848	ABC	#1/0 ACSR	7.36Y	122.7	0.03	2.29	13.37	6	284	80	96	0.06	0.0	8.576	0.136	0	0	0	71
PL.23457	PL.21849	ABC	#1/0 ACSR	7.36Y	122.7	0.03	2.31	13.37	6	284	80	96	0.06	0.0	8.693	0.117	0	0	1	71
PL.23458	PL.23457	ABC	#1/0 ACSR	7.36Y	122.7	0.01	2.32	13.36	6	284	80	96	0.02	0.0	8.738	0.046	0	0	0	70
PL.23595	PL.23458	ABC	#1/0 ACSR	7.36Y	122.7	0.01	2.34	10.95	5	233	66	96	0.02	0.0	8.801	0.062	5	1	1	68
PL.23596	PL.23595	ABC	#1/0 ACSR	7.36Y	122.7	0.01	2.34	10.71	5	228	64	96	0.01	0.0	8.831	0.030	0	0	0	67
PL.23777	PL.23596	C	6 A (CWC)	7.36Y	122.7	0.00	2.34	1.81	1	13	4	96	0.00	0.0	8.835	0.004	0	0	0	1
PD.3319	PL.23777	C	15T	7.36Y	122.7	0.00	2.34	1.81	0	13	4	96	0.00	0.0	8.835	0.004	0	0	0	1
PL.23778	PD.3319	C	6 A (CWC)	7.36Y	122.7	0.00	2.34	1.81	1	13	4	96	0.00	0.0	8.861	0.026	13	4	1	1
PL.23405	PL.23596	ABC	#1/0 ACSR	7.36Y	122.6	0.01	2.35	10.11	4	215	61	96	0.01	0.0	8.875	0.044	3	1	1	66
PL.23773	PL.23405	C	6 A (CWC)	7.36Y	122.6	0.00	2.35	0.90	1	6	2	95	0.00	0.0	8.879	0.005	0	0	0	1
PD.3317	PL.23773	C	15T	7.36Y	122.6	0.00	2.35	0.90	0	6	2	95	0.00	0.0	8.879	0.005	0	0	0	1
PL.23774	PD.3317	C	6 A (CWC)	7.36Y	122.6	0.00	2.35	0.90	1	6	2	95	0.00	0.0	8.915	0.035	6	2	1	1
PL.23406	PL.23405	ABC	#1/0 ACSR	7.36Y	122.6	0.02	2.37	9.66	4	205	58	96	0.03	0.0	8.978	0.104	2	1	1	64
PL.23779	PL.23406	C	#1/0 ACSR	7.36Y	122.6	0.00	2.37	1.27	1	9	3	95	0.00	0.0	8.983	0.005	0	0	0	1
PD.3320	PL.23779	C	15T	7.36Y	122.6	0.00	2.37	1.27	0	9	3	95	0.00	0.0	8.983	0.005	0	0	0	1
PL.23780	PD.3320	C	#1/0 ACSR	7.36Y	122.6	0.00	2.37	1.27	1	9	3	95	0.00	0.0	9.003	0.020	9	3	1	1
PL.23597	PL.23406	ABC	#1/0 ACSR	7.36Y	122.6	0.01	2.38	9.15	4	194	55	96	0.01	0.0	9.034	0.056	4	1	2	62
PL.23598	PL.23597	ABC	#1/0 ACSR	7.36Y	122.6	0.01	2.39	8.98	4	191	54	96	0.01	0.0	9.078	0.043	0	0	0	60

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Millers Creek

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.23402	PL.23598	ABC	#1/0 ACSR	7.36Y	122.6	0.01	2.40	8.98	4	191	54	96	0.01	0.0	9.148	0.071	3	1	1	60
PL.23599	PL.23402	ABC	#1/0 ACSR	7.35Y	122.6	0.02	2.42	8.25	4	175	50	96	0.03	0.0	9.295	0.147	8	2	2	52
PL.23600	PL.23599	ABC	#1/0 ACSR	7.35Y	122.6	0.02	2.43	7.88	3	167	47	96	0.02	0.0	9.403	0.108	3	1	2	50
PL.23607	PL.23600	ABC	#1/0 ACSR	7.35Y	122.6	0.01	2.44	7.19	3	153	43	96	0.01	0.0	9.454	0.051	0	0	0	45
PL.23608	PL.23607	ABC	#1/0 ACSR	7.35Y	122.6	0.01	2.45	7.19	3	153	43	96	0.01	0.0	9.505	0.051	3	1	1	45
PL.23403	PL.23608	ABC	#1/0 ACSR	7.35Y	122.5	0.01	2.45	6.43	3	136	39	96	0.01	0.0	9.575	0.071	0	0	0	41
PL.23611	PL.23403	ABC	#1/0 ACSR	7.35Y	122.5	0.01	2.46	5.48	2	116	33	96	0.01	0.0	9.639	0.063	0	0	0	33
PL.23612	PL.23611	ABC	#1/0 ACSR	7.35Y	122.5	0.01	2.47	5.48	2	116	33	96	0.01	0.0	9.743	0.104	0	0	0	33
PL.23799	PL.23612	C	6 A (CWC)	7.35Y	122.5	0.00	2.47	3.40	2	24	7	96	0.00	0.0	9.748	0.005	0	0	0	5
PD.3330	PL.23799	C	15T	7.35Y	122.5	0.00	2.47	3.40	0	24	7	96	0.00	0.0	9.748	0.005	0	0	0	5
PL.23800	PD.3330	C	6 A (CWC)	7.35Y	122.5	0.02	2.49	3.40	2	24	7	96	0.00	0.0	9.871	0.124	0	0	0	5
PL.23100	PL.23800	C	6 A (CWC)	7.35Y	122.5	0.02	2.51	3.40	2	24	7	96	0.00	0.0	10.028	0.157	6	2	1	5
PL.23101	PL.23100	C	6 A (CWC)	7.35Y	122.5	0.01	2.52	2.49	2	18	5	96	0.00	0.0	10.141	0.113	9	2	2	4
PL.23102	PL.23101	C	6 A (CWC)	7.35Y	122.5	0.01	2.53	1.27	1	9	3	95	0.00	0.0	10.286	0.144	0	0	0	2
PL.23105	PL.23102	C	6 A (CWC)	7.35Y	122.5	0.00	2.53	0.26	0	2	1	89	0.00	0.0	10.441	0.155	2	1	1	1
PL.23111	PL.23105	C	#4 ACSR	7.35Y	122.5	0.00	2.53	0.00	0	0	0	100	0.00	0.0	10.598	0.157	0	0	0	0
PL.23104	PL.23102	C	6 A (CWC)	7.35Y	122.5	0.00	2.53	1.01	1	7	2	96	0.00	0.0	10.340	0.055	0	0	0	1
PL.23106	PL.23104	C	#4 ACSR	7.35Y	122.5	0.00	2.53	1.01	1	7	2	96	0.00	0.0	10.387	0.046	0	0	0	1
PL.23107	PL.23106	C	#4 ACSR	7.35Y	122.5	0.00	2.54	1.01	1	7	2	96	0.00	0.0	10.444	0.057	7	2	1	1
PL.23404	PL.23612	ABC	#1/0 ACSR	7.35Y	122.5	0.00	2.48	4.35	2	92	26	96	0.00	0.0	9.802	0.059	0	0	0	28
PL.23093	PL.23404	ABC	#1/0 ACSR	7.35Y	122.5	0.00	2.48	4.35	2	92	26	96	0.00	0.0	9.842	0.040	0	0	0	28
PL.23613	PL.23093	ABC	#1/0 ACSR	7.35Y	122.5	0.00	2.48	1.58	1	33	10	96	0.00	0.0	9.899	0.057	1	0	1	12
PL.23614	PL.23613	ABC	#1/0 ACSR	7.35Y	122.5	0.00	2.48	1.53	1	32	10	95	0.00	0.0	9.956	0.057	0	0	0	11
PL.23863	PL.23614	ABC	#1/0 ACSR	7.35Y	122.5	0.00	2.48	1.53	1	32	10	95	0.00	0.0	9.961	0.005	0	0	0	11
PD.3364-A	PL.23863	ABC	Closed	7.35Y	122.5	0.00	2.48	1.53	0	32	10	95	0.00	0.0	9.961	0.005	0	0	0	11
PD.3364-B	PD.3364-A	ABC	Closed	7.35Y	122.5	0.00	2.48	1.53	0	32	10	95	0.00	0.0	9.961	0.005	0	0	0	11
PL.23864	PD.3364-B	ABC	#1/0 ACSR	7.35Y	122.5	0.00	2.48	1.53	1	32	10	95	0.00	0.0	9.973	0.012	0	0	0	11
PL.23193	PL.23864	ABC	#1/0 ACSR	7.35Y	122.5	0.00	2.49	1.15	1	24	7	96	0.00	0.0	10.147	0.174	0	0	0	8
PL.23301	PL.23193	ABC	#1/0 ACSR	7.35Y	122.5	0.00	2.49	1.15	1	24	7	96	0.00	0.0	10.299	0.152	0	0	0	8
PL.23103	PL.23301	B	#1/0 ACSR	7.35Y	122.5	0.00	2.49	1.51	1	11	3	96	0.00	0.0	10.358	0.059	0	0	0	3
PL.23860	PL.23103	B	#1/0 ACSR	7.35Y	122.5	0.00	2.49	1.51	1	11	3	96	0.00	0.0	10.363	0.005	0	0	0	3

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Millers Creek

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PD.3361	PL.23860	B	10T	7.35Y	122.5	0.00	2.49	1.51	0	11	3	96	0.00	0.0	10.363	0.005	0	0	0	3
PL.23859	PD.3361	B	#1/0 ACSR	7.35Y	122.5	0.01	2.50	1.51	1	11	3	96	0.00	0.0	10.524	0.162	0	0	0	3
PL.23616	PL.23859	B	#1/0 ACSR	7.35Y	122.5	0.00	2.50	1.51	1	11	3	96	0.00	0.0	10.625	0.101	3	1	1	3
PL.23615	PL.23616	B	#1/0 ACSR	7.35Y	122.5	0.00	2.50	1.02	0	7	2	96	0.00	0.0	10.665	0.040	0	0	0	2
PL.23099	PL.23615	B	#4 ACSR	7.35Y	122.5	0.00	2.50	0.78	1	6	2	95	0.00	0.0	10.705	0.040	6	2	1	1
PL.23098	PL.23615	B	#4 ACSR	7.35Y	122.5	0.00	2.50	0.24	0	2	0	100	0.00	0.0	10.704	0.038	0	0	0	1
PL.23097	PL.23098	B	#1/0 ACSR	7.35Y	122.5	0.00	2.50	0.24	0	2	0	100	0.00	0.0	10.779	0.076	2	0	1	1
PL.23195	PL.23301	ABC	#1/0 ACSR	7.35Y	122.5	0.00	2.49	0.65	0	14	4	96	0.00	0.0	10.358	0.060	0	0	0	5
PL.23196	PL.23195	ABC	#1/0 ACSR	7.35Y	122.5	0.00	2.49	0.51	0	11	4	94	0.00	0.0	10.448	0.089	0	0	0	4
PL.23641	PL.23196	ABC	#1/0 ACSR	7.35Y	122.5	0.00	2.49	0.51	0	11	4	94	0.00	0.0	10.574	0.127	3	1	1	4
PL.23642	PL.23641	B	#1/0 ACSR	7.35Y	122.5	0.00	2.50	1.11	0	8	2	97	0.00	0.0	10.717	0.142	0	0	0	3
PL.23805	PL.23642	B	#4 ACSR	7.35Y	122.5	0.00	2.50	0.00	0	0	0	100	0.00	0.0	10.721	0.004	0	0	0	0
PD.3333	PL.23805	B	15T	7.35Y	122.5	0.00	2.50	0.00	0	0	0	100	0.00	0.0	10.721	0.004	0	0	0	0
PL.23806	PD.3333	B	#4 ACSR	7.35Y	122.5	0.00	2.50	0.00	0	0	0	100	0.00	0.0	10.791	0.070	0	0	0	0
PL.23617	PL.23642	B	#1/0 ACSR	7.35Y	122.5	0.00	2.50	1.11	0	8	2	97	0.00	0.0	10.806	0.089	0	0	0	3
PL.23618	PL.23617	B	#1/0 ACSR	7.35Y	122.5	0.00	2.50	1.11	0	8	2	97	0.00	0.0	10.897	0.091	0	0	0	3
PL.23108	PL.23618	B	#1/0 ACSR	7.35Y	122.5	0.00	2.50	1.11	0	8	2	97	0.00	0.0	11.059	0.162	0	0	0	3
PL.23109	PL.23108	B	#1/0 ACSR	7.35Y	122.5	0.00	2.51	1.11	0	8	2	97	0.00	0.0	11.226	0.167	0	0	0	3
PL.23127	PL.23109	B	#2 ACSR	7.35Y	122.5	0.00	2.51	1.11	1	8	2	97	0.00	0.0	11.294	0.068	0	0	0	3
PL.23809	PL.23127	B	#4 ACSR	7.35Y	122.5	0.00	2.51	1.11	1	8	2	97	0.00	0.0	11.299	0.005	0	0	0	3
PD.3335	PL.23809	B	15T	7.35Y	122.5	0.00	2.51	1.11	0	8	2	97	0.00	0.0	11.299	0.005	0	0	0	3
PL.23810	PD.3335	B	#4 ACSR	7.35Y	122.5	0.00	2.52	1.11	1	8	2	97	0.00	0.0	11.391	0.092	0	0	0	3
PL.23302	PL.23810	B	#4 ACSR	7.35Y	122.5	0.01	2.52	1.11	1	8	2	97	0.00	0.0	11.514	0.123	0	0	0	3
PL.23303	PL.23302	B	#4 ACSR	7.35Y	122.5	0.01	2.53	1.11	1	8	2	97	0.00	0.0	11.693	0.179	0	0	0	3
PL.23304	PL.23303	B	#4 ACSR	7.35Y	122.5	0.01	2.54	1.11	1	8	2	97	0.00	0.0	11.833	0.140	0	0	0	3
PL.23409	PL.23304	B	#4 ACSR	7.35Y	122.5	0.00	2.54	1.11	1	8	2	97	0.00	0.0	11.927	0.094	2	1	1	3
PL.23626	PL.23409	B	#4 ACSR	7.35Y	122.5	0.00	2.54	0.77	1	5	2	93	0.00	0.0	11.989	0.061	1	0	1	2
PL.23625	PL.23626	B	#4 ACSR	7.35Y	122.5	0.00	2.55	0.60	0	4	1	97	0.00	0.0	12.083	0.094	4	1	1	1
PL.23110	PL.23108	B	#1/0 ACSR	7.35Y	122.5	0.00	2.50	0.00	0	0	0	100	0.00	0.0	11.225	0.165	0	0	0	0
PL.23803	PL.23195	C	#2 ACSR	7.35Y	122.5	0.00	2.49	0.43	0	3	1	95	0.00	0.0	10.363	0.005	0	0	0	1
PD.3332	PL.23803	C	15T	7.35Y	122.5	0.00	2.49	0.43	0	3	1	95	0.00	0.0	10.363	0.005	0	0	0	1

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Millers Creek

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.23804	PD.3332	C	#2 ACSR	7.35Y	122.5	0.00	2.49	0.43	0	3	1	95	0.00	0.0	10.387	0.024	3	1	1	1
PL.23801	PL.23864	A	#4 ACSR	7.35Y	122.5	0.00	2.48	1.15	1	8	2	97	0.00	0.0	9.977	0.005	0	0	0	3
PD.3331	PL.23801	A	15T	7.35Y	122.5	0.00	2.48	1.15	0	8	2	97	0.00	0.0	9.977	0.005	0	0	0	3
PL.23802	PD.3331	A	#4 ACSR	7.35Y	122.5	0.00	2.48	1.15	1	8	2	97	0.00	0.0	9.997	0.020	0	0	0	3
PL.23194	PL.23802	A	#4 ACSR	7.35Y	122.5	0.00	2.48	0.87	1	6	2	95	0.00	0.0	10.029	0.033	6	2	2	2
PL.23095	PL.23802	A	#4 ACSR	7.35Y	122.5	0.00	2.48	0.28	0	2	1	89	0.00	0.0	10.090	0.093	2	1	1	1
PL.23094	PL.23093	ABC	#1/0 ACSR	7.35Y	122.5	0.00	2.48	2.77	1	59	16	97	0.00	0.0	9.928	0.085	6	2	2	16
PL.23115	PL.23094	ABC	#1/0 ACSR	7.35Y	122.5	0.00	2.48	2.48	1	53	15	96	0.00	0.0	9.958	0.030	0	0	0	14
PL.23116	PL.23115	ABC	#1/0 ACSR	7.35Y	122.5	0.00	2.49	2.48	1	53	15	96	0.00	0.0	10.046	0.088	0	0	0	14
PL.23118	PL.23116	ABC	#1/0 ACSR	7.35Y	122.5	0.00	2.49	2.39	1	51	14	96	0.00	0.0	10.120	0.074	0	0	0	13
PL.23788	PL.23118	C	#2 ACSR	7.35Y	122.5	0.00	2.49	1.18	1	8	2	97	0.00	0.0	10.125	0.005	0	0	0	2
PD.3324	PL.23788	C	15T	7.35Y	122.5	0.00	2.49	1.18	0	8	2	97	0.00	0.0	10.125	0.005	0	0	0	2
PL.23787	PD.3324	C	#2 ACSR	7.35Y	122.5	0.00	2.49	1.18	1	8	2	97	0.00	0.0	10.157	0.032	8	2	2	2
PL.23119	PL.23118	A	#4 ACSR	7.35Y	122.5	0.00	2.50	3.61	3	26	7	97	0.00	0.0	10.143	0.023	0	0	0	6
PL.23785	PL.23119	A	6 A (CWC)	7.35Y	122.5	0.00	2.50	3.61	3	26	7	97	0.00	0.0	10.148	0.005	0	0	0	6
PD.3323	PL.23785	A	15T	7.35Y	122.5	0.00	2.50	3.61	0	26	7	97	0.00	0.0	10.148	0.005	0	0	0	6
PL.23786	PD.3323	A	6 A (CWC)	7.35Y	122.5	0.01	2.51	3.61	3	26	7	97	0.00	0.0	10.210	0.062	0	0	0	6
PL.23120	PL.23786	A	6 A (CWC)	7.35Y	122.5	0.02	2.53	3.61	3	26	7	97	0.00	0.0	10.354	0.144	0	0	0	6
PL.23191	PL.23120	A	6 A (CWC)	7.35Y	122.5	0.00	2.53	1.27	1	9	3	95	0.00	0.0	10.390	0.036	9	3	2	2
PL.23605	PL.23120	A	#1/0 ACSR	7.35Y	122.5	0.01	2.54	2.34	1	17	5	96	0.00	0.0	10.469	0.115	2	1	1	4
PL.23606	PL.23605	A	#1/0 ACSR	7.35Y	122.5	0.00	2.54	2.06	1	15	4	97	0.00	0.0	10.547	0.078	0	0	0	3
PL.23121	PL.23606	A	#1/0 ACSR	7.35Y	122.5	0.00	2.54	2.06	1	15	4	97	0.00	0.0	10.634	0.087	0	0	0	3
PL.66170	PL.23121	A	#1/0 ACSR	7.35Y	122.5	0.00	2.54	0.00	0	0	0	100	0.00	0.0	10.764	0.130	0	0	0	0
PL.23300	PL.23121	A	#1/0 ACSR	7.35Y	122.5	0.00	2.55	2.06	1	15	4	97	0.00	0.0	10.737	0.103	0	0	0	3
PL.23122	PL.23300	A	#1/0 ACSR	7.35Y	122.4	0.00	2.55	2.03	1	14	4	96	0.00	0.0	10.853	0.116	14	4	2	2
PL.23192	PL.23300	A	#1/0 ACSR	7.35Y	122.5	0.00	2.55	0.04	0	0	0	100	0.00	0.0	10.778	0.041	0	0	1	1
PL.23190	PL.23118	ABC	#1/0 ACSR	7.35Y	122.5	0.00	2.49	0.80	0	17	5	96	0.00	0.0	10.243	0.122	0	0	0	5
PL.23125	PL.23190	ABC	#1/0 ACSR	7.35Y	122.5	0.00	2.49	0.70	0	15	4	97	0.00	0.0	10.292	0.050	0	0	0	4
PL.23123	PL.23125	ABC	#1/0 ACSR	7.35Y	122.5	0.00	2.50	0.70	0	15	4	97	0.00	0.0	10.404	0.111	2	1	2	4
PL.23784	PL.23123	A	#1/0 ACSR	7.35Y	122.5	0.00	2.50	1.83	1	13	4	96	0.00	0.0	10.408	0.005	0	0	0	2
PD.3322	PL.23784	A	15T	7.35Y	122.5	0.00	2.50	1.83	0	13	4	96	0.00	0.0	10.408	0.005	0	0	0	2

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Millers Creek

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.23783	PD.3322	A	#1/0 ACSR	7.35Y	122.5	0.00	2.50	1.83	1	13	4	96	0.00	0.0	10.486	0.078	0	0	0	2
PL.23604	PL.23783	A	#1/0 ACSR	7.35Y	122.5	0.00	2.50	1.83	1	13	4	96	0.00	0.0	10.542	0.056	0	0	0	2
PL.23603	PL.23604	A	#1/0 ACSR	7.35Y	122.5	0.00	2.50	1.83	1	13	4	96	0.00	0.0	10.591	0.049	0	0	0	2
PL.23601	PL.23603	A	#1/0 ACSR	7.35Y	122.5	0.00	2.50	1.83	1	13	4	96	0.00	0.0	10.622	0.031	4	1	1	2
PL.23602	PL.23601	A	#1/0 ACSR	7.35Y	122.5	0.00	2.51	1.20	1	8	2	97	0.00	0.0	10.692	0.070	8	2	1	1
PL.23124	PL.23190	A	6 A (CWC)	7.35Y	122.5	0.00	2.49	0.29	0	2	1	89	0.00	0.0	10.257	0.014	2	1	1	1
PL.23789	PL.23116	A	6 A (CWC)	7.35Y	122.5	0.00	2.49	0.26	0	2	1	89	0.00	0.0	10.051	0.005	0	0	0	1
PD.3325	PL.23789	A	15T	7.35Y	122.5	0.00	2.49	0.26	0	2	1	89	0.00	0.0	10.051	0.005	0	0	0	1
PL.23790	PD.3325	A	6 A (CWC)	7.35Y	122.5	0.00	2.49	0.26	0	2	1	89	0.00	0.0	10.094	0.043	2	1	1	1
PL.23795	PL.23403	C	6 A (CWC)	7.35Y	122.5	0.00	2.46	2.85	2	20	6	96	0.00	0.0	9.580	0.005	0	0	0	8
PD.3328	PL.23795	C	15T	7.35Y	122.5	0.00	2.46	2.85	0	20	6	96	0.00	0.0	9.580	0.005	0	0	0	8
PL.23796	PD.3328	C	6 A (CWC)	7.35Y	122.5	0.00	2.46	2.85	2	20	6	96	0.00	0.0	9.621	0.041	3	1	3	8
PL.23610	PL.23796	C	6 A (CWC)	7.35Y	122.5	0.01	2.47	2.46	2	17	5	96	0.00	0.0	9.686	0.065	11	3	2	5
PL.23113	PL.23610	C	#4 ACSR	7.35Y	122.5	0.00	2.47	0.94	1	7	2	96	0.00	0.0	9.704	0.019	7	2	3	3
PL.23791	PL.23113	C	#2 ACSR	7.35Y	122.5	0.00	2.47	0.00	0	0	0	100	0.00	0.0	9.709	0.005	0	0	0	0
PD.3326	PL.23791	C	10T	7.35Y	122.5	0.00	2.47	0.00	0	0	0	100	0.00	0.0	9.709	0.005	0	0	0	0
PL.23792	PD.3326	C	#2 ACSR	7.35Y	122.5	0.00	2.47	0.00	0	0	0	100	0.00	0.0	9.802	0.093	0	0	0	0
PL.23797	PL.23608	A	6 A (CWC)	7.35Y	122.6	0.00	2.45	1.84	1	13	4	96	0.00	0.0	9.509	0.005	0	0	0	3
PD.3329	PL.23797	A	15T	7.35Y	122.6	0.00	2.45	1.84	0	13	4	96	0.00	0.0	9.509	0.005	0	0	0	3
PL.23798	PD.3329	A	6 A (CWC)	7.35Y	122.5	0.01	2.45	1.84	1	13	4	96	0.00	0.0	9.581	0.072	3	1	1	3
PL.23092	PL.23798	A	6 A (CWC)	7.35Y	122.5	0.00	2.46	1.45	1	10	3	96	0.00	0.0	9.697	0.116	10	3	2	2
PL.23793	PL.23600	C	6 A (CWC)	7.35Y	122.6	0.00	2.43	1.70	1	12	3	97	0.00	0.0	9.408	0.005	0	0	0	3
PD.3327	PL.23793	C	15T	7.35Y	122.6	0.00	2.43	1.70	0	12	3	97	0.00	0.0	9.408	0.005	0	0	0	3
PL.23794	PD.3327	C	6 A (CWC)	7.35Y	122.6	0.00	2.44	1.70	1	12	3	97	0.00	0.0	9.455	0.047	7	2	1	3
PL.23609	PL.23794	C	6 A (CWC)	7.35Y	122.6	0.00	2.44	0.74	1	5	1	98	0.00	0.0	9.482	0.027	5	1	2	2
PL.23829	PL.23402	C	6 A (CWC)	7.36Y	122.6	0.00	2.40	1.79	1	13	4	96	0.00	0.0	9.153	0.005	0	0	0	7
PD.3346	PL.23829	C	15T	7.36Y	122.6	0.00	2.40	1.79	0	13	4	96	0.00	0.0	9.153	0.005	0	0	0	7
PL.23830	PD.3346	C	6 A (CWC)	7.36Y	122.6	0.00	2.40	1.79	1	13	4	96	0.00	0.0	9.198	0.045	2	1	1	7
PL.23090	PL.23830	C	6 A (CWC)	7.36Y	122.6	0.01	2.41	1.45	1	10	3	96	0.00	0.0	9.315	0.117	0	0	1	6
PL.23091	PL.23090	C	6 A (CWC)	7.36Y	122.6	0.01	2.41	1.42	1	10	3	96	0.00	0.0	9.410	0.095	0	0	0	5
PL.23299	PL.23091	C	6 A (CWC)	7.35Y	122.6	0.01	2.42	1.42	1	10	3	96	0.00	0.0	9.523	0.113	0	0	1	5

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Millers Creek

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.23781	PL.23299	C	2 AL URD	7.35Y	122.6	0.00	2.42	1.42	1	10	3	96	0.00	0.0	9.527	0.005	0	0	0	4
PD.3321	PL.23781	C	10T	7.35Y	122.6	0.00	2.42	1.42	0	10	3	96	0.00	0.0	9.527	0.005	0	0	0	4
PL.23782	PD.3321	C	2 AL URD	7.35Y	122.6	0.00	2.43	1.42	1	10	3	96	0.00	0.0	9.650	0.122	7	2	2	4
PL.23309	PL.23782	C	2 AL URD	7.35Y	122.6	0.00	2.43	0.48	0	3	1	95	0.00	0.0	9.814	0.164	0	0	0	2
PL.23114	PL.23309	C	2 AL URD	7.35Y	122.6	0.00	2.43	0.10	0	1	0	100	0.00	0.0	9.848	0.034	1	0	1	1
PL.23310	PL.23309	C	2 AL URD	7.35Y	122.6	0.00	2.43	0.37	0	3	1	95	0.00	0.0	9.919	0.105	3	1	1	1
PL.23775	PL.23458	A	#1/0 ACSR	7.36Y	122.7	0.00	2.33	7.24	3	51	14	96	0.00	0.0	8.743	0.005	0	0	0	2
PD.3318	PL.23775	A	15T	7.36Y	122.7	0.00	2.33	7.24	0	51	14	96	0.00	0.0	8.743	0.005	0	0	0	2
PL.23776	PD.3318	A	#1/0 ACSR	7.36Y	122.7	0.01	2.34	7.24	3	51	14	96	0.00	0.0	8.820	0.076	0	0	0	2
PL.23298	PL.23776	A	#1/0 ACSR	7.36Y	122.6	0.02	2.36	7.24	3	51	14	96	0.01	0.0	8.935	0.116	0	0	0	2
PL.23536	PL.23298	A	#1/0 ACSR	7.36Y	122.6	0.01	2.37	7.24	3	51	14	96	0.00	0.0	8.986	0.051	2	1	1	2
PL.23537	PL.23536	A	#1/0 ACSR	7.36Y	122.6	0.01	2.38	6.98	3	49	14	96	0.00	0.0	9.167	0.180	49	14	1	1
PL.23691	PL.23413	A	6 A (CWC)	7.39Y	123.2	0.00	1.79	0.99	1	7	2	96	0.00	0.0	6.797	0.004	0	0	0	2
PD.3275	PL.23691	A	10T	7.39Y	123.2	0.00	1.79	0.99	0	7	2	96	0.00	0.0	6.797	0.004	0	0	0	2
PL.23692	PD.3275	A	6 A (CWC)	7.39Y	123.2	0.00	1.79	0.99	1	7	2	96	0.00	0.0	6.855	0.058	7	2	2	2
PL.23693	PL.23416	A	#4 ACSR	7.39Y	123.2	0.00	1.76	1.20	1	9	2	98	0.00	0.0	6.732	0.005	0	0	0	1
PD.3276	PL.23693	A	20T	7.39Y	123.2	0.00	1.76	1.20	0	9	2	98	0.00	0.0	6.732	0.005	0	0	0	1
PL.23694	PD.3276	A	#4 ACSR	7.39Y	123.2	0.00	1.76	1.20	1	9	2	98	0.00	0.0	6.783	0.051	9	2	1	1
PL.22861	PL.23886	ABC	6 A (CWC)	7.40Y	123.4	0.00	1.61	0.78	1	16	8	89	0.00	0.0	6.414	0.005	0	0	0	2
PD.3363	PL.22861	ABC	20T	7.40Y	123.4	0.00	1.61	0.78	0	16	8	89	0.00	0.0	6.414	0.005	0	0	0	2
PL.23181	PD.3363	ABC	6 A (CWC)	7.40Y	123.4	0.00	1.61	0.67	0	13	6	91	0.00	0.0	6.471	0.057	0	0	0	1
PL.22862	PL.23181	ABC	6 A (CWC)	7.40Y	123.4	0.00	1.62	0.67	0	13	6	91	0.00	0.0	6.605	0.134	0	0	0	1
PL.23287	PL.22862	ABC	6 A (CWC)	7.40Y	123.4	0.00	1.62	0.67	0	13	6	91	0.00	0.0	6.678	0.073	0	0	0	1
PL.23288	PL.23287	ABC	6 A (CWC)	7.40Y	123.4	0.00	1.62	0.67	0	13	6	91	0.00	0.0	6.764	0.086	0	0	0	1
PL.23289	PL.23288	ABC	6 A (CWC)	7.40Y	123.4	0.00	1.62	0.67	0	13	6	91	0.00	0.0	6.884	0.120	13	6	1	1
PL.22860	PD.3363	ABC	6 A (CWC)	7.40Y	123.4	0.00	1.61	0.11	0	2	1	89	0.00	0.0	6.470	0.056	2	1	1	1
PL.23689	PL.23286	C	#4 ACSR	7.41Y	123.5	0.00	1.47	0.00	0	0	0	100	0.00	0.0	6.198	0.005	0	0	0	0
PD.3274	PL.23689	C	30T	7.41Y	123.5	0.00	1.47	0.00	0	0	0	100	0.00	0.0	6.198	0.005	0	0	0	0
PL.23690	PD.3274	C	#4 ACSR	7.41Y	123.5	0.00	1.47	0.00	0	0	0	100	0.00	0.0	6.273	0.075	0	0	0	0
PL.23883	PL.23510	ABC	#1/0 ACSR	7.42Y	123.7	0.01	1.31	22.52	10	482	137	96	0.05	0.0	5.970	0.036	0	0	0	128
PD.3374	PL.23883	ABC	50L	7.42Y	123.7	0.00	1.31	22.52	45	482	137	96	0.00	0.0	5.970	0.036	0	0	0	128

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Millers Creek

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru

PL.23884	PD.3374	ABC	#1/0 ACSR	7.42Y	123.6	0.07	1.39	22.52	10	482	137	96	0.24	0.1	6.152	0.182	7	2	1	128
PL.23501	PL.23884	ABC	#1/0 ACSR	7.41Y	123.6	0.03	1.42	22.18	10	475	135	96	0.10	0.0	6.229	0.077	0	0	0	127
PL.23683	PL.23501	A	#2 ACSR	7.41Y	123.6	0.00	1.42	0.15	0	1	0	100	0.00	0.0	6.233	0.005	0	0	0	1
PD.3271	PL.23683	A	20T	7.41Y	123.6	0.00	1.42	0.15	0	1	0	100	0.00	0.0	6.233	0.005	0	0	0	1
PL.23684	PD.3271	A	#2 ACSR	7.41Y	123.6	0.00	1.42	0.15	0	1	0	100	0.00	0.0	6.256	0.023	1	0	1	1
PL.22863	PL.23501	C	#2 ACSR	7.41Y	123.6	0.00	1.42	2.61	1	19	5	97	0.00	0.0	6.236	0.008	6	2	1	6
PL.23685	PL.22863	C	6 A (CWC)	7.41Y	123.6	0.00	1.42	1.72	1	12	3	97	0.00	0.0	6.241	0.005	0	0	0	5
PD.3272	PL.23685	C	20T	7.41Y	123.6	0.00	1.42	1.72	0	12	3	97	0.00	0.0	6.241	0.005	0	0	0	5
PL.23686	PD.3272	C	6 A (CWC)	7.41Y	123.6	0.01	1.43	1.72	1	12	3	97	0.00	0.0	6.334	0.093	2	1	1	5
PL.23498	PL.23686	C	#4 ACSR	7.41Y	123.6	0.00	1.43	1.43	1	10	3	96	0.00	0.0	6.345	0.011	0	0	1	4
PL.23502	PL.23498	C	#4 ACSR	7.41Y	123.6	0.00	1.43	1.42	1	10	3	96	0.00	0.0	6.397	0.052	0	0	0	3
PL.23503	PL.23502	C	#4 ACSR	7.41Y	123.6	0.00	1.43	1.42	1	10	3	96	0.00	0.0	6.418	0.020	10	3	3	3
PL.23166	PL.23501	ABC	#1/0 ACSR	7.41Y	123.6	0.02	1.44	21.26	9	455	129	96	0.07	0.0	6.290	0.062	0	0	0	120
PL.22991	PL.23166	ABC	#1/0 ACSR	7.41Y	123.5	0.02	1.46	21.26	9	455	129	96	0.05	0.0	6.331	0.040	0	0	0	120
PL.23629	PL.22991	ABC	#1/0 ACSR	7.41Y	123.5	0.02	1.48	19.91	9	426	121	96	0.06	0.0	6.389	0.058	0	0	1	107
PL.23630	PL.23629	ABC	#1/0 ACSR	7.41Y	123.5	0.02	1.50	19.89	9	425	121	96	0.06	0.0	6.446	0.057	1	0	1	106
PL.23627	PL.23630	ABC	#1/0 ACSR	7.41Y	123.5	0.01	1.51	19.84	9	424	121	96	0.02	0.0	6.468	0.022	2	0	1	105
PL.23628	PL.23627	ABC	#1/0 ACSR	7.41Y	123.4	0.06	1.57	19.76	9	423	120	96	0.17	0.0	6.630	0.161	0	0	0	104
PL.23823	PL.23628	A	#4 ACSR	7.41Y	123.4	0.00	1.57	0.36	0	3	1	95	0.00	0.0	6.634	0.005	0	0	0	1
PD.3343	PL.23823	A	20T	7.41Y	123.4	0.00	1.57	0.36	0	3	1	95	0.00	0.0	6.634	0.005	0	0	0	1
PL.23824	PD.3343	A	#4 ACSR	7.41Y	123.4	0.00	1.57	0.36	0	3	1	95	0.00	0.0	6.688	0.054	3	1	1	1
PL.23168	PL.23628	ABC	#1/0 ACSR	7.40Y	123.4	0.02	1.59	19.64	9	420	119	96	0.07	0.0	6.700	0.070	0	0	0	103
PL.23821	PL.23168	C	#4 ACSR	7.40Y	123.4	0.00	1.59	0.02	0	0	0	100	0.00	0.0	6.704	0.005	0	0	0	1
PD.3342	PL.23821	C	20T	7.40Y	123.4	0.00	1.59	0.02	0	0	0	100	0.00	0.0	6.704	0.005	0	0	0	1
PL.23822	PD.3342	C	#4 ACSR	7.40Y	123.4	0.00	1.59	0.02	0	0	0	100	0.00	0.0	6.724	0.020	0	0	1	1
PL.23169	PL.23168	ABC	#1/0 ACSR	7.40Y	123.4	0.02	1.61	19.64	9	420	119	96	0.06	0.0	6.756	0.057	0	0	0	102
PL.23348	PL.23169	ABC	#1/0 ACSR	7.40Y	123.4	0.01	1.62	19.64	9	420	119	96	0.04	0.0	6.794	0.037	0	0	1	102
PL.23349	PL.23348	ABC	#1/0 ACSR	7.40Y	123.3	0.04	1.67	19.63	9	419	119	96	0.13	0.0	6.920	0.127	3	1	2	101
PL.23877	PL.23349	B	6 A (CWC)	7.40Y	123.3	0.00	1.67	34.00	24	242	69	96	0.01	0.0	6.923	0.003	0	0	0	60
PD.3371	PL.23877	B	50L	7.40Y	123.3	0.00	1.67	34.00	68	242	69	96	0.00	0.0	6.923	0.003	0	0	0	60
PL.23878	PD.3371	B	6 A (CWC)	7.39Y	123.2	0.15	1.83	34.00	24	242	69	96	0.28	0.1	7.021	0.098	0	0	0	60

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Millers Creek

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.23170	PL.23878	B	6 A (CWC)	7.39Y	123.1	0.08	1.91	34.00	24	242	69	96	0.14	0.1	7.072	0.051	1	0	1	60
PL.23039	PL.23170	B	#4 ACSR	7.39Y	123.1	0.00	1.91	0.31	0	2	1	89	0.00	0.0	7.116	0.044	2	1	1	1
PL.23427	PL.23170	B	6 A (CWC)	7.38Y	123.0	0.14	2.04	33.53	24	238	68	96	0.24	0.1	7.163	0.091	5	1	1	58
PL.23428	PL.23427	B	6 A (CWC)	7.37Y	122.8	0.16	2.20	32.24	23	229	65	96	0.27	0.1	7.271	0.108	7	2	2	56
PL.23042	PL.23428	B	6 A (CWC)	7.37Y	122.8	0.02	2.22	31.20	22	221	63	96	0.04	0.0	7.287	0.016	0	0	0	54
PL.23043	PL.23042	B	6 A (CWC)	7.37Y	122.8	0.00	2.23	3.27	2	23	6	97	0.00	0.0	7.336	0.049	23	6	3	3
PL.23171	PL.23042	B	6 A (CWC)	7.36Y	122.6	0.15	2.38	27.93	20	198	56	96	0.23	0.1	7.408	0.121	0	0	0	51
PL.23172	PL.23171	B	6 A (CWC)	7.35Y	122.5	0.11	2.49	27.93	20	198	56	96	0.16	0.1	7.496	0.088	5	1	2	51
PL.23045	PL.23172	B	6 A (CWC)	7.34Y	122.3	0.17	2.66	27.22	19	193	54	96	0.25	0.1	7.633	0.136	0	0	0	49
PL.23346	PL.23045	B	6 A (CWC)	7.34Y	122.3	0.07	2.73	27.22	19	192	54	96	0.10	0.1	7.688	0.056	2	1	1	49
PL.23347	PL.23346	B	6 A (CWC)	7.33Y	122.2	0.05	2.78	26.88	19	190	54	96	0.07	0.0	7.730	0.042	0	0	1	48
PL.23345	PL.23347	B	6 A (CWC)	7.32Y	122.0	0.18	2.96	26.84	19	189	53	96	0.26	0.1	7.881	0.151	5	1	1	47
PL.23344	PL.23345	B	6 A (CWC)	7.32Y	122.0	0.06	3.02	26.15	19	184	52	96	0.08	0.0	7.929	0.048	12	3	2	46
PL.23342	PL.23344	B	6 A (CWC)	7.31Y	121.8	0.14	3.16	24.49	17	173	49	96	0.18	0.1	8.052	0.123	2	0	1	44
PL.23343	PL.23342	B	6 A (CWC)	7.31Y	121.8	0.03	3.18	24.24	17	171	48	96	0.03	0.0	8.076	0.024	0	0	0	43
PL.23046	PL.23343	B	#4 ACSR	7.31Y	121.8	0.00	3.18	0.36	0	3	1	95	0.00	0.0	8.171	0.095	3	1	1	1
PL.23173	PL.23343	B	6 A (CWC)	7.31Y	121.8	0.02	3.21	23.88	17	168	47	96	0.03	0.0	8.097	0.021	2	0	1	42
PL.23048	PL.23173	B	6 A (CWC)	7.31Y	121.8	0.00	3.21	23.67	17	166	47	96	0.01	0.0	8.102	0.005	0	0	0	41
PD.3341	PL.23048	B	15T	7.31Y	121.8	0.00	3.21	23.67	0	166	47	96	0.00	0.0	8.102	0.005	0	0	0	41
PL.23047	PD.3341	B	#1/0 ACSR	7.31Y	121.8	0.00	3.21	3.55	2	25	7	96	0.00	0.0	8.137	0.035	25	7	3	3
PL.23441	PD.3341	B	6 A (CWC)	7.30Y	121.7	0.13	3.34	20.12	14	142	40	96	0.14	0.1	8.248	0.146	3	1	1	38
PL.23323	PL.23441	B	6 A (CWC)	7.30Y	121.7	0.00	3.35	0.94	1	7	2	96	0.00	0.0	8.287	0.039	7	2	1	1
PL.23324	PL.23323	B	6 A (CWC)	7.30Y	121.7	0.00	3.35	0.00	0	0	0	100	0.00	0.0	8.344	0.057	0	0	0	0
PL.23442	PL.23441	B	6 A (CWC)	7.30Y	121.6	0.05	3.40	18.74	13	132	37	96	0.05	0.0	8.308	0.060	4	1	2	36
PL.23081	PL.23442	B	#1/0 ACSR	7.30Y	121.6	0.00	3.40	1.14	0	8	2	97	0.00	0.0	8.335	0.028	8	2	1	1
PL.23443	PL.23442	B	6 A (CWC)	7.29Y	121.5	0.09	3.48	16.96	12	119	33	96	0.08	0.1	8.418	0.111	1	0	1	33
PL.23079	PL.23443	B	6 A (CWC)	7.29Y	121.4	0.09	3.57	7.86	6	55	15	96	0.04	0.1	8.672	0.254	1	0	1	13
PL.23082	PL.23079	B	6 A (CWC)	7.28Y	121.4	0.05	3.62	7.65	5	54	15	96	0.02	0.0	8.848	0.176	16	4	3	12
PL.23440	PL.23082	B	#4 ACSR	7.28Y	121.3	0.03	3.66	5.42	4	38	11	96	0.01	0.0	8.988	0.140	1	0	1	9
PL.23815	PL.23440	B	#4 ACSR	7.28Y	121.3	0.00	3.66	5.02	4	35	10	96	0.00	0.0	8.993	0.005	0	0	0	7
PD.3338	PL.23815	B	15T	7.28Y	121.3	0.00	3.66	5.02	0	35	10	96	0.00	0.0	8.993	0.005	0	0	0	7

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Millers Creek

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.23816	PD.3338	B	#4 ACSR	7.28Y	121.3	0.03	3.69	5.02	4	35	10	96	0.01	0.0	9.114	0.121	0	0	0	7
PL.23279	PL.23816	B	#4 ACSR	7.28Y	121.3	0.04	3.72	5.02	4	35	10	96	0.01	0.0	9.287	0.174	0	0	0	7
PL.23280	PL.23279	B	#4 ACSR	7.28Y	121.3	0.02	3.74	5.02	4	35	10	96	0.00	0.0	9.360	0.073	0	0	0	7
PL.23321	PL.23280	B	#4 ACSR	7.27Y	121.2	0.01	3.75	5.02	4	35	10	96	0.00	0.0	9.423	0.063	7	2	1	7
PL.23322	PL.23321	B	#4 ACSR	7.27Y	121.2	0.00	3.76	3.99	3	28	8	96	0.00	0.0	9.444	0.021	0	0	0	6
PL.23084	PL.23322	B	#2 ACSR	7.27Y	121.2	0.00	3.76	0.57	0	4	1	97	0.00	0.0	9.495	0.051	0	0	0	1
PL.23813	PL.23084	B	1/0 AL URD	7.27Y	121.2	0.00	3.76	0.57	0	4	1	97	0.00	0.0	9.500	0.005	0	0	0	1
PD.3337	PL.23813	B	12T	7.27Y	121.2	0.00	3.76	0.57	0	4	1	97	0.00	0.0	9.500	0.005	0	0	0	1
PL.23814	PD.3337	B	1/0 AL URD	7.27Y	121.2	0.00	3.76	0.57	0	4	1	97	0.00	0.0	9.518	0.018	0	0	0	1
PL.23811	PL.23814	B	#2 ACSR	7.27Y	121.2	0.00	3.76	0.57	0	4	1	97	0.00	0.0	9.523	0.005	0	0	0	1
PD.3336	PL.23811	B	10T	7.27Y	121.2	0.00	3.76	0.57	0	4	1	97	0.00	0.0	9.523	0.005	0	0	0	1
PL.23812	PD.3336	B	#2 ACSR	7.27Y	121.2	0.00	3.76	0.57	0	4	1	97	0.00	0.0	9.548	0.025	0	0	0	1
PL.23085	PL.23812	B	#2 ACSR	7.27Y	121.2	0.00	3.76	0.00	0	0	0	100	0.00	0.0	9.582	0.034	0	0	0	0
PL.23086	PL.23812	B	#2 ACSR	7.27Y	121.2	0.00	3.76	0.57	0	4	1	97	0.00	0.0	9.615	0.067	4	1	1	1
PL.23317	PL.23322	B	#4 ACSR	7.27Y	121.2	0.02	3.77	3.42	3	24	7	96	0.00	0.0	9.557	0.113	5	1	1	5
PL.23318	PL.23317	B	#4 ACSR	7.27Y	121.2	0.01	3.78	2.73	2	19	5	97	0.00	0.0	9.605	0.048	0	0	0	4
PL.23319	PL.23318	B	#4 ACSR	7.27Y	121.2	0.00	3.78	1.61	1	11	3	96	0.00	0.0	9.670	0.065	0	0	1	3
PL.23320	PL.23319	B	#4 ACSR	7.27Y	121.2	0.00	3.79	1.61	1	11	3	96	0.00	0.0	9.716	0.046	0	0	0	2
PL.23281	PL.23320	B	#4 ACSR	7.27Y	121.2	0.01	3.80	1.61	1	11	3	96	0.00	0.0	9.866	0.150	3	1	1	2
PL.23088	PL.23281	B	#4 ACSR	7.27Y	121.2	0.01	3.81	1.21	1	8	2	97	0.00	0.0	10.049	0.183	0	0	0	1
PL.23282	PL.23088	B	#4 ACSR	7.27Y	121.2	0.00	3.81	1.21	1	8	2	97	0.00	0.0	10.128	0.079	8	2	1	1
PL.23087	PL.23318	B	#2 ACSR	7.27Y	121.2	0.00	3.78	1.12	1	8	2	97	0.00	0.0	9.633	0.028	8	2	1	1
PL.23083	PL.23440	B	#4 ACSR	7.28Y	121.3	0.00	3.66	0.22	0	2	0	100	0.00	0.0	9.030	0.042	2	0	1	1
PL.23066	PL.23443	B	6 A (CWC)	7.29Y	121.5	0.03	3.51	8.97	6	63	18	96	0.01	0.0	8.489	0.071	0	0	0	19
PL.23315	PL.23066	B	6 A (CWC)	7.29Y	121.5	0.02	3.53	8.66	6	61	17	96	0.01	0.0	8.533	0.044	1	0	2	17
PL.23316	PL.23315	B	6 A (CWC)	7.29Y	121.5	0.01	3.54	8.50	6	60	17	96	0.01	0.0	8.565	0.032	4	1	1	15
PL.23067	PL.23316	B	6 A (CWC)	7.29Y	121.5	0.01	3.55	6.87	5	48	14	96	0.00	0.0	8.595	0.030	0	0	0	13
PL.23069	PL.23067	B	6 A (CWC)	7.28Y	121.4	0.04	3.59	6.34	5	45	12	97	0.01	0.0	8.744	0.149	5	1	1	12
PL.23313	PL.23069	B	6 A (CWC)	7.28Y	121.4	0.02	3.61	5.67	4	40	11	96	0.01	0.0	8.820	0.076	4	1	1	10
PL.23314	PL.23313	B	6 A (CWC)	7.28Y	121.4	0.02	3.62	5.11	4	36	10	96	0.00	0.0	8.895	0.075	7	2	2	9
PL.23312	PL.23314	B	6 A (CWC)	7.28Y	121.3	0.03	3.66	4.07	3	29	8	96	0.01	0.0	9.081	0.185	3	1	1	7

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Millers Creek

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.23311	PL.23312	B	6 A (CWC)	7.28Y	121.3	0.01	3.67	3.69	3	26	7	97	0.00	0.0	9.163	0.082	0	0	0	6
PL.23174	PL.23311	B	6 A (CWC)	7.28Y	121.3	0.01	3.68	2.88	2	20	6	96	0.00	0.0	9.222	0.059	0	0	0	5
PL.23284	PL.23174	B	6 A (CWC)	7.28Y	121.3	0.02	3.70	2.88	2	20	6	96	0.00	0.0	9.386	0.164	0	0	0	5
PL.23285	PL.23284	B	6 A (CWC)	7.28Y	121.3	0.02	3.72	2.88	2	20	6	96	0.00	0.0	9.534	0.149	0	0	0	5
PL.23175	PL.23285	B	6 A (CWC)	7.28Y	121.3	0.01	3.73	2.88	2	20	6	96	0.00	0.0	9.590	0.056	0	0	0	5
PL.23073	PL.23175	B	#4 ACSR	7.28Y	121.3	0.00	3.73	0.94	1	7	2	96	0.00	0.0	9.649	0.059	7	2	2	2
PL.23176	PL.23175	B	6 A (CWC)	7.28Y	121.3	0.00	3.73	1.94	1	14	4	96	0.00	0.0	9.622	0.032	0	0	0	3
PL.23074	PL.23176	B	#4 ACSR	7.28Y	121.3	0.00	3.73	0.61	0	4	1	97	0.00	0.0	9.661	0.039	4	1	2	2
PL.23075	PL.23176	B	6 A (CWC)	7.28Y	121.3	0.00	3.73	1.34	1	9	3	95	0.00	0.0	9.671	0.048	0	0	0	1
PL.23077	PL.23075	B	6 A (CWC)	7.28Y	121.3	0.00	3.73	0.00	0	0	0	100	0.00	0.0	9.743	0.072	0	0	0	0
PL.23076	PL.23075	B	#4 ACSR	7.28Y	121.3	0.00	3.74	1.34	1	9	3	95	0.00	0.0	9.737	0.067	9	3	1	1
PL.23071	PL.23311	B	#1/0 ACSR	7.28Y	121.3	0.00	3.67	0.81	0	6	2	95	0.00	0.0	9.219	0.056	6	2	1	1
PL.23070	PL.23069	B	#4 ACSR	7.28Y	121.4	0.00	3.59	0.00	0	0	0	100	0.00	0.0	8.885	0.141	0	0	1	1
PL.23068	PL.23067	B	#4 ACSR	7.29Y	121.5	0.00	3.55	0.52	0	4	1	97	0.00	0.0	8.684	0.089	4	1	1	1
PL.23447	PL.23316	B	6 A (CWC)	7.29Y	121.5	0.00	3.54	1.11	1	8	2	97	0.00	0.0	8.618	0.053	8	2	1	1
PL.23078	PL.23066	B	6 A (CWC)	7.29Y	121.5	0.00	3.51	0.31	0	2	1	89	0.00	0.0	8.557	0.068	2	1	2	2
PL.23080	PL.23066	B	#4 ACSR	7.29Y	121.5	0.00	3.51	0.00	0	0	0	100	0.00	0.0	8.585	0.096	0	0	0	0
PL.23283	PL.23080	B	#4 ACSR	7.29Y	121.5	0.00	3.51	0.00	0	0	0	100	0.00	0.0	8.729	0.144	0	0	0	0
PL.23044	PL.23171	B	#4 ACSR	7.36Y	122.6	0.00	2.38	0.00	0	0	0	100	0.00	0.0	7.474	0.066	0	0	0	0
PL.23040	PL.23427	B	6 A (CWC)	7.38Y	123.0	0.00	2.04	0.59	0	4	1	97	0.00	0.0	7.215	0.052	4	1	1	1
PL.23041	PL.23040	B	6 A (CWC)	7.38Y	123.0	0.00	2.04	0.00	0	0	0	100	0.00	0.0	7.384	0.169	0	0	0	0
PL.23137	PL.23041	B	6 A (CWC)	7.38Y	123.0	0.00	2.04	0.00	0	0	0	100	0.00	0.0	7.431	0.048	0	0	0	0
PL.22994	PL.23878	B	6 A (CWC)	7.39Y	123.2	0.00	1.83	0.00	0	0	0	100	0.00	0.0	7.062	0.040	0	0	0	0
PL.22993	PL.22994	B	6 A (CWC)	7.39Y	123.2	0.00	1.83	0.00	0	0	0	100	0.00	0.0	7.119	0.057	0	0	0	0
PL.23277	PL.22993	B	6 A (CWC)	7.39Y	123.2	0.00	1.83	0.00	0	0	0	100	0.00	0.0	7.276	0.157	0	0	0	0
PL.23278	PL.23277	B	6 A (CWC)	7.39Y	123.2	0.00	1.83	0.00	0	0	0	100	0.00	0.0	7.312	0.036	0	0	0	0
PL.22992	PL.23278	B	#4 ACSR	7.39Y	123.2	0.00	1.83	0.00	0	0	0	100	0.00	0.0	7.419	0.107	0	0	0	0
PL.23847	PL.23349	A	#4 ACSR	7.40Y	123.3	0.01	1.67	24.44	19	174	49	96	0.01	0.0	6.925	0.005	0	0	0	39
PD.3355	PL.23847	A	20T	7.40Y	123.3	0.00	1.67	24.44	0	174	49	96	0.00	0.0	6.925	0.005	0	0	0	39
PL.23848	PD.3355	A	#4 ACSR	7.39Y	123.1	0.20	1.88	24.44	19	174	49	96	0.26	0.2	7.110	0.185	0	0	0	39
PL.23051	PL.23848	A	#4 ACSR	7.37Y	122.9	0.24	2.12	24.44	19	174	49	96	0.32	0.2	7.333	0.223	0	0	1	39

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Millers Creek

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.23177	PL.23051	A	#4 ACSR	7.37Y	122.8	0.11	2.23	23.24	18	165	46	96	0.14	0.1	7.438	0.105	0	0	0	36
PL.23178	PL.23177	A	#4 ACSR	7.36Y	122.6	0.17	2.39	22.25	17	158	44	96	0.20	0.1	7.604	0.166	0	0	0	35
PL.23050	PL.23178	A	#4 ACSR	7.35Y	122.5	0.06	2.46	21.28	16	151	42	96	0.07	0.0	7.671	0.067	0	0	0	33
PL.23054	PL.23050	A	#4 ACSR	7.35Y	122.5	0.00	2.46	0.02	0	0	0	100	0.00	0.0	7.682	0.011	0	0	1	1
PL.23338	PL.23050	A	#4 ACSR	7.35Y	122.5	0.04	2.50	21.25	16	150	42	96	0.05	0.0	7.714	0.043	0	0	2	32
PL.23339	PL.23338	A	#4 ACSR	7.34Y	122.4	0.15	2.65	21.20	16	150	42	96	0.17	0.1	7.873	0.158	0	0	0	30
PL.23331	PL.23339	A	#4 ACSR	7.33Y	122.2	0.13	2.78	17.00	13	120	34	96	0.12	0.1	8.045	0.172	5	1	2	22
PL.23332	PL.23331	A	#4 ACSR	7.33Y	122.1	0.09	2.86	16.29	13	115	32	96	0.07	0.1	8.177	0.132	22	6	3	20
PL.23431	PL.23332	A	#4 ACSR	7.33Y	122.1	0.04	2.90	12.21	9	86	24	96	0.03	0.0	8.252	0.076	0	0	0	16
PL.23060	PL.23431	A	#4 ACSR	7.33Y	122.1	0.00	2.90	0.00	0	0	0	100	0.00	0.0	8.280	0.027	0	0	0	0
PL.23329	PL.23431	A	#4 ACSR	7.32Y	122.0	0.06	2.97	12.21	9	86	24	96	0.04	0.0	8.370	0.118	2	1	1	16
PL.23330	PL.23329	A	#4 ACSR	7.32Y	122.0	0.04	3.01	11.95	9	84	24	96	0.03	0.0	8.446	0.075	0	0	0	15
PL.23436	PL.23330	A	#4 ACSR	7.32Y	121.9	0.05	3.06	10.76	8	76	21	96	0.03	0.0	8.563	0.118	18	5	4	13
PL.23437	PL.23436	A	#4 ACSR	7.32Y	121.9	0.02	3.08	7.13	5	50	14	96	0.01	0.0	8.638	0.074	7	2	1	7
PL.23438	PL.23437	A	#4 ACSR	7.31Y	121.9	0.01	3.09	6.08	5	43	12	96	0.00	0.0	8.689	0.051	0	0	0	6
PL.23063	PL.23438	A	#1/0 ACSR	7.31Y	121.9	0.00	3.09	3.25	1	23	6	97	0.00	0.0	8.723	0.034	23	6	2	2
PL.23179	PL.23438	A	#4 ACSR	7.31Y	121.9	0.01	3.11	2.83	2	20	6	96	0.00	0.0	8.820	0.131	5	2	1	4
PL.23065	PL.23179	A	#1/0 ACSR	7.31Y	121.9	0.00	3.11	1.69	1	12	3	97	0.00	0.0	8.856	0.036	12	3	2	2
PL.72556	PL.23065	A	#1/0 ACSR	7.31Y	121.9	0.00	3.11	0.00	0	0	0	100	0.00	0.0	8.906	0.050	0	0	0	0
PL.72557	PL.72556	A	#1/0 ACSR	7.31Y	121.9	0.00	3.11	0.00	0	0	0	100	0.00	0.0	8.960	0.054	0	0	0	0
PL.23064	PL.23179	A	#1/0 ACSR	7.31Y	121.9	0.00	3.11	0.36	0	3	1	95	0.00	0.0	8.838	0.018	3	1	1	1
PL.23062	PL.23437	A	#1/0 ACSR	7.32Y	121.9	0.00	3.08	0.00	0	0	0	100	0.00	0.0	8.661	0.023	0	0	0	0
PL.23325	PL.23436	A	#4 ACSR	7.32Y	121.9	0.00	3.06	1.08	1	8	2	97	0.00	0.0	8.661	0.098	0	0	0	2
PL.23326	PL.23325	A	#4 ACSR	7.32Y	121.9	0.00	3.06	1.08	1	8	2	97	0.00	0.0	8.674	0.013	0	0	0	2
PL.23327	PL.23326	A	#4 ACSR	7.32Y	121.9	0.00	3.06	1.08	1	8	2	97	0.00	0.0	8.737	0.063	0	0	1	2
PL.23328	PL.23327	A	#4 ACSR	7.32Y	121.9	0.00	3.07	1.03	1	7	2	96	0.00	0.0	8.755	0.017	7	2	1	1
PL.23061	PL.23330	A	#4 ACSR	7.32Y	122.0	0.00	3.01	1.19	1	8	2	97	0.00	0.0	8.500	0.055	8	2	2	2
PL.23059	PL.23332	A	#4 ACSR	7.33Y	122.1	0.00	2.86	1.01	1	7	2	96	0.00	0.0	8.279	0.102	7	2	1	1
PL.23819	PL.23339	A	#4 ACSR	7.34Y	122.3	0.01	2.66	4.19	3	30	8	97	0.00	0.0	7.922	0.049	0	0	0	8
PD.3340	PL.23819	A	12T	7.34Y	122.3	0.00	2.66	4.19	0	30	8	97	0.00	0.0	7.922	0.049	0	0	0	8
PL.23820	PD.3340	A	#4 ACSR	7.34Y	122.3	0.01	2.67	4.19	3	30	8	97	0.00	0.0	7.997	0.075	0	0	1	8

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Millers Creek

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.23337	PL.23820	A	#4 ACSR	7.34Y	122.3	0.02	2.69	4.18	3	30	8	97	0.00	0.0	8.109	0.111	0	0	0	7
PL.23275	PL.23337	A	#4 ACSR	7.34Y	122.3	0.02	2.71	4.18	3	30	8	97	0.00	0.0	8.208	0.100	0	0	0	7
PL.23055	PL.23275	A	#4 ACSR	7.34Y	122.3	0.02	2.73	4.18	3	30	8	97	0.00	0.0	8.312	0.104	0	0	0	7
PL.23423	PL.23055	A	#4 ACSR	7.34Y	122.3	0.00	2.73	1.61	1	11	3	96	0.00	0.0	8.374	0.061	3	1	1	4
PL.23424	PL.23423	A	#4 ACSR	7.34Y	122.3	0.00	2.73	0.24	0	2	0	100	0.00	0.0	8.517	0.143	0	0	0	2
PL.23058	PL.23424	A	#4 ACSR	7.34Y	122.3	0.00	2.74	0.24	0	2	0	100	0.00	0.0	8.680	0.163	0	0	0	2
PL.23276	PL.23058	A	#4 ACSR	7.34Y	122.3	0.00	2.74	0.24	0	2	0	100	0.00	0.0	8.773	0.094	2	0	1	2
PL.23089	PL.23276	A	#4 ACSR	7.34Y	122.3	0.00	2.74	0.01	0	0	0	100	0.00	0.0	8.902	0.129	0	0	1	1
PL.23057	PL.23423	A	#1/0 ACSR	7.34Y	122.3	0.00	2.73	0.96	0	7	2	96	0.00	0.0	8.379	0.005	0	0	0	1
PL.23817	PL.23057	A	1/0 AL URD	7.34Y	122.3	0.00	2.73	0.96	1	7	2	96	0.00	0.0	8.383	0.005	0	0	0	1
PD.3339	PL.23817	A	8T	7.34Y	122.3	0.00	2.73	0.96	0	7	2	96	0.00	0.0	8.383	0.005	0	0	0	1
PL.23818	PD.3339	A	1/0 AL URD	7.34Y	122.3	0.00	2.73	0.96	1	7	2	96	0.00	0.0	8.398	0.015	7	2	1	1
PL.23335	PL.23055	A	#4 ACSR	7.34Y	122.3	0.00	2.73	2.58	2	18	5	96	0.00	0.0	8.376	0.064	12	3	1	3
PL.23336	PL.23335	A	#4 ACSR	7.34Y	122.3	0.00	2.74	0.83	1	6	2	95	0.00	0.0	8.475	0.099	0	0	0	2
PL.23333	PL.23336	A	#4 ACSR	7.34Y	122.3	0.00	2.74	0.83	1	6	2	95	0.00	0.0	8.587	0.112	2	0	1	2
PL.23334	PL.23333	A	#4 ACSR	7.34Y	122.3	0.00	2.75	0.59	0	4	1	97	0.00	0.0	8.752	0.165	0	0	0	1
PL.23056	PL.23334	A	#1/0 ACSR	7.34Y	122.3	0.00	2.75	0.59	0	4	1	97	0.00	0.0	8.850	0.098	4	1	1	1
PL.21834	PL.23334	A	#4 ACSR	7.34Y	122.3	0.00	2.75	0.00	0	0	0	100	0.00	0.0	8.857	0.105	0	0	0	0
PL.23049	PL.23178	A	#4 ACSR	7.36Y	122.6	0.00	2.39	0.97	1	7	2	96	0.00	0.0	7.626	0.021	7	2	2	2
PL.23052	PL.23177	A	#4 ACSR	7.37Y	122.8	0.00	2.23	0.99	1	7	2	96	0.00	0.0	7.488	0.050	0	0	0	1
PL.23053	PL.23052	A	#1/0 ACSR	7.37Y	122.8	0.00	2.23	0.99	0	7	2	96	0.00	0.0	7.526	0.038	7	2	1	1
PL.23340	PL.23051	A	#4 ACSR	7.37Y	122.9	0.00	2.12	1.15	1	8	2	97	0.00	0.0	7.397	0.063	4	1	1	2
PL.23341	PL.23340	A	#4 ACSR	7.37Y	122.9	0.00	2.12	0.53	0	4	1	97	0.00	0.0	7.414	0.017	4	1	1	1
PL.23849	PL.22991	A	#4 ACSR	7.41Y	123.5	0.00	1.46	0.45	0	3	1	95	0.00	0.0	6.335	0.005	0	0	0	2
PD.3356	PL.23849	A	20T	7.41Y	123.5	0.00	1.46	0.45	0	3	1	95	0.00	0.0	6.335	0.005	0	0	0	2
PL.23850	PD.3356	A	#4 ACSR	7.41Y	123.5	0.00	1.46	0.45	0	3	1	95	0.00	0.0	6.350	0.015	3	1	2	2
PL.23825	PL.22991	C	#4 ACSR	7.41Y	123.5	0.00	1.46	3.62	3	26	7	97	0.00	0.0	6.335	0.005	0	0	0	11
PD.3344	PL.23825	C	20T	7.41Y	123.5	0.00	1.46	3.62	0	26	7	97	0.00	0.0	6.335	0.005	0	0	0	11
PL.23826	PD.3344	C	#4 ACSR	7.41Y	123.5	0.01	1.47	3.62	3	26	7	97	0.00	0.0	6.413	0.078	0	0	0	11
PL.23422	PL.23826	C	6 A (CWC)	7.41Y	123.5	0.02	1.49	3.59	3	26	7	97	0.00	0.0	6.516	0.102	0	0	1	10
PL.22864	PL.23422	C	#2 ACSR	7.41Y	123.5	0.00	1.49	0.03	0	0	0	100	0.00	0.0	6.598	0.082	0	0	1	1

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Millers Creek

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.23499	PL.23422	C	6 A (CWC)	7.41Y	123.5	0.01	1.50	3.56	3	25	7	96	0.00	0.0	6.574	0.059	1	0	1	8
PL.23500	PL.23499	C	6 A (CWC)	7.41Y	123.5	0.00	1.50	3.40	2	24	7	96	0.00	0.0	6.596	0.022	0	0	0	7
PL.22866	PL.23500	C	#4 ACSR	7.41Y	123.5	0.00	1.51	1.47	1	10	3	96	0.00	0.0	6.719	0.123	10	3	1	1
PL.23167	PL.23500	C	6 A (CWC)	7.41Y	123.5	0.00	1.51	1.94	1	14	4	96	0.00	0.0	6.639	0.043	0	0	0	6
PL.22867	PL.23167	C	6 A (CWC)	7.41Y	123.5	0.01	1.51	1.94	1	14	4	96	0.00	0.0	6.701	0.062	0	0	0	6
PL.23637	PL.22867	C	#4 ACSR	7.41Y	123.5	0.00	1.51	0.80	1	6	2	95	0.00	0.0	6.840	0.139	3	1	1	3
PL.23638	PL.23637	C	#4 ACSR	7.41Y	123.5	0.00	1.51	0.45	0	3	1	95	0.00	0.0	6.858	0.019	3	1	2	2
PL.23135	PL.22867	C	6 A (CWC)	7.41Y	123.5	0.01	1.52	1.14	1	8	2	97	0.00	0.0	6.840	0.139	0	0	0	3
PL.23305	PL.23135	C	6 A (CWC)	7.41Y	123.5	0.00	1.52	1.14	1	8	2	97	0.00	0.0	6.900	0.060	0	0	0	3
PL.23274	PL.23305	C	6 A (CWC)	7.41Y	123.5	0.00	1.52	1.14	1	8	2	97	0.00	0.0	6.973	0.073	7	2	2	3
PL.23136	PL.23274	C	#4 ACSR	7.41Y	123.5	0.00	1.52	0.21	0	1	0	100	0.00	0.0	7.013	0.040	1	0	1	1
PL.22865	PL.23826	C	#4 ACSR	7.41Y	123.5	0.00	1.47	0.03	0	0	0	100	0.00	0.0	6.546	0.133	0	0	1	1
PL.23709	PL.23890	C	#2 ACSR	7.43Y	123.8	0.00	1.19	0.94	1	7	2	96	0.00	0.0	5.833	0.005	0	0	0	1
PD.3284	PL.23709	C	30T	7.43Y	123.8	0.00	1.19	0.94	0	7	2	96	0.00	0.0	5.833	0.005	0	0	0	1
PL.23710	PD.3284	C	#2 ACSR	7.43Y	123.8	0.00	1.19	0.94	1	7	2	96	0.00	0.0	5.876	0.043	7	2	1	1
CP.35	PL.23889	ABC	Cap (300)	7.44Y	123.9	0.00	1.08	0.00	0	0	0	100	0.00	0.0	5.724	0.043	0	0	0	0
PL.23701	PL.23523	A	6 A (CWC)	7.22Y	120.3	0.00	4.70	4.77	3	33	9	96	0.00	0.0	4.628	0.005	0	0	0	6
PD.3280	PL.23701	A	30T	7.22Y	120.3	0.00	4.70	4.77	0	33	9	96	0.00	0.0	4.628	0.005	0	0	0	6
PL.23702	PD.3280	A	6 A (CWC)	7.22Y	120.3	0.03	4.72	4.77	3	33	9	96	0.01	0.0	4.758	0.129	7	2	2	6
PL.23421	PL.23702	A	6 A (CWC)	7.22Y	120.3	0.01	4.73	3.70	3	26	7	97	0.00	0.0	4.796	0.039	3	1	2	4
PL.23707	PL.23421	A	6 A (CWC)	7.22Y	120.3	0.00	4.73	0.16	0	1	0	100	0.00	0.0	4.801	0.005	0	0	0	1
PD.3283	PL.23707	A	20T	7.22Y	120.3	0.00	4.73	0.16	0	1	0	100	0.00	0.0	4.801	0.005	0	0	0	1
PL.23708	PD.3283	A	6 A (CWC)	7.22Y	120.3	0.00	4.73	0.16	0	1	0	100	0.00	0.0	4.844	0.043	1	0	1	1
PL.22856	PL.23708	A	6 A (CWC)	7.22Y	120.3	0.00	4.73	0.00	0	0	0	100	0.00	0.0	4.923	0.079	0	0	0	0
PL.23265	PL.22856	A	6 A (CWC)	7.22Y	120.3	0.00	4.73	0.00	0	0	0	100	0.00	0.0	5.012	0.088	0	0	0	0
PL.23266	PL.23265	A	6 A (CWC)	7.22Y	120.3	0.00	4.73	0.00	0	0	0	100	0.00	0.0	5.145	0.134	0	0	0	0
PL.22855	PL.23421	A	6 A (CWC)	7.22Y	120.3	0.00	4.73	3.13	2	22	6	96	0.00	0.0	4.848	0.052	22	6	1	1
PL.23831	PL.23523	C	6 A (CWC)	7.22Y	120.3	0.00	4.70	1.80	1	12	4	95	0.00	0.0	4.628	0.005	0	0	0	7
PD.3347	PL.23831	C	30T	7.22Y	120.3	0.00	4.70	1.80	0	12	4	95	0.00	0.0	4.628	0.005	0	0	0	7
PL.23832	PD.3347	C	6 A (CWC)	7.22Y	120.3	0.00	4.70	1.80	1	12	4	95	0.00	0.0	4.682	0.054	0	0	0	7
PL.23524	PL.23832	C	6 A (CWC)	7.22Y	120.3	0.00	4.70	1.73	1	12	3	97	0.00	0.0	4.733	0.051	4	1	1	6

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Millers Creek

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.23525	PL.23524	C	6 A (CWC)	7.22Y	120.3	0.00	4.71	1.18	1	8	2	97	0.00	0.0	4.774	0.041	6	2	2	5
PL.23703	PL.23525	C	350 MCM AL	7.22Y	120.3	0.00	4.71	0.13	0	1	0	100	0.00	0.0	4.779	0.005	0	0	0	1
PD.3281	PL.23703	C	20T	7.22Y	120.3	0.00	4.71	0.13	0	1	0	100	0.00	0.0	4.779	0.005	0	0	0	1
PL.23704	PD.3281	C	350 MCM AL	7.22Y	120.3	0.00	4.71	0.13	0	1	0	100	0.00	0.0	4.789	0.010	1	0	1	1
PL.22854	PL.23525	C	#4 ACSR	7.22Y	120.3	0.00	4.71	0.21	0	1	0	100	0.00	0.0	4.797	0.023	1	0	2	2
PL.22852	PL.23832	C	#1/0 ACSR	7.22Y	120.3	0.00	4.70	0.07	0	0	0	100	0.00	0.0	4.702	0.020	0	0	0	1
PL.23699	PL.22852	C	1/0 AL URD	7.22Y	120.3	0.00	4.70	0.07	0	0	0	100	0.00	0.0	4.706	0.005	0	0	0	1
PD.3279	PL.23699	C	20T	7.22Y	120.3	0.00	4.70	0.07	0	0	0	100	0.00	0.0	4.706	0.005	0	0	0	1
PL.23700	PD.3279	C	1/0 AL URD	7.22Y	120.3	0.00	4.70	0.07	0	0	0	100	0.00	0.0	4.726	0.019	0	0	1	1
PL.23677	PL.23435	A	#1/0 ACSR	7.28Y	121.3	0.00	3.68	0.17	0	1	0	100	0.00	0.0	3.448	0.005	0	0	0	1
PD.3268	PL.23677	A	30T	7.28Y	121.3	0.00	3.68	0.17	0	1	0	100	0.00	0.0	3.448	0.005	0	0	0	1
PL.23678	PD.3268	A	#1/0 ACSR	7.28Y	121.3	0.00	3.68	0.17	0	1	0	100	0.00	0.0	3.486	0.038	1	0	1	1
PL.23673	PL.23484	A	#4 ACSR	7.33Y	122.2	0.00	2.78	0.40	0	3	1	95	0.00	0.0	2.436	0.005	0	0	0	3
PD.3266	PL.23673	A	30T	7.33Y	122.2	0.00	2.78	0.40	0	3	1	95	0.00	0.0	2.436	0.005	0	0	0	3
PL.23674	PD.3266	A	#4 ACSR	7.33Y	122.2	0.00	2.78	0.40	0	3	1	95	0.00	0.0	2.520	0.084	3	1	3	3
PL.23669	PL.23163	C	6 A (CWC)	7.35Y	122.4	0.00	2.56	0.31	0	2	1	89	0.00	0.0	2.199	0.005	0	0	0	1
PD.3264	PL.23669	C	30T	7.35Y	122.4	0.00	2.56	0.31	0	2	1	89	0.00	0.0	2.199	0.005	0	0	0	1
PL.23670	PD.3264	C	6 A (CWC)	7.35Y	122.4	0.00	2.56	0.31	0	2	1	89	0.00	0.0	2.259	0.060	2	1	1	1
PL.23671	PL.23882	C	6 A (CWC)	7.35Y	122.5	0.00	2.49	0.01	0	0	0	100	0.00	0.0	2.116	0.005	0	0	0	1
PD.3265	PL.23671	C	30T	7.35Y	122.5	0.00	2.49	0.01	0	0	0	100	0.00	0.0	2.116	0.005	0	0	0	1
PL.23672	PD.3265	C	6 A (CWC)	7.35Y	122.5	0.00	2.49	0.01	0	0	0	100	0.00	0.0	2.196	0.080	0	0	1	1
PL.23665	PL.23450	A	6 A (CWC)	7.36Y	122.7	0.00	2.32	2.97	2	21	6	96	0.00	0.0	1.925	0.005	0	0	0	6
PD.3262	PL.23665	A	50T	7.36Y	122.7	0.00	2.32	2.97	0	21	6	96	0.00	0.0	1.925	0.005	0	0	0	6
PL.23666	PD.3262	A	6 A (CWC)	7.36Y	122.7	0.02	2.33	2.97	2	21	6	96	0.00	0.0	2.044	0.119	0	0	0	6
PL.23259	PL.23666	A	6 A (CWC)	7.36Y	122.7	0.01	2.34	2.97	2	21	6	96	0.00	0.0	2.122	0.078	0	0	0	6
PL.23162	PL.23259	A	6 A (CWC)	7.36Y	122.7	0.01	2.35	2.38	2	17	5	96	0.00	0.0	2.186	0.064	0	0	0	5
PL.23487	PL.23162	A	#4 ACSR	7.36Y	122.6	0.00	2.35	1.33	1	9	3	95	0.00	0.0	2.247	0.061	0	0	2	4
PL.23488	PL.23487	A	#4 ACSR	7.36Y	122.6	0.00	2.35	1.32	1	9	3	95	0.00	0.0	2.287	0.040	9	3	2	2
PL.22846	PL.23162	A	#2 ACSR	7.36Y	122.7	0.00	2.35	1.05	1	7	2	96	0.00	0.0	2.230	0.044	7	2	1	1
PL.22847	PL.23259	A	#1/0 ACSR	7.36Y	122.7	0.00	2.34	0.59	0	4	1	97	0.00	0.0	2.160	0.038	4	1	1	1
PL.22845	PL.23145	ABC	#1/0 ACSR	7.38Y	123.0	0.06	1.98	23.22	10	495	141	96	0.21	0.0	1.641	0.149	0	0	0	167

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Millers Creek

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru

PL.23639	PL.22845	ABC	#1/0 ACSR	7.38Y	123.0	0.03	2.01	23.22	10	494	141	96	0.10	0.0	1.712	0.072	6	2	1	167
PL.23640	PL.23639	ABC	#1/0 ACSR	7.38Y	123.0	0.03	2.04	22.92	10	488	139	96	0.11	0.0	1.792	0.080	0	0	0	166
PL.23212	PL.23640	ABC	#1/0 ACSR	7.38Y	122.9	0.04	2.08	22.92	10	488	139	96	0.13	0.0	1.886	0.094	0	0	0	166
PL.23879	PL.23212	ABC	#1/0 ACSR	7.37Y	122.9	0.05	2.13	22.92	10	488	139	96	0.17	0.0	2.011	0.125	0	0	0	166
PD.3372	PL.23879	ABC	50L	7.37Y	122.9	0.00	2.13	22.92	46	487	139	96	0.00	0.0	2.011	0.125	0	0	0	166
PL.23880	PD.3372	ABC	#1/0 ACSR	7.37Y	122.8	0.05	2.19	22.92	10	487	139	96	0.18	0.0	2.139	0.128	0	0	1	166
PL.23538	PL.23880	ABC	#1/0 ACSR	7.37Y	122.8	0.05	2.24	22.92	10	487	139	96	0.16	0.0	2.257	0.118	7	2	2	165
PL.23539	PL.23538	ABC	#1/0 ACSR	7.36Y	122.7	0.04	2.27	22.60	10	480	137	96	0.12	0.0	2.348	0.092	2	1	1	163
PL.23719	PL.23539	C	#1/0 ACSR	7.36Y	122.7	0.00	2.27	2.35	1	17	5	96	0.00	0.0	2.353	0.005	0	0	0	2
PD.3289	PL.23719	C	20T	7.36Y	122.7	0.00	2.27	2.35	0	17	5	96	0.00	0.0	2.353	0.005	0	0	0	2
PL.23720	PD.3289	C	#1/0 ACSR	7.36Y	122.7	0.00	2.27	2.35	1	17	5	96	0.00	0.0	2.385	0.032	17	5	2	2
PL.23449	PL.23539	ABC	#1/0 ACSR	7.36Y	122.7	0.07	2.35	21.71	9	461	131	96	0.23	0.0	2.531	0.183	0	0	1	160
PL.23448	PL.23449	ABC	#1/0 ACSR	7.36Y	122.6	0.07	2.41	21.33	9	453	129	96	0.21	0.0	2.707	0.176	0	0	0	158
PL.22876	PL.23448	ABC	#1/0 ACSR	7.36Y	122.6	0.00	2.42	21.33	9	453	129	96	0.01	0.0	2.715	0.008	0	0	0	158
PL.23723	PL.22876	A	6 A (CWC)	7.36Y	122.6	0.00	2.42	0.70	0	5	1	98	0.00	0.0	2.720	0.005	0	0	0	2
PD.3291	PL.23723	A	20T	7.36Y	122.6	0.00	2.42	0.70	0	5	1	98	0.00	0.0	2.720	0.005	0	0	0	2
PL.23724	PD.3291	A	6 A (CWC)	7.35Y	122.6	0.00	2.42	0.70	0	5	1	98	0.00	0.0	2.798	0.078	1	0	1	2
PL.22877	PL.23724	A	#2 ACSR	7.35Y	122.6	0.00	2.42	0.63	0	4	1	97	0.00	0.0	2.845	0.047	4	1	1	1
PL.23146	PL.22876	ABC	#1/0 ACSR	7.35Y	122.5	0.06	2.47	21.10	9	448	127	96	0.17	0.0	2.860	0.145	0	0	0	156
PL.23540	PL.23146	ABC	#1/0 ACSR	7.35Y	122.5	0.01	2.48	20.77	9	441	125	96	0.02	0.0	2.880	0.019	0	0	0	154
PL.23541	PL.23540	ABC	#1/0 ACSR	7.35Y	122.5	0.03	2.51	20.77	9	441	125	96	0.08	0.0	2.951	0.071	9	2	3	154
PL.23543	PL.23541	ABC	#1/0 ACSR	7.35Y	122.4	0.05	2.56	20.36	9	432	122	96	0.15	0.0	3.088	0.137	1	0	1	151
PL.23544	PL.23543	ABC	#1/0 ACSR	7.35Y	122.4	0.02	2.58	20.33	9	431	122	96	0.07	0.0	3.154	0.066	0	0	1	150
PL.23837	PL.23544	A	#4 ACSR	7.35Y	122.4	0.00	2.58	1.46	1	10	3	96	0.00	0.0	3.159	0.005	0	0	0	1
PD.3350	PL.23837	A	20T	7.35Y	122.4	0.00	2.58	1.46	0	10	3	96	0.00	0.0	3.159	0.005	0	0	0	1
PL.23838	PD.3350	A	#4 ACSR	7.35Y	122.4	0.00	2.58	1.46	1	10	3	96	0.00	0.0	3.199	0.040	10	3	1	1
PL.23727	PL.23544	C	6 A (CWC)	7.35Y	122.4	0.00	2.58	0.44	0	3	1	95	0.00	0.0	3.159	0.005	0	0	0	2
PD.3293	PL.23727	C	20T	7.35Y	122.4	0.00	2.58	0.44	0	3	1	95	0.00	0.0	3.159	0.005	0	0	0	2
PL.23728	PD.3293	C	6 A (CWC)	7.35Y	122.4	0.00	2.58	0.44	0	3	1	95	0.00	0.0	3.298	0.140	0	0	0	2
PL.22879	PL.23728	C	#4 ACSR	7.34Y	122.4	0.00	2.58	0.43	0	3	1	95	0.00	0.0	3.400	0.102	3	1	1	1
PL.22880	PL.23728	C	#4 ACSR	7.35Y	122.4	0.00	2.58	0.00	0	0	0	100	0.00	0.0	3.364	0.066	0	0	1	1

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Millers Creek

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.23545	PL.23544	ABC	#1/0 ACSR	7.34Y	122.4	0.03	2.61	19.67	9	417	118	96	0.09	0.0	3.242	0.088	1	0	1	145
PL.23546	PL.23545	ABC	#1/0 ACSR	7.34Y	122.4	0.04	2.65	19.60	9	415	118	96	0.10	0.0	3.345	0.102	17	5	3	144
PL.23731	PL.23546	A	#4 ACSR	7.34Y	122.4	0.00	2.65	0.75	1	5	1	98	0.00	0.0	3.349	0.005	0	0	0	1
PD.3295	PL.23731	A	20T	7.34Y	122.4	0.00	2.65	0.75	0	5	1	98	0.00	0.0	3.349	0.005	0	0	0	1
PL.23732	PD.3295	A	#4 ACSR	7.34Y	122.4	0.00	2.65	0.75	1	5	1	98	0.00	0.0	3.432	0.083	5	1	1	1
PL.23446	PL.23546	ABC	#1/0 ACSR	7.34Y	122.3	0.04	2.69	18.55	8	393	111	96	0.11	0.0	3.470	0.125	5	1	1	140
PL.23547	PL.23446	ABC	#1/0 ACSR	7.34Y	122.3	0.01	2.70	18.12	8	384	109	96	0.03	0.0	3.500	0.030	3	1	1	138
PL.23548	PL.23547	ABC	#1/0 ACSR	7.34Y	122.3	0.03	2.73	17.98	8	381	108	96	0.08	0.0	3.593	0.093	1	0	1	137
PL.23733	PL.23548	C	#4 ACSR	7.34Y	122.3	0.00	2.73	0.95	1	7	2	96	0.00	0.0	3.598	0.005	0	0	0	2
PD.3296	PL.23733	C	20T	7.34Y	122.3	0.00	2.73	0.95	0	7	2	96	0.00	0.0	3.598	0.005	0	0	0	2
PL.23734	PD.3296	C	#4 ACSR	7.34Y	122.3	0.00	2.73	0.95	1	7	2	96	0.00	0.0	3.679	0.081	7	2	2	2
PL.23439	PL.23548	ABC	#1/0 ACSR	7.33Y	122.2	0.03	2.76	17.63	8	373	106	96	0.08	0.0	3.695	0.101	2	1	1	134
PL.23729	PL.23439	A	#4 ACSR	7.33Y	122.2	0.00	2.76	4.16	3	29	8	96	0.00	0.0	3.699	0.005	0	0	0	10
PD.3294	PL.23729	A	20T	7.33Y	122.2	0.00	2.76	4.16	0	29	8	96	0.00	0.0	3.699	0.005	0	0	0	10
PL.23730	PD.3294	A	#4 ACSR	7.33Y	122.2	0.02	2.79	4.16	3	29	8	96	0.01	0.0	3.827	0.128	0	0	0	10
PL.23215	PL.23730	A	#4 ACSR	7.33Y	122.2	0.02	2.80	4.16	3	29	8	96	0.00	0.0	3.921	0.095	0	0	0	10
PL.22882	PL.23215	A	#4 ACSR	7.33Y	122.2	0.02	2.83	4.16	3	29	8	96	0.01	0.0	4.043	0.121	0	0	0	10
PL.22883	PL.22882	A	#4 ACSR	7.33Y	122.2	0.02	2.84	4.16	3	29	8	96	0.00	0.0	4.144	0.102	0	0	0	10
PL.23216	PL.22883	A	#4 ACSR	7.33Y	122.1	0.03	2.87	4.16	3	29	8	96	0.01	0.0	4.303	0.159	0	0	0	10
PL.23542	PL.23216	A	#4 ACSR	7.33Y	122.1	0.02	2.90	4.16	3	29	8	96	0.00	0.0	4.422	0.118	0	0	1	10
PL.23554	PL.23542	A	#4 ACSR	7.32Y	122.1	0.03	2.92	4.15	3	29	8	96	0.01	0.0	4.582	0.160	4	1	1	9
PL.23555	PL.23554	A	#4 ACSR	7.32Y	122.1	0.01	2.94	3.61	3	25	7	96	0.00	0.0	4.669	0.087	0	0	0	8
PL.23217	PL.23555	A	#4 ACSR	7.32Y	122.0	0.02	2.96	3.61	3	25	7	96	0.00	0.0	4.789	0.120	0	0	0	8
PL.23147	PL.23217	A	#4 ACSR	7.32Y	122.0	0.01	2.97	2.97	2	21	6	96	0.00	0.0	4.887	0.098	0	0	0	7
PL.23218	PL.23147	A	#4 ACSR	7.32Y	122.0	0.02	2.99	2.97	2	21	6	96	0.00	0.0	5.006	0.119	0	0	0	7
PL.23148	PL.23218	A	#4 ACSR	7.32Y	122.0	0.00	2.99	1.30	1	9	3	95	0.00	0.0	5.034	0.029	0	0	0	4
PL.22889	PL.23148	A	#4 ACSR	7.32Y	122.0	0.00	2.99	1.00	1	7	2	96	0.00	0.0	5.091	0.057	0	0	0	3
PL.22891	PL.22889	A	#2 ACSR	7.32Y	122.0	0.00	2.99	1.00	1	7	2	96	0.00	0.0	5.173	0.082	0	0	0	3
PL.23149	PL.22891	A	#2 ACSR	7.32Y	122.0	0.00	3.00	0.64	0	5	1	98	0.00	0.0	5.355	0.182	0	0	0	2
PL.22894	PL.23149	A	#2 ACSR	7.32Y	122.0	0.00	3.00	0.06	0	0	0	100	0.00	0.0	5.524	0.170	0	0	1	1
PL.22893	PL.23149	A	#2 ACSR	7.32Y	122.0	0.00	3.00	0.58	0	4	1	97	0.00	0.0	5.395	0.040	0	0	0	1

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Millers Creek

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.22895	PL.22893	A	#1/0 ACSR	7.32Y	122.0	0.00	3.00	0.58	0	4	1	97	0.00	0.0	5.427	0.032	4	1	1	1
PL.22892	PL.22891	A	#2 ACSR	7.32Y	122.0	0.00	2.99	0.35	0	2	1	89	0.00	0.0	5.276	0.103	2	1	1	1
PL.22890	PL.23148	A	#4 ACSR	7.32Y	122.0	0.00	2.99	0.30	0	2	1	89	0.00	0.0	5.110	0.075	0	0	0	1
PL.23222	PL.22890	A	#4 ACSR	7.32Y	122.0	0.00	2.99	0.30	0	2	1	89	0.00	0.0	5.253	0.144	2	1	1	1
PL.22885	PL.23218	A	#4 ACSR	7.32Y	122.0	0.00	2.99	1.66	1	12	3	97	0.00	0.0	5.026	0.020	0	0	0	3
PL.23741	PL.22885	A	#1/0 ACSR	7.32Y	122.0	0.00	2.99	1.17	1	8	2	97	0.00	0.0	5.069	0.043	0	0	0	2
PD.3300	PL.23741	A	12T	7.32Y	122.0	0.00	2.99	1.17	0	8	2	97	0.00	0.0	5.069	0.043	0	0	0	2
PL.23742	PD.3300	A	#1/0 ACSR	7.32Y	122.0	0.00	2.99	1.17	1	8	2	97	0.00	0.0	5.176	0.107	0	0	0	2
PL.22888	PL.23742	A	#1/0 ACSR	7.32Y	122.0	0.00	2.99	1.17	1	8	2	97	0.00	0.0	5.299	0.123	0	0	0	2
PL.23219	PL.22888	A	#1/0 ACSR	7.32Y	122.0	0.00	3.00	1.17	1	8	2	97	0.00	0.0	5.389	0.090	0	0	0	2
PL.23220	PL.23219	A	#1/0 ACSR	7.32Y	122.0	0.00	3.00	1.17	1	8	2	97	0.00	0.0	5.475	0.086	0	0	0	2
PL.23556	PL.23220	A	#1/0 ACSR	7.32Y	122.0	0.00	3.00	1.17	1	8	2	97	0.00	0.0	5.604	0.129	0	0	1	2
PL.23557	PL.23556	A	#1/0 ACSR	7.32Y	122.0	0.00	3.01	1.17	1	8	2	97	0.00	0.0	5.741	0.138	0	0	0	1
PL.23221	PL.23557	A	#1/0 ACSR	7.32Y	122.0	0.00	3.01	1.17	1	8	2	97	0.00	0.0	5.856	0.114	8	2	1	1
PL.22886	PL.22885	A	#2 ACSR	7.32Y	122.0	0.00	2.99	0.49	0	3	1	95	0.00	0.0	5.095	0.069	3	1	1	1
PL.22887	PL.22885	A	#2 ACSR	7.32Y	122.0	0.00	2.99	0.00	0	0	0	100	0.00	0.0	5.076	0.050	0	0	0	0
PL.22884	PL.23217	A	#1/0 ACSR	7.32Y	122.0	0.00	2.96	0.64	0	5	1	98	0.00	0.0	4.808	0.019	5	1	1	1
PL.23549	PL.23439	ABC	#1/0 ACSR	7.33Y	122.2	0.03	2.79	16.15	7	342	97	96	0.06	0.0	3.782	0.088	17	5	2	123
PL.23550	PL.23549	ABC	#1/0 ACSR	7.33Y	122.2	0.02	2.81	15.33	7	324	92	96	0.04	0.0	3.852	0.069	14	4	2	121
PL.23551	PL.23550	ABC	#1/0 ACSR	7.33Y	122.2	0.02	2.83	14.69	6	311	88	96	0.04	0.0	3.927	0.075	0	0	0	119
PL.23737	PL.23551	C	#2 ACSR	7.33Y	122.2	0.00	2.83	0.99	1	7	2	96	0.00	0.0	3.932	0.004	0	0	0	1
PD.3298	PL.23737	C	20T	7.33Y	122.2	0.00	2.83	0.99	0	7	2	96	0.00	0.0	3.932	0.004	0	0	0	1
PL.23738	PD.3298	C	#2 ACSR	7.33Y	122.2	0.00	2.83	0.99	1	7	2	96	0.00	0.0	3.955	0.023	7	2	1	1
PL.23432	PL.23551	ABC	#1/0 ACSR	7.33Y	122.2	0.01	2.83	14.36	6	304	86	96	0.02	0.0	3.955	0.028	4	1	1	118
PL.23433	PL.23432	ABC	#1/0 ACSR	7.33Y	122.2	0.01	2.84	7.92	3	167	48	96	0.01	0.0	4.020	0.064	3	1	1	62
PL.23871	PL.23433	A	#1/0 ACSR	7.33Y	122.2	0.00	2.84	23.29	10	164	47	96	0.00	0.0	4.022	0.003	0	0	0	61
PD.3368	PL.23871	A	35L	7.33Y	122.2	0.00	2.84	23.29	67	164	47	96	0.00	0.0	4.022	0.003	0	0	0	61
PL.23872	PD.3368	A	#1/0 ACSR	7.33Y	122.1	0.03	2.88	23.29	10	164	47	96	0.04	0.0	4.084	0.061	9	3	1	61
PL.23552	PL.23872	A	#1/0 ACSR	7.33Y	122.1	0.03	2.91	22.01	10	155	44	96	0.03	0.0	4.148	0.065	9	3	1	60
PL.23553	PL.23552	A	#1/0 ACSR	7.32Y	122.1	0.02	2.93	20.69	9	146	41	96	0.01	0.0	4.179	0.030	0	0	0	59
PL.22909	PL.23553	A	6 A (CWC)	7.32Y	122.1	0.00	2.93	1.01	1	7	2	96	0.00	0.0	4.220	0.041	7	2	2	2

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Millers Creek

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.23558	PL.23553	A	#1/0 ACSR	7.32Y	122.1	0.01	2.94	19.68	9	139	39	96	0.01	0.0	4.201	0.022	5	1	1	57
PL.23559	PL.23558	A	#1/0 ACSR	7.32Y	122.0	0.05	2.99	18.97	8	134	38	96	0.04	0.0	4.311	0.110	4	1	1	56
PL.23434	PL.23559	A	#1/0 ACSR	7.32Y	122.0	0.04	3.03	15.88	7	112	32	96	0.03	0.0	4.425	0.115	3	1	1	53
PL.22911	PL.23434	A	#1/0 ACSR	7.32Y	121.9	0.05	3.08	15.46	7	109	31	96	0.04	0.0	4.561	0.135	0	0	0	51
PL.23560	PL.22911	A	#1/0 ACSR	7.31Y	121.9	0.02	3.10	15.17	7	107	30	96	0.02	0.0	4.622	0.061	2	1	1	50
PL.23561	PL.23560	A	#1/0 ACSR	7.31Y	121.9	0.02	3.12	14.89	6	105	30	96	0.01	0.0	4.672	0.050	0	0	0	49
PL.23154	PL.23561	A	6 A (CWC)	7.31Y	121.9	0.00	3.12	0.70	1	5	1	98	0.00	0.0	4.741	0.069	0	0	1	2
PL.22913	PL.23154	A	6 A (CWC)	7.31Y	121.9	0.01	3.13	0.70	0	5	1	98	0.00	0.0	4.915	0.174	0	0	0	1
PL.23238	PL.22913	A	6 A (CWC)	7.31Y	121.9	0.00	3.13	0.70	0	5	1	98	0.00	0.0	5.023	0.108	0	0	0	1
PL.22918	PL.23238	A	6 A (CWC)	7.31Y	121.9	0.00	3.13	0.70	0	5	1	98	0.00	0.0	5.121	0.098	0	0	0	1
PL.23239	PL.22918	A	6 A (CWC)	7.31Y	121.9	0.00	3.14	0.70	0	5	1	98	0.00	0.0	5.264	0.143	0	0	0	1
PL.22917	PL.23239	A	#4 ACSR	7.31Y	121.9	0.00	3.14	0.70	1	5	1	98	0.00	0.0	5.452	0.187	5	1	1	1
PL.22914	PL.23561	A	#1/0 ACSR	7.31Y	121.8	0.04	3.16	14.19	6	100	28	96	0.03	0.0	4.793	0.121	0	0	0	47
PL.23240	PL.22914	A	#1/0 ACSR	7.31Y	121.8	0.05	3.22	14.19	6	100	28	96	0.04	0.0	4.949	0.156	0	0	0	47
PL.23155	PL.23240	A	#1/0 ACSR	7.31Y	121.8	0.01	3.23	13.50	6	95	27	96	0.01	0.0	4.983	0.033	0	0	0	46
PL.22916	PL.23155	A	#1/0 ACSR	7.30Y	121.7	0.03	3.26	13.50	6	95	27	96	0.02	0.0	5.078	0.096	0	0	0	46
PL.23241	PL.22916	A	#1/0 ACSR	7.30Y	121.7	0.04	3.30	13.50	6	95	27	96	0.03	0.0	5.213	0.135	0	0	0	46
PL.22919	PL.23241	A	#1/0 ACSR	7.30Y	121.7	0.01	3.31	13.50	6	95	27	96	0.01	0.0	5.253	0.040	0	0	0	46
PL.23242	PL.22919	A	#1/0 ACSR	7.30Y	121.6	0.07	3.39	13.50	6	95	27	96	0.05	0.0	5.476	0.223	0	0	0	46
PL.22922	PL.23242	A	#1/0 ACSR	7.29Y	121.6	0.03	3.42	13.23	6	93	26	96	0.02	0.0	5.572	0.096	0	0	0	45
PL.23243	PL.22922	A	#1/0 ACSR	7.29Y	121.6	0.03	3.45	13.23	6	93	26	96	0.02	0.0	5.666	0.094	2	1	3	45
PL.23444	PL.23243	A	6 A (CWC)	7.29Y	121.5	0.00	3.45	0.85	1	6	2	95	0.00	0.0	5.819	0.153	2	1	4	8
PL.23564	PL.23444	A	6 A (CWC)	7.29Y	121.5	0.00	3.45	0.09	0	1	0	100	0.00	0.0	5.900	0.081	0	0	0	2
PL.23565	PL.23564	A	6 A (CWC)	7.29Y	121.5	0.00	3.45	0.09	0	1	0	100	0.00	0.0	5.933	0.033	0	0	0	2
PL.22920	PL.23565	A	#4 ACSR	7.29Y	121.5	0.00	3.45	0.00	0	0	0	100	0.00	0.0	6.017	0.084	0	0	1	1
PL.23156	PL.23565	A	6 A (CWC)	7.29Y	121.5	0.00	3.45	0.09	0	1	0	100	0.00	0.0	6.070	0.137	0	0	0	1
PL.23244	PL.23156	A	6 A (CWC)	7.29Y	121.5	0.00	3.45	0.09	0	1	0	100	0.00	0.0	6.143	0.073	1	0	1	1
PL.23570	PL.23244	A	#4 ACSR	7.29Y	121.5	0.00	3.45	0.00	0	0	0	100	0.00	0.0	6.192	0.049	0	0	0	0
PL.23571	PL.23570	A	#4 ACSR	7.29Y	121.5	0.00	3.45	0.00	0	0	0	100	0.00	0.0	6.332	0.140	0	0	0	0
PL.23245	PL.23571	A	#4 ACSR	7.29Y	121.5	0.00	3.45	0.00	0	0	0	100	0.00	0.0	6.459	0.127	0	0	0	0
PL.23445	PL.23444	A	6 A (CWC)	7.29Y	121.5	0.00	3.45	0.44	0	3	1	95	0.00	0.0	5.897	0.078	3	1	2	2

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Millers Creek

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru

PL.22921	PL.23243	A	#1/0 ACSR	7.29Y	121.5	0.05	3.50	12.11	5	85	24	96	0.03	0.0	5.850	0.184	0	0	0	34
PL.23246	PL.22921	A	#1/0 ACSR	7.29Y	121.5	0.03	3.53	12.11	5	85	24	96	0.02	0.0	5.949	0.099	0	0	0	34
PL.23247	PL.23246	A	#1/0 ACSR	7.29Y	121.4	0.03	3.56	12.11	5	85	24	96	0.02	0.0	6.047	0.098	0	0	0	34
PL.23157	PL.23247	A	#1/0 ACSR	7.29Y	121.4	0.02	3.58	12.11	5	85	24	96	0.01	0.0	6.126	0.079	0	0	0	32
PL.22925	PL.23157	A	#4 ACSR	7.28Y	121.4	0.00	3.58	0.57	0	4	1	97	0.00	0.0	6.222	0.097	4	1	2	2
PL.22926	PL.23157	A	#1/0 ACSR	7.28Y	121.4	0.06	3.65	11.54	5	81	23	96	0.03	0.0	6.358	0.232	0	0	0	30
PL.23745	PL.22926	A	#4 ACSR	7.28Y	121.4	0.00	3.65	1.21	1	8	2	97	0.00	0.0	6.363	0.005	0	0	0	3
PD.3302	PL.23745	A	15T	7.28Y	121.4	0.00	3.65	1.21	0	8	2	97	0.00	0.0	6.363	0.005	0	0	0	3
PL.23746	PD.3302	A	#4 ACSR	7.28Y	121.3	0.00	3.65	1.21	1	8	2	97	0.00	0.0	6.481	0.118	5	1	1	3
PL.23566	PL.23746	A	#4 ACSR	7.28Y	121.3	0.00	3.65	0.45	0	3	1	95	0.00	0.0	6.572	0.091	1	0	1	2
PL.23743	PL.23566	A	#4 ACSR	7.28Y	121.3	0.00	3.65	0.36	0	3	1	95	0.00	0.0	6.576	0.005	0	0	0	1
PD.3301	PL.23743	A	10T	7.28Y	121.3	0.00	3.65	0.36	0	3	1	95	0.00	0.0	6.576	0.005	0	0	0	1
PL.23744	PD.3301	A	#4 ACSR	7.28Y	121.3	0.00	3.66	0.36	0	3	1	95	0.00	0.0	6.696	0.120	0	0	0	1
PL.23248	PL.23744	A	#4 ACSR	7.28Y	121.3	0.00	3.66	0.36	0	3	1	95	0.00	0.0	6.841	0.145	0	0	0	1
PL.23249	PL.23248	A	#4 ACSR	7.28Y	121.3	0.00	3.66	0.36	0	3	1	95	0.00	0.0	6.980	0.139	0	0	0	1
PL.22928	PL.23249	A	#1/0 ACSR	7.28Y	121.3	0.00	3.66	0.36	0	3	1	95	0.00	0.0	7.051	0.071	3	1	1	1
PL.22927	PL.22926	A	#1/0 ACSR	7.28Y	121.3	0.02	3.67	10.34	4	72	20	96	0.01	0.0	6.460	0.102	5	2	1	27
PL.22929	PL.22927	A	#1/0 ACSR	7.28Y	121.3	0.02	3.69	8.41	4	59	17	96	0.01	0.0	6.558	0.099	0	0	0	24
PL.23250	PL.22929	A	#1/0 ACSR	7.28Y	121.3	0.03	3.72	8.41	4	59	17	96	0.01	0.0	6.682	0.124	0	0	0	24
PL.22931	PL.23250	A	#1/0 ACSR	7.28Y	121.3	0.00	3.72	8.41	4	59	17	96	0.00	0.0	6.693	0.011	0	0	0	24
PL.22932	PL.22931	A	#1/0 ACSR	7.28Y	121.3	0.00	3.72	0.54	0	4	1	97	0.00	0.0	6.729	0.036	4	1	2	2
PL.23158	PL.22931	A	#1/0 ACSR	7.28Y	121.3	0.03	3.75	7.87	3	55	16	96	0.01	0.0	6.853	0.160	0	0	1	22
PL.22933	PL.23158	A	#1/0 ACSR	7.27Y	121.2	0.03	3.77	7.56	3	53	15	96	0.01	0.0	6.990	0.137	0	0	0	19
PL.22934	PL.22933	A	#1/0 ACSR	7.27Y	121.2	0.01	3.78	7.56	3	53	15	96	0.00	0.0	7.052	0.061	8	2	3	19
PL.22935	PL.22934	A	#4 ACSR	7.27Y	121.2	0.00	3.78	0.00	0	0	0	100	0.00	0.0	7.063	0.011	0	0	0	0
PL.22936	PL.22934	A	#1/0 ACSR	7.27Y	121.2	0.01	3.80	6.46	3	45	13	96	0.00	0.0	7.135	0.083	0	0	0	16
PL.23572	PL.22936	A	#1/0 ACSR	7.27Y	121.2	0.02	3.82	6.46	3	45	13	96	0.01	0.0	7.284	0.149	0	0	0	16
PL.23573	PL.23572	A	#1/0 ACSR	7.27Y	121.2	0.01	3.83	6.46	3	45	13	96	0.00	0.0	7.374	0.091	2	1	1	16
PL.23574	PL.23573	A	6 A (CWC)	7.27Y	121.2	0.00	3.84	0.52	0	4	1	97	0.00	0.0	7.508	0.134	4	1	1	1
PL.23575	PL.23574	A	6 A (CWC)	7.27Y	121.2	0.00	3.84	0.00	0	0	0	100	0.00	0.0	7.595	0.086	0	0	0	0
PL.23875	PL.23573	A	#1/0 ACSR	7.27Y	121.2	0.01	3.84	5.64	2	39	11	96	0.00	0.0	7.413	0.038	0	0	0	14

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Millers Creek

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PD.3370	PL.23875	A	20T	7.27Y	121.2	0.00	3.84	5.64	0	39	11	96	0.00	0.0	7.413	0.038	0	0	0	14
PL.23876	PD.3370	A	6 A (CWC)	7.27Y	121.1	0.05	3.89	5.64	4	39	11	96	0.01	0.0	7.599	0.186	0	0	0	14
PL.23576	PL.23876	A	6 A (CWC)	7.26Y	121.1	0.04	3.92	5.64	4	39	11	96	0.01	0.0	7.739	0.140	0	0	0	14
PL.23577	PL.23576	A	6 A (CWC)	7.26Y	121.1	0.02	3.94	5.64	4	39	11	96	0.01	0.0	7.804	0.065	0	0	0	14
PL.22937	PL.23577	A	#4 ACSR	7.26Y	121.1	0.00	3.95	1.64	1	11	3	96	0.00	0.0	7.865	0.061	0	0	0	2
PL.23159	PL.22937	A	#4 ACSR	7.26Y	121.1	0.00	3.95	0.46	0	3	1	95	0.00	0.0	7.906	0.041	3	1	1	1
PL.22938	PL.22937	A	#1/0 ACSR	7.26Y	121.1	0.00	3.95	1.18	1	8	2	97	0.00	0.0	7.886	0.021	8	2	1	1
PL.23429	PL.23577	A	6 A (CWC)	7.26Y	121.0	0.01	3.95	4.00	3	28	8	96	0.00	0.0	7.856	0.052	0	0	1	12
PL.22939	PL.23429	A	#4 ACSR	7.26Y	121.0	0.00	3.95	0.00	0	0	0	100	0.00	0.0	7.898	0.042	0	0	0	0
PL.23430	PL.23429	A	6 A (CWC)	7.26Y	121.0	0.03	3.98	4.00	3	28	8	96	0.01	0.0	8.002	0.146	0	0	0	11
PL.22940	PL.23430	A	6 A (CWC)	7.26Y	121.0	0.02	4.00	4.00	3	28	8	96	0.01	0.0	8.134	0.132	0	0	0	11
PL.23251	PL.22940	A	6 A (CWC)	7.26Y	121.0	0.01	4.01	4.00	3	28	8	96	0.00	0.0	8.199	0.066	0	0	0	11
PL.23621	PL.23251	A	#4 ACSR	7.26Y	121.0	0.01	4.02	4.00	3	28	8	96	0.00	0.0	8.229	0.030	0	0	0	11
PL.23622	PL.23621	A	#4 ACSR	7.26Y	121.0	0.00	4.02	4.00	3	28	8	96	0.00	0.0	8.256	0.027	0	0	0	11
PL.22941	PL.23622	A	#4 ACSR	7.26Y	121.0	0.01	4.03	2.27	2	16	4	97	0.00	0.0	8.354	0.098	0	0	0	9
PL.22942	PL.22941	A	#4 ACSR	7.26Y	121.0	0.01	4.04	2.27	2	16	4	97	0.00	0.0	8.443	0.089	0	0	0	9
PL.22944	PL.22942	A	6 A (CWC)	7.26Y	120.9	0.01	4.05	2.27	2	16	4	97	0.00	0.0	8.549	0.106	0	0	0	9
PL.23619	PL.22944	A	6 A (CWC)	7.26Y	120.9	0.02	4.07	2.27	2	16	4	97	0.00	0.0	8.719	0.170	0	0	0	9
PL.23620	PL.23619	A	6 A (CWC)	7.26Y	120.9	0.01	4.08	2.27	2	16	4	97	0.00	0.0	8.820	0.101	0	0	0	9
PL.23807	PL.23620	A	#4 ACSR	7.25Y	120.9	0.02	4.10	2.27	2	16	4	97	0.00	0.0	8.997	0.177	0	0	0	9
PD.3334	PL.23807	A	12T	7.25Y	120.9	0.00	4.10	2.27	0	16	4	97	0.00	0.0	8.997	0.177	0	0	0	9
PL.23808	PD.3334	A	#4 ACSR	7.25Y	120.9	0.01	4.11	2.27	2	16	4	97	0.00	0.0	9.121	0.124	0	0	0	9
PL.23253	PL.23808	A	#4 ACSR	7.25Y	120.9	0.01	4.12	2.27	2	16	4	97	0.00	0.0	9.207	0.086	0	0	0	9
PL.22948	PL.23253	A	#4 ACSR	7.25Y	120.9	0.02	4.14	2.27	2	16	4	97	0.00	0.0	9.417	0.210	0	0	0	9
PL.23128	PL.22948	A	#4 ACSR	7.25Y	120.9	0.01	4.15	2.27	2	16	4	97	0.00	0.0	9.488	0.071	0	0	0	9
PL.23138	PL.23128	A	#4 ACSR	7.25Y	120.8	0.01	4.16	2.27	2	16	4	97	0.00	0.0	9.625	0.136	0	0	0	9
PL.23633	PL.23138	A	#4 ACSR	7.25Y	120.8	0.01	4.18	2.27	2	16	4	97	0.00	0.0	9.771	0.147	0	0	0	9
PL.23634	PL.23633	A	#4 ACSR	7.25Y	120.8	0.01	4.19	2.27	2	16	4	97	0.00	0.0	9.880	0.109	0	0	0	9
PL.23254	PL.23634	A	#4 ACSR	7.25Y	120.8	0.01	4.20	2.27	2	16	4	97	0.00	0.0	10.026	0.146	0	0	0	9
PL.23417	PL.23254	A	#4 ACSR	7.25Y	120.8	0.00	4.20	0.10	0	1	0	100	0.00	0.0	10.155	0.130	0	0	0	5
PL.23132	PL.23417	A	#4 ACSR	7.25Y	120.8	0.00	4.20	0.10	0	1	0	100	0.00	0.0	10.260	0.104	0	0	0	5

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Millers Creek

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru

PL.23827	PL.23132	A	#4 ACSR	7.25Y	120.8	0.00	4.21	0.10	0	1	0	100	0.00	0.0	10.373	0.113	0	0	0	5
PD.3345	PL.23827	A	8T	7.25Y	120.8	0.00	4.21	0.10	0	1	0	100	0.00	0.0	10.373	0.113	0	0	0	5
PL.23828	PD.3345	A	#4 ACSR	7.25Y	120.8	0.00	4.21	0.10	0	1	0	100	0.00	0.0	10.532	0.159	0	0	0	5
PL.23420	PL.23828	A	#4 ACSR	7.25Y	120.8	0.00	4.21	0.10	0	1	0	100	0.00	0.0	10.721	0.189	0	0	0	5
PL.23257	PL.23420	A	#4 ACSR	7.25Y	120.8	0.00	4.21	0.10	0	1	0	100	0.00	0.0	10.882	0.161	0	0	1	5
PL.23133	PL.23257	A	#1/0 ACSR	7.25Y	120.8	0.00	4.21	0.09	0	1	0	100	0.00	0.0	11.010	0.128	0	0	0	4
PL.23258	PL.23133	A	#1/0 ACSR	7.25Y	120.8	0.00	4.21	0.09	0	1	0	100	0.00	0.0	11.089	0.079	0	0	0	4
PL.23161	PL.23258	A	#1/0 ACSR	7.25Y	120.8	0.00	4.21	0.02	0	0	0	100	0.00	0.0	11.131	0.042	0	0	1	1
PL.23631	PL.23258	A	#1/0 ACSR	7.25Y	120.8	0.00	4.21	0.06	0	0	0	100	0.00	0.0	11.118	0.029	0	0	2	3
PL.23632	PL.23631	A	#1/0 ACSR	7.25Y	120.8	0.00	4.21	0.00	0	0	0	100	0.00	0.0	11.286	0.169	0	0	1	1
PL.23418	PL.23417	A	#4 ACSR	7.25Y	120.8	0.00	4.20	0.00	0	0	0	100	0.00	0.0	10.205	0.050	0	0	0	0
PL.23129	PL.23254	A	#4 ACSR	7.25Y	120.8	0.01	4.21	2.17	2	15	4	97	0.00	0.0	10.123	0.097	0	0	0	4
PL.23130	PL.23129	A	#4 ACSR	7.25Y	120.8	0.01	4.22	2.17	2	15	4	97	0.00	0.0	10.190	0.067	0	0	0	4
PL.23131	PL.23130	A	#4 ACSR	7.25Y	120.8	0.00	4.22	0.64	0	4	1	97	0.00	0.0	10.246	0.056	4	1	1	1
PL.23411	PL.23130	A	#4 ACSR	7.25Y	120.8	0.01	4.23	1.53	1	11	3	96	0.00	0.0	10.372	0.182	0	0	0	3
PL.23635	PL.23411	A	#1/0 ACSR	7.25Y	120.8	0.00	4.23	0.65	0	5	1	98	0.00	0.0	10.435	0.063	1	0	1	2
PL.23636	PL.23635	A	#1/0 ACSR	7.25Y	120.8	0.00	4.23	0.50	0	3	1	95	0.00	0.0	10.566	0.131	0	0	0	1
PL.23255	PL.23636	A	#1/0 ACSR	7.25Y	120.8	0.00	4.24	0.50	0	3	1	95	0.00	0.0	10.646	0.080	3	1	1	1
PL.23412	PL.23411	A	#4 ACSR	7.25Y	120.8	0.00	4.23	0.89	1	6	2	95	0.00	0.0	10.402	0.030	6	2	1	1
PL.22943	PL.22941	A	#4 ACSR	7.26Y	121.0	0.00	4.03	0.00	0	0	0	100	0.00	0.0	8.425	0.071	0	0	0	0
PL.23160	PL.23622	A	#4 ACSR	7.26Y	121.0	0.01	4.04	1.73	1	12	3	97	0.00	0.0	8.408	0.152	0	0	0	2
PL.23252	PL.23160	A	#4 ACSR	7.26Y	121.0	0.01	4.04	1.73	1	12	3	97	0.00	0.0	8.532	0.124	0	0	0	2
PL.23624	PL.23252	A	#4 ACSR	7.26Y	120.9	0.01	4.05	1.73	1	12	3	97	0.00	0.0	8.616	0.085	0	0	0	2
PL.23623	PL.23624	A	#4 ACSR	7.26Y	120.9	0.01	4.06	1.73	1	12	3	97	0.00	0.0	8.712	0.096	0	0	0	2
PL.22945	PL.23623	A	#1/0 ACSR	7.26Y	120.9	0.00	4.06	1.60	1	11	3	96	0.00	0.0	8.742	0.030	11	3	1	1
PL.22947	PL.23623	A	#4 ACSR	7.26Y	120.9	0.00	4.06	0.12	0	1	0	100	0.00	0.0	8.791	0.079	1	0	1	1
PL.22946	PL.23623	A	#1/0 ACSR	7.26Y	120.9	0.00	4.06	0.00	0	0	0	100	0.00	0.0	8.826	0.114	0	0	0	0
PL.23568	PL.23158	A	#4 ACSR	7.27Y	121.2	0.00	3.75	0.31	0	2	1	89	0.00	0.0	6.898	0.045	0	0	0	2
PL.23569	PL.23568	A	#4 ACSR	7.27Y	121.2	0.00	3.75	0.31	0	2	1	89	0.00	0.0	6.984	0.086	0	0	1	2
PL.23567	PL.23569	A	#4 ACSR	7.27Y	121.2	0.00	3.75	0.30	0	2	1	89	0.00	0.0	7.118	0.134	2	1	1	1
PL.22930	PL.22927	A	#4 ACSR	7.28Y	121.3	0.00	3.68	1.16	1	8	2	97	0.00	0.0	6.597	0.137	8	2	2	2

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Millers Creek

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.22924	PL.23247	A	#1/0 ACSR	7.29Y	121.4	0.00	3.56	0.00	0	0	0	100	0.00	0.0	6.086	0.039	0	0	2	2
PL.22923	PL.23242	A	6 A (CWC)	7.30Y	121.6	0.00	3.39	0.27	0	2	1	89	0.00	0.0	5.576	0.100	2	1	1	1
PL.22915	PL.23240	A	#1/0 ACSR	7.31Y	121.8	0.00	3.22	0.69	0	5	1	98	0.00	0.0	4.996	0.047	5	1	1	1
PL.22912	PL.22911	A	#4 ACSR	7.32Y	121.9	0.00	3.08	0.29	0	2	1	89	0.00	0.0	4.653	0.092	2	1	1	1
PL.23562	PL.23434	A	#4 ACSR	7.32Y	122.0	0.00	3.03	0.00	0	0	0	100	0.00	0.0	4.485	0.059	0	0	1	1
PL.23563	PL.23562	A	#4 ACSR	7.32Y	122.0	0.00	3.03	0.00	0	0	0	100	0.00	0.0	4.515	0.031	0	0	0	0
PL.22910	PL.23559	A	#4 ACSR	7.32Y	122.0	0.00	2.99	2.59	2	18	5	96	0.00	0.0	4.375	0.065	18	5	2	2
PL.23873	PL.23432	C	#1/0 ACSR	7.33Y	122.2	0.00	2.83	18.72	8	132	37	96	0.00	0.0	3.958	0.003	0	0	0	55
PD.3369	PL.23873	C	35L	7.33Y	122.2	0.00	2.83	18.72	53	132	37	96	0.00	0.0	3.958	0.003	0	0	0	55
PL.23874	PD.3369	C	#1/0 ACSR	7.33Y	122.1	0.07	2.90	18.72	8	132	37	96	0.06	0.0	4.113	0.155	0	0	1	55
PL.22896	PL.23874	C	#1/0 ACSR	7.32Y	122.0	0.05	2.95	18.67	8	132	37	96	0.04	0.0	4.218	0.104	0	0	1	54
PL.22897	PL.22896	C	#1/0 ACSR	7.32Y	122.0	0.03	2.98	15.75	7	111	31	96	0.02	0.0	4.290	0.072	9	3	1	48
PL.23735	PL.22897	C	#4 ACSR	7.32Y	122.0	0.00	2.98	0.68	1	5	1	98	0.00	0.0	4.294	0.004	0	0	0	1
PD.3297	PL.23735	C	15T	7.32Y	122.0	0.00	2.98	0.68	0	5	1	98	0.00	0.0	4.294	0.004	0	0	0	1
PL.23736	PD.3297	C	#4 ACSR	7.32Y	122.0	0.00	2.98	0.68	1	5	1	98	0.00	0.0	4.354	0.060	5	1	1	1
PL.22898	PL.22897	C	#1/0 ACSR	7.32Y	122.0	0.00	2.98	0.56	0	4	1	97	0.00	0.0	4.320	0.030	4	1	1	1
PL.22899	PL.22897	C	#1/0 ACSR	7.32Y	122.0	0.05	3.03	13.20	6	93	26	96	0.03	0.0	4.461	0.171	3	1	1	45
PL.23581	PL.22899	C	#1/0 ACSR	7.32Y	122.0	0.01	3.04	12.72	6	90	25	96	0.00	0.0	4.482	0.021	1	0	1	44
PL.23582	PL.23581	C	#1/0 ACSR	7.32Y	121.9	0.02	3.06	12.59	5	89	25	96	0.01	0.0	4.552	0.070	13	4	1	43
PL.23583	PL.23582	C	#1/0 ACSR	7.32Y	121.9	0.01	3.07	10.75	5	76	21	96	0.01	0.0	4.602	0.049	4	1	1	42
PL.23753	PL.23583	C	#4 ACSR	7.32Y	121.9	0.00	3.07	0.00	0	0	0	100	0.00	0.0	4.606	0.005	0	0	0	1
PD.3306	PL.23753	C	15T	7.32Y	121.9	0.00	3.07	0.00	0	0	0	100	0.00	0.0	4.606	0.005	0	0	0	1
PL.23754	PD.3306	C	#4 ACSR	7.32Y	121.9	0.00	3.07	0.00	0	0	0	100	0.00	0.0	4.668	0.062	0	0	1	1
PL.23425	PL.23583	C	#1/0 ACSR	7.32Y	121.9	0.01	3.08	10.22	4	72	20	96	0.00	0.0	4.636	0.034	0	0	0	40
PL.23426	PL.23425	C	#1/0 ACSR	7.31Y	121.9	0.04	3.11	10.22	4	72	20	96	0.02	0.0	4.785	0.149	0	0	1	40
PL.23749	PL.23426	C	#4 ACSR	7.31Y	121.9	0.00	3.12	0.77	1	5	2	93	0.00	0.0	4.789	0.005	0	0	0	7
PD.3304	PL.23749	C	15T	7.31Y	121.9	0.00	3.12	0.77	0	5	2	93	0.00	0.0	4.789	0.005	0	0	0	7
PL.23750	PD.3304	C	#4 ACSR	7.31Y	121.9	0.00	3.12	0.77	1	5	2	93	0.00	0.0	4.879	0.090	1	0	2	7
PL.23578	PL.23750	C	#4 ACSR	7.31Y	121.9	0.00	3.12	0.66	1	5	1	98	0.00	0.0	4.941	0.062	0	0	4	5
PL.22904	PL.23578	C	#4 ACSR	7.31Y	121.9	0.00	3.12	0.60	0	4	1	97	0.00	0.0	4.981	0.039	4	1	1	1
PL.22906	PL.22904	C	#4 ACSR	7.31Y	121.9	0.00	3.12	0.00	0	0	0	100	0.00	0.0	5.140	0.159	0	0	0	0

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Millers Creek

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru

PL.22903	PL.23426	C	#1/0 ACSR	7.31Y	121.9	0.01	3.13	9.43	4	66	19	96	0.01	0.0	4.849	0.064	10	3	1	32
PL.22907	PL.22903	C	#1/0 ACSR	7.31Y	121.8	0.03	3.15	8.02	3	56	16	96	0.01	0.0	4.985	0.137	0	0	0	31
PL.22949	PL.22907	C	#1/0 ACSR	7.31Y	121.8	0.02	3.18	8.02	3	56	16	96	0.01	0.0	5.106	0.121	0	0	0	31
PL.23751	PL.22949	C	#1/0 ACSR	7.31Y	121.8	0.00	3.18	8.02	3	56	16	96	0.00	0.0	5.111	0.005	0	0	0	31
PD.3305	PL.23751	C	15T	7.31Y	121.8	0.00	3.18	8.02	0	56	16	96	0.00	0.0	5.111	0.005	0	0	0	31
PL.23752	PD.3305	C	#1/0 ACSR	7.31Y	121.8	0.03	3.21	8.02	3	56	16	96	0.01	0.0	5.291	0.181	0	0	0	31
PL.22951	PL.23752	C	#1/0 ACSR	7.30Y	121.7	0.05	3.27	8.02	3	56	16	96	0.02	0.0	5.560	0.269	0	0	0	31
PL.22952	PL.22951	C	#1/0 ACSR	7.30Y	121.7	0.01	3.27	8.02	3	56	16	96	0.00	0.0	5.590	0.029	0	0	0	31
PL.23150	PL.22952	C	#1/0 ACSR	7.30Y	121.7	0.02	3.29	7.59	3	53	15	96	0.01	0.0	5.699	0.109	0	0	0	30
PL.22953	PL.23150	C	#1/0 ACSR	7.30Y	121.7	0.03	3.32	6.51	3	46	13	96	0.01	0.0	5.860	0.161	0	0	0	28
PL.22954	PL.22953	C	#1/0 ACSR	7.30Y	121.7	0.01	3.33	6.51	3	46	13	96	0.00	0.0	5.916	0.056	0	0	0	28
PL.23841	PL.22954	C	#1/0 ACSR	7.30Y	121.7	0.00	3.33	5.82	3	41	11	97	0.00	0.0	5.921	0.004	0	0	0	22
PD.3352	PL.23841	C	10T	7.30Y	121.7	0.00	3.33	5.82	0	41	11	97	0.00	0.0	5.921	0.004	0	0	0	22
PL.23842	PD.3352	C	#1/0 ACSR	7.30Y	121.6	0.03	3.35	5.82	3	41	11	97	0.01	0.0	6.108	0.187	0	0	1	22
PL.23586	PL.23842	C	#1/0 ACSR	7.30Y	121.6	0.00	3.36	5.82	3	41	11	97	0.00	0.0	6.124	0.017	3	1	1	21
PL.22955	PL.23586	C	#1/0 ACSR	7.30Y	121.6	0.02	3.37	5.46	2	38	11	96	0.00	0.0	6.268	0.143	0	0	0	20
PL.22956	PL.22955	C	#1/0 ACSR	7.30Y	121.6	0.00	3.37	0.40	0	3	1	95	0.00	0.0	6.384	0.117	3	1	2	2
PL.23151	PL.22955	C	#1/0 ACSR	7.30Y	121.6	0.00	3.38	5.06	2	36	10	96	0.00	0.0	6.308	0.040	0	0	0	18
PL.23761	PL.23151	C	#4 ACSR	7.30Y	121.6	0.00	3.38	0.95	1	7	2	96	0.00	0.0	6.312	0.005	0	0	0	1
PD.3310	PL.23761	C	8T	7.30Y	121.6	0.00	3.38	0.95	0	7	2	96	0.00	0.0	6.312	0.005	0	0	0	1
PL.23762	PD.3310	C	#4 ACSR	7.30Y	121.6	0.00	3.38	0.95	1	7	2	96	0.00	0.0	6.402	0.090	0	0	0	1
PL.23236	PL.23762	C	#4 ACSR	7.30Y	121.6	0.00	3.39	0.95	1	7	2	96	0.00	0.0	6.533	0.130	7	2	1	1
PL.22957	PL.23151	C	#1/0 ACSR	7.30Y	121.6	0.01	3.39	4.10	2	29	8	96	0.00	0.0	6.418	0.110	0	0	0	17
PL.23152	PL.22957	C	6 A (CWC)	7.30Y	121.6	0.01	3.40	1.56	1	11	3	96	0.00	0.0	6.536	0.118	1	0	1	9
PL.23843	PL.23152	C	6 A (CWC)	7.30Y	121.6	0.00	3.40	0.96	1	7	2	96	0.00	0.0	6.541	0.005	0	0	0	6
PD.3353	PL.23843	C	8T	7.30Y	121.6	0.00	3.40	0.96	0	7	2	96	0.00	0.0	6.541	0.005	0	0	0	6
PL.23844	PD.3353	C	6 A (CWC)	7.30Y	121.6	0.01	3.40	0.96	1	7	2	96	0.00	0.0	6.690	0.150	0	0	0	6
PL.23237	PL.23844	C	6 A (CWC)	7.30Y	121.6	0.00	3.41	0.96	1	7	2	96	0.00	0.0	6.762	0.072	0	0	0	6
PL.22964	PL.23237	C	6 A (CWC)	7.30Y	121.6	0.01	3.41	0.96	1	7	2	96	0.00	0.0	6.912	0.150	0	0	0	6
PL.22963	PL.22964	C	6 A (CWC)	7.29Y	121.6	0.00	3.42	0.96	1	7	2	96	0.00	0.0	6.990	0.078	0	0	0	6
PL.22965	PL.22963	C	#4 ACSR	7.29Y	121.6	0.00	3.42	0.96	1	7	2	96	0.00	0.0	7.077	0.087	0	0	0	6

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Millers Creek

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.22966	PL.22965	C	#4 ACSR	7.29Y	121.6	0.00	3.42	0.01	0	0	0	100	0.00	0.0	7.128	0.051	0	0	2	2
PL.22967	PL.22965	C	#4 ACSR	7.29Y	121.6	0.00	3.42	0.95	1	7	2	96	0.00	0.0	7.114	0.037	1	0	1	4
PL.23851	PL.22967	C	#4 ACSR	7.29Y	121.6	0.00	3.42	0.35	0	2	1	89	0.00	0.0	7.119	0.005	0	0	0	1
PD.3357	PL.23851	C	8T	7.29Y	121.6	0.00	3.42	0.35	0	2	1	89	0.00	0.0	7.119	0.005	0	0	0	1
PL.23852	PD.3357	C	#4 ACSR	7.29Y	121.6	0.00	3.43	0.35	0	2	1	89	0.00	0.0	7.254	0.135	0	0	0	1
PL.22969	PL.23852	C	#4 ACSR	7.29Y	121.6	0.00	3.43	0.35	0	2	1	89	0.00	0.0	7.311	0.057	0	0	0	1
PL.22970	PL.22969	C	#4 ACSR	7.29Y	121.6	0.00	3.43	0.00	0	0	0	100	0.00	0.0	7.476	0.165	0	0	0	0
PL.23153	PL.22969	C	#4 ACSR	7.29Y	121.6	0.00	3.43	0.35	0	2	1	89	0.00	0.0	7.396	0.084	2	1	1	1
PL.22968	PL.22969	C	#4 ACSR	7.29Y	121.6	0.00	3.43	0.00	0	0	0	100	0.00	0.0	7.453	0.142	0	0	0	0
PL.23845	PL.22967	C	#4 ACSR	7.29Y	121.6	0.00	3.42	0.48	0	3	1	95	0.00	0.0	7.119	0.005	0	0	0	2
PD.3354	PL.23845	C	8T	7.29Y	121.6	0.00	3.42	0.48	0	3	1	95	0.00	0.0	7.119	0.005	0	0	0	2
PL.23846	PD.3354	C	#4 ACSR	7.29Y	121.6	0.00	3.43	0.48	0	3	1	95	0.00	0.0	7.295	0.177	0	0	0	2
PL.22971	PL.23846	C	#1/0 ACSR	7.29Y	121.6	0.00	3.43	0.48	0	3	1	95	0.00	0.0	7.419	0.124	3	1	2	2
PL.22962	PL.23152	C	#4 ACSR	7.30Y	121.6	0.00	3.40	0.47	0	3	1	95	0.00	0.0	6.649	0.113	3	1	2	2
PL.22959	PL.22957	C	#1/0 ACSR	7.30Y	121.6	0.00	3.39	2.55	1	18	5	96	0.00	0.0	6.423	0.005	0	0	0	8
PD.3315	PL.22959	C	8T	7.30Y	121.6	0.00	3.39	2.55	0	18	5	96	0.00	0.0	6.423	0.005	0	0	0	8
PL.22958	PD.3315	C	#4 ACSR	7.30Y	121.6	0.00	3.39	0.26	0	2	1	89	0.00	0.0	6.537	0.114	0	0	2	3
PL.22960	PL.22958	C	#1/0 ACSR	7.30Y	121.6	0.00	3.39	0.24	0	2	0	100	0.00	0.0	6.591	0.054	2	0	1	1
PL.23592	PD.3315	C	#1/0 ACSR	7.30Y	121.6	0.01	3.40	2.29	1	16	5	95	0.00	0.0	6.557	0.134	6	2	1	5
PL.23593	PL.23592	C	#1/0 ACSR	7.30Y	121.6	0.01	3.40	1.41	1	10	3	96	0.00	0.0	6.741	0.184	0	0	1	4
PL.23771	PL.23593	C	#1/0 ACSR	7.30Y	121.6	0.00	3.40	1.41	1	10	3	96	0.00	0.0	6.745	0.005	0	0	0	3
PD.3316	PL.23771	C	8T	7.30Y	121.6	0.00	3.40	1.41	0	10	3	96	0.00	0.0	6.745	0.005	0	0	0	3
PL.23772	PD.3316	C	#1/0 ACSR	7.30Y	121.6	0.00	3.40	1.41	1	10	3	96	0.00	0.0	6.836	0.091	4	1	2	3
PL.23594	PL.23772	C	#1/0 ACSR	7.30Y	121.6	0.00	3.41	0.89	0	6	2	95	0.00	0.0	6.880	0.044	6	2	1	1
PL.23759	PL.22954	C	6 A (CWC)	7.30Y	121.7	0.00	3.33	0.69	0	5	1	98	0.00	0.0	5.921	0.005	0	0	0	6
PD.3309	PL.23759	C	10T	7.30Y	121.7	0.00	3.33	0.69	0	5	1	98	0.00	0.0	5.921	0.005	0	0	0	6
PL.23760	PD.3309	C	6 A (CWC)	7.30Y	121.7	0.00	3.33	0.69	0	5	1	98	0.00	0.0	6.045	0.124	0	0	0	6
PL.23224	PL.23760	C	6 A (CWC)	7.30Y	121.7	0.00	3.33	0.69	0	5	1	98	0.00	0.0	6.156	0.112	0	0	0	6
PL.23225	PL.23224	C	6 A (CWC)	7.30Y	121.7	0.00	3.34	0.69	0	5	1	98	0.00	0.0	6.286	0.130	0	0	0	6
PL.23226	PL.23225	C	6 A (CWC)	7.30Y	121.7	0.00	3.34	0.69	0	5	1	98	0.00	0.0	6.409	0.122	0	0	0	6
PL.23763	PL.23226	C	#1/0 ACSR	7.30Y	121.7	0.00	3.34	0.59	0	4	1	97	0.00	0.0	6.413	0.005	0	0	0	1

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Millers Creek

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru

PD.3311	PL.23763	C	8T	7.30Y	121.7	0.00	3.34	0.59	0	4	1	97	0.00	0.0	6.413	0.005	0	0	0	1
PL.23764	PD.3311	C	#1/0 ACSR	7.30Y	121.7	0.00	3.34	0.59	0	4	1	97	0.00	0.0	6.567	0.154	4	1	1	1
PL.22961	PL.23226	C	6 A (CWC)	7.30Y	121.7	0.00	3.34	0.11	0	1	0	100	0.00	0.0	6.441	0.033	0	0	2	5
PL.23587	PL.22961	C	#4 ACSR	7.30Y	121.7	0.00	3.34	0.11	0	1	0	100	0.00	0.0	6.498	0.056	1	0	1	3
PL.23765	PL.23587	C	#4 ACSR	7.30Y	121.7	0.00	3.34	0.00	0	0	0	100	0.00	0.0	6.537	0.039	0	0	0	2
PD.3312	PL.23765	C	8T	7.30Y	121.7	0.00	3.34	0.00	0	0	0	100	0.00	0.0	6.537	0.039	0	0	0	2
PL.23766	PD.3312	C	#4 ACSR	7.30Y	121.7	0.00	3.34	0.00	0	0	0	100	0.00	0.0	6.648	0.111	0	0	0	2
PL.23227	PL.23766	C	#4 ACSR	7.30Y	121.7	0.00	3.34	0.00	0	0	0	100	0.00	0.0	6.740	0.092	0	0	0	2
PL.23768	PL.23227	C	#4 ACSR	7.30Y	121.7	0.00	3.34	0.00	0	0	0	100	0.00	0.0	6.863	0.123	0	0	0	2
PL.23228	PL.23768	C	#4 ACSR	7.30Y	121.7	0.00	3.34	0.00	0	0	0	100	0.00	0.0	7.008	0.146	0	0	0	2
PL.23229	PL.23228	C	#4 ACSR	7.30Y	121.7	0.00	3.34	0.00	0	0	0	100	0.00	0.0	7.075	0.066	0	0	0	2
PL.23588	PL.23229	C	#4 ACSR	7.30Y	121.7	0.00	3.34	0.00	0	0	0	100	0.00	0.0	7.201	0.126	0	0	1	2
PL.23589	PL.23588	C	#4 ACSR	7.30Y	121.7	0.00	3.34	0.00	0	0	0	100	0.00	0.0	7.347	0.146	0	0	0	1
PL.23590	PL.23589	C	#4 ACSR	7.30Y	121.7	0.00	3.34	0.00	0	0	0	100	0.00	0.0	7.397	0.051	0	0	0	1
PL.23591	PL.23590	C	#4 ACSR	7.30Y	121.7	0.00	3.34	0.00	0	0	0	100	0.00	0.0	7.466	0.069	0	0	0	1
PL.23769	PL.23591	C	#4 ACSR	7.30Y	121.7	0.00	3.34	0.00	0	0	0	100	0.00	0.0	7.471	0.005	0	0	0	1
PD.3314	PL.23769	C	12T	7.30Y	121.7	0.00	3.34	0.00	0	0	0	100	0.00	0.0	7.471	0.005	0	0	0	1
PL.23770	PD.3314	C	#4 ACSR	7.30Y	121.7	0.00	3.34	0.00	0	0	0	100	0.00	0.0	7.575	0.104	0	0	0	1
PL.23230	PL.23770	C	#4 ACSR	7.30Y	121.7	0.00	3.34	0.00	0	0	0	100	0.00	0.0	7.692	0.117	0	0	0	1
PL.23231	PL.23230	C	#4 ACSR	7.30Y	121.7	0.00	3.34	0.00	0	0	0	100	0.00	0.0	7.822	0.130	0	0	0	1
PL.23232	PL.23231	C	#4 ACSR	7.30Y	121.7	0.00	3.34	0.00	0	0	0	100	0.00	0.0	7.898	0.076	0	0	0	1
PL.23234	PL.23232	C	#4 ACSR	7.30Y	121.7	0.00	3.34	0.00	0	0	0	100	0.00	0.0	8.006	0.107	0	0	0	1
PL.23233	PL.23234	C	#4 ACSR	7.30Y	121.7	0.00	3.34	0.00	0	0	0	100	0.00	0.0	8.159	0.153	0	0	0	1
PL.23235	PL.23233	C	#4 ACSR	7.30Y	121.7	0.00	3.34	0.00	0	0	0	100	0.00	0.0	8.225	0.066	0	0	1	1
PL.23747	PL.23150	C	#4 ACSR	7.30Y	121.7	0.00	3.29	1.08	1	8	2	97	0.00	0.0	5.704	0.005	0	0	0	2
PD.3303	PL.23747	C	10T	7.30Y	121.7	0.00	3.29	1.08	0	8	2	97	0.00	0.0	5.704	0.005	0	0	0	2
PL.23748	PD.3303	C	#4 ACSR	7.30Y	121.7	0.00	3.30	1.08	1	8	2	97	0.00	0.0	5.844	0.140	7	2	1	2
PL.23585	PL.23748	C	#4 ACSR	7.30Y	121.7	0.00	3.30	0.07	0	0	0	100	0.00	0.0	5.880	0.036	0	0	1	1
PL.23758	PL.22952	C	#1/0 ACSR	7.30Y	121.7	0.00	3.27	0.43	0	3	1	95	0.00	0.0	5.594	0.005	0	0	0	1
PD.3308	PL.23758	C	10T	7.30Y	121.7	0.00	3.27	0.43	0	3	1	95	0.00	0.0	5.594	0.005	0	0	0	1
PL.23757	PD.3308	C	#1/0 ACSR	7.30Y	121.7	0.00	3.27	0.43	0	3	1	95	0.00	0.0	5.705	0.111	3	1	1	1

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Millers Creek

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.23739	PL.22896	C	6 A (CWC)	7.32Y	122.0	0.00	2.95	2.91	2	21	6	96	0.00	0.0	4.222	0.005	0	0	0	5
PD.3299	PL.23739	C	15T	7.32Y	122.0	0.00	2.95	2.91	0	21	6	96	0.00	0.0	4.222	0.005	0	0	0	5
PL.23740	PD.3299	C	6 A (CWC)	7.32Y	122.0	0.02	2.97	2.91	2	21	6	96	0.00	0.0	4.347	0.125	0	0	0	5
PL.23223	PL.23740	C	6 A (CWC)	7.32Y	122.0	0.01	2.98	2.91	2	21	6	96	0.00	0.0	4.456	0.109	0	0	0	5
PL.23755	PL.23223	C	6 A (CWC)	7.32Y	122.0	0.00	2.98	1.26	1	9	2	98	0.00	0.0	4.460	0.005	0	0	0	2
PD.3307	PL.23755	C	10T	7.32Y	122.0	0.00	2.98	1.26	0	9	2	98	0.00	0.0	4.460	0.005	0	0	0	2
PL.23756	PD.3307	C	6 A (CWC)	7.32Y	122.0	0.01	2.99	1.26	1	9	2	98	0.00	0.0	4.655	0.195	0	0	0	2
PL.22900	PL.23756	C	6 A (CWC)	7.32Y	122.0	0.00	3.00	1.26	1	9	2	98	0.00	0.0	4.731	0.076	0	0	0	2
PL.22901	PL.22900	C	6 A (CWC)	7.32Y	122.0	0.00	3.00	1.26	1	9	2	98	0.00	0.0	4.804	0.074	2	0	1	2
PL.22902	PL.22901	C	#4 ACSR	7.32Y	122.0	0.00	3.01	1.03	1	7	2	96	0.00	0.0	4.935	0.130	7	2	1	1
PL.23839	PL.23223	C	#4 ACSR	7.32Y	122.0	0.00	2.98	1.65	1	12	3	97	0.00	0.0	4.461	0.005	0	0	0	3
PD.3351	PL.23839	C	10T	7.32Y	122.0	0.00	2.98	1.65	0	12	3	97	0.00	0.0	4.461	0.005	0	0	0	3
PL.23840	PD.3351	C	#4 ACSR	7.32Y	122.0	0.00	2.98	1.65	1	12	3	97	0.00	0.0	4.481	0.020	7	2	1	3
PL.23584	PL.23840	C	#4 ACSR	7.32Y	122.0	0.00	2.99	0.65	0	5	1	98	0.00	0.0	4.567	0.086	5	1	2	2
PL.22881	PL.23446	C	#4 ACSR	7.34Y	122.3	0.00	2.69	0.65	1	5	1	98	0.00	0.0	3.536	0.066	5	1	1	1
PL.23835	PL.23544	A	#1/0 ACSR	7.35Y	122.4	0.00	2.58	0.06	0	0	0	100	0.00	0.0	3.159	0.005	0	0	0	1
PD.3349	PL.23835	A	20T	7.35Y	122.4	0.00	2.58	0.06	0	0	0	100	0.00	0.0	3.159	0.005	0	0	0	1
PL.23836	PD.3349	A	#1/0 ACSR	7.35Y	122.4	0.00	2.58	0.06	0	0	0	100	0.00	0.0	3.213	0.054	0	0	1	1
PL.23725	PL.23146	A	#4 ACSR	7.35Y	122.5	0.00	2.47	0.99	1	7	2	96	0.00	0.0	2.865	0.004	0	0	0	2
PD.3292	PL.23725	A	20T	7.35Y	122.5	0.00	2.47	0.99	0	7	2	96	0.00	0.0	2.865	0.004	0	0	0	2
PL.23726	PD.3292	A	#4 ACSR	7.35Y	122.5	0.00	2.47	0.99	1	7	2	96	0.00	0.0	2.922	0.058	7	2	2	2
PL.23721	PL.23449	C	#4 ACSR	7.36Y	122.7	0.00	2.35	1.12	1	8	2	97	0.00	0.0	2.536	0.005	0	0	0	1
PD.3290	PL.23721	C	20T	7.36Y	122.7	0.00	2.35	1.12	0	8	2	97	0.00	0.0	2.536	0.005	0	0	0	1
PL.23722	PD.3290	C	#4 ACSR	7.36Y	122.7	0.00	2.35	1.12	1	8	2	97	0.00	0.0	2.585	0.049	8	2	1	1
PL.23661	PL.23143	C	6 A (CWC)	7.43Y	123.8	0.00	1.23	0.55	0	4	1	97	0.00	0.0	0.938	0.005	0	0	0	1
PD.3260	PL.23661	C	50T	7.43Y	123.8	0.00	1.23	0.55	0	4	1	97	0.00	0.0	0.938	0.005	0	0	0	1
PL.23662	PD.3260	C	6 A (CWC)	7.43Y	123.8	0.00	1.23	0.55	0	4	1	97	0.00	0.0	1.085	0.147	4	1	1	1
PL.23867	PL.23480	C	6 A (CWC)	7.43Y	123.9	0.00	1.09	19.01	14	136	39	96	0.00	0.0	0.819	0.003	0	0	0	40
PD.3366	PL.23867	C	35L	7.43Y	123.9	0.00	1.09	19.01	54	136	39	96	0.00	0.0	0.819	0.003	0	0	0	40
PL.23868	PD.3366	C	6 A (CWC)	7.43Y	123.8	0.10	1.19	19.01	14	136	39	96	0.11	0.1	0.940	0.120	0	0	0	40
PL.23204	PL.23868	C	6 A (CWC)	7.42Y	123.7	0.11	1.30	19.01	14	136	38	96	0.11	0.1	1.065	0.125	0	0	0	40

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Millers Creek

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.23308	PL.23204	C	6 A (CWC)	7.42Y	123.6	0.09	1.39	19.01	14	136	38	96	0.09	0.1	1.164	0.099	0	0	0	40
PL.23141	PL.23308	C	6 A (CWC)	7.41Y	123.5	0.11	1.50	18.46	13	132	37	96	0.10	0.1	1.291	0.127	0	0	0	39
PL.23205	PL.23141	C	6 A (CWC)	7.40Y	123.4	0.11	1.61	18.46	13	132	37	96	0.11	0.1	1.423	0.132	0	0	0	39
PL.23476	PL.23205	C	6 A (CWC)	7.40Y	123.3	0.10	1.71	18.46	13	132	37	96	0.09	0.1	1.551	0.129	18	5	2	39
PL.23477	PL.23476	C	6 A (CWC)	7.39Y	123.2	0.09	1.80	15.96	11	114	32	96	0.08	0.1	1.675	0.124	0	0	0	37
PL.23208	PL.23477	C	6 A (CWC)	7.39Y	123.1	0.09	1.89	15.96	11	114	32	96	0.07	0.1	1.795	0.120	0	0	0	37
PL.23474	PL.23208	C	6 A (CWC)	7.38Y	123.0	0.09	1.98	15.96	11	113	32	96	0.08	0.1	1.919	0.124	2	0	1	37
PL.23475	PL.23474	C	6 A (CWC)	7.38Y	123.0	0.07	2.05	15.72	11	112	31	96	0.06	0.1	2.017	0.099	0	0	0	36
PL.23209	PL.23475	C	6 A (CWC)	7.37Y	122.9	0.10	2.15	15.72	11	112	31	96	0.08	0.1	2.155	0.138	0	0	0	36
PL.23456	PL.23209	C	6 A (CWC)	7.37Y	122.8	0.06	2.21	15.72	11	112	31	96	0.05	0.0	2.247	0.092	7	2	2	36
PL.22843	PL.23456	C	6 A (CWC)	7.37Y	122.8	0.01	2.22	2.55	2	18	5	96	0.00	0.0	2.332	0.085	8	2	1	2
PL.22844	PL.22843	C	#1/0 ACSR	7.37Y	122.8	0.00	2.22	1.49	1	11	3	96	0.00	0.0	2.363	0.031	11	3	1	1
PL.23472	PL.23456	C	6 A (CWC)	7.36Y	122.7	0.06	2.27	12.12	9	86	24	96	0.04	0.0	2.361	0.114	0	0	1	32
PL.23655	PL.23472	C	6 A (CWC)	7.36Y	122.7	0.00	2.28	12.12	9	86	24	96	0.00	0.0	2.366	0.005	0	0	0	31
PD.3257	PL.23655	C	15T	7.36Y	122.7	0.00	2.28	12.12	0	86	24	96	0.00	0.0	2.366	0.005	0	0	0	31
PL.23656	PD.3257	C	6 A (CWC)	7.36Y	122.7	0.05	2.33	12.12	9	86	24	96	0.03	0.0	2.458	0.093	6	2	1	31
PL.23473	PL.23656	C	6 A (CWC)	7.36Y	122.6	0.03	2.36	11.33	8	80	23	96	0.02	0.0	2.521	0.063	1	0	1	30
PL.23468	PL.23473	C	6 A (CWC)	7.36Y	122.6	0.03	2.39	11.12	8	79	22	96	0.02	0.0	2.584	0.063	0	0	0	29
PL.23467	PL.23468	C	6 A (CWC)	7.35Y	122.6	0.03	2.42	11.12	8	79	22	96	0.02	0.0	2.646	0.062	7	2	1	29
PL.23466	PL.23467	C	6 A (CWC)	7.35Y	122.5	0.07	2.49	10.17	7	72	20	96	0.04	0.1	2.794	0.147	1	0	1	28
PL.23465	PL.23466	C	6 A (CWC)	7.35Y	122.5	0.03	2.52	10.04	7	71	20	96	0.02	0.0	2.863	0.070	0	0	0	27
PL.23142	PL.23465	C	6 A (CWC)	7.35Y	122.4	0.04	2.56	8.37	6	59	17	96	0.02	0.0	2.977	0.113	3	1	1	24
PL.22873	PL.23142	C	#4 ACSR	7.35Y	122.4	0.00	2.57	1.84	1	13	4	96	0.00	0.0	2.997	0.020	0	0	0	4
PL.23461	PL.22873	C	#4 ACSR	7.35Y	122.4	0.00	2.57	1.03	1	7	2	96	0.00	0.0	3.019	0.022	4	1	2	3
PL.23462	PL.23461	C	#4 ACSR	7.35Y	122.4	0.00	2.57	0.46	0	3	1	95	0.00	0.0	3.063	0.045	3	1	1	1
PL.22874	PL.22873	C	#4 ACSR	7.35Y	122.4	0.00	2.57	0.80	1	6	2	95	0.00	0.0	3.030	0.033	6	2	1	1
PL.23463	PL.23142	C	6 A (CWC)	7.34Y	122.4	0.03	2.59	6.08	4	43	12	96	0.01	0.0	3.081	0.105	1	0	1	19
PL.23464	PL.23463	C	6 A (CWC)	7.34Y	122.4	0.02	2.61	5.98	4	42	12	96	0.01	0.0	3.164	0.082	6	2	4	18
PL.22870	PL.23464	C	#4 ACSR	7.34Y	122.4	0.00	2.61	0.30	0	2	1	89	0.00	0.0	3.213	0.049	2	1	2	2
PL.23470	PL.23464	C	6 A (CWC)	7.34Y	122.4	0.02	2.63	3.86	3	27	8	96	0.00	0.0	3.254	0.090	1	0	1	10
PL.23471	PL.23470	C	6 A (CWC)	7.34Y	122.4	0.02	2.65	3.66	3	26	7	97	0.00	0.0	3.361	0.107	0	0	0	9

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Millers Creek

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru

PL.23469	PL.23471	C	6 A (CWC)	7.34Y	122.3	0.03	2.67	3.66	3	26	7	97	0.01	0.0	3.529	0.168	0	0	1	9
PL.22869	PL.23469	C	#4 ACSR	7.34Y	122.3	0.00	2.68	0.54	0	4	1	97	0.00	0.0	3.589	0.060	4	1	1	1
PL.23455	PL.23469	C	6 A (CWC)	7.34Y	122.3	0.02	2.70	3.12	2	22	6	96	0.00	0.0	3.695	0.166	0	0	0	7
PL.23210	PL.23455	C	6 A (CWC)	7.34Y	122.3	0.02	2.72	3.12	2	22	6	96	0.00	0.0	3.826	0.131	0	0	0	7
PL.23454	PL.23210	C	6 A (CWC)	7.34Y	122.3	0.02	2.73	3.12	2	22	6	96	0.00	0.0	3.953	0.127	7	2	4	7
PL.23459	PL.23454	C	6 A (CWC)	7.34Y	122.3	0.01	2.74	2.13	2	15	4	97	0.00	0.0	4.047	0.094	5	1	1	3
PL.23460	PL.23459	C	6 A (CWC)	7.34Y	122.3	0.00	2.74	1.43	1	10	3	96	0.00	0.0	4.124	0.077	10	3	2	2
PL.22868	PL.23454	C	#4 ACSR	7.34Y	122.3	0.00	2.73	0.00	0	0	0	100	0.00	0.0	4.059	0.105	0	0	0	0
PL.22871	PL.23464	C	6 A (CWC)	7.34Y	122.4	0.00	2.62	0.97	1	7	2	96	0.00	0.0	3.258	0.094	5	1	1	2
PL.22872	PL.22871	C	#4 ACSR	7.34Y	122.4	0.00	2.62	0.22	0	2	0	100	0.00	0.0	3.301	0.044	2	0	1	1
PL.22875	PL.23465	C	6 A (CWC)	7.35Y	122.5	0.00	2.52	1.67	1	12	3	97	0.00	0.0	2.903	0.040	12	3	3	3
PL.22841	PL.23308	C	#1/0 ACSR	7.42Y	123.6	0.00	1.39	0.56	0	4	1	97	0.00	0.0	1.201	0.037	4	1	1	1
PL.23659	PL.23199	A	6 A (CWC)	7.45Y	124.2	0.00	0.76	1.76	1	13	4	96	0.00	0.0	0.578	0.005	0	0	0	3
PD.3259	PL.23659	A	50T	7.45Y	124.2	0.00	0.76	1.76	0	13	4	96	0.00	0.0	0.578	0.005	0	0	0	3
PL.23660	PD.3259	A	6 A (CWC)	7.45Y	124.2	0.01	0.77	1.76	1	13	4	96	0.00	0.0	0.704	0.126	0	0	0	3
PL.23200	PL.23660	A	6 A (CWC)	7.45Y	124.2	0.01	0.79	1.76	1	13	4	96	0.00	0.0	0.861	0.157	0	0	0	3
PL.23201	PL.23200	A	6 A (CWC)	7.45Y	124.2	0.01	0.80	1.76	1	13	4	96	0.00	0.0	1.039	0.178	0	0	0	3
PL.23202	PL.23201	A	6 A (CWC)	7.45Y	124.2	0.01	0.81	1.76	1	13	4	96	0.00	0.0	1.193	0.154	0	0	0	3
PL.22838	PL.23202	A	#1/0 ACSR	7.45Y	124.2	0.00	0.81	0.83	0	6	2	95	0.00	0.0	1.233	0.040	6	2	1	1
PL.23139	PL.23202	A	6 A (CWC)	7.45Y	124.2	0.01	0.82	0.93	1	7	2	96	0.00	0.0	1.354	0.161	0	0	0	2
PL.23203	PL.23139	A	6 A (CWC)	7.45Y	124.2	0.00	0.82	0.93	1	7	2	96	0.00	0.0	1.535	0.181	7	2	2	2
PL.21532	Millers Creek	ABC	336 MCM AC	7.50Y	125.0	0.01	0.01	83.63	16	1791	578	95	0.05	0.0	0.009	0.009	0	0	0	417
PL.27999	PL.21532	ABC	336 MCM AC	7.50Y	125.0	0.00	0.01	83.63	16	1791	578	95	0.01	0.0	0.011	0.002	0	0	0	417

----- Feeder No. 2 (Youth Haven F2) Beginning with Device PD.3871 -----

PD.3871	PL.27999	ABC	200VWE	7.50Y	125.0	0.00	0.01	83.63	0	1791	578	95	0.00	0.0	0.011	0.002	0	0	0	417
PL.28000	PD.3871	ABC	336 MCM AC	7.50Y	124.9	0.05	0.05	83.63	16	1791	578	95	0.42	0.0	0.082	0.071	8	2	2	417
PL.23011	PL.28000	ABC	336 MCM AC	7.50Y	124.9	0.03	0.08	83.25	16	1782	575	95	0.23	0.0	0.122	0.040	1	0	1	415
PL.23012	PL.23011	ABC	336 MCM AC	7.49Y	124.8	0.08	0.16	83.20	16	1781	574	95	0.68	0.0	0.239	0.117	0	0	0	414
PL.23014	PL.23012	ABC	336 MCM AC	7.49Y	124.8	0.03	0.18	82.91	16	1774	571	95	0.25	0.0	0.282	0.044	0	0	1	412

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Millers Creek

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.23015	PL.23014	ABC	336 MCM AC	7.49Y	124.8	0.02	0.21	82.91	16	1773	570	95	0.19	0.0	0.316	0.034	7	2	1	411
PL.23016	PL.23015	ABC	336 MCM AC	7.48Y	124.7	0.05	0.25	82.57	16	1766	568	95	0.42	0.0	0.390	0.074	5	1	2	410
PL.23013	PL.23016	ABC	336 MCM AC	7.48Y	124.7	0.02	0.28	82.35	16	1761	565	95	0.21	0.0	0.427	0.037	2	1	1	408
PL.23008	PL.23013	ABC	336 MCM AC	7.48Y	124.7	0.04	0.31	82.24	16	1758	564	95	0.32	0.0	0.482	0.056	3	1	1	407
PL.23007	PL.23008	ABC	336 MCM AC	7.48Y	124.6	0.09	0.41	82.08	16	1754	562	95	0.83	0.0	0.629	0.146	0	0	0	406
PL.23892	PL.23007	C	#1/0 ACSR	7.48Y	124.6	0.00	0.41	0.01	0	0	0	100	0.00	0.0	0.640	0.011	0	0	0	1
PL.24411	PL.23892	C	6 A (CWC)	7.48Y	124.6	0.00	0.41	0.01	0	0	0	100	0.00	0.0	0.644	0.005	0	0	0	1
PD.3399	PL.24411	C	50T	7.48Y	124.6	0.00	0.41	0.01	0	0	0	100	0.00	0.0	0.644	0.005	0	0	0	1
PL.24412	PD.3399	C	6 A (CWC)	7.48Y	124.6	0.00	0.41	0.01	0	0	0	100	0.00	0.0	0.781	0.136	0	0	1	1
PL.24053	PL.24412	C	6 A (CWC)	7.48Y	124.6	0.00	0.41	0.00	0	0	0	100	0.00	0.0	0.856	0.076	0	0	0	0
PL.23005	PL.23007	ABC	336 MCM AC	7.47Y	124.5	0.08	0.49	82.07	16	1753	560	95	0.73	0.0	0.757	0.128	1	0	1	405
PL.23006	PL.23005	ABC	336 MCM AC	7.47Y	124.4	0.09	0.58	82.04	16	1752	559	95	0.84	0.0	0.904	0.147	0	0	0	404
PL.24409	PL.23006	C	#1/0 ACSR	7.47Y	124.4	0.00	0.58	0.06	0	0	0	100	0.00	0.0	0.909	0.005	0	0	0	1
PD.3398	PL.24409	C	50T	7.47Y	124.4	0.00	0.58	0.06	0	0	0	100	0.00	0.0	0.909	0.005	0	0	0	1
PL.24410	PD.3398	C	#1/0 ACSR	7.47Y	124.4	0.00	0.58	0.06	0	0	0	100	0.00	0.0	0.928	0.019	0	0	1	1
PL.24078	PL.23006	ABC	336 MCM AC	7.46Y	124.4	0.07	0.65	82.02	16	1751	556	95	0.60	0.0	1.011	0.106	0	0	0	403
PL.23009	PL.24078	ABC	336 MCM AC	7.46Y	124.3	0.06	0.71	82.02	16	1750	555	95	0.54	0.0	1.107	0.096	0	0	1	403
PL.23010	PL.23009	ABC	336 MCM AC	7.45Y	124.2	0.12	0.83	82.02	16	1749	554	95	1.04	0.1	1.289	0.183	0	0	0	402
PL.23893	PL.23010	A	#1/0 ACSR	7.45Y	124.2	0.00	0.83	0.33	0	2	1	89	0.00	0.0	1.321	0.032	2	1	1	1
PL.24079	PL.23010	ABC	336 MCM AC	7.45Y	124.1	0.09	0.92	81.91	16	1746	551	95	0.80	0.0	1.431	0.142	0	0	0	401
PL.23003	PL.24079	ABC	336 MCM AC	7.44Y	124.0	0.07	0.99	81.91	16	1745	549	95	0.65	0.0	1.546	0.115	0	0	1	401
PL.23004	PL.23003	ABC	336 MCM AC	7.44Y	123.9	0.07	1.06	81.89	16	1744	547	95	0.65	0.0	1.662	0.116	0	0	0	400
PL.24132	PL.23004	ABC	336 MCM AC	7.43Y	123.9	0.08	1.14	81.89	16	1744	546	95	0.73	0.0	1.791	0.129	0	0	0	400
PL.24261	PL.24132	ABC	336 MCM AC	7.43Y	123.8	0.04	1.19	81.89	16	1743	544	95	0.38	0.0	1.858	0.067	0	0	1	400
PL.24262	PL.24261	ABC	336 MCM AC	7.43Y	123.8	0.03	1.22	81.88	16	1742	543	95	0.26	0.0	1.903	0.046	8	2	1	399
PL.24263	PL.24262	ABC	336 MCM AC	7.42Y	123.7	0.07	1.29	81.49	16	1734	540	95	0.64	0.0	2.018	0.115	0	0	0	398
PL.24133	PL.24263	ABC	336 MCM AC	7.42Y	123.6	0.07	1.35	81.49	16	1733	539	95	0.59	0.0	2.124	0.105	0	0	0	398
PL.24134	PL.24133	ABC	336 MCM AC	7.42Y	123.6	0.04	1.40	81.49	16	1732	537	96	0.37	0.0	2.190	0.066	0	0	0	398
PL.24216	PL.24134	ABC	336 MCM AC	7.41Y	123.6	0.03	1.42	81.49	16	1732	536	96	0.26	0.0	2.237	0.047	2	0	1	398
PL.24217	PL.24216	ABC	336 MCM AC	7.41Y	123.5	0.05	1.47	81.41	16	1730	535	96	0.44	0.0	2.316	0.079	8	2	2	396
PL.23897	PL.24217	ABC	336 MCM AC	7.41Y	123.5	0.06	1.54	81.03	16	1721	532	96	0.54	0.0	2.414	0.098	0	0	0	394

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Millers Creek

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.24080	PL.23897	ABC	336 MCM AC	7.41Y	123.4	0.03	1.56	75.80	15	1609	499	96	0.23	0.0	2.462	0.048	0	0	0	368
PL.24515	PL.24080	ABC	336 MCM AC	7.40Y	123.4	0.03	1.60	75.80	15	1609	499	96	0.26	0.0	2.517	0.055	0	0	0	368
PL.24516	PL.24515	ABC	336 MCM AC	7.40Y	123.4	0.02	1.62	75.80	15	1608	498	96	0.19	0.0	2.556	0.039	0	0	0	368
PL.24090	PL.24516	ABC	336 MCM AC	7.40Y	123.3	0.08	1.70	75.78	15	1608	498	96	0.70	0.0	2.701	0.145	0	0	0	367
PL.24403	PL.24090	C	#1/0 ACSR	7.40Y	123.3	0.00	1.70	0.00	0	0	0	100	0.00	0.0	2.706	0.005	0	0	0	0
PD.3396	PL.24403	C	40T	7.40Y	123.3	0.00	1.70	0.00	0	0	0	100	0.00	0.0	2.706	0.005	0	0	0	0
PL.24404	PD.3396	C	#1/0 ACSR	7.40Y	123.3	0.00	1.70	0.00	0	0	0	100	0.00	0.0	2.724	0.018	0	0	0	0
PL.24405	PL.24090	ABC	336 MCM AC	7.40Y	123.3	0.00	1.71	75.78	15	1607	496	96	0.02	0.0	2.706	0.004	0	0	0	367
PL.24406	PL.24405	ABC	336 MCM AC	7.39Y	123.2	0.06	1.77	75.78	15	1607	496	96	0.50	0.0	2.809	0.104	0	0	0	367
PL.24401	PL.24406	A	#1/0 ACSR	7.39Y	123.2	0.00	1.77	1.15	0	8	2	97	0.00	0.0	2.814	0.005	0	0	0	4
PD.3395	PL.24401	A	40T	7.39Y	123.2	0.00	1.77	1.15	0	8	2	97	0.00	0.0	2.814	0.005	0	0	0	4
PL.24402	PD.3395	A	#1/0 ACSR	7.39Y	123.2	0.00	1.77	1.15	0	8	2	97	0.00	0.0	2.860	0.046	6	2	2	4
PL.23904	PL.24402	A	6 A (CWC)	7.39Y	123.2	0.00	1.77	0.37	0	3	1	95	0.00	0.0	2.917	0.057	0	0	0	2
PL.23905	PL.23904	A	#4 ACSR	7.39Y	123.2	0.00	1.77	0.37	0	3	1	95	0.00	0.0	3.055	0.138	0	0	0	2
PL.24146	PL.23905	A	#4 ACSR	7.39Y	123.2	0.00	1.77	0.37	0	3	1	95	0.00	0.0	3.126	0.071	0	0	0	2
PL.24147	PL.24146	A	#4 ACSR	7.39Y	123.2	0.00	1.77	0.37	0	3	1	95	0.00	0.0	3.219	0.092	2	1	1	2
PL.23354	PL.24147	A	#4 ACSR	7.39Y	123.2	0.00	1.77	0.07	0	1	0	100	0.00	0.0	3.301	0.083	1	0	1	1
PL.24091	PL.24406	ABC	336 MCM AC	7.39Y	123.2	0.07	1.84	75.40	15	1598	492	96	0.60	0.0	2.936	0.126	0	0	0	363
PL.24148	PL.24091	ABC	336 MCM AC	7.38Y	123.1	0.09	1.93	75.40	15	1598	491	96	0.76	0.0	3.094	0.158	0	0	0	363
PL.23000	PL.24148	ABC	336 MCM AC	7.38Y	123.0	0.05	1.98	75.40	15	1597	489	96	0.38	0.0	3.173	0.079	7	2	1	363
PL.23001	PL.23000	ABC	336 MCM AC	7.38Y	122.9	0.09	2.07	75.05	14	1589	486	96	0.73	0.0	3.328	0.155	10	3	1	362
PL.23002	PL.23001	ABC	336 MCM AC	7.37Y	122.9	0.04	2.10	74.61	14	1579	482	96	0.30	0.0	3.392	0.064	3	1	1	361
PL.22999	PL.23002	ABC	336 MCM AC	7.37Y	122.9	0.04	2.14	74.46	14	1576	480	96	0.34	0.0	3.464	0.072	0	0	0	360
PL.22996	PL.22999	ABC	336 MCM AC	7.37Y	122.8	0.02	2.17	74.08	14	1567	477	96	0.20	0.0	3.506	0.042	0	0	0	358
PL.22997	PL.22996	ABC	336 MCM AC	7.37Y	122.8	0.03	2.19	74.08	14	1567	477	96	0.22	0.0	3.554	0.048	2	0	1	358
PL.22998	PL.22997	ABC	336 MCM AC	7.37Y	122.8	0.04	2.23	74.01	14	1565	476	96	0.30	0.0	3.618	0.064	0	0	0	357
PL.24266	PL.22998	ABC	336 MCM AC	7.36Y	122.7	0.03	2.26	74.01	14	1565	475	96	0.23	0.0	3.669	0.050	9	3	1	357
PL.22995	PL.24266	ABC	336 MCM AC	7.36Y	122.7	0.04	2.30	73.58	14	1556	472	96	0.30	0.0	3.735	0.067	0	0	0	356
PL.24092	PL.22995	ABC	336 MCM AC	7.36Y	122.6	0.08	2.38	73.12	14	1545	469	96	0.65	0.0	3.879	0.144	0	0	0	355
PL.24264	PL.24092	ABC	336 MCM AC	7.35Y	122.6	0.07	2.45	73.12	14	1545	467	96	0.59	0.0	4.010	0.131	2	1	1	355
PL.24265	PL.24264	ABC	336 MCM AC	7.35Y	122.5	0.04	2.49	73.03	14	1542	465	96	0.34	0.0	4.085	0.076	0	0	0	354

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Millers Creek

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.24093	PL.24265	ABC	336 MCM AC	7.35Y	122.5	0.04	2.54	73.03	14	1542	464	96	0.36	0.0	4.165	0.080	0	0	1	354
PL.24391	PL.24093	C	6 A (CWC)	7.35Y	122.5	0.00	2.54	8.88	6	63	18	96	0.00	0.0	4.170	0.005	0	0	0	11
PD.3390	PL.24391	C	40T	7.35Y	122.5	0.00	2.54	8.88	0	63	18	96	0.00	0.0	4.170	0.005	0	0	0	11
PL.24392	PD.3390	C	6 A (CWC)	7.34Y	122.4	0.05	2.58	8.88	6	63	18	96	0.02	0.0	4.283	0.113	0	0	0	11
PL.24057	PL.24392	C	6 A (CWC)	7.34Y	122.4	0.01	2.59	3.31	2	23	7	96	0.00	0.0	4.346	0.063	1	0	1	4
PL.24056	PL.24057	C	#4 ACSR	7.34Y	122.4	0.00	2.60	3.11	2	22	6	96	0.00	0.0	4.383	0.037	2	1	1	3
PL.24055	PL.24056	C	#1/0 ACSR	7.34Y	122.4	0.00	2.60	0.50	0	4	1	97	0.00	0.0	4.435	0.052	4	1	1	1
PL.24054	PL.24056	C	#1/0 ACSR	7.34Y	122.4	0.00	2.60	2.34	1	17	5	96	0.00	0.0	4.472	0.089	17	5	1	1
PL.24218	PL.24392	C	6 A (CWC)	7.34Y	122.4	0.02	2.60	5.57	4	39	11	96	0.00	0.0	4.357	0.074	7	2	1	7
PL.24219	PL.24218	C	6 A (CWC)	7.34Y	122.4	0.01	2.61	2.42	2	17	5	96	0.00	0.0	4.406	0.049	0	0	0	5
PL.24094	PL.24219	C	6 A (CWC)	7.34Y	122.4	0.00	2.61	0.96	1	7	2	96	0.00	0.0	4.433	0.028	7	2	2	2
PL.24058	PL.24219	C	#1/0 ACSR	7.34Y	122.4	0.00	2.61	1.46	1	10	3	96	0.00	0.0	4.462	0.056	10	3	3	3
PL.24059	PL.24218	C	#4 ACSR	7.34Y	122.4	0.00	2.60	2.22	2	16	4	97	0.00	0.0	4.388	0.031	16	4	1	1
PL.23906	PL.24093	ABC	336 MCM AC	7.34Y	122.4	0.08	2.61	70.07	14	1479	446	96	0.60	0.0	4.311	0.145	0	0	0	342
PL.24150	PL.23906	ABC	336 MCM AC	7.34Y	122.3	0.06	2.67	70.07	14	1478	445	96	0.43	0.0	4.415	0.104	0	0	0	342
PL.24151	PL.24150	ABC	336 MCM AC	7.34Y	122.3	0.07	2.74	70.07	14	1478	444	96	0.53	0.0	4.544	0.129	0	0	0	342
PL.24152	PL.24151	ABC	336 MCM AC	7.33Y	122.2	0.09	2.83	70.07	14	1477	442	96	0.68	0.0	4.708	0.164	0	0	0	342
PL.24153	PL.24152	ABC	336 MCM AC	7.32Y	122.1	0.09	2.92	70.07	14	1476	441	96	0.70	0.0	4.878	0.170	0	0	0	342
PL.24154	PL.24153	ABC	336 MCM AC	7.32Y	122.0	0.08	2.99	70.07	14	1476	439	96	0.60	0.0	5.022	0.144	0	0	0	342
PL.24155	PL.24154	ABC	336 MCM AC	7.32Y	121.9	0.07	3.06	70.07	14	1475	438	96	0.51	0.0	5.145	0.123	0	0	0	342
PL.24156	PL.24155	ABC	336 MCM AC	7.31Y	121.9	0.07	3.13	70.07	14	1475	436	96	0.51	0.0	5.270	0.124	0	0	0	342
PL.24157	PL.24156	ABC	336 MCM AC	7.31Y	121.8	0.07	3.19	70.07	14	1474	435	96	0.51	0.0	5.393	0.123	0	0	0	342
PL.24158	PL.24157	ABC	336 MCM AC	7.31Y	121.8	0.03	3.22	70.07	14	1474	434	96	0.20	0.0	5.441	0.048	0	0	0	342
PL.24095	PL.24158	ABC	336 MCM AC	7.30Y	121.7	0.06	3.27	69.46	13	1461	430	96	0.43	0.0	5.548	0.107	0	0	0	338
PL.23922	PL.24095	ABC	336 MCM AC	7.30Y	121.7	0.04	3.32	62.71	12	1318	388	96	0.31	0.0	5.642	0.094	0	0	0	271
PL.24497	PL.23922	ABC	336 MCM AC	7.30Y	121.7	0.00	3.32	62.71	12	1318	388	96	0.02	0.0	5.646	0.005	0	0	0	271
PD.3443-A	PL.24497	ABC	Closed	7.30Y	121.7	0.00	3.32	62.71	0	1318	388	96	0.00	0.0	5.646	0.005	0	0	0	271
PD.3443-B	PD.3443-A	ABC	Closed	7.30Y	121.7	0.00	3.32	62.71	0	1318	388	96	0.00	0.0	5.646	0.005	0	0	0	271
PL.24498	PD.3443-B	ABC	336 MCM AC	7.30Y	121.6	0.04	3.36	62.71	12	1318	388	96	0.29	0.0	5.734	0.088	0	0	0	271
PL.24185	PL.24498	ABC	336 MCM AC	7.30Y	121.6	0.06	3.42	62.71	12	1317	387	96	0.39	0.0	5.852	0.117	0	0	0	271
PL.24186	PL.24185	ABC	336 MCM AC	7.29Y	121.5	0.04	3.46	62.71	12	1317	386	96	0.31	0.0	5.945	0.094	0	0	0	271

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Millers Creek

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.24103	PL.24186	ABC	336 MCM AC	7.29Y	121.5	0.04	3.50	62.61	12	1315	385	96	0.29	0.0	6.033	0.088	0	0	0	269
PL.24188	PL.24103	ABC	336 MCM AC	7.29Y	121.4	0.05	3.56	62.61	12	1314	384	96	0.38	0.0	6.149	0.116	0	0	0	269
PL.24189	PL.24188	ABC	336 MCM AC	7.28Y	121.4	0.04	3.60	62.61	12	1314	383	96	0.30	0.0	6.240	0.090	1	0	1	269
PL.23369	PL.24189	ABC	336 MCM AC	7.28Y	121.4	0.05	3.65	62.57	12	1313	382	96	0.33	0.0	6.340	0.100	0	0	0	268
PL.24190	PL.23369	ABC	336 MCM AC	7.28Y	121.3	0.05	3.70	62.57	12	1312	382	96	0.38	0.0	6.453	0.114	0	0	0	268
PL.24191	PL.24190	ABC	336 MCM AC	7.27Y	121.2	0.06	3.76	62.57	12	1312	381	96	0.39	0.0	6.572	0.119	0	0	0	268
PL.24471	PL.24191	A	#1/0 ACSR	7.27Y	121.2	0.00	3.76	1.42	1	10	3	96	0.00	0.0	6.577	0.005	0	0	0	4
PD.3430	PL.24471	A	50T	7.27Y	121.2	0.00	3.76	1.42	0	10	3	96	0.00	0.0	6.577	0.005	0	0	0	4
PL.24472	PD.3430	A	#1/0 ACSR	7.27Y	121.2	0.00	3.76	1.42	1	10	3	96	0.00	0.0	6.644	0.068	8	2	1	4
PL.23372	PL.24472	A	#4 ACSR	7.27Y	121.2	0.00	3.76	0.34	0	2	1	89	0.00	0.0	6.753	0.108	0	0	0	3
PL.23371	PL.23372	A	6 A (CWC)	7.27Y	121.2	0.00	3.76	0.34	0	2	1	89	0.00	0.0	6.814	0.062	2	1	3	3
PL.24485	PL.24191	A	#1/0 ACSR	7.27Y	121.2	0.00	3.76	1.40	1	10	3	96	0.00	0.0	6.576	0.004	0	0	0	1
PD.3438	PL.24485	A	50T	7.27Y	121.2	0.00	3.76	1.40	0	10	3	96	0.00	0.0	6.576	0.004	0	0	0	1
PL.24486	PD.3438	A	#1/0 ACSR	7.27Y	121.2	0.00	3.76	1.40	1	10	3	96	0.00	0.0	6.579	0.003	0	0	0	1
PL.23370	PL.24486	A	#4 ACSR	7.27Y	121.2	0.00	3.76	1.40	1	10	3	96	0.00	0.0	6.630	0.051	0	0	0	1
PL.24075	PL.23370	A	#4 ACSR	7.27Y	121.2	0.00	3.76	1.40	1	10	3	96	0.00	0.0	6.650	0.019	10	3	1	1
PL.24104	PL.24191	ABC	336 MCM AC	7.27Y	121.2	0.04	3.80	61.63	12	1292	374	96	0.28	0.0	6.661	0.089	0	0	0	263
PL.24192	PL.24104	ABC	336 MCM AC	7.27Y	121.2	0.05	3.85	61.63	12	1292	374	96	0.34	0.0	6.766	0.105	0	0	0	263
PL.23939	PL.24192	ABC	336 MCM AC	7.27Y	121.1	0.05	3.90	61.63	12	1291	373	96	0.37	0.0	6.882	0.116	0	0	0	263
PL.24193	PL.23939	ABC	336 MCM AC	7.26Y	121.1	0.04	3.94	61.63	12	1291	372	96	0.26	0.0	6.963	0.081	0	0	0	263
PL.24194	PL.24193	ABC	336 MCM AC	7.26Y	121.0	0.06	4.00	61.63	12	1291	371	96	0.40	0.0	7.088	0.125	0	0	0	263
PL.24195	PL.24194	ABC	336 MCM AC	7.26Y	120.9	0.05	4.05	61.63	12	1290	370	96	0.37	0.0	7.205	0.117	0	0	0	263
PL.23940	PL.24195	ABC	336 MCM AC	7.26Y	120.9	0.03	4.08	61.63	12	1290	369	96	0.20	0.0	7.269	0.063	0	0	0	263
PL.24507	PL.23940	B	#1/0 ACSR	7.26Y	120.9	0.00	4.08	52.26	23	365	104	96	0.01	0.0	7.271	0.003	0	0	0	72
PD.10803	PL.24507	B	100CodeSMo	7.26Y	120.9	0.00	4.08	52.26	0	365	104	96	0.00	0.0	7.271	0.003	0	0	0	72
PL.24508	PD.10803	B	#1/0 ACSR	7.25Y	120.9	0.03	4.11	52.26	23	365	104	96	0.07	0.0	7.296	0.025	0	0	0	72
PL.23941	PL.24508	B	6 A (CWC)	7.25Y	120.9	0.01	4.12	2.91	2	20	6	96	0.00	0.0	7.338	0.042	0	0	0	1
PL.23943	PL.23941	B	#4 ACSR	7.25Y	120.9	0.00	4.12	2.91	2	20	6	96	0.00	0.0	7.408	0.070	20	6	1	1
PL.24106	PL.23941	B	6 A (CWC)	7.25Y	120.9	0.00	4.12	0.00	0	0	0	100	0.00	0.0	7.355	0.017	0	0	0	0
PL.23942	PL.24508	B	6 A (CWC)	7.25Y	120.8	0.08	4.19	49.35	35	344	98	96	0.20	0.1	7.331	0.034	0	0	0	71
PL.23384	PL.23942	B	6 A (CWC)	7.23Y	120.5	0.33	4.52	49.35	35	344	98	96	0.87	0.3	7.479	0.148	3	1	1	71

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Millers Creek

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.23945	PL.23384	B	6 A (CWC)	7.23Y	120.5	0.01	4.53	2.35	2	16	5	95	0.00	0.0	7.530	0.051	0	0	0	1
PL.23949	PL.23945	B	6 A (CWC)	7.23Y	120.5	0.00	4.53	2.35	2	16	5	95	0.00	0.0	7.570	0.040	16	5	1	1
PL.23944	PL.23384	B	#4 ACSR	7.23Y	120.5	0.00	4.52	0.00	0	0	0	100	0.00	0.0	7.504	0.026	0	0	0	0
PL.24341	PL.23384	B	6 A (CWC)	7.23Y	120.5	0.01	4.53	4.58	3	32	9	96	0.00	0.0	7.524	0.045	0	0	0	7
PL.24342	PL.24341	B	6 A (CWC)	7.23Y	120.5	0.01	4.54	4.58	3	32	9	96	0.00	0.0	7.578	0.055	12	3	1	7
PL.24340	PL.24342	B	6 A (CWC)	7.23Y	120.5	0.00	4.55	2.89	2	20	6	96	0.00	0.0	7.612	0.034	7	2	1	6
PL.23948	PL.24340	B	#4 ACSR	7.23Y	120.5	0.00	4.55	0.13	0	1	0	100	0.00	0.0	7.660	0.048	1	0	1	1
PL.23946	PL.24340	B	6 A (CWC)	7.23Y	120.5	0.00	4.55	0.14	0	1	0	100	0.00	0.0	7.642	0.029	1	0	1	1
PL.23947	PL.24340	B	#1/0 ACSR	7.23Y	120.5	0.00	4.55	1.59	1	11	3	96	0.00	0.0	7.660	0.048	11	3	3	3
PL.23385	PL.23384	B	6 A (CWC)	7.22Y	120.4	0.11	4.63	41.93	30	292	83	96	0.24	0.1	7.534	0.055	1	0	1	62
PL.24336	PL.23385	B	6 A (CWC)	7.22Y	120.3	0.09	4.72	41.84	30	291	82	96	0.20	0.1	7.581	0.047	0	0	1	61
PL.24337	PL.24336	B	6 A (CWC)	7.20Y	120.0	0.27	4.99	41.83	30	290	82	96	0.58	0.2	7.722	0.141	11	3	2	60
PL.23950	PL.24337	B	6 A (CWC)	7.20Y	120.0	0.05	5.03	39.13	28	271	77	96	0.10	0.0	7.749	0.027	8	2	3	56
PL.24334	PL.23950	B	6 A (CWC)	7.19Y	119.9	0.12	5.15	37.92	27	263	74	96	0.23	0.1	7.818	0.069	19	5	2	53
PL.24335	PL.24334	B	6 A (CWC)	7.18Y	119.7	0.16	5.31	35.10	25	243	69	96	0.30	0.1	7.917	0.099	0	0	0	51
PL.24457	PL.24335	B	6 A (CWC)	7.18Y	119.7	0.00	5.31	7.61	5	53	15	96	0.00	0.0	7.922	0.005	0	0	0	11
PD.3423	PL.24457	B	15T	7.18Y	119.7	0.00	5.31	7.61	0	53	15	96	0.00	0.0	7.922	0.005	0	0	0	11
PL.24458	PD.3423	B	6 A (CWC)	7.18Y	119.7	0.03	5.34	7.61	5	53	15	96	0.01	0.0	8.000	0.078	0	0	0	11
PL.24197	PL.24458	B	6 A (CWC)	7.18Y	119.6	0.04	5.38	7.61	5	53	15	96	0.02	0.0	8.109	0.109	0	0	0	11
PL.24196	PL.24197	B	6 A (CWC)	7.18Y	119.6	0.01	5.39	7.61	5	53	15	96	0.00	0.0	8.141	0.031	0	0	0	11
PL.23954	PL.24196	B	6 A (CWC)	7.18Y	119.6	0.03	5.41	7.61	5	53	15	96	0.01	0.0	8.215	0.074	0	0	0	11
PL.24332	PL.23954	B	#4 ACSR	7.17Y	119.6	0.01	5.42	7.61	6	53	15	96	0.00	0.0	8.231	0.016	4	1	1	11
PL.24333	PL.24332	B	#4 ACSR	7.17Y	119.6	0.02	5.44	6.97	5	48	13	97	0.01	0.0	8.311	0.080	0	0	0	10
PL.24330	PL.24333	B	#4 ACSR	7.17Y	119.5	0.02	5.46	6.97	5	48	13	97	0.01	0.0	8.377	0.066	0	0	1	10
PL.24331	PL.24330	B	#4 ACSR	7.17Y	119.5	0.01	5.47	6.97	5	48	13	97	0.00	0.0	8.399	0.023	0	0	0	9
PL.23390	PL.24331	B	#4 ACSR	7.17Y	119.5	0.01	5.48	6.97	5	48	13	97	0.00	0.0	8.440	0.040	7	2	1	9
PL.24328	PL.23390	B	#2 ACSR	7.17Y	119.5	0.00	5.49	3.36	2	23	6	97	0.00	0.0	8.485	0.046	4	1	1	5
PL.24329	PL.24328	B	#2 ACSR	7.17Y	119.5	0.00	5.49	2.72	2	19	5	97	0.00	0.0	8.529	0.044	2	1	1	4
PL.23958	PL.24329	B	#4 ACSR	7.17Y	119.5	0.00	5.49	2.46	2	17	5	96	0.00	0.0	8.543	0.014	0	0	0	3
PL.23960	PL.23958	B	#4 ACSR	7.17Y	119.5	0.00	5.49	1.25	1	9	2	98	0.00	0.0	8.600	0.056	9	2	1	1
PL.23959	PL.23958	B	#4 ACSR	7.17Y	119.5	0.00	5.49	1.21	1	8	2	97	0.00	0.0	8.581	0.037	8	2	2	2

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Millers Creek

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.23389	PL.23390	B	#4 ACSR	7.17Y	119.5	0.01	5.49	2.54	2	18	5	96	0.00	0.0	8.497	0.058	0	0	0	3
PL.23956	PL.23389	B	#4 ACSR	7.17Y	119.5	0.00	5.49	0.71	1	5	1	98	0.00	0.0	8.532	0.035	0	0	0	1
PL.23957	PL.23956	B	#4 ACSR	7.17Y	119.5	0.00	5.49	0.71	1	5	1	98	0.00	0.0	8.675	0.143	0	0	0	1
PL.24198	PL.23957	B	#4 ACSR	7.17Y	119.5	0.00	5.50	0.71	1	5	1	98	0.00	0.0	8.806	0.131	0	0	0	1
PL.24199	PL.24198	B	#4 ACSR	7.17Y	119.5	0.00	5.50	0.71	1	5	1	98	0.00	0.0	8.911	0.105	5	1	1	1
PL.23392	PL.23389	B	#4 ACSR	7.17Y	119.5	0.00	5.49	1.83	1	13	4	96	0.00	0.0	8.539	0.041	0	0	0	2
PL.23391	PL.23392	B	#4 ACSR	7.17Y	119.5	0.01	5.50	1.77	1	12	3	97	0.00	0.0	8.680	0.141	12	3	1	1
PL.23955	PL.23392	B	#4 ACSR	7.17Y	119.5	0.00	5.49	0.06	0	0	0	100	0.00	0.0	8.579	0.041	0	0	1	1
PL.72559	PL.24335	B	#1/0 ACSR	7.18Y	119.7	0.00	5.31	27.49	12	190	54	96	0.00	0.0	7.921	0.004	0	0	0	40
PD.10802	PL.72559	B	50L	7.18Y	119.7	0.00	5.31	27.49	55	190	54	96	0.00	0.0	7.921	0.004	0	0	0	40
PL.72558	PD.10802	B	#1/0 ACSR	7.18Y	119.7	0.03	5.34	27.49	12	190	54	96	0.04	0.0	7.970	0.049	0	0	0	40
PL.23952	PL.72558	B	#1/0 ACSR	7.18Y	119.6	0.03	5.38	27.49	12	190	54	96	0.04	0.0	8.022	0.052	1	0	1	40
PL.23951	PL.23952	B	#4 ACSR	7.17Y	119.6	0.07	5.45	27.29	21	189	53	96	0.10	0.1	8.080	0.058	0	0	1	39
PL.23381	PL.23951	B	#4 ACSR	7.17Y	119.6	0.00	5.45	1.24	1	9	2	98	0.00	0.0	8.119	0.039	9	2	2	2
PL.24249	PL.23951	B	#4 ACSR	7.17Y	119.5	0.08	5.53	26.01	20	180	51	96	0.11	0.1	8.153	0.073	10	3	3	36
PL.24250	PL.24249	B	#4 ACSR	7.16Y	119.4	0.06	5.59	24.54	19	169	48	96	0.08	0.0	8.212	0.059	5	1	1	33
PL.24251	PL.24250	B	#4 ACSR	7.16Y	119.3	0.11	5.71	22.11	17	153	43	96	0.13	0.1	8.327	0.114	0	0	1	29
PL.24252	PL.24251	B	#4 ACSR	7.16Y	119.3	0.03	5.74	22.06	17	152	43	96	0.04	0.0	8.358	0.031	0	0	0	28
PL.24108	PL.24252	B	#4 ACSR	7.15Y	119.2	0.07	5.80	20.02	15	138	39	96	0.07	0.1	8.431	0.074	0	0	0	26
PL.23964	PL.24108	B	#4 ACSR	7.15Y	119.1	0.07	5.87	20.02	15	138	39	96	0.07	0.1	8.509	0.077	0	0	0	26
PL.23379	PL.23964	B	#4 ACSR	7.14Y	119.0	0.08	5.96	19.46	15	134	38	96	0.09	0.1	8.610	0.101	10	3	2	25
PL.23966	PL.23379	B	#4 ACSR	7.14Y	119.0	0.01	5.97	3.21	2	22	6	96	0.00	0.0	8.732	0.123	8	2	2	5
PL.23967	PL.23966	B	#4 ACSR	7.14Y	119.0	0.00	5.97	1.01	1	7	2	96	0.00	0.0	8.837	0.105	7	2	2	2
PL.23968	PL.23966	B	#1/0 ACSR	7.14Y	119.0	0.00	5.97	1.02	0	7	2	96	0.00	0.0	8.790	0.057	7	2	1	1
PL.23380	PL.23379	B	#4 ACSR	7.14Y	119.0	0.05	6.00	14.80	11	102	29	96	0.04	0.0	8.683	0.073	0	0	0	18
PL.24253	PL.23380	B	#4 ACSR	7.14Y	119.0	0.04	6.04	14.80	11	102	29	96	0.03	0.0	8.748	0.065	14	4	2	18
PL.24254	PL.24253	B	#4 ACSR	7.14Y	118.9	0.04	6.08	12.83	10	88	25	96	0.03	0.0	8.813	0.065	0	0	0	16
PL.23969	PL.24254	B	#1/0 ACSR	7.14Y	118.9	0.00	6.08	2.17	1	15	4	97	0.00	0.0	8.848	0.035	15	4	2	2
PL.24255	PL.24254	B	#4 ACSR	7.13Y	118.9	0.02	6.11	10.66	8	73	21	96	0.01	0.0	8.865	0.053	1	0	1	14
PL.24256	PL.24255	B	#4 ACSR	7.13Y	118.9	0.02	6.13	10.48	8	72	20	96	0.01	0.0	8.912	0.046	0	0	0	13
PL.24257	PL.24256	B	#4 ACSR	7.13Y	118.9	0.00	6.13	3.54	3	24	7	96	0.00	0.0	8.957	0.045	22	6	2	3

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Millers Creek

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru

PL.24258	PL.24257	B	#4 ACSR	7.13Y	118.9	0.00	6.13	0.33	0	2	1	89	0.00	0.0	9.013	0.056	2	1	1	1
PL.23970	PL.24256	B	#4 ACSR	7.13Y	118.9	0.00	6.13	1.44	1	10	3	96	0.00	0.0	9.024	0.112	10	3	1	1
PL.23971	PL.24256	B	#4 ACSR	7.13Y	118.8	0.02	6.15	5.50	4	38	11	96	0.01	0.0	9.006	0.095	0	0	1	9
PL.23972	PL.23971	B	#4 ACSR	7.13Y	118.8	0.01	6.16	5.50	4	38	11	96	0.00	0.0	9.031	0.025	0	0	0	8
PL.24109	PL.23972	B	#4 ACSR	7.13Y	118.8	0.02	6.18	3.27	3	22	6	96	0.00	0.0	9.159	0.128	0	0	0	6
PL.23027	PL.24109	B	#4 ACSR	7.13Y	118.8	0.02	6.20	3.27	3	22	6	96	0.00	0.0	9.315	0.155	3	1	1	6
PL.23028	PL.23027	B	#4 ACSR	7.13Y	118.8	0.02	6.21	2.83	2	19	5	97	0.00	0.0	9.445	0.130	0	0	0	5
PL.24200	PL.23028	B	#4 ACSR	7.13Y	118.8	0.02	6.24	2.83	2	19	5	97	0.00	0.0	9.622	0.176	0	0	0	5
PL.24201	PL.24200	B	#4 ACSR	7.13Y	118.8	0.01	6.25	2.83	2	19	5	97	0.00	0.0	9.732	0.110	0	0	0	5
PL.23974	PL.24201	B	#4 ACSR	7.12Y	118.7	0.01	6.26	2.83	2	19	5	97	0.00	0.0	9.812	0.080	0	0	0	5
PL.23976	PL.23974	B	#4 ACSR	7.12Y	118.7	0.00	6.26	0.59	0	4	1	97	0.00	0.0	9.874	0.062	4	1	1	1
PL.23975	PL.23974	B	#4 ACSR	7.12Y	118.7	0.00	6.26	0.53	0	4	1	97	0.00	0.0	9.880	0.068	4	1	1	1
PL.24110	PL.23974	B	#4 ACSR	7.12Y	118.7	0.01	6.27	1.71	1	12	3	97	0.00	0.0	9.967	0.154	3	1	1	3
PL.23978	PL.24110	B	#4 ACSR	7.12Y	118.7	0.00	6.27	0.85	1	6	2	95	0.00	0.0	10.094	0.127	6	2	1	1
PL.23979	PL.23978	B	#4 ACSR	7.12Y	118.7	0.00	6.27	0.00	0	0	0	100	0.00	0.0	10.172	0.077	0	0	0	0
PL.23977	PL.24110	B	#4 ACSR	7.12Y	118.7	0.00	6.27	0.46	0	3	1	95	0.00	0.0	10.022	0.055	3	1	1	1
PL.23973	PL.23972	B	#4 ACSR	7.13Y	118.8	0.00	6.16	2.22	2	15	4	97	0.00	0.0	9.095	0.063	15	4	2	2
PL.23965	PL.23964	B	#4 ACSR	7.15Y	119.1	0.00	5.87	0.55	0	4	1	97	0.00	0.0	8.550	0.041	4	1	1	1
PL.23963	PL.24252	B	#4 ACSR	7.16Y	119.3	0.00	5.74	2.04	2	14	4	96	0.00	0.0	8.401	0.043	14	4	2	2
PL.23961	PL.24250	B	#4 ACSR	7.16Y	119.4	0.00	5.59	1.75	1	12	3	97	0.00	0.0	8.226	0.014	0	0	0	3
PL.24107	PL.23961	B	#4 ACSR	7.16Y	119.4	0.00	5.59	0.81	1	6	2	95	0.00	0.0	8.269	0.043	6	2	2	2
PL.23962	PL.23961	B	#4 ACSR	7.16Y	119.4	0.00	5.60	0.94	1	6	2	95	0.00	0.0	8.269	0.043	6	2	1	1
PL.24338	PL.24337	B	6 A (CWC)	7.20Y	120.0	0.00	4.99	1.08	1	8	2	97	0.00	0.0	7.747	0.025	6	2	1	2
PL.24339	PL.24338	B	6 A (CWC)	7.20Y	120.0	0.00	4.99	0.19	0	1	0	100	0.00	0.0	7.809	0.062	1	0	1	1
PL.24105	PL.23940	ABC	336 MCM AC	7.25Y	120.9	0.01	4.09	44.21	9	925	265	96	0.07	0.0	7.312	0.044	0	0	0	191
PL.23382	PL.24105	ABC	336 MCM AC	7.25Y	120.9	0.01	4.11	44.21	9	925	265	96	0.07	0.0	7.354	0.042	7	2	1	191
PL.23980	PL.23382	ABC	336 MCM AC	7.25Y	120.9	0.01	4.12	37.00	7	774	223	96	0.06	0.0	7.404	0.050	0	0	0	156
PL.24513	PL.23980	ABC	336 MCM AC	7.25Y	120.9	0.00	4.12	37.00	7	774	223	96	0.00	0.0	7.407	0.003	0	0	0	156
PD.3451	PL.24513	ABC	70L	7.25Y	120.9	0.00	4.12	37.00	53	774	223	96	0.00	0.0	7.407	0.003	0	0	0	156
PL.24514	PD.3451	ABC	336 MCM AC	7.25Y	120.8	0.04	4.17	37.00	7	774	223	96	0.18	0.0	7.564	0.158	0	0	0	156
PL.24113	PL.24514	ABC	336 MCM AC	7.25Y	120.8	0.03	4.19	36.46	7	762	219	96	0.11	0.0	7.658	0.094	0	0	0	155

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Millers Creek

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru

PL.24114	PL.24113	ABC	336 MCM AC	7.25Y	120.8	0.01	4.20	36.09	7	754	216	96	0.04	0.0	7.698	0.040	0	0	0	154
PL.24115	PL.24114	ABC	336 MCM AC	7.25Y	120.8	0.01	4.22	35.72	7	747	214	96	0.05	0.0	7.743	0.045	0	0	1	153
PL.23993	PL.24115	ABC	336 MCM AC	7.25Y	120.8	0.01	4.23	35.71	7	746	214	96	0.05	0.0	7.791	0.048	0	0	0	152
PL.24290	PL.23993	ABC	#4 ACSR	7.25Y	120.8	0.00	4.23	1.93	1	40	11	96	0.00	0.0	7.814	0.023	0	0	1	7
PL.24489	PL.24290	ABC	#4 ACSR	7.25Y	120.8	0.00	4.23	1.93	1	40	11	96	0.00	0.0	7.818	0.005	0	0	0	6
PD.3440	PL.24489	ABC	20T	7.25Y	120.8	0.00	4.23	1.93	0	40	11	96	0.00	0.0	7.818	0.005	0	0	0	6
PL.24490	PD.3440	ABC	#4 ACSR	7.25Y	120.8	0.00	4.23	1.93	1	40	11	96	0.00	0.0	7.860	0.042	0	0	0	6
PL.24117	PL.24490	ABC	#4 ACSR	7.25Y	120.8	0.00	4.24	1.20	1	25	7	96	0.00	0.0	7.937	0.077	0	0	1	4
PL.24288	PL.24117	ABC	#4 ACSR	7.25Y	120.8	0.00	4.24	1.20	1	25	7	96	0.00	0.0	7.957	0.020	0	0	0	3
PL.24289	PL.24288	ABC	#4 ACSR	7.25Y	120.8	0.00	4.24	1.20	1	25	7	96	0.00	0.0	8.047	0.090	0	0	0	3
PL.23995	PL.24289	ABC	#4 ACSR	7.25Y	120.8	0.00	4.24	0.00	0	0	0	100	0.00	0.0	8.154	0.107	0	0	1	1
PL.23997	PL.24289	A	#4 ACSR	7.25Y	120.8	0.00	4.24	3.61	3	25	7	96	0.00	0.0	8.052	0.005	0	0	0	2
PD.3414	PL.23997	A	12T	7.25Y	120.8	0.00	4.24	3.61	0	25	7	96	0.00	0.0	8.052	0.005	0	0	0	2
PL.24118	PD.3414	A	#4 ACSR	7.25Y	120.8	0.01	4.25	1.92	1	13	4	96	0.00	0.0	8.121	0.069	0	0	0	1
PL.24206	PL.24118	A	#4 ACSR	7.24Y	120.7	0.01	4.25	1.92	1	13	4	96	0.00	0.0	8.268	0.146	13	4	1	1
PL.23996	PD.3414	A	#4 ACSR	7.25Y	120.8	0.00	4.24	1.69	1	12	3	97	0.00	0.0	8.114	0.063	12	3	1	1
PL.24441	PL.24490	B	#1/0 ACSR	7.25Y	120.8	0.00	4.23	2.19	1	15	4	97	0.00	0.0	7.865	0.005	0	0	0	2
PD.3415	PL.24441	B	12T	7.25Y	120.8	0.00	4.23	2.19	0	15	4	97	0.00	0.0	7.865	0.005	0	0	0	2
PL.24442	PD.3415	B	#1/0 ACSR	7.25Y	120.8	0.00	4.23	2.19	1	15	4	97	0.00	0.0	7.887	0.022	15	4	2	2
PL.24309	PL.23993	ABC	336 MCM AC	7.25Y	120.8	0.01	4.24	32.57	6	681	196	96	0.04	0.0	7.833	0.042	0	0	1	141
PL.24310	PL.24309	ABC	336 MCM AC	7.25Y	120.8	0.01	4.25	32.57	6	681	195	96	0.04	0.0	7.875	0.043	1	0	1	140
PL.24119	PL.24310	ABC	336 MCM AC	7.24Y	120.7	0.01	4.26	25.04	5	523	151	96	0.04	0.0	7.949	0.074	10	3	1	109
PL.24324	PL.24119	ABC	336 MCM AC	7.24Y	120.7	0.01	4.27	24.58	5	513	148	96	0.03	0.0	8.016	0.067	5	2	1	108
PL.24325	PL.24324	ABC	336 MCM AC	7.24Y	120.7	0.02	4.30	24.33	5	508	147	96	0.06	0.0	8.135	0.119	0	0	0	107
PL.24006	PL.24325	C	#2 ACSR	7.24Y	120.7	0.00	4.30	1.78	1	12	3	97	0.00	0.0	8.139	0.005	0	0	0	3
PD.3432	PL.24006	C	20T	7.24Y	120.7	0.00	4.30	1.78	0	12	3	97	0.00	0.0	8.139	0.005	0	0	0	3
PL.24005	PD.3432	C	#2 ACSR	7.24Y	120.7	0.00	4.30	0.27	0	2	1	89	0.00	0.0	8.182	0.042	2	1	1	1
PL.24121	PD.3432	C	#2 ACSR	7.24Y	120.7	0.00	4.30	1.50	1	10	3	96	0.00	0.0	8.167	0.028	2	1	1	2
PL.24007	PL.24121	C	6 A (CWC)	7.24Y	120.7	0.00	4.30	1.15	1	8	2	97	0.00	0.0	8.219	0.052	8	2	1	1
PL.24227	PL.24325	ABC	336 MCM AC	7.24Y	120.7	0.01	4.30	23.73	5	495	143	96	0.02	0.0	8.177	0.042	3	1	1	104
PL.24228	PL.24227	ABC	336 MCM AC	7.24Y	120.7	0.03	4.33	22.39	4	467	135	96	0.07	0.0	8.354	0.177	0	0	0	98

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Millers Creek

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.24427	PL.24228	C	#2 ACSR	7.24Y	120.7	0.00	4.33	0.76	0	5	1	98	0.00	0.0	8.359	0.005	0	0	0	1
PD.3407	PL.24427	C	20T	7.24Y	120.7	0.00	4.33	0.76	0	5	1	98	0.00	0.0	8.359	0.005	0	0	0	1
PL.24428	PD.3407	C	#2 ACSR	7.24Y	120.7	0.00	4.33	0.76	0	5	1	98	0.00	0.0	8.374	0.016	0	0	0	1
PL.24268	PL.24428	C	#2 ACSR	7.24Y	120.7	0.00	4.34	0.76	0	5	1	98	0.00	0.0	8.437	0.063	5	1	1	1
PL.23376	PL.24228	ABC	336 MCM AC	7.24Y	120.7	0.01	4.34	22.13	4	462	134	96	0.03	0.0	8.420	0.066	17	5	3	97
PL.24277	PL.23376	ABC	336 MCM AC	7.24Y	120.7	0.00	4.35	18.08	3	377	110	96	0.01	0.0	8.449	0.030	1	0	2	80
PL.24279	PL.24277	ABC	336 MCM AC	7.24Y	120.6	0.01	4.35	18.02	3	376	109	96	0.01	0.0	8.494	0.045	8	2	2	78
PL.24280	PL.24279	ABC	336 MCM AC	7.24Y	120.6	0.01	4.36	17.63	3	368	107	96	0.01	0.0	8.534	0.040	3	1	1	76
PL.24278	PL.24280	ABC	336 MCM AC	7.24Y	120.6	0.01	4.37	17.47	3	364	106	96	0.03	0.0	8.643	0.109	0	0	0	75
PL.24023	PL.24278	C	#2 ACSR	7.24Y	120.6	0.00	4.37	2.11	1	15	4	97	0.00	0.0	8.647	0.005	0	0	0	3
PD.3408	PL.24023	C	20T	7.24Y	120.6	0.00	4.37	2.11	0	15	4	97	0.00	0.0	8.647	0.005	0	0	0	3
PL.24123	PD.3408	C	#2 ACSR	7.24Y	120.6	0.00	4.37	0.15	0	1	0	100	0.00	0.0	8.683	0.036	1	0	1	1
PL.24024	PD.3408	C	#2 ACSR	7.24Y	120.6	0.00	4.38	1.95	1	14	4	96	0.00	0.0	8.689	0.041	14	4	2	2
PL.24025	PL.24278	ABC	336 MCM AC	7.24Y	120.6	0.01	4.39	16.76	3	349	102	96	0.03	0.0	8.756	0.113	0	0	0	72
PL.24207	PL.24025	ABC	336 MCM AC	7.24Y	120.6	0.01	4.40	16.76	3	349	102	96	0.03	0.0	8.863	0.107	0	0	0	72
PL.24477	PL.24207	C	#2 ACSR	7.24Y	120.6	0.00	4.40	6.73	4	47	13	96	0.00	0.0	8.867	0.005	0	0	0	8
PD.3434	PL.24477	C	20T	7.24Y	120.6	0.00	4.40	6.73	0	47	13	96	0.00	0.0	8.867	0.005	0	0	0	8
PL.24478	PD.3434	C	#2 ACSR	7.24Y	120.6	0.01	4.41	6.73	4	47	13	96	0.00	0.0	8.908	0.040	6	2	1	8
PL.24281	PL.24478	C	#2 ACSR	7.24Y	120.6	0.01	4.42	5.89	3	41	12	96	0.00	0.0	8.935	0.028	0	0	0	7
PL.24026	PL.24281	C	#2 ACSR	7.23Y	120.6	0.00	4.42	3.06	2	21	6	96	0.00	0.0	9.001	0.066	21	6	2	2
PL.24125	PL.24281	C	#2 ACSR	7.23Y	120.6	0.00	4.42	2.83	2	20	6	96	0.00	0.0	8.972	0.037	11	3	2	5
PL.24028	PL.24125	C	#2 ACSR	7.23Y	120.6	0.00	4.42	0.00	0	0	0	100	0.00	0.0	9.019	0.047	0	0	0	0
PL.24027	PL.24125	C	#4 ACSR	7.23Y	120.6	0.00	4.42	0.62	0	4	1	97	0.00	0.0	9.031	0.059	4	1	1	1
PL.24029	PL.24125	C	#4 ACSR	7.23Y	120.6	0.00	4.42	0.69	1	5	1	98	0.00	0.0	9.098	0.125	0	0	0	2
PL.24030	PL.24029	C	#4 ACSR	7.23Y	120.6	0.00	4.42	0.01	0	0	0	100	0.00	0.0	9.186	0.089	0	0	1	1
PL.24031	PL.24029	C	#4 ACSR	7.23Y	120.6	0.00	4.43	0.69	1	5	1	98	0.00	0.0	9.184	0.087	0	0	0	1
PL.24208	PL.24031	C	#4 ACSR	7.23Y	120.6	0.00	4.43	0.69	1	5	1	98	0.00	0.0	9.269	0.084	0	0	0	1
PL.24209	PL.24208	C	#4 ACSR	7.23Y	120.6	0.00	4.43	0.69	1	5	1	98	0.00	0.0	9.337	0.068	0	0	0	1
PL.24032	PL.24209	C	#1/0 ACSR	7.23Y	120.6	0.00	4.43	0.69	0	5	1	98	0.00	0.0	9.425	0.088	0	0	0	1
PL.24033	PL.24032	C	#1/0 ACSR	7.23Y	120.6	0.00	4.43	0.69	0	5	1	98	0.00	0.0	9.528	0.103	5	1	1	1
PL.24124	PL.24207	ABC	336 MCM AC	7.24Y	120.6	0.00	4.40	13.98	3	291	85	96	0.00	0.0	8.887	0.025	0	0	0	62

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Millers Creek

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.24433	PL.24124	A	#4 ACSR	7.24Y	120.6	0.00	4.41	5.10	4	36	10	96	0.00	0.0	8.892	0.005	0	0	0	7
PD.3410	PL.24433	A	20T	7.24Y	120.6	0.00	4.41	5.10	0	36	10	96	0.00	0.0	8.892	0.005	0	0	0	7
PL.24434	PD.3410	A	#4 ACSR	7.23Y	120.6	0.01	4.42	5.10	4	36	10	96	0.00	0.0	8.946	0.055	8	2	2	7
PL.24034	PL.24434	A	#4 ACSR	7.23Y	120.6	0.02	4.43	4.01	3	28	8	96	0.00	0.0	9.042	0.096	5	1	1	5
PL.24282	PL.24034	A	#4 ACSR	7.23Y	120.6	0.01	4.44	3.32	3	23	6	97	0.00	0.0	9.135	0.092	7	2	1	4
PL.24283	PL.24282	A	#4 ACSR	7.23Y	120.6	0.00	4.45	2.38	2	17	5	96	0.00	0.0	9.211	0.076	17	5	3	3
PL.24431	PL.24124	ABC	336 MCM AC	7.24Y	120.6	0.00	4.41	12.28	2	256	76	96	0.00	0.0	8.892	0.004	0	0	0	55
PL.24432	PL.24431	ABC	336 MCM AC	7.24Y	120.6	0.01	4.42	12.28	2	256	76	96	0.01	0.0	9.004	0.112	0	0	0	55
PL.24493	PL.24432	ABC	#1/0 ACSR	7.24Y	120.6	0.00	4.42	0.92	0	18	9	89	0.00	0.0	9.009	0.005	0	0	0	1
PD.3442	PL.24493	ABC	20T	7.24Y	120.6	0.00	4.42	0.92	0	18	9	89	0.00	0.0	9.009	0.005	0	0	0	1
PL.24494	PD.3442	ABC	#1/0 ACSR	7.24Y	120.6	0.00	4.42	0.92	0	18	9	89	0.00	0.0	9.022	0.014	18	9	1	1
PL.24495	PL.24432	ABC	336 MCM AC	7.24Y	120.6	0.00	4.42	11.38	2	238	67	96	0.00	0.0	9.008	0.005	0	0	0	54
PL.24496	PL.24495	ABC	336 MCM AC	7.23Y	120.6	0.00	4.42	11.38	2	238	67	96	0.00	0.0	9.046	0.037	0	0	0	54
PL.24435	PL.24496	C	#4 ACSR	7.23Y	120.6	0.00	4.42	1.28	1	9	2	98	0.00	0.0	9.051	0.005	0	0	0	1
PD.3411	PL.24435	C	20T	7.23Y	120.6	0.00	4.42	1.28	0	9	2	98	0.00	0.0	9.051	0.005	0	0	0	1
PL.24436	PD.3411	C	#4 ACSR	7.23Y	120.6	0.00	4.42	1.28	1	9	2	98	0.00	0.0	9.107	0.056	9	2	1	1
PL.24126	PL.24496	ABC	336 MCM AC	7.23Y	120.6	0.00	4.42	10.95	2	229	64	96	0.01	0.0	9.105	0.059	0	0	0	53
PL.24479	PL.24126	C	#4 ACSR	7.23Y	120.6	0.00	4.42	0.36	0	3	1	95	0.00	0.0	9.110	0.005	0	0	0	1
PD.3435	PL.24479	C	20T	7.23Y	120.6	0.00	4.42	0.36	0	3	1	95	0.00	0.0	9.110	0.005	0	0	0	1
PL.24480	PD.3435	C	#4 ACSR	7.23Y	120.6	0.00	4.42	0.36	0	3	1	95	0.00	0.0	9.150	0.040	3	1	1	1
PL.24488	PL.24126	C	#4 ACSR	7.23Y	120.6	0.00	4.42	1.03	1	7	2	96	0.00	0.0	9.110	0.005	0	0	0	1
PD.3439	PL.24488	C	20T	7.23Y	120.6	0.00	4.42	1.03	0	7	2	96	0.00	0.0	9.110	0.005	0	0	0	1
PL.24487	PD.3439	C	#4 ACSR	7.23Y	120.6	0.00	4.43	1.03	1	7	2	96	0.00	0.0	9.212	0.102	7	2	1	1
PL.24127	PL.24126	ABC	336 MCM AC	7.23Y	120.6	0.01	4.43	10.48	2	219	62	96	0.01	0.0	9.180	0.075	0	0	0	51
PL.24284	PL.24127	ABC	336 MCM AC	7.23Y	120.6	0.00	4.43	9.97	2	208	59	96	0.00	0.0	9.238	0.058	3	1	1	49
PL.24285	PL.24284	ABC	336 MCM AC	7.23Y	120.6	0.01	4.44	9.83	2	205	58	96	0.01	0.0	9.339	0.101	0	0	0	48
PL.24035	PL.24285	ABC	336 MCM AC	7.23Y	120.6	0.01	4.45	9.83	2	205	58	96	0.01	0.0	9.417	0.078	0	0	0	48
PL.24128	PL.24035	ABC	336 MCM AC	7.23Y	120.5	0.01	4.45	9.83	2	205	58	96	0.01	0.0	9.501	0.084	0	0	0	47
PL.24481	PL.24128	C	#4 ACSR	7.23Y	120.5	0.00	4.45	0.69	1	5	1	98	0.00	0.0	9.505	0.005	0	0	0	1
PD.3436	PL.24481	C	25T	7.23Y	120.5	0.00	4.45	0.69	0	5	1	98	0.00	0.0	9.505	0.005	0	0	0	1
PL.24482	PD.3436	C	#4 ACSR	7.23Y	120.5	0.00	4.45	0.69	1	5	1	98	0.00	0.0	9.572	0.067	5	1	1	1

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Millers Creek

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.24036	PL.24482	C	#4 ACSR	7.23Y	120.5	0.00	4.45	0.00	0	0	0	100	0.00	0.0	9.640	0.067	0	0	0	0
PL.24245	PL.24128	ABC	336 MCM AC	7.23Y	120.5	0.00	4.45	0.92	0	19	5	97	0.00	0.0	9.533	0.032	0	0	1	6
PL.24246	PL.24245	ABC	336 MCM AC	7.23Y	120.5	0.00	4.45	0.91	0	19	5	97	0.00	0.0	9.578	0.045	1	0	1	5
PL.24229	PL.24246	ABC	336 MCM AC	7.23Y	120.5	0.00	4.45	0.00	0	0	0	100	0.00	0.0	9.650	0.072	0	0	0	0
PL.18961	PL.24229	ABC	336 MCM AC	7.23Y	120.5	0.00	4.45	0.00	0	0	0	100	0.00	0.0	9.655	0.005	0	0	0	0
PD.2824-B	PL.18961	ABC	Open	7.23Y	120.5	0.00	4.45	0.00	0	0	0	100	0.00	0.0	9.655	0.005	0	0	0	0
PL.24375	PL.24246	A	#4 ACSR	7.23Y	120.5	0.00	4.45	2.64	2	18	5	96	0.00	0.0	9.582	0.005	0	0	0	4
PD.3380	PL.24375	A	25T	7.23Y	120.5	0.00	4.45	2.64	0	18	5	96	0.00	0.0	9.582	0.005	0	0	0	4
PL.24376	PD.3380	A	#4 ACSR	7.23Y	120.5	0.00	4.46	2.64	2	18	5	96	0.00	0.0	9.621	0.038	3	1	1	4
PL.24037	PL.24376	A	#4 ACSR	7.23Y	120.5	0.00	4.46	2.25	2	16	4	97	0.00	0.0	9.647	0.026	16	4	3	3
PL.24377	PL.24128	A	6 A (CWC)	7.23Y	120.5	0.01	4.46	26.04	19	181	51	96	0.01	0.0	9.505	0.004	0	0	0	40
PD.3381	PL.24377	A	25T	7.23Y	120.5	0.00	4.46	26.04	0	181	51	96	0.00	0.0	9.505	0.004	0	0	0	40
PL.24378	PD.3381	A	6 A (CWC)	7.23Y	120.5	0.03	4.49	26.04	19	181	51	96	0.05	0.0	9.534	0.028	1	0	1	40
PL.24038	PL.24378	A	6 A (CWC)	7.23Y	120.5	0.03	4.53	25.90	19	180	51	96	0.05	0.0	9.563	0.029	0	0	1	39
PL.23401	PL.24038	A	6 A (CWC)	7.23Y	120.5	0.01	4.54	2.76	2	19	5	97	0.00	0.0	9.662	0.099	7	2	2	4
PL.23400	PL.23401	A	6 A (CWC)	7.23Y	120.5	0.01	4.54	1.72	1	12	3	97	0.00	0.0	9.747	0.085	5	1	1	2
PL.23398	PL.23400	A	6 A (CWC)	7.23Y	120.5	0.00	4.54	0.99	1	7	2	96	0.00	0.0	9.768	0.021	7	2	1	1
PL.24241	PL.24038	A	6 A (CWC)	7.23Y	120.4	0.04	4.57	23.15	17	161	45	96	0.05	0.0	9.606	0.043	25	7	4	34
PL.24242	PL.24241	A	6 A (CWC)	7.22Y	120.4	0.03	4.60	19.54	14	136	38	96	0.03	0.0	9.641	0.035	0	0	0	30
PL.23399	PL.24242	A	#4 ACSR	7.22Y	120.4	0.02	4.62	5.87	5	41	11	97	0.01	0.0	9.736	0.095	14	4	2	7
PL.24286	PL.23399	A	#4 ACSR	7.22Y	120.4	0.01	4.63	3.81	3	26	7	97	0.00	0.0	9.795	0.059	4	1	1	5
PL.24287	PL.24286	A	#4 ACSR	7.22Y	120.4	0.00	4.64	3.20	2	22	6	96	0.00	0.0	9.829	0.034	2	1	1	4
PL.24226	PL.24287	A	#4 ACSR	7.22Y	120.4	0.00	4.64	1.88	1	13	4	96	0.00	0.0	9.861	0.032	4	1	1	2
PL.24225	PL.24226	A	#4 ACSR	7.22Y	120.4	0.00	4.64	1.29	1	9	3	95	0.00	0.0	9.903	0.043	9	3	1	1
PL.24042	PL.24226	A	#4 ACSR	7.22Y	120.4	0.00	4.64	0.00	0	0	0	100	0.00	0.0	9.906	0.045	0	0	0	0
PL.24041	PL.24287	A	#1/0 ACSR	7.22Y	120.4	0.00	4.64	0.97	0	7	2	96	0.00	0.0	9.847	0.019	7	2	1	1
PL.24039	PL.24242	A	#4 ACSR	7.22Y	120.4	0.00	4.60	1.17	1	8	2	97	0.00	0.0	9.692	0.051	8	2	1	1
PL.24040	PL.24242	A	6 A (CWC)	7.22Y	120.4	0.01	4.61	12.50	9	87	24	96	0.01	0.0	9.665	0.024	3	1	1	22
PL.24243	PL.24040	A	#4 ACSR	7.22Y	120.4	0.02	4.64	12.01	9	84	23	96	0.01	0.0	9.707	0.042	6	2	2	21
PL.24244	PL.24243	A	#4 ACSR	7.22Y	120.3	0.04	4.68	11.11	9	77	22	96	0.02	0.0	9.789	0.082	0	0	0	19
PL.24236	PL.24244	A	#4 ACSR	7.22Y	120.3	0.00	4.68	0.17	0	1	0	100	0.00	0.0	9.852	0.063	0	0	2	3

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Millers Creek

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.24237	PL.24236	A	#4 ACSR	7.22Y	120.3	0.00	4.68	0.16	0	1	0	100	0.00	0.0	9.888	0.036	1	0	1	1
PL.24238	PL.24244	A	#4 ACSR	7.22Y	120.3	0.02	4.70	10.94	8	76	21	96	0.01	0.0	9.835	0.047	0	0	1	16
PL.24239	PL.24238	A	#4 ACSR	7.22Y	120.3	0.03	4.73	10.94	8	76	21	96	0.02	0.0	9.906	0.071	8	2	1	15
PL.24240	PL.24239	A	#4 ACSR	7.22Y	120.3	0.01	4.75	9.78	8	68	19	96	0.01	0.0	9.936	0.030	0	0	0	14
PL.24234	PL.24240	A	#4 ACSR	7.21Y	120.2	0.01	4.76	9.69	7	67	19	96	0.01	0.0	9.963	0.027	8	2	1	13
PL.24235	PL.24234	A	#4 ACSR	7.21Y	120.2	0.01	4.77	8.59	7	60	17	96	0.01	0.0	9.993	0.029	0	0	0	12
PL.24129	PL.24235	A	#4 ACSR	7.21Y	120.2	0.02	4.79	8.59	7	60	17	96	0.01	0.0	10.057	0.064	0	0	0	12
PL.24045	PL.24129	A	#1/0 ACSR	7.21Y	120.2	0.00	4.79	0.77	0	5	1	98	0.00	0.0	10.093	0.036	5	1	1	1
PL.24130	PL.24129	A	#4 ACSR	7.21Y	120.2	0.00	4.80	7.82	6	54	15	96	0.00	0.0	10.070	0.013	0	0	0	11
PL.24232	PL.24130	A	#4 ACSR	7.21Y	120.2	0.02	4.82	7.82	6	54	15	96	0.01	0.0	10.141	0.071	0	0	1	11
PL.24233	PL.24232	A	#4 ACSR	7.21Y	120.2	0.03	4.85	7.82	6	54	15	96	0.01	0.0	10.218	0.077	0	0	0	10
PL.24222	PL.24233	A	#4 ACSR	7.21Y	120.1	0.01	4.86	4.90	4	34	10	96	0.00	0.0	10.272	0.054	4	1	1	7
PL.24223	PL.24222	A	#4 ACSR	7.21Y	120.1	0.01	4.87	3.12	2	22	6	96	0.00	0.0	10.320	0.048	0	0	0	5
PL.23397	PL.24223	A	#1/0 ACSR	7.21Y	120.1	0.00	4.87	3.12	1	22	6	96	0.00	0.0	10.350	0.030	13	4	3	5
PL.24230	PL.23397	A	#1/0 ACSR	7.21Y	120.1	0.00	4.87	1.19	1	8	2	97	0.00	0.0	10.387	0.037	2	1	1	2
PL.24231	PL.24230	A	#1/0 ACSR	7.21Y	120.1	0.00	4.87	0.92	0	6	2	95	0.00	0.0	10.415	0.028	6	2	1	1
PL.24046	PL.24222	A	#4 ACSR	7.21Y	120.1	0.00	4.86	1.13	1	8	2	97	0.00	0.0	10.310	0.039	8	2	1	1
PL.23395	PL.24233	A	#4 ACSR	7.21Y	120.1	0.00	4.85	2.92	2	20	6	96	0.00	0.0	10.239	0.021	0	0	1	3
PL.23396	PL.23395	A	#4 ACSR	7.21Y	120.1	0.01	4.86	2.92	2	20	6	96	0.00	0.0	10.415	0.176	20	6	2	2
PL.24044	PL.24235	A	#4 ACSR	7.21Y	120.2	0.00	4.77	0.00	0	0	0	100	0.00	0.0	10.018	0.025	0	0	0	0
PL.24043	PL.24240	A	#4 ACSR	7.22Y	120.3	0.00	4.75	0.08	0	1	0	100	0.00	0.0	9.976	0.040	1	0	1	1
PL.24439	PL.24035	C	#4 ACSR	7.23Y	120.6	0.00	4.45	0.00	0	0	0	100	0.00	0.0	9.422	0.005	0	0	0	1
PD.3413	PL.24439	C	25T	7.23Y	120.6	0.00	4.45	0.00	0	0	0	100	0.00	0.0	9.422	0.005	0	0	0	1
PL.24440	PD.3413	C	#4 ACSR	7.23Y	120.6	0.00	4.45	0.00	0	0	0	100	0.00	0.0	9.485	0.063	0	0	1	1
PL.24437	PL.24127	C	#4 ACSR	7.23Y	120.6	0.00	4.43	1.54	1	11	3	96	0.00	0.0	9.185	0.005	0	0	0	2
PD.3412	PL.24437	C	25T	7.23Y	120.6	0.00	4.43	1.54	0	11	3	96	0.00	0.0	9.185	0.005	0	0	0	2
PL.24438	PD.3412	C	#4 ACSR	7.23Y	120.6	0.00	4.43	1.54	1	11	3	96	0.00	0.0	9.252	0.067	11	3	2	2
PL.24429	PL.24207	A	#4 ACSR	7.24Y	120.6	0.00	4.40	1.61	1	11	3	96	0.00	0.0	8.867	0.005	0	0	0	2
PD.3409	PL.24429	A	20T	7.24Y	120.6	0.00	4.40	1.61	0	11	3	96	0.00	0.0	8.867	0.005	0	0	0	2
PL.24430	PD.3409	A	#4 ACSR	7.24Y	120.6	0.00	4.40	1.61	1	11	3	96	0.00	0.0	8.895	0.027	11	3	2	2
PL.24475	PL.23376	C	6 A (CWC)	7.24Y	120.7	0.00	4.35	9.72	7	68	19	96	0.00	0.0	8.424	0.005	0	0	0	14

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Millers Creek

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PD.3433	PL.24475	C	20T	7.24Y	120.7	0.00	4.35	9.72	0	68	19	96	0.00	0.0	8.424	0.005	0	0	0	14
PL.24476	PD.3433	C	6 A (CWC)	7.24Y	120.6	0.02	4.37	9.72	7	68	19	96	0.01	0.0	8.468	0.043	0	0	1	14
PL.24275	PL.24476	C	6 A (CWC)	7.24Y	120.6	0.03	4.39	9.69	7	68	19	96	0.01	0.0	8.526	0.058	0	0	1	13
PL.24276	PL.24275	C	6 A (CWC)	7.23Y	120.6	0.03	4.42	9.69	7	68	19	96	0.01	0.0	8.592	0.066	3	1	1	12
PL.24274	PL.24276	C	6 A (CWC)	7.23Y	120.6	0.01	4.43	9.26	7	64	18	96	0.01	0.0	8.627	0.035	7	2	1	11
PL.24273	PL.24274	C	6 A (CWC)	7.23Y	120.6	0.01	4.45	8.22	6	57	16	96	0.01	0.0	8.661	0.034	3	1	1	10
PL.24272	PL.24273	C	6 A (CWC)	7.23Y	120.5	0.02	4.46	7.79	6	54	15	96	0.01	0.0	8.708	0.047	0	0	0	9
PL.24270	PL.24272	C	6 A (CWC)	7.23Y	120.5	0.02	4.48	7.79	6	54	15	96	0.01	0.0	8.758	0.051	16	4	3	9
PL.24271	PL.24270	C	6 A (CWC)	7.23Y	120.5	0.02	4.50	5.54	4	39	11	96	0.01	0.0	8.836	0.078	0	0	0	6
PL.24269	PL.24271	C	6 A (CWC)	7.23Y	120.5	0.02	4.51	5.54	4	39	11	96	0.00	0.0	8.911	0.074	14	4	2	6
PL.23386	PL.24269	C	6 A (CWC)	7.23Y	120.5	0.01	4.52	2.27	2	16	4	97	0.00	0.0	8.978	0.067	0	0	0	2
PL.24012	PL.23386	C	6 A (CWC)	7.23Y	120.5	0.00	4.52	2.27	2	16	4	97	0.00	0.0	9.004	0.027	9	2	1	2
PL.24122	PL.24012	C	#4 ACSR	7.23Y	120.5	0.00	4.52	1.03	1	7	2	96	0.00	0.0	9.024	0.020	0	0	0	1
PL.24011	PL.24122	C	#4 ACSR	7.23Y	120.5	0.00	4.53	1.03	1	7	2	96	0.00	0.0	9.111	0.086	7	2	1	1
PL.24010	PL.24122	C	#4 ACSR	7.23Y	120.5	0.00	4.52	0.00	0	0	0	100	0.00	0.0	9.069	0.044	0	0	0	0
PL.24008	PL.24269	C	#4 ACSR	7.23Y	120.5	0.00	4.51	0.70	1	5	1	98	0.00	0.0	8.934	0.023	5	1	1	1
PL.24009	PL.24269	C	6 A (CWC)	7.23Y	120.5	0.00	4.52	0.63	0	4	1	97	0.00	0.0	8.961	0.050	4	1	1	1
PL.24455	PL.24227	A	6 A (CWC)	7.24Y	120.7	0.00	4.30	3.64	3	25	7	96	0.00	0.0	8.181	0.005	0	0	0	5
PD.3422	PL.24455	A	20T	7.24Y	120.7	0.00	4.30	3.64	0	25	7	96	0.00	0.0	8.181	0.005	0	0	0	5
PL.24456	PD.3422	A	6 A (CWC)	7.24Y	120.7	0.00	4.31	3.64	3	25	7	96	0.00	0.0	8.204	0.023	4	1	1	5
PL.24327	PL.24456	A	6 A (CWC)	7.24Y	120.7	0.01	4.32	3.13	2	22	6	96	0.00	0.0	8.259	0.054	2	1	1	4
PL.24326	PL.24327	A	6 A (CWC)	7.24Y	120.7	0.01	4.32	2.84	2	20	6	96	0.00	0.0	8.394	0.135	20	6	3	3
PL.24453	PL.24310	B	#1/0 ACSR	7.24Y	120.7	0.00	4.25	22.38	10	156	44	96	0.00	0.0	7.880	0.005	0	0	0	30
PD.3421	PL.24453	B	20T	7.24Y	120.7	0.00	4.25	22.38	0	156	44	96	0.00	0.0	7.880	0.005	0	0	0	30
PL.24454	PD.3421	B	#1/0 ACSR	7.24Y	120.7	0.02	4.27	22.38	10	156	44	96	0.02	0.0	7.917	0.037	11	3	1	30
PL.24322	PL.24454	B	#4 ACSR	7.24Y	120.7	0.02	4.29	5.48	4	38	11	96	0.01	0.0	7.988	0.071	0	0	0	4
PL.24323	PL.24322	B	#4 ACSR	7.24Y	120.7	0.01	4.30	5.48	4	38	11	96	0.00	0.0	8.044	0.056	9	2	1	4
PL.23999	PL.24323	B	#4 ACSR	7.24Y	120.7	0.01	4.31	4.21	3	29	8	96	0.00	0.0	8.107	0.063	0	0	0	3
PL.24320	PL.23999	B	#1/0 ACSR	7.24Y	120.7	0.01	4.32	4.21	2	29	8	96	0.00	0.0	8.186	0.079	11	3	1	3
PL.24321	PL.24320	B	#1/0 ACSR	7.24Y	120.7	0.01	4.32	2.66	1	19	5	97	0.00	0.0	8.309	0.123	0	0	0	2
PL.24004	PL.24321	B	#1/0 ACSR	7.24Y	120.7	0.00	4.33	2.66	1	19	5	97	0.00	0.0	8.457	0.148	19	5	2	2

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Millers Creek

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru

PL.23998	PL.24454	B	#2 ACSR	7.24Y	120.7	0.06	4.33	14.87	8	104	29	96	0.04	0.0	8.048	0.131	7	2	1	24
PL.24000	PL.23998	B	#2 ACSR	7.24Y	120.6	0.03	4.36	11.90	7	83	23	96	0.02	0.0	8.140	0.092	7	2	2	21
PL.24318	PL.24000	B	6 A (CWC)	7.24Y	120.6	0.03	4.39	10.92	8	76	21	96	0.02	0.0	8.205	0.065	9	2	4	19
PL.24319	PL.24318	B	6 A (CWC)	7.23Y	120.6	0.03	4.42	9.68	7	67	19	96	0.01	0.0	8.263	0.057	2	0	1	15
PL.24317	PL.24319	B	6 A (CWC)	7.23Y	120.6	0.01	4.43	9.45	7	66	18	96	0.01	0.0	8.295	0.033	4	1	1	14
PL.24345	PL.24317	B	#4 ACSR	7.23Y	120.6	0.00	4.43	1.40	1	10	3	96	0.00	0.0	8.314	0.019	3	1	1	3
PL.24346	PL.24345	B	#4 ACSR	7.23Y	120.6	0.00	4.44	1.03	1	7	2	96	0.00	0.0	8.419	0.104	7	2	2	2
PL.24002	PL.24317	B	6 A (CWC)	7.23Y	120.5	0.05	4.48	7.49	5	52	15	96	0.02	0.0	8.439	0.143	1	0	1	10
PL.24003	PL.24002	B	6 A (CWC)	7.23Y	120.5	0.06	4.54	7.38	5	51	14	96	0.02	0.0	8.629	0.190	2	1	1	9
PL.24013	PL.24003	B	#4 ACSR	7.23Y	120.4	0.02	4.56	7.10	5	49	14	96	0.01	0.0	8.686	0.057	0	0	0	8
PL.24120	PL.24013	B	#4 ACSR	7.23Y	120.4	0.00	4.56	1.26	1	9	2	98	0.00	0.0	8.715	0.029	4	1	2	3
PL.24014	PL.24120	B	#4 ACSR	7.23Y	120.4	0.00	4.57	0.68	1	5	1	98	0.00	0.0	8.878	0.163	5	1	1	1
PL.24314	PL.24013	B	6 A (CWC)	7.23Y	120.4	0.01	4.57	4.02	3	28	8	96	0.00	0.0	8.733	0.047	0	0	0	4
PL.24313	PL.24314	B	6 A (CWC)	7.23Y	120.4	0.01	4.58	4.02	3	28	8	96	0.00	0.0	8.789	0.056	16	4	2	4
PL.24311	PL.24313	B	6 A (CWC)	7.23Y	120.4	0.00	4.58	1.79	1	12	3	97	0.00	0.0	8.824	0.035	6	2	1	2
PL.24312	PL.24311	B	6 A (CWC)	7.23Y	120.4	0.00	4.58	0.94	1	7	2	96	0.00	0.0	8.874	0.050	7	2	1	1
PL.24315	PL.24013	B	#1/0 ACSR	7.23Y	120.4	0.00	4.56	1.81	1	13	4	96	0.00	0.0	8.723	0.037	13	4	1	1
PL.24316	PL.24315	B	#1/0 ACSR	7.23Y	120.4	0.00	4.56	0.00	0	0	0	100	0.00	0.0	8.780	0.057	0	0	0	0
PL.24001	PL.23998	B	6 A (CWC)	7.24Y	120.7	0.00	4.33	2.01	1	14	4	96	0.00	0.0	8.079	0.031	14	4	2	2
PL.23378	PL.24454	B	#1/0 ACSR	7.24Y	120.7	0.00	4.27	0.47	0	3	1	95	0.00	0.0	7.957	0.040	3	1	1	1
PL.24443	PL.23993	A	#4 ACSR	7.25Y	120.8	0.00	4.23	3.60	3	25	7	96	0.00	0.0	7.795	0.005	0	0	0	4
PD.3416	PL.24443	A	20T	7.25Y	120.8	0.00	4.23	3.60	0	25	7	96	0.00	0.0	7.795	0.005	0	0	0	4
PL.24444	PD.3416	A	#4 ACSR	7.25Y	120.8	0.00	4.23	3.60	3	25	7	96	0.00	0.0	7.809	0.014	0	0	0	4
PL.23994	PL.24444	A	6 A (CWC)	7.25Y	120.8	0.00	4.23	3.05	2	21	6	96	0.00	0.0	7.858	0.049	21	6	2	2
PL.24116	PL.24444	A	#4 ACSR	7.25Y	120.8	0.00	4.23	0.55	0	4	1	97	0.00	0.0	7.848	0.038	4	1	2	2
PL.24445	PL.24114	C	#1/0 ACSR	7.25Y	120.8	0.00	4.20	1.09	0	8	2	97	0.00	0.0	7.702	0.005	0	0	0	1
PD.3417	PL.24445	C	20T	7.25Y	120.8	0.00	4.20	1.09	0	8	2	97	0.00	0.0	7.702	0.005	0	0	0	1
PL.24446	PD.3417	C	#1/0 ACSR	7.25Y	120.8	0.00	4.20	1.09	0	8	2	97	0.00	0.0	7.831	0.129	8	2	1	1
PL.24447	PL.24113	C	#2 ACSR	7.25Y	120.8	0.00	4.19	1.10	1	8	2	97	0.00	0.0	7.663	0.005	0	0	0	1
PD.3418	PL.24447	C	20T	7.25Y	120.8	0.00	4.19	1.10	0	8	2	97	0.00	0.0	7.663	0.005	0	0	0	1
PL.24448	PD.3418	C	#2 ACSR	7.25Y	120.8	0.00	4.19	1.10	1	8	2	97	0.00	0.0	7.675	0.012	8	2	1	1

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Millers Creek

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.24449	PL.24514	C	#4 ACSR	7.25Y	120.8	0.00	4.17	1.64	1	11	3	96	0.00	0.0	7.569	0.005	0	0	0	1
PD.3419	PL.24449	C	20T	7.25Y	120.8	0.00	4.17	1.64	0	11	3	96	0.00	0.0	7.569	0.005	0	0	0	1
PL.24450	PD.3419	C	#4 ACSR	7.25Y	120.8	0.00	4.17	1.64	1	11	3	96	0.00	0.0	7.581	0.013	11	3	1	1
PL.23383	PL.23382	ABC	336 MCM AC	7.25Y	120.9	0.00	4.11	6.87	1	144	41	96	0.00	0.0	7.377	0.023	0	0	0	34
PL.24509	PL.23383	A	6 A (CWC)	7.25Y	120.8	0.08	4.19	20.49	15	143	40	96	0.09	0.1	7.462	0.085	0	0	0	32
PD.3449	PL.24509	A	35L	7.25Y	120.8	0.00	4.19	20.49	59	143	40	96	0.00	0.0	7.462	0.085	0	0	0	32
PL.24510	PD.3449	A	6 A (CWC)	7.24Y	120.7	0.07	4.26	20.49	15	143	40	96	0.08	0.1	7.544	0.082	11	3	2	32
PL.23981	PL.24510	A	#4 ACSR	7.24Y	120.7	0.00	4.26	0.00	0	0	0	100	0.00	0.0	7.580	0.036	0	0	0	0
PL.23982	PL.24510	A	6 A (CWC)	7.23Y	120.6	0.16	4.42	18.90	13	132	37	96	0.16	0.1	7.727	0.182	0	0	0	30
PL.24111	PL.23982	A	6 A (CWC)	7.23Y	120.5	0.03	4.45	15.89	11	111	31	96	0.03	0.0	7.770	0.043	0	0	0	26
PL.23388	PL.24111	A	6 A (CWC)	7.23Y	120.5	0.07	4.53	15.62	11	109	31	96	0.06	0.1	7.875	0.105	6	2	2	25
PL.24303	PL.23388	A	6 A (CWC)	7.23Y	120.4	0.05	4.58	12.63	9	88	25	96	0.04	0.0	7.973	0.098	7	2	1	19
PL.24304	PL.24303	A	6 A (CWC)	7.22Y	120.4	0.02	4.60	11.57	8	81	23	96	0.01	0.0	8.005	0.032	0	0	0	18
PL.23984	PL.24304	A	6 A (CWC)	7.22Y	120.3	0.05	4.65	11.57	8	80	23	96	0.03	0.0	8.105	0.100	0	0	0	18
PL.23985	PL.23984	A	#1/0 ACSR	7.22Y	120.3	0.00	4.65	1.16	1	8	2	97	0.00	0.0	8.130	0.025	8	2	1	1
PL.23986	PL.23984	A	#1/0 ACSR	7.22Y	120.3	0.00	4.65	0.91	0	6	2	95	0.00	0.0	8.140	0.035	6	2	1	1
PL.24301	PL.23984	A	6 A (CWC)	7.22Y	120.3	0.02	4.68	9.50	7	66	19	96	0.01	0.0	8.167	0.062	11	3	1	16
PL.24302	PL.24301	A	6 A (CWC)	7.22Y	120.3	0.02	4.70	7.85	6	55	15	96	0.01	0.0	8.236	0.069	5	1	1	15
PL.23988	PL.24302	A	6 A (CWC)	7.21Y	120.2	0.06	4.76	7.15	5	50	14	96	0.02	0.0	8.423	0.187	2	1	1	14
PL.24299	PL.23988	A	6 A (CWC)	7.21Y	120.2	0.01	4.77	6.83	5	47	13	96	0.00	0.0	8.460	0.037	0	0	0	13
PL.24300	PL.24299	A	6 A (CWC)	7.21Y	120.2	0.05	4.82	6.83	5	47	13	96	0.02	0.0	8.609	0.149	3	1	1	13
PL.23989	PL.24300	A	#4 ACSR	7.21Y	120.2	0.01	4.82	2.28	2	16	4	97	0.00	0.0	8.682	0.073	0	0	0	2
PL.24112	PL.23989	A	#4 ACSR	7.21Y	120.2	0.00	4.82	0.06	0	0	0	100	0.00	0.0	8.791	0.108	0	0	1	1
PL.23991	PL.23989	A	#4 ACSR	7.21Y	120.2	0.00	4.82	2.21	2	15	4	97	0.00	0.0	8.712	0.030	15	4	1	1
PL.24295	PL.24300	A	6 A (CWC)	7.21Y	120.2	0.02	4.83	3.24	2	23	6	97	0.00	0.0	8.715	0.106	0	0	0	7
PL.24296	PL.24295	A	6 A (CWC)	7.21Y	120.2	0.01	4.84	3.24	2	22	6	96	0.00	0.0	8.774	0.059	0	0	0	7
PL.23393	PL.24296	A	6 A (CWC)	7.21Y	120.1	0.02	4.86	3.24	2	22	6	96	0.00	0.0	8.938	0.165	0	0	1	7
PL.24022	PL.23393	A	#4 ACSR	7.21Y	120.1	0.01	4.88	2.04	2	14	4	96	0.00	0.0	9.101	0.162	0	0	0	3
PL.24203	PL.24022	A	#4 ACSR	7.21Y	120.1	0.01	4.89	2.04	2	14	4	96	0.00	0.0	9.237	0.137	0	0	0	3
PL.24016	PL.24203	A	#4 ACSR	7.21Y	120.1	0.01	4.91	2.04	2	14	4	96	0.00	0.0	9.385	0.147	0	0	0	3
PL.24204	PL.24016	A	#4 ACSR	7.21Y	120.1	0.01	4.92	2.04	2	14	4	96	0.00	0.0	9.494	0.109	0	0	0	3

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Millers Creek

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru

PL.24015	PL.24204	A	#4 ACSR	7.20Y	120.1	0.01	4.93	2.04	2	14	4	96	0.00	0.0	9.607	0.113	0	0	0	3
PL.24017	PL.24015	A	#4 ACSR	7.20Y	120.1	0.02	4.94	2.04	2	14	4	96	0.00	0.0	9.781	0.174	0	0	0	3
PL.24205	PL.24017	A	#4 ACSR	7.20Y	120.0	0.01	4.95	2.04	2	14	4	96	0.00	0.0	9.897	0.117	0	0	0	3
PL.24293	PL.24205	A	#4 ACSR	7.20Y	120.0	0.00	4.96	2.04	2	14	4	96	0.00	0.0	9.956	0.059	7	2	1	3
PL.24294	PL.24293	A	#4 ACSR	7.20Y	120.0	0.00	4.96	1.01	1	7	2	96	0.00	0.0	10.032	0.076	7	2	2	2
PL.23394	PL.23393	A	6 A (CWC)	7.21Y	120.1	0.00	4.87	1.19	1	8	2	97	0.00	0.0	9.007	0.069	0	0	0	3
PL.24021	PL.23394	A	#4 ACSR	7.21Y	120.1	0.00	4.87	1.19	1	8	2	97	0.00	0.0	9.027	0.019	0	0	0	3
PL.24018	PL.24021	A	#4 ACSR	7.21Y	120.1	0.01	4.87	1.19	1	8	2	97	0.00	0.0	9.135	0.108	2	1	1	3
PL.24291	PL.24018	A	#4 ACSR	7.21Y	120.1	0.00	4.88	0.92	1	6	2	95	0.00	0.0	9.259	0.124	1	0	1	2
PL.24292	PL.24291	A	#4 ACSR	7.21Y	120.1	0.00	4.88	0.73	1	5	1	98	0.00	0.0	9.412	0.154	0	0	0	1
PL.24019	PL.24292	A	#4 ACSR	7.21Y	120.1	0.00	4.89	0.73	1	5	1	98	0.00	0.0	9.523	0.111	0	0	0	1
PL.24020	PL.24019	A	#4 ACSR	7.21Y	120.1	0.00	4.89	0.73	1	5	1	98	0.00	0.0	9.576	0.053	5	1	1	1
PL.23990	PL.24300	A	#4 ACSR	7.21Y	120.2	0.01	4.82	0.92	1	6	2	95	0.00	0.0	8.742	0.133	0	0	0	3
PL.24202	PL.23990	A	#4 ACSR	7.21Y	120.2	0.00	4.82	0.92	1	6	2	95	0.00	0.0	8.820	0.078	5	1	1	3
PL.23992	PL.24202	A	#4 ACSR	7.21Y	120.2	0.00	4.82	0.18	0	1	0	100	0.00	0.0	8.912	0.092	0	0	0	2
PL.24297	PL.23992	A	#4 ACSR	7.21Y	120.2	0.00	4.82	0.18	0	1	0	100	0.00	0.0	9.075	0.163	1	0	1	2
PL.24298	PL.24297	A	#4 ACSR	7.21Y	120.2	0.00	4.82	0.08	0	1	0	100	0.00	0.0	9.220	0.146	1	0	1	1
PL.23987	PL.24302	A	6 A (CWC)	7.22Y	120.3	0.00	4.70	0.00	0	0	0	100	0.00	0.0	8.317	0.081	0	0	0	0
PL.24305	PL.23388	A	#2 ACSR	7.23Y	120.5	0.00	4.53	2.16	1	15	4	97	0.00	0.0	7.888	0.013	7	2	1	4
PL.24306	PL.24305	A	#2 ACSR	7.23Y	120.5	0.00	4.53	1.10	1	8	2	97	0.00	0.0	7.943	0.056	8	2	3	3
PL.23983	PL.24111	A	#1/0 ACSR	7.23Y	120.5	0.00	4.45	0.27	0	2	1	89	0.00	0.0	7.804	0.034	2	1	1	1
PL.24307	PL.23982	A	#4 ACSR	7.23Y	120.6	0.00	4.42	3.00	2	21	6	96	0.00	0.0	7.738	0.011	0	0	0	4
PL.24308	PL.24307	A	#4 ACSR	7.23Y	120.6	0.00	4.43	3.00	2	21	6	96	0.00	0.0	7.778	0.040	21	6	4	4
PL.24451	PL.23383	A	#2 ACSR	7.25Y	120.9	0.00	4.11	0.13	0	1	0	100	0.00	0.0	7.381	0.005	0	0	0	2
PD.3420	PL.24451	A	50T	7.25Y	120.9	0.00	4.11	0.13	0	1	0	100	0.00	0.0	7.381	0.005	0	0	0	2
PL.24452	PD.3420	A	#2 ACSR	7.25Y	120.9	0.00	4.11	0.13	0	1	0	100	0.00	0.0	7.416	0.035	1	0	2	2
PL.24379	PL.24186	A	#1/0 ACSR	7.29Y	121.5	0.00	3.46	0.29	0	2	1	89	0.00	0.0	5.950	0.005	0	0	0	2
PD.3382	PL.24379	A	50T	7.29Y	121.5	0.00	3.46	0.29	0	2	1	89	0.00	0.0	5.950	0.005	0	0	0	2
PL.24380	PD.3382	A	#1/0 ACSR	7.29Y	121.5	0.00	3.46	0.29	0	2	1	89	0.00	0.0	5.985	0.035	0	0	1	2
PL.23927	PL.24380	A	6 A (CWC)	7.29Y	121.5	0.00	3.46	0.24	0	2	0	100	0.00	0.0	6.080	0.095	0	0	0	1
PL.24187	PL.23927	A	6 A (CWC)	7.29Y	121.5	0.00	3.46	0.24	0	2	0	100	0.00	0.0	6.175	0.095	0	0	0	1

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Millers Creek

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.23928	PL.24187	A	6 A (CWC)	7.29Y	121.5	0.00	3.46	0.24	0	2	0	100	0.00	0.0	6.342	0.167	2	0	1	1
PL.24505	PL.24095	C	#1/0 ACSR	7.30Y	121.7	0.00	3.27	20.24	9	142	40	96	0.00	0.0	5.551	0.003	0	0	0	67
PD.3447	PL.24505	C	70L	7.30Y	121.7	0.00	3.27	20.24	29	142	40	96	0.00	0.0	5.551	0.003	0	0	0	67
PL.24506	PD.3447	C	#1/0 ACSR	7.30Y	121.7	0.01	3.29	20.24	9	142	40	96	0.01	0.0	5.578	0.027	2	1	2	67
PL.23923	PL.24506	C	#1/0 ACSR	7.30Y	121.7	0.04	3.32	19.92	9	140	40	96	0.03	0.0	5.654	0.076	0	0	0	65
PL.23929	PL.23923	C	#1/0 ACSR	7.30Y	121.7	0.01	3.33	19.92	9	140	40	96	0.01	0.0	5.676	0.023	0	0	0	65
PL.23930	PL.23929	C	#1/0 ACSR	7.30Y	121.6	0.07	3.40	19.68	9	138	39	96	0.06	0.0	5.831	0.155	0	0	0	63
PL.24159	PL.23930	C	#1/0 ACSR	7.29Y	121.5	0.08	3.48	19.68	9	138	39	96	0.07	0.1	5.997	0.166	0	0	0	63
PL.24160	PL.24159	C	#1/0 ACSR	7.29Y	121.5	0.05	3.53	19.68	9	138	39	96	0.05	0.0	6.118	0.121	3	1	1	63
PL.23931	PL.24160	C	#1/0 ACSR	7.29Y	121.4	0.05	3.58	18.02	8	126	36	96	0.04	0.0	6.227	0.109	0	0	0	60
PL.24161	PL.23931	C	#1/0 ACSR	7.28Y	121.4	0.07	3.65	18.02	8	126	36	96	0.06	0.0	6.387	0.160	0	0	0	60
PL.23934	PL.24161	C	#1/0 ACSR	7.28Y	121.3	0.05	3.69	18.00	8	126	36	96	0.04	0.0	6.496	0.109	0	0	0	59
PL.23351	PL.23934	C	6 A (CWC)	7.27Y	121.2	0.06	3.76	18.00	13	126	36	96	0.06	0.0	6.575	0.078	0	0	0	59
PL.24096	PL.23351	C	6 A (CWC)	7.27Y	121.2	0.07	3.83	18.00	13	126	36	96	0.07	0.1	6.659	0.085	0	0	0	59
PL.23355	PL.24096	C	6 A (CWC)	7.27Y	121.1	0.07	3.90	18.00	13	126	36	96	0.07	0.1	6.747	0.088	0	0	0	59
PL.24164	PL.23355	C	6 A (CWC)	7.26Y	121.0	0.09	3.99	18.00	13	126	36	96	0.08	0.1	6.852	0.105	0	0	0	59
PL.24499	PL.24164	C	6 A (CWC)	7.26Y	121.0	0.00	3.99	18.00	13	126	35	96	0.00	0.0	6.857	0.005	0	0	0	59
PD.3444-A	PL.24499	C	Closed	7.26Y	121.0	0.00	3.99	18.00	0	126	35	96	0.00	0.0	6.857	0.005	0	0	0	59
PD.3444-B	PD.3444-A	C	Closed	7.26Y	121.0	0.00	3.99	18.00	0	126	35	96	0.00	0.0	6.857	0.005	0	0	0	59
PL.24500	PD.3444-B	C	6 A (CWC)	7.25Y	120.9	0.11	4.10	18.00	13	126	35	96	0.11	0.1	6.993	0.136	0	0	0	59
PL.24097	PL.24500	C	6 A (CWC)	7.25Y	120.9	0.05	4.15	18.00	13	126	35	96	0.04	0.0	7.048	0.055	0	0	0	59
PL.23017	PL.24097	C	6 A (CWC)	7.25Y	120.8	0.06	4.21	18.00	13	126	35	96	0.06	0.0	7.128	0.080	4	1	1	59
PL.23018	PL.23017	C	6 A (CWC)	7.24Y	120.7	0.06	4.28	17.46	12	122	34	96	0.06	0.0	7.206	0.078	0	0	0	58
PL.24224	PL.23018	C	6 A (CWC)	7.24Y	120.6	0.09	4.37	17.31	12	121	34	96	0.08	0.1	7.321	0.114	0	0	1	56
PL.24503	PL.24224	C	6 A (CWC)	7.24Y	120.6	0.00	4.37	3.75	3	26	7	97	0.00	0.0	7.325	0.005	0	0	0	19
PD.3446-A	PL.24503	C	Closed	7.24Y	120.6	0.00	4.37	3.75	0	26	7	97	0.00	0.0	7.325	0.005	0	0	0	19
PD.3446-B	PD.3446-A	C	Closed	7.24Y	120.6	0.00	4.37	3.75	0	26	7	97	0.00	0.0	7.325	0.005	0	0	0	19
PL.24504	PD.3446-B	C	6 A (CWC)	7.24Y	120.6	0.02	4.38	3.75	3	26	7	97	0.00	0.0	7.448	0.123	8	2	2	19
PL.24221	PL.24504	C	6 A (CWC)	7.24Y	120.6	0.01	4.40	2.66	2	19	5	97	0.00	0.0	7.540	0.092	0	0	0	17
PL.24511	PL.24221	C	6 A (CWC)	7.24Y	120.6	0.00	4.40	2.31	2	16	5	95	0.00	0.0	7.543	0.003	0	0	0	15
PD.3450	PL.24511	C	100CodeSMo	7.24Y	120.6	0.00	4.40	2.31	0	16	5	95	0.00	0.0	7.543	0.003	0	0	0	15

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Millers Creek

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.24512	PD.3450	C	6 A (CWC)	7.24Y	120.6	0.01	4.41	2.31	2	16	5	95	0.00	0.0	7.645	0.102	0	0	0	15
PL.24212	PL.24512	C	6 A (CWC)	7.23Y	120.6	0.01	4.42	2.31	2	16	5	95	0.00	0.0	7.748	0.103	0	0	0	15
PL.24165	PL.24212	C	6 A (CWC)	7.23Y	120.6	0.01	4.43	2.31	2	16	5	95	0.00	0.0	7.843	0.095	0	0	0	15
PL.24211	PL.24165	C	6 A (CWC)	7.23Y	120.6	0.01	4.44	2.31	2	16	5	95	0.00	0.0	7.959	0.116	0	0	0	15
PL.24166	PL.24211	C	6 A (CWC)	7.23Y	120.5	0.02	4.46	2.31	2	16	5	95	0.00	0.0	8.140	0.181	0	0	0	15
PL.24049	PL.24166	C	#4 ACSR	7.23Y	120.5	0.00	4.46	2.31	2	16	5	95	0.00	0.0	8.157	0.017	0	0	0	15
PL.24050	PL.24049	C	#4 ACSR	7.23Y	120.5	0.01	4.47	1.61	1	11	3	96	0.00	0.0	8.317	0.160	0	0	0	13
PL.24168	PL.24050	C	#4 ACSR	7.23Y	120.5	0.01	4.48	1.61	1	11	3	96	0.00	0.0	8.405	0.088	0	0	0	13
PL.24099	PL.24168	C	#4 ACSR	7.23Y	120.5	0.01	4.49	1.61	1	11	3	96	0.00	0.0	8.564	0.159	0	0	0	13
PL.24169	PL.24099	C	#4 ACSR	7.23Y	120.5	0.01	4.50	1.61	1	11	3	96	0.00	0.0	8.737	0.173	0	0	0	13
PL.24359	PL.24169	C	#4 ACSR	7.23Y	120.5	0.00	4.51	1.61	1	11	3	96	0.00	0.0	8.770	0.033	0	0	1	13
PL.24360	PL.24359	C	#4 ACSR	7.23Y	120.5	0.01	4.51	1.61	1	11	3	96	0.00	0.0	8.876	0.106	0	0	0	12
PL.24213	PL.24360	C	#4 ACSR	7.23Y	120.5	0.01	4.52	1.61	1	11	3	96	0.00	0.0	8.970	0.094	0	0	0	12
PL.24170	PL.24213	C	#4 ACSR	7.23Y	120.5	0.01	4.53	1.61	1	11	3	96	0.00	0.0	9.139	0.169	0	0	0	12
PL.24357	PL.24170	C	#4 ACSR	7.23Y	120.5	0.01	4.54	1.61	1	11	3	96	0.00	0.0	9.285	0.146	0	0	1	12
PL.24358	PL.24357	C	#4 ACSR	7.23Y	120.4	0.01	4.55	1.61	1	11	3	96	0.00	0.0	9.445	0.160	0	0	0	11
PL.24171	PL.24358	C	#4 ACSR	7.23Y	120.4	0.01	4.56	1.61	1	11	3	96	0.00	0.0	9.552	0.107	0	0	0	11
PL.24172	PL.24171	C	#4 ACSR	7.23Y	120.4	0.01	4.57	1.61	1	11	3	96	0.00	0.0	9.661	0.110	0	0	0	11
PL.24355	PL.24172	C	#4 ACSR	7.23Y	120.4	0.01	4.58	1.61	1	11	3	96	0.00	0.0	9.824	0.163	0	0	1	11
PL.24356	PL.24355	C	#4 ACSR	7.22Y	120.4	0.01	4.59	1.61	1	11	3	96	0.00	0.0	9.914	0.090	0	0	0	10
PL.23377	PL.24356	C	#4 ACSR	7.22Y	120.4	0.00	4.59	1.28	1	9	2	98	0.00	0.0	9.931	0.017	0	0	0	9
PL.24052	PL.23377	C	#4 ACSR	7.22Y	120.4	0.00	4.59	0.01	0	0	0	100	0.00	0.0	9.977	0.046	0	0	1	1
PL.24353	PL.24052	C	#4 ACSR	7.22Y	120.4	0.00	4.59	1.27	1	9	2	98	0.00	0.0	10.016	0.085	0	0	1	8
PL.24354	PL.24353	C	#4 ACSR	7.22Y	120.4	0.00	4.60	1.21	1	8	2	97	0.00	0.0	10.104	0.087	2	0	1	7
PL.24351	PL.24354	C	#4 ACSR	7.22Y	120.4	0.01	4.60	0.96	1	7	2	96	0.00	0.0	10.262	0.158	0	0	1	6
PL.24352	PL.24351	C	#4 ACSR	7.22Y	120.4	0.00	4.61	0.95	1	7	2	96	0.00	0.0	10.372	0.110	3	1	1	5
PL.24350	PL.24352	C	#4 ACSR	7.22Y	120.4	0.00	4.61	0.51	0	4	1	97	0.00	0.0	10.448	0.076	1	0	1	4
PL.24349	PL.24350	C	#4 ACSR	7.22Y	120.4	0.00	4.61	0.41	0	3	1	95	0.00	0.0	10.554	0.106	0	0	1	3
PL.24347	PL.24349	C	#4 ACSR	7.22Y	120.4	0.00	4.61	0.40	0	3	1	95	0.00	0.0	10.644	0.090	3	1	1	2
PL.24348	PL.24347	C	#4 ACSR	7.22Y	120.4	0.00	4.61	0.01	0	0	0	100	0.00	0.0	10.762	0.118	0	0	1	1
PL.24051	PL.24348	C	#4 ACSR	7.22Y	120.4	0.00	4.61	0.01	0	0	0	100	0.00	0.0	10.762	0.118	0	0	1	1
PL.24051	PL.24356	C	#4 ACSR	7.22Y	120.4	0.00	4.59	0.33	0	2	1	89	0.00	0.0	10.060	0.146	0	0	0	1

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Millers Creek

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.24173	PL.24051	C	#4 ACSR	7.22Y	120.4	0.00	4.59	0.33	0	2	1	89	0.00	0.0	10.173	0.113	2	1	1	1
PL.24461	PL.24168	C	6 A (CWC)	7.23Y	120.5	0.00	4.48	0.00	0	0	0	100	0.00	0.0	8.410	0.005	0	0	0	0
PD.3425	PL.24461	C	10T	7.23Y	120.5	0.00	4.48	0.00	0	0	0	100	0.00	0.0	8.410	0.005	0	0	0	0
PL.24462	PD.3425	C	6 A (CWC)	7.23Y	120.5	0.00	4.48	0.00	0	0	0	100	0.00	0.0	8.537	0.127	0	0	0	0
PL.24463	PL.24049	C	6 A (CWC)	7.23Y	120.5	0.00	4.46	0.70	0	5	1	98	0.00	0.0	8.161	0.005	0	0	0	2
PD.3426	PL.24463	C	10T	7.23Y	120.5	0.00	4.46	0.70	0	5	1	98	0.00	0.0	8.161	0.005	0	0	0	2
PL.24464	PD.3426	C	6 A (CWC)	7.23Y	120.5	0.00	4.46	0.70	0	5	1	98	0.00	0.0	8.196	0.034	3	1	1	2
PL.24361	PL.24464	C	6 A (CWC)	7.23Y	120.5	0.00	4.46	0.32	0	2	1	89	0.00	0.0	8.301	0.106	0	0	0	1
PL.24167	PL.24361	C	6 A (CWC)	7.23Y	120.5	0.00	4.47	0.32	0	2	1	89	0.00	0.0	8.430	0.128	0	0	0	1
PL.24065	PL.24167	C	#4 ACSR	7.23Y	120.5	0.00	4.47	0.32	0	2	1	89	0.00	0.0	8.442	0.012	0	0	0	1
PL.24064	PL.24065	C	#4 ACSR	7.23Y	120.5	0.00	4.47	0.32	0	2	1	89	0.00	0.0	8.536	0.094	0	0	0	1
PL.24063	PL.24064	C	#4 ACSR	7.23Y	120.5	0.00	4.47	0.32	0	2	1	89	0.00	0.0	8.659	0.123	0	0	0	1
PL.24062	PL.24063	C	#4 ACSR	7.23Y	120.5	0.00	4.47	0.32	0	2	1	89	0.00	0.0	8.776	0.117	2	1	1	1
PL.24220	PL.24221	C	6 A (CWC)	7.24Y	120.6	0.00	4.40	0.36	0	2	1	89	0.00	0.0	7.690	0.150	0	0	0	2
PL.24098	PL.24220	C	6 A (CWC)	7.24Y	120.6	0.00	4.40	0.36	0	2	1	89	0.00	0.0	7.876	0.186	0	0	0	2
PL.24047	PL.24098	C	6 A (CWC)	7.24Y	120.6	0.00	4.40	0.00	0	0	0	100	0.00	0.0	7.924	0.047	0	0	0	0
PL.24048	PL.24098	C	#4 ACSR	7.24Y	120.6	0.00	4.40	0.36	0	2	1	89	0.00	0.0	7.934	0.057	2	1	2	2
PL.24501	PL.24224	C	6 A (CWC)	7.24Y	120.6	0.00	4.37	13.51	10	94	26	96	0.00	0.0	7.325	0.005	0	0	0	36
PD.3445-A	PL.24501	C	Closed	7.24Y	120.6	0.00	4.37	13.51	0	94	26	96	0.00	0.0	7.325	0.005	0	0	0	36
PD.3445-B	PD.3445-A	C	Closed	7.24Y	120.6	0.00	4.37	13.51	0	94	26	96	0.00	0.0	7.325	0.005	0	0	0	36
PL.24502	PD.3445-B	C	6 A (CWC)	7.23Y	120.5	0.10	4.47	13.51	10	94	26	96	0.07	0.1	7.498	0.173	7	2	1	36
PL.24468	PL.24502	C	6 A (CWC)	7.23Y	120.5	0.00	4.47	2.89	2	20	6	96	0.00	0.0	7.502	0.005	0	0	0	6
PD.3428	PL.24468	C	30T	7.23Y	120.5	0.00	4.47	2.89	0	20	6	96	0.00	0.0	7.502	0.005	0	0	0	6
PL.24467	PD.3428	C	6 A (CWC)	7.23Y	120.5	0.01	4.48	2.89	2	20	6	96	0.00	0.0	7.545	0.043	3	1	1	6
PL.23025	PL.24467	C	6 A (CWC)	7.23Y	120.5	0.00	4.48	2.50	2	17	5	96	0.00	0.0	7.573	0.027	5	1	1	5
PL.23024	PL.23025	C	6 A (CWC)	7.23Y	120.5	0.01	4.49	1.74	1	12	3	97	0.00	0.0	7.699	0.126	0	0	0	4
PL.23022	PL.23024	C	#4 ACSR	7.23Y	120.5	0.00	4.49	0.93	1	6	2	95	0.00	0.0	7.756	0.057	6	2	1	2
PL.23023	PL.23022	C	#4 ACSR	7.23Y	120.5	0.00	4.49	0.00	0	0	0	100	0.00	0.0	7.818	0.063	0	0	1	1
PL.23021	PL.23024	C	6 A (CWC)	7.23Y	120.5	0.00	4.49	0.81	1	6	2	95	0.00	0.0	7.735	0.036	0	0	0	2
PL.23020	PL.23021	C	6 A (CWC)	7.23Y	120.5	0.00	4.49	0.81	1	6	2	95	0.00	0.0	7.787	0.052	0	0	0	2
PL.23357	PL.23020	C	6 A (CWC)	7.23Y	120.5	0.00	4.50	0.81	1	6	2	95	0.00	0.0	7.970	0.183	6	2	2	2

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Millers Creek

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru

PL.24417	PL.24502	C	#4 ACSR	7.23Y	120.5	0.00	4.47	9.65	7	67	19	96	0.00	0.0	7.502	0.005	0	0	0	29
PD.3402	PL.24417	C	30T	7.23Y	120.5	0.00	4.47	9.65	0	67	19	96	0.00	0.0	7.502	0.005	0	0	0	29
PL.24418	PD.3402	C	#4 ACSR	7.23Y	120.5	0.02	4.49	9.65	7	67	19	96	0.01	0.0	7.538	0.035	0	0	0	29
PL.23026	PL.24418	C	#4 ACSR	7.23Y	120.4	0.06	4.55	9.65	7	67	19	96	0.03	0.0	7.686	0.148	0	0	0	29
PL.24174	PL.23026	C	#4 ACSR	7.23Y	120.4	0.02	4.58	9.65	7	67	19	96	0.01	0.0	7.740	0.055	0	0	0	29
PL.23367	PL.24174	C	#1/0 ACSR	7.22Y	120.4	0.04	4.61	9.65	4	67	19	96	0.02	0.0	7.907	0.167	0	0	0	29
PL.23358	PL.23367	C	#1/0 ACSR	7.22Y	120.4	0.01	4.63	8.84	4	62	17	96	0.00	0.0	7.965	0.057	0	0	0	28
PL.23359	PL.23358	C	#1/0 ACSR	7.22Y	120.4	0.01	4.64	8.84	4	61	17	96	0.01	0.0	8.031	0.067	2	1	1	28
PL.23029	PL.23359	C	6 A (CWC)	7.22Y	120.3	0.07	4.71	8.48	6	59	17	96	0.03	0.1	8.210	0.178	3	1	1	27
PL.23030	PL.23029	C	6 A (CWC)	7.21Y	120.2	0.05	4.76	8.08	6	56	16	96	0.02	0.0	8.350	0.140	7	2	2	26
PL.23031	PL.23030	C	6 A (CWC)	7.21Y	120.2	0.01	4.77	7.01	5	49	14	96	0.00	0.0	8.383	0.033	0	0	1	24
PL.24131	PL.23031	C	6 A (CWC)	7.21Y	120.2	0.01	4.77	6.96	5	48	14	96	0.00	0.0	8.412	0.029	8	2	1	23
PL.23361	PL.24131	C	#1/0 ACSR	7.21Y	120.2	0.00	4.77	0.00	0	0	0	100	0.00	0.0	8.486	0.075	0	0	0	0
PL.23032	PL.24131	C	6 A (CWC)	7.21Y	120.2	0.04	4.81	5.86	4	41	11	97	0.01	0.0	8.562	0.150	3	1	1	22
PL.23033	PL.23032	C	6 A (CWC)	7.21Y	120.2	0.01	4.82	5.42	4	38	11	96	0.00	0.0	8.593	0.031	0	0	0	21
PL.24469	PL.23033	C	#4 ACSR	7.21Y	120.2	0.00	4.82	3.04	2	21	6	96	0.00	0.0	8.598	0.005	0	0	0	10
PD.3429	PL.24469	C	20T	7.21Y	120.2	0.00	4.82	3.04	0	21	6	96	0.00	0.0	8.598	0.005	0	0	0	10
PL.24470	PD.3429	C	#4 ACSR	7.21Y	120.2	0.00	4.82	3.04	2	21	6	96	0.00	0.0	8.613	0.016	3	1	1	10
PL.23034	PL.24470	C	#4 ACSR	7.21Y	120.2	0.02	4.84	2.66	2	18	5	96	0.00	0.0	8.772	0.158	0	0	0	9
PL.24100	PL.23034	C	#4 ACSR	7.21Y	120.1	0.02	4.86	2.66	2	18	5	96	0.00	0.0	8.934	0.162	0	0	0	8
PL.23366	PL.24100	C	#1/0 ACSR	7.21Y	120.1	0.00	4.86	0.00	0	0	0	100	0.00	0.0	9.004	0.070	0	0	0	0
PL.24101	PL.24100	C	#4 ACSR	7.21Y	120.1	0.01	4.87	2.66	2	18	5	96	0.00	0.0	9.028	0.094	0	0	0	8
PL.24068	PL.24101	C	#4 ACSR	7.21Y	120.1	0.00	4.87	0.20	0	1	0	100	0.00	0.0	9.112	0.084	1	0	1	1
PL.24069	PL.24101	C	#4 ACSR	7.21Y	120.1	0.00	4.87	0.07	0	0	0	100	0.00	0.0	9.088	0.060	0	0	1	1
PL.24070	PL.24101	C	#4 ACSR	7.21Y	120.1	0.02	4.89	2.40	2	17	5	96	0.00	0.0	9.209	0.181	0	0	0	6
PL.24459	PL.24070	C	#4 ACSR	7.21Y	120.1	0.00	4.89	0.43	0	3	1	95	0.00	0.0	9.213	0.005	0	0	0	2
PD.3424	PL.24459	C	12T	7.21Y	120.1	0.00	4.89	0.43	0	3	1	95	0.00	0.0	9.213	0.005	0	0	0	2
PL.24460	PD.3424	C	#4 ACSR	7.21Y	120.1	0.00	4.89	0.43	0	3	1	95	0.00	0.0	9.304	0.090	0	0	0	2
PL.24176	PL.24460	C	#4 ACSR	7.21Y	120.1	0.00	4.89	0.43	0	3	1	95	0.00	0.0	9.407	0.103	3	1	2	2
PL.24483	PL.24070	C	6 A (CWC)	7.21Y	120.1	0.00	4.89	1.97	1	14	4	96	0.00	0.0	9.213	0.005	0	0	0	4
PD.3437	PL.24483	C	12T	7.21Y	120.1	0.00	4.89	1.97	0	14	4	96	0.00	0.0	9.213	0.005	0	0	0	4

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Millers Creek

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru

PL.24484	PD.3437	C	6 A (CWC)	7.21Y	120.1	0.01	4.91	1.97	1	14	4	96	0.00	0.0	9.376	0.163	0	0	0	4
PL.24177	PL.24484	C	6 A (CWC)	7.21Y	120.1	0.01	4.92	1.97	1	14	4	96	0.00	0.0	9.472	0.095	0	0	0	4
PL.24178	PL.24177	C	6 A (CWC)	7.20Y	120.1	0.01	4.93	1.97	1	14	4	96	0.00	0.0	9.629	0.157	0	0	0	4
PL.24072	PL.24178	C	6 A (CWC)	7.20Y	120.1	0.01	4.94	1.97	1	14	4	96	0.00	0.0	9.731	0.102	0	0	0	4
PL.24074	PL.24072	C	#4 ACSR	7.20Y	120.1	0.00	4.94	0.01	0	0	0	100	0.00	0.0	9.803	0.072	0	0	1	1
PL.24071	PL.24072	C	6 A (CWC)	7.20Y	120.1	0.00	4.94	0.00	0	0	0	100	0.00	0.0	9.796	0.065	0	0	0	0
PL.24073	PL.24072	C	#4 ACSR	7.20Y	120.0	0.01	4.95	1.96	2	14	4	96	0.00	0.0	9.867	0.136	0	0	0	3
PL.24343	PL.24073	C	#4 ACSR	7.20Y	120.0	0.01	4.96	1.96	2	14	4	96	0.00	0.0	10.013	0.146	8	2	2	3
PL.24344	PL.24343	C	#4 ACSR	7.20Y	120.0	0.01	4.97	0.77	1	5	1	98	0.00	0.0	10.180	0.167	0	0	0	1
PL.24179	PL.24344	C	#4 ACSR	7.20Y	120.0	0.00	4.97	0.77	1	5	1	98	0.00	0.0	10.337	0.156	5	1	1	1
PL.23365	PL.23034	C	#4 ACSR	7.21Y	120.2	0.00	4.84	0.00	0	0	0	100	0.00	0.0	8.861	0.089	0	0	1	1
PL.24421	PL.23033	C	6 A (CWC)	7.21Y	120.2	0.00	4.82	2.38	2	17	5	96	0.00	0.0	8.598	0.005	0	0	0	11
PD.3404	PL.24421	C	20T	7.21Y	120.2	0.00	4.82	2.38	0	17	5	96	0.00	0.0	8.598	0.005	0	0	0	11
PL.24422	PD.3404	C	6 A (CWC)	7.21Y	120.2	0.02	4.84	2.38	2	17	5	96	0.00	0.0	8.758	0.160	3	1	1	11
PL.23387	PL.24422	C	6 A (CWC)	7.21Y	120.2	0.01	4.85	1.87	1	13	4	96	0.00	0.0	8.866	0.108	0	0	1	8
PL.23364	PL.23387	C	#1/0 ACSR	7.21Y	120.1	0.01	4.86	1.83	1	13	4	96	0.00	0.0	9.080	0.214	0	0	0	7
PL.24473	PL.23364	C	6 A (CWC)	7.21Y	120.1	0.00	4.86	0.06	0	0	0	100	0.00	0.0	9.085	0.005	0	0	0	3
PD.3431	PL.24473	C	12T	7.21Y	120.1	0.00	4.86	0.06	0	0	0	100	0.00	0.0	9.085	0.005	0	0	0	3
PL.24474	PD.3431	C	6 A (CWC)	7.21Y	120.1	0.00	4.86	0.06	0	0	0	100	0.00	0.0	9.218	0.134	0	0	2	3
PL.23037	PL.24474	C	6 A (CWC)	7.21Y	120.1	0.00	4.86	0.02	0	0	0	100	0.00	0.0	9.311	0.093	0	0	0	1
PL.24210	PL.23037	C	6 A (CWC)	7.21Y	120.1	0.00	4.86	0.02	0	0	0	100	0.00	0.0	9.417	0.106	0	0	0	1
PL.24180	PL.24210	C	6 A (CWC)	7.21Y	120.1	0.00	4.86	0.02	0	0	0	100	0.00	0.0	9.582	0.165	0	0	0	1
PL.24181	PL.24180	C	#4 ACSR	7.21Y	120.1	0.00	4.86	0.02	0	0	0	100	0.00	0.0	9.690	0.108	0	0	0	1
PL.24182	PL.24181	C	#4 ACSR	7.21Y	120.1	0.00	4.86	0.02	0	0	0	100	0.00	0.0	9.789	0.099	0	0	0	1
PL.24102	PL.24182	C	#4 ACSR	7.21Y	120.1	0.00	4.86	0.02	0	0	0	100	0.00	0.0	9.911	0.121	0	0	1	1
PL.23937	PL.24182	C	#4 ACSR	7.21Y	120.1	0.00	4.86	0.00	0	0	0	100	0.00	0.0	9.887	0.097	0	0	0	0
PL.24426	PL.23364	C	6 A (CWC)	7.21Y	120.1	0.00	4.86	1.78	1	12	3	97	0.00	0.0	9.085	0.005	0	0	0	4
PD.3406	PL.24426	C	12T	7.21Y	120.1	0.00	4.86	1.78	0	12	3	97	0.00	0.0	9.085	0.005	0	0	0	4
PL.24425	PD.3406	C	6 A (CWC)	7.21Y	120.1	0.01	4.87	1.78	1	12	3	97	0.00	0.0	9.258	0.173	0	0	0	4
PL.23936	PL.24425	C	6 A (CWC)	7.21Y	120.1	0.01	4.88	1.78	1	12	3	97	0.00	0.0	9.438	0.180	0	0	0	4
PL.23935	PL.23936	C	6 A (CWC)	7.21Y	120.1	0.01	4.89	1.78	1	12	3	97	0.00	0.0	9.555	0.117	1	0	1	4

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Millers Creek

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.23374	PL.23935	C	6 A (CWC)	7.21Y	120.1	0.00	4.89	0.00	0	0	0	100	0.00	0.0	9.604	0.049	0	0	0	0
PL.23375	PL.23935	C	#4 ACSR	7.21Y	120.1	0.01	4.90	1.66	1	12	3	97	0.00	0.0	9.651	0.097	0	0	0	3
PL.23035	PL.23375	C	#4 ACSR	7.21Y	120.1	0.01	4.91	1.66	1	11	3	96	0.00	0.0	9.820	0.169	0	0	0	3
PL.23036	PL.23035	C	#4 ACSR	7.21Y	120.1	0.00	4.92	1.66	1	11	3	96	0.00	0.0	9.860	0.039	0	0	0	3
PL.23038	PL.23036	C	#4 ACSR	7.20Y	120.1	0.01	4.92	1.66	1	11	3	96	0.00	0.0	9.977	0.118	5	2	1	3
PL.24267	PL.23038	C	#4 ACSR	7.20Y	120.1	0.01	4.93	0.88	1	6	2	95	0.00	0.0	10.151	0.174	3	1	1	2
PL.23938	PL.24267	C	#4 ACSR	7.20Y	120.1	0.00	4.93	0.45	0	3	1	95	0.00	0.0	10.197	0.046	3	1	1	1
PL.24424	PL.24422	C	6 A (CWC)	7.21Y	120.2	0.00	4.84	0.10	0	1	0	100	0.00	0.0	8.814	0.056	0	0	0	2
PD.3405	PL.24424	C	12T	7.21Y	120.2	0.00	4.84	0.10	0	1	0	100	0.00	0.0	8.814	0.056	0	0	0	2
PL.24423	PD.3405	C	6 A (CWC)	7.21Y	120.2	0.00	4.84	0.10	0	1	0	100	0.00	0.0	8.916	0.103	0	0	1	2
PL.23363	PL.24423	C	#4 ACSR	7.21Y	120.2	0.00	4.84	0.08	0	1	0	100	0.00	0.0	8.953	0.037	0	0	0	1
PL.23362	PL.23363	C	#4 ACSR	7.21Y	120.2	0.00	4.84	0.08	0	1	0	100	0.00	0.0	9.053	0.099	1	0	1	1
PL.24419	PL.23367	C	6 A (CWC)	7.22Y	120.4	0.00	4.61	0.80	1	6	2	95	0.00	0.0	7.912	0.005	0	0	0	1
PD.3403	PL.24419	C	20T	7.22Y	120.4	0.00	4.61	0.80	0	6	2	95	0.00	0.0	7.912	0.005	0	0	0	1
PL.24420	PD.3403	C	6 A (CWC)	7.22Y	120.4	0.00	4.62	0.80	1	6	2	95	0.00	0.0	8.055	0.143	6	2	1	1
PL.24415	PL.23018	C	6 A (CWC)	7.24Y	120.7	0.00	4.28	0.15	0	1	0	100	0.00	0.0	7.211	0.005	0	0	0	2
PD.3401	PL.24415	C	30T	7.24Y	120.7	0.00	4.28	0.15	0	1	0	100	0.00	0.0	7.211	0.005	0	0	0	2
PL.24416	PD.3401	C	6 A (CWC)	7.24Y	120.7	0.00	4.28	0.15	0	1	0	100	0.00	0.0	7.229	0.018	1	0	1	2
PL.23019	PL.24416	C	6 A (CWC)	7.24Y	120.7	0.00	4.28	0.00	0	0	0	100	0.00	0.0	7.367	0.138	0	0	1	1
PL.24465	PL.24161	C	#1/0 ACSR	7.28Y	121.4	0.00	3.65	0.00	0	0	0	100	0.00	0.0	6.391	0.005	0	0	0	0
PD.3427	PL.24465	C	30T	7.28Y	121.4	0.00	3.65	0.00	0	0	0	100	0.00	0.0	6.391	0.005	0	0	0	0
PL.24466	PD.3427	C	#1/0 ACSR	7.28Y	121.4	0.00	3.65	0.00	0	0	0	100	0.00	0.0	6.444	0.052	0	0	0	0
PL.24397	PL.24161	C	6 A (CWC)	7.28Y	121.4	0.00	3.65	0.02	0	0	0	100	0.00	0.0	6.392	0.005	0	0	0	1
PD.3393	PL.24397	C	30T	7.28Y	121.4	0.00	3.65	0.02	0	0	0	100	0.00	0.0	6.392	0.005	0	0	0	1
PL.24398	PD.3393	C	6 A (CWC)	7.28Y	121.4	0.00	3.65	0.02	0	0	0	100	0.00	0.0	6.461	0.069	0	0	0	1
PL.23933	PL.24398	C	6 A (CWC)	7.28Y	121.4	0.00	3.65	0.02	0	0	0	100	0.00	0.0	6.622	0.161	0	0	1	1
PL.24383	PL.24160	C	#1/0 ACSR	7.29Y	121.5	0.00	3.53	1.26	1	9	2	98	0.00	0.0	6.122	0.005	0	0	0	2
PD.3384	PL.24383	C	30T	7.29Y	121.5	0.00	3.53	1.26	0	9	2	98	0.00	0.0	6.122	0.005	0	0	0	2
PL.24384	PD.3384	C	#1/0 ACSR	7.29Y	121.5	0.00	3.53	1.26	1	9	2	98	0.00	0.0	6.164	0.042	6	2	1	2
PL.24248	PL.24384	C	#1/0 ACSR	7.29Y	121.5	0.00	3.54	0.43	0	3	1	95	0.00	0.0	6.203	0.039	0	0	0	1
PL.23932	PL.24248	C	#1/0 ACSR	7.29Y	121.5	0.00	3.54	0.43	0	3	1	95	0.00	0.0	6.242	0.039	3	1	1	1

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Millers Creek

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.24381	PL.23929	C	#1/0 ACSR	7.30Y	121.7	0.00	3.33	0.24	0	2	0	100	0.00	0.0	5.681	0.005	0	0	0	2
PD.3383	PL.24381	C	10T	7.30Y	121.7	0.00	3.33	0.24	0	2	0	100	0.00	0.0	5.681	0.005	0	0	0	2
PL.24382	PD.3383	C	#1/0 ACSR	7.30Y	121.7	0.00	3.33	0.24	0	2	0	100	0.00	0.0	5.798	0.117	0	0	1	2
PL.24247	PL.24382	C	#1/0 ACSR	7.30Y	121.7	0.00	3.33	0.24	0	2	0	100	0.00	0.0	5.859	0.061	2	0	1	1
PL.24373	PL.24158	A	6 A (CWC)	7.31Y	121.8	0.00	3.22	1.83	1	13	4	96	0.00	0.0	5.446	0.005	0	0	0	4
PD.3379	PL.24373	A	40T	7.31Y	121.8	0.00	3.22	1.83	0	13	4	96	0.00	0.0	5.446	0.005	0	0	0	4
PL.24374	PD.3379	A	6 A (CWC)	7.31Y	121.8	0.00	3.22	1.83	1	13	4	96	0.00	0.0	5.468	0.022	8	2	1	4
PL.23921	PL.24374	A	6 A (CWC)	7.31Y	121.8	0.00	3.22	0.65	0	5	1	98	0.00	0.0	5.532	0.064	2	1	2	3
PL.23924	PL.23921	A	#4 ACSR	7.31Y	121.8	0.00	3.22	0.00	0	0	0	100	0.00	0.0	5.552	0.020	0	0	0	0
PL.23925	PL.23921	A	6 A (CWC)	7.31Y	121.8	0.00	3.22	0.34	0	2	1	89	0.00	0.0	5.571	0.039	0	0	0	1
PL.23926	PL.23925	A	#4 ACSR	7.31Y	121.8	0.00	3.22	0.34	0	2	1	89	0.00	0.0	5.612	0.042	2	1	1	1
PL.24389	PL.24265	A	#4 ACSR	7.35Y	122.5	0.00	2.49	0.00	0	0	0	100	0.00	0.0	4.090	0.005	0	0	0	0
PD.3389	PL.24389	A	40T	7.35Y	122.5	0.00	2.49	0.00	0	0	0	100	0.00	0.0	4.090	0.005	0	0	0	0
PL.24390	PD.3389	A	#4 ACSR	7.35Y	122.5	0.00	2.49	0.00	0	0	0	100	0.00	0.0	4.119	0.029	0	0	0	0
PL.24393	PL.22995	A	#4 ACSR	7.36Y	122.7	0.00	2.30	1.39	1	10	3	96	0.00	0.0	3.740	0.005	0	0	0	1
PD.3391	PL.24393	A	40T	7.36Y	122.7	0.00	2.30	1.39	0	10	3	96	0.00	0.0	3.740	0.005	0	0	0	1
PL.24394	PD.3391	A	#4 ACSR	7.36Y	122.7	0.00	2.30	1.39	1	10	3	96	0.00	0.0	3.784	0.044	10	3	1	1
PL.24395	PL.22999	C	#4 ACSR	7.37Y	122.9	0.00	2.14	1.13	1	8	2	97	0.00	0.0	3.469	0.005	0	0	0	2
PD.3392	PL.24395	C	40T	7.37Y	122.9	0.00	2.14	1.13	0	8	2	97	0.00	0.0	3.469	0.005	0	0	0	2
PL.24396	PD.3392	C	#4 ACSR	7.37Y	122.9	0.00	2.14	1.13	1	8	2	97	0.00	0.0	3.488	0.019	8	2	2	2
PL.24399	PL.24516	C	#1/0 ACSR	7.40Y	123.4	0.00	1.62	0.04	0	0	0	100	0.00	0.0	2.561	0.004	0	0	0	1
PD.3394	PL.24399	C	40T	7.40Y	123.4	0.00	1.62	0.04	0	0	0	100	0.00	0.0	2.561	0.004	0	0	0	1
PL.24400	PD.3394	C	#1/0 ACSR	7.40Y	123.4	0.00	1.62	0.04	0	0	0	100	0.00	0.0	2.598	0.038	0	0	1	1
PL.24491	PL.23897	ABC	#1/0 ACSR	7.41Y	123.5	0.00	1.54	5.24	2	112	31	96	0.00	0.0	2.419	0.005	0	0	0	26
PD.3441	PL.24491	ABC	50T	7.41Y	123.5	0.00	1.54	5.24	0	112	31	96	0.00	0.0	2.419	0.005	0	0	0	26
PL.24492	PD.3441	ABC	#1/0 ACSR	7.41Y	123.5	0.00	1.54	5.24	2	112	31	96	0.00	0.0	2.454	0.035	5	1	3	26
PL.23898	PL.24492	ABC	#4 ACSR	7.41Y	123.4	0.02	1.55	5.01	4	107	30	96	0.01	0.0	2.537	0.083	0	0	0	23
PL.24387	PL.23898	C	6 A (CWC)	7.41Y	123.4	0.00	1.56	0.24	0	2	0	100	0.00	0.0	2.542	0.005	0	0	0	1
PD.3388	PL.24387	C	30T	7.41Y	123.4	0.00	1.56	0.24	0	2	0	100	0.00	0.0	2.542	0.005	0	0	0	1
PL.24388	PD.3388	C	6 A (CWC)	7.41Y	123.4	0.00	1.56	0.24	0	2	0	100	0.00	0.0	2.631	0.089	2	0	1	1
PL.24081	PL.23898	ABC	#4 ACSR	7.41Y	123.4	0.02	1.58	4.93	4	105	30	96	0.02	0.0	2.670	0.133	0	0	0	22

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Millers Creek

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.23899	PL.24081	ABC	#4 ACSR	7.40Y	123.4	0.02	1.60	4.93	4	105	30	96	0.01	0.0	2.754	0.084	8	2	1	22
PL.24365	PL.23899	ABC	#4 ACSR	7.40Y	123.4	0.02	1.61	4.57	4	98	27	96	0.01	0.0	2.852	0.098	2	1	1	21
PL.24366	PL.24365	ABC	#4 ACSR	7.40Y	123.4	0.02	1.63	4.49	3	96	27	96	0.01	0.0	2.966	0.115	8	2	1	20
PL.24364	PL.24366	ABC	#4 ACSR	7.40Y	123.4	0.01	1.64	4.11	3	88	25	96	0.01	0.0	3.022	0.056	0	0	0	19
PL.23900	PL.24364	ABC	#4 ACSR	7.40Y	123.3	0.01	1.65	4.11	3	88	25	96	0.01	0.0	3.100	0.078	0	0	0	19
PL.24259	PL.23900	ABC	#4 ACSR	7.40Y	123.3	0.01	1.66	4.11	3	88	25	96	0.01	0.0	3.158	0.058	6	2	1	19
PL.24260	PL.24259	ABC	#4 ACSR	7.40Y	123.3	0.02	1.68	3.84	3	82	23	96	0.01	0.0	3.263	0.105	0	0	0	18
PL.24214	PL.24260	ABC	#4 ACSR	7.40Y	123.3	0.02	1.69	3.84	3	82	23	96	0.01	0.0	3.366	0.104	0	0	0	18
PL.24135	PL.24214	ABC	#4 ACSR	7.40Y	123.3	0.02	1.71	3.84	3	82	23	96	0.02	0.0	3.533	0.167	0	0	0	18
PL.24136	PL.24135	ABC	#4 ACSR	7.40Y	123.3	0.01	1.73	3.84	3	82	23	96	0.01	0.0	3.604	0.071	0	0	0	18
PL.24082	PL.24136	ABC	#4 ACSR	7.40Y	123.3	0.02	1.75	3.84	3	82	23	96	0.02	0.0	3.774	0.170	0	0	0	18
PL.24083	PL.24082	ABC	#4 ACSR	7.39Y	123.2	0.01	1.76	3.57	3	76	21	96	0.01	0.0	3.872	0.097	0	0	0	14
PL.24215	PL.24083	ABC	#4 ACSR	7.39Y	123.2	0.02	1.78	3.57	3	76	21	96	0.01	0.0	3.982	0.111	0	0	0	14
PL.24141	PL.24215	ABC	#4 ACSR	7.39Y	123.2	0.03	1.80	3.57	3	76	21	96	0.02	0.0	4.169	0.186	0	0	0	14
PL.24142	PL.24141	ABC	#4 ACSR	7.39Y	123.2	0.02	1.82	3.57	3	76	21	96	0.01	0.0	4.293	0.124	0	0	0	14
PL.23907	PL.24142	ABC	#4 ACSR	7.39Y	123.2	0.01	1.83	3.57	3	76	21	96	0.01	0.0	4.396	0.103	0	0	0	14
PL.23909	PL.23907	C	6 A (CWC)	7.39Y	123.2	0.00	1.83	2.70	2	19	5	97	0.00	0.0	4.401	0.005	0	0	0	3
PD.3385	PL.23909	C	30T	7.39Y	123.2	0.00	1.83	2.70	0	19	5	97	0.00	0.0	4.401	0.005	0	0	0	3
PL.24086	PD.3385	C	6 A (CWC)	7.39Y	123.2	0.00	1.84	1.51	1	11	3	96	0.00	0.0	4.500	0.100	11	3	2	2
PL.23908	PD.3385	C	#4 ACSR	7.39Y	123.2	0.00	1.84	1.19	1	8	2	97	0.00	0.0	4.432	0.031	8	2	1	1
PL.24085	PL.23907	ABC	#4 ACSR	7.39Y	123.1	0.02	1.85	2.67	2	57	16	96	0.01	0.0	4.552	0.156	0	0	0	11
PL.24371	PL.24085	C	#4 ACSR	7.39Y	123.1	0.00	1.85	7.83	6	56	16	96	0.00	0.0	4.557	0.005	0	0	0	10
PD.3378	PL.24371	C	20T	7.39Y	123.1	0.00	1.85	7.83	0	56	16	96	0.00	0.0	4.557	0.005	0	0	0	10
PL.24372	PD.3378	C	#4 ACSR	7.39Y	123.1	0.03	1.88	7.83	6	56	16	96	0.01	0.0	4.641	0.084	0	0	0	10
PL.24143	PL.24372	C	#4 ACSR	7.38Y	123.1	0.04	1.92	7.83	6	56	16	96	0.02	0.0	4.757	0.117	0	0	0	10
PL.24087	PL.24143	C	#4 ACSR	7.38Y	123.0	0.03	1.95	7.83	6	56	16	96	0.01	0.0	4.847	0.089	0	0	0	10
PL.23914	PL.24087	C	#4 ACSR	7.38Y	123.0	0.04	2.00	7.83	6	56	16	96	0.02	0.0	4.973	0.127	0	0	0	10
PL.24088	PL.23914	C	#4 ACSR	7.38Y	123.0	0.01	2.01	6.94	5	49	14	96	0.00	0.0	5.000	0.027	0	0	0	8
PL.24144	PL.24088	C	#4 ACSR	7.38Y	122.9	0.05	2.06	6.94	5	49	14	96	0.02	0.0	5.184	0.184	7	2	1	8
PL.23916	PL.24144	C	#4 ACSR	7.38Y	122.9	0.00	2.06	0.48	0	3	1	95	0.00	0.0	5.254	0.070	3	1	1	1
PL.23917	PL.24144	C	#4 ACSR	7.38Y	122.9	0.01	2.07	5.46	4	39	11	96	0.00	0.0	5.242	0.058	0	0	0	6

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Millers Creek

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru
PL.24089	PL.23917	C	#4 ACSR	7.37Y	122.9	0.02	2.09	3.76	3	27	7	97	0.00	0.0	5.355	0.113	8	2	1	5
PL.23919	PL.24089	C	#4 ACSR	7.37Y	122.9	0.01	2.10	2.35	2	17	5	96	0.00	0.0	5.459	0.104	0	0	0	3
PL.23920	PL.23919	C	#4 ACSR	7.37Y	122.9	0.00	2.10	2.35	2	17	5	96	0.00	0.0	5.491	0.031	0	0	0	3
PL.24367	PL.23920	C	#4 ACSR	7.37Y	122.9	0.00	2.11	2.35	2	17	5	96	0.00	0.0	5.520	0.029	3	1	1	3
PL.24368	PL.24367	C	#4 ACSR	7.37Y	122.9	0.01	2.11	1.95	2	14	4	96	0.00	0.0	5.603	0.083	0	0	0	2
PL.24076	PL.24368	C	#4 ACSR	7.37Y	122.9	0.00	2.11	0.87	1	6	2	95	0.00	0.0	5.628	0.025	6	2	1	1
PL.24077	PL.24368	C	#4 ACSR	7.37Y	122.9	0.00	2.12	1.09	1	8	2	97	0.00	0.0	5.708	0.104	8	2	1	1
PL.24061	PL.24089	C	#4 ACSR	7.37Y	122.9	0.00	2.09	0.33	0	2	1	89	0.00	0.0	5.425	0.070	0	0	0	1
PL.24060	PL.24061	C	#4 ACSR	7.37Y	122.9	0.00	2.09	0.33	0	2	1	89	0.00	0.0	5.533	0.108	0	0	0	1
PL.24145	PL.24060	C	#4 ACSR	7.37Y	122.9	0.00	2.09	0.33	0	2	1	89	0.00	0.0	5.631	0.098	2	1	1	1
PL.23918	PL.23917	C	#2 ACSR	7.38Y	122.9	0.00	2.07	1.70	1	12	3	97	0.00	0.0	5.285	0.043	12	3	1	1
PL.23915	PL.23914	C	#4 ACSR	7.38Y	123.0	0.00	2.00	0.88	1	6	2	95	0.00	0.0	5.050	0.077	6	2	2	2
PL.23910	PL.24085	ABC	#4 ACSR	7.39Y	123.1	0.00	1.85	0.06	0	1	0	100	0.00	0.0	4.592	0.040	0	0	0	1
PL.23911	PL.23910	ABC	#4 ACSR	7.39Y	123.1	0.00	1.85	0.06	0	1	0	100	0.00	0.0	4.700	0.108	1	0	1	1
PL.23902	PL.24082	B	6 A (CWC)	7.39Y	123.2	0.00	1.75	0.80	1	6	2	95	0.00	0.0	3.861	0.086	0	0	0	4
PD.3386	PL.23902	B	30T	7.39Y	123.2	0.00	1.75	0.80	0	6	2	95	0.00	0.0	3.861	0.086	0	0	0	4
PL.24084	PD.3386	B	6 A (CWC)	7.39Y	123.2	0.00	1.75	0.54	0	4	1	97	0.00	0.0	3.936	0.076	4	1	1	1
PL.23903	PD.3386	B	6 A (CWC)	7.39Y	123.2	0.00	1.75	0.27	0	2	1	89	0.00	0.0	4.003	0.142	1	0	1	3
PL.24362	PL.23903	B	6 A (CWC)	7.39Y	123.2	0.00	1.76	0.16	0	1	0	100	0.00	0.0	4.129	0.126	0	0	1	2
PL.24363	PL.24362	B	6 A (CWC)	7.39Y	123.2	0.00	1.76	0.12	0	1	0	100	0.00	0.0	4.226	0.097	0	0	0	1
PL.24139	PL.24363	B	6 A (CWC)	7.39Y	123.2	0.00	1.76	0.12	0	1	0	100	0.00	0.0	4.365	0.139	0	0	0	1
PL.24140	PL.24139	B	6 A (CWC)	7.39Y	123.2	0.00	1.76	0.12	0	1	0	100	0.00	0.0	4.513	0.148	1	0	1	1
PL.24385	PL.24136	C	#4 ACSR	7.40Y	123.3	0.00	1.73	0.00	0	0	0	100	0.00	0.0	3.609	0.005	0	0	0	0
PD.3387	PL.24385	C	30T	7.40Y	123.3	0.00	1.73	0.00	0	0	0	100	0.00	0.0	3.609	0.005	0	0	0	0
PL.24386	PD.3387	C	#4 ACSR	7.40Y	123.3	0.00	1.73	0.00	0	0	0	100	0.00	0.0	3.763	0.155	0	0	0	0
PL.24137	PL.24386	C	#4 ACSR	7.40Y	123.3	0.00	1.73	0.00	0	0	0	100	0.00	0.0	3.865	0.102	0	0	0	0
PL.24138	PL.24137	C	#4 ACSR	7.40Y	123.3	0.00	1.73	0.00	0	0	0	100	0.00	0.0	3.990	0.124	0	0	0	0
PL.23901	PL.24138	C	#4 ACSR	7.40Y	123.3	0.00	1.73	0.00	0	0	0	100	0.00	0.0	4.085	0.095	0	0	0	0
PL.23894	PL.24216	C	#4 ACSR	7.41Y	123.6	0.00	1.42	0.02	0	0	0	100	0.00	0.0	2.269	0.032	0	0	0	1
PL.24407	PL.23894	C	#4 ACSR	7.41Y	123.6	0.00	1.42	0.02	0	0	0	100	0.00	0.0	2.273	0.005	0	0	0	1
PD.3397	PL.24407	C	50T	7.41Y	123.6	0.00	1.42	0.02	0	0	0	100	0.00	0.0	2.273	0.005	0	0	0	1

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Balanced Voltage Drop Report
Source: Millers Creek

Database: C:\MILSOFT\DATA\2010-2013 WP PROJECTED LOAD PHASE 2 IMPROVEMENTS.WM\
Title: 2010-2013 CWP - Jackson Energy Co-op - McKee, Kentucky
Case: 2013 Projected load with Phase 2 Improvements

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	-----Element-----			
																KW	KVAR	Cons On	Cons Thru	
PL.24408	PD.3397	C	#4 ACSR	7.41Y	123.6	0.00	1.42	0.02	0	0	0	100	0.00	0.0	2.300	0.026	0	0	0	1
PL.23895	PL.24408	C	6 A (CWC)	7.41Y	123.6	0.00	1.42	0.02	0	0	0	100	0.00	0.0	2.482	0.182	0	0	0	1
PL.23896	PL.23895	C	#4 ACSR	7.41Y	123.6	0.00	1.42	0.02	0	0	0	100	0.00	0.0	2.567	0.085	0	0	1	1
PL.24413	PL.23012	C	#1/0 ACSR	7.49Y	124.8	0.00	0.16	0.85	0	6	2	95	0.00	0.0	0.296	0.057	0	0	0	2
PD.3400	PL.24413	C	50T	7.49Y	124.8	0.00	0.16	0.85	0	6	2	95	0.00	0.0	0.296	0.057	0	0	0	2
PL.24414	PD.3400	C	#1/0 ACSR	7.49Y	124.8	0.00	0.16	0.85	0	6	2	95	0.00	0.0	0.308	0.013	0	0	1	2
PL.23891	PL.24414	C	#1/0 ACSR	7.49Y	124.8	0.00	0.16	0.85	0	6	2	95	0.00	0.0	0.348	0.040	6	2	1	1

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

	Load	Adjustment	Capacitance	Charging	Gen&Motors	Loops&Metas	Losses	No Load	Losses	Total			
KW	5528	0	0	0	0	0	170		0.00	5698	Lowest Voltage = 118.11 on Element PL.20917		
KVAR	1608	0	0	0	0	0	268			1876	Max Accm VoltD = 6.89 on Element PL.20917		
											Max Elem VoltD = 0.33 on Element PL.23384		