Kentucky
FRONTIER
GAS

5/31/2011

Jeff Derouen
Executive Director
Public Service Commission

Subject: Case No. 2011-00017

Mr. Derouen,

With reference to the above case number, please find enclosed the requested binders containing odorant test records. Additional information will be sent under separate cover.

Thank you,
Larry J. Rich
LJR/hlp

RECEIVED
JUN 9 2011
PUBLIC SERVICE
COMMISSION

2963 Ky Rt 321 N * P.O.Box 408 * Prestonsburg, Ky. 41653* 606-886-2431 * 866-942-9427 *Fax:606-889-9196 * lrich@ec.rr.com

Kentucky FRONTIER GAS

Odorization Reports

Kentucky FRONTIER GAS

RECEIVED
JUN 2 2011
PUBLIC SERVICE COMMISSION

Odorization Check Report

Location: 149 creekside Abbott Rd (Auxier)

Date: 3/18/10 Time: _____

Odor Level: 47
Actual .33%

____Nil
____Barely Detectable
____Readily Detectable
___✓Strong

List other odors present: ~~174 Oaklawn Est, Rt. 321 N~~

Remarks: (odorometer reading)

Observed By: [signature]

Location: 171 Oaklawn Est Rt 321 N (Auxier)

Date: 3/18/10 Time: _____

Odor Level: 47
Actual 33%

____Nil
____Barely Detectable
____Readily Detectable
___✓Strong

List other odors present:

Remarks: (odorometer reading)

Observed By: [signature]

Location:

Date: _____ Time: _____

Odor Level:

____Nil
____Barely Detectable
____Readily Detectable
____Strong

List other odors present:

Remarks: (odorometer reading)

Observed By:

P.O Box 408 * Prestonsburg, Ky. 41653* 606-886-2431 * 866-942-9427 *Fax:606-889-9196 * lrich@ec.rr.com

Kentucky FRONTIER GAS

Odorization Check Report

Location: Old Allen by Dave Flannery Meter (EKU)

Date: 3-25-10 Time: 2:35pm

Odor Level: 0.25%

____Nil
____Barely Detectable
✓ Readily Detectable
____ Strong

List other odors present: ____

Remarks: (odorometer reading) 0.35%

Observed By: [signature]

Location: 3831 Mulberry LN. Hueysville (old Stand) (EKU)

Date: 3-25-10 Time: 3:55pm

Odor Level: 0.33%

____Nil
____Barely Detectable
✓ Readily Detectable
____ Strong

List other odors present: ____

Remarks: (odorometer reading) 0.54%

Observed By: [signature]

Location: Beside Clyde Conley meter, Webb BR. RD Lackey (EKU)

Date: 3-25-10 Time: 4:25

Odor Level: 0.33%

____Nil
____Barely Detectable
✓ Readily Detectable
____ Strong

List other odors present: ____

Remarks: (odorometer reading) 0.47%

Observed By: [signature]

P.O.Box 408 * Prestonsburg, Ky. 41653* 606-886-2431 * 866-942-9427 *Fax:606-889-9196 * lrich@ec.rr.com

EKU

Kentucky FRONTIER GAS

Odorization Check Report

Location: Old Stand pipe on Fitzpatrick Rd. (EKU)

Date: 3-25-10 Time: 12:15pm

Odor Level: 0.17%

____Nil
____Barely Detectable
✓ Readily Detectable
____ Strong

List other odors present: _____

Remarks: (odorometer reading) 0.24%

Observed By: [signature]

Location: Old Middle Creek Rd. Old Stand pipe (EKU)

Date: 3-25-10 Time: 12:40

Odor Level: 0.17%

____Nil
____Barely Detectable
✓ Readily Detectable
____ Strong

List other odors present: _____

Remarks: (odorometer reading) 0.26%

Observed By: [signature]

Location: May Truck Parts 1428 Allen EKU

Date: 3-25-10 Time: 2:15

Odor Level: 0.40%

____Nil
____Barely Detectable
✓ Readily Detectable
____ Strong

List other odors present: _____

Remarks: (odorometer reading) 0.52%

Observed By: [signature]

P.O.Box 408 * Prestonsburg, Ky. 41653* 606-886-2431 * 866-942-9427 *Fax:606-889-9196 * lrich@ec.rr.com

Kentucky FRONTIER GAS

Odorization Check Report

Location: Champs Country Cookin Minnie KY RT 122 (EKU)

Date: 3-25-10 Time: 5:00 pm

Odor Level: 0.17%

____Nil
____Barely Detectable
✓ Readily Detectable
____ Strong

List other odors present: _____

Remarks: (odorometer reading) 0.21

Observed By: [signature]

Location: _____

Date: _____ Time: _____

Odor Level:

____Nil
____Barely Detectable
____ Readily Detectable
____ Strong

List other odors present: _____

Remarks: (odorometer reading) _____

Observed By: _____

Location: _____

Date: _____ Time: _____

Odor Level:

____Nil
____Barely Detectable
____ Readily Detectable
____ Strong

List other odors present: _____

Remarks: (odorometer reading) _____

Observed By: _____

P.O.Box 408 * Prestonsburg, Ky. 41653* 606-886-2431 * 866-942-9427 *Fax:606-889-9196 * lrich@ec.rr.com

Kentucky FRONTIER GAS

Odorization Check Report

Location: BOBIE ROBERTS (MLG)

Date: 4-8-10 Time: 10:29 A.M.

Odor Level: 0.25%

_____Nil
_____Barely Detectable
_____ Readily Detectable
_____ Strong

List other odors present: _____

Remarks: (odorometer reading) 0.30%

Observed By: James DOVE

Location: Longley (maytown) (MLG)

Date: 4-8-10 Time: 11:43 A.M.

Odor Level: 0.33%

_____Nil
_____Barely Detectable
_____ Readily Detectable
_____ Strong

List other odors present: _____

Remarks: (odorometer reading) 0.40%

Observed By: JAMES DOVE

Location: WEEKSBURY (MLG)

Date: 4-8-10 Time: 12:55 A.M.

Odor Level: 0.25%

_____Nil
_____Barely Detectable
_____ Readily Detectable
_____ Strong

List other odors present: _____

Remarks: (odorometer reading) 0.30%

Observed By: JAMES DOVE

P.O.Box 408 * Prestonsburg, Ky. 41653* 606-886-2431 * 866-942-9427 *Fax:606-889-9196 * lrich@ec.rr.com

Kentucky FRONTIER GAS

Odorization Check Report

Location: Bevinsville (MLC)

Date: 4-8-10 Time: 1:18 p.m

Odor Level: 0.25%

_____Nil
_____Barely Detectable
_____ Readily Detectable
_____ Strong

List other odors present: _____

Remarks: (odorometer reading) 0.30%

Observed By: James Dove

Location: _____

Date: _____Time: _____

Odor Level:

_____Nil
_____Barely Detectable
_____ Readily Detectable
_____ Strong

List other odors present: _____

Remarks: (odorometer reading)_____

Observed By: _____

Location: _____

Date: _____Time: _____

Odor Level:

_____Nil
_____Barely Detectable
_____ Readily Detectable
_____ Strong

List other odors present: _____

Remarks: (odorometer reading)_____

Observed By: _____

P.O.Box 408 * Prestonsburg, Ky. 41653* 606-886-2431 * 866-942-9427 *Fax:606-889-9196 * lrich@ec.rr.com

Kentucky FRONTIER GAS

Odorization Check Report

Location: [illegible] Middle Creek (EKU)

Date: [illegible] Time: 10:30 Am

Odor Level: 0.08 %

____Nil
____Barely Detectable
____Readily Detectable
✓ Strong

List other odors present: ____

Remarks: (odorometer reading) 0.15 %

Observed By: [signature]

Location: 304 West Middle Creek Rd. (EKU)

Date: 4-9-10 Time: 10:50 [illegible]

Odor Level: 0.08 %

____Nil
____Barely Detectable
____Readily Detectable
✓ Strong

List other odors present: ____

Remarks: (odorometer reading) 0.14 %

Observed By: [signature]

Location: May Truck Parts, 1428 Old Allen Rd. (EKU)

Date: 4-9-10 Time: 11:32 Am

Odor Level: 0.40 %

____Nil
____Barely Detectable
✓ Readily Detectable
____Strong

List other odors present: ____

Remarks: (odorometer reading) 0.55 %

Observed By: [signature]

[illegible] Frontier Gas, LLC

P.O.Box 408 * Prestonsburg, Ky. 41653* 606-886-2431 * 866-942-9427 *Fax:606-889-9196 * lrich@ec.rr.com

Kentucky FRONTIER GAS

Odorization Check Report

Location: Dave Flannery Meter Old Allen (EKU)

Date: 4-9-10 Time: 11:55

Odor Level: 0.25%

____ Nil
____ Barely Detectable
✓ Readily Detectable
____ Strong

List other odors present: ____

Remarks: (odorometer reading) 0.38%

Observed By: [signature]

Location: 3831 Salt Lick Br. Rd. Heavegsville (EKU)

Date: 4-9-10 Time: 12:45 pm

Odor Level: 0.25%

____ Nil
____ Barely Detectable
✓ Readily Detectable
____ Strong

List other odors present: ____

Remarks: (odorometer reading) 0.32%

Observed By: [signature]

Location: Clyde Conley Webb Br. Knott co. (EKU)

Date: 4-9-10 Time: 1:25 pm

Odor Level:

____ Nil
____ Barely Detectable
✓ Readily Detectable
____ Strong

List other odors present: ____

Remarks: (odorometer reading) ____

Observed By: [signature]

Kentucky Frontier Gas LLC

P.O.Box 408 * Prestonsburg, Ky. 41653* 606-886-2431 * 866-942-9427 *Fax:606-889-9196 * lrich@ec.rr.com

Kentucky FRONTIER GAS

Odorization Check Report

Location: Champs Country Cookin 122 minnie Ky (EKU)

Date: 4-9-10 Time: 2:10pm

Odor Level: 0.33%

_____Nil
_____Barely Detectable
___✓___Readily Detectable
_____ Strong

List other odors present: _____

Remarks: (odorometer reading) 0.44%

Observed By: [signature]

Location: _____

Date: _____Time: _____

Odor Level:

_____Nil
_____Barely Detectable
_____ Readily Detectable
_____ Strong

List other odors present: _____

Remarks: (odorometer reading)_____

Observed By: _____

Location: _____

Date: _____Time: _____

Odor Level:

_____Nil
_____Barely Detectable
_____ Readily Detectable
_____ Strong

List other odors present: _____

Remarks: (odorometer reading)_____

Observed By: _____

P.O.Box 408 * Prestonsburg, Ky. 41653* 606-886-2431 * 866-942-9427 *Fax:606-889-9196 * lrich@ec.rr.com

Kentucky FRONTIER GAS

Odorization Check Report

Location: 179 Oaklawn Estates (Allixiev)

Date: 4-16-10 Time: 9:30Am

Odor Level: 0.25%

____Nil
____Barely Detectable
__✓__ Readily Detectable
____ Strong

List other odors present: _____

Remarks: (odorometer reading) 0.36%

Observed By: [signature]

Location: 27 Creekside Dr. Abbott (Allixiev)

Date: 4-16-10 Time: 10:20

Odor Level: 0.40%

____Nil
____Barely Detectable
__✓__ Readily Detectable
____ Strong

List other odors present: _____

Remarks: (odorometer reading) 0.52%

Observed By: [signature]

Location: _____

Date: _____ Time: _____

Odor Level:

____Nil
____Barely Detectable
____ Readily Detectable
____ Strong

List other odors present: _____

Remarks: (odorometer reading) _____

Observed By: _____

Kentucky Frontier Gas LLC

P.O.Box 408 * Prestonsburg, Ky. 41653* 606-886-2431 * 866-942-9427 *Fax:606-889-9196 * lrich@ec.rr.com

Kentucky FRONTIER GAS

Odorization Check Report

Location: Little Yellow House on ~~[illegible]~~ Fizpatrick Rd. (EKU)

Date: 4-16-10 Time: 10:45

Odor Level: 0.08%

____ Nil
____ Barely Detectable
✓ Readily Detectable
✓ Strong

List other odors present: _____

Remarks: (odorometer reading) 0.16%

Observed By: [illegible]

Location: 304 West Old Middle Creek Rd. (EKU)

Date: 4-16-10 Time: 11:10

Odor Level: 0.08%

____ Nil
____ Barely Detectable
✓ Readily Detectable
✓ Strong

List other odors present: _____

Remarks: (odorometer reading) 0.18%

Observed By: [illegible]

Location: May Truck Parts 1428 Allen (EKU)

Date: 4-16-10 Time: 12:00

Odor Level: 0.17%

____ Nil
____ Barely Detectable
✓ Readily Detectable
____ Strong

List other odors present: _____

Remarks: (odorometer reading) 0.24%

Observed By: [illegible]

P.O.Box 408 * Prestonsburg, Ky. 41653* 606-886-2431 * 866-942-9427 *Fax:606-889-9196 * lrich@ec.rr.com

Kentucky FRONTIER GAS

Odorization Check Report

Location: Beside Dave Flannery meter Old Allen (EKU)

Date: 4-16-10 Time: 12:30

Odor Level: 0.17%

____Nil
____Barely Detectable
✓ Readily Detectable
____ Strong

List other odors present: _____

Remarks: (odorometer reading) 0.29%

Observed By: [signature]

Location: Champs Country Cookin (EKU)

Date: 4-16-10 Time: 3:40

Odor Level: 0.17%

____Nil
____Barely Detectable
✓ Readily Detectable
____ Strong

List other odors present: _____

Remarks: (odorometer reading) 0.21%

Observed By: [signature]

Location: 3831 Mulberry LN. Hueysville KY (EKU)

Date: 4-16-10 Time: 4:30

Odor Level: 0.25%

____Nil
____Barely Detectable
____ Readily Detectable
____ Strong

List other odors present: _____

Remarks: (odorometer reading) 0.35%

Observed By: [signature]

P.O.Box 408 * Prestonsburg, Ky. 41653* 606-886-2431 * 866-942-9427 *Fax:606-889-9196 * lrich@ec.rr.com

Kentucky FRONTIER GAS

Odorization Check Report

Location: 179 Oaklawn Estates (Auxier)

Date: 4-23-10 Time: 9:10 Am

Odor Level: 0.33%

____ Nil
____ Barely Detectable
✓ Readily Detectable
____ Strong

List other odors present: ____

Remarks: (odorometer reading) 0.47%

Observed By: [signature]

Location: 27 Creekside Dr Abbott (Auxier)

Date: 4-23-10 Time: 9:50Am

Odor Level: 0.33%

____ Nil
____ Barely Detectable
✓ Readily Detectable
____ Strong

List other odors present: ____

Remarks: (odorometer reading) 0.41%

Observed By: [signature]

Location: 304 West old Middle Creek Rd (EKU)

Date: 4-23-10 Time: 1:00

Odor Level: 0.25%

____ Nil
____ Barely Detectable
____ Readily Detectable
✓ Strong

List other odors present: ____

Remarks: (odorometer reading) 0.35%

Observed By: [signature]

P.O.Box 408 * Prestonsburg, Ky. 41653* 606-886-2431 * 866-942-9427 *Fax:606-889-9196 * lrich@ec.rr.com

Kentucky FRONTIER GAS

Odorization Check Report

Location: May Truck Parts 1428 Allen (EKU)

Date: 4-23-10 Time: 1:30 pm

Odor Level: 0.33%

____ Nil
____ Barely Detectable
✓ Readily Detectable
____ Strong

List other odors present: ____

Remarks: (odorometer reading) 0.42%

Observed By: [illegible]

Location: 3831 (EKU)

Date: 4-23-10 Time: 2:15

Odor Level: 0.17%

____ Nil
____ Barely Detectable
✓ Readily Detectable
____ Strong

List other odors present: ____

Remarks: (odorometer reading) 0.23%

Observed By: [illegible]

Location: Champs Country Cookin 122 Minnie (EKU)

Date: 4-23-10 Time: 2:45

Odor Level: 0.25%

____ Nil
____ Barely Detectable
✓ Readily Detectable
____ Strong

List other odors present: ____

Remarks: (odorometer reading) 0.35%

Observed By: [illegible]

P.O.Box 408 * Prestonsburg, Ky. 41653* 606-886-2431 * 866-942-9427 *Fax:606-889-9196 * lrich@ec.rr.com

Kentucky FRONTIER GAS

Odorization Check Report

Location: 304 West Old Middle Creek Rd. (EKU)

Date: 5-21-16 Time: 3:45pm

Odor Level: 0.25%

_____Nil
_____Barely Detectable
___✓___Readily Detectable
_____ Strong

List other odors present: _____

Remarks: (odorometer reading) 0.31%

Observed By: [illegible]

Location: _____

Date: _____Time: _____

Odor Level:

_____Nil
_____Barely Detectable
_____ Readily Detectable
_____ Strong

List other odors present: _____

Remarks: (odorometer reading)_____

Observed By: _____

Location: _____

Date: _____Time: _____

Odor Level:

_____Nil
_____Barely Detectable
_____ Readily Detectable
_____ Strong

List other odors present: _____

Remarks: (odorometer reading)_____

Observed By: _____

P.O.Box 408 * Prestonsburg, Ky. 41653* 606-886-2431 * 866-942-9427 *Fax:606-889-9196 * lrich@ec.rr.com

Kentucky FRONTIER GAS

Odorization Check Report

Location: Oaklawn Estates (Auxier)

Date: 5-21-10 Time: 8:50AM

Odor Level: 0.33%

____Nil
____Barely Detectable
✓ Readily Detectable
____ Strong

List other odors present: ____

Remarks: (odorometer reading) 0.40%

Observed By: [illegible]

Location: 27 Creek side Abbott (EKU)

Date: 5-21-10 Time: 9:50AM

Odor Level: 0.25%

____Nil
____Barely Detectable
✓ Readily Detectable
____ Strong

List other odors present: ____

Remarks: (odorometer reading) 0.37%

Observed By: [illegible]

Location: Champs Country Cookin Rt 122 Minnie KY (EKU)

Date: 5-21-10 Time: 1:30

Odor Level: 0.17%

____Nil
____Barely Detectable
✓ Readily Detectable
____ Strong

List other odors present: ____

Remarks: (odorometer reading) 0.25%

Observed By: [illegible]

Kentucky Frontier Gas LLC

P.O.Box 408 * Prestonsburg, Ky. 41653* 606-886-2431 * 866-942-9427 *Fax:606-889-9196 * lrich@ec.rr.com

Kentucky FRONTIER GAS

Odorization Check Report

Location: Beside Clyde Conley Webb Br Lacky (EKU)

Date: 5-21-10 Time: 2:30pm

Odor Level: 0.17%

____Nil
____Barely Detectable
✓ Readily Detectable
____ Strong

List other odors present: [illegible]

Remarks: (odorometer reading) 0.24%

Observed By: [signature]

Location: 3831 Railroad Station Rd Irvineysville (EKU)

Date: 5-21-10 Time: 2:45pm

Odor Level: 0.25%

____Nil
____Barely Detectable
✓ Readily Detectable
____ Strong

List other odors present: ____

Remarks: (odorometer reading) 0.32%

Observed By: [signature]

Location: May Truck Parts (EKU)

Date: 5-21-10 Time: 3:16pm

Odor Level:

____Nil
____Barely Detectable
✓ Readily Detectable
____ Strong

List other odors present: ____

Remarks: (odorometer reading) ____

Observed By: [signature]

Frontier Gas LLC

P.O.Box 408 * Prestonsburg, Ky. 41653* 606-886-2431 * 866-942-9427 *Fax:606-889-9196 * lrich@ec.rr.com

Kentucky FRONTIER GAS

Odorization Check Report

Location: 304 West Middle Creek Road, EKU

Date: 6-7-10 Time: 11:45Am

Odor Level: 0.08%

____Nil
____Barely Detectable
____Readily Detectable
✓ Strong

List other odors present: _____

Remarks: (odorometer reading) 0.15%

Observed By: [signature]

Location: 3831 Salt Lick Hueysville KY 41653, EKU

Date: 6-7-10 Time: 12:45 Am

Odor Level: 0.25%

____Nil
____Barely Detectable
✓ Readily Detectable
____Strong

List other odors present: _____

Remarks: (odorometer reading) 0.34%

Observed By: [signature]

Location: May Truck Parts 1428 Allen KY, EKU

Date: 6-8-10 Time: 2:10 Pm

Odor Level: 0.25%

____Nil
____Barely Detectable
✓ Readily Detectable
____Strong

List other odors present: _____

Remarks: (odorometer reading) 0.32%

Observed By: [signature]

[illegible] LLC

P.O.Box 408 * Prestonsburg, Ky. 41653* 606-886-2431 * 866-942-9427 *Fax:606-889-9196 * lrich@ec.rr.com

Kentucky FRONTIER GAS

Odorization Check Report

Location: Champs Country Cooker, EKU

Date: 6-8-10 Time: 3:30

Odor Level: 0.25%

____ Nil
____ Barely Detectable
✓ Readily Detectable
____ Strong

List other odors present: ____

Remarks: (odorometer reading) 0.35%

Observed By: [signature]

Location: 27 Creekside Abbott KY, Auxier Road Gas

Date: 6-9-10 Time: 9:30

Odor Level: 0.33%

____ Nil
____ Barely Detectable
✓ Readily Detectable
____ Strong

List other odors present: ____

Remarks: (odorometer reading) 0.41%

Observed By: [signature]

Location: 179 Oaklawn Estates, Auxier Road Gas

Date: 6-9-10 Time: 10:10 Am

Odor Level: 0.25%

____ Nil
____ Barely Detectable
✓ Readily Detectable
____ Strong

List other odors present: ____

Remarks: (odorometer reading) 0.39%

Observed By: [signature]

Kentucky Frontier Gas, LLC

P.O.Box 408 * Prestonsburg, Ky. 41653* 606-886-2431 * 866-942-9427 *Fax:606-889-9196 * lrich@ec.rr.com

Kentucky FRONTIER GAS

Odorization Check Report

Location: 90 Roberts Dr Prestonsburg (Mike Little)

Date: 6-14-10 Time: 10:40Am

Odor Level: 0.50%

___ Nil
✓ Barely Detectable
___ Readily Detectable
___ Strong

List other odors present: ___

Remarks: (odorometer reading) 0.64%

Observed By: [signature]

Location: 245 N May St. Maytown (Mike Little)

Date: 6-14-10 Time: 1:25Pm

Odor Level: 0.08%

___ Nil
___ Barely Detectable
✓ Readily Detectable
___ Strong

List other odors present: ___

Remarks: (odorometer reading) 0.18%

Observed By: [signature]

Location: 881 Hen Pen Rd. Melvin (Mike Little)

Date: 6-14-10 Time: 3:00Pm

Odor Level: 0.17%

___ Nil
___ Barely Detectable
✓ Readily Detectable
___ Strong

List other odors present: ___

Remarks: (odorometer reading) 0.21%

Observed By: [signature]

P.O.Box 408 * Prestonsburg, Ky. 41653* 606-886-2431 * 866-942-9427 *Fax:606-889-9196 * lrich@ec.rr.com

Kentucky FRONTIER GAS

Odorization Check Report

Location: 881 Hen Pen Br. Melvin (Mike Little)

Date: 6-25-10 Time: 10:30 am

Odor Level: 0.25% MH
0.33% JW

____ Nil
____ Barely Detectable
✓ Readily Detectable
____ Strong

List other odors present: _____

Remarks: (odorometer reading) 0.30 MH, 0.45 JW

Observed By: [signature]

Location: Champs Country Cook in RT122 (EKU) Minnie

Date: 6-25-10 Time: 11:30 Am

Odor Level: 0.08% MH
0.17% JW

____ Nil
____ Barely Detectable
✓ Readily Detectable
____ Strong

List other odors present: _____

Remarks: (odorometer reading) 0.18 MH 0.26 JW

Observed By: [signature]

Location: Webb Branch Lucky (EKU)

Date: 6-25-10 Time: 12:00 pm

Odor Level: 0.33%

____ Nil
____ Barely Detectable
✓ Readily Detectable
____ Strong

List other odors present: _____

Remarks: (odorometer reading) 0.45%

Observed By: [signature]

P.O.Box 408 * Prestonsburg, Ky. 41653* 606-886-2431 * 866-942-9427 *Fax:606-889-9196 * lrich@ec.rr.com

Kentucky FRONTIER GAS

Odorization Check Report

Location: May Truck Parts 1428 Allen (EKU)

Date: 2:30 PM Time: 6-25-10

Odor Level: 0.17% MH
0.33% JW

____ Nil
____ Barely Detectable
✓ Readily Detectable
____ Strong

List other odors present: _____

Remarks: (odorometer reading) 0.24% MH 0.42% JW

Observed By: [illegible]

Location: 90 Roberts Dr Coble Roberts (mike Little)

Date: 6-25-10 Time: 2:45 P.M

Odor Level: 0.25% MH
0.33% JW

____ Nil
____ Barely Detectable
✓ Readily Detectable
____ Strong

List other odors present: _____

Remarks: (odorometer reading) 0.36% MH 0.47% JW

Observed By: [illegible]

Location: 245 N. May St. Maytown (Mike Little)

Date: 6-25-10 Time: 3:20 PM

Odor Level: 0.08% MH
0.08% JW

____ Nil
____ Barely Detectable
____ Readily Detectable
✓ Strong

List other odors present: _____

Remarks: (odorometer reading) 0.18% MH 0.19% JW

Observed By: [illegible]

P O Box 408 * Prestonsburg, Ky. 41653* 606-886-2431 * 866-942-9427 *Fax:606-889-9196 * lrich@ec.rr.com

Kentucky FRONTIER GAS

Odorization Check Report

Location: 304 west Old Middle Creek Rd (EKU)

Date: 6-25-10 Time: 4:00

Odor Level: 0.00% mH
0.08% JW

____Nil
____Barely Detectable
____Readily Detectable
✓ Strong

List other odors present: _____

Remarks: (odorometer reading) 0.09% mH 0.11% JW

Observed By: [signature]

Location: _____

Date: 6-25-10 Time: 4:30

Odor Level: 0.25% mH
0.33% JW

____Nil
____Barely Detectable
✓ Readily Detectable
____ Strong

List other odors present: _____

Remarks: (odorometer reading) 0.32% mH 0.45% JW

Observed By: [signature]

Location: _____

Date: _____ Time: _____

Odor Level:

____Nil
____Barely Detectable
____ Readily Detectable
____ Strong

List other odors present: _____

Remarks: (odorometer reading) _____

Observed By: _____

P.O Box 408 * Prestonsburg, Ky. 41653* 606-886-2431 * 866-942-9427 *Fax:606-889-9196 * lrich@ec.rr.com

Kentucky FRONTIER GAS

Odorization Check Report

Location: 333 old middlecreek Rd (EKU)

Date: 7/8/10 Time: 3:00

Odor Level: 0.18

____Nil
____Barely Detectable
____Readily Detectable
___✓Strong

List other odors present: .08%

Remarks: (odorometer reading)

Observed By: [signature]

Location: 179 Oaklawn Est. (Auxier)

Date: 7/8/10 Time: 4:10

Odor Level: .34

____Nil
____Barely Detectable
____Readily Detectable
___✓Strong

List other odors present: 0.33%

Remarks: (odorometer reading)

Observed By: [signature]

Location: _____

Date: _____ Time: _____

Odor Level:

____Nil
____Barely Detectable
____Readily Detectable
____Strong

List other odors present: _____

Remarks: (odorometer reading)

Observed By: _____

Kentucky Frontier Gas, LLC

P.O.Box 408 * Prestonsburg, Ky. 41653* 606-886-2431 * 866-942-9427 *Fax:606-889-9196 * lrich@ec.rr.com

Kentucky FRONTIER GAS

Odorization Check Report

Location: 245 N May St. Maytown (MLG)

Date: 7/8/10 Time: 12:15

Odor Level: .12

____Nil
____Barely Detectable
____Readily Detectable
✓ Strong

List other odors present: .08%

Remarks: (odorometer reading)

Observed By: [signature]

Location: 31 Johns Dr Allen (EKU)

Date: 7/8/10 Time: 2:00

Odor Level: .17

____Nil
____Barely Detectable
____Readily Detectable
✓ Strong

List other odors present: .08%

Remarks: (odorometer reading)

Observed By: [signature]

Location: 90 Roberts Dr. Goble Roberts (MLG)

Date: 7/8/10 Time: 2:20

Odor Level: .11

____Nil
____Barely Detectable
____Readily Detectable
✓ Strong

List other odors present: 0.17%

Remarks: (odorometer reading)

Observed By: [signature]

Frontier Gas LLC

P.O.Box 408 * Prestonsburg, Ky. 41653* 606-886-2431 * 866-942-9427 *Fax:606-889-9196 * lrich@ec.rr.com

Kentucky FRONTIER GAS

Odorization Check Report

Location: 30 Webb Br Lackey (EKU)

Date: 7/8/10 Time: 10:00

Odor Level: .38

_____ Nil
_____ Barely Detectable
✓ Readily Detectable
_____ Strong

List other odors present: .25%

Remarks: (odorometer reading)

Observed By: [signature]

Location: 3026 Ky Rt 466 Weeksbury (MLG)

Date: 7/8/10 Time: 11:00

Odor Level: .42

_____ Nil
_____ Barely Detectable
✓ Readily Detectable
_____ Strong

List other odors present: .33%

Remarks: (odorometer reading)

Observed By: [signature]

Location: Champs 9151 Ky Rt 122 Minnie (EKU)

Date: 7/8/10 Time: 11:40

Odor Level: .21

_____ Nil
_____ Barely Detectable
✓ Readily Detectable
_____ Strong

List other odors present: .17%

Remarks: (odorometer reading)

Observed By: [signature]

P.O.Box 408 * Prestonsburg, Ky. 41653* 606-886-2431 * 866-942-9427 *Fax:606-889-9196 * lrich@ec.rr.com

Kentucky FRONTIER GAS

Odorization Check Report

Location: 533 oldwest Middle Crk Rd (EKU)

Date: 7/1/10 Time: 2:15

Odor Level:

____Nil
____Barely Detectable
____Readily Detectable
___/___Strong

List other odors present: .17 Actual .08%

Remarks: (odorometer reading)

Observed By: [signature]

Location: 27 Creekside Dr Abbott (Auxier)

Date: 7/1/10 Time: 2:40

Odor Level:

____Nil
____Barely Detectable
___/___Readily Detectable
____Strong

List other odors present: .38 Actual .33%

Remarks: (odorometer reading)

Observed By: [signature]

Location:

Date: _____ Time: _____

Odor Level:

____Nil
____Barely Detectable
____Readily Detectable
____Strong

List other odors present:

Remarks: (odorometer reading)

Observed By:

Kentucky Frontier Gas LLC

P.O.Box 408 * Prestonsburg, Ky. 41653* 606-886-2431 * 866-942-9427 *Fax:606-889-9196 * lrich@ec.rr.com

Kentucky FRONTIER GAS

Odorization Check Report

Location: 245 N. May St. Maytown (MLG)

Date: 7/1/10 Time: 12:15

Odor Level:

____Nil
____Barely Detectable
____Readily Detectable
✓ Strong

List other odors present: .13 Actual .08 oz

Remarks: (odorometer reading)

Observed By: [signature]

Location: 31 John Dr Allen (EKD)

Date: 7/1/10 Time: 12:40

Odor Level:

____Nil
____Barely Detectable
✓ Readily Detectable
____ Strong

List other odors present: .19 Actual .08 oz

Remarks: (odorometer reading)

Observed By: [signature]

Location: 90 Roberts Dr Goble Roberts (MLG)

Date: 7/1/10 Time: 1:35

Odor Level:

____Nil
____Barely Detectable
✓ Readily Detectable
____ Strong

List other odors present: .19 Actual .08 oz

Remarks: (odorometer reading)

Observed By: [signature]

Frontier Gas LLC

P.O.Box 408 * Prestonsburg, Ky. 41653* 606-886-2431 * 866-942-9427 *Fax:606-889-9196 * lrich@ec.rr.com

Kentucky FRONTIER GAS

Odorization Check Report

Location: 31 Johns Dr Allen (EKU)

Date: 7/14/10 Time: 3:30

Odor Level: .08%

____Nil
____Barely Detectable
____Readily Detectable
__✓__ Strong

List other odors present: _____

Remarks: (odorometer reading) .19%

Observed By: [signature]

Location: 90 Roberts Dr Goble Roberts MLG

Date: 7/14/10 Time: 4:20

Odor Level: .08%

____Nil
____Barely Detectable
____Readily Detectable
____Strong

List other odors present: _____

Remarks: (odorometer reading) .18%

Observed By: [signature]

Location: _____

Date: _____ Time: _____

Odor Level:

____Nil
____Barely Detectable
____Readily Detectable
____Strong

List other odors present: _____

Remarks: (odorometer reading) _____

Observed By: _____

Kentucky Frontier Gas LLC

P.O.Box 408 * Prestonsburg, Ky. 41653* 606-886-2431 * 866-942-9427 *Fax:606-889-9196 * lrich@ec.rr.com

Kentucky FRONTIER GAS

Odorization Check Report

Ky Rt 466 3026

Location: (MLG) Number One Fork Weeklbury Ratliff & Sanders cemetary

Date: 7/1/10 Time: 10:30

Odor Level:
- ____ Nil
- ____ Barely Detectable
- ✓ Readily Detectable
- ____ Strong

List other odors present: .41 Actual .33 oz

Remarks: (odorometer reading)

Observed By: [signature]

Location: 50 Webb Br Lackey (EKU)

Date: 7/1/10 Time: 11:20

Odor Level:
- ____ Nil
- ____ Barely Detectable
- ✓ Readily Detectable
- ____ Strong

List other odors present: .36 Actual .25 oz

Remarks: (odorometer reading)

Observed By: [signature]

Location: Champs 9151 Ky Rt 122 Minnie Ky

Date: 7/1/10 Time: 11:50

Odor Level:
- ____ Nil
- ____ Barely Detectable
- ____ Readily Detectable
- ✓ Strong

List other odors present: .18 Actual .08 oz

Remarks: (odorometer reading)

Observed By: [signature]

P.O.Box 408 * Prestonsburg, Ky. 41653* 606-886-2431 * 866-942-9427 *Fax:606-889-9196 * lrich@ec.rr.com

Kentucky FRONTIER GAS

Odorization Check Report

Location: 30 Webb Dr Lackey (EKU)

Date: 7/14/10 Time: 9:55

Odor Level: .25%

____Nil
____Barely Detectable
✓ Readily Detectable
____ Strong

List other odors present: ____

Remarks: (odorometer reading) 0.38

Observed By: [signature]

Location: 3026 Ky Rt 766 Weeksbury (MLG)

Date: 7/14/10 Time: 10:40

Odor Level: .33%

____Nil
____Barely Detectable
✓ Readily Detectable
____ Strong

List other odors present: ____

Remarks: (odorometer reading) 0.43

Observed By: [signature]

Location: 9151 Ky Rt 122 Minnie (EKU)

Date: 7/14/10 Time: 11:30

Odor Level: .08%

____Nil
____Barely Detectable
✓ Readily Detectable
____ Strong

List other odors present: ____

Remarks: (odorometer reading) 0.18

Observed By: [signature]

Kentucky Frontier Gas LLC

P.O.Box 408 * Prestonsburg, Ky. 41653* 606-886-2431 * 866-942-9427 *Fax:606-889-9196 * lrich@ec.rr.com

Kentucky FRONTIER GAS

Odorization Check Report

Location: 245 N May St MayTown MLG

Date: 7/14/10 Time: 12:00

Odor Level: 0.8%

____Nil
____Barely Detectable
____Readily Detectable
✓ Strong

List other odors present: _____

Remarks: (odorometer reading) .16

Observed By: [signature]

Location: 333 old west Middle Oak Rd (EKU)

Date: 7/14/10 Time: 2:00

Odor Level: .08%

____Nil
____Barely Detectable
____Readily Detectable
✓ Strong

List other odors present: _____

Remarks: (odorometer reading) .16

Observed By: _____

Location: 179 Oaklawn Est. (Auxier)

Date: 7/14/10 Time: 2:40

Odor Level: .33%

____Nil
____Barely Detectable
✓ Readily Detectable
____Strong

List other odors present: .40

Remarks: (odorometer reading) _____

Observed By: [signature]

Kentucky Frontier Gas LLC

P.O.Box 408 * Prestonsburg, Ky. 41653* 606-886-2431 * 866-942-9427 *Fax:606-889-9196 * lrich@ec.rr.com

Kentucky FRONTIER GAS

Odorization Check Report

Location: 333 Old West Middle Crk. Rd. (EKU)

Date: 7/19/10 Time: 1:30

Odor Level: ~~.75%~~ .25%

____Nil
____Barely Detectable
____Readily Detectable
✓ Strong

List other odors present: _____

Remarks: (odorometer reading) .75%

Observed By: [signature]

Location: 31 John Dr Allen (EKU)

Date: 7/19/10 Time: 2:10

Odor Level: .25%

____Nil
____Barely Detectable
____Readily Detectable
✓ Strong

List other odors present: _____

Remarks: (odorometer reading) .75%

Observed By: [signature]

Location: 90 Roberts Dr Goble Roberts (MLG)

Date: 7/19/10 Time: 2:45

Odor Level: .25%

____Nil
____Barely Detectable
____Readily Detectable
✓ Strong

List other odors present: .75%

Remarks: (odorometer reading) _____

Observed By: [signature]

Frontier Gas LLC

P.O.Box 408 * Prestonsburg, Ky. 41653* 606-886-2431 * 866-942-9427 *Fax:606-889-9196 * lrich@ec.rr.com

Kentucky FRONTIER GAS

Odorization Check Report

Location: Weeksbury (MLG)

Date: 7/20/10 Time: 10:50 Am

Odor Level: .35%

____Nil
____Barely Detectable
____ Readily Detectable
____ Strong

List other odors present: _____

Remarks: (odorometer reading) 1.5%

Observed By: [signature]

Location: _____

Date: 7/20/10 Time: 11:35

Odor Level: .40%

____Nil
____Barely Detectable
✓ Readily Detectable
____ Strong

List other odors present: _____

Remarks: (odorometer reading) 1.75

Observed By: [signature]

Location: _____

Date: _____ Time: _____

Odor Level:

____Nil
____Barely Detectable
____ Readily Detectable
____ Strong

List other odors present: _____

Remarks: (odorometer reading) _____

Observed By: _____

Kentucky Frontier Gas LLC

P.O.Box 408 * Prestonsburg, Ky. 41653* 606-886-2431 * 866-942-9427 *Fax:606-889-9196 * lrich@ec.rr.com

Kentucky FRONTIER GAS

Odorization Check Report

Location: 27 Creekside Dr Abbott (Auxier)

Date: 7/19/10 Time: 3:30

Odor Level: .40%

____Nil
____Barely Detectable
✓ Readily Detectable
____ Strong

List other odors present: _____

Remarks: (odorometer reading) 1.75

Observed By: [signature]

Location: 245 N. May St. Maytown (MLG)

Date: 7/20/10 Time: 9:35AM

Odor Level:

____Nil
____Barely Detectable
____ Readily Detectable
____ Strong

List other odors present: Ø

Remarks: (odorometer reading) _____

Observed By: _____

Location: 9151 Ky Rt 122 Minnie EKU

Date: 7/20/10 Time: 10:10

Odor Level: .20%

____Nil
____Barely Detectable
✓ Readily Detectable
____ Strong

List other odors present: _____

Remarks: (odorometer reading) .75

Observed By: [signature]

Kentucky Frontier Gas, LLC

P.O.Box 408 * Prestonsburg, Ky. 41653* 606-886-2431 * 866-942-9427 *Fax:606-889-9196 * lrich@ec.rr.com

Kentucky FRONTIER GAS

Odorization Check Report

Location: 27 Creek Side Abbott (Auxier Road Gas)

Date: 8-12-10 Time: 10:04 Am

Odor Level: 0.25%

____Nil
____Barely Detectable
✓ Readily Detectable
____ Strong

List other odors present: _____

Remarks: (odorometer reading) 0.33%

Observed By: [signature]

Location: May Truck Parts 1428 Allen (EKU)

Date: 8-12-10 Time: 12:25 Am

Odor Level: 0.17%

____Nil
____Barely Detectable
✓ Readily Detectable
____ Strong

List other odors present: _____

Remarks: (odorometer reading) 0.24%

Observed By: [signature]

Location: 245 May St. May Town, Langley (Mike Little)

Date: 8-12-10 Time: 12:55 Pm

Odor Level: 0.33%

____Nil
____Barely Detectable
✓ Readily Detectable
____ Strong

List other odors present: _____

Remarks: (odorometer reading) 0.44%

Observed By: [signature]

P.O Box 408 * Prestonsburg, Ky 41653* 606-886-2431 * 866-942-9427 *Fax:606-889-9196 * lrich@ec.rr.com

Kentucky FRONTIER GAS

Odorization Check Report

Location: 21 Rose St. Hueysville (EKU)

Date: 8-12-10 Time: 1:35 Pm

Odor Level: 0.33%

____Nil
____Barely Detectable
✓ Readily Detectable
____ Strong

List other odors present: _____

Remarks: (odorometer reading) 0.40%

Observed By: [signature]

Location: Henpen Br. Melvin (mike Little)

Date: 8-12-10 Time: 2:50 pm

Odor Level: 0.33%

____Nil
____Barely Detectable
✓ Readily Detectable
____ Strong

List other odors present: _____

Remarks: (odorometer reading) 0.43%

Observed By: [signature]

Location: Champs Country Cookin 122 minnie (EKU)

Date: 8-12-10 Time: 3:15 pm

Odor Level: 0.25%

____Nil
____Barely Detectable
✓ Readily Detectable
____ Strong

List other odors present: _____

Remarks: (odorometer reading) 0.38%

Observed By: [signature]

P.O.Box 408 * Prestonsburg, Ky. 41653* 606-886-2431 * 866-942-9427 *Fax:606-889-9196 * lrich@ec.rr.com

Kentucky FRONTIER GAS

Odorization Check Report

Location: 304 West Old Middle Creek RD (EKU)

Date: 8-13-10 Time: 11:09AM

Odor Level: 0.08%

____Nil
____Barely Detectable
____Readily Detectable
✓ Strong

List other odors present: _____

Remarks: (odorometer reading) 0.12%

Observed By: [signature]

Location: 90 South Roberts St (Mike Little)

Date: 8-13-10 Time: 2:30

Odor Level: 0.25%

____Nil
____Barely Detectable
✓ Readily Detectable
____Strong

List other odors present: _____

Remarks: (odorometer reading) 0.36%

Observed By: [signature]

Location: _____

Date: _____ Time: _____

Odor Level:

____Nil
____Barely Detectable
____Readily Detectable
____Strong

List other odors present: _____

Remarks: (odorometer reading) _____

Observed By: _____

P.O Box 408 * Prestonsburg, Ky. 41653* 606-886-2431 * 866-942-9427 *Fax:606-889-9196 * lrich@ec.rr.com

Kentucky FRONTIER GAS

Odorization Check Report

Location: 415 May St May Town (Mike Little)

Date: 8-24-10 Time: 1:40 pm

Odor Level: 0.17%

_____ Nil
_____ Barely Detectable
✓ Readily Detectable
_____ Strong

List other odors present: _____

Remarks: (odorometer reading) 0.28%

Observed By: [illegible]

Location: 90 Roberts Dr. Goble Roberts (Mike Little)

Date: 8-24-10 Time: 2:15 pm

Odor Level: 0.17%

_____ Nil
_____ Barely Detectable
_____ Readily Detectable
_____ Strong

List other odors present: _____

Remarks: (odorometer reading) 0.25%

Observed By: [illegible]

Location: _____

Date: _____ Time: _____

Odor Level:

_____ Nil
_____ Barely Detectable
_____ Readily Detectable
_____ Strong

List other odors present: _____

Remarks: (odorometer reading) _____

Observed By: _____

P O Box 408 * Prestonsburg, Ky. 41653* 606-886-2431 * 866-942-9427 *Fax:606-889-9196 * lrich@ec.rr.com

Kentucky FRONTIER GAS

Odorization Check Report

Location: 304 West Old Middle Creek Rd (EKU)

Date: 8-24-10 Time: 8:20 Am

Odor Level: 0.08%

____Nil
____Barely Detectable
____Readily Detectable
✓ Strong

List other odors present: ____

Remarks: (odorometer reading) 0.12%

Observed By: [signature]

Location: Oaklawn (Auxier Road Gas)

Date: 8-24-10 Time: 9:05 Am

Odor Level: 0.17%

____Nil
____Barely Detectable
✓ Readily Detectable
____ Strong

List other odors present: ____

Remarks: (odorometer reading) 0.27%

Observed By: [signature]

Location: May Truck Parts 1428 Allen (EKU)

Date: 8-24-10 Time: 10:00 Am

Odor Level: 0.17%

____Nil
____Barely Detectable
✓ Readily Detectable
____ Strong

List other odors present: ____

Remarks: (odorometer reading) 0.23%

Observed By: [signature]

P O Box 408 * Prestonsburg, Ky. 41653* 606-886-2431 * 866-942-9427 *Fax:606-889-9196 * lrich@ec.rr.com

Kentucky FRONTIER GAS

Odorization Check Report

Location: Henpin Rd Melvin (mike Little)

Date: 8-24-10 Time: 12:05 PM

Odor Level: 0.25%

____ Nil
____ Barely Detectable
✓ Readily Detectable
____ Strong

List other odors present: ____

Remarks: (odorometer reading) 0.35%

Observed By: [signature]

Location: Champs Country Cooking RT 122 Minnie (EKU)

Date: 8-24-10 Time: 12:35 PM

Odor Level: 0.17%

____ Nil
____ Barely Detectable
✓ Readily Detectable
____ Strong

List other odors present: ____

Remarks: (odorometer reading) 0.27%

Observed By: [signature]

Location: Hyde Conley Webb Br. Rd (EKU)

Date: 8-24-10 Time: 1:10 PM

Odor Level 0.25%

____ Nil
____ Barely Detectable
✓ Readily Detectable
____ Strong

List other odors present: ____

Remarks: (odorometer reading) 0.35%

Observed By: [signature]

P.O.Box 408 * Prestonsburg, Ky. 41653* 606-886-2431 * 866-942-9427 *Fax:606-889-9196 * lrich@ec.rr.com

Kentucky FRONTIER GAS

Odorization Check Report

Location: 245 May St. Maytown (MLG)

Date: 1-21-11 Time: 12:35 pm

Odor Level: 0.25%

____ Nil
____ Barely Detectable
✓ Readily Detectable
____ Strong

List other odors present: ____

Remarks: (odorometer reading) .30

Observed By: [signature]

Location: Clyde Conley Webb Br. Lacky (EKU)

Date: 1-21-11 Time: 1:00 pm

Odor Level: 0.17%

____ Nil
____ Barely Detectable
____ Readily Detectable
✓ Strong

List other odors present: ____

Remarks: (odorometer reading) .24

Observed By: [signature]

Location: Mile Mark 1 Weeksbury (MLG)

Date: 1-21-11 Time: 2:20

Odor Level: 0.25%

____ Nil
____ Barely Detectable
✓ Readily Detectable
____ Strong

List other odors present: ____

Remarks: (odorometer reading) .33

Observed By: [signature]

P.O.Box 408 * Prestonsburg, Ky. 41653* 606-886-2431 * 866-942-9427 *Fax:606-889-9196 * lrich@ec.rr.com

KENTUCKY FRONTIER GAS COMPANY LLC
P.O. BOX 408
PRESTONSBURG, KY 41653

ORDER: 1663 UTILITY WORKER ISSUED: 01/21/2011
BOOK: 75 ACCOUNT: 1 OPERATOR: CUB
HOME PHONE NUMBER
GENERAL MAINTENANCE WORK PHONE NUMBER
ALL LOCATIONS SERVICE: GAS SEQ: 1
PRESTONSBURG KY 41653 APPT: _____ BETWEEN _____ & _____
LOT NUMBER: _____ TRACT NUMBER: _____ PARCEL NUMBER: _____

METER NUMBER: _____ METER SIZE: 1 METER INSTALL DATE: _____
METER LOCATION: _____

READ: _____ READ DATE: _____ LAST READ: LAST READ DATE: _____

PAST USAGE	DATE	PAST USAGE	DATE	PAST USAGE	DATE

COMMENTS:

JOB	DESCRIPTION
O	WEEKLY ODORIZATION

RESOLUTION COMMENTS:
Auxier, EKU, MLG

COMPLETION DATE: 1-21-11 TIME: 3:30 pm COMPLETED BY: [signature]

TIME STARTED: _____
TRAVEL TIME : _____
IS GAS LINE EXPOSED? YES NO MAIN SERVICE SIZE
GPS READING _____

Kentucky FRONTIER GAS

Odorization Check Report

Location: 179 Oaklawn Estates (Aux. 1)

Date: 1-21-11 Time: 10:20 Am

Odor Level: 0.25 %

____Nil
____Barely Detectable
__✓__ Readily Detectable
____ Strong

List other odors present: _____

Remarks: (odorometer reading) .37

Observed By: [signature]

Location: 304 W. Old Middle Creek Rd. (EKU)

Date: 1-21-11 Time: 11:10 Am

Odor Level: 0.17%

____Nil
____Barely Detectable
____ Readily Detectable
__✓__ Strong

List other odors present: _____

Remarks: (odorometer reading) .26

Observed By: [signature]

Location: May Truck Parts Allen (EKU)

Date: 1-21-11 Time: 11:35 Am

Odor Level: 0.17 %

____Nil
____Barely Detectable
__✓__ Readily Detectable
____ Strong

List other odors present: _____

Remarks: (odorometer reading) .27

Observed By: [signature]

P.O.Box 408 * Prestonsburg, Ky. 41653* 606-886-2431 * 866-942-9427 *Fax:606-889-9196 * lrich@ec.rr.com

Kentucky FRONTIER GAS

Odorization Check Report

Location: Shamps Country Cookin Minnie (EKU)

Date: 1-21-11 Time: 3:05 pm

Odor Level: 0.25%

_____Nil
_____Barely Detectable
✓ Readily Detectable
_____ Strong

List other odors present: _____

Remarks: (odorometer reading) .31

Observed By: [signature]

Location: _____

Date: _____Time: _____

Odor Level:

_____Nil
_____Barely Detectable
_____ Readily Detectable
_____ Strong

List other odors present: _____

Remarks: (odorometer reading)_____

Observed By: _____

Location: _____

Date: _____Time: _____

Odor Level:

_____Nil
_____Barely Detectable
_____ Readily Detectable
_____ Strong

List other odors present: _____

Remarks: (odorometer reading)_____

Observed By: _____

P.O Box 408 * Prestonsburg, Ky. 41653* 606-886-2431 * 866-942-9427 *Fax:606-889-9196 * lrich@ec.rr.com

Kentucky FRONTIER GAS

Odorization Check Report

Location: 27 Creekside Dr. Abbott (Auxier Road Gas)

Date: 3-11-11 Time: 11:01 Am

Odor Level: 0.17%

____Nil
____Barely Detectable
____Readily Detectable
✓ Strong

List other odors present: [redacted]

Remarks: (odorometer reading) [redacted] .20%

Observed By: [signature]

Location: 304 West Old Middle Creek Rd. (EKU)

Date: 3-11-11 Time: 11:30

Odor Level: 0.08%

____Nil
____Barely Detectable
____Readily Detectable
✓ Strong

List other odors present: [redacted]

Remarks: (odorometer reading) .13%

Observed By: [signature]

Location: Dave Flannery Meter old Allen (EKU)

Date: 3-11-11 Time: 12:45

Odor Level: 0.33%

____Nil
____Barely Detectable
✓ Readily Detectable
____Strong

List other odors present: [redacted]

Remarks: (odorometer reading) 0.46%

Observed By: [signature]

P O Box 408 * Prestonsburg, Ky. 41653* 606-886-2431 * 866-942-9427 *Fax:606-889-9196 * lrich@ec.rr.com

Kentucky FRONTIER GAS

Odorization Check Report

Location: Clyde Conley Webb Rd. Lackey (EKU)

Date: 3-11-11 Time: 1:30 pm

Odor Level: 0.25%

____ Nil
____ Barely Detectable
✓ Readily Detectable
____ Strong

List other odors present: ~~[illegible]~~

Remarks: (odorometer reading) .33%

Observed By: [signature]

Location: Champ's Country Cookin Minnie (EKU).

Date: 3-11-11 Time: 1:50 pm

Odor Level: 0.25%

____ Nil
____ Barely Detectable
✓ Readily Detectable
____ Strong

List other odors present: ____

Remarks: (odorometer reading) .32%

Observed By: [signature]

Location: Ratliff + Sanders Cemetary (MLG)

Date: 3-11-11 Time: 2:30 pm

Odor Level: 0.25%

____ Nil
____ Barely Detectable
____ Readily Detectable
____ Strong

List other odors present: ~~[illegible]~~ Pets C

Remarks: (odorometer reading) .32%

Observed By: [signature]

P.O.Box 408 * Prestonsburg, Ky. 41653* 606-886-2431 * 866-942-9427 *Fax:606-889-9196 * lrich@ec.rr.com

Kentucky FRONTIER GAS

Odorization Check Report

Location: 245 May St. Maytown (MLG)

Date: 3-11-11 Time: 3:30 pm

Odor Level: 0.08%

____Nil
____Barely Detectable
____Readily Detectable
✓ Strong

List other odors present: _____

Remarks: (odorometer reading) .19%

Observed By: [signature]

Location: 90 Roberts Dr Goble Roberts (MLG)

Date: 3-11-11 Time: 4:10 pm

Odor Level: 0.25%

____Nil
____Barely Detectable
✓ Readily Detectable
____Strong

List other odors present: _____

Remarks: (odorometer reading) .34%

Observed By: [signature]

Location: _____

Date: _____ Time: _____

Odor Level:

____Nil
____Barely Detectable
____Readily Detectable
____Strong

List other odors present: _____

Remarks: (odorometer reading) _____

Observed By: _____

P.O.Box 408 * Prestonsburg, Ky. 41653* 606-886-2431 * 866-942-9427 *Fax:606-889-9196 * lrich@ec.rr.com

"Sniff Test" and/or "Odorometer Test"

ODORIZATION CHECK REPORT

FORM 11

Annual Period JAN. 2010

COMPANY: DEMA GAS

Location: CLEDITH PATTON'S METER
Date: 1/4/10
Odor Level:
- Nil
- Barely Detectable
- ✓ Readily Detectable
- Strong

List other odors present: CAPTAIN 90

Remarks: (Odorometer Reading) .60

Observed By: Jaron Wesley

Location: CLEDITH PATTON'S METER
Date: 1/18/10
Odor Level:
- Nil
- Barely Detectable
- ✓ Readily Detectable
- Strong

List other odors present: CAPTAIN 90

Remarks: (Odorometer Reading) .59

Observed By: Jaron Wesley

Location: CLEDITH PATTON'S METER
Date: 1/25/10
Odor Level:
- Nil
- Barely Detectable
- ✓ Readily Detectable
- Strong

List other odors present: CAPTAIN 90

Remarks: (Odorometer Reading) .62

Observed By: Jaron Wesley

Location:
Date:
Odor Level:
- Nil
- Barely Detectable
- Readily Detectable
- Strong

List other odors present:

Remarks: (Odorometer Reading)

Observed By:

DTEX Test Log

..#	00070	COW CREEK GAS (FLOY)		User:	JASON WESLEY
Test Start Date:	01-11-10	<Blank>		Notes:	
Test Start Time:	08:32:41	<Blank>		DTEX Model:	DX1000G
TDL Result:	0.04%	PRESTONSBURG		Serial Number:	40984
RDL Result:	0.74%	KY	<Blank>	Test Error Code:	**
Test Time (Sec):	10	Altitude (ft): 0		Test Temp (C):	18

DTEX Test Log

.t #:	00075	COW CREEK (MAG CO)		User:	JASON WESLEY
Test Start Date:	01-11-10	BLOCK BUILDING		Notes:	
Test Start Time:	09:34:55	<Blank>		DTEX Model:	DX1000G
TDL Result:	0.05%	SALYERSVILLE		Serial Number:	40984
RDL Result:	0.63%	KY	41465	Test Error Code:	**
Test Time (Sec):	8	Altitude (ft): 0		Test Temp (C):	18

DTEX Test Log

Test #:	00071	COW CREEK GAS (FLOYD		User:	JASON WESLEY
Test Start Date:	01-11-10	HOME BR		Notes:	
Test Start Time:	08:42:32	<Blank>		DTEX Model:	DX1000G
TDL Result:	0.04%	PRESTONSBURG		Serial Number:	40984
RDL Result:	0.71%	KY	<Blank>	Test Error Code:	**
Test Time (Sec):	8	Altitude (ft): 0		Test Temp (C):	18

DTEX Test Log

Test #:	00074	DEMA GAS		User:	JASON WESLEY
Test Start Date:	01-11-10	CLEDITH PATTONS		Notes:	
Test Start Time:	09:34:22	<Blank>		DTEX Model:	DX1000G
TDL Result:	0.05%	TOPMOST		Serial Number:	40984
RDL Result:	0.67%	KY	<Blank>	Test Error Code:	**
Test Time (Sec):	11	Altitude (ft): 0		Test Temp (C):	18

"Sniff Test" and/or "Odorometer Test"

ODORIZATION CHECK REPORT

FORM 11

Annual Period JAN. 2010

COMPANY: COW CREEK GAS / FLOYD COUNTY

Location: COW CREEK CHURCH
Date: 1/4/10
Odor Level:
- ____ Nil
- ____ Barely Detectable
- ✓ Readily Detectable
- ____ Strong

List other odors present: CAPTAIN 90

Remarks: (Odorometer Reading) .56

Observed By: Jason Wesley

Location: COW CREEK CHURCH
Date: 1/18/10
Odor Level:
- ____ Nil
- ____ Barely Detectable
- ✓ Readily Detectable
- ____ Strong

List other odors present: CAPTAIN 90

Remarks: (Odorometer Reading) .60

Observed By: Jason Wesley

Location: COW CREEK CHURCH
Date: 1/25/10
Odor Level:
- ____ Nil
- ____ Barely Detectable
- ✓ Readily Detectable
- ____ Strong

List other odors present: CAPTAIN 90

Remarks: (Odorometer Reading) .60

Observed By: Jason Wesley

Location: ____
Date: ____
Odor Level:
- ____ Nil
- ____ Barely Detectable
- ____ Readily Detectable
- ____ Strong

List other odors present: ____

Remarks: (Odorometer Reading) ____

Observed By: ____

"Sniff Test" and/or "Odorometer Test"
ODORIZATION CHECK REPORT

FORM 11

Annual Period JAN. 2010

COMPANY: COW CREEK GAS / FLOYD COUNTY

Location: HOME BRANCH
Date: 1/4/10
Odor Level:
- Nil
- Barely Detectable
- ✓ Readily Detectable
- Strong

List other odors present: CAPTAIN 90

Remarks: (Odorometer Reading) .60

Observed By: Jason Wesley

Location: HOME BRANCH
Date: 1/18/10
Odor Level:
- Nil
- Barely Detectable
- ✓ Readily Detectable
- Strong

List other odors present: CAPTAIN 90

Remarks: (Odorometer Reading) .57

Observed By: Jason Wesley

Location: HOME BRANCH
Date: 1/25/10
Odor Level:
- Nil
- Barely Detectable
- ✓ Readily Detectable
- Strong

List other odors present: CAPTAIN 90

Remarks: (Odorometer Reading) .58

Observed By: Jason Wesley

Location:
Date:
Odor Level:
- Nil
- Barely Detectable
- Readily Detectable
- Strong

List other odors present:

Remarks: (Odorometer Reading)

Observed By:

"Sniff Test" and/or "Odorometer Test"

ODORIZATION CHECK REPORT

FORM 11

Annual Period JAN. 2010

COMPANY: COW CREEK GAS / MAGOFFIN COUNTY

Location: BLOCK BUILDING
Date: 1/4/10
Odor Level:
- Nil
- Barely Detectable
- ✓ Readily Detectable
- Strong

List other odors present: CAPTAIN 90

Remarks: (Odorometer Reading) .58

Observed By: Jason Wesley

Location: BLOCK BUILDING
Date: 1/18/10
Odor Level:
- Nil
- Barely Detectable
- ✓ Readily Detectable
- Strong

List other odors present: CAPTAIN 90

Remarks: (Odorometer Reading) .61

Observed By: Jason Wesley

Location: BLOCK BUILDING
Date: 1/25/10
Odor Level:
- Nil
- Barely Detectable
- ✓ Readily Detectable
- Strong

List other odors present: CAPTAIN 90

Remarks: (Odorometer Reading) .59

Observed By: Jason Wesley

Location:
Date:
Odor Level:
- Nil
- Barely Detectable
- Readily Detectable
- Strong

List other odors present:

Remarks: (Odorometer Reading)

Observed By:

"Sniff Test" and/or "Odorometer Test"

ODORIZATION CHECK REPORT

FORM 11

Annual Period FEB. 2010

COMPANY: DEMA GAS

Location: CLEDITH PATTON'S METER
Date: 2/5/10
Odor Level:
- Nil
- Barely Detectable
- ✓ Readily Detectable
- Strong

List other odors present: CAPTAIN 90

Remarks: (Odorometer Reading) .59

Observed By: Jason Wesley

Location: CLEDITH PATTON'S METER
Date: 2/10/10
Odor Level:
- Nil
- Barely Detectable
- ✓ Readily Detectable
- Strong

List other odors present: CAPTAIN 90

Remarks: (Odorometer Reading) .58

Observed By: Jason Wesley

Location: CLEDITH PATTON'S METER
Date: 2/18/10
Odor Level:
- Nil
- Barely Detectable
- ✓ Readily Detectable
- Strong

List other odors present: CAPTAIN 90

Remarks: (Odorometer Reading) .57

Observed By: Jason Wesley

Location: CLEDITH PATTON'S METER
Date: 2/26/10
Odor Level:
- Nil
- Barely Detectable
- ✓ Readily Detectable
- Strong

List other odors present: CAPTAIN 90

Remarks: (Odorometer Reading) .58

Observed By: Jason Wesley

"Sniff Test" and/or "Odorometer Test"

ODORIZATION CHECK REPORT

FORM 11

Annual Period FEB. 2010

COMPANY: COW CREEK GAS / FLOYD COUNTY

Location: HOME BRANCH
Date: 2/5/10
Odor Level:
- Nil
- Barely Detectable
- ✓ Readily Detectable
- Strong

List other odors present: CAPTAIN 90

Remarks: (Odorometer Reading) .59

Observed By: Jason Werley

Location: HOME BRANCH
Date: 2/10/10
Odor Level:
- Nil
- Barely Detectable
- ✓ Readily Detectable
- Strong

List other odors present: CAPTAIN 90

Remarks: (Odorometer Reading) .61

Observed By: Jason Werley

Location: HOME BRANCH
Date: 2/18/10
Odor Level:
- Nil
- Barely Detectable
- ✓ Readily Detectable
- Strong

List other odors present: CAPTAIN 90

Remarks: (Odorometer Reading) .58

Observed By: Jason Werley

Location: HOME BRANCH
Date: 2/26/10
Odor Level:
- Nil
- Barely Detectable
- ✓ Readily Detectable
- Strong

List other odors present: CAPTAIN 90

Remarks: (Odorometer Reading) .59

Observed By: Jason Werley

"Sniff Test" and/or "Odorometer Test"

ODORIZATION CHECK REPORT

FORM 11

Annual Period MARCH 2010

COMPANY: COW CREEK GAS/FLOYD COUNTY

Location: COW CREEK CHURCH
Date: 3/5/10
Odor Level:
- Nil
- Barely Detectable
- ✓ Readily Detectable
- Strong

List other odors present: CAPTAIN 90

Remarks: (Odorometer Reading) .59

Observed By: [signature]

Location: COW CREEK CHURCH
Date: 3/12/10
Odor Level:
- Nil
- Barely Detectable
- ✓ Readily Detectable
- Strong

List other odors present: CAPTAIN 90

Remarks: (Odorometer Reading) .62

Observed By: [signature]

Location:
Date:
Odor Level:
- Nil
- Barely Detectable
- Readily Detectable
- Strong

List other odors present:

Remarks: (Odorometer Reading)

Observed By:

Location:
Date:
Odor Level:
- Nil
- Barely Detectable
- Readily Detectable
- Strong

List other odors present:

Remarks: (Odorometer Reading)

Observed By:

"Sniff Test" and/or "Odorometer Test"
ODORIZATION CHECK REPORT

FORM 11

Annual Period FEB. 2010

COMPANY: COW CREEK GAS / MAGOFFIN COUNTY

Location: BLOCK BUILDING
Date: 2/5/10
Odor Level:
- Nil
- Barely Detectable
- ✓ Readily Detectable
- Strong

List other odors present: CAPTAIN 90

Remarks: (Odorometer Reading) .57

Observed By: Jason Worley

Location: BLOCK BUILDING
Date: 2/10/10
Odor Level:
- Nil
- Barely Detectable
- ✓ Readily Detectable
- Strong

List other odors present: CAPTAIN 90

Remarks: (Odorometer Reading) .60

Observed By: Jason Worley

Location: BLOCK BUILDING
Date: 2/18/10
Odor Level:
- Nil
- Barely Detectable
- ✓ Readily Detectable
- Strong

List other odors present: CAPTAIN 90

Remarks: (Odorometer Reading) .57

Observed By: Jason Worley

Location: BLOCK BUILDING
Date: 2/26/10
Odor Level:
- Nil
- Barely Detectable
- ✓ Readily Detectable
- Strong

List other odors present: CAPTAIN 90

Remarks: (Odorometer Reading) .58

Observed By: Jason Worley

"Sniff Test" and/or "Odorometer Test"

ODORIZATION CHECK REPORT

FORM 11

Annual Period MARCH 2010

COMPANY: COW CREEK GAS / FLOYD COUNTY

Location: HOME BRANCH
Date: 3/5/10
Odor Level:
- ___ Nil
- ___ Barely Detectable
- ✓ Readily Detectable
- ___ Strong

List other odors present: CAPTAIN 90

Remarks: (Odorometer Reading) .62

Observed By: [signature]

Location: HOME BRANCH
Date: 3/12/10
Odor Level:
- ___ Nil
- ___ Barely Detectable
- ✓ Readily Detectable
- ___ Strong

List other odors present: CAPTAIN 90

Remarks: (Odorometer Reading) .60

Observed By: [signature]

Location:
Date:
Odor Level:
- ___ Nil
- ___ Barely Detectable
- ___ Readily Detectable
- ___ Strong

List other odors present:

Remarks: (Odorometer Reading)

Observed By:

Location:
Date:
Odor Level:
- ___ Nil
- ___ Barely Detectable
- ___ Readily Detectable
- ___ Strong

List other odors present:

Remarks: (Odorometer Reading)

Observed By:

"Sniff Test" and/or "Odorometer Test"

ODORIZATION CHECK REPORT

FORM 11

Annual Period MARCH 2010

COMPANY: COW CR. GAS / MAGOFFIN COUNTY

Location: BLOCK BUILDING
Date: 3/5/10
Odor Level:
- ____ Nil
- ____ Barely Detectable
- ✓ Readily Detectable
- ____ Strong

List other odors present: CAPTAIN 90

Remarks: (Odorometer Reading) .59

Observed By: Jason Wesley

Location: BLOCK BUILDING
Date: 3/12/10
Odor Level:
- ____ Nil
- ____ Barely Detectable
- ✓ Readily Detectable
- ____ Strong

List other odors present: CAPTAIN 90

Remarks: (Odorometer Reading) .61

Observed By: Jason Wesley

Location: ____
Date: ____
Odor Level:
- ____ Nil
- ____ Barely Detectable
- ____ Readily Detectable
- ____ Strong

List other odors present: ____

Remarks: (Odorometer Reading) ____

Observed By: ____

Location: ____
Date: ____
Odor Level:
- ____ Nil
- ____ Barely Detectable
- ____ Readily Detectable
- ____ Strong

List other odors present: ____

Remarks: (Odorometer Reading) ____

Observed By: ____

"Sniff Test" and/or "Odorometer Test"

ODORIZATION CHECK REPORT

FORM 11

Annual Period FEB. 2010

COMPANY: COW CREEK GAS/FLOYD COUNTY

Location: COW CREEK CHURCH
Date: 2/5/10
Odor Level:
- Nil
- Barely Detectable
- ✓ Readily Detectable
- Strong

List other odors present: CAPTAIN 90

Remarks: (Odorometer Reading) .59

Observed By: Jason Wesley

Location: COW CREEK CHURCH
Date: 2/10/10
Odor Level:
- Nil
- Barely Detectable
- ✓ Readily Detectable
- Strong

List other odors present: CAPTAIN 90

Remarks: (Odorometer Reading) .58

Observed By: Jason Wesley

Location: COW CREEK CHURCH
Date: 2/18/10
Odor Level:
- Nil
- Barely Detectable
- ✓ Readily Detectable
- Strong

List other odors present: CAPTAIN 90

Remarks: (Odorometer Reading) .61

Observed By: Jason Wesley

Location: COW CREEK CHURCH
Date: 2/26/10
Odor Level:
- Nil
- Barely Detectable
- ✓ Readily Detectable
- Strong

List other odors present: CAPTAIN 90

Remarks: (Odorometer Reading) .61

Observed By: Jason Wesley

"Sniff Test" and/or "Odorometer Test"

ODORIZATION CHECK REPORT

FORM 11

Annual Period MARCH 2010

COMPANY: DEMA GAS

Location: CLEDITH PATTON'S METER
Date: 3/5/10
Odor Level:
- ____ Nil
- ____ Barely Detectable
- ✓ Readily Detectable
- ____ Strong

List other odors present: CAPTAIN 90

Remarks: (Odorometer Reading) .59

Observed By: [signature]

Location: CLEDITH PATTON'S METER
Date: 3/12/10
Odor Level:
- ____ Nil
- ____ Barely Detectable
- ✓ Readily Detectable
- ____ Strong

List other odors present: CAPTAIN 90

Remarks: (Odorometer Reading) .61

Observed By: [signature]

Location: ____
Date: ____
Odor Level:
- ____ Nil
- ____ Barely Detectable
- ____ Readily Detectable
- ____ Strong

List other odors present: ____

Remarks: (Odorometer Reading) ____

Observed By: ____

Location: ____
Date: ____
Odor Level:
- ____ Nil
- ____ Barely Detectable
- ____ Readily Detectable
- ____ Strong

List other odors present: ____

Remarks: (Odorometer Reading) ____

Observed By: ____

DTEX Test Log

[illegible]	00001	COW CREEK GAS (FLOY)		User:	JASON WESLEY
[illegible] Start Date:	04-15-10	<Blank>		Notes:	
Test Start Time:	08:31:20	<Blank>		DTEX Model:	DX1000G
TDL Result:	0.01%	PRESTONSBURG		Serial Number:	40984
RDL Result:	0.91%	KY	<Blank>	Test Error Code:	**
Test Time (Sec):	69	Altitude (ft): 0		Test Temp (C):	22

Test #:	00002	COW CREEK GAS (FLOY)		User:	JASON WESLEY
Test Start Date:	04-15-10	<Blank>		Notes:	
Test Start Time:	08:32:54	<Blank>		DTEX Model:	DX1000G
TDL Result:	0.05%	PRESTONSBURG		Serial Number:	40984
RDL Result:	0.69%	KY	<Blank>	Test Error Code:	**
Test Time (Sec):	13	Altitude (ft): 0		Test Temp (C):	22

Test #:	00003	COW CREEK GAS (FLOY)		User:	JASON WESLEY
Test Start Date:	04-15-10	<Blank>		Notes:	
Test Start Time:	08:33:32	<Blank>		DTEX Model:	DX1000G
TDL Result:	0.03%	PRESTONSBURG		Serial Number:	40984
RDL Result:	0.63%	KY	<Blank>	Test Error Code:	**
Test Time (Sec):	13	Altitude (ft): 0		Test Temp (C):	22

Test #:	00004	COW CREEK GAS (FLOYD		User:	JASON WESLEY
Test Start Date:	04-15-10	HOME BR		Notes:	
[illegible]t Start Time:	08:42:42	<Blank>		DTEX Model:	DX1000G
[illegible] Result:	0.03%	PRESTONSBURG		Serial Number:	40984
[illegible] Result:	0.67%	KY	<Blank>	Test Error Code:	**
Test Time (Sec):	11	Altitude (ft): 0		Test Temp (C):	24

Test #:	00005	DEMA GAS		User:	JASON WESLEY
Test Start Date:	04-15-10	CLEDITH PATTONS		Notes:	
Test Start Time:	09:39:34	<Blank>		DTEX Model:	DX1000G
TDL Result:	0.03%	TOPMOST		Serial Number:	40984
RDL Result:	0.71%	KY	<Blank>	Test Error Code:	**
Test Time (Sec):	16	Altitude (ft): 0		Test Temp (C):	24

Test #:	00006	DEMA GAS		User:	JASON WESLEY
Test Start Date:	04-15-10	CLEDITH PATTONS		Notes:	
Test Start Time:	09:40:17	<Blank>		DTEX Model:	DX1000G
TDL Result:	0.07%	TOPMOST		Serial Number:	40984
RDL Result:	0.93%	KY	<Blank>	Test Error Code:	**
Test Time (Sec):	13	Altitude (ft): 0		Test Temp (C):	24

Test #:	00007	DEMA GAS		User:	JASON WESLEY
Test Start Date:	04-15-10	CLEDITH PATTONS		Notes:	
Test Start Time:	09:40:50	<Blank>		DTEX Model:	DX1000G
TDL Result:	0.05%	TOPMOST		Serial Number:	40984
RDL Result:	0.77%	KY	<Blank>	Test Error Code:	**
Test Time (Sec):	10	Altitude (ft): 0		Test Temp (C):	24

[illegible]	00008	COW CREEK (MAG.CO.)		User:	JASON WESLEY
[illegible] Start Date:	04-15-10	BLOCK BUILDING		Notes:	
Test Start Time:	11:55:01	<Blank>		DTEX Model:	DX1000G
TDL Result:	0.01%	SALYERSVILLE		Serial Number:	40984
RDL Result:	0.23%	KY	41465	Test Error Code:	**
Test Time (Sec):	16	Altitude (ft): 0		Test Temp (C):	26

Test #:	00009	COW CREEK (MAG.CO.)		User:	JASON WESLEY
Test Start Date:	04-15-10	BLOCK BUILDING		Notes:	
Test Start Time:	11:56:26	<Blank>		DTEX Model:	DX1000G
TDL Result:	0.01%	SALYERSVILLE		Serial Number:	40984
RDL Result:	0.34%	KY	41465	Test Error Code:	**
Test Time (Sec):	15	Altitude (ft): 0		Test Temp (C):	26

Test #:	00010	COW CREEK (MAG.CO.)		User:	JASON WESLEY
Test Start Date:	04-15-10	BLOCK BUILDING		Notes:	
Test Start Time:	11:57:00	<Blank>		DTEX Model:	DX1000G
TDL Result:	0.13%	SALYERSVILLE		Serial Number:	40984
RDL Result:	0.80%	KY	41465	Test Error Code:	**
Test Time (Sec):	16	Altitude (ft): 0		Test Temp (C):	26

Test #:	00011	COW CREEK (MAG.CO.)		User:	JASON WESLEY
Test Start Date:	04-15-10	BLOCK BUILDING		Notes:	
[illegible] Start Time:	11:57:36	<Blank>		DTEX Model:	DX1000G
[illegible] Result:	0.07%	SALYERSVILLE		Serial Number:	40984
[illegible] Result:	0.44%	KY	41465	Test Error Code:	**
Test Time (Sec):	12	Altitude (ft): 0		Test Temp (C):	26

Test #:	00012	COW CREEK (MAG.CO.)		User:	JASON WESLEY
Test Start Date:	04-15-10	BLOCK BUILDING		Notes:	
Test Start Time:	11:58:07	<Blank>		DTEX Model:	DX1000G
TDL Result:	0.04%	SALYERSVILLE		Serial Number:	40984
RDL Result:	0.61%	KY	41465	Test Error Code:	**
Test Time (Sec):	13	Altitude (ft): 0		Test Temp (C):	26

Test #:	00013	COW CREEK GAS (FLOY)		User:	JASON WESLEY
Test Start Date:	04-23-10	<Blank>		Notes:	
Test Start Time:	09:36:33	<Blank>		DTEX Model:	DX1000G
TDL Result:	0.01%	PRESTONSBURG		Serial Number:	40984
RDL Result:	0.48%	KY	<Blank>	Test Error Code:	**
Test Time (Sec):	16	Altitude (ft): 0		Test Temp (C):	17

Test #:	00014	COW CREEK GAS (FLOY)		User:	JASON WESLEY
Test Start Date:	04-23-10	<Blank>		Notes:	
Test Start Time:	09:37:07	<Blank>		DTEX Model:	DX1000G
TDL Result:	0.07%	PRESTONSBURG		Serial Number:	40984
RDL Result:	0.64%	KY	<Blank>	Test Error Code:	**
Test Time (Sec):	11	Altitude (ft): 0		Test Temp (C):	17

	00015	COW CREEK GAS (FLOY)		User:	JASON WESLEY
Te.. Start Date:	04-23-10	<Blank>		Notes:	
Test Start Time:	09:37:39	<Blank>		DTEX Model:	DX1000G
TDL Result:	0.03%	PRESTONSBURG		Serial Number:	40984
RDL Result:	0.53%	KY	<Blank>	Test Error Code:	**
Test Time (Sec):	11	Altitude (ft): 0		Test Temp (C):	17

Test #:	00016	COW CREEK GAS (FLOYD		User:	JASON WESLEY
Test Start Date:	04-23-10	HOME BR		Notes:	
Test Start Time:	09:54:24	<Blank>		DTEX Model:	DX1000G
TDL Result:	0.02%	PRESTONSBURG		Serial Number:	40984
RDL Result:	0.43%	KY	<Blank>	Test Error Code:	**
Test Time (Sec):	10	Altitude (ft): 0		Test Temp (C):	18

Test #:	00017	COW CREEK GAS (FLOYD		User:	JASON WESLEY
Test Start Date:	04-23-10	HOME BR		Notes:	
Test Start Time:	09:54:51	<Blank>		DTEX Model:	DX1000G
TDL Result:	0.03%	PRESTONSBURG		Serial Number:	40984
RDL Result:	0.63%	KY	<Blank>	Test Error Code:	**
Test Time (Sec):	12	Altitude (ft): 0		Test Temp (C):	18

Test #:	00018	COW CREEK (MAG.CO.)		User:	JASON WESLEY
Test Start Date:	04-23-10	BLOCK BUILDING		Notes:	
Test Start Time:	13:00:32	<Blank>		DTEX Model:	DX1000G
TDL Result:	0.02%	SALYERSVILLE		Serial Number:	40984
RDL Result:	0.59%	KY	41465	Test Error Code:	**
Test Time (Sec):	14	Altitude (ft): 0		Test Temp (C):	16

Test #:	00019	COW CREEK (MAG.CO.)		User:	JASON WESLEY
Test Start Date:	04-23-10	BLOCK BUILDING		Notes:	
Test Start Time:	13:01:04	<Blank>		DTEX Model:	DX1000G
TDL Result:	0.05%	SALYERSVILLE		Serial Number:	40984
RDL Result:	0.58%	KY	41465	Test Error Code:	**
Test Time (Sec):	8	Altitude (ft): 0		Test Temp (C):	16

Test #:	00020	COW CREEK (MAG.CO.)		User:	JASON WESLEY
Test Start Date:	04-23-10	BLOCK BUILDING		Notes:	
Test Start Time:	13:01:30	<Blank>		DTEX Model:	DX1000G
TDL Result:	0.04%	SALYERSVILLE		Serial Number:	40984
RDL Result:	0.68%	KY	41465	Test Error Code:	**
Test Time (Sec):	10	Altitude (ft): 0		Test Temp (C):	16

Test #:	00021	DEMA GAS		User:	JASON WESLEY
Test Start Date:	04-23-10	CLEDITH PATTONS		Notes:	
Test Start Time:	15:44:33	<Blank>		DTEX Model:	DX1000G
TDL Result:	0.04%	TOPMOST		Serial Number:	40984
RDL Result:	0.65%	KY	<Blank>	Test Error Code:	**
Test Time (Sec):	9	Altitude (ft): 0		Test Temp (C):	17

[illegible]:	00022	COW CREEK GAS (FLOY)		User:	JASON WESLEY
[illegible] Start Date:	04-30-10	<Blank>		Notes:	
Test Start Time:	08:27:57	<Blank>		DTEX Model:	DX1000G
TDL Result:	0.02%	PRESTONSBURG		Serial Number:	40984
RDL Result:	0.46%	KY	<Blank>	Test Error Code:	**
Test Time (Sec):	11	Altitude (ft): 0		Test Temp (C):	14

Test #:	00023	COW CREEK GAS (FLOY)		User:	JASON WESLEY
Test Start Date:	04-30-10	<Blank>		Notes:	
Test Start Time:	08:28:25	<Blank>		DTEX Model:	DX1000G
TDL Result:	0.03%	PRESTONSBURG		Serial Number:	40984
RDL Result:	0.72%	KY	<Blank>	Test Error Code:	**
Test Time (Sec):	12	Altitude (ft): 0		Test Temp (C):	14

Test #:	00024	COW CREEK GAS (FLOY)		User:	JASON WESLEY
Test Start Date:	04-30-10	<Blank>		Notes:	
Test Start Time:	08:29:10	<Blank>		DTEX Model:	DX1000G
TDL Result:	0.01%	PRESTONSBURG		Serial Number:	40984
RDL Result:	0.53%	KY	<Blank>	Test Error Code:	**
Test Time (Sec):	9	Altitude (ft): 0		Test Temp (C):	14

Test #:	00025	COW CREEK GAS (FLOY)		User:	JASON WESLEY
Test Start Date:	04-30-10	<Blank>		Notes:	
[illegible]t Start Time:	08:29:36	<Blank>		DTEX Model:	DX1000G
[illegible] Result:	0.04%	PRESTONSBURG		Serial Number:	40984
[illegible] Result:	0.72%	KY	<Blank>	Test Error Code:	**
Test Time (Sec):	10	Altitude (ft): 0		Test Temp (C):	14

Test #:	00026	COW CREEK GAS (FLOYD		User:	JASON WESLEY
Test Start Date:	04-30-10	HOME BR		Notes:	
Test Start Time:	08:42:12	<Blank>		DTEX Model:	DX1000G
TDL Result:	0.03%	PRESTONSBURG		Serial Number:	40984
RDL Result:	0.54%	KY	<Blank>	Test Error Code:	**
Test Time (Sec):	16	Altitude (ft): 0		Test Temp (C):	16

Test #:	00027	COW CREEK GAS (FLOYD		User:	JASON WESLEY
Test Start Date:	04-30-10	HOME BR		Notes:	
Test Start Time:	08:42:44	<Blank>		DTEX Model:	DX1000G
TDL Result:	0.04%	PRESTONSBURG		Serial Number:	40984
RDL Result:	0.63%	KY	<Blank>	Test Error Code:	**
Test Time (Sec):	9	Altitude (ft): 0		Test Temp (C):	16

Test #:	00028	DEMA GAS		User:	JASON WESLEY
Test Start Date:	04-30-10	CLEDITH PATTONS		Notes:	
Test Start Time:	10:22:17	<Blank>		DTEX Model:	DX1000G
TDL Result:	0.05%	TOPMOST		Serial Number:	40984
RDL Result:	0.58%	KY	<Blank>	Test Error Code:	**
Test Time (Sec):	11	Altitude (ft): 0		Test Temp (C):	18

[illegible]	00029	DEMA GAS		User:	JASON WESLEY
[illegible] Start Date:	04-30-10	CLEDITH PATTONS		Notes:	
Test Start Time:	10:22:45	<Blank>		DTEX Model:	DX1000G
TDL Result:	0.04%	TOPMOST		Serial Number:	40984
RDL Result:	0.85%	KY	<Blank>	Test Error Code:	**
Test Time (Sec):	9	Altitude (ft): 0		Test Temp (C):	18

Test #:	00030	DEMA GAS		User:	JASON WESLEY
Test Start Date:	04-30-10	CLEDITH PATTONS		Notes:	
Test Start Time:	10:23:13	<Blank>		DTEX Model:	DX1000G
TDL Result:	0.03%	TOPMOST		Serial Number:	40984
RDL Result:	0.55%	KY	<Blank>	Test Error Code:	**
Test Time (Sec):	8	Altitude (ft): 0		Test Temp (C):	18

Test #:	00031	DEMA GAS		User:	JASON WESLEY
Test Start Date:	04-30-10	CLEDITH PATTONS		Notes:	
Test Start Time:	10:23:55	<Blank>		DTEX Model:	DX1000G
TDL Result:	0.04%	TOPMOST		Serial Number:	40984
RDL Result:	0.69%	KY	<Blank>	Test Error Code:	**
Test Time (Sec):	11	Altitude (ft): 0		Test Temp (C):	18

Test #:	00032	COW CREEK (MAG.CO.)		User:	JASON WESLEY
Test Start Date:	04-30-10	BLOCK BUILDING		Notes:	
[illegible] Start Time:	12:38:05	<Blank>		DTEX Model:	DX1000G
[illegible] Result:	0.03%	SALYERSVILLE		Serial Number:	40984
[illegible] Result:	0.50%	KY	41465	Test Error Code:	**
Test Time (Sec):	8	Altitude (ft): 0		Test Temp (C):	24

Test #:	00033	COW CREEK (MAG.CO.)		User:	JASON WESLEY
Test Start Date:	04-30-10	BLOCK BUILDING		Notes:	
Test Start Time:	12:38:30	<Blank>		DTEX Model:	DX1000G
TDL Result:	0.03%	SALYERSVILLE		Serial Number:	40984
RDL Result:	0.81%	KY	41465	Test Error Code:	**
Test Time (Sec):	12	Altitude (ft): 0		Test Temp (C):	24

Test #:	00034	COW CREEK (MAG.CO.)		User:	JASON WESLEY
Test Start Date:	04-30-10	BLOCK BUILDING		Notes:	
Test Start Time:	12:39:12	<Blank>		DTEX Model:	DX1000G
TDL Result:	0.04%	SALYERSVILLE		Serial Number:	40984
RDL Result:	0.62%	KY	41465	Test Error Code:	**
Test Time (Sec):	86	Altitude (ft): 0		Test Temp (C):	24

Test #:	00035	COW CREEK GAS (FLOY)		User:	JASON WESLEY
Test Start Date:	05-07-10	<Blank>		Notes:	
Test Start Time:	10:07:30	<Blank>		DTEX Model:	DX1000G
TDL Result:	0.02%	PRESTONSBURG		Serial Number:	40984
RDL Result:	0.50%	KY	<Blank>	Test Error Code:	**
Test Time (Sec):	10	Altitude (ft): 0		Test Temp (C):	24

[illegible]	00036	COW CREEK GAS (FLOY)		User:	JASON WESLEY
[illegible] Start Date:	05-07-10	<Blank>		Notes:	
Test Start Time:	10:07:56	<Blank>		DTEX Model:	DX1000G
TDL Result:	0.02%	PRESTONSBURG		Serial Number:	40984
RDL Result:	0.68%	KY	<Blank>	Test Error Code:	**
Test Time (Sec):	14	Altitude (ft): 0		Test Temp (C):	24

Test #:	00037	COW CREEK GAS (FLOYD		User:	JASON WESLEY
Test Start Date:	05-07-10	HOME BR		Notes:	
Test Start Time:	10:25:57	<Blank>		DTEX Model:	DX1000G
TDL Result:	0.02%	PRESTONSBURG		Serial Number:	40984
RDL Result:	0.48%	KY	<Blank>	Test Error Code:	**
Test Time (Sec):	15	Altitude (ft): 0		Test Temp (C):	24

Test #:	00038	COW CREEK GAS (FLOYD		User:	JASON WESLEY
Test Start Date:	05-07-10	HOME BR		Notes:	
Test Start Time:	10:26:29	<Blank>		DTEX Model:	DX1000G
TDL Result:	0.04%	PRESTONSBURG		Serial Number:	40984
RDL Result:	0.72%	KY	<Blank>	Test Error Code:	**
Test Time (Sec):	8	Altitude (ft): 0		Test Temp (C):	24

Test #:	00039	COW CREEK GAS (FLOYD		User:	JASON WESLEY
Test Start Date:	05-07-10	HOME BR		Notes:	
[illegible] Start Time:	10:26:56	<Blank>		DTEX Model:	DX1000G
[illegible] Result:	0.05%	PRESTONSBURG		Serial Number:	40984
[illegible] Result:	0.63%	KY	<Blank>	Test Error Code:	**
Test Time (Sec):	10	Altitude (ft): 0		Test Temp (C):	24

Test #:	00040	DEMÀ GAS		User:	JASON WESLEY
Test Start Date:	05-07-10	CLEDITH PATTONS		Notes:	
Test Start Time:	12:03:08	<Blank>		DTEX Model:	DX1000G
TDL Result:	0.02%	TOPMOST		Serial Number:	40984
RDL Result:	0.66%	KY	<Blank>	Test Error Code:	**
Test Time (Sec):	13	Altitude (ft): 0		Test Temp (C):	25

Test #:	00041	COW CREEK (MAG.CO.)		User:	JASON WESLEY
Test Start Date:	05-07-10	BLOCK BUILDING		Notes:	
Test Start Time:	12:30:01	<Blank>		DTEX Model:	DX1000G
TDL Result:	0.01%	SALYERSVILLE		Serial Number:	40984
RDL Result:	0.38%	KY	41465	Test Error Code:	**
Test Time (Sec):	12	Altitude (ft): 0		Test Temp (C):	26

Test #:	00042	COW CREEK (MAG.CO.)		User:	JASON WESLEY
Test Start Date:	05-07-10	BLOCK BUILDING		Notes:	
Test Start Time:	12:30:29	<Blank>		DTEX Model:	DX1000G
TDL Result:	0.02%	SALYERSVILLE		Serial Number:	40984
RDL Result:	0.58%	KY	41465	Test Error Code:	**
Test Time (Sec):	9	Altitude (ft): 0		Test Temp (C):	26

[illegible]t:	00043	COW CREEK (MAG.CO.)		User:	JASON WESLEY
[illegible] Start Date:	05-07-10	BLOCK BUILDING		Notes:	
Test Start Time:	12:30:55	<Blank>		DTEX Model:	DX1000G
TDL Result:	0.06%	SALYERSVILLE		Serial Number:	40984
RDL Result:	0.69%	KY	41465	Test Error Code:	**
Test Time (Sec):	9	Altitude (ft): 0		Test Temp (C):	26

Test #:	00044	COW CREEK (MAG.CO.)		User:	JASON WESLEY
Test Start Date:	05-07-10	BLOCK BUILDING		Notes:	
Test Start Time:	12:31:24	<Blank>		DTEX Model:	DX1000G
TDL Result:	0.04%	SALYERSVILLE		Serial Number:	40984
RDL Result:	0.64%	KY	41465	Test Error Code:	**
Test Time (Sec):	10	Altitude (ft): 0		Test Temp (C):	26

Test #:	00045	COW CREEK GAS (FLOY)		User:	JASON WESLEY
Test Start Date:	05-14-10	<Blank>		Notes:	
Test Start Time:	08:02:39	<Blank>		DTEX Model:	DX1000G
TDL Result:	0.04%	PRESTONSBURG		Serial Number:	40984
RDL Result:	0.75%	KY	<Blank>	Test Error Code:	**
Test Time (Sec):	15	Altitude (ft): 0		Test Temp (C):	24

Test #:	00046	COW CREEK GAS (FLOY)		User:	JASON WESLEY
Test Start Date:	05-14-10	<Blank>		Notes:	
[illegible] Start Time:	08:03:12	<Blank>		DTEX Model:	DX1000G
[illegible] Result:	0.04%	PRESTONSBURG		Serial Number:	40984
[illegible] Result:	0.88%	KY	<Blank>	Test Error Code:	**
Test Time (Sec):	12	Altitude (ft): 0		Test Temp (C):	24

Test #:	00047	COW CREEK GAS (FLOY)		User:	JASON WESLEY
Test Start Date:	05-14-10	<Blank>		Notes:	
Test Start Time:	08:03:41	<Blank>		DTEX Model:	DX1000G
TDL Result:	0.05%	PRESTONSBURG		Serial Number:	40984
RDL Result:	0.84%	KY	<Blank>	Test Error Code:	**
Test Time (Sec):	8	Altitude (ft): 0		Test Temp (C):	24

Test #:	00048	COW CREEK GAS (FLOY)		User:	JASON WESLEY
Test Start Date:	05-14-10	<Blank>		Notes:	
Test Start Time:	08:04:09	<Blank>		DTEX Model:	DX1000G
TDL Result:	0.04%	PRESTONSBURG		Serial Number:	40984
RDL Result:	0.62%	KY	<Blank>	Test Error Code:	**
Test Time (Sec):	8	Altitude (ft): 0		Test Temp (C):	24

Test #:	00049	COW CREEK GAS (FLOYD		User:	JASON WESLEY
Test Start Date:	05-14-10	HOME BR		Notes:	
Test Start Time:	08:12:43	<Blank>		DTEX Model:	DX1000G
TDL Result:	0.03%	PRESTONSBURG		Serial Number:	40984
RDL Result:	0.52%	KY	<Blank>	Test Error Code:	**
Test Time (Sec):	8	Altitude (ft): 0		Test Temp (C):	25

[illegible]	00050	COW CREEK GAS (FLOYD		User:	JASON WESLEY
[illegible] Start Date:	05-14-10	HOME BR		Notes:	
Test Start Time:	08:13:07	<Blank>		DTEX Model:	DX1000G
TDL Result:	0.05%	PRESTONSBURG		Serial Number:	40984
RDL Result:	0.88%	KY	<Blank>	Test Error Code:	**
Test Time (Sec):	11	Altitude (ft): 0		Test Temp (C):	25

Test #:	00051	COW CREEK GAS (FLOYD		User:	JASON WESLEY
Test Start Date:	05-14-10	HOME BR		Notes:	
Test Start Time:	08:13:37	<Blank>		DTEX Model:	DX1000G
TDL Result:	0.03%	PRESTONSBURG		Serial Number:	40984
RDL Result:	0.65%	KY	<Blank>	Test Error Code:	**
Test Time (Sec):	10	Altitude (ft): 0		Test Temp (C):	25

Test #:	00052	COW CREEK (MAG.CO.)		User:	JASON WESLEY
Test Start Date:	05-14-10	BLOCK BUILDING		Notes:	
Test Start Time:	09:45:53	<Blank>		DTEX Model:	DX1000G
TDL Result:	0.01%	SALYERSVILLE		Serial Number:	40984
RDL Result:	0.30%	KY	41465	Test Error Code:	**
Test Time (Sec):	17	Altitude (ft): 0		Test Temp (C):	25

Test #:	00053	COW CREEK (MAG.CO.)		User:	JASON WESLEY
Test Start Date:	05-14-10	BLOCK BUILDING		Notes:	
[illegible] Start Time:	09:46:25	<Blank>		DTEX Model:	DX1000G
[illegible] Result:	0.02%	SALYERSVILLE		Serial Number:	40984
[illegible] Result:	0.62%	KY	41465	Test Error Code:	**
Test Time (Sec):	9	Altitude (ft): 0		Test Temp (C):	25

Test #:	00054	DEMA GAS		User:	JASON WESLEY
Test Start Date:	05-14-10	CLEDITH PATTONS		Notes:	
Test Start Time:	12:19:46	<Blank>		DTEX Model:	DX1000G
TDL Result:	0.02%	TOPMOST		Serial Number:	40984
RDL Result:	0.53%	KY	<Blank>	Test Error Code:	**
Test Time (Sec):	11	Altitude (ft): 0		Test Temp (C):	26

Test #:	00055	DEMA GAS		User:	JASON WESLEY
Test Start Date:	05-14-10	CLEDITH PATTONS		Notes:	
Test Start Time:	12:20:13	<Blank>		DTEX Model:	DX1000G
TDL Result:	0.03%	TOPMOST		Serial Number:	40984
RDL Result:	0.51%	KY	<Blank>	Test Error Code:	**
Test Time (Sec):	7	Altitude (ft): 0		Test Temp (C):	26

Test #:	00056	DEMA GAS		User:	JASON WESLEY
Test Start Date:	05-14-10	CLEDITH PATTONS		Notes:	
Test Start Time:	12:20:37	<Blank>		DTEX Model:	DX1000G
TDL Result:	0.05%	TOPMOST		Serial Number:	40984
RDL Result:	0.65%	KY	<Blank>	Test Error Code:	**
Test Time (Sec):	8	Altitude (ft): 0		Test Temp (C):	26

t:	00057	COW CREEK GAS (FLOY)		User:	JASON WESLEY
Start Date:	05-21-10	<Blank>		Notes:	
Test Start Time:	09:25:11	<Blank>		DTEX Model:	DX1000G
TDL Result:	0.04%	PRESTONSBURG		Serial Number:	40984
RDL Result:	0.86%	KY	<Blank>	Test Error Code:	**
Test Time (Sec):	87	Altitude (ft): 0		Test Temp (C):	24

Test #:	00058	COW CREEK GAS (FLOY)		User:	JASON WESLEY
Test Start Date:	05-21-10	<Blank>		Notes:	
Test Start Time:	09:27:03	<Blank>		DTEX Model:	DX1000G
TDL Result:	0.03%	PRESTONSBURG		Serial Number:	40984
RDL Result:	0.82%	KY	<Blank>	Test Error Code:	**
Test Time (Sec):	7	Altitude (ft): 0		Test Temp (C):	24

Test #:	00059	COW CREEK GAS (FLOY)		User:	JASON WESLEY
Test Start Date:	05-21-10	<Blank>		Notes:	
Test Start Time:	09:27:27	<Blank>		DTEX Model:	DX1000G
TDL Result:	0.07%	PRESTONSBURG		Serial Number:	40984
RDL Result:	0.66%	KY	<Blank>	Test Error Code:	**
Test Time (Sec):	8	Altitude (ft): 0		Test Temp (C):	25

Test #:	00060	COW CREEK GAS (FLOY)		User:	JASON WESLEY
Test Start Date:	05-21-10	<Blank>		Notes:	
Start Time:	09:27:53	<Blank>		DTEX Model:	DX1000G
Result:	0.03%	PRESTONSBURG		Serial Number:	40984
Result:	0.54%	KY	<Blank>	Test Error Code:	**
Test Time (Sec):	8	Altitude (ft): 0		Test Temp (C):	25

Test #:	00061	COW CREEK GAS (FLOY)		User:	JASON WESLEY
Test Start Date:	05-21-10	<Blank>		Notes:	
Test Start Time:	09:28:18	<Blank>		DTEX Model:	DX1000G
TDL Result:	0.02%	PRESTONSBURG		Serial Number:	40984
RDL Result:	0.68%	KY	<Blank>	Test Error Code:	**
Test Time (Sec):	9	Altitude (ft): 0		Test Temp (C):	25

Test #:	00062	COW CREEK GAS (FLOYD		User:	JASON WESLEY
Test Start Date:	05-21-10	HOME BR		Notes:	
Test Start Time:	09:44:03	<Blank>		DTEX Model:	DX1000G
TDL Result:	0.02%	PRESTONSBURG		Serial Number:	40984
RDL Result:	0.57%	KY	<Blank>	Test Error Code:	**
Test Time (Sec):	13	Altitude (ft): 0		Test Temp (C):	25

Test #:	00063	COW CREEK GAS (FLOYD		User:	JASON WESLEY
Test Start Date:	05-21-10	HOME BR		Notes:	
Test Start Time:	09:44:32	<Blank>		DTEX Model:	DX1000G
TDL Result:	0.02%	PRESTONSBURG		Serial Number:	40984
RDL Result:	0.65%	KY	<Blank>	Test Error Code:	**
Test Time (Sec):	8	Altitude (ft): 0		Test Temp (C):	25

[illegible]	00064	DEMA GAS		User:	JASON WESLEY
Test Start Date:	05-21-10	CLEDITH PATTONS		Notes:	
Test Start Time:	10:37:49	<Blank>		DTEX Model:	DX1000G
TDL Result:	0.03%	TOPMOST		Serial Number:	40984
RDL Result:	0.65%	KY	<Blank>	Test Error Code:	**
Test Time (Sec):	15	Altitude (ft): 0		Test Temp (C):	25

Test #:	00065	COW CREEK (MAG.CO.)		User:	JASON WESLEY
Test Start Date:	05-21-10	BLOCK BUILDING		Notes:	
Test Start Time:	12:43:47	<Blank>		DTEX Model:	DX1000G
TDL Result:	0.01%	SALYERSVILLE		Serial Number:	40984
RDL Result:	0.41%	KY	41465	Test Error Code:	**
Test Time (Sec):	10	Altitude (ft): 0		Test Temp (C):	26

Test #:	00066	COW CREEK (MAG.CO.)		User:	JASON WESLEY
Test Start Date:	05-21-10	BLOCK BUILDING		Notes:	
Test Start Time:	12:44:13	<Blank>		DTEX Model:	DX1000G
TDL Result:	0.03%	SALYERSVILLE		Serial Number:	40984
RDL Result:	0.63%	KY	41465	Test Error Code:	**
Test Time (Sec):	11	Altitude (ft): 0		Test Temp (C):	26

Test #:	00067	COW CREEK GAS (FLOY)		User:	JASON WESLEY
Test Start Date:	05-28-10	<Blank>		Notes:	
[illegible] Start Time:	13:22:45	<Blank>		DTEX Model:	DX1000G
[illegible] Result:	0.02%	PRESTONSBURG		Serial Number:	40984
[illegible] Result:	0.48%	KY	<Blank>	Test Error Code:	**
Test Time (Sec):	9	Altitude (ft): 0		Test Temp (C):	25

Test #:	00068	COW CREEK GAS (FLOY)		User:	JASON WESLEY
Test Start Date:	05-28-10	<Blank>		Notes:	
Test Start Time:	13:23:11	<Blank>		DTEX Model:	DX1000G
TDL Result:	0.04%	PRESTONSBURG		Serial Number:	40984
RDL Result:	0.64%	KY	<Blank>	Test Error Code:	**
Test Time (Sec):	14	Altitude (ft): 0		Test Temp (C):	25

Test #:	00069	COW CREEK GAS (FLOYD		User:	JASON WESLEY
Test Start Date:	05-28-10	HOME BR		Notes:	
Test Start Time:	13:48:16	<Blank>		DTEX Model:	DX1000G
TDL Result:	0.05%	PRESTONSBURG		Serial Number:	40984
RDL Result:	0.69%	KY	<Blank>	Test Error Code:	**
Test Time (Sec):	12	Altitude (ft): 0		Test Temp (C):	26

Test #:	00070	DEMA GAS		User:	JASON WESLEY
Test Start Date:	05-28-10	CLEDITH PATTONS		Notes:	
Test Start Time:	15:00:19	<Blank>		DTEX Model:	DX1000G
TDL Result:	0.03%	TOPMOST		Serial Number:	40984
RDL Result:	0.54%	KY	<Blank>	Test Error Code:	**
[illegible]t Time (Sec):	11	Altitude (ft): 0		Test Temp (C):	28

t:	00071	DEMA GAS		User:	JASON WESLEY
Start Date:	05-28-10	CLEDITH PATTONS		Notes:	
Test Start Time:	15:00:47	<Blank>		DTEX Model:	DX1000G
TDL Result:	0.04%	TOPMOST		Serial Number:	40984
RDL Result:	0.68%	KY	<Blank>	Test Error Code:	**
Test Time (Sec):	10	Altitude (ft): 0		Test Temp (C):	28

Test #:	00072	COW CREEK (MAG.CO.)		User:	JASON WESLEY
Test Start Date:	05-28-10	BLOCK BUILDING		Notes:	
Test Start Time:	15:49:51	<Blank>		DTEX Model:	DX1000G
TDL Result:	0.05%	SALYERSVILLE		Serial Number:	40984
RDL Result:	0.72%	KY	41465	Test Error Code:	**
Test Time (Sec):	8	Altitude (ft): 0		Test Temp (C):	29

Test #:	00073	COW CREEK (MAG.CO.)		User:	JASON WESLEY
Test Start Date:	05-28-10	BLOCK BUILDING		Notes:	
Test Start Time:	15:50:14	<Blank>		DTEX Model:	DX1000G
TDL Result:	0.02%	SALYERSVILLE		Serial Number:	40984
RDL Result:	0.50%	KY	41465	Test Error Code:	**
Test Time (Sec):	7	Altitude (ft): 0		Test Temp (C):	29

Test #:	00074	COW CREEK (MAG.CO.)		User:	JASON WESLEY
Test Start Date:	05-28-10	BLOCK BUILDING		Notes:	
t Start Time:	15:50:36	<Blank>		DTEX Model:	DX1000G
Result:	0.08%	SALYERSVILLE		Serial Number:	40984
Result:	0.81%	KY	41465	Test Error Code:	**
Test Time (Sec):	10	Altitude (ft): 0		Test Temp (C):	29

Test #:	00075	COW CREEK (MAG.CO.)		User:	JASON WESLEY
Test Start Date:	05-28-10	BLOCK BUILDING		Notes:	
Test Start Time:	15:51:10	<Blank>		DTEX Model:	DX1000G
TDL Result:	0.03%	SALYERSVILLE		Serial Number:	40984
RDL Result:	0.68%	KY	41465	Test Error Code:	**
Test Time (Sec):	9	Altitude (ft): 0		Test Temp (C):	29

DTEX Test Log

Test #	00001	DEMA GAS		User:	JASON WESLEY
Test Start Date	09-17-10	CLEDITH PATTONS		Notes:	
Test Start Time	16:33:42	<Blank>		DTEX Model:	DX1000G
TDL Result	0.03%	TOPMOST		Serial Number:	40984
RDL Result	0.58%	KY	<Blank>	Test Error Code:	**
Test Time (Sec)	27	Altitude (ft): 0		Test Temp (C):	29

Test #	00002	COW CREEK (MAG.CO.)		User:	JASON WESLEY
Test Start Date	09-24-10	BLOCK BUILDING		Notes:	
Test Start Time	12:47:04	<Blank>		DTEX Model:	DX1000G
TDL Result	0.03%	SALYERSVILLE		Serial Number:	40984
RDL Result	0.70%	KY	41465	Test Error Code:	**
Test Time (Sec):	16	Altitude (ft): 0		Test Temp (C):	36

Test #	00003	DEMA GAS		User:	JASON WESLEY
Test Start Date	09-24-10	CLEDITH PATTONS		Notes:	
Test Start Time	14:43:55	<Blank>		DTEX Model:	DX1000G
TDL Result	0.03%	TOPMOST		Serial Number:	40984
RDL Result	0.67%	KY	<Blank>	Test Error Code:	**
Test Time (Sec)	26	Altitude (ft): 0		Test Temp (C):	36

Test #	00004	COW CREEK GAS (FLOY)		User:	JASON WESLEY
Test Start Date	09-24-10	<Blank>		Notes:	
Test Start Time	16:26:27	<Blank>		DTEX Model:	DX1000G
TDL Result	0.03%	PRESTONSBURG		Serial Number:	40984
RDL Result	0.71%	KY	<Blank>	Test Error Code:	**
Test Time (Sec)	19	Altitude (ft): 0		Test Temp (C):	37

Test #	00005	COW CREEK GAS (FLOYD		User:	JASON WESLEY
Test Start Date	09-24-10	HOME BR		Notes:	
Test Start Time	16:51:53	<Blank>		DTEX Model:	DX1000G
TDL Result	0.04%	PRESTONSBURG		Serial Number:	40984
RDL Result	0.74%	KY	<Blank>	Test Error Code:	**
Test Time (Sec)	17	Altitude (ft): 0		Test Temp (C):	37

Test #	00006	COW CREEK GAS (FLOYD		User:	JASON WESLEY
Test Start Date	09-24-10	HOME BR		Notes:	
Test Start Time	16:52:25	<Blank>		DTEX Model:	DX1000G
TDL Result	0.03%	PRESTONSBURG		Serial Number:	40984
RDL Result	0.50%	KY	<Blank>	Test Error Code:	**
Test Time (Sec)	12	Altitude (ft): 0		Test Temp (C):	37

Test #	00007	COW CREEK GAS (FLOYD		User:	JASON WESLEY
Test Start Date	09-24-10	HOME BR		Notes:	
Test Start Time	16:52:50	<Blank>		DTEX Model:	DX1000G
TDL Result	0.03%	PRESTONSBURG		Serial Number:	40984
RDL Result	0.74%	KY	<Blank>	Test Error Code:	**
Test Time (Sec)	16	Altitude (ft): 0		Test Temp (C):	37

Test #:	00008	COW CREEK GAS (FLOY)		User:	JASON WESLEY
Test Start Date:	10-01-10	<Blank>		Notes:	
Test Start Time:	09:03:51	<Blank>		DTEX Model:	DX1000G
TDL Result:	0.06%	PRESTONSBURG		Serial Number:	40984
RDL Result:	0.86%	KY	<Blank>	Test Error Code:	**
Test Time (Sec):	19	Altitude (ft): 0		Test Temp (C):	21

Test #:	00009	COW CREEK GAS (FLOY)		User:	JASON WESLEY
Test Start Date:	10-01-10	<Blank>		Notes:	
Test Start Time:	09:04:27	<Blank>		DTEX Model:	DX1000G
TDL Result:	0.01%	PRESTONSBURG		Serial Number:	40984
RDL Result:	0.68%	KY	<Blank>	Test Error Code:	**
Test Time (Sec):	16	Altitude (ft): 0		Test Temp (C):	21

Test #:	00010	COW CREEK GAS (FLOYD		User:	JASON WESLEY
Test Start Date:	10-01-10	HOME BR		Notes:	
Test Start Time:	09:16:06	<Blank>		DTEX Model:	DX1000G
TDL Result:	0.03%	PRESTONSBURG		Serial Number:	40984
RDL Result:	0.86%	KY	<Blank>	Test Error Code:	**
Test Time (Sec):	17	Altitude (ft): 0		Test Temp (C):	22

Test #:	00011	COW CREEK GAS (FLOYD		User:	JASON WESLEY
Test Start Date:	10-01-10	HOME BR		Notes:	
Test Start Time:	09:16:37	<Blank>		DTEX Model:	DX1000G
TDL Result:	0.05%	PRESTONSBURG		Serial Number:	40984
RDL Result:	0.88%	KY	<Blank>	Test Error Code:	**
Test Time (Sec):	15	Altitude (ft): 0		Test Temp (C):	22

Test #:	00012	COW CREEK GAS (FLOYD		User:	JASON WESLEY
Test Start Date:	10-01-10	HOME BR		Notes:	
Test Start Time:	09:17:05	<Blank>		DTEX Model:	DX1000G
TDL Result:	0.02%	PRESTONSBURG		Serial Number:	40984
RDL Result:	0.79%	KY	<Blank>	Test Error Code:	**
Test Time (Sec):	14	Altitude (ft): 0		Test Temp (C):	22

Test #:	00013	COW CREEK GAS (FLOYD		User:	JASON WESLEY
Test Start Date:	10-01-10	HOME BR		Notes:	
Test Start Time:	09:17:33	<Blank>		DTEX Model:	DX1000G
TDL Result:	0.02%	PRESTONSBURG		Serial Number:	40984
RDL Result:	0.61%	KY	<Blank>	Test Error Code:	**
Test Time (Sec):	9	Altitude (ft): 0		Test Temp (C):	22

Test #:	00014	COW CREEK (MAG.CO.)		User:	JASON WESLEY
Test Start Date:	10-01-10	BLOCK BUILDING		Notes:	
Test Start Time:	11:42:58	<Blank>		DTEX Model:	DX1000G
TDL Result:	0.02%	SALYERSVILLE		Serial Number:	40984
RDL Result:	0.41%	KY	41465	Test Error Code:	**
Test Time (Sec):	13	Altitude (ft): 0		Test Temp (C):	32

Test #	00015	COW CREEK (MAG.CO.)		User:	JASON WESLEY
Test Start Date	10-01-10	BLOCK BUILDING		Notes:	
Test Start Time	11:43:25	<Blank>		DTEX Model:	DX1000G
TDL Result	0.02%	SALYERSVILLE		Serial Number:	40984
RDL Result	0.63%	KY	41465	Test Error Code:	**
Test Time (Sec)	14	Altitude (ft): 0		Test Temp (C):	32

Test #	00016	DEMA GAS		User:	JASON WESLEY
Test Start Date	10-01-10	CLEDITH PATTONS		Notes:	
Test Start Time	13:00:45	<Blank>		DTEX Model:	DX1000G
TDL Result	0.04%	TOPMOST		Serial Number:	40984
RDL Result	0.81%	KY	<Blank>	Test Error Code:	**
Test Time (Sec)	16	Altitude (ft): 0		Test Temp (C):	29

Test #	00017	DEMA GAS		User:	JASON WESLEY
Test Start Date	10-01-10	CLEDITH PATTONS		Notes:	
Test Start Time	13:01:16	<Blank>		DTEX Model:	DX1000G
TDL Result	0.03%	TOPMOST		Serial Number:	40984
RDL Result	0.83%	KY	<Blank>	Test Error Code:	**
Test Time (Sec)	13	Altitude (ft): 0		Test Temp (C):	29

Test #	00018	DEMA GAS		User:	JASON WESLEY
Test Start Date	10-01-10	CLEDITH PATTONS		Notes:	
st Start Time	13:01:45	<Blank>		DTEX Model:	DX1000G
JL Result	0.04%	TOPMOST		Serial Number:	40984
RDL Result	0.65%	KY	<Blank>	Test Error Code:	**
Test Time (Sec)	10	Altitude (ft): 0		Test Temp (C):	29

Test #	00019	COW CREEK GAS (FLOY)		User:	JASON WESLEY
Test Start Date	10-08-10	<Blank>		Notes:	
Test Start Time	09:22:27	<Blank>		DTEX Model:	DX1000G
TDL Result	0.01%	PRESTONSBURG		Serial Number:	40984
RDL Result	0.74%	KY	<Blank>	Test Error Code:	**
Test Time (Sec)	17	Altitude (ft): 0		Test Temp (C):	22

Test #	00020	COW CREEK GAS (FLOY)		User:	JASON WESLEY
Test Start Date	10-08-10	<Blank>		Notes:	
Test Start Time	09:22:59	<Blank>		DTEX Model:	DX1000G
TDL Result	0.05%	PRESTONSBURG		Serial Number:	40984
RDL Result	0.58%	KY	<Blank>	Test Error Code:	**
Test Time (Sec)	16	Altitude (ft): 0		Test Temp (C):	22

Test #	00021	COW CREEK GAS (FLOY)		User:	JASON WESLEY
Test Start Date	10-08-10	<Blank>		Notes:	
Test Start Time	09:23:31	<Blank>		DTEX Model:	DX1000G
TDL Result	0.03%	PRESTONSBURG		Serial Number:	40984
RDL Result	0.63%	KY	<Blank>	Test Error Code:	**
Test Time (Sec)	14	Altitude (ft): 0		Test Temp (C):	22

.est #:	00022	COW CREEK GAS (FLOYD		User:	JASON WESLEY
Test Start Date:	10-08-10	HOME BR		Notes:	
Test Start Time:	09:43:16	<Blank>		DTEX Model:	DX1000G
TDL Result:	0.04%	PRESTONSBURG		Serial Number:	40984
RDL Result:	0.73%	KY	<Blank>	Test Error Code:	**
Test Time (Sec):	12	Altitude (ft): 0		Test Temp (C):	24

Test #:	00023	COW CREEK (MAG.CO.)		User:	JASON WESLEY
Test Start Date:	10-08-10	BLOCK BUILDING		Notes:	
Test Start Time:	12:46:22	<Blank>		DTEX Model:	DX1000G
TDL Result:	0.03%	SALYERSVILLE		Serial Number:	40984
RDL Result:	0.58%	KY	41465	Test Error Code:	**
Test Time (Sec):	15	Altitude (ft): 0		Test Temp (C):	32

Test #:	00024	COW CREEK (MAG.CO.)		User:	JASON WESLEY
Test Start Date:	10-08-10	BLOCK BUILDING		Notes:	
Test Start Time:	12:46:52	<Blank>		DTEX Model:	DX1000G
TDL Result:	0.04%	SALYERSVILLE		Serial Number:	40984
RDL Result:	0.69%	KY	41465	Test Error Code:	**
Test Time (Sec):	10	Altitude (ft): 0		Test Temp (C):	32

Test #:	00025	DEMA GAS		User:	JASON WESLEY
Test Start Date:	10-08-10	CLEDITH PATTONS		Notes:	
st Start Time:	14:52:03	<Blank>		DTEX Model:	DX1000G
›L Result:	0.03%	TOPMOST		Serial Number:	40984
RDL Result:	0.48%	KY	<Blank>	Test Error Code:	**
Test Time (Sec):	14	Altitude (ft): 0		Test Temp (C):	36

Test #:	00026	DEMA GAS		User:	JASON WESLEY
Test Start Date:	10-08-10	CLEDITH PATTONS		Notes:	
Test Start Time:	14:52:32	<Blank>		DTEX Model:	DX1000G
TDL Result:	0.04%	TOPMOST		Serial Number:	40984
RDL Result:	0.56%	KY	<Blank>	Test Error Code:	**
Test Time (Sec):	14	Altitude (ft): 0		Test Temp (C):	36

Test #:	00027	DEMA GAS		User:	JASON WESLEY
Test Start Date:	10-08-10	CLEDITH PATTONS		Notes:	
Test Start Time:	14:53:02	<Blank>		DTEX Model:	DX1000G
TDL Result:	0.01%	TOPMOST		Serial Number:	40984
RDL Result:	0.60%	KY	<Blank>	Test Error Code:	**
Test Time (Sec):	12	Altitude (ft): 0		Test Temp (C):	36

Test #:	00028	COW CREEK (MAG.CO.)		User:	JASON WESLEY
Test Start Date:	10-15-10	BLOCK BUILDING		Notes:	
Test Start Time:	08:52:46	<Blank>		DTEX Model:	DX1000G
TDL Result:	0.02%	SALYERSVILLE		Serial Number:	40984
RDL Result:	0.56%	KY	41465	Test Error Code:	**
Test Time (Sec):	14	Altitude (ft): 0		Test Temp (C):	17

est #:	00029	COW CREEK (MAG.CO.)		User:	JASON WESLEY
Test Start Date:	10-15-10	BLOCK BUILDING		Notes:	
Test Start Time:	08:53:15	<Blank>		DTEX Model:	DX1000G
TDL Result:	0.02%	SALYERSVILLE		Serial Number:	40984
RDL Result:	0.56%	KY	41465	Test Error Code:	**
Test Time (Sec):	12	Altitude (ft): 0		Test Temp (C):	17

Test #:	00030	COW CREEK (MAG.CO.)		User:	JASON WESLEY
Test Start Date:	10-15-10	BLOCK BUILDING		Notes:	
Test Start Time:	08:53:47	<Blank>		DTEX Model:	DX1000G
TDL Result:	0.03%	SALYERSVILLE		Serial Number:	40984
RDL Result:	0.74%	KY	41465	Test Error Code:	**
Test Time (Sec):	11	Altitude (ft): 0		Test Temp (C):	17

Test #:	00031	DEMA GAS		User:	JASON WESLEY
Test Start Date:	10-15-10	CLEDITH PATTONS		Notes:	
Test Start Time:	11:13:20	<Blank>		DTEX Model:	DX1000G
TDL Result:	0.03%	TOPMOST		Serial Number:	40984
RDL Result:	0.69%	KY	<Blank>	Test Error Code:	**
Test Time (Sec):	14	Altitude (ft): 0		Test Temp (C):	25

Test #:	00032	COW CREEK GAS (FLOY)		User:	JASON WESLEY
Test Start Date:	10-15-10	<Blank>		Notes:	
st Start Time:	13:19:34	<Blank>		DTEX Model:	DX1000G
L Result:	0.03%	PRESTONSBURG		Serial Number:	40984
RDL Result:	0.76%	KY	<Blank>	Test Error Code:	**
Test Time (Sec):	22	Altitude (ft): 0		Test Temp (C):	26

Test #:	00033	COW CREEK GAS (FLOY)		User:	JASON WESLEY
Test Start Date:	10-15-10	<Blank>		Notes:	
Test Start Time:	13:20:11	<Blank>		DTEX Model:	DX1000G
TDL Result:	0.03%	PRESTONSBURG		Serial Number:	40984
RDL Result:	0.55%	KY	<Blank>	Test Error Code:	**
Test Time (Sec):	16	Altitude (ft): 0		Test Temp (C):	26

Test #:	00034	COW CREEK GAS (FLOY)		User:	JASON WESLEY
Test Start Date:	10-15-10	<Blank>		Notes:	
Test Start Time:	13:20:43	<Blank>		DTEX Model:	DX1000G
TDL Result:	0.04%	PRESTONSBURG		Serial Number:	40984
RDL Result:	0.67%	KY	<Blank>	Test Error Code:	**
Test Time (Sec):	16	Altitude (ft): 0		Test Temp (C):	26

Test #:	00035	COW CREEK GAS (FLOYD		User:	JASON WESLEY
Test Start Date:	10-15-10	HOME BR		Notes:	
Test Start Time:	13:36:57	<Blank>		DTEX Model:	DX1000G
TDL Result:	0.03%	PRESTONSBURG		Serial Number:	40984
RDL Result:	0.58%	KY	<Blank>	Test Error Code:	**
Test Time (Sec):	14	Altitude (ft): 0		Test Temp (C):	28

Test #:	00036	COW CREEK GAS (FLOYD		User:	JASON WESLEY
Test Start Date:	10-15-10	HOME BR		Notes:	
Test Start Time:	13:37:26	<Blank>		DTEX Model:	DX1000G
TDL Result:	0.02%	PRESTONSBURG		Serial Number:	40984
RDL Result:	0.71%	KY	<Blank>	Test Error Code:	**
Test Time (Sec):	11	Altitude (ft): 0		Test Temp (C):	28

Test #:	00037	COW CREEK (MAG.CO.)		User:	JASON WESLEY
Test Start Date:	10-22-10	BLOCK BUILDING		Notes:	
Test Start Time:	03:11:15	<Blank>		DTEX Model:	DX1000G
TDL Result:	0.01%	SALYERSVILLE		Serial Number:	40984
RDL Result:	0.56%	KY	41465	Test Error Code:	**
Test Time (Sec):	12	Altitude (ft): 0		Test Temp (C):	22

Test #:	00038	COW CREEK (MAG.CO.)		User:	JASON WESLEY
Test Start Date:	10-22-10	BLOCK BUILDING		Notes:	
Test Start Time:	03:14:21	<Blank>		DTEX Model:	DX1000G
TDL Result:	0.03%	SALYERSVILLE		Serial Number:	40984
RDL Result:	0.61%	KY	41465	Test Error Code:	**
Test Time (Sec):	9	Altitude (ft): 0		Test Temp (C):	22

Test #:	00039	COW CREEK GAS (FLOY)		User:	JASON WESLEY
Test Start Date:	10-22-10	<Blank>		Notes:	
Test Start Time:	04:07:36	<Blank>		DTEX Model:	DX1000G
TDL Result:	0.03%	PRESTONSBURG		Serial Number:	40984
RDL Result:	0.66%	KY	<Blank>	Test Error Code:	**
Test Time (Sec):	13	Altitude (ft): 0		Test Temp (C):	22

Test #:	00040	COW CREEK GAS (FLOYD		User:	JASON WESLEY
Test Start Date:	10-22-10	HOME BR		Notes:	
Test Start Time:	04:25:13	<Blank>		DTEX Model:	DX1000G
TDL Result:	0.03%	PRESTONSBURG		Serial Number:	40984
RDL Result:	0.69%	KY	<Blank>	Test Error Code:	**
Test Time (Sec):	10	Altitude (ft): 0		Test Temp (C):	22

Test #:	00041	DEMA GAS		User:	JASON WESLEY
Test Start Date:	10-22-10	CLEDITH PATTONS		Notes:	
Test Start Time:	05:39:13	<Blank>		DTEX Model:	DX1000G
TDL Result:	0.03%	TOPMOST		Serial Number:	40984
RDL Result:	0.57%	KY	<Blank>	Test Error Code:	**
Test Time (Sec):	11	Altitude (ft): 0		Test Temp (C):	22

Test #:	00042	DEMA GAS		User:	JASON WESLEY
Test Start Date:	10-22-10	CLEDITH PATTONS		Notes:	
Test Start Time:	05:39:38	<Blank>		DTEX Model:	DX1000G
TDL Result:	0.03%	TOPMOST		Serial Number:	40984
RDL Result:	0.74%	KY	<Blank>	Test Error Code:	**
Test Time (Sec):	11	Altitude (ft): 0		Test Temp (C):	22

Test #	00043	DEMA GAS		User:	JASON WESLEY
Test Start Date	10-22-10	CLEDITH PATTONS		Notes:	
Test Start Time	05:40:03	<Blank>		DTEX Model:	DX1000G
TDL Result	0.03%	TOPMOST		Serial Number:	40984
RDL Result	0.70%	KY	<Blank>	Test Error Code:	**
Test Time (Sec)	10	Altitude (ft): 0		Test Temp (C):	22

Test #	00044	COW CREEK (MAG CO.)		User:	JASON WESLEY
Test Start Date	10-29-10	BLOCK BUILDING		Notes:	
Test Start Time	00:14:00	<Blank>		DTEX Model:	DX1000G
TDL Result	0.02%	SALYERSVILLE		Serial Number:	40984
RDL Result	0.35%	KY	41465	Test Error Code:	**
Test Time (Sec)	15	Altitude (ft): 0		Test Temp (C):	22

Test #	00045	COW CREEK (MAG CO.)		User:	JASON WESLEY
Test Start Date	10-29-10	BLOCK BUILDING		Notes:	
Test Start Time	00:15:12	<Blank>		DTEX Model:	DX1000G
TDL Result	0.03%	SALYERSVILLE		Serial Number:	40984
RDL Result	0.63%	KY	41465	Test Error Code:	**
Test Time (Sec)	15	Altitude (ft): 0		Test Temp (C):	22

Test #	00046	COW CREEK GAS (FLOY)		User:	JASON WESLEY
Test Start Date	10-29-10	<Blank>		Notes:	
st Start Time	01:26:09	<Blank>		DTEX Model:	DX1000G
DL Result	0.04%	PRESTONSBURG		Serial Number:	40984
RDL Result	0.69%	KY	<Blank>	Test Error Code:	**
Test Time (Sec)	14	Altitude (ft): 0		Test Temp (C):	22

Test #	00047	COW CREEK GAS (FLOYD		User:	JASON WESLEY
Test Start Date	10-29-10	HOME BR		Notes:	
Test Start Time	01:45:13	<Blank>		DTEX Model:	DX1000G
TDL Result	0.04%	PRESTONSBURG		Serial Number:	40984
RDL Result	0.62%	KY	<Blank>	Test Error Code:	**
Test Time (Sec)	13	Altitude (ft): 0		Test Temp (C):	22

Test #	00048	DEMA GAS		User:	JASON WESLEY
Test Start Date	10-29-10	CLEDITH PATTONS		Notes:	
Test Start Time	04:52:14	<Blank>		DTEX Model:	DX1000G
TDL Result	0.04%	TOPMOST		Serial Number:	40984
RDL Result	0.64%	KY	<Blank>	Test Error Code:	**
Test Time (Sec)	11	Altitude (ft): 0		Test Temp (C):	22

Test #	00049	COW CREEK (MAG CO.)		User:	JASON WESLEY
Test Start Date	11-04-10	BLOCK BUILDING		Notes:	
Test Start Time	23:25:49	<Blank>		DTEX Model:	DX1000G
TDL Result	0.03%	SALYERSVILLE		Serial Number:	40984
RDL Result	0.68%	KY	41465	Test Error Code:	**
Test Time (Sec)	14	Altitude (ft): 0		Test Temp (C):	26

est #	00050	COW CREEK GAS (FLOY)		User:	JASON WESLEY
Test Start Date	11-05-10	<Blank>		Notes:	
Test Start Time	03:02:17	<Blank>		DTEX Model:	DX1000G
TDL Result	0.01%	PRESTONSBURG		Serial Number:	40984
RDL Result:	0.73%	KY	<Blank>	Test Error Code:	**
Test Time (Sec)	15	Altitude (ft): 0		Test Temp (C):	29

Test #	00051	COW CREEK GAS (FLOY)		User:	JASON WESLEY
Test Start Date	11-05-10	<Blank>		Notes:	
Test Start Time	03:02:47	<Blank>		DTEX Model:	DX1000G
TDL Result:	0.04%	PRESTONSBURG		Serial Number:	40984
RDL Result	0.70%	KY	<Blank>	Test Error Code:	**
Test Time (Sec)	14	Altitude (ft): 0		Test Temp (C):	29

Test #	00052	COW CREEK GAS (FLOYD		User:	JASON WESLEY
Test Start Date	11-05-10	HOME BR		Notes:	
Test Start Time	03:24:07	<Blank>		DTEX Model:	DX1000G
TDL Result:	0.04%	PRESTONSBURG		Serial Number:	40984
RDL Result:	0.68%	KY	<Blank>	Test Error Code:	**
Test Time (Sec)	15	Altitude (ft): 0		Test Temp (C):	25

Test #	00053	DEMA GAS		User:	JASON WESLEY
Test Start Date	11-05-10	CLEDITH PATTONS		Notes:	
st Start Time	05:49:14	<Blank>		DTEX Model:	DX1000G
L Result	0.05%	TOPMOST		Serial Number:	40984
RDL Result:	0.70%	KY	<Blank>	Test Error Code:	**
Test Time (Sec)	12	Altitude (ft): 0		Test Temp (C):	25

Test #	00054	COW CREEK GAS (FLOY)		User:	JASON WESLEY
Test Start Date	11-11-10	<Blank>		Notes:	
Test Start Time	22:37:29	<Blank>		DTEX Model:	DX1000G
TDL Result	0.05%	PRESTONSBURG		Serial Number:	40984
RDL Result:	0.77%	KY	<Blank>	Test Error Code:	**
Test Time (Sec)	15	Altitude (ft): 0		Test Temp (C)	16

Test #	00055	COW CREEK GAS (FLOY)		User:	JASON WESLEY
Test Start Date	11-11-10	<Blank>		Notes:	
Test Start Time	22:37:59	<Blank>		DTEX Model:	DX1000G
TDL Result:	0.01%	PRESTONSBURG		Serial Number:	40984
RDL Result	0.58%	KY	<Blank>	Test Error Code:	**
Test Time (Sec)	13	Altitude (ft): 0		Test Temp (C):	16

Test #	00056	COW CREEK GAS (FLOY)		User:	JASON WESLEY
Test Start Date	11-11-10	<Blank>		Notes:	
Test Start Time	22:38:26	<Blank>		DTEX Model:	DX1000G
TDL Result	0.05%	PRESTONSBURG		Serial Number:	40984
RDL Result:	0.79%	KY	<Blank>	Test Error Code:	**
Test Time (Sec)	13	Altitude (ft): 0		Test Temp (C):	16

Test #	00057	COW CREEK GAS (FLOY)		User:	JASON WESLEY
Test Start Date:	11-11-10	<Blank>		Notes:	
Test Start Time:	22:38:55	<Blank>		DTEX Model:	DX1000G
TDL Result:	0.04%	PRESTONSBURG		Serial Number:	40984
RDL Result:	0.70%	KY	<Blank>	Test Error Code:	**
Test Time (Sec)	12	Altitude (ft): 0		Test Temp (C):	16

Test #	00058	COW CREEK GAS (FLOYD		User:	JASON WESLEY
Test Start Date:	11-11-10	HOME BR		Notes:	
Test Start Time:	22:53:58	<Blank>		DTEX Model:	DX1000G
TDL Result:	0.04%	PRESTONSBURG		Serial Number:	40984
RDL Result:	0.75%	KY	<Blank>	Test Error Code:	**
Test Time (Sec):	15	Altitude (ft): 0		Test Temp (C):	17

Test #	00059	COW CREEK GAS (FLOYD		User	JASON WESLEY
Test Start Date	11-11-10	HOME BR		Notes:	
Test Start Time:	22:54:28	<Blank>		DTEX Model:	DX1000G
TDL Result:	0.06%	PRESTONSBURG		Serial Number:	40984
RDL Result:	0.51%	KY	<Blank>	Test Error Code:	**
Test Time (Sec):	12	Altitude (ft): 0		Test Temp (C):	17

Test #:	00060	COW CREEK GAS (FLOYD		User:	JASON WESLEY
Test Start Date:	11-11-10	HOME BR		Notes:	
Test Start Time:	22:54:55	<Blank>		DTEX Model:	DX1000G
TDL Result:	0.05%	PRESTONSBURG		Serial Number:	40984
RDL Result:	0.79%	KY	<Blank>	Test Error Code:	**
Test Time (Sec):	19	Altitude (ft): 0		Test Temp (C):	17

Test #:	00061	COW CREEK GAS (FLOYD		User:	JASON WESLEY
Test Start Date:	11-11-10	HOME BR		Notes:	
Test Start Time:	22:55:28	<Blank>		DTEX Model:	DX1000G
TDL Result:	0.04%	PRESTONSBURG		Serial Number:	40984
RDL Result:	0.51%	KY	<Blank>	Test Error Code:	**
Test Time (Sec):	18	Altitude (ft): 0		Test Temp (C):	17

Test #	00062	COW CREEK GAS (FLOYD		User:	JASON WESLEY
Test Start Date:	11-11-10	HOME BR		Notes:	
Test Start Time:	22:56:08	<Blank>		DTEX Model:	DX1000G
TDL Result:	0.02%	PRESTONSBURG		Serial Number:	40984
RDL Result:	0.47%	KY	<Blank>	Test Error Code:	**
Test Time (Sec):	13	Altitude (ft): 0		Test Temp (C):	17

Test #	00063	COW CREEK GAS (FLOYD		User:	JASON WESLEY
Test Start Date:	11-11-10	HOME BR		Notes:	
Test Start Time:	22:56:38	<Blank>		DTEX Model:	DX1000G
TDL Result:	0.04%	PRESTONSBURG		Serial Number:	40984
RDL Result:	0.79%	KY	<Blank>	Test Error Code:	**
Test Time (Sec)	10	Altitude (ft): 0		Test Temp (C):	17

Test #	00064	DEMA GAS		User:	JASON WESLEY
Test Start Date	11-12-10	CLEDITH PATTONS		Notes:	
Test Start Time	00:34:10	<Blank>		DTEX Model:	DX1000G
TDL Result	0.03%	TOPMOST		Serial Number:	40984
RDL Result	0.54%	KY	<Blank>	Test Error Code:	**
Test Time (Sec)	16	Altitude (ft) 0		Test Temp (C)	24

Test #	00065	DEMA GAS		User:	JASON WESLEY
Test Start Date	11-12-10	CLEDITH PATTONS		Notes:	
Test Start Time	00:34:40	<Blank>		DTEX Model:	DX1000G
TDL Result	0.02%	TOPMOST		Serial Number	40984
RDL Result	0.50%	KY	<Blank>	Test Error Code:	**
Test Time (Sec)	13	Altitude (ft): 0		Test Temp (C):	24

Test #	00066	DEMA GAS		User:	JASON WESLEY
Test Start Date	11-12-10	CLEDITH PATTONS		Notes:	
Test Start Time	00:35:07	<Blank>		DTEX Model	DX1000G
TDL Result	0.02%	TOPMOST		Serial Number	40984
RDL Result	0.71%	KY	<Blank>	Test Error Code	**
Test Time (Sec)	13	Altitude (ft): 0		Test Temp (C)	24

Test #	00067	COW CREEK (MAG CO)		User:	JASON WESLEY
Test Start Date	11-12-10	BLOCK BUILDING		Notes:	
Test Start Time	04:28:58	<Blank>		DTEX Model:	DX1000G
TDL Result	0.03%	SALYERSVILLE		Serial Number	40984
RDL Result	0.61%	KY	41465	Test Error Code	**
Test Time (Sec)	12	Altitude (ft) 0		Test Temp (C)	29

Test #	00068	BTU GAS		User:	JASON WESLEY
Test Start Date	11-15-10	LOCATION 1 OFFICE GA		Notes:	
Test Start Time	00:07:54	RAGE		DTEX Model:	DX1000G
TDL Result	0.01%	SALYERSVILLE		Serial Number	40984
RDL Result	0.59%	KY	41465	Test Error Code	**
Test Time (Sec)	15	Altitude (ft): 0		Test Temp (C):	28

Test #	00069	BTU GAS		User:	JASON WESLEY
Test Start Date	11-15-10	LOCATION 1 OFFICE GA		Notes	
Test Start Time	00:08:26	RAGE		DTEX Model	DX1000G
TDL Result	0.04%	SALYERSVILLE		Serial Number	40984
RDL Result	0.74%	KY	41465	Test Error Code:	**
Test Time (Sec)	13	Altitude (ft) 0		Test Temp (C)	28

Test #	00070	BTU GAS		User:	JASON WESLEY
Test Start Date	11-15-10	LOCATION 2 ELK CREEK		Notes	
Test Start Time	00:41:11	<Blank>		DTEX Model	DX1000G
TDL Result	0.03%	SALYERSVILLE		Serial Number	40984
RDL Result	0.52%	KY	41465	Test Error Code:	**
Test Time (Sec)	19	Altitude (ft) 0		Test Temp (C)	24

Test #:	00071	BTU GAS		User:	JASON WESLEY
Test Start Date:	11-15-10	LOCATION 2 ELK CREEK		Notes:	
Test Start Time:	00:41:45	<Blank>		DTEX Model:	DX1000G
TDL Result:	0.03%	SALYERSVILLE		Serial Number:	40984
RDL Result:	0.50%	KY	41465	Test Error Code:	**
Test Time (Sec):	20	Altitude (ft): 0		Test Temp (C):	24

Test #:	00072	BTU GAS		User:	JASON WESLEY
Test Start Date:	11-15-10	LOCATION 3 MOUTH OF		Notes:	
Test Start Time:	01:06:47	LITTERAL FK		DTEX Model:	DX1000G
TDL Result:	0.03%	SALYERSVILLE		Serial Number:	40984
RDL Result:	0.58%	KY	41465	Test Error Code:	**
Test Time (Sec):	28	Altitude (ft): 0		Test Temp (C):	22

Test #:	00073	BTU GAS		User:	JASON WESLEY
Test Start Date:	11-15-10	LOCATION 3 MOUTH OF		Notes:	
Test Start Time:	01:07:31	LITTERAL FK		DTEX Model:	DX1000G
TDL Result:	0.03%	SALYERSVILLE		Serial Number:	40984
RDL Result:	0.64%	KY	41465	Test Error Code:	**
Test Time (Sec):	15	Altitude (ft): 0		Test Temp (C):	22

Test #:	00074	BTU GAS		User:	JASON WESLEY
Test Start Date:	11-15-10	LOCATION 4 METER SET		Notes:	
Test Start Time:	01:35:03	ON RT 114		DTEX Model:	DX1000G
TDL Result:	0.03%	SALYERSVILLE		Serial Number:	40984
RDL Result:	0.58%	KY	41465	Test Error Code:	**
Test Time (Sec):	26	Altitude (ft): 0		Test Temp (C):	21

Test #:	00075	BTU GAS		User:	JASON WESLEY
Test Start Date:	11-15-10	LOCATION 4 METER SET		Notes:	
Test Start Time:	01:35:42	ON RT 114		DTEX Model:	DX1000G
TDL Result:	0.03%	SALYERSVILLE		Serial Number:	40984
RDL Result:	0.75%	KY	41465	Test Error Code:	**
Test Time (Sec):	14	Altitude (ft): 0		Test Temp (C):	21

DTEX Test Log

Test #:	00005	COW CR. GAS TEST #1		User:	JASON WESLEY
Test Start Date:	11-19-10	FLOYD CO.		Notes:	
Test Start Time:	00:16:50	<Blank>		DTEX Model:	DX1000G
TDL Result:	0.05%	PRESTONSBURG		Serial Number:	40984
RDL Result:	0.68%	KY	<Blank>	Test Error Code:	**
Test Time (Sec):	10	Altitude (ft): 0		Test Temp (C):	24

DTEX Test Log

Test #:	00006	COW CR. GAS TEST #2		User:	JASON WESLEY
Test Start Date:	11-19-10	FLOYD CO. HOME BR.		Notes:	
Test Start Time:	00:29:51	<Blank>		DTEX Model:	DX1000G
TDL Result:	0.03%	PRESTONSBURG		Serial Number:	40984
RDL Result:	0.66%	KY	<Blank>	Test Error Code:	**
Test Time (Sec):	14	Altitude (ft): 0		Test Temp (C):	24

DTEX Test Log

Test #:	00010	DEMA GAS TEST #1		User:	JASON WESLEY
Test Start Date:	11-19-10	MARK ANDERSON METER		Notes:	
Test Start Time:	02:12:39	SET		DTEX Model:	DX1000G
TDL Result:	0.03%	TOPMOST		Serial Number:	40984
RDL Result:	0.66%	KY	<Blank>	Test Error Code:	**
Test Time (Sec):	13	Altitude (ft): 0		Test Temp (C):	28

DTEX Test Log

Test #:	00011	COW CR. GAS MAG. CO.		User:	JASON WESLEY
Test Start Date:	11-19-10	BLOCK BUILDING		Notes:	
Test Start Time:	04:07:47	<Blank>		DTEX Model:	DX1000G
TDL Result:	0.02%	SALYERSVILLE		Serial Number:	40984
RDL Result:	0.61%	KY	41465	Test Error Code:	**
Test Time (Sec):	18	Altitude (ft): 0		Test Temp (C):	28

DTEX Test Log

Test #	00004	COW CR. GAS TEST #1		User:	JASON WESLEY
Test Start Date:	11-23-10	FLOYD CO.		Notes:	
Test Start Time:	23:16:38	<Blank>		DTEX Model:	DX1000G
TDL Result:	0.04%	PRESTONSBURG		Serial Number:	40984
RDL Result:	0.58%	KY	<Blank>	Test Error Code:	**
Test Time (Sec):	10	Altitude (ft): 0		Test Temp (C):	17

DTEX Test Log

Test #:	00007	COW CR. GAS TEST #2		User:	JASON WESLEY
Test Start Date:	11-23-10	FLOYD CO. HOME BR.		Notes:	
Test Start Time:	23:31:11	<Blank>		DTEX Model:	DX1000G
TDL Result:	0.04%	PRESTONSBURG		Serial Number:	40984
RDL Result:	0.70%	KY	<Blank>	Test Error Code:	**
Test Time (Sec)	10	Altitude (ft): 0		Test Temp (C):	18

DTEX Test Log

Test #:	00018	DEMA GAS TEST #1		User:	JASON WESLEY
Test Start Date:	11-24-10	MARK ANDERSON METER		Notes:	
Test Start Time:	07:33:14	SET		DTEX Model:	DX1000G
TDL Result:	0.04%	TOPMOST		Serial Number:	40984
RDL Result:	0.68%	KY	<Blank>	Test Error Code:	**
Test Time (Sec):	10	Altitude (ft): 0		Test Temp (C):	25

DTEX Test Log

Test #:	00009	COW CR. GAS MAG. CO.		User:	JASON WESLEY
Test Start Date:	11-24-10	BLOCK BUILDING		Notes:	
Test Start Time:	06:18:31	<Blank>		DTEX Model:	DX1000G
TDL Result:	0.02%	SALYERSVILLE		Serial Number:	40984
RDL Result:	0.63%	KY	41465	Test Error Code:	**
Test Time (Sec):	10	Altitude (ft): 0		Test Temp (C):	30

DTEX Test Log

Test #	00019	COW CR. GAS TEST #1		User:	JASON WESLEY
Test Start Date:	12-02-10	FLOYD CO.		Notes:	
Test Start Time:	23:24:59	<Blank>		DTEX Model:	DX1000G
TDL Result:	0.04%	PRESTONSBURG		Serial Number:	40984
RDL Result:	0.66%	KY	<Blank>	Test Error Code:	**
Test Time (Sec):	16	Altitude (ft): 0		Test Temp (C):	22

DTEX Test Log

Test #:	00021	COW CR. GAS TEST #2		User:	JASON WESLEY
Test Start Date:	12-02-10	FLOYD CO. HOME BR.		Notes:	
Test Start Time:	23:38:34	<Blank>		DTEX Model:	DX1000G
TDL Result:	0.04%	PRESTONSBURG		Serial Number:	40984
RDL Result:	0.70%	KY	<Blank>	Test Error Code:	**
Test Time (Sec):	14	Altitude (ft): 0		Test Temp (C):	24

DTEX Test Log

Test #:	00026	COW CR. GAS MAG. CO.		User:	JASON WESLEY
Test Start Date:	12-06-10	BLOCK BUILDING		Notes:	
Test Start Time:	03:29:19	<Blank>		DTEX Model:	DX1000G
TDL Result:	0.03%	SALYERSVILLE		Serial Number:	40984
RDL Result:	0.63%	KY	41465	Test Error Code:	**
Test Time (Sec)	13	Altitude (ft): 0		Test Temp (C):	28

DTEX Test Log

Test #:	00036	DEMA GAS TEST #1		User:	JASON WESLEY
Test Start Date:	12-06-10	MARK ANDERSON METER		Notes:	
Test Start Time:	05:59:45	SET		DTEX Model:	DX1000G
TDL Result:	0.04%	TOPMOST		Serial Number:	40984
RDL Result:	0.74%	KY	<Blank>	Test Error Code:	**
Test Time (Sec):	13	Altitude (ft): 0		Test Temp (C):	12

DTEX Test Log

. est #	00001	COW CR. GAS TEST #1		User:	JASON WESLEY
Test Start Date:	12-16-10	FLOYD CO.		Notes:	
Test Start Time	21:42:53	<Blank>		DTEX Model:	DX1000G
TDL Result:	0.03%	PRESTONSBURG		Serial Number:	40984
RDL Result:	0.65%	KY	<Blank>	Test Error Code:	**
Test Time (Sec):	16	Altitude (ft): 0		Test Temp (C):	28

DTEX Test Log

est #:	00003	COW CR. GAS TEST #2		User:	JASON WESLEY
Test Start Date:	12-16-10	FLOYD CO. HOME BR.		Notes:	
Test Start Time:	21:58:40	<Blank>		DTEX Model:	DX1000G
TDL Result:	0.04%	PRESTONSBURG		Serial Number:	40984
RDL Result:	0.71%	KY	<Blank>	Test Error Code:	**
Test Time (Sec)	13	Altitude (ft): 0		Test Temp (C):	28

DTEX Test Log

Test #:	00004	DEMA GAS TEST #1		User:	JASON WESLEY
Test Start Date:	12-17-10	MARK ANDERSON METER		Notes:	
Test Start Time:	11:03:11	SET		DTEX Model:	DX1000G
TDL Result:	0.04%	TOPMOST		Serial Number:	40984
RDL Result:	0.63%	KY	<Blank>	Test Error Code:	**
Test Time (Sec)	14	Altitude (ft): 0		Test Temp (C):	25

DTEX Test Log

Test #:	00005	COW CR. GAS MAG. CO.		User:	JASON WESLEY
Test Start Date:	12-17-10	BLOCK BUILDING		Notes:	
Test Start Time:	03:08:15	<Blank>		DTEX Model:	DX1000G
TDL Result:	0.04%	SALYERSVILLE		Serial Number:	40984
RDL Result:	0.62%	KY	41465	Test Error Code:	**
Test Time (Sec):	15	Altitude (ft): 0		Test Temp (C):	24

DTEX Test Log

Test #:	00014	COW CR. GAS TEST #1		User:	JASON WESLEY
Test Start Date:	12-21-10	FLOYD CO.		Notes:	
Test Start Time:	23:34:53	<Blank>		DTEX Model:	DX1000G
TDL Result:	0.04%	PRESTONSBURG		Serial Number:	40984
RDL Result:	0.62%	KY	<Blank>	Test Error Code:	**
Test Time (Sec):	14	Altitude (ft): 0		Test Temp (C):	20

DTEX Test Log

, est #:	00015	COW CR. GAS TEST #2		User:	JASON WESLEY
Test Start Date:	12-21-10	FLOYD CO. HOME BR.		Notes:	
Test Start Time:	23:57:04	<Blank>		DTEX Model:	DX1000G
TDL Result:	0.03%	PRESTONSBURG		Serial Number:	40984
RDL Result:	0.63%	KY	<Blank>	Test Error Code:	**
Test Time (Sec):	14	Altitude (ft): 0		Test Temp (C):	16

DTEX Test Log

Test #	00016	DEMA GAS TEST #1		User:	JASON WESLEY
Test Start Date:	12-21-10	MARK ANDERSON METER		Notes:	
Test Start Time:	02:21:17	SET		DTEX Model:	DX1000G
TDL Result:	0.04%	TOPMOST		Serial Number:	40984
RDL Result	0.67%	KY	<Blank>	Test Error Code:	**
Test Time (Sec)	11	Altitude (ft): 0		Test Temp (C):	16

DTEX Test Log

.est #:	00017	COW CR. GAS MAG. CO.		User:	JASON WESLEY
Test Start Date:	12-21-10	BLOCK BUILDING		Notes:	
Test Start Time:	03:55:15	<Blank>		DTEX Model:	DX1000G
TDL Result:	0.04%	SALYERSVILLE		Serial Number:	40984
RDL Result:	0.69%	KY	41465	Test Error Code:	**
Test Time (Sec)	11	Altitude (ft): 0		Test Temp (C):	16

DTEX Test Log

Test #	00009	DEMA GAS TEST #1		User:	JASON WESLEY
Test Start Date:	01-06-11	MARK ANDERSON METER		Notes:	
Test Start Time:	05:52:13	SET		DTEX Model:	DX1000G
TDL Result:	0.03%	TOPMOST		Serial Number:	40984
RDL Result:	0.63%	KY	<Blank>	Test Error Code:	**
Test Time (Sec):	9	Altitude (ft): 0		Test Temp (C):	18

DTEX Test Log

Test #	00001	COW CR. GAS TEST #1		User:	JASON WESLEY
Test Start Date	01-06-11	FLOYD CO.		Notes:	
Test Start Time	11:15:09	<Blank>		DTEX Model:	DX1000G
TDL Result	0.05%	PRESTONSBURG		Serial Number:	40984
RDL Result	0.68%	KY	<Blank>	Test Error Code:	**
Test Time (Sec)	14	Altitude (ft): 0		Test Temp (C):	17

DTEX Test Log

est #	00002	COW CR. GAS TEST #2		User:	JASON WESLEY
Test Start Date:	01-06-11	FLOYD CO. HOME BR.		Notes:	
Test Start Time:	11:35:15	<Blank>		DTEX Model:	DX1000G
TDL Result	0.03%	PRESTONSBURG		Serial Number:	40984
RDL Result:	0.65%	KY	<Blank>	Test Error Code:	**
Test Time (Sec)	14	Altitude (ft): 0		Test Temp (C):	18

DTEX Test Log

Test #:	00004	COW CR. GAS MAG. CO.		User:	JASON WESLEY
Test Start Date:	01-06-11	BLOCK BUILDING		Notes:	
Test Start Time:	14:43:33	<Blank>		DTEX Model:	DX1000G
TDL Result:	0.02%	SALYERSVILLE		Serial Number:	40984
RDL Result:	0.60%	KY	41465	Test Error Code:	**
Test Time (Sec):	12	Altitude (ft): 0		Test Temp (C):	18

DTEX Test Log

Test #:	00012	DEMA GAS TEST #1		User:	JASON WESLEY
Test Start Date:	01-13-11	MARK ANDERSON METER		Notes:	
Test Start Time:	03:02:42	SET		DTEX Model:	DX1000G
TDL Result:	0.04%	TOPMOST		Serial Number:	40984
RDL Result:	0.65%	KY	<Blank>	Test Error Code:	**
Test Time (Sec):	9	Altitude (ft): 0		Test Temp (C):	18

DTEX Test Log

Test #	00013	COW CR. GAS TEST #1		User:	JASON WESLEY
Test Start Date:	01-13-11	FLOYD CO.		Notes:	
Test Start Time:	04:00:29	<Blank>		DTEX Model:	DX1000G
TDL Result:	0.03%	PRESTONSBURG		Serial Number:	40984
RDL Result:	0.68%	KY	<Blank>	Test Error Code:	**
Test Time (Sec):	17	Altitude (ft): 0		Test Temp (C):	20

DTEX Test Log

Test #	00014	COW CR. GAS TEST #2		User:	JASON WESLEY
Test Start Date:	01-20-11	FLOYD CO. HOME BR.		Notes:	
Test Start Time:	00:08:02	<Blank>		DTEX Model:	DX1000G
TDL Result	0.02%	PRESTONSBURG		Serial Number:	40984
RDL Result	0.65%	KY	<Blank>	Test Error Code:	**
Test Time (Sec):	20	Altitude (ft): 0		Test Temp (C):	25

DTEX Test Log

..st #:	00017	COW CR. GAS TEST #1		User:	JASON WESLEY
Test Start Date:	01-20-11	FLOYD CO.		Notes:	
Test Start Time:	11:10:02	<Blank>		DTEX Model:	DX1000G
TDL Result:	0.03%	PRESTONSBURG		Serial Number:	40984
RDL Result:	0.69%	KY	<Blank>	Test Error Code:	**
Test Time (Sec):	12	Altitude (ft): 0		Test Temp (C):	25

DTEX Test Log

Test #:	00018	DEMA GAS TEST #1		User:	JASON WESLEY
Test Start Date:	01-20-11	MARK ANDERSON METER		Notes:	
Test Start Time:	12:51:11	SET		DTEX Model:	DX1000G
TDL Result:	0.03%	TOPMOST		Serial Number:	40984
RDL Result:	0.71%	KY	<Blank>	Test Error Code:	**
Test Time (Sec):	11	Altitude (ft): 0		Test Temp (C):	25

DTEX Test Log

Test #	00020	COW CR. GAS MAG. CO.		User:	JASON WESLEY
Test Start Date:	01-20-11	BLOCK BUILDING		Notes:	
Test Start Time:	02:15:39	<Blank>		DTEX Model:	DX1000G
TDL Result:	0.02%	SALYERSVILLE		Serial Number:	40984
RDL Result:	0.63%	KY	41465	Test Error Code:	**
Test Time (Sec):	17	Altitude (ft): 0		Test Temp (C):	24

DTEX Test Log

Test #	00038	DEMA GAS TEST #1		User:	JASON WESLEY
Test Start Date	01-26-11	MARK ANDERSON METER		Notes:	
Test Start Time	05:06:14	SET		DTEX Model:	DX1000G
TDL Result	0.02%	TOPMOST		Serial Number:	40984
RDL Result	0.61%	KY	<Blank>	Test Error Code:	**
Test Time (Sec)	11	Altitude (ft): 0		Test Temp (C):	17

DTEX Test Log

est #	00026	COW CR. GAS TEST #1		User:	JASON WESLEY
Test Start Date:	01-26-11	FLOYD CO.		Notes:	
Test Start Time:	09:45:45	<Blank>		DTEX Model:	DX1000G
TDL Result:	0.03%	PRESTONSBURG		Serial Number:	40984
RDL Result	0.67%	KY	<Blank>	Test Error Code:	**
Test Time (Sec)	13	Altitude (ft): 0		Test Temp (C)	18

DTEX Test Log

est #	00027	COW CR. GAS TEST #2		User:	JASON WESLEY
Test Start Date	01-26-11	FLOYD CO. HOME BR.		Notes:	
Test Start Time	10:13:13	<Blank>		DTEX Model:	DX1000G
TDL Result	0.03%	PRESTONSBURG		Serial Number:	40984
RDL Result	0.67%	KY	<Blank>	Test Error Code:	**
Test Time (Sec)	11	Altitude (ft): 0		Test Temp (C)	18

DTEX Test Log

Test #:	00030	COW CR. GAS MAG. CO.		User:	JASON WESLEY
Test Start Date:	01-26-11	BLOCK BUILDING		Notes:	
Test Start Time:	02:18:09	<Blank>		DTEX Model:	DX1000G
TDL Result:	0.03%	SALYERSVILLE		Serial Number:	40984
RDL Result:	0.68%	KY	41465	Test Error Code:	**
Test Time (Sec):	21	Altitude (ft): 0		Test Temp (C):	17

DTEX Test Log

Test #:	00008	COW CR. GAS TEST #1		User:	JASON WESLEY
Test Start Date:	02-02-11	FLOYD CO.		Notes:	
Test Start Time:	03:41:20	<Blank>		DTEX Model:	DX1000G
TDL Result:	0.03%	PRESTONSBURG		Serial Number:	40984
RDL Result:	0.68%	KY	<Blank>	Test Error Code:	**
Test Time (Sec)	10	Altitude (ft): 0		Test Temp (C):	21

DTEX Test Log

Test #:	00010	COW CR. GAS TEST #2		User:	JASON WESLEY
Test Start Date:	02-02-11	FLOYD CO. HOME BR.		Notes:	
Test Start Time:	03:56:39	<Blank>		DTEX Model:	DX1000G
TDL Result:	0.05%	PRESTONSBURG		Serial Number:	40984
RDL Result:	0.68%	KY	<Blank>	Test Error Code:	**
Test Time (Sec):	10	Altitude (ft): 0		Test Temp (C):	21

DTEX Test Log

..st #:	00012	DEMA GAS TEST #1		User:	JASON WESLEY
Test Start Date:	02-02-11	MARK ANDERSON METER		Notes:	
Test Start Time:	05:17:40	SET		DTEX Model:	DX1000G
TDL Result:	0.04%	TOPMOST		Serial Number:	40984
RDL Result:	0.68%	KY	<Blank>	Test Error Code:	**
Test Time (Sec):	9	Altitude (ft): 0		Test Temp (C):	21

DTEX Test Log

Test #	00002	COW CR. GAS MAG. CO.		User:	JASON WESLEY
Test Start Date:	02-02-11	BLOCK BUILDING		Notes:	
Test Start Time:	11:30:42	<Blank>		DTEX Model:	DX1000G
TDL Result:	0.03%	SALYERSVILLE		Serial Number:	40984
RDL Result:	0.59%	KY	41465	Test Error Code:	**
Test Time (Sec):	14	Altitude (ft): 0		Test Temp (C):	21

DTEX Test Log

Test #:	00014	COW CR. GAS TEST #1		User:	JASON WESLEY
Test Start Date:	02-09-11	FLOYD CO.		Notes:	
Test Start Time:	09:24:39	<Blank>		DTEX Model:	DX1000G
TDL Result	0.02%	PRESTONSBURG		Serial Number:	40984
RDL Result	0.58%	KY	<Blank>	Test Error Code:	**
Test Time (Sec)	10	Altitude (ft): 0		Test Temp (C):	18

DTEX Test Log

.st #:	00015	COW CR. GAS TEST #2		User:	JASON WESLEY
Test Start Date:	02-09-11	FLOYD CO. HOME BR.		Notes:	
Test Start Time:	09:58:11	<Blank>		DTEX Model:	DX1000G
TDL Result	0.03%	PRESTONSBURG		Serial Number:	40984
RDL Result	0.65%	KY	<Blank>	Test Error Code:	**
Test Time (Sec):	10	Altitude (ft): 0		Test Temp (C):	18

DTEX Test Log

.st #	00016	DEMA GAS TEST #1		User:	JASON WESLEY
Test Start Date	02-09-11	MARK ANDERSON METER		Notes:	
Test Start Time	11:13:11	SET		DTEX Model:	DX1000G
TDL Result:	0.03%	TOPMOST		Serial Number:	40984
RDL Result:	0.65%	KY	<Blank>	Test Error Code:	**
Test Time (Sec)	9	Altitude (ft): 0		Test Temp (C):	18

DTEX Test Log

Test #	00017	COW CR. GAS MAG. CO.		User:	JASON WESLEY
Test Start Date	02-09-11	BLOCK BUILDING		Notes:	
Test Start Time	02:16:12	<Blank>		DTEX Model:	DX1000G
TDL Result	0.03%	SALYERSVILLE		Serial Number:	40984
RDL Result	0.63%	KY	41465	Test Error Code:	**
Test Time (Sec)	8	Altitude (ft): 0		Test Temp (C):	18

DTEX Test Log

.st #	00024	COW CR. GAS TEST #1		User:	JASON WESLEY
Test Start Date:	02-15-11	FLOYD CO.		Notes:	
Test Start Time:	09:28:02	<Blank>		DTEX Model:	DX1000G
TDL Result:	0.03%	PRESTONSBURG		Serial Number:	40984
RDL Result:	0.70%	KY	<Blank>	Test Error Code:	**
Test Time (Sec)	12	Altitude (ft): 0		Test Temp (C):	20

DTEX Test Log

Test #	00025	COW CR. GAS TEST #2		User:	JASON WESLEY
Test Start Date:	02-15-11	FLOYD CO. HOME BR.		Notes:	
Test Start Time:	09:51:14	<Blank>		DTEX Model:	DX1000G
TDL Result:	0.03%	PRESTONSBURG		Serial Number:	40984
RDL Result:	0.65%	KY	<Blank>	Test Error Code:	**
Test Time (Sec):	12	Altitude (ft): 0		Test Temp (C):	21

DTEX Test Log

Test #:	00027	DEMA GAS TEST #1		User:	JASON WESLEY
Test Start Date:	02-15-11	MARK ANDERSON METER		Notes:	
Test Start Time:	11:23:40	SET		DTEX Model:	DX1000G
TDL Result:	0.04%	TOPMOST		Serial Number:	40984
RDL Result:	0.69%	KY	<Blank>	Test Error Code:	**
Test Time (Sec)	10	Altitude (ft): 0		Test Temp (C):	21

DTEX Test Log

Test #:	00029	COW CR. GAS MAG. CO.		User:	JASON WESLEY
Test Start Date:	02-15-11	BLOCK BUILDING		Notes:	
Test Start Time	12:57:38	<Blank>		DTEX Model:	DX1000G
TDL Result	0.01%	SALYERSVILLE		Serial Number:	40984
RDL Result	0.60%	KY	41465	Test Error Code:	**
Test Time (Sec):	17	Altitude (ft): 0		Test Temp (C):	26

DTEX Test Log

Test #	00035	COW CR. GAS TEST #1		User:	JASON WESLEY
Test Start Date:	02-22-11	FLOYD CO.		Notes:	
Test Start Time:	11:13:43	<Blank>		DTEX Model:	DX1000G
TDL Result:	0.03%	PRESTONSBURG		Serial Number:	40984
RDL Result	0.65%	KY	<Blank>	Test Error Code:	**
Test Time (Sec):	15	Altitude (ft): 0		Test Temp (C):	28

DTEX Test Log

Test #	00036	COW CR. GAS TEST #2		User:	JASON WESLEY
Test Start Date	02-22-11	FLOYD CO. HOME BR.		Notes:	
Test Start Time	11:38:13	<Blank>		DTEX Model:	DX1000G
TDL Result:	0.03%	PRESTONSBURG		Serial Number:	40984
RDL Result:	0.69%	KY	<Blank>	Test Error Code:	**
Test Time (Sec)	15	Altitude (ft): 0		Test Temp (C):	28

DTEX Test Log

Test #:	00037	DEMA GAS TEST #1		User:	JASON WESLEY
Test Start Date:	02-22-11	MARK ANDERSON METER		Notes:	
Test Start Time:	01:36:12	SET		DTEX Model:	DX1000G
TDL Result	0.03%	TOPMOST		Serial Number:	40984
RDL Result	0.69%	KY	<Blank>	Test Error Code:	**
Test Time (Sec):	11	Altitude (ft): 0		Test Temp (C):	28

DTEX Test Log

Test #:	00038	COW CR. GAS MAG. CO.		User:	JASON WESLEY
Test Start Date:	02-22-11	BLOCK BUILDING		Notes:	
Test Start Time:	02:51:12	<Blank>		DTEX Model:	DX1000G
TDL Result:	0.03%	SALYERSVILLE		Serial Number:	40984
RDL Result:	0.70%	KY	41465	Test Error Code:	**
Test Time (Sec):	11	Altitude (ft): 0		Test Temp (C):	28

DTEX Test Log

Test #:	00044	COW CR. GAS TEST #1		User:	JASON WESLEY
Test Start Date:	03-01-11	FLOYD CO.		Notes:	
Test Start Time:	09:03:44	<Blank>		DTEX Model:	DX1000G
TDL Result:	0.03%	PRESTONSBURG		Serial Number:	40984
RDL Result:	0.63%	KY	<Blank>	Test Error Code:	**
Test Time (Sec):	12	Altitude (ft): 0		Test Temp (C):	22

DTEX Test Log

.st #	00045	COW CR. GAS TEST #2		User:	JASON WESLEY
Test Start Date:	03-01-11	FLOYD CO. HOME BR.		Notes:	
Test Start Time:	09:41:13	<Blank>		DTEX Model:	DX1000G
TDL Result:	0.03%	PRESTONSBURG		Serial Number:	40984
RDL Result:	0.63%	KY	<Blank>	Test Error Code:	**
Test Time (Sec):	11	Altitude (ft): 0		Test Temp (C):	22

DTEX Test Log

Test #:	00047	DEMA GAS TEST #1		User:	JASON WESLEY
Test Start Date:	03-01-11	MARK ANDERSON METER		Notes:	
Test Start Time:	12:38:41	SET		DTEX Model:	DX1000G
TDL Result:	0.02%	TOPMOST		Serial Number:	40984
RDL Result:	0.70%	KY	<Blank>	Test Error Code:	**
Test Time (Sec):	15	Altitude (ft): 0		Test Temp (C):	22

DTEX Test Log

..st #:	00049	COW CR. GAS MAG. CO.		User:	JASON WESLEY
Test Start Date:	03-01-11	BLOCK BUILDING		Notes:	
Test Start Time:	02:21:37	<Blank>		DTEX Model:	DX1000G
TDL Result:	0.03%	SALYERSVILLE		Serial Number:	40984
RDL Result:	0.68%	KY	41465	Test Error Code:	**
Test Time (Sec):	8	Altitude (ft): 0		Test Temp (C):	22

DTEX Test Log

Test #:	00002	COW CR GAS TEST #1		User:	JASON WESLEY
Test Start Date:	03-08-11	FLOYD CO.		Notes:	
Test Start Time:	09:04:42	<Blank>		DTEX Model:	DX1000G
TDL Result	0.03%	PRESTONSBURG		Serial Number:	40984
RDL Result:	0.65%	KY	<Blank>	Test Error Code:	**
Test Time (Sec)	10	Altitude (ft): 0		Test Temp (C):	16

DTEX Test Log

Test #	00004	COW CR. GAS TEST #2		User:	JASON WESLEY
Test Start Date	03-08-11	FLOYD CO. HOME BR.		Notes:	
Test Start Time	09:47:42	<Blank>		DTEX Model:	DX1000G
TDL Result	0.03%	PRESTONSBURG		Serial Number:	40984
RDL Result	0.68%	KY	<Blank>	Test Error Code:	**
Test Time (Sec)	8	Altitude (ft): 0		Test Temp (C):	16

DTEX Test Log

Test #:	00005	DEMA GAS TEST #1		User:	JASON WESLEY
Test Start Date:	03-08-11	MARK ANDERSON METER		Notes:	
Test Start Time:	11:13:12	SET		DTEX Model:	DX1000G
TDL Result:	0.04%	TOPMOST		Serial Number:	40984
RDL Result:	0.68%	KY	<Blank>	Test Error Code:	**
Test Time (Sec):	8	Altitude (ft): 0		Test Temp (C):	16

DTEX Test Log

Test #	00007	COW CR. GAS MAG. CO.		User:	JASON WESLEY
Test Start Date	03-08-11	BLOCK BUILDING		Notes:	
Test Start Time	12:47:30	<Blank>		DTEX Model:	DX1000G
TDL Result:	0.02%	SALYERSVILLE		Serial Number:	40984
RDL Result:	0.68%	KY	41465	Test Error Code:	**
Test Time (Sec)	12	Altitude (ft): 0		Test Temp (C):	18

DTEX Test Log

..st #	00017	COW CR. GAS TEST #1		User:	JASON WESLEY
Test Start Date	03-14-11	FLOYD CO.		Notes:	
Test Start Time	09:21:45	<Blank>		DTEX Model:	DX1000G
TDL Result	0.02%	PRESTONSBURG		Serial Number:	40984
RDL Result	0.68%	KY	<Blank>	Test Error Code:	**
Test Time (Sec)	15	Altitude (ft): 0		Test Temp (C):	28

DTEX Test Log

Test #	00018	COW CR. GAS TEST #2		User:	JASON WESLEY
Test Start Date:	03-14-11	FLOYD CO. HOME BR.		Notes:	
Test Start Time:	09:46:15	<Blank>		DTEX Model:	DX1000G
TDL Result:	0.03%	PRESTONSBURG		Serial Number:	40984
RDL Result:	0.70%	KY	<Blank>	Test Error Code:	**
Test Time (Sec)	15	Altitude (ft): 0		Test Temp (C):	28

DTEX Test Log

Test #:	00020	DEMA GAS TEST #1		User:	JASON WESLEY
Test Start Date:	03-14-11	MARK ANDERSON METER		Notes:	
Test Start Time:	11:18:49	SET		DTEX Model:	DX1000G
TDL Result:	0.03%	TOPMOST		Serial Number:	40984
RDL Result:	0.65%	KY	<Blank>	Test Error Code:	**
Test Time (Sec):	13	Altitude (ft): 0		Test Temp (C):	28

DTEX Test Log

,st #	00023	COW CR. GAS MAG. CO.		User:	JASON WESLEY
Test Start Date	03-14-11	BLOCK BUILDING		Notes:	
Test Start Time	02:10:19	<Blank>		DTEX Model:	DX1000G
TDL Result	0.02%	SALYERSVILLE		Serial Number:	40984
RDL Result	0.65%	KY	41465	Test Error Code:	**
Test Time (Sec)	15	Altitude (ft): 0		Test Temp (C):	30

DTEX Test Log

Test #	00033	DEMA GAS TEST #1		User:	JASON WESLEY
Test Start Date:	03-21-11	MARK ANDERSON METER		Notes:	
Test Start Time:	09:05:22	SET		DTEX Model:	DX1000G
TDL Result:	0.03%	TOPMOST		Serial Number:	40984
RDL Result:	0.70%	KY	<Blank>	Test Error Code:	**
Test Time (Sec)	15	Altitude (ft): 0		Test Temp (C):	26

DTEX Test Log

Test #	00035	COW CR. GAS TEST #1		User:	JASON WESLEY
Test Start Date:	03-21-11	FLOYD CO.		Notes:	
Test Start Time:	12:37:52	<Blank>		DTEX Model:	DX1000G
TDL Result:	0.03%	PRESTONSBURG		Serial Number:	40984
RDL Result:	0.60%	KY	<Blank>	Test Error Code:	**
Test Time (Sec):	13	Altitude (ft): 0		Test Temp (C):	26

DTEX Test Log

Test #	00036	COW CR. GAS TEST #2		User:	JASON WESLEY
Test Start Date	03-21-11	FLOYD CO. HOME BR.		Notes:	
Test Start Time:	12:51:11	<Blank>		DTEX Model:	DX1000G
TDL Result	0.03%	PRESTONSBURG		Serial Number:	40984
RDL Result:	0.63%	KY	<Blank>	Test Error Code:	**
Test Time (Sec)	13	Altitude (ft): 0		Test Temp (C):	26

DTEX Test Log

Test #:	00039	COW CR. GAS MAG. CO.		User:	JASON WESLEY
Test Start Date:	03-21-11	BLOCK BUILDING		Notes:	
Test Start Time:	01:50:10	<Blank>		DTEX Model:	DX1000G
TDL Result:	0.03%	SALYERSVILLE		Serial Number:	40984
RDL Result:	0.60%	KY	41465	Test Error Code:	**
Test Time (Sec)	13	Altitude (ft): 0		Test Temp (C):	24

DTEX Test Log

Test #	00049	COW CR. GAS TEST #1		User:	JASON WESLEY
Test Start Date:	03-27-11	FLOYD CO.		Notes:	
Test Start Time:	10.52:45	<Blank>		DTEX Model:	DX1000G
TDL Result:	0.03%	PRESTONSBURG		Serial Number:	40984
RDL Result:	0.66%	KY	<Blank>	Test Error Code:	**
Test Time (Sec):	12	Altitude (ft): 0		Test Temp (C):	20

DTEX Test Log

Test #:	00050	COW CR. GAS TEST #2		User:	JASON WESLEY
Test Start Date:	03-27-11	FLOYD CO. HOME BR.		Notes:	
Test Start Time:	11:36:15	<Blank>		DTEX Model:	DX1000G
TDL Result:	0.04%	PRESTONSBURG		Serial Number:	40984
RDL Result:	0.65%	KY	<Blank>	Test Error Code:	**
Test Time (Sec):	14	Altitude (ft): 0		Test Temp (C):	20

DTEX Test Log

Test #:	00051	DEMA GAS TEST #1		User:	JASON WESLEY
Test Start Date:	03-27-11	MARK ANDERSON METER		Notes:	
Test Start Time:	01:13:13	SET		DTEX Model:	DX1000G
TDL Result:	0.03%	TOPMOST		Serial Number:	40984
RDL Result:	0.65%	KY	<Blank>	Test Error Code:	**
Test Time (Sec):	13	Altitude (ft): 0		Test Temp (C):	20

DTEX Test Log

Test #:	00053	COW CR. GAS MAG. CO.		User:	JASON WESLEY
Test Start Date:	03-27-11	BLOCK BUILDING		Notes:	
Test Start Time:	02:28:42	<Blank>		DTEX Model:	DX1000G
TDL Result:	0.02%	SALYERSVILLE		Serial Number:	40984
RDL Result:	0.63%	KY	41465	Test Error Code:	**
Test Time (Sec):	141	Altitude (ft): 0		Test Temp (C):	25

DTEX Test Log

Test #:	00062	COW CR. GAS TEST #1		User:	JASON WESLEY
Test Start Date:	04-03-11	FLOYD CO.		Notes:	
Test Start Time:	11:18:17	<Blank>		DTEX Model:	DX1000G
TDL Result:	0.03%	PRESTONSBURG		Serial Number:	40984
RDL Result:	0.63%	KY	<Blank>	Test Error Code:	**
Test Time (Sec):	22	Altitude (ft): 0		Test Temp (C):	30

DTEX Test Log

Test #:	00063	COW CR. GAS TEST #2		User:	JASON WESLEY
Test Start Date:	04-03-11	FLOYD CO. HOME BR.		Notes:	
Test Start Time:	11:42:13	<Blank>		DTEX Model:	DX1000G
TDL Result:	0.03%	PRESTONSBURG		Serial Number:	40984
RDL Result:	0.66%	KY	<Blank>	Test Error Code:	**
Test Time (Sec):	12	Altitude (ft): 0		Test Temp (C):	30

DTEX Test Log

Test #	00064	DEMA GAS TEST #1		User:	JASON WESLEY
Test Start Date:	04-03-11	MARK ANDERSON METER		Notes:	
Test Start Time	01:35:12	SET		DTEX Model:	DX1000G
TDL Result:	0.03%	TOPMOST		Serial Number:	40984
RDL Result	0.69%	KY	<Blank>	Test Error Code:	**
Test Time (Sec)	13	Altitude (ft): 0		Test Temp (C):	30

DTEX Test Log

Test #	00065	COW CR. GAS MAG. CO		User:	JASON WESLEY
Test Start Date:	04-03-11	BLOCK BUILDING		Notes:	
Test Start Time:	02:53:13	<Blank>		DTEX Model:	DX1000G
TDL Result:	0.04%	SALYERSVILLE		Serial Number:	40984
RDL Result:	0.66%	KY	41465	Test Error Code:	**
Test Time (Sec)	15	Altitude (ft): 0		Test Temp (C):	30

DTEX Test Log

#	00006	DEMA GAS TEST #1		User	JASON WESLEY
Test Start Date	04-09-11	MARK ANDERSON METER		Notes	
Test Start Time	11:46:14	SET		DTEX Model	DX1000G
TDL Result	0.03%	TOPMOST		Serial Number	40984
RDL Result	0.70%	KY	<Blank>	Test Error Code	**
Test Time (Sec)	14	Altitude (ft): 0		Test Temp (C)	14

DTEX Test Log

#	00007	COW CR. GAS MAG. CO.		User:	JASON WESLEY
Test Start Date:	04-09-11	BLOCK BUILDING		Notes:	
Test Start Time:	02:51:13	<Blank>		DTEX Model:	DX1000G
TDL Result:	0.02%	SALYERSVILLE		Serial Number:	40984
RDL Result	0.68%	KY	41465	Test Error Code:	**
Test Time (Sec):	15	Altitude (ft): 0		Test Temp (C):	29

DTEX Test Log

#:	00002	COW CR. GAS TEST #1		User:	JASON WESLEY
Test Start Date:	04-09-11	FLOYD CO.		Notes:	
Test Start Time:	09:37:44	<Blank>		DTEX Model:	DX1000G
TDL Result:	0.03%	PRESTONSBURG		Serial Number:	40984
RDL Result	0.68%	KY	<Blank>	Test Error Code:	**
Test Time (Sec):	14	Altitude (ft): 0		Test Temp (C):	13

DTEX Test Log

st #:	00004	COW CR GAS TEST #2		User:	JASON WESLEY
st Start Date:	04-09-11	FLOYD CO. HOME BR.		Notes:	
Test Start Time:	10:03:48	<Blank>		DTEX Model:	DX1000G
TDL Result:	0.04%	PRESTONSBURG		Serial Number:	40984
RDL Result:	0.72%	KY	<Blank>	Test Error Code:	**
Test Time (Sec):	16	Altitude (ft): 0		Test Temp (C):	13

Kentucky FRONTIER GAS

Odorization Check Report

Location: Coburn Hollow

Date: 1-5-10 Time: 11:30

Odor Level: 1.30

____Nil
____Barely Detectable
✓ Readily Detectable
____ Strong

List other odors present: _____

Remarks: (odorometer reading) 1.30

Observed By: [illegible]

Location: 537 narrows Branch

Date: 1/5/10 Time: 12:30

Odor Level:

____Nil
____Barely Detectable
✓ Readily Detectable
____ Strong

List other odors present: 537 narrows branch

Remarks: (odorometer reading) _____

Observed By: [illegible]

Location: 281 Branch Forest Hills

Date: 1-5-10 Time: 1:30

Odor Level: 1.30

____Nil
____Barely Detectable
____ Readily Detectable
✓ Strong

List other odors present: _____

Remarks: (odorometer reading) 1.30

Observed By: _____

Kentucky Frontier Gas LLC

P.O.Box 408 * Prestonsburg, Ky. 41653* 606-886-2431 * 866-942-9427 *Fax:606-889-9196 * lrich@ec.rr.com

Kentucky FRONTIER GAS

Odorization Check Report

Location: Coburn Hollow

Date: 1-21-10 Time: 10:00

Odor Level: 1.30

____Nil
____Barely Detectable
____Readily Detectable
✓ Strong

List other odors present: _____

Remarks: (odorometer reading) 1.30

Observed By: [illegible]

Location: _____

Date: 1-21-10 Time: 11:00

Odor Level: 1.30

____Nil
____Barely Detectable
____Readily Detectable
✓ Strong

List other odors present: _____

Remarks: (odorometer reading) 1.30

Observed By: [illegible]

Location: _____

Date: 1-21-10 Time: 12:00

Odor Level: 1.30

____Nil
____Barely Detectable
____Readily Detectable
____Strong

List other odors present: _____

Remarks: (odorometer reading) 1.30

Observed By: [illegible]

Kentucky Frontier Gas LLC

P.O.Box 408 * Prestonsburg, Ky. 41653* 606-886-2431 * 866-942-9427 *Fax:606-889-9196 * lrich@ec.rr.com

Kentucky FRONTIER GAS

Odorization Check Report

Location: Coeburn Hollow

Date: 2-2-10 Time: 9:00

Odor Level: 1.30

____Nil
____Barely Detectable
____ Readily Detectable
✓ Strong

List other odors present: _____

Remarks: (odorometer reading) 1.30

Observed By: [illegible]

Location: 537 narrow Branch

Date: 2-2-10 Time: 10:00

Odor Level: 1.30

____Nil
____Barely Detectable
____ Readily Detectable
✓ Strong

List other odors present: _____

Remarks: (odorometer reading) 1.30

Observed By: [illegible]

Location: 281 Kate Br. Forrest Hills

Date: 2-2-10 Time: 11:00

Odor Level: 1.30

____Nil
____Barely Detectable
✓ Readily Detectable
____ Strong

List other odors present: _____

Remarks: (odorometer reading) 1.30

Observed By: _____

Frontier Gas LLC

P.O.Box 408 * Prestonsburg, Ky. 41653* 606-886-2431 * 866-942-9427 *Fax:606-889-9196 * lrich@ec.rr.com

Kentucky FRONTIER GAS

Odorization Check Report

Location: Coeburn Hollow

Date: 2-25-10 Time: 2:00

Odor Level: 1.30

____Nil
____Barely Detectable
____Readily Detectable
✓ Strong

List other odors present: _____

Remarks: (odorometer reading) 1.30

Observed By: [illegible]

Location: 537 Narrows Br.

Date: 2-25-10 Time: 3:00

Odor Level: 1.30

____Nil
____Barely Detectable
____Readily Detectable
✓ Strong

List other odors present: _____

Remarks: (odorometer reading) 1.30

Observed By: [illegible]

Location: 281 Kate Br.

Date: _____ Time: 4:00

Odor Level: 1.30

____Nil
____Barely Detectable
____Readily Detectable
✓ Strong

List other odors present: _____

Remarks: (odorometer reading) 1.30

Observed By: [illegible]

Frontier Gas, LLC

P.O.Box 408 * Prestonsburg, Ky. 41653* 606-886-2431 * 866-942-9427 *Fax:606-889-9196 * lrich@ec.rr.com

Kentucky FRONTIER GAS

Odorization Check Report

Location: Cockburn Hollow

Date: 3-11-10 Time: 8:00

Odor Level: 1.20

____Nil
____Barely Detectable
____Readily Detectable
✓ Strong

List other odors present: _____

Remarks: (odorometer reading) 1.20

Observed By: [illegible]

Location: 537 narrow br

Date: 3-11-10 Time: 9:00

Odor Level: 1.30

____Nil
____Barely Detectable
____Readily Detectable
✓ Strong

List other odors present: _____

Remarks: (odorometer reading) 1.30

Observed By: [illegible]

Location: 281 Kate Br.

Date: 3-11-10 Time: 10:00

Odor Level: 1.20

____Nil
____Barely Detectable
____Readily Detectable
✓ Strong

List other odors present: _____

Remarks: (odorometer reading) 1.20

Observed By: [illegible]

Kentucky FRONTIER GAS

Odorization Check Report

Location: Forest [illegible]

Date: 3-25-10 Time: 12:30pm

Odor Level: 1.20 = 0.40

____Nil
____Barely Detectable
____Readily Detectable
✓ Strong

List other odors present: _____

Remarks: (odorometer reading) 1.20 = 0.40

Observed By: Marcus Stuto

Location: 187 Old Hardy Rd

Date: 3-25-10 Time: 1:30pm

Odor Level: 1.30 = 0.50

____Nil
____Barely Detectable
____Readily Detectable
✓ Strong

List other odors present: _____

Remarks: (odorometer reading) 1.30 = 0.50

Observed By: Marcus Stuto

Location: 196 Louis lane Pond Creek

Date: 3-25-10 Time: 2:00pm

Odor Level: 1.30 = 0.50

____Nil
____Barely Detectable
____Readily Detectable
✓ Strong

List other odors present: _____

Remarks: (odorometer reading) 1.30 = 0.50

Observed By: _____

Frontier Gas LLC

P.O.Box 408 * Prestonsburg, Ky. 41653* 606-886-2431 * 866-942-9427 *Fax:606-889-9196 * lrich@ec.rr.com

Kentucky FRONTIER GAS

Odorization Check Report

Location: Coburn Hollow

Date: 4/14/10 Time: 8:00

Odor Level: 1.20

____ Nil
____ Barely Detectable
✓ Readily Detectable
____ Strong

List other odors present: ____

Remarks: (odorometer reading) 1.20

Observed By: Marcy Stout

Location: 537 narrows Branch

Date: 4-14-10 Time: 9:00

Odor Level: 1.30

____ Nil
____ Barely Detectable
____ Readily Detectable
✓ Strong

List other odors present: 1

Remarks: (odorometer reading) 1.30

Observed By: Marcy Stout

Location: 281 Branch Forrest Hills

Date: 4-14-10 Time: 10:00

Odor Level: 1.30

____ Nil
____ Barely Detectable
____ Readily Detectable
✓ Strong

List other odors present: ____

Remarks: (odorometer reading) 1.30

Observed By: Marcy Stout

Frontier Gas, LLC

P.O.Box 408 * Prestonsburg, Ky. 41653* 606-886-2431 * 866-942-9427 *Fax:606-889-9196 * lrich@ec.rr.com

Kentucky FRONTIER GAS

Odorization Check Report

Location: _____

Date: 4-27-10 Time: 1:00

Odor Level: 1.30

____ Nil
____ Barely Detectable
____ Readily Detectable
✓ Strong

List other odors present: _____

Remarks: (odorometer reading) 1.30

Observed By: [signature]

Location: 537 narrows branch

Date: 4-27-10 Time: 2:00

Odor Level: 1.30

____ Nil
____ Barely Detectable
✓ Readily Detectable
____ Strong

List other odors present: _____

Remarks: (odorometer reading) 1.30

Observed By: [signature]

Location: 281 Kate Br Forrest Hills

Date: 4-27-10 Time: 3:00

Odor Level: 1.20

____ Nil
____ Barely Detectable
____ Readily Detectable
____ Strong

List other odors present: 281 Kate Br. Forrest Hills

Remarks: (odorometer reading) 1.20

Observed By: [signature]

Kentucky Frontier Gas LLC

P.O.Box 408 * Prestonsburg, Ky. 41653* 606-886-2431 * 866-942-9427 *Fax:606-889-9196 * lrich@ec.rr.com

Kentucky FRONTIER GAS

Odorization Check Report

Location: Coeburn Hollow

Date: 5-3-10 Time: 11:00

Odor Level: 1.30

____Nil
____Barely Detectable
____Readily Detectable
✓ Strong

List other odors present: ____

Remarks: (odorometer reading) 1.30

Observed By: [illegible]

Location: 537 narrow Br

Date: 5-3-10 Time: 12:00

Odor Level: 1.20

____Nil
____Barely Detectable
____Readily Detectable
✓ Strong

List other odors present: ____

Remarks: (odorometer reading) 1.20

Observed By: [illegible]

Location: 281 Kate Br

Date: 5-3-10 Time: 1:00

Odor Level: 1.30

____Nil
____Barely Detectable
____Readily Detectable
✓ Strong

List other odors present: ____

Remarks: (odorometer reading) 1.30

Observed By: [illegible]

Kentucky Frontier Gas LLC

P.O.Box 408 * Prestonsburg, Ky. 41653* 606-886-2431 * 866-942-9427 *Fax:606-889-9196 * lrich@ec.rr.com

Kentucky FRONTIER GAS

Odorization Check Report

Location: Coburn Hollow

Date: 5-30-10 Time: 12:00

Odor Level: 1.30

____ Nil
____ Barely Detectable
____ Readily Detectable
✓ Strong

List other odors present: _____

Remarks: (odorometer reading) 1.30

Observed By: [illegible]

Location: 537 Narrows Br

Date: 5-30-10 Time: 1:00

Odor Level: 1.30

____ Nil
____ Barely Detectable
____ Readily Detectable
✓ Strong

List other odors present: _____

Remarks: (odorometer reading) 1.30

Observed By: [illegible]

Location: 281 Kate Br

Date: 5-30-10 Time: 2:30

Odor Level: 1.30

____ Nil
____ Barely Detectable
____ Readily Detectable
✓ Strong

List other odors present: _____

Remarks: (odorometer reading) 1.30

Observed By: [illegible]

Frontier Gas LLC

P.O.Box 408 * Prestonsburg, Ky. 41653* 606-886-2431 * 866-942-9427 *Fax:606-889-9196 * lrich@ec.rr.com

Kentucky FRONTIER GAS

Odorization Check Report

Location: Coburn Hollow

Date: 6-15-10 Time: 11:00AM

Odor Level: 1.30 = 0.50

____Nil
____Barely Detectable
____Readily Detectable
✓ Strong

List other odors present: _____

Remarks: (odorometer reading) 1.30 = 0.50

Observed By: MS - TS

Location: 537 narrows branch

Date: 6-15-10 Time: 12:00

Odor Level: 1.30 = 0.50

____Nil
____Barely Detectable
____Readily Detectable
✓ Strong

List other odors present: 1.30 = 0.50

Remarks: (odorometer reading) _____

Observed By: MS - TS

Location: 281 Kate Branch Forrest Hills

Date: 6-15-10 Time: 1:00

Odor Level: 1.20 0.40

____Nil
____Barely Detectable
____Readily Detectable
✓ Strong

List other odors present: _____

Remarks: (odorometer reading) 1.20 0.40

Observed By: MS - TS

Belfry

Kentucky FRONTIER GAS

Odorization Check Report

Location: Kate Branch

Date: 6-1-10 Time: 0800

Odor Level: .50

____Nil
____Barely Detectable
___✓Readily Detectable
____ Strong

List other odors present: _____

Remarks: (odorometer reading) _____

Observed By: M.S. T.S.

Location: Old Hardy Road

Date: 6-1-10 Time: 0900

Odor Level: .50

____Nil
____Barely Detectable
___✓Readily Detectable
____ Strong

List other odors present: _____

Remarks: (odorometer reading) _____

Observed By: M.S. T.S.

Location: Pond Creek

Date: 6-1-10 Time: 1000

Odor Level: .50

____Nil
____Barely Detectable
___✓Readily Detectable
____ Strong

List other odors present: _____

Remarks: (odorometer reading) _____

Observed By: M.S. T.S.

Kentucky Frontier Gas, LLC

P.O.Box 408 * Prestonsburg, Ky. 41653* 606-886-2431 * 866-942-9427 *Fax:606-889-9196 * lrich@ec.rr.com

Kentucky FRONTIER GAS

Odorization Check Report

Location: Kate Branch

Date: 6-8-10 Time: 0800

Odor Level: .50

____Nil
____Barely Detectable
___✓Readily Detectable
____ Strong

List other odors present: _____

Remarks: (odorometer reading)_____

Observed By: M.S. T.S.

Location: Old Hardy Road

Date: 6-8-10 Time: 0900

Odor Level: .50

____Nil
____Barely Detectable
___✓Readily Detectable
____ Strong

List other odors present: _____

Remarks: (odorometer reading)_____

Observed By: M.S. T.S.

Location: Pond Creek

Date: 6-8-10 Time: 1000

Odor Level: .50

____Nil
____Barely Detectable
___✓Readily Detectable
____ Strong

List other odors present: _____

Remarks: (odorometer reading)_____

Observed By: M.S. T.S.

Kentucky Frontier Gas, LLC

P.O.Box 408 * Prestonsburg, Ky. 41653* 606-886-2431 * 866-942-9427 *Fax:606-889-9196 * lrich@ec.rr.com

Kentucky FRONTIER GAS

Odorization Check Report

Location: Kate Branch

Date: 6-15-10 Time: 0800

Odor Level: .50

____Nil
____Barely Detectable
___✓Readily Detectable
____ Strong

List other odors present: _____

Remarks: (odorometer reading)_____

Observed By: M.S. T.S.

Location: Old Hardy Road

Date: 6-15-10 Time: 0900

Odor Level: .50

____Nil
____Barely Detectable
___✓Readily Detectable
____ Strong

List other odors present: _____

Remarks: (odorometer reading)_____

Observed By: M.S. T.S.

Location: Pond Creek

Date: 6-15-10 Time: 1000

Odor Level: .50

____Nil
____Barely Detectable
___✓Readily Detectable
____ Strong

List other odors present: _____

Remarks: (odorometer reading)_____

Observed By: M.S. T.S.

Kentucky Frontier Gas, LLC

P.O.Box 408 * Prestonsburg, Ky. 41653* 606-886-2431 * 866-942-9427 *Fax:606-889-9196 * lrich@ec.rr.com

Kentucky FRONTIER GAS

Odorization Check Report

Location: KATE BRANCH

Date: 6-22-10 Time: 0800

Odor Level: .50

____Nil
____Barely Detectable
___✓Readily Detectable
____Strong

List other odors present: ____

Remarks: (odorometer reading) ____

Observed By: M.S. T.S.

Location: OLD HARDY ROAD

Date: 6-22-10 Time: 0900

Odor Level: .50

____Nil
____Barely Detectable
___✓Readily Detectable
____Strong

List other odors present: ____

Remarks: (odorometer reading) ____

Observed By: M.S. T.S.

Location: POND CREEK

Date: 6-22-10 Time: 1000

Odor Level: .50

____Nil
____Barely Detectable
___✓Readily Detectable
____Strong

List other odors present: ____

Remarks: (odorometer reading) ____

Observed By: MS. T.S.

Kentucky Frontier Gas, LLC

P.O.Box 408 * Prestonsburg, Ky. 41653* 606-886-2431 * 866-942-9427 *Fax:606-889-9196 * lrich@ec.rr.com

Kentucky FRONTIER GAS

Odorization Check Report

Belfry

Location: Coeburn Hollow

Date: 6-25-10 Time: 1400

Odor Level: 1.30 = 0.50

____Nil
____Barely Detectable
____Readily Detectable
___✓Strong

List other odors present: _____

Remarks: (odorometer reading) _____

Observed By: T.S. M.S.

Location: Kate Branch Forrest Hills

Date: 6-25-10 Time: 1500

Odor Level: 1.30 = 0.50

____Nil
____Barely Detectable
____Readily Detectable
___✓Strong

List other odors present: _____

Remarks: (odorometer reading) _____

Observed By: T.S. M.S.

Location: Narrows Branch

Date: 6-25-10 Time: 1600

Odor Level: 1.30 = 0.50

____Nil
____Barely Detectable
____Readily Detectable
___✓Strong

List other odors present: _____

Remarks: (odorometer reading) _____

Observed By: T.S. M.S.

Kentucky Frontier Gas LLC

P.O.Box 408 * Prestonsburg, Ky. 41653* 606-886-2431 * 866-942-9427 *Fax:606-889-9196 * lrich@ec.rr.com

Kentucky FRONTIER GAS

Odorization Check Report

Location: Kate Branch

Date: 6-29-10 Time: 0800

Odor Level: .50

____Nil
____Barely Detectable
___✓Readily Detectable
____Strong

List other odors present: _____

Remarks: (odorometer reading) _____

Observed By: M.S. T.S.

Location: Old Hardy Road

Date: 6-29-10 Time: 0900

Odor Level: .50

____Nil
____Barely Detectable
___✓Readily Detectable
____Strong

List other odors present: _____

Remarks: (odorometer reading) _____

Observed By: M.S. T.S.

Location: Pond Creek

Date: 6-29-10 Time: 1000

Odor Level: .50

____Nil
____Barely Detectable
___✓Readily Detectable
____Strong

List other odors present: _____

Remarks: (odorometer reading) _____

Observed By: M.S. T.S.

Kentucky Frontier Gas, LLC

P.O.Box 408 * Prestonsburg, Ky. 41653* 606-886-2431 * 866-942-9427 *Fax:606-889-9196 * lrich@ec.rr.com

Kentucky FRONTIER GAS

Odorization Check Report

Location: KATE BRANCH

Date: 7-6-10 Time: 0800

Odor Level: .50

____Nil
____Barely Detectable
___✓Readily Detectable
____Strong

List other odors present: _____

Remarks: (odorometer reading) _____

Observed By: M.S. T.S.

Location: OLD HARDY ROAD

Date: 7-6-10 Time: 0900

Odor Level: .50

____Nil
____Barely Detectable
___✓Readily Detectable
____Strong

List other odors present: _____

Remarks: (odorometer reading) _____

Observed By: M.S. T.S.

Location: POND CREEK

Date: 7-6-10 Time: 1000

Odor Level: .50

____Nil
____Barely Detectable
___✓Readily Detectable
____Strong

List other odors present: _____

Remarks: (odorometer reading) _____

Observed By: M.S. T.S.

Kentucky Frontier Gas, LLC

P.O.Box 408 * Prestonsburg, Ky. 41653* 606-886-2431 • 866-942-9427 *Fax:606-889-9196 * lrich@ec.rr.com

Kentucky FRONTIER GAS

Odorization Check Report

Location: Kate Branch

Date: 7-13-10 Time: 0800

Odor Level: .50

____Nil
____Barely Detectable
___✓Readily Detectable
____Strong

List other odors present: _____

Remarks: (odorometer reading) _____

Observed By: M.S. T.S.

Location: Old Hardy Road

Date: 7-13-10 Time: 0900

Odor Level: .50

____Nil
____Barely Detectable
___✓Readily Detectable
____Strong

List other odors present: _____

Remarks: (odorometer reading) _____

Observed By: M.S. T.S.

Location: Pond Creek

Date: 7-13-10 Time: 1000

Odor Level: .50

____Nil
____Barely Detectable
___✓Readily Detectable
____Strong

List other odors present: _____

Remarks: (odorometer reading) _____

Observed By: M.S. T.S.

Kentucky Frontier Gas, LLC

P.O.Box 408 * Prestonsburg, Ky. 41653* 606-886-2431 * 866-942-9427 *Fax:606-889-9196 * lrich@ec.rr.com

Kentucky FRONTIER GAS

Odorization Check Report

Location: Forrest Hills

Date: 7-16-10 Time: 10:00AM

Odor Level: .50

____Nil
____Barely Detectable
____ Readily Detectable
✓ Strong

List other odors present: _____

Remarks: (odorometer reading) .50

Observed By: MS-TS

Location: Huddy

Date: 7-16-10 Time: 11:30AM

Odor Level: .50

____Nil
____Barely Detectable
____ Readily Detectable
✓ Strong

List other odors present: _____

Remarks: (odorometer reading) .50

Observed By: MS-TS

Location: Narrows Branch

Date: 7-16-10 Time: 1:00pm

Odor Level: .40

____Nil
____Barely Detectable
____ Readily Detectable
✓ Strong

List other odors present: _____

Remarks: (odorometer reading) .40

Observed By: MS-TS

Kentucky Frontier Gas LLC

P.O.Box 408 * Prestonsburg, Ky. 41653* 606-886-2431 * 866-942-9427 *Fax:606-889-9196 * lrich@ec.rr.com

Kentucky FRONTIER GAS

Odorization Check Report

Location: Forrest Hills

Date: 7-23-10 Time: 1:00pm

Odor Level: .50

____Nil
____Barely Detectable
__✓__Readily Detectable
____Strong

List other odors present: _____

Remarks: (odorometer reading) .50

Observed By: MS - TS

Location: Huddy

Date: 7-23-10 Time: 2:00pm

Odor Level: .50

____Nil
____Barely Detectable
__✓__Readily Detectable
____Strong

List other odors present: .50

Remarks: (odorometer reading) _____

Observed By: MS-TS

Location: Narrows branch

Date: 7-23-10 Time: 6:00 pm

Odor Level: .50

____Nil
____Barely Detectable
__✓__Readily Detectable
____Strong

List other odors present: _____

Remarks: (odorometer reading) .50

Observed By: MS - TS

Kentucky Frontier Gas, LLC

P.O.Box 408 * Prestonsburg, Ky. 41653* 606-886-2431 * 866-942-9427 *Fax:606-889-9196 * lrich@ec.rr.com

Kentucky FRONTIER GAS

Odorization Check Report

Location: Kate Branch

Date: 7-20-10 Time: 0800

Odor Level: .50

____Nil
____Barely Detectable
___✓Readily Detectable
____Strong

List other odors present: _____

Remarks: (odorometer reading) _____

Observed By: M.S. T.S.

Location: Old Hardy Road

Date: 7-20-10 Time: 0900

Odor Level: .50

____Nil
____Barely Detectable
___✓Readily Detectable
____Strong

List other odors present: _____

Remarks: (odorometer reading) _____

Observed By: M.S. T.S.

Location: Pond Creek

Date: 7-20-10 Time: 1000

Odor Level: .50

____Nil
____Barely Detectable
___✓Readily Detectable
____Strong

List other odors present: _____

Remarks: (odorometer reading) _____

Observed By: M.S. T.S.

Kentucky Frontier Gas, LLC

P.O.Box 408 * Prestonsburg, Ky. 41653* 606-886-2431 * 866-942-9427 *Fax:606-889-9196 * lrich@ec.rr.com

Kentucky FRONTIER GAS

Odorization Check Report

Location: Kate Branch

Date: 7-27-10 Time: 0800

Odor Level: .50

____Nil
____Barely Detectable
___✓Readily Detectable
____Strong

List other odors present: _____

Remarks: (odorometer reading) _____

Observed By: M.S. T.S.

Location: Old Hardy Road

Date: 7.27.10 Time: 0900

Odor Level: .50

____Nil
____Barely Detectable
___✓Readily Detectable
____Strong

List other odors present: _____

Remarks: (odorometer reading) _____

Observed By: M.S. T.S.

Location: Pond Creek

Date: 7-27-10 Time: 1000

Odor Level: .50

____Nil
____Barely Detectable
___✓Readily Detectable
____Strong

List other odors present: _____

Remarks: (odorometer reading) _____

Observed By: M.S. T.S.

Kentucky Frontier Gas, LLC

P.O.Box 408 * Prestonsburg, Ky. 41653* 606-886-2431 * 866-942-9427 *Fax:606-889-9196 * lrich@ec.rr.com

Kentucky FRONTIER GAS

Odorization Check Report

Location: Kate Branch

Date: 8-3-10 Time: 0800

Odor Level: .50

____Nil
____Barely Detectable
___✓Readily Detectable
____Strong

List other odors present: _____

Remarks: (odorometer reading) _____

Observed By: M.S. T.S.

Location: Old Hardy Road

Date: 8-3-10 Time: 0900

Odor Level: .50

____Nil
____Barely Detectable
___✓Readily Detectable
____Strong

List other odors present: _____

Remarks: (odorometer reading) _____

Observed By: M.S. T.S.

Location: Pond Creek

Date: 8-3-10 Time: 1000

Odor Level: .50

____Nil
____Barely Detectable
___✓Readily Detectable
____Strong

List other odors present: _____

Remarks: (odorometer reading) _____

Observed By: M.S. T.S.

Kentucky Frontier Gas, LLC

P.O.Box 408 * Prestonsburg, Ky. 41653* 606-886-2431 * 866-942-9427 *Fax:606-889-9196 * lrich@ec.rr.com

Kentucky FRONTIER GAS

Odorization Check Report

Location: Kate Branch

Date: 8-10-10 Time: 0800

Odor Level: .50

____Nil
____Barely Detectable
___✓Readily Detectable
____Strong

List other odors present: _____

Remarks: (odorometer reading) _____

Observed By: M.S. T.S.

Location: Old Hardy Road

Date: 8-10-10 Time: 0900

Odor Level: .50

____Nil
____Barely Detectable
___✓Readily Detectable
____Strong

List other odors present: _____

Remarks: (odorometer reading) _____

Observed By: M.S. T.S.

Location: Pond Creek

Date: 8-10-10 Time: 1000

Odor Level: .50

____Nil
____Barely Detectable
___✓Readily Detectable
____Strong

List other odors present: _____

Remarks: (odorometer reading) _____

Observed By: M.S. T.S.

Kentucky Frontier Gas, LLC

P.O.Box 408 * Prestonsburg, Ky. 41653* 606-886-2431 * 866-942-9427 *Fax:606-889-9196 * lrich@ec.rr.com

Kentucky FRONTIER GAS

Odorization Check Report

Location: Kate Branch

Date: 8-17-10 Time: 0800

Odor Level: .50

____Nil
____Barely Detectable
___✓Readily Detectable
____ Strong

List other odors present: _____

Remarks: (odorometer reading)_____

Observed By: M.S. T.S.

Location: Old Hardy Road

Date: 8-17-10 Time: 0900

Odor Level: .50

____Nil
____Barely Detectable
___✓Readily Detectable
____ Strong

List other odors present: _____

Remarks: (odorometer reading)_____

Observed By: M.S. T.S.

Location: Pond Creek

Date: 8-17-10 Time: 1000

Odor Level: .50

____Nil
____Barely Detectable
___✓Readily Detectable
____ Strong

List other odors present: _____

Remarks: (odorometer reading)_____

Observed By: M.S. T.S.

Kentucky Frontier Gas, LLC

P.O.Box 408 * Prestonsburg, Ky. 41653* 606-886-2431 * 866-942-9427 *Fax:606-889-9196 * lrich@ec.rr.com

Kentucky FRONTIER GAS

Odorization Check Report

Location: KATE BRANCH

Date: 8-24-10 Time: 0800

Odor Level: .50

____Nil
____Barely Detectable
___✓Readily Detectable
____Strong

List other odors present: _____

Remarks: (odorometer reading) _____

Observed By: M.S. T.S.

Location: OLD HARDY ROAD

Date: 8-24-10 Time: 0900

Odor Level: .50

____Nil
____Barely Detectable
___✓Readily Detectable
____Strong

List other odors present: _____

Remarks: (odorometer reading) _____

Observed By: M.S. T.S.

Location: POND CREEK

Date: 8-24-10 Time: 1000

Odor Level: .50

____Nil
____Barely Detectable
___✓Readily Detectable
____Strong

List other odors present: _____

Remarks: (odorometer reading) _____

Observed By: M.S. T.S.

Kentucky Frontier Gas, LLC

P.O.Box 408 * Prestonsburg, Ky. 41653* 606-886-2431 * 866-942-9427 *Fax:606-889-9196 * lrich@ec.rr.com

Kentucky FRONTIER GAS

Odorization Check Report

Location: Kate Branch

Date: 9-31-10 Time: 0800

Odor Level: .50

____Nil
____Barely Detectable
___✓Readily Detectable
____ Strong

List other odors present: _____

Remarks: (odorometer reading) _____

Observed By: M.S. T.S.

Location: Old Hardy Road

Date: 9-31-10 Time: 0900

Odor Level: .50

____Nil
____Barely Detectable
___✓Readily Detectable
____ Strong

List other odors present: _____

Remarks: (odorometer reading) _____

Observed By: M.S. T.S.

Location: Pond Creek

Date: 8-31-10 Time: 1000

Odor Level: .50

____Nil
____Barely Detectable
___✓Readily Detectable
____ Strong

List other odors present: _____

Remarks: (odorometer reading) _____

Observed By: M.S. T.S.

Kentucky Frontier Gas, LLC

P.O.Box 408 * Prestonsburg, Ky. 41653* 606-886-2431 * 866-942-9427 *Fax:606-889-9196 * lrich@ec.rr.com

Kentucky FRONTIER GAS

Odorization Check Report

Location: Kate Branch

Date: 9-7-10 Time: 0800

Odor Level: .50

____Nil
____Barely Detectable
___✓Readily Detectable
____ Strong

List other odors present: _____

Remarks: (odorometer reading)_____

Observed By: M.S. T.S.

Location: Old Hardy Road

Date: 9-7-10 Time: 0900

Odor Level: .50

____Nil
____Barely Detectable
___✓Readily Detectable
____ Strong

List other odors present: _____

Remarks: (odorometer reading)_____

Observed By: M.S. T.S.

Location: Pond Creek

Date: 9-7-10 Time: 1000

Odor Level: .50

____Nil
____Barely Detectable
___✓Readily Detectable
____ Strong

List other odors present: _____

Remarks: (odorometer reading)_____

Observed By: M.S. T.S.

Kentucky Frontier Gas, LLC

P.O.Box 408 * Prestonsburg, Ky. 41653* 606-886-2431 * 866-942-9427 *Fax:606-889-9196 * lrich@ec.rr.com

Kentucky FRONTIER GAS

Odorization Check Report

Location: Kate Branch

Date: 9-14-10 Time: 0800

Odor Level: .50

____Nil
____Barely Detectable
___✓Readily Detectable
____Strong

List other odors present: _____

Remarks: (odorometer reading) _____

Observed By: M.S. T.S.

Location: Old Hardy Road

Date: 9-14-10 Time: 0900

Odor Level: .50

____Nil
____Barely Detectable
___✓Readily Detectable
____Strong

List other odors present: _____

Remarks: (odorometer reading) _____

Observed By: M.S. T.S.

Location: Pond Creek

Date: 9-14-10 Time: 1000

Odor Level: .50

____Nil
____Barely Detectable
___✓Readily Detectable
____Strong

List other odors present: _____

Remarks: (odorometer reading) _____

Observed By: M.S. T.S.

Kentucky Frontier Gas, LLC

P.O.Box 408 * Prestonsburg, Ky. 41653* 606-886-2431 * 866-942-9427 *Fax:606-889-9196 * lrich@ec.rr.com

Kentucky FRONTIER GAS

Odorization Check Report

Location: Kyata Branch

Date: 9-21-10 Time: 0800

Odor Level: .50

____Nil
____Barely Detectable
___✓Readily Detectable
____ Strong

List other odors present: _____

Remarks: (odorometer reading)_____

Observed By: MS TS

Location: Old Hardy Rd

Date: 9-21-10 Time: 0900

Odor Level: .50

____Nil
____Barely Detectable
___✓Readily Detectable
____ Strong

List other odors present: _____

Remarks: (odorometer reading)_____

Observed By: MS TS

Location: Pond Creek Rd

Date: 9-21-10 Time: 1000

Odor Level: .50

____Nil
____Barely Detectable
___✓Readily Detectable
____ Strong

List other odors present: _____

Remarks: (odorometer reading)_____

Observed By: MS TS

Kentucky Frontier Gas, LLC

P.O.Box 408 * Prestonsburg, Ky. 41653* 606-886-2431 * 866-942-9427 *Fax:606-889-9196 * lrich@ec.rr.com

Kentucky FRONTIER GAS

Odorization Check Report

Location: KATE BRANCH

Date: 9-28-10 Time: 1000

Odor Level: .50

____Nil
____Barely Detectable
___✓Readily Detectable
____ Strong

List other odors present: _____

Remarks: (odorometer reading)_____

Observed By: MS TS

Location: OLD HARLY ROAD

Date: 9-28-10 Time: 1100

Odor Level: .50

____Nil
____Barely Detectable
___✓Readily Detectable
____ Strong

List other odors present: _____

Remarks: (odorometer reading)_____

Observed By: MS TS

Location: Pond Creek

Date: 9-28-10 Time: 1200

Odor Level: .50

____Nil
____Barely Detectable
___✓Readily Detectable
____ Strong

List other odors present: _____

Remarks: (odorometer reading)_____

Observed By: MS TS

Kentucky Frontier Gas, LLC

P.O.Box 408 * Prestonsburg, Ky. 41653* 606-886-2431 * 866-942-9427 *Fax:606-889-9196 * lrich@ec.rr.com

Kentucky FRONTIER GAS

Odorization Check Report

Location: KATE BRANCH

Date: 10-5-10 Time: 900

Odor Level: .50

____Nil
____Barely Detectable
✓ Readily Detectable
____ Strong

List other odors present: _____

Remarks: (odorometer reading) _____

Observed By: MS DS

Location: Old Hardy Road

Date: 10-5-10 Time: 1000

Odor Level: .50

____Nil
____Barely Detectable
✓ Readily Detectable
____ Strong

List other odors present: _____

Remarks: (odorometer reading) _____

Observed By: DS MS

Location: Coeburn Hollow

Date: 10-5-10 Time: 1130

Odor Level: .50

____Nil
____Barely Detectable
✓ Readily Detectable
____ Strong

List other odors present: _____

Remarks: (odorometer reading) _____

Observed By: DS MS

Kentucky Frontier Gas, LLC

P.O.Box 408 * Prestonsburg, Ky. 41653* 606-886-2431 * 866-942-9427 *Fax:606-889-9196 * lrich@ec.rr.com

Kentucky FRONTIER GAS

Odorization Check Report

Location: Kate Branch

Date: 10 1-10 Time: 900

Odor Level: .50

_____Nil
_____Barely Detectable
___✓___Readily Detectable
_____ Strong

List other odors present: _____

Remarks: (odorometer reading)_____

Observed By: TS

Location: Old Hardy Road

Date: 10-2-10 Time: 1000

Odor Level: .50

_____Nil
_____Barely Detectable
___✓___Readily Detectable
_____ Strong

List other odors present: _____

Remarks: (odorometer reading)_____

Observed By: MS TS

Location: Goodwin Holmes

Date: 10-2-10 Time: 1130

Odor Level:

_____Nil
_____Barely Detectable
_____ Readily Detectable
_____ Strong

List other odors present: _____

Remarks: (odorometer reading)_____

Observed By: TS MS

Kentucky Frontier Gas, LLC

P.O.Box 408 * Prestonsburg, Ky. 41653* 606-886-2431 * 866-942-9427 *Fax:606-889-9196 * lrich@ec.rr.com

Kentucky FRONTIER GAS

Odorization Check Report

Location: Kate Branch

Date: 10-19-10 Time: 930

Odor Level: .50

_____Nil
_____Barely Detectable
___✓___Readily Detectable
_____ Strong

List other odors present: _____

Remarks: (odorometer reading)_____

Observed By: MS TS

Location: Old Hardy RD.

Date: 10-19-10 Time: 1015

Odor Level: .50

_____Nil
_____Barely Detectable
___✓___Readily Detectable
_____ Strong

List other odors present: _____

Remarks: (odorometer reading)_____

Observed By: TS MS

Location: Goodman 1 to 110w

Date: 10-19-10 Time: 1200

Odor Level: .50

_____Nil
_____Barely Detectable
___✓___Readily Detectable
_____ Strong

List other odors present: _____

Remarks: (odorometer reading)_____

Observed By: TS. MS.

Kentucky Frontier Gas, LLC

P.O.Box 408 * Prestonsburg, Ky. 41653* 606-886-2431 * 866-942-9427 *Fax:606-889-9196 * lrich@ec.rr.com

Kentucky FRONTIER GAS

Odorization Check Report

Location: KATE BRANCH

Date: 10-26-10 Time: 900

Odor Level: .50

____Nil
____Barely Detectable
___✓Readily Detectable
____ Strong

List other odors present: _____

Remarks: (odorometer reading)_____

Observed By: TS MS

Location: OLD HARDY RD

Date: 10-26-10 Time: 1000

Odor Level: .50

____Nil
____Barely Detectable
___✓Readily Detectable
____ Strong

List other odors present: _____

Remarks: (odorometer reading)_____

Observed By: MS TS

Location: COLBURN HOLLOW

Date: 10-26-10 Time: 1200

Odor Level: .50

____Nil
____Barely Detectable
___✓Readily Detectable
____ Strong

List other odors present: _____

Remarks: (odorometer reading)_____

Observed By: TS MS

Kentucky Frontier Gas, LLC

P.O.Box 408 * Prestonsburg, Ky. 41653* 606-886-2431 * 866-942-9427 *Fax:606-889-9196 * lrich@ec.rr.com

Bell-14

Kentucky FRONTIER GAS

Odorization Check Report

Location: KATE BRANCH

Date: 11-2-10 Time: 900

Odor Level: .50

____Nil
____Barely Detectable
__✓__Readily Detectable
____Strong

List other odors present: _____

Remarks: (odorometer reading) _____

Observed By: J.S. M.S.

Location: Old Hardy Rd

Date: 1100 Time: 11-2-10

Odor Level: .50

____Nil
____Barely Detectable
__✓__Readily Detectable
____Strong

List other odors present: _____

Remarks: (odorometer reading) _____

Observed By: M.S. J.S.

Location: Coxburn Hollow

Date: 11-2-10 Time: 1200

Odor Level: .50

____Nil
____Barely Detectable
__✓__Readily Detectable
____Strong

List other odors present: _____

Remarks: (odorometer reading) _____

Observed By: M.S. J.S.

Kentucky Frontier Gas, LLC

P.O.Box 408 * Prestonsburg, Ky. 41653* 606-886-2431 * 866-942-9427 *Fax:606-889-9196 * lrich@ec.rr.com

Belfry

Kentucky FRONTIER GAS

Odorization Check Report

Location: Kate Branch

Date: 11-9-10 Time: 10:30

Odor Level: .50

____Nil
____~~Barely~~ Detectable
___✓ Readily Detectable
____ Strong

List other odors present: _____

Remarks: (odorometer reading)_____

Observed By: MS. TS.

Location: Old Harry RD

Date: 11-9-10 Time: 11:30

Odor Level: .50

____Nil
____Barely Detectable
___✓ Readily Detectable
____ Strong

List other odors present: _____

Remarks: (odorometer reading)_____

Observed By: TS. MS.

Location: Coebum Hollow

Date: 11-9-10 Time: 11-9-10

Odor Level: .50

____Nil
____Barely Detectable
___✓ Readily Detectable
____ Strong

List other odors present: _____

Remarks: (odorometer reading)_____

Observed By: MS TS

Kentucky Frontier Gas, LLC

P.O.Box 408 * Prestonsburg, Ky. 41653* 606-886-2431 * 866-942-9427 *Fax:606-889-9196 * lrich@ec.rr.com

Kentucky FRONTIER GAS

Belfry

Odorization Check Report

Location: Hurday

Date: 11-16-10 Time: 800

Odor Level: .50

_____Nil
_____Barely Detectable
✓ Readily Detectable
_____ Strong

List other odors present: _____

Remarks: (odorometer reading)_____

Observed By: MS TS

Location: Old Hardy road

Date: 11-16-10 Time: 1000

Odor Level: .50

_____Nil
_____Barely Detectable
_____ Readily Detectable
_____ Strong

List other odors present: _____

Remarks: (odorometer reading)_____

Observed By: MS TS

Location: Kate Branch

Date: 11-16-10 Time: 1130

Odor Level: .50

_____Nil
_____Barely Detectable
_____ Readily Detectable
_____ Strong

List other odors present: _____

Remarks: (odorometer reading)_____

Observed By: _____

Frontier Gas LLC

P.O.Box 408 * Prestonsburg, Ky. 41653* 606-886-2431 * 866-942-9427 *Fax:606-889-9196 * lrich@ec.rr.com

Kentucky FRONTIER GAS

Belfry

Odorization Check Report

Location: Hardy

Date: 11-23-10 Time: 800

Odor Level: .50

____Nil
____Barely Detectable
___✓Readily Detectable
____ Strong

List other odors present: _____

Remarks: (odorometer reading)_____

Observed By: TS MS

Location: Old Hardy Road

Date: 11-23-10 Time: 1000

Odor Level: .50

____Nil
____Barely Detectable
___✓Readily Detectable
____ Strong

List other odors present: _____

Remarks: (odorometer reading)_____

Observed By: MS TS

Location: Kate Branch

Date: 11-23-10 Time: 1130

Odor Level: .50

____Nil
____Barely Detectable
___✓Readily Detectable
____ Strong

List other odors present: _____

Remarks: (odorometer reading)_____

Observed By: MS TS

Frontier Gas LLC

P.O Box 408 * Prestonsburg, Ky. 41653* 606-886-2431 * 866-942-9427 *Fax:606-889-9196 * lrich@ec.rr.com

Kentucky FRONTIER GAS

Belfry

Odorization Check Report

Location: Huddy

Date: 11 30-10 Time: 900

Odor Level: .50

____Nil
____Barely Detectable
___✓Readily Detectable
____ Strong

List other odors present:

Remarks: (odorometer reading)

Observed By: MS TS

Location: Harey Road

Date: 11-30-10 Time: 1030

Odor Level: .50

____Nil
____Barely Detectable
___✓Readily Detectable
____ Strong

List other odors present:

Remarks: (odorometer reading)

Observed By: MS TS

Location: Kate Branch

Date: 11-30-10 Time: 1130

Odor Level: .50

____Nil
____Barely Detectable
___✓Readily Detectable
____ Strong

List other odors present:

Remarks: (odorometer reading)

Observed By: MS TS

P.O.Box 408 * Prestonsburg, Ky. 41653* 606-886-2431 * 866-942-9427 *Fax:606-889-9196 * lrich@ec.rr.com

Belfry

Kentucky FRONTIER GAS

Odorization Check Report

Location: KATE BRANCH

Date: 12-7-10 Time: 800

Odor Level: .50

____Nil
____Barely Detectable
___✓Readily Detectable
____ Strong

List other odors present: _____

Remarks: (odorometer reading)_____

Observed By: MS TS

Location: OLD HARDY ROAD

Date: 12-7-10 Time: 1000

Odor Level: .50

____Nil
____Barely Detectable
___✓Readily Detectable
____ Strong

List other odors present: _____

Remarks: (odorometer reading)_____

Observed By: TS MS

Location: HARDY

Date: 12-7-10 Time: 1200

Odor Level: .50

____Nil
____Barely Detectable
___✓Readily Detectable
____ Strong

List other odors present: _____

Remarks: (odorometer reading)_____

Observed By: MS TS

P.O Box 408 * Prestonsburg, Ky. 41653* 606-886-2431 * 866-942-9427 *Fax:606-889-9196 * lrich@ec.rr.com

Kentucky FRONTIER GAS

Belfry

Odorization Check Report

Location: Huddy

Date: 12-14-10 Time: 800

Odor Level:
- ____ Nil
- ____ Barely Detectable
- ✓ Readily Detectable
- ____ Strong

List other odors present: ____

Remarks: (odorometer reading) ____

Observed By: MS TS

Location: Old Hardy Road

Date: 12-14-10 Time: 945

Odor Level:
- ____ Nil
- ____ Barely Detectable
- ✓ Readily Detectable
- ____ Strong

List other odors present: ____

Remarks: (odorometer reading) ____

Observed By: MS TS

Location: Kate Branch

Date: 12-14-10 Time: 1200

Odor Level: .50
- ____ Nil
- ____ Barely Detectable
- ✓ Readily Detectable
- ____ Strong

List other odors present: ____

Remarks: (odorometer reading) ____

Observed By: MS TS

Kentucky Frontier Gas LLC

P O Box 408 * Prestonsburg, Ky. 41653* 606-886-2431 * 866-942-9427 *Fax:606-889-9196 * lrich@ec.rr.com

Kentucky FRONTIER GAS

Belfry

Odorization Check Report

Location: Hardy

Date: 11-27-10 Time: 830

Odor Level: .50

_____Nil
_____Barely Detectable
___✓__Readily Detectable
_____ Strong

List other odors present:

Remarks: (odorometer reading)

Observed By: MS TS

Location: OK Hardy Road

Date: 11-27-10 Time: 1000

Odor Level: .50

_____Nil
_____Barely Detectable
___✓__Readily Detectable
_____ Strong

List other odors present:

Remarks: (odorometer reading)

Observed By: MS TS

Location:

Date: 11-27-10 Time: 1130

Odor Level: .50

_____Nil
_____Barely Detectable
___✓__Readily Detectable
_____ Strong

List other odors present:

Remarks: (odorometer reading)

Observed By: MS TS

P O Box 408 * Prestonsburg, Ky. 41653* 606-886-2431 * 866-942-9427 *Fax:606-889-9196 * lrich@ec.rr.com

Kentucky FRONTIER GAS

Belfry

Odorization Check Report

Location: Old Hardy Road

Date: 12-28-10 Time: 830

Odor Level: .50

_____Nil
_____Barely Detectable
___✓___Readily Detectable
_____ Strong

List other odors present: _____

Remarks: (odorometer reading)_____

Observed By: MS TS

Location: Hadley

Date: 12-28-10 Time: 1000

Odor Level: .50

_____Nil
_____Barely Detectable
___✓___Readily Detectable
_____ Strong

List other odors present: _____

Remarks: (odorometer reading)_____

Observed By: MS TS

Location: Kate Branch

Date: 12-28-10 Time: 1130

Odor Level: .50

_____Nil
_____Barely Detectable
___✓___Readily Detectable
_____ Strong

List other odors present: _____

Remarks: (odorometer reading)_____

Observed By: MS TS

P.O.Box 408 * Prestonsburg, Ky. 41653* 606-886-2431 * 866-942-9427 *Fax:606-889-9196 * lrich@ec.rr.com

Kentucky FRONTIER GAS

Belfry

Odorization Check Report

Location: Old Harry Road

Date: 1-4-11 Time: 0800

Odor Level: .50

_____Nil
_____Barely Detectable
___✓___Readily Detectable
_____ Strong

List other odors present: _____

Remarks: (odorometer reading)_____

Observed By: MS TS

Location: Hardy

Date: 1-4-11 Time: 1000

Odor Level: .50

_____Nil
_____Barely Detectable
___✓___Readily Detectable
_____ Strong

List other odors present: _____

Remarks: (odorometer reading)_____

Observed By: MS TS

Location: Kate Branch

Date: 1-4-11 Time: 1200

Odor Level: .50

_____Nil
_____Barely Detectable
___✓___Readily Detectable
_____ Strong

List other odors present: _____

Remarks: (odorometer reading)_____

Observed By: MS TS

Kentucky Frontier Gas LLC

P.O.Box 408 * Prestonsburg, Ky. 41653* 606-886-2431 *866-942-9427 *Fax:606-889-9196 * lrich@ec.rr.com

Kentucky FRONTIER GAS

Belfry

Odorization Check Report

Location: Hedy

Date: 1-11-11 Time: 0815

Odor Level: .50

_____Nil
_____Barely Detectable
_____Readily Detectable
_____Strong

List other odors present:

Remarks: (odorometer reading)

Observed By: MS TS

Location: Old Harry Road

Date: 1-4-11 Time: 930

Odor Level: .50

_____Nil
_____Barely Detectable
_____Readily Detectable
_____Strong

List other odors present:

Remarks: (odorometer reading)

Observed By: MS TS

Location: Kate Branch

Date: 1-11-11 Time: 1200

Odor Level: .50

_____Nil
_____Barely Detectable
_____Readily Detectable
_____Strong

List other odors present:

Remarks: (odorometer reading)

Observed By: MS TS

Kentucky Frontier Gas LLC

P.O.Box 408 * Prestonsburg, Ky. 41653* 606-886-2431 * 866-942-9427 *Fax:606-889-9196 * lrich@ec.rr.com

Kentucky FRONTIER GAS

Belfry

Odorization Check Report

Location: RATC BRANCH

Date: 1-18-11 Time: 0800

Odor Level: .50

_____Nil
_____Barely Detectable
___✓___Readily Detectable
_____ Strong

List other odors present: _____

Remarks: (odorometer reading)_____

Observed By: TS MS

Location: OLD HARDY ROAD

Date: 1-18-11 Time: 1000

Odor Level: .50

_____Nil
_____Barely Detectable
___✓___Readily Detectable
_____ Strong

List other odors present: _____

Remarks: (odorometer reading)_____

Observed By: MS TS

Location: Haddix

Date: 1-18-11 Time: 1200

Odor Level: .50

_____Nil
_____Barely Detectable
___✓___Readily Detectable
_____ Strong

List other odors present: _____

Remarks: (odorometer reading)_____

Observed By: [illegible]

Kentucky Frontier Gas LLC

P.O.Box 408 * Prestonsburg, Ky. 41653* 606-886-2431 * 866-942-9427 *Fax:606-889-9196 * lrich@ec.rr.com

Kentucky FRONTIER GAS

Belfry

Odorization Check Report

Location: Old Hardy Road

Date: 1-25-11 Time: 845

Odor Level .50

_____Nil
_____Barely Detectable
___✓___Readily Detectable
_____Strong

List other odors present: _____

Remarks: (odorometer reading)_____

Observed By: MS TS

Location: Huddy

Date: 1-25-11 Time: 1000

Odor Level .50

_____Nil
_____Barely Detectable
___✓___Readily Detectable
_____Strong

List other odors present: _____

Remarks: (odorometer reading)_____

Observed By: MS TS.

Location: Rate Branch

Date: 1-25-11 Time: 1100

Odor Level: .50

_____Nil
_____Barely Detectable
___✓___Readily Detectable
_____Strong

List other odors present: _____

Remarks: (odorometer reading)_____

Observed By: MS TS

Kentucky Frontier Gas LLC

P.O Box 408 * Prestonsburg, Ky. 41653* 606-886-2431 * 866-942-9427 *Fax:606-889-9196 * lrich@ec.rr.com

Kentucky FRONTIER GAS

Belfry

Odorization Check Report

Location: Hardy

Date: 2-1-11 Time: 0900

Odor Level: .50

_____Nil
_____Barely Detectable
___✓___Readily Detectable
_____ Strong

List other odors present: _____

Remarks: (odorometer reading)_____

Observed By: MS TS

Location: Old Hardy Road

Date: 2-1-11 Time: 1020

Odor Level: .50

_____Nil
_____Barely Detectable
___✓___Readily Detectable
_____ Strong

List other odors present: _____

Remarks: (odorometer reading)_____

Observed By: MS TS

Location: Kate Branch

Date: 2-1-11 Time: 1200

Odor Level: .50

_____Nil
_____Barely Detectable
___✓___Readily Detectable
_____ Strong

List other odors present: _____

Remarks: (odorometer reading)_____

Observed By: MS TS

Kentucky Frontier Gas LLC

P.O.Box 408 * Prestonsburg, Ky. 41653* 606-886-2431 * 866-942-9427 *Fax:606-889-9196 * lrich@ec.rr.com

Kentucky FRONTIER GAS

Bell Fy

Odorization Check Report

Location: Hardy

Date: 2-8-11 Time: 0800

Odor Level: .50

_____Nil
_____Barely Detectable
___✓___Readily Detectable
_____Strong

List other odors present: _____

Remarks: (odorometer reading) _____

Observed By: TS MS

Location: Oldhardy Road

Date: 2-8-11 Time: 930

Odor Level: .50

_____Nil
_____Barely Detectable
___✓___Readily Detectable
_____Strong

List other odors present: _____

Remarks: (odorometer reading) _____

Observed By: TS MS

Location: Kate Branch

Date: 2-8-11 Time: 1200

Odor Level: .50

_____Nil
_____Barely Detectable
___✓___Readily Detectable
_____Strong

List other odors present: _____

Remarks: (odorometer reading) _____

Observed By: TS MS

P.O.Box 408 * Prestonsburg, Ky. 41653* 606-886-2431 * 866-942-9427 *Fax:606-889-9196 * lrich@ec.rr.com

Kentucky FRONTIER GAS

Belfry

Odorization Check Report

Location: Old Hardy Road

Date: 2-15-11 Time: 0840

Odor Level: .50

____Nil
____Barely Detectable
__✓__Readily Detectable
____Strong

List other odors present: _____

Remarks: (odorometer reading) _____

Observed By: TS MS

Location: Huddy

Date: 2-15-11 Time: 930

Odor Level: .50

____Nil
____Barely Detectable
__✓__Readily Detectable
____Strong

List other odors present: _____

Remarks: (odorometer reading) _____

Observed By: TS MS

Location: KATE BRANCH

Date: 2-15-11 Time: 1130

Odor Level: .50

____Nil
____Barely Detectable
__✓__Readily Detectable
____Strong

List other odors present: _____

Remarks: (odorometer reading) _____

Observed By: MS TS

P.O Box 408 * Prestonsburg, Ky. 41653* 606-886-2431 * 866-942-9427 *Fax:606-889-9196 * lrich@ec rr.com

Kentucky FRONTIER GAS

Belfry

Odorization Check Report

Location: Old Haley Road

Date: 2-22-11 Time: 900

Odor Level: .50

_____Nil
_____Barely Detectable
___✓___Readily Detectable
_____ Strong

List other odors present: _____

Remarks: (odorometer reading)_____

Observed By: MS TS

Location: Huddy

Date: 2-22-11 Time: 1100

Odor Level: .50

_____Nil
_____Barely Detectable
___✓___Readily Detectable
_____ Strong

List other odors present: _____

Remarks: (odorometer reading)_____

Observed By: TS MS

Location: Kate Branch

Date: 2-22-11 Time: 1200

Odor Level: .50

_____Nil
_____Barely Detectable
___✓___Readily Detectable
_____ Strong

List other odors present: _____

Remarks: (odorometer reading)_____

Observed By: TS MS

Kentucky Frontier Gas LLC

P.O Box 408 * Prestonsburg, Ky. 41653* 606-886-2431 * 866-942-9427 *Fax:606-889-9196 * lrich@ec.rr.com

Kentucky FRONTIER GAS

Pc-117y

Odorization Check Report

Location: Huddy

Date: 3-1-11 Time: 800

Odor Level: .40

_____Nil
_____Barely Detectable
___✓___Readily Detectable
_____ Strong

List other odors present: _____

Remarks: (odorometer reading)_____

Observed By: MSTS

Location: OLE HARDY ROAD

Date: 3-1-4 Time: 1100

Odor Level: .50

_____Nil
_____Barely Detectable
___✓___Readily Detectable
_____ Strong

List other odors present: _____

Remarks: (odorometer reading)_____

Observed By: TS MS

Location: KATE BRANCH

Date: 800 Time: 3-1-4

Odor Level: .50

_____Nil
_____Barely Detectable
___✓___Readily Detectable
_____ Strong

List other odors present: _____

Remarks: (odorometer reading)_____

Observed By: TS MS

Kentucky Frontier Gas LLC

P.O.Box 408 * Prestonsburg, Ky. 41653* 606-886-2431 * 866-942-9427 *Fax:606-889-9196 * lrich@ec.rr.com

Kentucky FRONTIER GAS

Rel Fy

Odorization Check Report

Location: Gate Branch

Date: 3-8-11 Time: 900

Odor Level: .50

_____Nil
_____Barely Detectable
_____Readily Detectable
_____Strong

List other odors present: _____

Remarks: (odorometer reading) _____

Observed By: MS TS

Location: Old Hardy RD

Date: 3-8-11 Time: 1200

Odor Level: .50

_____Nil
_____Barely Detectable
_____Readily Detectable
_____Strong

List other odors present: _____

Remarks: (odorometer reading) _____

Observed By: TS MS

Location: _____

Date: 3-8-11 Time: 300

Odor Level: .50

_____Nil
_____Barely Detectable
_____Readily Detectable
_____Strong

List other odors present: _____

Remarks: (odorometer reading) _____

Observed By: TS MS

Kentucky Frontier Gas, LLC

P.O.Box 408 * Prestonsburg, Ky. 41653* 606-886-2431 * 866-942-9427 *Fax:606-889-9196 * lrich@ec.rr.com

Kentucky FRONTIER GAS

Pc 1/Fy

Odorization Check Report

Location: KATE BRANCH

Date: 3 15 11 Time: 930

Odor Level: .50

_____Nil
_____Barely Detectable
_____Readily Detectable
_____Strong

List other odors present: _____

Remarks: (odorometer reading) _____

Observed By: MS TS

Location: Hardy

Date: 1000 Time: 3-15-11

Odor Level: .50

_____Nil
_____Barely Detectable
_____Readily Detectable
_____Strong

List other odors present: _____

Remarks: (odorometer reading) _____

Observed By: TS MS

Location: Old Hardy RD

Date: 3-15-11 Time: 215

Odor Level: .50

_____Nil
_____Barely Detectable
_____Readily Detectable
_____Strong

List other odors present: _____

Remarks: (odorometer reading) _____

Observed By: TS MS

Kentucky Frontier Gas, LLC

P.O.Box 408 * Prestonsburg, Ky. 41653* 606-886-2431 * 866-942-9427 *Fax:606-889-9196 * lrich@ec.rr.com

Kentucky FRONTIER GAS

Belfry

Odorization Check Report

Location: Old Hardy Rd

Date: 3-22-11 Time: 1000

Odor Level: .50

_____Nil
_____Barely Detectable
___✓__Readily Detectable
_____ Strong

List other odors present: _____

Remarks: (odorometer reading)_____

Observed By: TS MS

Location: Huddy

Date: 3-22-11 Time: 1230

Odor Level: .90

_____Nil
_____Barely Detectable
___✓__Readily Detectable
_____ Strong

List other odors present: _____

Remarks: (odorometer reading)_____

Observed By: TS MS

Location: Kate Campbell

Date: 3-22-11 Time: 3:45

Odor Level: .40

_____Nil
_____Barely Detectable
___✓__Readily Detectable
_____ Strong

List other odors present: _____

Remarks: (odorometer reading)_____

Observed By: TS MS

Kentucky Frontier Gas, LLC

P.O.Box 408 * Prestonsburg, Ky. 41653* 606-886-2431 * 866-942-9427 *Fax:606-889-9196 * lrich@ec.rr.com

Kentucky FRONTIER GAS

Pelfry

Odorization Check Report

Location: Hardy

Date: 3-29-11 Time: 830

Odor Level: .40

_____Nil
_____Barely Detectable
____—Readily Detectable
_____ Strong

List other odors present: _____

Remarks: (odorometer reading)_____

Observed By: TS MS

Location: KATC Branch

Date: 3-29-4 Time: 1045

Odor Level: .40

_____Nil
_____Barely Detectable
____—Readily Detectable
_____ Strong

List other odors present: _____

Remarks: (odorometer reading)_____

Observed By: MS TS

Location: OLC Hardy RD

Date: 3-29-4 Time: 400

Odor Level: .50

_____Nil
_____Barely Detectable
____—Readily Detectable
_____ Strong

List other odors present: _____

Remarks: (odorometer reading)_____

Observed By: TS MS

Kentucky Frontier Gas, LLC

P.O.Box 408 * Prestonsburg, Ky. 41653* 606-886-2431 * 866-942-9427 *Fax:606-889-9196 * lrich@ec.rr.com

Kentucky FRONTIER GAS

Belfry

Odorization Check Report

Location: Old Hardy RD

Date: 4-1-11 Time: 800

Odor Level: .50

_____Nil
_____Barely Detectable
____—Readily Detectable
_____ Strong

List other odors present: _____

Remarks: (odorometer reading)_____

Observed By: TSMS

Location: Kate Camp

Date: 4-1-11 Time: 930

Odor Level: .50

_____Nil
_____Barely Detectable
____—Readily Detectable
_____ Strong

List other odors present: _____

Remarks: (odorometer reading)_____

Observed By: TSMS

Location: Huddy

Date: 4-1-11 Time: 1130

Odor Level: .50

_____Nil
_____Barely Detectable
____—Readily Detectable
_____ Strong

List other odors present: _____

Remarks: (odorometer reading)_____

Observed By: TSMS

Kentucky Frontier Gas, LLC

P.O.Box 408 * Prestonsburg, Ky. 41653* 606-886-2431 * 866-942-9427 *Fax:606-889-9196 * lrich@ec.rr.com

Kentucky FRONTIER GAS

Belfry

Odorization Check Report

Location: Old Hardy Rd

Date: 4-8-11 Time: 800

Odor Level: .50

____Nil
____Barely Detectable
___✓Readily Detectable
____ Strong

List other odors present: _____

Remarks: (odorometer reading) _____

Observed By: TSMS

Location: Huddy

Date: 4-8-11 Time: 920

Odor Level: .40

____Nil
____Barely Detectable
___✓Readily Detectable
____ Strong

List other odors present: _____

Remarks: (odorometer reading) _____

Observed By: TS MS

Location: Kato Camp

Date: 4-8-11 Time: 1035

Odor Level: .50

____Nil
____Barely Detectable
___✓Readily Detectable
____ Strong

List other odors present: _____

Remarks: (odorometer reading) _____

Observed By: TS MS

Kentucky Frontier Gas LLC

P.O.Box 408 * Prestonsburg, Ky. 41653* 606-886-2431 * 866-942-9427 *Fax:606-889-9196 * lrich@ec.rr.com

Kentucky FRONTIER GAS

Be 1/4 4

Odorization Check Report

Location: Hudoy

Date: 4-15-4 Time: 830

Odor Level: .50

_____Nil
_____Barely Detectable
___✓___Readily Detectable
_____ Strong

List other odors present: _____

Remarks: (odorometer reading) _____

Observed By: TS MS

Location: OLD HARDY RD

Date: 4-15-4 Time: 945

Odor Level: .50

_____Nil
_____Barely Detectable
___✓___Readily Detectable
_____ Strong

List other odors present: _____

Remarks: (odorometer reading) _____

Observed By: MS TS

Location: KATE CAMP

Date: 4-15-4 Time: 1100

Odor Level: .50

_____Nil
_____Barely Detectable
___✓___Readily Detectable
_____ Strong

List other odors present: _____

Remarks: (odorometer reading) _____

Observed By: TS MS

Kentucky Frontier Gas LLC

P.O.Box 408 * Prestonsburg, Ky. 41653* 606-886-2431 * 866-942-9427 *Fax:606-889-9196 * lrich@ec.rr.com

Kentucky FRONTIER GAS

Belfry

Odorization Check Report

Location: Hardy RD

Date: 4-22-4 Time: 830

Odor Level: .50

____Nil
____Barely Detectable
___✓Readily Detectable
____ Strong

List other odors present: _____

Remarks: (odorometer reading) _____

Observed By: TS MS

Location: Hardy

Date: 4-22-4 Time: 1000

Odor Level: .50

____Nil
____Barely Detectable
___✓Readily Detectable
____ Strong

List other odors present: _____

Remarks: (odorometer reading) _____

Observed By: TS MS

Location: Kate Camp

Date: 4-22 Time: 1130

Odor Level: .50

____Nil
____Barely Detectable
___✓Readily Detectable
____ Strong

List other odors present: _____

Remarks: (odorometer reading) _____

Observed By: TS MS

Kentucky Frontier Gas LLC

P.O.Box 408 * Prestonsburg, Ky. 41653* 606-886-2431 * 866-942-9427 *Fax:606-889-9196 * lrich@ec.rr.com

PHelps

Kentucky FRONTIER GAS

Odorization Check Report

Location: Edith Karee

Date: 6-1-10 Time: 1200p

Odor Level: .40

____Nil
____Barely Detectable
___✓Readily Detectable
____ Strong

List other odors present: _____

Remarks: (odorometer reading)_____

Observed By: MS TS

Location: Post office

Date: 6-1-10 Time: 200p

Odor Level: .40

____Nil
____Barely Detectable
___✓Readily Detectable
____ Strong

List other odors present: _____

Remarks: (odorometer reading)_____

Observed By: MS TS

Location: Ronda Stratton

Date: 6-1-10 Time: 300p

Odor Level: .40

____Nil
____Barely Detectable
___✓Readily Detectable
____ Strong

List other odors present: _____

Remarks: (odorometer reading)_____

Observed By: MS TS

Kentucky Frontier Gas, LLC

P.O.Box 408 * Prestonsburg, Ky. 41653* 606-886-2431 * 866-942-9427 *Fax:606-889-9196 * lrich@ec.rr.com

Kentucky FRONTIER GAS

Odorization Check Report

Location: Edith Karee

Date: 6-8-10 Time: 1200p

Odor Level: .40

____Nil
____Barely Detectable
___✓Readily Detectable
____ Strong

List other odors present: _____

Remarks: (odorometer reading)_____

Observed By: MS TS

Location: Post office

Date: 6-8-10 Time: 200p

Odor Level: .40

____Nil
____Barely Detectable
___✓Readily Detectable
____ Strong

List other odors present: _____

Remarks: (odorometer reading)_____

Observed By: MS TS

Location: Ronda Straton

Date: 6-8-10 Time: 300p

Odor Level: .40

____Nil
____Barely Detectable
___✓Readily Detectable
____ Strong

List other odors present: _____

Remarks: (odorometer reading)_____

Observed By: MS TS

Kentucky Frontier Gas, LLC

P.O.Box 408 * Prestonsburg, Ky. 41653* 606-886-2431 * 866-942-9427 *Fax:606-889-9196 * lrich@ec.rr.com

Kentucky FRONTIER GAS

Odorization Check Report

Location: Edith Karee

Date: 6-15-10 Time: 1200p

Odor Level: .40

____Nil
____Barely Detectable
___✓Readily Detectable
____ Strong

List other odors present: _____

Remarks: (odorometer reading)_____

Observed By: MS TS

Location: Post office

Date: 6-15-10 Time: 200p

Odor Level: .40

____Nil
____Barely Detectable
___✓Readily Detectable
____ Strong

List other odors present: _____

Remarks: (odorometer reading)_____

Observed By: MS TS

Location: Ronda Straton

Date: 6-15-10 Time: 300p

Odor Level: .40

____Nil
____Barely Detectable
___✓Readily Detectable
____ Strong

List other odors present: _____

Remarks: (odorometer reading)_____

Observed By: MS TS

Kentucky Frontier Gas, LLC

P.O.Box 408 * Prestonsburg, Ky. 41653* 606-886-2431 * 866-942-9427 *Fax:606-889-9196 * lrich@ec.rr.com

Kentucky FRONTIER GAS

Odorization Check Report

Location: Smiths Laundramat Phelps

Date: 6-16-10 Time: 1400

Odor Level: .50

____Nil
____Barely Detectable
____Readily Detectable
✓ Strong

List other odors present: ____

Remarks: (odorometer reading) 1.40 .50

Observed By: TS MS

Location: Pike County Library Phelps

Date: 6-16-10 Time: 1500

Odor Level: .50

____Nil
____Barely Detectable
____Readily Detectable
✓ Strong

List other odors present: ____

Remarks: (odorometer reading) 1.40 - .50

Observed By: TS. M.S.

Location: Pike County Fiscal Court

Date: 6-16-10 Time: 1500

Odor Level: .50

____Nil
____Barely Detectable
____Readily Detectable
✓ Strong

List other odors present: ____

Remarks: (odorometer reading) 1.40 - .50

Observed By: TS MS

Frontier Gas LLC

P.O.Box 408 * Prestonsburg, Ky. 41653* 606-886-2431 * 866-942-9427 *Fax:606-889-9196 * lrich@ec.rr.com

Kentucky FRONTIER GAS

Odorization Check Report

Location: Edith Karee

Date: 6-22-10 Time: 1200p

Odor Level: .40

____Nil
____Barely Detectable
___✓Readily Detectable
____ Strong

List other odors present: _____

Remarks: (odorometer reading) _____

Observed By: MS TS

Location: Post office

Date: 6-22-10 Time: 200p

Odor Level: .40

____Nil
____Barely Detectable
___✓Readily Detectable
____ Strong

List other odors present: _____

Remarks: (odorometer reading) _____

Observed By: MS TS

Location: Ronda Stratton

Date: 6-22-10 Time: 300p

Odor Level: .40

____Nil
____Barely Detectable
___✓Readily Detectable
____ Strong

List other odors present: _____

Remarks: (odorometer reading) _____

Observed By: MS TS

Kentucky Frontier Gas, LLC

P.O.Box 408 * Prestonsburg, Ky. 41653* 606-886-2431 * 866-942-9427 *Fax:606-889-9196 * lrich@ec.rr.com

Kentucky FRONTIER GAS

Odorization Check Report

Location: Edith Karee

Date: 6-24-10 Time: 1200p

Odor Level: .40

____Nil
____Barely Detectable
___✓Readily Detectable
____ Strong

List other odors present: _____

Remarks: (odorometer reading) _____

Observed By: MS TS

Location: Post office

Date: 6-24-10 Time: 200p

Odor Level: .40

____Nil
____Barely Detectable
___✓Readily Detectable
____ Strong

List other odors present: _____

Remarks: (odorometer reading) _____

Observed By: MS TS

Location: Ronda Straton

Date: 6-24-10 Time: 300p

Odor Level: .40

____Nil
____Barely Detectable
___✓Readily Detectable
____ Strong

List other odors present: _____

Remarks: (odorometer reading) _____

Observed By: MS TS

Kentucky Frontier Gas, LLC

P.O.Box 408 * Prestonsburg, Ky. 41653* 606-886-2431 * 866-942-9427 *Fax:606-889-9196 * lrich@ec.rr.com

Kentucky FRONTIER GAS

Odorization Check Report

Location: Edith Karee

Date: 7-6-10 Time: 1200p

Odor Level: .40

____Nil
____Barely Detectable
___✓Readily Detectable
____ Strong

List other odors present: _____

Remarks: (odorometer reading) _____

Observed By: MS TS

Location: Post office

Date: 7-6-10 Time: 200p

Odor Level: .40

____Nil
____Barely Detectable
___✓Readily Detectable
____ Strong

List other odors present: _____

Remarks: (odorometer reading) _____

Observed By: MS TS

Location: Ronda Stratton

Date: 7-6-10 Time: 300p

Odor Level: .40

____Nil
____Barely Detectable
___✓Readily Detectable
____ Strong

List other odors present: _____

Remarks: (odorometer reading) _____

Observed By: MS TS

Kentucky Frontier Gas, LLC

P.O.Box 408 * Prestonsburg, Ky. 41653* 606-886-2431 * 866-942-9427 *Fax:606-889-9196 * lrich@ec.rr.com

Kentucky FRONTIER GAS

Odorization Check Report

Location: Edith Karee

Date: 7-13-10 Time: 1200p

Odor Level: .40

____Nil
____Barely Detectable
___✓Readily Detectable
____Strong

List other odors present: _____

Remarks: (odorometer reading) _____

Observed By: MS TS

Location: Post office

Date: 7-13-10 Time: 200p

Odor Level: .40

____Nil
____Barely Detectable
___✓Readily Detectable
____Strong

List other odors present: _____

Remarks: (odorometer reading) _____

Observed By: MS TS

Location: Ronda Straton

Date: 7-13-10 Time: 300p

Odor Level: .40

____Nil
____Barely Detectable
___✓Readily Detectable
____Strong

List other odors present: _____

Remarks: (odorometer reading) _____

Observed By: MS TS

Kentucky Frontier Gas, LLC

P.O.Box 408 * Prestonsburg, Ky. 41653* 606-886-2431 * 866-942-9427 *Fax:606-889-9196 * lrich@ec.rr.com

Kentucky FRONTIER GAS

Odorization Check Report

Location: Edith Karee

Date: 7-20-10 Time: 1200p

Odor Level: .40

____Nil
____Barely Detectable
___✓Readily Detectable
____ Strong

List other odors present: _____

Remarks: (odorometer reading) _____

Observed By: MS TS

Location: Post office

Date: 7-20-10 Time: 200p

Odor Level: .40

____Nil
____Barely Detectable
___✓Readily Detectable
____ Strong

List other odors present: _____

Remarks: (odorometer reading) _____

Observed By: MS TS

Location: Ronda Stratton

Date: 7-20-10 Time: 300p

Odor Level: .40

____Nil
____Barely Detectable
___✓Readily Detectable
____ Strong

List other odors present: _____

Remarks: (odorometer reading) _____

Observed By: MS TS

Kentucky Frontier Gas, LLC

P.O.Box 408 * Prestonsburg, Ky. 41653* 606-886-2431 * 866-942-9427 *Fax:606-889-9196 * lrich@ec.rr.com

Kentucky FRONTIER GAS

Odorization Check Report

Location: Edith Karee

Date: 7-27-10 Time: 1200p

Odor Level: .40

____Nil
____Barely Detectable
___✓Readily Detectable
____ Strong

List other odors present: _____

Remarks: (odorometer reading) _____

Observed By: MS TS

Location: Post office

Date: 7-27-10 Time: 200p

Odor Level: .40

____Nil
____Barely Detectable
___✓Readily Detectable
____ Strong

List other odors present: _____

Remarks: (odorometer reading) _____

Observed By: MS TS

Location: Ronda Straton

Date: 7-27-10 Time: 300p

Odor Level: .40

____Nil
____Barely Detectable
___✓Readily Detectable
____ Strong

List other odors present: _____

Remarks: (odorometer reading) _____

Observed By: MS TS

Kentucky Frontier Gas, LLC

P.O.Box 408 * Prestonsburg, Ky. 41653* 606-886-2431 * 866-942-9427 *Fax:606-889-9196 * lrich@ec.rr.com

Kentucky FRONTIER GAS

Odorization Check Report

Location: Edith Karee

Date: 8-3-10 Time: 1200p

Odor Level: .40

____Nil
____Barely Detectable
___✓Readily Detectable
____Strong

List other odors present: _____

Remarks: (odorometer reading) _____

Observed By: MS TS

Location: Post office

Date: 8-3-10 Time: 200p

Odor Level: .40

____Nil
____Barely Detectable
___✓Readily Detectable
____Strong

List other odors present: _____

Remarks: (odorometer reading) _____

Observed By: MS TS

Location: Ronda Straton

Date: 8-3-10 Time: 300p

Odor Level: .40

____Nil
____Barely Detectable
___✓Readily Detectable
____Strong

List other odors present: _____

Remarks: (odorometer reading) _____

Observed By: MS TS

Kentucky Frontier Gas, LLC

P.O.Box 408 * Prestonsburg, Ky. 41653* 606-886-2431 * 866-942-9427 *Fax:606-889-9196 * lrich@ec.rr.com

Kentucky FRONTIER GAS

Odorization Check Report

Location: Edith Karee

Date: 8-10-10 Time: 1200p

Odor Level: .40

____Nil
____Barely Detectable
___✓Readily Detectable
____ Strong

List other odors present: _____

Remarks: (odorometer reading) _____

Observed By: MS TS

Location: Post office

Date: 8-10-10 Time: 200p

Odor Level: .40

____Nil
____Barely Detectable
___✓Readily Detectable
____ Strong

List other odors present: _____

Remarks: (odorometer reading) _____

Observed By: MS TS

Location: Ronda Stratton

Date: 8-10-10 Time: 300p

Odor Level: .40

____Nil
____Barely Detectable
___✓Readily Detectable
____ Strong

List other odors present: _____

Remarks: (odorometer reading) _____

Observed By: MS TS

Kentucky Frontier Gas, LLC

P.O.Box 408 * Prestonsburg, Ky. 41653* 606-886-2431 * 866-942-9427 *Fax:606-889-9196 * lrich@ec.rr.com

Kentucky FRONTIER GAS

Odorization Check Report

Location: Edith Karee

Date: 5-17-10 Time: 1200p

Odor Level: .40

____Nil
____Barely Detectable
___✓Readily Detectable
____ Strong

List other odors present: _____

Remarks: (odorometer reading)_____

Observed By: MS TS

Location: Post office

Date: 5-17-10 Time: 200p

Odor Level: .40

____Nil
____Barely Detectable
___✓Readily Detectable
____ Strong

List other odors present: _____

Remarks: (odorometer reading)_____

Observed By: MS TS

Location: Ronda Stratton

Date: 5-17-10 Time: 300p

Odor Level: .40

____Nil
____Barely Detectable
___✓Readily Detectable
____ Strong

List other odors present: _____

Remarks: (odorometer reading)_____

Observed By: MS TS

Kentucky Frontier Gas, LLC

P.O.Box 408 * Prestonsburg, Ky. 41653* 606-886-2431 * 866-942-9427 *Fax:606-889-9196 * lrich@ec.rr.com

Kentucky FRONTIER GAS

Odorization Check Report

Location: Edith Kazee

Date: 8-24-10 Time: 1200p

Odor Level: .40

____Nil
____Barely Detectable
___✓Readily Detectable
____ Strong

List other odors present: _____

Remarks: (odorometer reading) _____

Observed By: MS TS

Location: Post office

Date: 8-24-10 Time: 200p

Odor Level: .40

____Nil
____Barely Detectable
___✓Readily Detectable
____ Strong

List other odors present: _____

Remarks: (odorometer reading) _____

Observed By: MS TS

Location: Ronda Stratton

Date: 8-24-10 Time: 300p

Odor Level: .40

____Nil
____Barely Detectable
___✓Readily Detectable
____ Strong

List other odors present: _____

Remarks: (odorometer reading) _____

Observed By: MS TS

Kentucky Frontier Gas, LLC

P.O.Box 408 * Prestonsburg, Ky. 41653* 606-886-2431 * 866-942-9427 *Fax:606-889-9196 * lrich@ec.rr.com

Kentucky FRONTIER GAS

Odorization Check Report

Location: Edith Kazee

Date: 8-31-10 Time: 1200p

Odor Level: .40

____Nil
____Barely Detectable
___✓Readily Detectable
____ Strong

List other odors present: _____

Remarks: (odorometer reading) _____

Observed By: MS JS

Location: Post office

Date: 8-31-10 Time: 200p

Odor Level: .40

____Nil
____Barely Detectable
___✓Readily Detectable
____ Strong

List other odors present: _____

Remarks: (odorometer reading) _____

Observed By: MS JS

Location: Ronda Stratton

Date: 8-31-10 Time: 300p

Odor Level: .40

____Nil
____Barely Detectable
___✓Readily Detectable
____ Strong

List other odors present: _____

Remarks: (odorometer reading) _____

Observed By: MS JS

Kentucky Frontier Gas, LLC

P.O.Box 408 * Prestonsburg, Ky. 41653* 606-886-2431 * 866-942-9427 *Fax:606-889-9196 * lrich@ec.rr.com

Kentucky FRONTIER GAS

Odorization Check Report

Location: Edith Karee

Date: 9-7-10 Time: 1200p

Odor Level: .40

____Nil
____Barely Detectable
___✓Readily Detectable
____ Strong

List other odors present: _____

Remarks: (odorometer reading) _____

Observed By: MS TS

Location: Post office

Date: 9-7-10 Time: 200p

Odor Level: .40

____Nil
____Barely Detectable
___✓Readily Detectable
____ Strong

List other odors present: _____

Remarks: (odorometer reading) _____

Observed By: MS TS

Location: Ronda Stratton

Date: 9-7-10 Time: 300p

Odor Level: .40

____Nil
____Barely Detectable
___✓Readily Detectable
____ Strong

List other odors present: _____

Remarks: (odorometer reading) _____

Observed By: MS TS

Kentucky Frontier Gas, LLC

P.O.Box 408 * Prestonsburg, Ky. 41653* 606-886-2431 * 866-942-9427 *Fax:606-889-9196 * lrich@ec.rr.com

Kentucky FRONTIER GAS

Odorization Check Report

Location: Edith Karee

Date: 9-14-10 Time: 1200p

Odor Level: .40

____Nil
____Barely Detectable
___✓Readily Detectable
____Strong

List other odors present: _____

Remarks: (odorometer reading) _____

Observed By: MS TS

Location: Post office

Date: 9-14-10 Time: 200p

Odor Level: .40

____Nil
____Barely Detectable
___✓Readily Detectable
____Strong

List other odors present: _____

Remarks: (odorometer reading) _____

Observed By: MS TS

Location: Ronda Straton

Date: 9-14-10 Time: 300p

Odor Level: .40

____Nil
____Barely Detectable
___✓Readily Detectable
____Strong

List other odors present: _____

Remarks: (odorometer reading) _____

Observed By: MS TS

Kentucky Frontier Gas, LLC

P.O.Box 408 * Prestonsburg, Ky. 41653* 606-886-2431 * 866-942-9427 *Fax:606-889-9196 * lrich@ec.rr.com

Kentucky FRONTIER GAS

Odorization Check Report

Location: Edith Kasee

Date: 9-21-10 Time: 1200p

Odor Level: .40

____Nil
____Barely Detectable
✓ Readily Detectable
____ Strong

List other odors present: _____

Remarks: (odorometer reading) _____

Observed By: TS MS

Location: Post Office

Date: 9-21-10 Time: 200p

Odor Level: .40

____Nil
____Barely Detectable
✓ Readily Detectable
____ Strong

List other odors present: _____

Remarks: (odorometer reading) _____

Observed By: TS MS

Location: Ronda Stratton

Date: 9-21-10 Time: 300p

Odor Level: .40

____Nil
____Barely Detectable
✓ Readily Detectable
____ Strong

List other odors present: _____

Remarks: (odorometer reading) _____

Observed By: TS MS

Kentucky Frontier Gas, LLC

P.O.Box 408 * Prestonsburg, Ky. 41653* 606-886-2431 * 866-942-9427 *Fax:606-889-9196 * lrich@ec.rr.com

Kentucky FRONTIER GAS

Odorization Check Report

Location: EDITH KASEE

Date: 4-28-10 Time: 200P

Odor Level: .40

____Nil
____Barely Detectable
___✓Readily Detectable
____ Strong

List other odors present: _____

Remarks: (odorometer reading)_____

Observed By: TS MS

Location: POST OFFICE

Date: 4-28-10 Time: 300PM

Odor Level: .40

____Nil
____Barely Detectable
___✓Readily Detectable
____ Strong

List other odors present: _____

Remarks: (odorometer reading)_____

Observed By: TS MS

Location: RONDA STRATON

Date: 4-28-10 Time: 400P

Odor Level:

____Nil
____Barely Detectable
___✓Readily Detectable
____ Strong

List other odors present: _____

Remarks: (odorometer reading)_____

Observed By: TS MS

Kentucky Frontier Gas, LLC

P.O.Box 408 * Prestonsburg, Ky. 41653* 606-886-2431 * 866-942-9427 *Fax:606-889-9196 * lrich@ec.rr.com

Kentucky FRONTIER GAS

Odorization Check Report

Location: Edith Kasec

Date: 10-5-10 Time: 1230

Odor Level: .50

____Nil
____Barely Detectable
___✓Readily Detectable
____ Strong

List other odors present: _____

Remarks: (odorometer reading)_____

Observed By: TS MS

Location: Ronda Stratton

Date: 10-5-10 Time: 130

Odor Level: .50

____Nil
____Barely Detectable
___✓Readily Detectable
____ Strong

List other odors present: _____

Remarks: (odorometer reading)_____

Observed By: MS TS

Location: Post office

Date: 10-5-10 Time: 230

Odor Level: .50

____Nil
____Barely Detectable
___✓Readily Detectable
____ Strong

List other odors present: _____

Remarks: (odorometer reading)_____

Observed By: TS MS

Kentucky Frontier Gas, LLC

P.O.Box 408 * Prestonsburg, Ky. 41653* 606-886-2431 * 866-942-9427 *Fax:606-889-9196 * lrich@ec.rr.com

Kentucky FRONTIER GAS

Odorization Check Report

Location: EDITH KASEC

Date: 10/2/10 Time: 1230

Odor Level: .50

____Nil
____Barely Detectable
___✓Readily Detectable
____ Strong

List other odors present: _____

Remarks: (odorometer reading)_____

Observed By: MS TS

Location: RONDA STRATTON

Date: 10/2/10 Time: 130

Odor Level: .50

____Nil
____Barely Detectable
___✓Readily Detectable
____ Strong

List other odors present: _____

Remarks: (odorometer reading)_____

Observed By: MS TS

Location: POST OFFICE

Date: 10-14-10 Time: 200

Odor Level: .50

____Nil
____Barely Detectable
___✓Readily Detectable
____ Strong

List other odors present: _____

Remarks: (odorometer reading)_____

Observed By: MS TS

Kentucky Frontier Gas, LLC

P.O.Box 408 * Prestonsburg, Ky. 41653* 606-886-2431 * 866-942-9427 *Fax:606-889-9196 * lrich@ec.rr.com

Kentucky FRONTIER GAS

Odorization Check Report

Location: Edith Kasec

Date: 10-19-10 Time: 100

Odor Level: 50

_____Nil
_____Barely Detectable
___✓___Readily Detectable
_____ Strong

List other odors present: _____

Remarks: (odorometer reading)_____

Observed By: TSMS

Location: [redacted] Victor Justice

Date: 10-19-10 Time: 230

Odor Level: 50

_____Nil
_____Barely Detectable
___✓___Readily Detectable
_____ Strong

List other odors present: _____

Remarks: (odorometer reading)_____

Observed By: TS M S

Location: Post Office

Date: 10-19-10 Time: 330

Odor Level: 50

_____Nil
_____Barely Detectable
___✓___Readily Detectable
_____ Strong

List other odors present: _____

Remarks: (odorometer reading)_____

Observed By: TS M S

Kentucky Frontier Gas, LLC

P.O.Box 408 * Prestonsburg, Ky. 41653* 606-886-2431 * 866-942-9427 *Fax:606-889-9196 * lrich@ec.rr.com

Kentucky FRONTIER GAS

Odorization Check Report

Location: Colin Kasee

Date: 10-26-10 Time: 1230

Odor Level: .50

_____Nil
_____Barely Detectable
___✓___Readily Detectable
_____ Strong

List other odors present: _____

Remarks: (odorometer reading)_____

Observed By: TJ MS

Location: Victor Justice

Date: 10-26-10 Time: 200

Odor Level: .50

_____Nil
_____Barely Detectable
___✓___Readily Detectable
_____ Strong

List other odors present: _____

Remarks: (odorometer reading)_____

Observed By: MS TS

Location: Post Office

Date: 10-26-10 Time: 230

Odor Level: .50

_____Nil
_____Barely Detectable
___✓___Readily Detectable
_____ Strong

List other odors present: _____

Remarks: (odorometer reading)_____

Observed By: MS TS

Kentucky Frontier Gas, LLC

P.O.Box 408 * Prestonsburg, Ky. 41653* 606-886-2431 * 866-942-9427 *Fax:606-889-9196 * lrich@ec.rr.com

Phelps

Kentucky FRONTIER GAS

Odorization Check Report

Location: Edith Kasey

Date: 11-2-10 Time: 100

Odor Level: .50

_____Nil
_____Barely Detectable
___✓___Readily Detectable
_____ Strong

List other odors present: _____

Remarks: (odorometer reading)_____

Observed By: M.S. T.S.

Location: Victor Justice

Date: 11-2-10 Time: 200

Odor Level: .50

_____Nil
_____Barely Detectable
___✓___Readily Detectable
_____ Strong

List other odors present: _____

Remarks: (odorometer reading)_____

Observed By: M.S. T.S.

Location: Post Office

Date: 11-2-10 Time: 330

Odor Level: 50

_____Nil
_____Barely Detectable
___✓___Readily Detectable
_____ Strong

List other odors present: _____

Remarks: (odorometer reading)_____

Observed By: T.S. M.S.

Kentucky Frontier Gas, LLC

P.O.Box 408 * Prestonsburg, Ky. 41653* 606-886-2431 * 866-942-9427 *Fax:606-889-9196 * lrich@ec.rr.com

Phelps

Kentucky FRONTIER GAS

Odorization Check Report

Location: Edith Kasee

Date: 11-16-10 Time: 1200

Odor Level: .50

____Nil
____Barely Detectable
___✓Readily Detectable
____ Strong

List other odors present: _____

Remarks: (odorometer reading)_____

Observed By: MS. TS

Location: Post Office

Date: 11-16-10 Time: 200

Odor Level: .50

____Nil
____Barely Detectable
___✓Readily Detectable
____ Strong

List other odors present: _____

Remarks: (odorometer reading)_____

Observed By: MS TS

Location: Victor Justice

Date: 11-16-10 Time: 0430

Odor Level: .50

____Nil
____Barely Detectable
___✓Readily Detectable
____ Strong

List other odors present: _____

Remarks: (odorometer reading)_____

Observed By: MS TS

Kentucky Frontier Gas, LLC

P.O.Box 408 * Prestonsburg, Ky. 41653* 606-886-2431 * 866-942-9427 *Fax:606-889-9196 * lrich@ec.rr.com

Kentucky FRONTIER GAS

Phelps

Odorization Check Report

Location: Edith Kasee

Date: 11-23-10 Time: 1200

Odor Level: 50

____Nil
____Barely Detectable
___✓Readily Detectable
____ Strong

List other odors present: _____

Remarks: (odorometer reading)_____

Observed By: MS TS

Location: Post Office

Date: 11-23-10 Time: 200

Odor Level: 50

____Nil
____Barely Detectable
___✓Readily Detectable
____ Strong

List other odors present: _____

Remarks: (odorometer reading)_____

Observed By: MS TS

Location: Victor Justice

Date: 11-23-10 Time: 400

Odor Level: 50

____Nil
____Barely Detectable
___✓Readily Detectable
____ Strong

List other odors present: _____

Remarks: (odorometer reading)_____

Observed By: TS MS

Kentucky Frontier Gas, LLC

P.O.Box 408 * Prestonsburg, Ky. 41653* 606-886-2431 * 866-942-9427 *Fax:606-889-9196 * lrich@ec.rr.com

Kentucky FRONTIER GAS

Phelps

Odorization Check Report

Location: Edith Kasee

Date: 11-30-10 Time: 1200

Odor Level: .50

_____Nil
_____Barely Detectable
_____ Readily Detectable
_____ Strong

List other odors present: _____

Remarks: (odorometer reading)_____

Observed By: TSMS

Location: Post Office

Date: 11-30-10 Time: 200

Odor Level: .50

_____Nil
_____Barely Detectable
_____ Readily Detectable
_____ Strong

List other odors present: _____

Remarks: (odorometer reading)_____

Observed By: MSGS

Location: Victor Justice

Date: 11-30-10 Time: 400

Odor Level: .50

_____Nil
_____Barely Detectable
_____ Readily Detectable
_____ Strong

List other odors present: _____

Remarks: (odorometer reading)_____

Observed By: TSMS

Kentucky Frontier Gas, LLC

P.O.Box 408 * Prestonsburg, Ky. 41653* 606-886-2431 * 866-942-9427 *Fax:606-889-9196 * lrich@ec.rr.com

Kentucky FRONTIER GAS

Phelps

Odorization Check Report

Location: Victor Justice

Date: 12-7-10 Time: 100

Odor Level: .50

_____Nil
_____Barely Detectable
_____ Readily Detectable
_____ Strong

List other odors present: _____

Remarks: (odorometer reading)_____

Observed By: MS TJ

Location: Post Office

Date: 12-7-10 Time: 200

Odor Level: .50

_____Nil
_____Barely Detectable
_____ Readily Detectable
_____ Strong

List other odors present: _____

Remarks: (odorometer reading)_____

Observed By: MS TJ

Location: Edith Kasee

Date: 12-7-10 Time: 500

Odor Level: .50

_____Nil
_____Barely Detectable
_____ Readily Detectable
_____ Strong

List other odors present: _____

Remarks: (odorometer reading)_____

Observed By: MS TJ

Kentucky Frontier Gas, LLC

P.O.Box 408 * Prestonsburg, Ky. 41653* 606-886-2431 * 866-942-9427 *Fax:606-889-9196 * lrich@ec.rr.com

Kentucky FRONTIER GAS

Phelps

Odorization Check Report

Location: Victor Justice

Date: 12-17-10 Time: 1200

Odor Level: .50

____Nil
____Barely Detectable
___✓Readily Detectable
____ Strong

List other odors present: _____

Remarks: (odorometer reading) _____

Observed By: MS TS

Location: Post Office

Date: 12-17-10 Time: 130

Odor Level: .50

____Nil
____Barely Detectable
___✓Readily Detectable
____ Strong

List other odors present: _____

Remarks: (odorometer reading) _____

Observed By: MS TS

Location: Victor Justice

Date: 12-17-10 Time: 400

Odor Level: .50

____Nil
____Barely Detectable
___✓Readily Detectable
____ Strong

List other odors present: _____

Remarks: (odorometer reading) _____

Observed By: MS TS

Kentucky Frontier Gas LLC

P.O.Box 408 * Prestonsburg, Ky. 41653* 606-886-2431 * 866-942-9427 *Fax:606-889-9196 * lrich@ec.rr.com

Kentucky FRONTIER GAS

Phelps

Odorization Check Report

Location: Edith Kasee

Date: 12-21-10 Time: 1230

Odor Level: .50

____Nil
____Barely Detectable
___✓Readily Detectable
____ Strong

List other odors present: _____

Remarks: (odorometer reading)_____

Observed By: MST S

Location: Post Office

Date: 12-21-10 Time: 230

Odor Level: .50

____Nil
____Barely Detectable
___✓Readily Detectable
____ Strong

List other odors present: _____

Remarks: (odorometer reading)_____

Observed By: MS TS

Location: Victor Justice

Date: 12-21-10 Time: 430

Odor Level: .50

____Nil
____Barely Detectable
___✓Readily Detectable
____ Strong

List other odors present: _____

Remarks: (odorometer reading)_____

Observed By: MS TS

P.O.Box 408 * Prestonsburg, Ky. 41653* 606-886-2431 * 866-942-9427 *Fax:606-889-9196 * lrich@ec.rr.com

Kentucky FRONTIER GAS

Phelps

Odorization Check Report

Location: Edith Kasee

Date: 12-28-10 Time: 1200

Odor Level: .50

____Nil
____Barely Detectable
___✓Readily Detectable
____ Strong

List other odors present: _____

Remarks: (odorometer reading)_____

Observed By: MS DS

Location: Post Office

Date: 12-28-10 Time: 145

Odor Level: .50

____Nil
____Barely Detectable
___✓Readily Detectable
____ Strong

List other odors present: _____

Remarks: (odorometer reading)_____

Observed By: MS DS

Location: Victor

Date: 12-28-10 Time: 330

Odor Level: .50

____Nil
____Barely Detectable
___✓Readily Detectable
____ Strong

List other odors present: _____

Remarks: (odorometer reading)_____

Observed By: DS MS

Kentucky Frontier Gas LLC

P.O Box 408 * Prestonsburg, Ky. 41653* 606-886-2431 * 866-942-9427 *Fax:606-889-9196 * lrich@ec.rr.com

Kentucky FRONTIER GAS

Phelps

Odorization Check Report

Location: Victor Justice

Date: 1-4-11 Time: 1245

Odor Level: .50

_____Nil
_____Barely Detectable
___✓___Readily Detectable
_____ Strong

List other odors present: _____

Remarks: (odorometer reading)_____

Observed By: TS MS

Location: Post office

Date: 1-4-11 Time: 200

Odor Level: .50

_____Nil
_____Barely Detectable
___✓___Readily Detectable
_____ Strong

List other odors present: _____

Remarks: (odorometer reading)_____

Observed By: MS TS

Location: Edith Kasee

Date: 1-4-11 Time: 400

Odor Level: .50

_____Nil
_____Barely Detectable
___✓___Readily Detectable
_____ Strong

List other odors present: _____

Remarks: (odorometer reading)_____

Observed By: MS TS

P.O.Box 408 * Prestonsburg, Ky. 41653* 606-886-2431 * 866-942-9427 *Fax:606-889-9196 * lrich@ec.rr.com

Kentucky FRONTIER GAS

Phelps

Odorization Check Report

Location: Victor Justice

Date: 1-11-11 Time: 100

Odor Level: .50

_____Nil
_____Barely Detectable
___✓___Readily Detectable
_____ Strong

List other odors present: _____

Remarks: (odorometer reading)_____

Observed By: MS TS

Location: Post Office

Date: 1-11-11 Time: 230

Odor Level: .50

_____Nil
_____Barely Detectable
___✓___Readily Detectable
_____ Strong

List other odors present: _____

Remarks: (odorometer reading)_____

Observed By: MS TS

Location: Edith Rasec

Date: 1-11-11 Time: 430

Odor Level: .50

_____Nil
_____Barely Detectable
___✓___Readily Detectable
_____ Strong

List other odors present: _____

Remarks: (odorometer reading)_____

Observed By: MS. TS.

Copyright 2011, Frontier Gas LLC

P.O.Box 408 * Prestonsburg, Ky. 41653* 606-886-2431 * 866-942-9427 *Fax:606-889-9196 * lrich@ec.rr.com

Kentucky FRONTIER GAS

Phelps

Odorization Check Report

Location: Edith Kasec

Date: 1-18-11 Time: 100

Odor Level: 150

_____Nil
_____Barely Detectable
___✓___Readily Detectable
_____ Strong

List other odors present: _____

Remarks: (odorometer reading)_____

Observed By: MS TS

Location: Victor Justice

Date: 1-18-11 Time: 300

Odor Level: 150

_____Nil
_____Barely Detectable
___✓___Readily Detectable
_____ Strong

List other odors present: _____

Remarks: (odorometer reading)_____

Observed By: MS TS

Location: Post Office

Date: 1-18-11 Time: 430

Odor Level: 150

_____Nil
_____Barely Detectable
___✓___Readily Detectable
_____ Strong

List other odors present: _____

Remarks: (odorometer reading)_____

Observed By: TS MS

Kentucky Frontier Gas LLC

P.O.Box 408 * Prestonsburg, Ky. 41653* 606-886-2431 * 866-942-9427 *Fax:606-889-9196 * lrich@ec.rr.com

Kentucky FRONTIER GAS

Phelps

Odorization Check Report

Location: Victor Justice

Date: 1-25-11 Time: 1245

Odor Level: 5d

_____Nil
_____Barely Detectable
___✓Readily Detectable
_____ Strong

List other odors present: _____

Remarks: (odorometer reading)_____

Observed By: MS TS

Location: Post Office

Date: 1-25-11 Time: 200

Odor Level: 5d

_____Nil
_____Barely Detectable
___✓Readily Detectable
_____ Strong

List other odors present: _____

Remarks: (odorometer reading)_____

Observed By: MS TS

Location: Cedar Knob

Date: 1-25-11 Time: 400

Odor Level: 5d

_____Nil
_____Barely Detectable
___✓Readily Detectable
_____ Strong

List other odors present: _____

Remarks: (odorometer reading)_____

Observed By: TS MS

Kentucky Frontier Gas LLC

P.O.Box 408 * Prestonsburg, Ky. 41653* 606-886-2431 * 866-942-9427 *Fax:606-889-9196 * lrich@ec.rr.com

Kentucky FRONTIER GAS

Phelps

Odorization Check Report

Location: Victor Justice

Date: 2-1-11 Time: 1230

Odor Level: .50

_____Nil
_____Barely Detectable
___✓___Readily Detectable
_____ Strong

List other odors present: _____

Remarks: (odorometer reading)_____

Observed By: MS FS

Location: Post Office

Date: 2-1-11 Time: 230

Odor Level: .50

_____Nil
_____Barely Detectable
___✓___Readily Detectable
_____ Strong

List other odors present: _____

Remarks: (odorometer reading)_____

Observed By: MS FS

Location: Edith Kasee

Date: 2-1-11 Time: 400

Odor Level: .50

_____Nil
_____Barely Detectable
___✓___Readily Detectable
_____ Strong

List other odors present: _____

Remarks: (odorometer reading)_____

Observed By: MS FS

P.O.Box 408 * Prestonsburg, Ky. 41653* 606-886-2431 * 866-942-9427 *Fax:606-889-9196 * lrich@ec.rr.com

Kentucky FRONTIER GAS

Phelps

Odorization Check Report

Location: Victor Justice

Date: 2-8-11 Time: 1000

Odor Level: .50

_____Nil
_____Barely Detectable
_____Readily Detectable
_____Strong

List other odors present: _____

Remarks: (odorometer reading) _____

Observed By: MS TS

Location: Post office

Date: 2-8-11 Time: 430

Odor Level: .50

_____Nil
_____Barely Detectable
_____Readily Detectable
_____Strong

List other odors present: _____

Remarks: (odorometer reading) _____

Observed By: MS TS

Location: Edith Kazee

Date: 2-8-11 Time: 500

Odor Level: .50

_____Nil
_____Barely Detectable
_____Readily Detectable
_____Strong

List other odors present: _____

Remarks: (odorometer reading) _____

Observed By: MS TS

Kentucky Frontier Gas, LLC

P.O.Box 408 * Prestonsburg, Ky. 41653* 606-886-2431 * 866-942-9427 *Fax:606-889-9196 * lrich@ec.rr.com

Kentucky FRONTIER GAS

Phelps

Odorization Check Report

Location: Post Office

Date: 2-15-11 Time: 330

Odor Level: .50

____Nil
____Barely Detectable
___✓Readily Detectable
____Strong

List other odors present: _____

Remarks: (odorometer reading) _____

Observed By: MSTS

Location: Victor Justice

Date: 2-15-11 Time: 400

Odor Level: .50

____Nil
____Barely Detectable
___✓Readily Detectable
____Strong

List other odors present: _____

Remarks: (odorometer reading) _____

Observed By: TSMS

Location: Edith Kaser

Date: 2-15-11 Time: 500

Odor Level: .50

____Nil
____Barely Detectable
___✓Readily Detectable
____Strong

List other odors present: _____

Remarks: (odorometer reading) _____

Observed By: MSTS

Kentucky Frontier Gas, LLC

P.O.Box 408 * Prestonsburg, Ky. 41653* 606-886-2431 * 866-942-9427 *Fax:606-889-9196 * lrich@ec.rr.com

Kentucky FRONTIER GAS

Phelps

Odorization Check Report

Location: Victor Justice

Date: 2-22-11 Time: 330

Odor Level: .50

_____Nil
_____Barely Detectable
_____Readily Detectable
_____Strong

List other odors present: _____

Remarks: (odorometer reading) _____

Observed By: TS MS

Location: Post Office

Date: 2-22-11 Time: 430

Odor Level: .50

_____Nil
_____Barely Detectable
_____Readily Detectable
_____Strong

List other odors present: _____

Remarks: (odorometer reading) _____

Observed By: TS MS

Location: Edith Kasec

Date: 2-22-11 Time: 500

Odor Level:

_____Nil
_____Barely Detectable
_____Readily Detectable
_____Strong

List other odors present: _____

Remarks: (odorometer reading) _____

Observed By: TS MS

Kentucky Frontier Gas, LLC

P.O.Box 408 * Prestonsburg, Ky. 41653* 606-886-2431 * 866-942-9427 *Fax:606-889-9196 * lrich@ec.rr.com

Kentucky FRONTIER GAS

Phelps

Odorization Check Report

Location: Post Office

Date: 3-1-11 Time: 330

Odor Level: .50

____Nil
____Barely Detectable
___✓Readily Detectable
____ Strong

List other odors present: _____

Remarks: (odorometer reading)_____

Observed By: TSMS

Location: Victor Justice

Date: 3-1-11 Time: 400

Odor Level: .50

____Nil
____Barely Detectable
___✓Readily Detectable
____ Strong

List other odors present: _____

Remarks: (odorometer reading)_____

Observed By: TSMS

Location: Edith Kasee

Date: 3-1-11 Time: 445

Odor Level: .50

____Nil
____Barely Detectable
___✓Readily Detectable
____ Strong

List other odors present: _____

Remarks: (odorometer reading)_____

Observed By: MS TS

Kentucky Frontier Gas, LLC

P.O.Box 408 * Prestonsburg, Ky. 41653* 606-886-2431 * 866-942-9427 *Fax:606-889-9196 * lrich@ec.rr.com

Kentucky FRONTIER GAS

Phelps

Odorization Check Report

Location: Victor Justice

Date: 3-8-11 Time: 345

Odor Level: .50

_____Nil
_____Barely Detectable
_____Readily Detectable
_____Strong

List other odors present: _____

Remarks: (odorometer reading) _____

Observed By: TS MS

Location: Postoffice

Date: 3-8-11 Time: 430

Odor Level: .50

_____Nil
_____Barely Detectable
_____Readily Detectable
_____Strong

List other odors present: _____

Remarks: (odorometer reading) _____

Observed By: TS MS

Location: Edith Kaece

Date: 3-8-11 Time: 500

Odor Level: .50

_____Nil
_____Barely Detectable
_____Readily Detectable
_____Strong

List other odors present: _____

Remarks: (odorometer reading) _____

Observed By: TS MS

Kentucky Frontier Gas, LLC

P.O.Box 408 * Prestonsburg, Ky. 41653* 606-886-2431 • 866-942-9427 *Fax:606-889-9196 * lrich@ec.rr.com

Kentucky FRONTIER GAS

Phelps

Odorization Check Report

Location: Victor Justice

Date: 3-15-11 Time: 300

Odor Level: .50

____Nil
____Barely Detectable
___✓Readily Detectable
____ Strong

List other odors present: _____

Remarks: (odorometer reading)_____

Observed By: MS TS

Location: Post Office

Date: 3-15-11 Time: 400

Odor Level: .50

____Nil
____Barely Detectable
___✓Readily Detectable
____ Strong

List other odors present: _____

Remarks: (odorometer reading)_____

Observed By: TS MS

Location: Edith Kazee

Date: 3-15-11 Time: 430

Odor Level: .50

____Nil
____Barely Detectable
___✓Readily Detectable
____ Strong

List other odors present: _____

Remarks: (odorometer reading)_____

Observed By: TS MS

Kentucky Frontier Gas, LLC

P.O.Box 408 * Prestonsburg, Ky. 41653* 606-886-2431 * 866-942-9427 *Fax:606-889-9196 * lrich@ec.rr.com

Kentucky FRONTIER GAS

Pre 1B

Odorization Check Report

Location: Edith Kasee

Date: 3-22-4 Time: 415

Odor Level: .50

_____Nil
_____Barely Detectable
_____Readily Detectable
_____Strong

List other odors present: _____

Remarks: (odorometer reading) _____

Observed By: TS MS

Location: Victor Justice

Date: 3-22-4 Time: 435

Odor Level: .50

_____Nil
_____Barely Detectable
_____Readily Detectable
_____Strong

List other odors present: _____

Remarks: (odorometer reading) _____

Observed By: TS MS

Location: Post Office

Date: 3-22-4 Time: 500

Odor Level: .50

_____Nil
_____Barely Detectable
_____Readily Detectable
_____Strong

List other odors present: _____

Remarks: (odorometer reading) _____

Observed By: TS MS

Kentucky Frontier Gas, LLC

P.O.Box 408 * Prestonsburg, Ky. 41653* 606-886-2431 * 866-942-9427 *Fax:606-889-9196 * lrich@ec.rr.com

Kentucky FRONTIER GAS

Phelps

Odorization Check Report

Location: Victor Justice

Date: 3-28-14 Time: 430

Odor Level: .50

_____Nil
_____Barely Detectable
_____Readily Detectable
_____Strong

List other odors present: _____

Remarks: (odorometer reading) _____

Observed By: TS MS

Location: Edith Gasee

Date: 3-28 Time: 500

Odor Level: .50

_____Nil
_____Barely Detectable
_____Readily Detectable
_____Strong

List other odors present: _____

Remarks: (odorometer reading) _____

Observed By: TS MS

Location: Post Office

Date: 3-28 Time: 515

Odor Level: .50

_____Nil
_____Barely Detectable
_____Readily Detectable
_____Strong

List other odors present: _____

Remarks: (odorometer reading) _____

Observed By: MS TS

Kentucky Frontier Gas, LLC

P.O.Box 408 * Prestonsburg, Ky. 41653* 606-886-2431 * 866-942-9427 *Fax:606-889-9196 * lrich@ec.rr.com

Kentucky FRONTIER GAS

Phelps

Odorization Check Report

Location: Victor Justice

Date: 4-1-11 Time: 130

Odor Level: .50

____Nil
____Barely Detectable
___✓Readily Detectable
____ Strong

List other odors present: _____

Remarks: (odorometer reading)_____

Observed By: TSMS

Location: Post Office

Date: 4-1-11 Time: 300

Odor Level: .50

____Nil
____Barely Detectable
___✓Readily Detectable
____ Strong

List other odors present: _____

Remarks: (odorometer reading)_____

Observed By: TS MS

Location: Edith Kasee

Date: 4-1-11 Time: 430

Odor Level: .50

____Nil
____Barely Detectable
___✓Readily Detectable
____ Strong

List other odors present: _____

Remarks: (odorometer reading)_____

Observed By: TSMS

Kentucky Frontier Gas, LLC

P.O.Box 408 * Prestonsburg, Ky. 41653* 606-886-2431 * 866-942-9427 *Fax:606-889-9196 * lrich@ec.rr.com

Kentucky FRONTIER GAS

Page 115

Odorization Check Report

Location: Victor Justice

Date: 4-8-11 Time: 930

Odor Level: .50

_____Nil
_____Barely Detectable
____✓Readily Detectable
_____ Strong

List other odors present: _____

Remarks: (odorometer reading)_____

Observed By: MSTS

Location: Post Office

Date: 4-8-11 Time: 200

Odor Level: .50

_____Nil
_____Barely Detectable
____✓Readily Detectable
_____ Strong

List other odors present: _____

Remarks: (odorometer reading)_____

Observed By: MSTS

Location: Edith Kasee

Date: 4-8-11 Time: 400

Odor Level: .50

_____Nil
_____Barely Detectable
____✓Readily Detectable
_____ Strong

List other odors present: _____

Remarks: (odorometer reading)_____

Observed By: TS PR

Kentucky Frontier Gas, LLC

P.O.Box 408 * Prestonsburg, Ky. 41653* 606-886-2431 * 866-942-9427 *Fax:606-889-9196 * lrich@ec.rr.com

Kentucky FRONTIER GAS

Phelps

Odorization Check Report

Location: Victor Justice

Date: 4-15-11 Time: 100

Odor Level: .50

_____Nil
_____Barely Detectable
___—Readily Detectable
_____ Strong

List other odors present: _____

Remarks: (odorometer reading)_____

Observed By: MSTS

Location: Post Office

Date: 4-15-11 Time: 530

Odor Level: .50

_____Nil
_____Barely Detectable
___—Readily Detectable
_____ Strong

List other odors present: _____

Remarks: (odorometer reading)_____

Observed By: MSTS

Location: Edith Kasee

Date: 4-15-11 Time: 430

Odor Level: .50

_____Nil
_____Barely Detectable
___—Readily Detectable
_____ Strong

List other odors present: _____

Remarks: (odorometer reading)_____

Observed By: TS

Kentucky Frontier Gas, LLC

P.O.Box 408 * Prestonsburg, Ky. 41653* 606-886-2431 * 866-942-9427 *Fax:606-889-9196 * lrich@ec.rr.com

Kentucky FRONTIER GAS

Pg 1 of 5

Odorization Check Report

Location: Victor Justice

Date: 4-22-11 Time: 100

Odor Level: .50

_____Nil
_____Barely Detectable
___—Readily Detectable
_____ Strong

List other odors present: _____

Remarks: (odorometer reading) _____

Observed By: MS TS

Location: Post Office

Date: 4-22-4 Time: 230

Odor Level: .50

_____Nil
_____Barely Detectable
___—Readily Detectable
_____ Strong

List other odors present: _____

Remarks: (odorometer reading) _____

Observed By: TS MS

Location: Edith Kaiser

Date: 4-22-11 Time: 345

Odor Level: .50

_____Nil
_____Barely Detectable
___—Readily Detectable
_____ Strong

List other odors present: _____

Remarks: (odorometer reading) _____

Observed By: [illegible]

P.O.Box 408 * Prestonsburg, Ky. 41653* 606-886-2431 * 866-942-9427 *Fax:606-889-9196 * lrich@ec.rr.com