

This Integrated Resource Plan represents a snapshot of an ongoing resource planning process using current business assumptions. The planning process is constantly evolving and may be revised as conditions change and as new information becomes available. Before embarking on any final strategic decisions or physical actions, the Companies will continue to evaluate alternatives for providing reliable energy while complying with all regulations in a least-cost manner. Such decisions or actions will be supported by specific analyses and will be subject to the appropriate regulatory approval processes.

RECEIVED
APR 21 2011
PUBLIC SERVICE
COMMISSION

Recommendations in PSC Staff Report on the Last IRP – Case No. 2008-00148

Load Forecasting

- **LG&E/KU should continue to examine and report on the potential impact of increasing competition and future environmental requirements and how these issues are incorporated into future load forecasts.**

As stated in section 7.(7)(e), the Base IRP forecast does not explicitly incorporate potential impacts of increasing competition. The load forecast assumes the status quo for our obligations to serve in both Kentucky and Virginia based on existing policy directions in the state and country. Integrated resource planning is based on the assumption of an obligation to serve a specifically defined service territory.

Future environmental requirements are incorporated in the Base IRP forecast and the High and Low forecast sensitivities using the SAE models for the commercial and industrial sectors, as described in Section 7.7.

- **LG&E/KU should continue its efforts to further integrate the load forecasting processes and report on these efforts in their next IRP filing.**

As stated in section 6 (Load Forecast, Reason for Forecast Changes), several changes in forecasting methodology were incorporated in the 2011 IRP forecasts to streamline and further integrate the forecasting process while maintaining or enhancing the consistency of data inputs and the quality of the forecast. Please see section 6 for a complete discussion of those changes.

Demand Side Management

- **Staff encourages the Companies to pursue DSM alternatives with industrial and large commercial customers.**
- **Continue aggressively seeking opportunities for new and innovative DSM programs.**
- **The Companies should work to verify (to the extent possible) the actual achieved reduction in energy usage of each of the pilot DSM programs.**

As a result of the Companies' ongoing review of Demand Side Management/Energy Efficiency ("DSM/EE") programs and research into possible new programs, the Companies have formulated concepts for enhanced and additional DSM/EE programs to be included in its DSM/EE Program Plan. This plan was filed with the Commission in Case No. 2011-00134. The Companies received customer feedback that has enabled the Companies to pursue DSM alternatives that are responsive to the increasing number of requests from the commercial customer segment. The proposed DSM/EE filing seeks the inclusion of additional energy efficiency retrofits eligible

for incentives such as refrigeration; and to add commercial customized incentives to encourage sustained energy efficient retrofits for customers that are not covered by the existing Commercial Conservation/Incentive Program.

The Companies developed the proposed DSM/EE Plan in collaboration with their Energy Efficiency Advisory Group that seeks opportunities for new and innovative DSM programs for both the residential and commercial customer segment. Upon approval, this Program Plan can further increase program participation opportunities for customers and support the Companies in meeting its 2008 IRP cumulative demand reductions. This Program Plan will enhance the following programs: Residential and Commercial Load Management; Commercial Conservation; Residential Conservation; Residential Low Income Weatherization Program; and Program Development and Administration. In addition to enhancing several currently approved programs, the Companies plan to seek approval for additional DSM programs that will further increase energy and demand savings for the Companies. These programs include the Smart Energy Profile Program, Residential Incentives Program, and a Residential Refrigerator Removal Program.

Supply-Side Resource Assessment

- **In the next IRP, LG&E/KU should specifically discuss the existence of any cogeneration within their service territories and the consideration given to cogeneration in the resource plan.**
- **LG&E and KU should specifically identify and describe the net metering equipment and systems installed on each system. A detailed discussion on the manner in which such resources were considered in the LG&E/KU resource plan should also be provided.**
- **LG&E/KU should provide a detailed discussion of the consideration given to distributed generation in the resource plan.**

The Companies have tariffs that allow for distributed generation to be produced by customers within the service territory as discussed below.

Both KU and LG&E have net metering tariffs which provide customers with the option of generating their own electricity using renewable resources. Net metering measures the difference between the energy a customer purchases from the Companies and the amount of energy the customer generates using their own renewable energy source. Any excess power generated is “banked” as a credit to be applied against the customer’s future energy purchases from the Companies. The Companies currently have 88 net metering customers with capacities from 0.875 kW to 29.5 kW. In 2010, those customers generated 84 MWh in excess of their individual energy consumption. Summaries of the Companies’ net metering customers for which the Companies have detailed data and the associated capacities by source type are shown in the following tables.

| | Solar | Wind | Solar/ Wind | N/A | Total |
|----------------------|--------------|-------------|------------------------|------------|--------------|
| <i>Customers (#)</i> | | | | | |
| Residential | 63 | 2 | 1 | 3 | 69 |
| Non-Residential | 15 | 2 | 0 | 2 | 19 |
| Total | 78 | 4 | 1 | 5 | 88 |

| | Solar | Wind | Total |
|----------------------|--------------|-------------|--------------|
| <i>Capacity (kW)</i> | | | |
| Residential | 135 | 7 | 142 |
| Non-Residential | 195 | 4 | 199 |
| Total | 329 | 12 | 341 |

In addition to the net metering tariffs which limit customers to 30 kW of generating capacity, the Companies also provide tariffs for customers with generating capacities greater than 30 kW. These tariffs allow for cogeneration customers with qualifying facilities to sell all or part of their excess power to the Companies. Successful cogeneration facilities are very site-specific and require an industrial host operating with the appropriate economic factors to make the arrangement cost-effective. Currently, there are no customers on this rate however, the Companies continue to investigate potential opportunities.

Given the very small impact of net metering customers relative to the size of the Companies' generation needs and the lack of cogeneration customers on the Companies' system, these options have not been explicitly included as resources in the resource plan. While these types of generation sources can be somewhat reliable for producing energy, they offer an uncertain contribution to meet peak demand.

In developing the optimal resource plan, a number of small technologies that could be utilized as distributed generation were considered as supply-side options as detailed in the study *Analysis of Supply-Side Technology Alternatives* (March 2011), Volume III, Technical Appendix. The wind conversion and landfill gas options passed the supply-side screening analysis and were included in the options available for the optimal expansion plan. However, due to the relatively high cost for firm capacity contribution and limited opportunities in Kentucky for these resources, they were not chosen as the least-cost means to meet the Companies' expected demand. The Companies will continue to evaluate potential generation opportunities as they arise and as technologies develop further.

LG&E/KU should provide a specific discussion of the improvements to and more efficient utilization of transmission and distribution facilities as required by 807 KAR 5:058, Section 8(2)(a). This information should be provided for the past three years and should address LG&E/KU's plans for the next three years.

The improvements to and more efficient utilization of transmission and distribution facilities are discussed in Section 8.(2)(a) in Volume I. In compliance with the FERC Standards of Conduct, the projects related to the Companies' transmission system are covered in detail in *Transmission Information* of Volume III, Technical Appendix of this Plan.

Companies are strongly encouraged to redouble efforts to pursue viable hydro power opportunities and to report on efforts in 2011 IRP per Change of Control Order (Case No. 2001-00204: Page 16).

The Companies' primary focus for additional hydro opportunities is at the Companies' existing hydro stations. An additional 6 MW of capacity will result from the ongoing upgrades at KU's Dix Dam Station; an additional 16 MW (expected at summer peak) will result from the rehabilitation of the units at the Ohio Falls Station. In addition to these rehabilitation efforts, the Companies continue to monitor potential hydro opportunities. While the Ohio River provides the most realistic potential for developing new hydro projects of significant size, other existing dams on the Ohio River are already licensed by other companies and the high cost of building a new dam makes that option economically unfeasible. Building a new hydro plant at an existing dam requires transmission access, multi-year licensing, and management of environmental concerns which typically drive such projects to be too expensive to be a least-cost option.

In 2008, a feasibility study was commissioned by LG&E to investigate potential expansion alternatives at the Ohio Falls Station. This study considered five configurations of additional units and concluded with the recommendation of a 50 MW bulb unit on Shippingport Island as the most viable and cost-effective alternative. This project was included as one of the technologies considered for further evaluation in the long-term expansion plan but it was not shown to be part of the least-cost plan.

Section 1251(12): Administrative Case No. 2007-00300 (Consideration of the Requirements of the Federal Energy Policy Act of 2005 Regarding Fuel Sources and Fossil Fuel Generation Efficiency – Fuel Sources

In connection with its decision not to mandate adoption of a fuel source standard, the Commission directs the jurisdictional generators to place greater emphasis on research into cost-effective alternatives to generation based on coal, natural gas, and fuel oil. Also, in accordance with 807 KAR 5058, Section 8(2)(b) and (d), the Commission directs the generators to include a full, detailed discussion of such efforts in IRPs filed subsequent to the date of this Order.

The Companies have investigated the potential for incorporating renewable energy into the portfolio of supply-side resources reviewed. In addition, renewable energy units which passed the supply-side screening and were considered for the optimal plan included expansion of the Ohio Falls Station and a wind energy conversion of 50 MW. Among the numerous renewable energy technologies considered were options of wind, solar, biomass, geothermal, waste-to-energy, hydroelectric, and energy storage. Further details of the renewable energy options considered in the supply-side screening are provided in the report titled *Analysis of Supply-Side Technology Alternatives* (March 2011) contained in Volume III, Technical Appendix.

Section 1251(13): Administrative Case No. 2007-00300 (Consideration of the Requirements of the Federal Energy Policy Act of 2005 Regarding Fuel Sources and Fossil Fuel Generation Efficiency – Fossil Fuel Generation Efficiency

The Commission does not share the generators' concern that a generation efficiency standard must be not only company-specific but also unit-specific. While the Commission agrees with the premise that generation efficiency needs to be flexible in order to accommodate company-specific and unit-specific circumstances, we believe the requirement to implement a plan as set forth in the proposed standard would allow each generator the flexibility to consider not only the operating characteristics of its generation fleet as a whole but also the specific operating characteristics of each individual generation unit.

As it similarly stated in its fuel source findings, while there is no mandate to adopt a generation efficiency standard, the Commission directs the jurisdictional generators to focus greater research into cost-effective generation efficiency initiatives and to include a full, detailed discussion of such efforts in subsequent IRPs in accordance with Section 8(2)(a).

Generation efficiency and utilization improvements are discussed in Section 8.(2)(a) in Volume I of this Plan.

**Kentucky Utilities Company
and
Louisville Gas and Electric Company**

Analysis of Supply-Side Technology Alternatives

Prepared by

Generation Planning & Analysis

March 2011

**KENTUCKY UTILITIES COMPANY
LOUISVILLE GAS and ELECTRIC COMPANY
ANALYSIS OF
SUPPLY-SIDE TECHNOLOGY ALTERNATIVES**

Table of Contents

| | | |
|------------|--|-----------|
| 1. | <i>EXECUTIVE SUMMARY</i> | 1 |
| 2. | <i>INTRODUCTION</i> | 2 |
| 3. | <i>DATA SOURCES</i> | 3 |
| 4. | <i>TECHNOLOGIES SCREENED</i> | 3 |
| 4.1 | <i>Coal-Fueled Technologies</i> | 3 |
| 4.1.1 | Pulverized Coal | 3 |
| 4.1.2 | Circulating Fluidized Bed | 4 |
| 4.1.3 | Pressurized Fluidized Bed Combustion | 5 |
| 4.1.4 | Integrated Gasification Combined Cycle | 6 |
| 4.1.5 | Coal Technologies with CO ₂ Capture | 7 |
| 4.2 | <i>Natural Gas-Fueled Technologies</i> | 7 |
| 4.2.1 | Spark Ignition Engine | 7 |
| 4.2.2 | Simple Cycle Combustion Turbine | 8 |
| 4.2.3 | Combined Cycle Combustion Turbine | 9 |
| 4.2.4 | Non-conventional Combustion Turbines | 9 |
| 4.2.5 | Microturbines | 11 |
| 4.2.6 | Fuel Cell | 11 |
| 4.3 | <i>Renewable Resource Technologies</i> | 12 |
| 4.3.1 | Wind Energy | 12 |
| 4.3.2 | Solar | 13 |
| 4.3.3 | Biomass | 14 |
| 4.3.4 | Geothermal | 14 |
| 4.3.5 | Hydroelectric | 15 |
| 4.3.6 | Waste to Energy | 15 |
| 4.4 | <i>Energy Storage Technologies</i> | 18 |
| 4.4.1 | Pumped Hydro Energy Storage | 18 |
| 4.4.2 | Compressed Air Energy Storage | 20 |
| 4.5 | <i>Other Technologies</i> | 20 |
| 4.5.1 | Ohio Falls Expansion | 20 |
| 5. | <i>ANALYSIS OVERVIEW</i> | 22 |
| 6. | <i>SENSITIVITY ANALYSIS</i> | 23 |
| 6.1 | <i>Capital Cost</i> | 24 |
| 6.2 | <i>Technology Operating Efficiency</i> | 24 |
| 6.3 | <i>Fuel Cost</i> | 25 |
| 7. | <i>RESULTING SCENARIOS</i> | 25 |

8. **SCREENING ANALYSIS** 25

9. **LEVELIZED SCREENING METHODOLOGY AND RESULTS**..... 27

10. **RECOMMENDATIONS** 31

Appendix A..... 32

1. EXECUTIVE SUMMARY

The Companies performed a detailed screening analysis of supply-side alternatives in order to evaluate, compare, and determine the least cost supply-side technology options to be used in further integrated resource optimization analysis.

The primary source of the data used in this evaluation for mature and developed technologies is the EPRI TAG. The *Cummins and Barnard Generation Options Technology Study* (December 2007) was also consulted to update experimental technologies. The reports provided the following: technology descriptions, detailed capital and O&M cost estimates, and detailed performance and emission results at 59°F (average) at expected operating load for peaking, intermediate and base load options. Other data used in the screening analysis was compiled via contracted studies from MWH Global, Inc.

Fifty-six technology alternatives were screened through a levelized screening analysis in which total costs were calculated for each alternative, at various levels of utilization, over a 30-year period and levelized to reflect uniform payment streams in each year. This method tends to be more forward-looking than other methods since it evaluates the economics of owning and operating a unit over a multi-year period. Levelized costs of each alternative, at varying capacity factors, are then compared and the least-cost technologies for capacity factor increments throughout the planning period are determined. The screening analysis considers three sensitivity variables: capital cost, heat rate, and fuel cost. Environmental costs (emissions) pertaining to NO_x and SO₂ are included in the analysis. The environmental cost implications regarding NO_x and SO₂ emissions are accounted for as a variable cost similar to a fuel adder. However, due to anticipated environmental regulations, allowance price forecasts for NO_x and SO₂ are significantly lower in 2011 through 2013 compared to recent years and then are assumed to be zero after 2013. Since there is no market anticipated for CO₂ emissions allowances, due to currently proposed regulations, no environmental cost has been included for CO₂.

Based on the results of the levelized screening analysis, it is recommended that the technologies listed in Table 1 be retained for further evaluation in the integrated resource optimization analysis.

Table 1
Alternatives for Further Consideration

Supercritical Pulverized Coal Unit - 800 MW
3x1 F-Class Combined Cycle Combustion Turbine
2x1 F-Class Combined Cycle Combustion Turbine
1x1 G-Class Combined Cycle Combustion Turbine
GE 7FA CT Simple Cycle Combustion Turbine
Landfill Gas IC Engine
Wind Energy Conversion
Ohio Falls 50MW Bulb Hydro Unit

2. INTRODUCTION

This study evaluated several supply-side technology costs and performance estimates for currently available and emerging technologies. As part of the IRP process, the Companies evaluate, at a high level, all of the currently available/emerging technologies. A detailed evaluation (using production costing computer models) of all currently available/emerging technologies is impractical due to the large number of possible alternatives and the significant amount of time required for computer simulation if each were modeled individually. The purpose of this study is to reduce the list of possible technology alternatives to a more manageable number. The study was conducted by comparing the levelized cost of building and operating each technology at various levels of utilization. A discussion of the data and a brief description of each generating technology are also presented. This is followed by a description of the levelized screening methodology. Finally, the basis for recommending one technology over another is presented and those technologies suggested for additional computer simulation are identified.

3. DATA SOURCES

EPRI TAG, which is a report funded by the sponsors of EPRI's Program 9, was used to provide technical descriptions for the developed and mature technologies, detailed capital costs, performance expectations, emission rates, and O&M costs for conventional generation alternatives (pulverized coal, simple and combined cycle combustion turbines, wind, solar, advanced coal and combustion turbines, and energy storage systems). A study from HDR Inc. was used for the 2x1 and 1x1 7F-Class and 1x1 G-Class combined cycle combustion turbines technologies. The *Cummins and Barnard Generation Options Technology Study* (December 2007) was the basis for the non-conventional technologies (microturbine, Kalina and Cheng cycle combustion turbine, some combustible renewable energy, and waste-to-energy). Data for non-conventional technologies is less detailed than conventional alternatives due to the lower level of maturity and frequency non-conventional technologies. The Companies' analysis and a study from MWH Global, Inc. regarding expansion of LG&E's Ohio Falls hydro station were also used. All technologies analyzed in the screening process are found in Exhibit 1.

4. TECHNOLOGIES SCREENED

4.1 Coal-Fueled Technologies

4.1.1 Pulverized Coal

Conventional pulverized coal-fired units supply most of the Companies' present generation needs. This mature, well proven, and highly reliable technology is used throughout the utility industry. Typically, coal-fired units have high capital costs, long construction periods (up to 10 years) and are economical for baseload duty. Both subcritical and supercritical units were evaluated, with supercritical units typically being larger plants operating at higher temperatures

and pressures and more efficiently. This evaluation contains four “Greenfield” pulverized coal options, which include two subcritical units 256 MW and 512 MW and two supercritical units 565 MW and 800 MW.

In order to meet state and federal air emissions regulations, all pulverized coal options utilize emissions controls as follows:

- NO_x: Combustion controls (low NO_x burners and overfire air) and SCR.
- Particulate Matter (PM₁₀): Fabric filter.
- Total Mercury (Hg⁰, Hg²⁺, Hg_(p)): Powder Activated Carbon injection, fabric filter and wet limestone FGD.
- SO₂: Wet FGD
- Acid Mist [PM_{2.5} (SO₃/H₂SO₄)]: Wet FGD followed by a wet ESP or Wet FGD with lime injection upstream of a baghouse.

4.1.2 *Circulating Fluidized Bed*

Circulating Fluidized Bed (“CFB”) boiler technology represents a mature and commercial technology for subcritical steam generation up to 340 MW and even higher with the installation of multiple CFB units supplying steam to a single steam turbine generator. CFB technology involves the injection into the boiler of crushed fuel and limestone and/or other inert bed materials which are suspended in a fluidized bed above the furnace floor by combustion air. This combustion air is injected into the furnace by primary air fans through numerous openings in the floor of the furnace. Secondary air is injected at a higher level in the furnace to promote fuel combustion and minimize NO_x formation. It is through the injection of limestone and the fluidized characteristics of the furnace materials that the CFB offers the inherent advantage of in situ SO₂ emissions control. The solid materials within the boiler are circulated through the furnace and cyclone

systems to provide for in-bed sulfur removal and increased residence time in the system for burnout and reaction. The in-bed reaction of the calcium in the limestone can achieve boiler SO₂ removal efficiencies up to 95 percent; however, the addition of a polishing scrubber can increase SO₂ removal efficiencies to as high as 98 percent while reducing sorbent consumption. To date, CFB combustion technology exists primarily with subcritical steam cycles. More effort has been placed on designing and developing supercritical CFB in recent years, however only one unit currently exists commercially. For this analysis, a 2x250 MW subcritical CFB unit was considered.

In order to meet state and federal air emissions regulations, the CFB options utilize emissions controls as follows:

- NO_x: Combustion controls (inherently low combustion temperatures in CFB) and non-selective catalytic reduction (“SNCR”) w/ ammonia injection in the boiler.
- Particulate Matter (PM₁₀): Fabric filters.
- Total Mercury (Hg^o, Hg²⁺, Hg_(p)): CFB w/ a fabric filter.
- SO₂: In furnace limestone injection with a polishing scrubber.
- Acid Mist [PM_{2.5} (SO₃/H₂SO₄)]: In furnace limestone injection with a polishing scrubber and baghouse.

4.1.3 Pressurized Fluidized Bed Combustion

Pressurized Fluidized Bed Combustion (“PFBC”) combined cycle units can be summarized as a standard combined cycle facility with an external combustor for the combustion turbine. The combustor is pressurized and supplied with coal and with combustion air from the combustion turbine compressor. Hot pressurized flue gas from the combustor is used to directly produce steam and is also sent through hot cyclones and supplied to a gas turbine for expansion

and power production. Combustion turbine exhaust gas is then sent through a heat recovery steam generator (“HRSG”) for additional steam production for steam turbine power generation.

Due to the limited commercial deployment of this technology, the complexity of the system, the mixed performance results indicated, and the lack of significantly improved cycle efficiencies and emissions as compared to other technologies, PFBC technology is considered to still be a developmental technology.

In order to meet state and federal air emissions regulations, the 290 MW PFBC combined cycle option in this evaluation utilizes emissions controls as follows:

- NO_x: Ammonia injection in the furnace and a catalyst in the HRSG.
- Particulate Matter (“PM₁₀”) and Mercury: Hot Cyclones prior to the turbine and a baghouse after the HRSG.
- SO₂/Acid Mist: Limestone injection in the furnace.

4.1.4 Integrated Gasification Combined Cycle

Integrated Gasification Combined Cycle (“IGCC”) gasifies coal, producing a raw fuel gas that is cleaned of the majority of flue gas contaminants and sent to a combined cycle power island. The syngas is combusted in one or more gas turbines, which exhaust to multiple HRSGs which produce steam for a conventional steam turbine. With only two commercial-scale IGCC plants on line for over 10 years, significant improvements in efficiency, fuel flexibility and economics will be required to reduce the cost of IGCC. The technology faces higher capital costs as compared to the pulverized coal and CFB technologies as well as historic low availability. Noted advantages to IGCC include the potential to provide a future carbon capture option and reduced water consumption rates as compared to other coal-fired designs.

This analysis considers two IGCC options: a 307 MW 1x1 unit (one combustion turbine with one steam turbine), and a 640 MW 2x1 unit (two combustion turbines with one steam turbine). These options utilize emissions controls as follows:

- NO_x: Combustion controls and nitrogen diluent injection.
- PM₁₀: Gas scrubber.
- H₂S: Carbonyl Sulfide (“COS”) hydrolysis / acid removal
- Mercury: Carbon bed

4.1.5 Coal Technologies with CO₂ Capture

CO₂ capture technology has been evaluated for all of the coal-fired options in this evaluation with plant capacities greater than 250. All of the options have assumed post-combustion monoethanolamine CO₂ capture with the exception of IGCC, in which pre-combustion capture was analyzed. The cost estimates from EPRI TAG for coal units do not include CO₂ sequestration options, so this data was obtained from the Cummins and Barnard report. For sequestration, the captured CO₂ is assumed to be transported to an off-site, underground cavern via an underground pipeline with all capital and monitoring costs included. While cost estimates for sequestration are provided, it should be noted that sequestration technology is still under development. As such, the values in this report should be considered indicative and subject to project specific applications.

4.2 Natural Gas-Fueled Technologies

4.2.1 Spark Ignition Engine

Spark ignition, also known as reciprocating, engines operate on fuels such as natural gas, propane, diesel or waste gases from industrial processes (engines using landfill gas and sewage-

sludge digestion are referenced in Section 4.3.6). A 5 MW natural gas engine has been included in this analysis. While the technology is well proven as a means of backup power, it has not developed into a mature generation technology for base-load operation.

4.2.2 Simple Cycle Combustion Turbine

Simple Cycle Combustion Turbines (“SCCTs”) generate power by compressing ambient air and then heating the pressurized air by injecting and burning natural gas or oil, and forcing the heated gases to expand through a turbine. The turbine drives the air compressor and electrical generator.

SCCTs are commonly used to supply peaking capacity and are commercially proven with key features such as low capital cost, short design and installation schedules, and the availability of various unit sizes. Additionally, SCCTs have positive attributes of rapid startup and the modularity for ease of maintenance. These features, combined with operation over a low range of capacity factors, tend to offset the primary drawback of SCCTs, the higher price relative to coal or oil or natural gas, making the SCCT an economical option for peaking duty but not for baseload or intermediate usage. The screening analysis includes three sizes of simple cycle combustion turbines (43, 84, and 206 MW at 59°F).

4.2.3 *Combined Cycle Combustion Turbine*

Combined Cycle Combustion Turbine (“CCCT”) plants consist of one or more combustion turbine unit(s), HRSGs, and a steam turbine generator. In addition to the SCCT generation process, the hot exhaust gases from combustion turbines are passed through the HRSG to produce high-pressure steam which is then expanded through a steam turbine that turns an electric generator. The exhaust gas heat recovery is cost effective for combustion turbines because the exhaust gas temperatures are very high.

CCCTs are generally chosen as baseload and intermediate generation providers due to their high efficiency, cost effective low emissions technology and relatively fast construction and startups beneficial to supplying base or intermediate load electric power. The key advantages of the CCCTs, when compared with reciprocating engines and SCCTs, are lower NO_x and carbon monoxide (“CO”) emissions, improved efficiency, and potentially greater operating flexibility if duct burners are used. Disadvantages are reduced plant reliability and increased maintenance, increased overall staffing requirements due to added plant complexity, and increased exposure to volatile natural gas prices. Six conventional CCCT configurations were evaluated in this study ranging in capacity from 109 MW to 943 MW at 59°F including a single CT (1x1), a double CT (2x1) and a triple CT (3x1) configuration.

4.2.4 *Non-conventional Combustion Turbines*

Three other advanced combustion turbine technologies (humid air turbine, Kalina Cycle, Cheng Cycle) are also included. These technologies are generally considered developmental, but offer significant potential for efficiency improvements over conventional technologies.

The Humid Air Turbine (“HAT”) utilizes moist air injected into the combustion chamber to generate electric power at a higher efficiency than a comparable combined cycle system. The

Once-through Boiler with Partial Steam Generation design integrates a small HRSG into the simple cycle evaporating only a portion of the boiler feedwater. The steam is then separated in a steam/water separator where a mist eliminator provides steam with about 5 percent entrained droplets to moisturize high-pressure air from a compressor. The air-steam mixture is superheated within the HRSG before being injected into the combustor. A portion of the unevaporated boiler feedwater is blown down to maintain water quality and the remainder is cycled back through the HRSG. The HAT reviewed herein is rated at 366 MW.

The Kalina Cycle combustion turbine involves injecting ammonia into the vapor side of the cycle resulting in higher efficiency compared to a conventional CCCT. The ammonia/water working fluid provides thermodynamic advantages based on non-isothermal boiling and condensing behavior of the dual component fluid, coupled with the ability to alter the ammonia concentration at various points in the cycle. This capability allows more effective heat acquisition, regenerative heat transfer, and heat rejection. The cycle is similar in nature to the combined cycle process except exhaust gas from the combustion turbine enters a heat recovery vapor generator (“HRVG”) and the ammonia/water mixture from the distillation condensation subsystem (“DCSS”) is heated in the HRVG. A portion of the mixture is removed at an intermediate point and is sent to a heat exchanger where it is heated with exhaust from the intermediate-pressure vapor turbine. The moisture returns to the HRVG where it is mixed with the balance of flow, superheated, and expanded in the vapor turbine generator. Additional vapor enters the HRVG from the high-pressure vapor turbine where it is reheated and supplied to the inlet of the intermediate-pressure vapor turbine. The vapor exhausts from the vapor turbine and condenses in the DCSS. The Kalina Cycle combustion turbine contained in this analysis is rated at 282 MW.

The Cheng cycle is characterized by the use of a gas turbine, which is capable of being injected with a large amount of superheated steam. A small HRSG which generates both saturated

as well as superheated steam is typically added at the combustion turbine exhaust to supply this steam in a simple cycle application. Superheated steam from the HRSG is injected into the combustion chamber and expanded through the turbine section producing increased electrical power. The Cheng cycle is most beneficial in a cogeneration plant where varying process steam and electrical power demands are typically experienced. As studied here, the Cheng cycle's greatest advantage in an electric power generation only mode, is that it increases power output and decreases heat rate therefore driving efficiency up compared to a simple cycle unit. The downside of the Cheng cycle is increased plant staffing due to the small HRSG and increased combustion turbine maintenance and increased demineralized water usage due to the injection of steam. The Cheng Cycle combustion turbine contained in this analysis is rated at 140 MW.

4.2.5 Microturbines

Microturbines are similar in concept to the larger SCCTs used as conventional generation alternatives but typically offer output ranges from approximately 20 to 400 kW. Current commercial systems are air cooled and are capable of producing power at approximately 23-33 percent efficiency by employing a recuperator (air-to-air heat exchanger) that transfers exhaust heat to the air flowing into the combustor, thereby reducing the amount of fuel required. With a gaseous fuel source, microturbines can be placed anywhere with extreme ease and prompt installation due to their small size, similar to a refrigerator, and ability to burn various gaseous fuels, such as natural gas, propane and renewable gaseous fuels. Both baseload and peaking microturbines rated 30 kW are considered in this evaluation.

4.2.6 Fuel Cell

Fuel cells electrochemically convert hydrogen-rich fuel, typically natural gas, to direct current ("DC") electricity. Inverters are required to convert the DC power to alternating current ("AC").

Fuel cells are ideal technologies for small distributed power generation due to the high efficiency, low air/noise emissions and limited moving parts. Waste heat can also be effectively used for commercial building heating and cooling. Each cell consists of an anode, cathode, and an electrolyte. Fuel cells oxidize a fuel at the anode, which releases electrons into an electrical circuit. Simultaneously, water and heat are produced at either the anode or cathode depending on the electrolyte used. Fuel cells, unlike batteries, do not consume their electrodes with use, but only consume the fuel and oxygen (in the air) supplied to them. Efficiencies of fuel cells can reach up to 85 percent if the waste heat is recycled. In addition, fuel cells are also considered because of their environmental benefits as the only emissions from natural gas fuel cells are carbon dioxide and water.

There are six major fuel cell types in development: alkaline, polymer electrolyte (also known as proton exchange membrane), direct methanol, phosphoric acid, molten carbonate, and solid oxide. The most mature fuel cell type is the phosphoric acid fuel cell (“PAFC”) however significant reductions in generation cost can be realized with molten carbonate fuel cells (“MCFC”) due to their improved efficiency. Solid oxide fuel cells (“SOFC”) are commercially available for commercial and residential applications. SOFCs are also being used in combination with gas turbines for combined heat and power (“CHP”) systems. A 20 MW MCFC and 25 MW SOFC with a 97 percent capacity factor was considered in this screening analysis.

4.3 Renewable Resource Technologies

4.3.1 Wind Energy

Wind is converted to power via a rotating turbine and generator. Utility-scale wind systems generally consist of multiple wind turbines with capacity factors dependent on the wind profile in the area. The potential for wind power production is rated on a scale of Class 1 to Class

7, with Class 7 representing an area with substantial wind speeds. A general rule to produce wind energy economically is to place wind turbines in a Class 3 or greater region. Most of Kentucky has a wind power class rating of 2 or less, meaning poor wind energy characteristics for wind power generation. Despite this limitation, a 200 MW wind farm was considered for this evaluation.

4.3.2 *Solar*

Solar energy conversion technologies capture the sun's energy and convert it to thermal energy (solar thermal) or electrical energy (solar photovoltaic), which drives the device (turbine, generator, or heat engine) for electrical generation. The advantages of solar technologies include no fuel requirements, no emissions produced, high reliability, and low O&M cost. The main disadvantages of solar technologies are high capital cost, low production capacity, and large amounts of required land.

Solar thermal power systems concentrate sunlight with mirrors or lenses to achieve the high temperatures needed to heat the thermal fluid. Solar thermal technologies currently in use include the following: parabolic trough, parabolic dish, solar chimney, and central receiver. Parabolic trough represents the vast majority of systems installed.

Solar photovoltaic power generation differs from solar thermal technology because it converts solar energy directly to DC electricity by the use of photovoltaic cells. These cells allow photons and electrons to interact with a semi-conductor material (usually silicon). Inverters are then required to convert the DC power to AC.

According to research reported by Cummins & Barnard, the relatively low solar intensity levels experienced in Kentucky result in relatively low capacity factors for solar technologies. Six

solar options were considered in the evaluation with ratings ranging from 1.2 MW to 100 MW and capacity factors between 18 and 65 percent.

4.3.3 Biomass

Biomass refers to using plant-based fuels for energy production typically in a configuration similar to pulverized coal units. Wood products are the primary biomass resource, however agricultural residues and yard wastes are also utilized. Efficiencies of biomass plants are lower when compared to modern coal units due to lower heating values and higher moisture contents in the fuel. The most efficient options for electrical generation from biomass resources include units co-fired with coal, offsetting a portion of the fossil fuel consumption. Biomass fuels present unique challenges when burned in any boiler as compared to coal due to higher moisture, chlorine, and volatile matter content, lower energy content, alkaline ash, and agglomeration of bed ash. The biomass alternatives included in this evaluation are a 514 MW supercritical pulverized coal facility and a 566 MW CFB both co-fired with ten percent biomass fuel by weight. A 100 MW CFBC and a 50 MW wood-fired stoker plant using 100% biomass were also considered. Emissions controls are similar to the coal-only configurations.

4.3.4 Geothermal

Geothermal power plants use heat from the Earth's crust extracted through deep wells to generate steam and drive turbine generators for the production of electricity. Geothermal power is limited to locations where geothermal pressure reserves are found. Most geothermal reserves can be found in the western portion of the United States, but virtually no geothermal resources exist in Kentucky. There are three types of geothermal power conversion systems in common use including dry steam, flash steam, and binary cycle. Binary cycle plants, which utilize a turbine

driven by fluid heated through a non-contact heat exchanger connected to the geothermal resource, could theoretically be implemented in Kentucky with very deep wells but this has not been proven. Therefore, thermal technology was not considered a viable option for Kentucky and was excluded from the screening analysis.

4.3.5 *Hydroelectric*

Hydroelectric power generation is a mature technology that is well understood. The costs and implementation schedules for these types of projects, however, can vary significantly based upon site specifics. The new hydroelectric installation considered here is a run-of-river based design sized for 30 MW of generation capacity at an unidentified Greenfield location. Additionally, expansion at LG&E's existing Ohio Falls Station was screened, and is covered separately under the section titled "***Other Technologies***".

4.3.6 *Waste to Energy*

Waste-to-energy ("WTE") technologies can utilize a variety of waste types to produce electricity. The economics associated with WTE facilities are difficult to determine, as costs are dependent upon waste transportation, processing, and tipping fees for the particular site. Values contained within this analysis are representative of technologies at generic sites.

Municipal Solid Waste

Converting Municipal Solid Waste ("MSW") to energy was developed as a means of reducing the quantity of municipal and agricultural solid wastes with the avoidance of disposal costs being the primary component of determining economic feasibility. Unprocessed refuse is fed to the reciprocating grate in the boiler where it is combusted in a waterwall furnace (mass burning) only after limited processing of the refuse to remove non-combustible and large items.

Other types of mass burning utilize refractory furnaces or rotary kiln furnaces. Smaller units utilize two-stage burning for higher efficiency via controlled-air furnaces. Large MSW facilities process up to 3,000 tons of waste per day. The driving force for MSW projects is the collection of a tipping fee to accept MSW, which must be competitive with the costs of hauling waste to the nearest landfill. Mass burning of MSW is widely believed to be a low cost alternative to other solid fuels, but it is difficult to justify due to environmental concerns over pollutants, high capital costs, poor load following characteristics, and low efficiency. A 7 MW unit with a 75 percent capacity factor requiring 300 to 350 tons per day of waste was considered in this evaluation.

Refuse-Derived Fuel

Refuse-Derived Fuel (“RDF”) is an evolution of MSW technology in which waste is sorted and processed into fluff or pellets that would be purchased as a fuel source by the generating facility. RDF is preferred in many refuse-to-energy applications due to its ability to be combusted with technologies traditionally used for coal. However, capital costs, unit size, capacity factors, and environmental concerns for RDF are similar to MSW characteristics. A 7 MW unit fueled by RDF with a capacity factor of 85 percent was also considered in the evaluation process.

Landfill Gas

Landfill Gas (“LFG”) is a valuable energy source that can be utilized in several applications, including power production, and is considered to be a commercial if not mature WTE technology. LFG is produced by the decomposition of wastes stored in landfills where it is collected and piped from wells, filtered, and then compressed. Although gas is produced when decomposition begins within a landfill, it may be several years before there is an adequate supply of gas to fuel an electric generator. Later, as the site ages, gas production (as well as the quality of the gas) declines to the point at which power generation is no longer economical. In the case of a typical well-engineered and well-operated landfill, gas may be produced for as many as 50 to 100

years, but electricity production may be economically feasible for only 10 to 15 years. Power can be generated via a combustion turbine, but internal combustion engines are most commonly used and, even then, such facilities are generally sized at less than 10 MW. LFG projects are typically co-located at the landfill to minimize gas collection, interconnection, and transmission costs. This evaluation considers a 5 MW unit with a capacity factor of 90 percent.

Sewage Sludge & Anaerobic Digestion

Bio-methane fueled generators from the digestion of sewage sludge or livestock manure is very similar to landfill gas energy projects with respect to the quality of fuel fired and the generation equipment required. For these projects, the installation of an anaerobic digester is typically utilized in which sludge waste is digested by bacteria and the resultant methane gas produced from the process is collected, cleaned, and forwarded to a power generation system. This technology is generally viewed as a “green” technology due to the fact that it prevents the release of greenhouse gases (primarily methane) to the environment and, like other WTE projects, can offset the utilization of other fossil fuels for power generation. An 85 kW unit with a 90 percent capacity factor was considered in this analysis.

Tire-Derived Fuel

Tire-Derived Fuels (“TDFs”) consisting of chipped tires with the steel belts removed are attractive due to the high heating value, low ash and sulfur content, and low fuel cost. The co-firing of up to 10 percent by weight of TDF in a fluidized bed boiler can be considered a commercial technology as there is no significant change in the technology for a dedicated coal unit however there is very limited success with mass firing of TDF. While TDF offers a fuel heating value equivalent to or better than coal, the general lack of availability of TDF is a drawback. The TDF alternative included in this evaluation is a 10 percent TDF co-fired fluidized bed system and is rated at 50 MW with capacity factor of 92 percent.

4.4 Energy Storage Technologies

Energy storage systems are utilized for supplying energy during peak load periods. The energy storage devices must be charged or recharged by equipment utilizing electricity generated by another source. As such, charging is typically accomplished during periods of low demand by electricity with low generation costs. Alternatively, recharging energy can be sourced from renewable energy sources that are intermittent in nature, such as wind or solar. It is assumed that the energy storage options considered in this analysis are charged using power generated from the Companies' coal units. In return, the energy storage system can be dispatched at times of high demand and/or high generation cost. Energy storage technologies typically have very fast startup times, thus making them an ideal source for instant dispatchable power.

For more than two decades, storage batteries (primarily lead-acid), pumped hydro storage, and compressed air storage have been the primary energy storage methods. Of these, pumped hydro storage and compressed air storage have been traditionally used for large utility-scale storage applications because of their large storage and power capabilities. However, due to their high initial costs, to date they have not been economically applied to small renewable energy systems. The economy of scale strongly favors these technologies for large storage applications. Batteries on the other hand are suitable for medium to small applications because they are modular and are produced and deployed in small units.

4.4.1 Pumped Hydro Energy Storage

Pumped Hydro Energy Storage ("PHES") is the oldest and most prevalent of the central station energy storage options and requires a setup similar to conventional hydroelectric facilities. Conventional PHES plants typically use an upper and lower reservoir. Off-peak electrical energy is used to pump water from the lower reservoir to upper reservoir. When the energy is required

during peak hours, the water in the upper reservoir is converted to electricity as the water flows through a turbine to the lower reservoir. Increasingly restrictive environmental regulations and established uses of the river systems in proximity to the Companies may further hamper consideration of this alternative. Finally, high capital costs and extended lead times are significant disadvantages that must be accounted for when considering this alternative.

A 350 MW PHES unit assumed to recover 70 percent of the energy input is considered in this screening analysis. Pumped hydro is considered a viable option to serve intermediate load levels but the low capacity factor (20 percent in this evaluation) makes it difficult for this technology to compete with other peaking technologies.

Advanced Battery Energy Storage Flow batteries are emerging energy storage devices that can serve many purposes in energy delivery systems. They can respond within milliseconds and deliver power for hours. They operate much like a conventional battery, storing and releasing energy through a reversible electrochemical reaction with a large number of charging and discharging cycles. They differ from a conventional battery in two ways 1) the reaction occurs between two electrolytes, rather than between an electrolyte and an electrode and 2) they store the two electrolytes external to the battery and the electrolytes are circulated through the cell stack as required. The great advantage that this system provides is very large electrical storage capacity, the limitation being only the capacity of the electrolyte storage reservoirs.

A battery energy storage system consists of the battery, DC switchgear, AC/DC converter/charger, transformer, AC switchgear, and a building to house the components. During peak power demand periods, the battery system can discharge power to the utility system for approximately 4 to 5 hours and then recharge during non-peak hours. In addition to high initial cost, a battery system will require replacement every 4 to 10 years, depending upon duty cycle. The flow battery storage unit included in this analysis is rated at 100 MW and has a capacity factor

of 20 percent and is assumed to recover 80 percent of the energy input.

4.4.2 Compressed Air Energy Storage

Compressed Air Energy Storage (“CAES”) uses an electric motor-driven compressor to pressurize an underground cavern or reservoir with air during off-peak periods typically with power supplied by low cost base-loaded units. During peak periods, the compressed air is heated and passed through a gas turbine expander to produce electrical power at an attractive heat rate ranging from 3,500 to 5,000 Btu/kWh. CAES facilities provide more electrical power to the grid than is utilized during cavern charging mode because of fuel that is supplied to the system during the energy generation mode. The necessary geology occurs across nearly 75 percent of the United States however the technology lacks the maturity of the other energy storage options due to the limited number of installations in operation. A 350 MW CAES unit with a 25 percent capacity factor was used in this evaluation.

4.5 Other Technologies

4.5.1 Ohio Falls Expansion

A screening-level study has been carried out to investigate potential Ohio Falls Project expansion alternatives. Four “in-river” development alternatives in the space between the existing powerhouse and the Corps spillway gate structure and one development alternative on Shippingport Island, a manmade island near the Falls of the Ohio, have been considered. The specific alternatives investigated are listed in Table 2.

Table 2
Hydro Electric Alternatives
At Ohio Falls

| Alternatives | Capital (\$M) | Incremental Energy (GWh) |
|--|---------------|--------------------------|
| 50 MW Bulb Unit at Shippingport Island* | | 172.2 |
| Hydroelectric - 14 MW Kaplans Units in Bays 9 & 10 | | 101.6 |
| 25 MW Bulb Units in Bays 9 & 10 | | 144.4 |
| 50 MW Kaplan Unit in river | | 144.1 |
| 50 MW Propeller Unit in river | | 123.5 |

**Cost estimate for Shippingport, does not include the time and costs associated with dealing with the significant archaeological resources known to be present at the site.*

The Ohio Falls Station is considered a run-of-the-river facility where river levels and the Army Corps of Engineers control the water flow. Therefore, the energy production of the facility can vary significantly and may not be available at the time of the Companies' peak needs. Cost/performance data for the Ohio Falls options are based on the cost evaluation supplied to the Companies by MWH Global, Inc.

21

5. ANALYSIS OVERVIEW

The Companies' screening analysis consists of 56 generation alternatives developed primarily by using EPRI TAG and Cummins & Barnard Report. The screening process involves utilizing specific unit operating data such as unit ratings, heat rate, operation and maintenance expenses, and capacity factors to estimate lifetime costs associated with owning and operating each technology type and size.

The base analysis includes the relevant fuel costs as well as the costs of SO₂ and NO_x emissions. The specific fuels utilized by each technology evaluated in this analysis are identified in Exhibit 1. Coal units are evaluated as utilizing Eastern bituminous high-sulfur coal. The costs for natural gas units include a firm gas charge of \$0.3104 per MMBtu of gas to guarantee the availability of the fuel supply for these units. This charge is applied either as a peak or baseload charge, depending on the type of unit.

Emissions allowance costs are also included to account for regulations limiting the emission of SO₂ and NO_x from certain generating facilities. However, due to anticipated environmental regulations, allowance price forecasts for NO_x and SO₂ are significantly lower in 2011 through 2013 compared to recent years and then are assumed to be zero after 2013. The emissions allowance costs are calculated by year by multiplying the forecasted market emissions allowance price by the emissions rate. EPRI TAG and Cummins & Barnard Report were used to estimate the expected SO₂ and NO_x emissions rates, as shown in Exhibit 2(a), for all applicable technologies assuming the appropriate emissions controls. The emissions allowance price forecasts used in this analysis are based on market quotes through 2013. The emissions allowance price forecasts are shown in Exhibit 2(b).

Also included in the analysis are tax credits for renewable generation projects. A federal production tax credit in the amount of two cents per kWh is included for wind, and one cent per kWh is included for MSW, RDF, TDF, LFG, sewage sludge, biomass and hydropower projects.

Sensitivities are utilized to provide valuable information on how each technology will perform under various operating conditions. Some of the sensitivities contained in this analysis are based on variations in capital cost, operating efficiency (measured by heat rate), and fuel cost. Each of the previously mentioned sensitivities has three possible scenarios: base, low, and high, which results in 27 sensitivity combinations.

An analysis comparing total levelized costs for all technologies as a function of capacity factor was also performed. This additional level of analytical scrutiny results in 297 (i.e., 27 cases x 11 capacity factor ranges = 297) “opportunities” for each technology to be identified as one of the three least cost options. Total costs are evaluated over a 30-year planning period in all possible case combinations.

Descriptions of the sensitivity analysis, resulting scenarios evaluated, screening analysis, and the levelized analysis are included in the following sections. The final portion of this evaluation includes a presentation of the least-cost, most viable technologies to be considered further in the detailed analysis.

6. SENSITIVITY ANALYSIS

Variances between original cost estimates and actual cost estimates are possible. These differences result from technology ratings (conventional or non-conventional). Conventional technology estimates for construction costs are expected to be more accurate relative to non-conventional alternatives where costs are less certain due to immature technology and uncertainties associated with less frequent utilization and installation. A sensitivity analysis that

addresses several variables with potential to change the perceived benefits of each technology has been incorporated into the screening process. Sensitivities present within the analysis do not include all possible relevant variables; however, the included permutations do provide pertinent information about how a technology performs under several combinations of economic and operating conditions. The variables identified for sensitivity analysis in the screening study are capital cost, technology operating efficiency (measured by heat rate), and fuel cost.

6.1 *Capital Cost*

Based on research and experience from Cummins & Barnard, high and low boundaries for capital costs were provided for each technology, expressed as a percentage to be added or subtracted from the base capital cost to account for cost uncertainty. Generally, the more conventional or commercially mature technologies have a narrower capital cost range compared to more developmental or site-dependent technologies which generally have a wider range. These estimated capital cost ranges were used to assign high and low capital cost scenarios for each technology.

6.2 *Technology Operating Efficiency*

The second sensitivity performed in the screening analysis involved the heat rate associated with each technology, referred to as the base heat rate. Decreasing (or increasing) the base heat rate represents a better (or worse) than expected efficiency of the operating facility over the heat rate expected during the design phase. A ± 5 percent adjustment to the heat rate specified for each technology was utilized where applicable.

6.3 Fuel Cost

The third sensitivity conducted in the screening analysis considers the cost of fuel consumed by each technology. The Companies develop 30-year base fuel forecasts for all fuels that are to be used at existing plants. Sensitivity fuel forecasts are then developed depicting high and low fuel cost scenarios which are used for the technologies that utilize coal and natural gas. For MSW, RDF, LFG, TDF, and biomass, the fuel costs are estimated based on research or data provided by Cummins and Barnard. The fuel costs utilized for each technology screened for the base and sensitivity fuel forecasts and are shown in Exhibit 3.

7. RESULTING SCENARIOS

The sensitivity analysis would not be as inclusive if all combinations of sensitivity variables were not analyzed. In other words, because there are three variables for which a sensitivity analysis is being performed (capital cost, heat rate, fuel cost) and each variable has three possible values (base, low or high), 27 total combinations of sensitivity cases must be evaluated.

Exhibit 2(a) shows the cost (capital, fixed O&M, and variable O&M) and base heat rate information associated with each of the previously described technologies operating at 59°F. All technologies evaluated in this analysis are shown in this exhibit.

8. SCREENING ANALYSIS

The least-cost operation of each of the technologies presented in this study occurs over significantly different capacity factors. Therefore, an analysis that compares the total cost for each

technology as a function of capacity factor is required. As previously discussed, the cost data for all technologies in this analysis originate from EPRI TAG and Cummins & Barnard or were derived based on information and/or cost estimates received by the Companies. All technologies listed in Exhibit 2(a), regardless of viability or technical maturity, were evaluated over a 30-year planning period in all 27 cases.

Several technologies were limited to maximum capacity factors based on design characteristics of the option and their application to the Companies' service territory. The pumped hydro energy storage, battery energy storage, and compressed air energy storage options were limited to 20 to 25 percent capacity factors based on design characteristics of the technologies supplied by Cummins & Barnard.

In general, conditions in Kentucky are not conducive to use solar power generation. This is reflected in the low capacity factors associated with these technologies which ranged from 18 to 65 percent. The six solar technologies (thermal) are expected to perform from 20 percent capacity factor for photovoltaic up to 70 percent capacity factor for a solar chimney. For solar power, most of the installations have been in the western part of the United States where solar radiation levels enable economic installation. For the Midwest, solar radiation levels are not ideal for solar technology. Wind energy was limited to a 30 percent capacity factor due to the generally low wind speeds that are prevalent in Kentucky, with the exception of a small area in eastern Kentucky.

The six hydro options were limited to capacity factors between 30 and 40 percent. These limitations were based on the projected energy received from these run-of-the river projects.

Due to limitations in fuel supply, the MSW, RDF, LFG, and sewage sludge options were limited to capacity factors between 75 and 90 percent. The IGCC units were limited to 85 percent

due to expected outage issues. The peaking microturbine is limited to a 15 percent capacity factor as it would run only during peak periods.

9. LEVELIZED SCREENING METHODOLOGY AND RESULTS

A 30-year levelized cost methodology was utilized in the base analysis. An annual total cost comprised of capital, fixed O&M, variable O&M, fuel and other costs, is determined for each technology over a range of capacity factors from 0 to 100 percent in 10 percent increments. For each technology, levelized costs in \$/kW-yr at varying capacity factors were compared and least-cost technologies at each capacity factor increment were determined. Levelization allows for the cost of each technology to be compared over the 30-year life of each project with different escalation rates and forecasts for the various cost components. A non-levelized analysis considers costs of owning and operating generating units for only a single year. Exhibits 4 and 5 include relevant information, which when utilized in conjunction with Exhibits 2 and 3, allow replication of the results presented here. Exhibit 4 provides a complete source of equations used in the levelization process. Exhibit 5 provides miscellaneous information referred to within the equations of Exhibit 4 in addition to the Adjusted 30-year Levelization Factor (“Adj. L_N ”) for the cost components that are escalated at constant rates such as O&M, capital, and energy storage charging costs. Adjusted L_{NS} for the sum of fuel costs and emissions allowance costs can be determined in a similar manner.

Using the equations of Exhibit 4 and data contained within Exhibits 2(a)-2(b), Exhibit 3, and Exhibit 5, the total 30-year levelized cost (\$/kW-yr in 2010 dollars) of each technology was calculated for each capacity factor increment. The results of this process are shown in pages 1

through 27 of Exhibit 6. Least-cost technologies over all ranges of capacity factors have been identified at the bottom of each case exhibit and are shaded in the tables. Technology capacity factors shown in pages 1 through 27 of Exhibit 6 were limited to the maximum allowed by the technology and/or environment in which they operate as previously discussed. For easy reference, technologies that have been identified as least cost over any range of capacity factors in at least one of the 27 cases have been summarized in Table 3.

Table 3
Least-Costly Technologies
In At-Least One Sensitivity Case

Combined Cycle 3x1 F-Class Combustion Turbine
Supercritical Pulverized Coal Unit, 800 MW
Landfill Gas IC Engine Simple Cycle GE 7FA Combustion Turbine
Wind Energy Conversion
Ohio Falls 50MW Bulb Hydro Unit

Exhibit 7 is a graphical representation of the technologies of these five options with base emissions, which appear as a least-cost generation alternative. The intersection of the lines with the vertical axis represents the fixed costs (carrying charges and fixed O&M) associated with the technology. The slope of the line is a function of the variable costs (fuel and variable O&M).

Identifying not only the least cost technologies, but also the second least cost and even the third least cost further enhances the results of this analysis. First, second, and third least-cost technology identification is justified by the fact that the \$/kW-yr difference between them may be minimal over any increment of capacity factors. The second and third least-cost technologies for at least one capacity factor increment in any of the 27 cases are summarized in Table 4 in order of the total number of times selected.

Table 4
Second and Third Least-Costly Technologies
In At-Least One Sensitivity Case

Combined Cycle 3x1 F-Class Combustion Turbine
Combined Cycle 2x1 F-Class Combustion Turbine
Supercritical Pulverized Coal Unit, 800 MW
Subcritical Pulverized Coal Unit, 500 MW
Combined Cycle 1x1 G-Class Combustion Turbine
Supercritical Pulverized Coal, 565 MW
Landfill Gas IC Engine Simple Cycle GE 7FA Combustion Turbine
Wind Energy Conversion
Kalina Cycle Combined Cycle Combustion Turbine
Ohio Falls 50MW Bulb Hydro Unit

The eleven different technology types and sizes specified between Tables 4 and 5 are those that initially appear to deserve consideration in detailed computer models. However, this list must be examined further before selecting technologies to pass onto the detailed analysis. As previously stated, there are 297 “opportunities” for each technology to be identified as one of the first three least cost options. Table 5, identifies how many occurrences a technology appeared as either first, second, or third least cost options over any capacity factor range. All technologies not identified within Table 5 failed to appear as one of the top three least-cost options in any of the cases identified.

Table 5
The Frequency of Occurrence of Each
Technology as First, Second or Third Least Cost

| <u># Occurrences</u> | | | | <u>Technology Name</u> |
|----------------------|------------|------------|--------------|--|
| <u>1st</u> | <u>2nd</u> | <u>3rd</u> | <u>Total</u> | |
| 131 | 73 | 20 | 224 | Combined Cycle 3x1 F-Class Combustion Turbine |
| 0 | 119 | 77 | 196 | Combined Cycle 2x1 F-Class Combustion Turbine |
| 88 | 27 | 10 | 125 | Supercritical Pulverized Coal Unit - 800 MW |
| 0 | 71 | 18 | 89 | Subcritical Pulverized Coal Unit - 500 MW |
| 0 | 0 | 58 | 58 | Combined Cycle 1x1 G-Class Combustion Turbine |
| 0 | 0 | 60 | 60 | Supercritical Pulverized Coal - 565 MW |
| 31 | 3 | 5 | 39 | Landfill Gas IC Engine |
| 27 | 0 | 7 | 34 | Simple Cycle GE 7FA Combustion Turbine |
| 19 | 4 | 9 | 32 | Wind Energy Conversion |
| 0 | 0 | 30 | 30 | Kalina Cycle Combined Cycle Combustion Turbine |
| 1 | 0 | 3 | 4 | Ohio Falls 50MW Bulb Hydro Unit |

Table 5 shows that the Combined Cycle 3x1 F-Class Combustion Turbine unit was selected 224 times as the first, second, or third least-cost technology while the 50MW Bulb Hydro Unit was selected only 4 times. Table 5 provides a good starting point for further reducing the list of technologies identified in Tables 3 and 4.

A review of Table 5 reveals that three different coal-fired technologies have been identified among the 11 least cost technologies. They are an 800 MW supercritical pulverized coal unit, a 565 MW supercritical pulverized coal unit, and a 500 MW subcritical pulverized coal unit. Of these, only the 800 MW unit ranks first among least cost generation alternatives in any of the sensitivity scenarios and therefore, it is the only coal unit recommended for further analysis.

The simple cycle GE 7FA combustion turbines will be considered for further optimization analysis as it is the only simple cycle configuration among the least cost alternatives. In addition, the combined cycle 3x1 and, 2x1 F-Class combustion turbine configurations and the combined cycle 1x1 G-Class combustion turbine are considered for further optimization analysis. Because the Kalina Cycle CCCT is only in developmental stages and is not commercially available, it is not evaluated further.

Although it only occurred four times, once in first and three times in third place among the least-cost technologies, the expansion of the Ohio Falls hydroelectric station is included for further evaluation. And, while the wind profile for most of Kentucky is not very suitable for power generation, the wind energy conversion option is included for further evaluation for potential opportunities as another renewable alternative.

10. RECOMMENDATIONS

Based on the various analyses discussed above, the technologies listed in Table 6 are recommended for further analysis in the optimization studies using Strategist®, a detailed modeling program. The technologies identified will provide a diverse set of alternatives to be evaluated in production and capital costing computer models. Exhibit 8 is a graphical representation of the least-cost technologies, which will be further evaluated in the Strategist® optimization software modeling.

Table 6
Technologies Suggested for Analysis
Within Strategist®

Supercritical Pulverized Coal Unit - 800 MW
Combined Cycle 3x1 F-Class Combustion Turbine
Combined Cycle 2x1 F-Class Combustion Turbine
Combined Cycle 1x1 G-Class Combustion Turbine
Simple Cycle GE 7FA Combustion Turbine
Landfill Gas IC Engine
Wind Energy Conversion
Ohio Falls 50MW Bulb Hydro Unit

Appendix A

Exhibit 1

**Technologies Analyzed
in the Screening Process**

Technologies Screened

| Tech. ID | Technology Description | Category | Sub-Category | Fuel Type | Source |
|----------|--|-----------------|--------------------------|----------------------|------------------------|
| 1 | Pumped Hydro Energy Storage | Storage | Pumped Hydro | Charging Only | EPRI |
| 2 | Advanced Battery Energy Storage | Storage | Battery | Charging Only | EPRI |
| 3 | Compressed Air Energy Storage | Storage | Compressed Air | Gas and Charging | EPRI |
| 4 | Simple Cycle GE LM6000 CT | Natural Gas | SCCT | Gas | Cummins & Barnard |
| 5 | Simple Cycle GE 7EA CT | Natural Gas | SCCT | Gas | Cummins & Barnard |
| 6 | Simple Cycle GE 7FA CT | Natural Gas | SCCT | Gas | EPRI |
| 7 | Combined Cycle GE 7EA CT | Natural Gas | CCCT | Gas | Cummins & Barnard |
| 8 | Combined Cycle 1x1 7F-Class | Natural Gas | CCCT | Gas | HDR |
| 9 | Combined Cycle 1x1 G-Class CT | Natural Gas | CCCT | Gas | HDR |
| 10 | Combined Cycle 2x1 7F-Class CT | Natural Gas | CCCT | Gas | HDR |
| 11 | Combined Cycle 3x1 7F-Class CT | Natural Gas | CCCT | Gas | HDR/EPRI |
| 12 | Combined Cycle Siemens 5000F CT | Natural Gas | CCCT | Gas | Cummins & Barnard |
| 13 | Humid Air Turbine Cycle CT | Natural Gas | CCCT | Gas | Cummins & Barnard |
| 14 | Kalina Cycle CC CT | Natural Gas | CCCT | Gas | Cummins & Barnard |
| 15 | Cheng Cycle CT | Natural Gas | CCCT | Gas | Cummins & Barnard |
| 16 | Peaking Microturbine | Natural Gas | CT | Gas | Cummins & Barnard |
| 17 | Baseload Microturbine | Natural Gas | CT | Gas | Cummins & Barnard |
| 18 | Subcritical Pulverized Coal - 256 MW | Coal | Pulverized Coal | Coal | Cummins & Barnard |
| 19 | Subcritical Pulverized Coal - 512 MW | Coal | Pulverized Coal | Coal | Cummins & Barnard |
| 20 | Circulating Fluidized Bed - 2x 250 MW | Coal | Fluidized Bed Combustion | Coal | EPRI |
| 21 | Supercritical Pulverized Coal - 565 MW | Coal | Pulverized Coal | Coal | EPRI |
| 22 | Supercritical Pulverized Coal-800 MW | Coal | Pulverized Coal | Coal | EPRI |
| 23 | Pressurized Fluidized Bed Combustion | Coal | Fluidized Bed Combustion | Coal | Cummins & Barnard |
| 24 | 1x1 IGCC | Coal | IGCC | Coal Gasification | Cummins & Barnard |
| 25 | 2x1 IGCC | Coal | IGCC | Coal Gasification | EPRI |
| 26 | Subcritical Pulverized Coal - 502 MW - CCS | Coal | Pulverized Coal | Coal | Cummins & Barnard |
| 27 | Circulating Fluidized Bed - CC | Coal | Fluidized Bed Combustion | Coal | EPRI |
| 28 | Supercritical Pulverized Coal - 565 MW - CCS | Coal | Pulverized Coal | Coal | EPRI |
| 29 | Supercritical Pulverized Coal - 800 MW - CCS | Coal | Pulverized Coal | Coal | EPRI |
| 30 | 1x1 IGCC - CCS | Coal | IGCC | Coal Gasification | Cummins & Barnard |
| 31 | 2x1 IGCC - CC | Coal | IGCC | Coal Gasification | EPRI |
| 32 | Wind Energy Conversion | Renewable | Wind | No Fuel | EPRI |
| 33 | Solar Photovoltaic | Renewable | Solar | No Fuel | EPRI |
| 34 | Solar Thermal, Parabolic Trough | Renewable | Solar | No Fuel | EPRI |
| 35 | Solar Thermal, Power Tower w Storage | Renewable | Solar | No Fuel | EPRI |
| 36 | Solar Thermal, Parabolic Dish | Renewable | Solar | No Fuel | Cummins & Barnard |
| 37 | Solar Thermal, Central Receiver | Renewable | Solar | No Fuel | Cummins & Barnard |
| 38 | Solar Thermal, Solar Chimney | Renewable | Solar | No Fuel | Cummins & Barnard |
| 39 | MSW Mass Burn | Waste To Energy | MSW | MSW | Cummins & Barnard |
| 40 | RDF Stoker-Fired | Waste To Energy | RDF | RDF | Cummins & Barnard |
| 41 | Wood Fired Stoker Plant | Waste To Energy | Bio Mass | Biomass | EPRI |
| 42 | Landfill Gas IC Engine | Waste To Energy | LFG | Landfill Gas | EPRI |
| 43 | TDF Multi-Fuel CFB (10% Co-fire) | Waste To Energy | TDF | 10% TDF / 90% Coal | Cummins & Barnard |
| 44 | Sewage Sludge & Anaerobic Digestion | Waste To Energy | SS | Sewage | Cummins & Barnard |
| 45 | Bio Mass (Co-Fire) | Waste To Energy | Bio Mass | 10% Renew / 90% Coal | EPRI/Cummins & Barnard |
| 46 | Wood-Fired CFBC | Waste To Energy | Fluidized Bed Combustion | Biomass | EPRI |
| 47 | Co-Fired CFBC | Waste To Energy | Fluidized Bed Combustion | 10% Renew / 90% Coal | EPRI |
| 48 | Molten Carbonate Fuel Cell | Natural Gas | Fuel Cell | Gas | EPRI |
| 49 | Solid Oxide Fuel Cell | Natural Gas | Fuel Cell | Gas | EPRI |
| 50 | Spark Ignition Engine | Natural Gas | Reciprocating Engine | Gas | Cummins & Barnard |
| 51 | Hydroelectric - New - 30 MW | Renewable | Hydro | No Fuel | Cummins & Barnard |
| 52 | Hydroelectric - 50 MW Bulb Unit | Renewable | Hydro | No Fuel | MWH |
| 53 | Hydroelectric - 14 MW Kaplans Units | Renewable | Hydro | No Fuel | MWH |
| 54 | Hydroelectric - 25 MW Bulb Units | Renewable | Hydro | No Fuel | MWH |
| 55 | Hydroelectric - 50 MW Kaplan Unit | Renewable | Hydro | No Fuel | MWH |
| 56 | Hydroelectric - 50 MW Propeller Unit | Renewable | Hydro | No Fuel | MWH |

Exhibit 2 (a)

**Cost (Capital, Fixed and Variable
Operation and Maintenance Cost),
Heat Rate and Emission Rates Data**

Heat Rate and Capital Cost Sensitivity Data

| Technology | Rating, MW (60°F) | Heat Rate Data, Btu/kWh | | Technology Installed Cost, \$/kW | | Fixed O&M \$/kW | Variable O&M \$/MWh | AVG LD In/Out | Emissions Rates (lb/mmBtu) | | |
|--|----------------------|-------------------------|--------|----------------------------------|-----|--------------------|------------------------|------------------|----------------------------|-----------------|-----------------|
| | | Base | High | Base | Low | | | | SO ₂ | NO _x | CO ₂ |
| Pumped Hydro Energy Storage | 350 | - | - | - | - | \$5.99 | - | 1.30 | 0 | 0 | 0 |
| Advanced Battery Energy Storage | 100 | - | - | - | - | \$14.97 | - | 1.20 | 0 | 0 | 0 |
| Compressed Air Energy Storage | 350 | 3,970 | 4,169 | 3,772 | 0 | \$30.89 | \$1.92 | 1.12 | 0.001 | 0.050 | 118 |
| Simple Cycle GE LM6000 CT | 43 | 9,214 | 9,675 | 8,753 | 0 | \$19.75 | \$2.49 | - | 0.001 | 0.050 | 118 |
| Simple Cycle GE 7EA CT | 84 | 11,740 | 12,327 | 11,153 | 0 | \$15.04 | \$25.42 | - | 0.001 | 0.030 | 118 |
| Simple Cycle GE 7FA CT | 206 | 8,848 | 10,340 | 9,356 | 0 | \$4.67 | \$15.12 | - | 0.001 | 0.018 | 117 |
| Combined Cycle GE 7EA CT | 109 | 8,093 | 8,498 | 7,688 | 0 | \$36.23 | \$6.00 | - | 0.001 | 0.007 | 118 |
| Combined Cycle GE 7FA CT | 314 | 6,777 | 7,116 | 6,438 | 0 | \$10.90 | \$4.56 | - | 0.001 | 0.016 | 117 |
| Combined Cycle 1X 7E Class | 406 | 6,725 | 7,081 | 6,389 | 0 | \$7.93 | \$4.23 | - | 0.001 | 0.016 | 117 |
| Combined Cycle 2X 7E Class | 629 | 6,768 | 7,105 | 6,430 | 0 | \$6.30 | \$3.99 | - | 0.001 | 0.016 | 117 |
| Combined Cycle 2X 7F Class | 943 | 6,753 | 7,091 | 6,415 | 0 | \$4.73 | \$3.96 | - | 0.001 | 0.016 | 117 |
| Combined Cycle Siemens 5000F CT | 251 | 7,085 | 7,439 | 6,731 | 0 | \$16.89 | \$6.20 | - | 0.001 | 0.007 | 118 |
| Humid Air Turbine Cycle CT | 365 | 10,355 | 10,873 | 9,837 | 0 | \$16.12 | \$4.95 | - | 0.001 | 0.018 | 118 |
| Kalina Cycle CC CT | 282 | 6,348 | 6,665 | 6,030 | 0 | \$16.12 | \$2.36 | - | 0.001 | 0.007 | 118 |
| Peaking Microturbine | 140 | 7,270 | 7,634 | 6,907 | 0 | \$4.97 | \$4.97 | - | 0.001 | 0.024 | 118 |
| Baseload Microturbine | 0 | 14,561 | 15,289 | 13,833 | 0 | \$157.12 | \$6.88 | - | 0.001 | 0.018 | 118 |
| Subcritical Pulverized Coal - 256 MW | 256 | 9,287 | 9,752 | 8,823 | 0 | \$74.43 | \$2.82 | - | 0.090 | 0.050 | 197 |
| Subcritical Pulverized Coal - 512 MW | 512 | 10,155 | 10,619 | 9,647 | 0 | \$53.25 | \$6.33 | - | 0.119 | 0.050 | 200 |
| Circulating Fluidized Bed - 2x 250 MW | 500 | 9,066 | 9,519 | 8,613 | 0 | \$53.62 | \$4.40 | - | 0.180 | 0.070 | 216 |
| Supercritical Pulverized Coal - 565 MW | 565 | 9,036 | 9,488 | 8,594 | 0 | \$46.06 | \$3.70 | - | 0.180 | 0.070 | 216 |
| Supercritical Pulverized Coal-800 MW | 800 | 9,048 | 9,501 | 8,596 | 0 | \$73.04 | \$2.80 | - | 0.120 | 0.050 | 197 |
| Precipitated Fluidized Bed Combustion | 290 | 8,456 | 8,879 | 8,033 | 0 | \$54.83 | \$2.67 | - | 0.050 | 0.050 | 197 |
| 1X IGCC - CC | 640 | 8,889 | 9,333 | 8,445 | 0 | \$78.93 | \$1.22 | - | 0.180 | 0.070 | 216 |
| 2X IGCC | 502 | 12,906 | 13,551 | 12,261 | 0 | \$70.23 | \$5.08 | - | 0.190 | 0.050 | 20 |
| Subcritical Pulverized Coal - 502 MW - CCS | 502 | 14,010 | 14,711 | 13,310 | 0 | \$91.23 | \$7.15 | - | 0.180 | 0.050 | 22 |
| Circulating Fluidized Bed - CC | 565 | 12,800 | 13,440 | 12,160 | 0 | \$75.42 | \$6.22 | - | 0.180 | 0.070 | 22 |
| Supercritical Pulverized Coal - 565 MW - CCS | 800 | 9,036 | 9,488 | 8,594 | 0 | \$62.82 | \$6.00 | - | 0.180 | 0.070 | 22 |
| Supercritical Pulverized Coal - 800 MW - CCS | 800 | 10,069 | 10,572 | 9,566 | 0 | \$68.86 | \$3.37 | - | 0.050 | 0.050 | 20 |
| 1X IGCC - CCS | 270 | 10,463 | 10,966 | 9,940 | 0 | \$87.33 | \$1.23 | - | 0.024 | 0.010 | 22 |
| 2X IGCC - CC | 556 | - | - | - | - | \$11.07 | \$7.37 | - | 0 | 0 | 0 |
| Wind Energy Conversion | 200 | - | - | - | - | \$30.48 | \$0.00 | - | 0 | 0 | 0 |
| Solar Photovoltaic | 25 | - | - | - | - | \$64.41 | \$0.00 | - | 0 | 0 | 0 |
| Solar Thermal, Parabolic Trough | 100 | - | - | - | - | \$64.41 | \$0.53 | - | 0 | 0 | 0 |
| Solar Thermal, Power Tower w Storage | 100 | - | - | - | - | \$64.15 | \$0.01 | - | 0 | 0 | 0 |
| Solar Thermal, Parabolic Dish | 1 | - | - | - | - | \$127.17 | \$0.80 | - | 0 | 0 | 0 |
| Solar Thermal, Central Receiver | 50 | - | - | - | - | \$73.78 | \$0.01 | - | 0 | 0 | 0 |
| Solar Thermal, Solar Chimney | 50 | - | - | - | - | \$590.49 | \$39.54 | - | 0.060 | 0.150 | 215 |
| MSW Mass Burn | 7 | 19,160 | 20,118 | 18,202 | 0 | \$489.98 | \$12.40 | - | 0.060 | 0.150 | 219 |
| RFV Stoker-Fired | 7 | 15,588 | 17,386 | 15,730 | 0 | \$131.06 | \$3.93 | - | 0.000 | 0.100 | 218 |
| Wood Fired Stoker Plant | 5 | 13,325 | 13,991 | 12,659 | 0 | \$60.96 | \$16.80 | - | 0.000 | 0.033 | 187 |
| Landfill Gas IC Engines | 5 | 9,500 | 9,975 | 9,025 | 0 | \$103.63 | \$3.14 | - | 0.090 | 0.050 | 196 |
| TDF Multi-Fuel CFB (10% Co-fue) | 30 | 10,669 | 11,203 | 10,136 | 0 | \$228.37 | \$1.19 | - | 0.000 | 0.210 | 181 |
| Sewage Sludge & Anaerobic Digestion | 0 | 9,900 | 10,395 | 9,405 | 0 | \$66.81 | \$2.12 | - | 0.000 | 0.050 | 198 |
| Bio Mass (Co-Fire) | 574 | 9,251 | 9,713 | 8,785 | 0 | \$91.54 | \$1.21 | - | 0.000 | 0.030 | 208 |
| Co-Fired CFBC | 100 | 11,570 | 12,149 | 10,992 | 0 | \$9.36 | \$7.94 | - | 0.000 | 0.010 | 130 |
| Co-Fired CFBC | 566 | 14,120 | 14,826 | 13,414 | 0 | \$14.04 | \$0.05 | - | 0.000 | 0.010 | 130 |
| Molten Carbonate Fuel Cell | 20 | 5,460 | 5,733 | 5,187 | 0 | \$180.84 | \$0.00 | - | 0.002 | 0.210 | 118 |
| Solid Oxide Fuel Cell | 25 | 6,370 | 6,689 | 6,052 | 0 | \$41.85 | \$0.00 | - | 0 | 0 | 0 |
| Spark Ignition Engine | 5 | 9,492 | 9,967 | 9,017 | 0 | \$14.67 | \$0.00 | - | 0 | 0 | 0 |
| Hydroelectric - New - 30 MW | 30 | - | - | - | - | \$9.66 | \$0.00 | - | 0 | 0 | 0 |
| Hydroelectric - 50 MW Bulb Unit | 50 | - | - | - | - | \$12.30 | \$0.00 | - | 0 | 0 | 0 |
| Hydroelectric - 14 MW Kaplan Units | 28 | - | - | - | - | \$0.00 | \$0.00 | - | 0 | 0 | 0 |
| Hydroelectric - 25 MW Bulb Units | 50 | - | - | - | - | \$12.28 | \$0.00 | - | 0 | 0 | 0 |
| Hydroelectric - 50 MW Kaplan Unit | 50 | - | - | - | - | \$10.52 | \$0.00 | - | 0 | 0 | 0 |
| Hydroelectric - 50 MW Propeller Unit | 50 | - | - | - | - | \$0.00 | \$0.00 | - | 0 | 0 | 0 |

Exhibit 2 (b)

Exhibit 2 (b)
Emissions Allowance Prices

Emissions Allowance Prices

| | SO ₂ \$/ton | NO _x \$/ton | CO ₂ \$/ton |
|--------------|------------------------|------------------------|------------------------|
| 2010 | 19 | 460 | 0 |
| 2011 | 30 | 340 | 0 |
| 2012 | 10 | 100 | 0 |
| 2013 | 10 | 50 | 0 |
| 2014+ | 0 | 0 | 0 |

Example calculation of SO₂ adder:

(NO_x and CO₂ adders are calculated similarly)

Using Supercritical Pulverized Coal Unit - , 800 MW

SO₂ Emission Rate = 0.18 lb SO₂ / MMBtu

2010 SO₂ \$/Ton = \$19

$$\begin{aligned}
 \text{2010 SCPC} & \quad \frac{0.18\#SO_2}{\text{MMBtu}} \quad * \quad \frac{19 \$}{\text{Ton } SO_2} \quad * \quad \frac{100 \text{ Cents}}{\$} \quad * \quad \frac{1 \text{ ton } SO_2}{2000 \#} \\
 \text{SO}_2 \text{ Cost Adder} & = \\
 & = \quad 0.2 \quad \text{cents/MMBtu}
 \end{aligned}$$

Exhibit 3
Fuel Forecast for Screening Analysis

CONFIDENTIAL INFORMATION

**Fuel Forecast
for Screening Analysis**
(Cents/MBtu)

| | Base Fuel Costs | | | | | Low Fuel Costs | | | | | High Fuel Costs | | | | | | | | | | | | | | | |
|------|-----------------|-----|----------------|-----|-----|----------------|--------------|------------------|------|-----|-----------------|-----|-----|-----|--------------|------------------|------|-----|----------------|-----|-----|-----|--------------|------------------|--|--|
| | Coal | Gas | MSW Tip Fee | RDF | LFG | TDF | Bio- Mass | Coal Bio-Mass | Coal | Gas | MSW Tip Fee | RDF | LFG | TDF | Bio- Mass | Coal Bio-Mass | Coal | Gas | MSW Tip Fee | RDF | LFG | TDF | Bio- Mass | Coal Bio-Mass | | |
| 2010 | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 2011 | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 2012 | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 2013 | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 2014 | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 2015 | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 2016 | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 2017 | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 2018 | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 2019 | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 2020 | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 2021 | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 2022 | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 2023 | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 2024 | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 2025 | | | | | | | | | | | | | | | | | | | | | | | | | | |

Exhibit 4
Levelization Equations

LEVELIZATION EQUATIONS USED IN TECHNOLOGY SCREENING

The total levelized cost of a particular technology in a specific year at a specific capacity factor is comprised of (at most) five separate components. The five possible components are levelized capital cost, levelized fixed cost, levelized variable cost, levelized fuel cost and levelized charging cost. The actual components utilized in calculating total levelized cost vary from technology to technology. For example, some technologies may exclude the charging component while others exclude the fuel component. Basically, technologies fall into four categories: Those that...

- I. Burn fuel only (i.e. Pulverized Coal, Gas Turbine)
- II. Burn no fuel and utilize no "grid" energy (i.e. Solar, Wind)
- III. Burn no fuel but utilize "grid" energy for charging (i.e. Battery, Pumped Hydro)
- IV. Burn fuel during generation and utilize "grid" energy for charging (i.e. CAES)

A levelization factor (L_n) converts a series of payments that are made over "n" periods and subject to a constant apparent escalation rate into an equivalent levelized payment stream and is calculated as follows:

$$L_n = \frac{k(1-k^n)}{a_n(1-k)}$$

$$n = \text{number of years} = 30$$

$$k = \frac{1 + e_a}{1 + i}$$

e_a = apparent esc rate including inflation and real escalation (i.e., VO&M = 2.0%). See Exhibit 5.

$$a_n = \frac{(1+i)^n - 1}{i(1+i)^n}$$

i = Discount Rate = Present Value Rate = 7.14%

$$\text{Adj } L_n = L_n / (1 + e_a)$$

The screening analysis utilizes the Adj. L_n . The Adj. L_n makes adjustments for beginning/ending year dollars to be consistent with the Companies' economic analysis methods. An Adj. L_n is calculated for the fixed, variable, fuel and charging costs only. The capital cost component does not utilize an Adj. L_n for levelization because it is levelized through a Fixed Charge Rate (FCR).

Definition of Variables:

| Variable | = | Definition (Units) | Source |
|------------------|---|---|---------------------------|
| Year | = | Levelized Year - Base Year | Exhibit 5 |
| Inst Cost | = | Installed Cost or Total Generic Unit Cost (\$/kW) | Exhibit 3 |
| FCR% | = | Fixed Charge Rate (%) | Exhibit 5 |
| Cap Esc% | = | Capital Escalation Rate (%) | Exhibit 5 |
| FO&M | = | Fixed O&M (\$/kW) | Exhibit 3 |
| VO&M | = | Variable O&M (\$/MWh) | Exhibit 3 |
| Fix Esc | = | Fixed O&M Escalation Rate (%) | Exhibit 5 |
| Var Esc | = | Variable O&M Escalation Rate (%) | Exhibit 5 |
| Fix Adj L_n | = | Fixed O&M Levelization Factor | Exhibit 5 |
| Var Adj L_n | = | Variable O&M Levelization Factor | Exhibit 5 |
| Fuel Adj L_n | = | Fuel Cost Levelization Factor | Base Fuel Only; Exhibit 5 |
| Charge Adj L_n | = | Charging Cost Levelization Factor | Exhibit 5 |
| CF% | = | Capacity Factor (%) | 0-100 % |
| MW | = | Size of Technology (MW) | Exhibit 2 (a) |
| HR | = | Heat Rate (Btu/KWh) | Exhibit 2 (a) |
| FC | = | Fuel Cost (\$/MMBtu) | Exhibit 3 |
| Avg Ld IO | = | Average Load (kWh In/kWh Out) | Exhibit 2 (a) |
| Charge | = | Charging Cost (\$/MWh) | Exhibit 5 |
| SO ₂ | = | SO ₂ Adder (Cents/MMBtu) | Exhibit 2(b) |
| NO _x | = | NO _x Adder (Cents/MMBtu) | Exhibit 2(b) |
| CO ₂ | = | CO ₂ Adder (Cents/MMBtu) | Exhibit 2(b) |

Cost Components of Technologies that:

1. Burn Fuel Only

$$Capital = Inst\ Cost \times FCR\% \times (1 + Cap\ Esc\%)^{Year}$$

$$Fixed = FO \& M \times (1 + Fix\ Esc\%)^{Year} \times Fix\ Adj\ L_n$$

$$Variable = \frac{(VO \& M) \times (1 + Var\ Esc\%)^{Year} \times CF\% \times 8760\ Hrs/Year \times MW}{MW \times 1000\ KW/MW} \times Var\ Adj\ L_n$$

$$Fuel = \frac{MW \times 1000\ KW/MW \times 8760\ Hrs/Year \times CF\% \times HR \times (FC + SO_2 + NO_x + CO_2)}{MW \times 1000\ KW/MW \times (10)^6\ BTU/MBTU} \times Fuel\ Adj\ L_n$$

2. Burn No Fuel and No Charging Energy

Use Capital, Fixed and Variable Equations from above.

3. Burn No Fuel but Utilize Charging Energy

Use Capital, Fixed and Variable Equations from above and Charging.

$$Charging = \frac{Avg\ Ld\ IO \times Charge \times MW \times 8760\ Hrs/Year \times CF\%}{MW \times 1000\ KW/MW} \times Charge\ Adj\ L_n$$

4. Burn Fuel and Utilize Charging Energy

Use Capital, Fixed, Variable, Fuel and Charging equations from above.

Exhibit 5

**Adjusted L_n , Fixed
Charge Rates, Escalation Rates
and Other Miscellaneous**

Adjusted L_n and Other Miscellaneous Data

(All Fuel prices are in Cents/MBtu)

| | 2.00% F O&M | 2.00% V O&M | 2.50% Capital | 6.71% WACC |
|---|------------------|----------------|------------------|---------------|
| | Escalation Rates | k | L_n | Adj L_n |
| Fuel | | | | |
| Coal | 2.14% | 0.9572 | 1.2787 | 1.2519 |
| Gas | 3.66% | 0.9714 | 1.5451 | 1.4905 |
| Charging | 2.00% | 0.9559 | 1.2572 | 1.2325 |
| MSW | 2.00% | 0.9559 | 1.2572 | 1.2325 |
| RDF | 2.00% | 0.9559 | 1.2572 | 1.2325 |
| LFG | 3.66% | 0.9714 | 1.5451 | 1.4905 |
| Coal+TDF | 2.14% | 0.9572 | 1.2787 | 1.2519 |
| Sewage | 2.00% | 0.9559 | 1.2572 | 1.2325 |
| Biomass | 2.00% | 0.9559 | 1.2572 | 1.2325 |
| Coal+Bio Mass | 2.00% | 0.9559 | 1.2572 | 1.2325 |
| Emissions | | | | |
| Annual NOx | 0.00% | 0.9371 | 1.0000 | 1.0000 |
| Ozone Nox | 0.00% | 0.9371 | 1.0000 | 1.0000 |
| SO2 | 0.00% | 0.9371 | 1.0000 | 1.0000 |
| CO2 | 0.00% | 0.9371 | 1.0000 | 1.0000 |
| Renewables Production Tax Credit | | | | |
| Assume to continue | Yes | | | |
| Tax Credit Period (Years) | 10 | | | |
| Levelized period (years) | 30 | | | |
| Inflation rate (%) | 2.00% | | | |

Fixed Charge Rates by Technology

| | |
|-------------------|-------|
| Coal | 9.00% |
| Simple Cycle CT | 9.62% |
| Combined Cycle CT | 9.01% |
| Other | 9.54% |

Exhibit 6
30-Year Levelized Cost
for All Technologies over
All Capacity Factors

Levelized Dollars at Various Capacity Factors With SO2 Adders, without CO2 Adders, and with NOx Adders

| Technology | 2010 (\$/kW yr) | | | | | | | | | | |
|--|-----------------|------------|------------|------------|------------|------------|------------|------------|------------|------------|------------|
| | 0% | 10% | 20% | 30% | 40% | 50% | 60% | 70% | 80% | 90% | 100% |
| Pumped Hydro Energy Storage | 186 | 227 | 268 | --- | --- | --- | --- | --- | --- | --- | --- |
| Advanced Battery Energy Storage | 156 | 204 | 252 | --- | --- | --- | --- | --- | --- | --- | --- |
| Compressed Air Energy Storage | 145 | 208 | 271 | --- | --- | --- | --- | --- | --- | --- | --- |
| Simple Cycle GE LM6000 CT | 142 | 239 | 337 | 435 | 532 | 630 | 728 | 825 | 923 | 1021 | 1119 |
| Simple Cycle GE 7EA CT | 115 | 234 | 352 | 470 | 588 | 707 | 825 | 943 | 1061 | 1179 | 1298 |
| Simple Cycle GE 7FA CT | 95 | 188 | 280 | 373 | 465 | 558 | 650 | 743 | 835 | 928 | 1020 |
| Combined Cycle GE 7EA CT | 209 | 278 | 347 | 416 | 485 | 554 | 623 | 692 | 761 | 830 | 899 |
| Combined Cycle 1x1 7F-Class | 149 | 206 | 264 | 321 | 378 | 436 | 493 | 550 | 608 | 665 | 722 |
| Combined Cycle 1x1 G-Class CT | 127 | 184 | 240 | 297 | 354 | 410 | 467 | 523 | 580 | 636 | 693 |
| Combined Cycle 2x1 7F-Class CT | 109 | 165 | 222 | 279 | 335 | 392 | 448 | 505 | 562 | 618 | 675 |
| Combined Cycle 3x1 7F-Class CT | 102 | 158 | 215 | 271 | 328 | 384 | 441 | 497 | 554 | 610 | 667 |
| Combined Cycle Siemens 5000F CT | 150 | 211 | 271 | 332 | 392 | 452 | 513 | 573 | 634 | 694 | 754 |
| Humid Air Turbine Cycle CT | 138 | 223 | 309 | 394 | 480 | 565 | 650 | 736 | 821 | 907 | 992 |
| Kalina Cycle CC CT | 147 | 199 | 251 | 302 | 354 | 405 | 457 | 509 | 560 | 612 | 664 |
| Cheng Cycle CT | 153 | 214 | 276 | 337 | 399 | 461 | 522 | 584 | 645 | 707 | 768 |
| Peaking Microturbine | 446 | 596 | 746 | 896 | 1046 | 1196 | 1346 | 1496 | 1646 | 1797 | 1947 |
| Baseload Microturbine | 477 | 597 | 717 | 837 | 957 | 1077 | 1197 | 1317 | 1437 | 1557 | 1677 |
| Subcritical Pulverized Coal - 256 MW | 358 | 384 | 410 | 436 | 462 | 488 | 514 | 540 | 566 | 592 | 618 |
| Subcritical Pulverized Coal - 512 MW | 319 | 345 | 370 | 396 | 422 | 448 | 473 | 499 | 525 | 551 | 576 |
| Circulating Fluidized Bed - 2x 250 MW | 294 | 326 | 358 | 390 | 422 | 454 | 486 | 518 | 550 | 582 | 614 |
| Supercritical Pulverized Coal - 565 MW | 324 | 352 | 379 | 406 | 433 | 460 | 488 | 515 | 542 | 569 | 596 |
| Supercritical Pulverized Coal-800 MW | 284 | 310 | 336 | 363 | 389 | 415 | 442 | 468 | 494 | 521 | 547 |
| Pressurized Fluidized Bed Combustion | 367 | 392 | 418 | 443 | 469 | 494 | 520 | 545 | 570 | --- | --- |
| 1x1 IGCC | 358 | 382 | 406 | 430 | 454 | 477 | 501 | 525 | 549 | --- | --- |
| 2x1 IGCC | 399 | 422 | 445 | 469 | 492 | 515 | 539 | 562 | 585 | --- | --- |
| Subcritical Pulverized Coal - 502 MW - CCS | 561 | 598 | 636 | 673 | 710 | 748 | 785 | 823 | 860 | 898 | 935 |
| Circulating Fluidized Bed - CC | 502 | 544 | 587 | 629 | 671 | 714 | 756 | 799 | 841 | 883 | 926 |
| Supercritical Pulverized Coal - 565 MW - CCS | 471 | 512 | 552 | 593 | 633 | 674 | 715 | 755 | 796 | 836 | 877 |
| Supercritical Pulverized Coal - 800 MW - CCS | 413 | 444 | 475 | 506 | 537 | 568 | 599 | 630 | 661 | 692 | 723 |
| 1x1 IGCC - CCS | 510 | 538 | 567 | 595 | 624 | 653 | 681 | 710 | 738 | --- | --- |
| 2x1 IGCC - CC | 459 | 486 | 513 | 540 | 568 | 595 | 622 | 649 | 676 | --- | --- |
| Wind Energy Conversion | 257 | 254 | 251 | 248 | --- | --- | --- | --- | --- | --- | --- |
| Solar Photovoltaic | 580 | 580 | --- | --- | --- | --- | --- | --- | --- | --- | --- |
| Solar Thermal, Parabolic Trough | 655 | 656 | --- | --- | --- | --- | --- | --- | --- | --- | --- |
| Solar Thermal, Power Tower w Storage | 829 | 829 | 830 | 830 | --- | --- | --- | --- | --- | --- | --- |
| Solar Thermal, Parabolic Dish | 764 | 764 | --- | --- | --- | --- | --- | --- | --- | --- | --- |
| Solar Thermal, Central Receiver | 808 | 809 | 810 | 811 | 812 | 812 | 813 | --- | --- | --- | --- |
| Solar Thermal, Solar Chimney | 673 | 673 | 673 | 673 | --- | --- | --- | --- | --- | --- | --- |
| MSW Mass Burn | 1809 | 1773 | 1738 | 1702 | 1667 | 1631 | 1596 | 1560 | --- | --- | --- |
| RDF Stoker-Fired | 1723 | 1808 | 1894 | 1979 | 2064 | 2149 | 2235 | 2320 | 2405 | --- | --- |
| Wood Fired Stoker Plant | 493 | 526 | 559 | 592 | 624 | 657 | 690 | 723 | 755 | --- | --- |
| Landfill Gas IC Engine | 275 | 321 | 367 | 412 | 458 | 504 | 549 | 595 | 640 | 686 | --- |
| TDF Multi-Fuel CFB (10% Co-fire) | 514 | 544 | 573 | 602 | 631 | 660 | 690 | 719 | 748 | 777 | 806 |
| Sewage Sludge & Anaerobic Digestion | 735 | 730 | 725 | 720 | 714 | 709 | 704 | 698 | 693 | 688 | --- |
| Bio Mass (Co-Fire) | 387 | 410 | 433 | 456 | 479 | 503 | 526 | 549 | 572 | 595 | 619 |
| Wood-Fired CFBC | 506 | 532 | 558 | 585 | 611 | 637 | 664 | 690 | 716 | 743 | 769 |
| Co-Fired CFBC | 620 | 666 | 713 | 760 | 806 | 853 | 900 | 946 | 993 | 1039 | 1086 |
| Molten Carbonate Fuel Cell | 267 | 318 | 369 | 420 | 470 | 521 | 572 | 623 | 674 | 724 | --- |
| Solid Oxide Fuel Cell | 172 | 222 | 271 | 320 | 370 | 419 | 468 | 518 | 567 | 616 | --- |
| Spark Ignition Engine | 425 | 498 | 572 | 645 | 719 | 792 | 865 | 939 | 1012 | 1086 | --- |
| Hydroelectric - New - 30 MW | 493 | 487 | 482 | 476 | 471 | --- | --- | --- | --- | --- | --- |
| Hydroelectric - 50 MW Bulb Unit | 434 | 428 | 423 | 418 | 412 | --- | --- | --- | --- | --- | --- |
| Hydroelectric - 25 MW Bulb Units | 566 | 560 | 555 | 550 | 544 | --- | --- | --- | --- | --- | --- |
| Hydroelectric - 50 MW Kaplan Unit | 532 | 526 | 521 | 516 | 510 | --- | --- | --- | --- | --- | --- |
| Hydroelectric - 50 MW Propeller Unit | 503 | 498 | 492 | 487 | 481 | --- | --- | --- | --- | --- | --- |
| Minimum Levelized \$/kW | 95 | 158 | 215 | 248 | 328 | 384 | 441 | 468 | 494 | 521 | 547 |

Levelized Dollars at Various Capacity Factors With SO2 Adders, without CO2 Adders, and with NOx Adders

| Technology | Capacity Factors | | | | | | | | | | |
|--|------------------|------|------|------|------|------|------|------|------|------|------|
| | 0% | 10% | 20% | 30% | 40% | 50% | 60% | 70% | 80% | 90% | 100% |
| Pumped Hydro Energy Storage | 168 | 206 | 244 | --- | --- | --- | --- | --- | --- | --- | --- |
| Advanced Battery Energy Storage | 141 | 186 | 230 | --- | --- | --- | --- | --- | --- | --- | --- |
| Compressed Air Energy Storage | 135 | 190 | 245 | --- | --- | --- | --- | --- | --- | --- | --- |
| Simple Cycle GE LM6000 CT | 130 | 218 | 305 | 393 | 480 | 567 | 655 | 742 | 829 | 917 | 1004 |
| Simple Cycle GE 7EA CT | 106 | 211 | 317 | 422 | 527 | 632 | 737 | 842 | 947 | 1052 | 1157 |
| Simple Cycle GE 7FA CT | 87 | 169 | 250 | 331 | 413 | 494 | 576 | 657 | 739 | 820 | 901 |
| Combined Cycle GE 7EA CT | 193 | 253 | 313 | 373 | 433 | 493 | 553 | 613 | 673 | 733 | 793 |
| Combined Cycle 1x1 7F-Class | 136 | 186 | 236 | 286 | 335 | 385 | 435 | 484 | 534 | 584 | 634 |
| Combined Cycle 1x1 G-Class CT | 116 | 165 | 214 | 263 | 312 | 361 | 410 | 459 | 508 | 558 | 607 |
| Combined Cycle 2x1 7F-Class CT | 99 | 148 | 197 | 246 | 295 | 345 | 394 | 443 | 492 | 541 | 590 |
| Combined Cycle 3x1 7F-Class CT | 93 | 142 | 191 | 240 | 289 | 338 | 387 | 436 | 484 | 533 | 582 |
| Combined Cycle Siemens 5000F CT | 139 | 191 | 244 | 296 | 348 | 401 | 453 | 506 | 558 | 611 | 663 |
| Humid Air Turbine Cycle CT | 127 | 201 | 275 | 348 | 422 | 496 | 570 | 644 | 717 | 791 | 865 |
| Kalina Cycle CC CT | 136 | 180 | 225 | 269 | 314 | 358 | 403 | 447 | 492 | 536 | 581 |
| Cheng Cycle CT | 140 | 194 | 247 | 301 | 354 | 408 | 461 | 514 | 568 | 621 | 675 |
| Peaking Microturbine | 422 | 556 | 689 | 823 | 957 | 1090 | 1224 | 1358 | 1492 | 1625 | 1759 |
| Baseload Microturbine | 451 | 555 | 658 | 762 | 866 | 969 | 1073 | 1177 | 1281 | 1384 | 1488 |
| Subcritical Pulverized Coal - 256 MW | 331 | 354 | 377 | 399 | 422 | 445 | 468 | 490 | 513 | 536 | 558 |
| Subcritical Pulverized Coal - 512 MW | 295 | 317 | 340 | 362 | 384 | 407 | 429 | 452 | 474 | 497 | 519 |
| Circulating Fluidized Bed - 2x 250 MW | 271 | 299 | 328 | 356 | 384 | 413 | 441 | 470 | 498 | 526 | 555 |
| Supercritical Pulverized Coal - 565 MW | 299 | 322 | 346 | 370 | 394 | 418 | 442 | 466 | 490 | 514 | 538 |
| Supercritical Pulverized Coal-800 MW | 261 | 284 | 307 | 330 | 353 | 376 | 400 | 423 | 446 | 469 | 492 |
| Pressurized Fluidized Bed Combustion | 325 | 348 | 370 | 392 | 414 | 436 | 459 | 481 | 503 | --- | --- |
| 1x1 IGCC | 329 | 350 | 371 | 392 | 412 | 433 | 454 | 475 | 496 | --- | --- |
| 2x1 IGCC | 368 | 389 | 409 | 429 | 449 | 469 | 489 | 509 | 530 | --- | --- |
| Subcritical Pulverized Coal - 502 MW - CCS | 513 | 546 | 579 | 612 | 645 | 677 | 710 | 743 | 776 | 809 | 841 |
| Circulating Fluidized Bed - CC | 463 | 500 | 538 | 575 | 612 | 650 | 687 | 725 | 762 | 799 | 837 |
| Supercritical Pulverized Coal - 565 MW - CCS | 452 | 488 | 524 | 560 | 596 | 632 | 668 | 704 | 740 | 776 | 812 |
| Supercritical Pulverized Coal - 800 MW - CCS | 396 | 424 | 452 | 480 | 507 | 535 | 563 | 591 | 618 | 646 | 674 |
| 1x1 IGCC - CCS | 488 | 513 | 538 | 563 | 588 | 613 | 638 | 663 | 688 | --- | --- |
| 2x1 IGCC - CC | 441 | 464 | 488 | 511 | 535 | 558 | 582 | 605 | 629 | --- | --- |
| Wind Energy Conversion | 232 | 229 | 227 | 224 | --- | --- | --- | --- | --- | --- | --- |
| Solar Photovoltaic | 472 | 472 | --- | --- | --- | --- | --- | --- | --- | --- | --- |
| Solar Thermal, Parabolic Trough | 540 | 541 | --- | --- | --- | --- | --- | --- | --- | --- | --- |
| Solar Thermal, Power Tower w Storage | 679 | 679 | 680 | 681 | --- | --- | --- | --- | --- | --- | --- |
| Solar Thermal, Parabolic Dish | 627 | 627 | --- | --- | --- | --- | --- | --- | --- | --- | --- |
| Solar Thermal, Central Receiver | 678 | 679 | 680 | 680 | 681 | 682 | 683 | --- | --- | --- | --- |
| Solar Thermal, Solar Chimney | 557 | 557 | 557 | 557 | --- | --- | --- | --- | --- | --- | --- |
| MSW Mass Burn | 1701 | 1676 | 1651 | 1626 | 1601 | 1576 | 1551 | 1526 | --- | --- | --- |
| RDF Stoker-Fired | 1555 | 1629 | 1703 | 1777 | 1851 | 1926 | 2000 | 2074 | 2148 | --- | --- |
| Wood Fired Stoker Plant | 444 | 471 | 499 | 527 | 555 | 583 | 611 | 638 | 666 | --- | --- |
| Landfill Gas IC Engine | 245 | 267 | 290 | 312 | 334 | 356 | 378 | 400 | 422 | 445 | --- |
| TDF Multi-Fuel CFB (10% Co-fire) | 476 | 501 | 527 | 552 | 577 | 603 | 628 | 654 | 679 | 704 | 730 |
| Sewage Sludge & Anaerobic Digestion | 667 | 662 | 657 | 651 | 646 | 641 | 636 | 630 | 625 | 620 | --- |
| Bio Mass (Co-Fire) | 356 | 376 | 396 | 416 | 436 | 456 | 476 | 496 | 516 | 536 | 556 |
| Wood-Fired CFBC | 466 | 488 | 510 | 532 | 554 | 576 | 598 | 620 | 642 | 664 | 687 |
| Co-Fired CFBC | 569 | 611 | 653 | 694 | 736 | 778 | 820 | 861 | 903 | 945 | 987 |
| Molten Carbonate Fuel Cell | 219 | 263 | 308 | 353 | 397 | 442 | 487 | 531 | 576 | 621 | --- |
| Solid Oxide Fuel Cell | 198 | 240 | 282 | 325 | 367 | 409 | 451 | 493 | 535 | 578 | --- |
| Spark Ignition Engine | 406 | 469 | 532 | 595 | 657 | 720 | 783 | 846 | 908 | 971 | --- |
| Hydroelectric - New - 30 MW | 426 | 421 | 416 | 410 | 405 | --- | --- | --- | --- | --- | --- |
| Hydroelectric - 50 MW Bulb Unit | 371 | 366 | 361 | 355 | 350 | --- | --- | --- | --- | --- | --- |
| Hydroelectric - 25 MW Bulb Units | 483 | 478 | 472 | 467 | 462 | --- | --- | --- | --- | --- | --- |
| Hydroelectric - 50 MW Kaplan Unit | 454 | 449 | 443 | 438 | 433 | --- | --- | --- | --- | --- | --- |
| Hydroelectric - 50 MW Propeller Unit | 429 | 424 | 419 | 413 | 408 | --- | --- | --- | --- | --- | --- |
| Minimum Levelized \$/kW | 87 | 142 | 191 | 224 | 289 | 338 | 378 | 400 | 422 | 445 | 492 |

Levelized Dollars at Various Capacity Factors With SO2 Adders, without CO2 Adders, and with NOx Adders

| Technology | 2010 (\$/kW yr) | | | | | | | | | | |
|--|-----------------|------------|------------|------------|------------|------------|------------|------------|------------|------------|------------|
| | 0% | 10% | 20% | 30% | 40% | 50% | 60% | 70% | 80% | 90% | 100% |
| Pumped Hydro Energy Storage | 166 | 209 | 250 | --- | --- | --- | --- | --- | --- | --- | --- |
| Advanced Battery Energy Storage | 141 | 189 | 237 | --- | --- | --- | --- | --- | --- | --- | --- |
| Compressed Air Energy Storage | 135 | 196 | 257 | --- | --- | --- | --- | --- | --- | --- | --- |
| Simple Cycle GE LM6000 CT | 130 | 225 | 319 | 413 | 507 | 601 | 695 | 789 | 884 | 978 | 1072 |
| Simple Cycle GE 7EA CT | 106 | 220 | 334 | 448 | 561 | 675 | 789 | 902 | 1016 | 1130 | 1243 |
| Simple Cycle GE 7FA CT | 87 | 176 | 264 | 353 | 442 | 530 | 619 | 708 | 796 | 885 | 974 |
| Combined Cycle GE 7EA CT | 193 | 259 | 325 | 391 | 457 | 523 | 589 | 655 | 721 | 787 | 853 |
| Combined Cycle 1x1 7F-Class | 136 | 191 | 246 | 300 | 355 | 410 | 465 | 519 | 574 | 629 | 683 |
| Combined Cycle 1x1 G-Class CT | 116 | 170 | 224 | 278 | 332 | 386 | 440 | 494 | 548 | 602 | 656 |
| Combined Cycle 2x1 7F-Class CT | 99 | 153 | 207 | 261 | 315 | 369 | 423 | 477 | 532 | 586 | 640 |
| Combined Cycle 3x1 7F-Class CT | 93 | 147 | 201 | 255 | 309 | 362 | 416 | 470 | 524 | 578 | 632 |
| Combined Cycle Siemens 5000F CT | 139 | 196 | 254 | 312 | 369 | 427 | 485 | 542 | 600 | 658 | 715 |
| Humid Air Turbine Cycle CT | 127 | 208 | 290 | 371 | 453 | 534 | 616 | 697 | 778 | 860 | 941 |
| Kalina Cycle CC CT | 136 | 185 | 234 | 283 | 332 | 381 | 431 | 480 | 529 | 578 | 627 |
| Cheng Cycle CT | 140 | 199 | 258 | 317 | 375 | 434 | 493 | 552 | 611 | 669 | 728 |
| Peaking Microturbine | 422 | 566 | 711 | 855 | 1000 | 1144 | 1288 | 1433 | 1577 | 1722 | 1866 |
| Baseload Microturbine | 451 | 565 | 680 | 794 | 908 | 1023 | 1137 | 1252 | 1366 | 1481 | 1595 |
| Subcritical Pulverized Coal - 256 MW | 331 | 356 | 381 | 406 | 431 | 456 | 481 | 506 | 530 | 555 | 580 |
| Subcritical Pulverized Coal - 512 MW | 295 | 319 | 344 | 368 | 393 | 418 | 442 | 467 | 492 | 516 | 541 |
| Circulating Fluidized Bed - 2x 250 MW | 271 | 302 | 333 | 363 | 394 | 425 | 456 | 486 | 517 | 548 | 578 |
| Supercritical Pulverized Coal - 565 MW | 299 | 325 | 351 | 377 | 403 | 429 | 455 | 481 | 507 | 533 | 559 |
| Supercritical Pulverized Coal-800 MW | 261 | 286 | 311 | 337 | 362 | 387 | 412 | 438 | 463 | 488 | 513 |
| Pressurized Fluidized Bed Combustion | 325 | 350 | 374 | 398 | 423 | 447 | 471 | 496 | 520 | --- | --- |
| 1x1 IGCC | 329 | 352 | 375 | 398 | 420 | 443 | 466 | 489 | 511 | --- | --- |
| 2x1 IGCC | 368 | 391 | 413 | 435 | 457 | 480 | 502 | 524 | 546 | --- | --- |
| Subcritical Pulverized Coal - 502 MW - CCS | 513 | 549 | 585 | 621 | 657 | 693 | 728 | 764 | 800 | 836 | 872 |
| Circulating Fluidized Bed - CC | 463 | 503 | 544 | 585 | 626 | 666 | 707 | 748 | 788 | 829 | 870 |
| Supercritical Pulverized Coal - 565 MW - CCS | 452 | 491 | 530 | 569 | 608 | 647 | 686 | 725 | 764 | 803 | 842 |
| Supercritical Pulverized Coal - 800 MW - CCS | 396 | 426 | 456 | 486 | 516 | 546 | 576 | 606 | 635 | 665 | 695 |
| 1x1 IGCC - CCS | 488 | 516 | 543 | 570 | 598 | 625 | 652 | 680 | 707 | --- | --- |
| 2x1 IGCC - CC | 441 | 467 | 493 | 519 | 545 | 571 | 597 | 623 | 649 | --- | --- |
| Wind Energy Conversion | 232 | 229 | 227 | 224 | --- | --- | --- | --- | --- | --- | --- |
| Solar Photovoltaic | 472 | 472 | --- | --- | --- | --- | --- | --- | --- | --- | --- |
| Solar Thermal, Parabolic Trough | 540 | 541 | --- | --- | --- | --- | --- | --- | --- | --- | --- |
| Solar Thermal, Power Tower w Storage | 679 | 679 | 680 | 681 | --- | --- | --- | --- | --- | --- | --- |
| Solar Thermal, Parabolic Dish | 627 | 627 | --- | --- | --- | --- | --- | --- | --- | --- | --- |
| Solar Thermal, Central Receiver | 678 | 679 | 680 | 680 | 681 | 682 | 683 | --- | --- | --- | --- |
| Solar Thermal, Solar Chimney | 557 | 557 | 557 | 557 | --- | --- | --- | --- | --- | --- | --- |
| MSW Mass Burn | 1701 | 1669 | 1637 | 1605 | 1573 | 1542 | 1510 | 1478 | --- | --- | --- |
| RDF Stoker-Fired | 1555 | 1637 | 1718 | 1799 | 1881 | 1962 | 2044 | 2125 | 2206 | --- | --- |
| Wood Fired Stoker Plant | 444 | 475 | 506 | 537 | 568 | 599 | 630 | 661 | 692 | --- | --- |
| Landfill Gas IC Engine | 245 | 289 | 333 | 377 | 421 | 465 | 509 | 553 | 597 | 641 | --- |
| TDF Multi-Fuel CFB (10% Co-fire) | 476 | 504 | 531 | 559 | 587 | 615 | 643 | 671 | 699 | 727 | 755 |
| Sewage Sludge & Anaerobic Digestion | 667 | 662 | 657 | 651 | 646 | 641 | 636 | 630 | 625 | 620 | --- |
| Bio Mass (Co-Fire) | 356 | 378 | 400 | 422 | 445 | 467 | 489 | 511 | 533 | 555 | 577 |
| Wood-Fired CFBC | 466 | 491 | 516 | 540 | 565 | 590 | 615 | 640 | 665 | 690 | 714 |
| Co-Fired CFBC | 569 | 614 | 659 | 704 | 749 | 794 | 839 | 884 | 929 | 974 | 1019 |
| Molten Carbonate Fuel Cell | 219 | 267 | 316 | 365 | 413 | 462 | 511 | 559 | 608 | 657 | --- |
| Solid Oxide Fuel Cell | 198 | 245 | 292 | 339 | 385 | 432 | 479 | 526 | 573 | 620 | --- |
| Spark Ignition Engine | 406 | 476 | 546 | 616 | 685 | 755 | 825 | 894 | 964 | 1034 | --- |
| Hydroelectric - New - 30 MW | 426 | 421 | 416 | 410 | 405 | --- | --- | --- | --- | --- | --- |
| Hydroelectric - 50 MW Bulb Unit | 371 | 366 | 361 | 355 | 350 | --- | --- | --- | --- | --- | --- |
| Hydroelectric - 25 MW Bulb Units | 483 | 478 | 472 | 467 | 462 | --- | --- | --- | --- | --- | --- |
| Hydroelectric - 50 MW Kaplan Unit | 454 | 449 | 443 | 438 | 433 | --- | --- | --- | --- | --- | --- |
| Hydroelectric - 50 MW Propeller Unit | 429 | 424 | 419 | 413 | 408 | --- | --- | --- | --- | --- | --- |
| Minimum Levelized \$/kW | 87 | 147 | 201 | 224 | 309 | 362 | 412 | 438 | 463 | 488 | 513 |

Levelized Dollars at Various Capacity Factors With SO2 Adders, without CO2 Adders, and with NOx Adders

| Technology | 2010 (\$/kW yr) | | | | | | | | | | |
|--|-----------------|------------|------------|------------|------------|------------|------------|------------|------------|------------|------------|
| | 0% | 10% | 20% | 30% | 40% | 50% | 60% | 70% | 80% | 90% | 100% |
| Pumped Hydro Energy Storage | 168 | 213 | 257 | --- | --- | --- | --- | --- | --- | --- | --- |
| Advanced Battery Energy Storage | 141 | 192 | 243 | --- | --- | --- | --- | --- | --- | --- | --- |
| Compressed Air Energy Storage | 135 | 202 | 269 | --- | --- | --- | --- | --- | --- | --- | --- |
| Simple Cycle GE LM6000 CT | 130 | 231 | 332 | 433 | 534 | 635 | 736 | 837 | 938 | 1039 | 1140 |
| Simple Cycle GE 7EA CT | 106 | 229 | 351 | 473 | 596 | 718 | 840 | 963 | 1085 | 1207 | 1330 |
| Simple Cycle GE 7FA CT | 67 | 183 | 279 | 375 | 471 | 567 | 663 | 758 | 854 | 950 | 1046 |
| Combined Cycle GE 7EA CT | 193 | 265 | 337 | 409 | 481 | 553 | 625 | 697 | 768 | 840 | 912 |
| Combined Cycle 1x1 7F-Class | 136 | 196 | 256 | 315 | 375 | 435 | 494 | 554 | 614 | 674 | 733 |
| Combined Cycle 1x1 G-Class CT | 116 | 175 | 234 | 293 | 352 | 411 | 470 | 529 | 588 | 646 | 705 |
| Combined Cycle 2x1 7F-Class CT | 99 | 158 | 217 | 276 | 335 | 394 | 453 | 512 | 571 | 630 | 689 |
| Combined Cycle 3x1 7F-Class CT | 93 | 152 | 211 | 270 | 328 | 387 | 446 | 505 | 564 | 623 | 682 |
| Combined Cycle Siemens 5000F CT | 139 | 201 | 264 | 327 | 390 | 453 | 516 | 579 | 642 | 704 | 767 |
| Humid Air Turbine Cycle CT | 127 | 216 | 305 | 394 | 483 | 572 | 661 | 750 | 839 | 928 | 1017 |
| Kalina Cycle CC CT | 136 | 189 | 243 | 297 | 351 | 405 | 459 | 512 | 566 | 620 | 674 |
| Cheng Cycle CT | 140 | 204 | 269 | 333 | 397 | 461 | 525 | 589 | 653 | 717 | 782 |
| Peaking Microturbine | 422 | 577 | 732 | 887 | 1042 | 1197 | 1353 | 1508 | 1663 | 1818 | 1973 |
| Baseload Microturbine | 451 | 576 | 701 | 826 | 951 | 1076 | 1201 | 1327 | 1452 | 1577 | 1702 |
| Subcritical Pulverized Coal - 256 MW | 331 | 358 | 385 | 413 | 440 | 467 | 494 | 521 | 548 | 575 | 602 |
| Subcritical Pulverized Coal - 512 MW | 295 | 321 | 348 | 375 | 402 | 428 | 455 | 482 | 509 | 536 | 562 |
| Circulating Fluidized Bed - 2x 250 MW | 271 | 304 | 337 | 370 | 404 | 437 | 470 | 503 | 536 | 569 | 602 |
| Supercritical Pulverized Coal - 565 MW | 299 | 327 | 355 | 383 | 411 | 440 | 468 | 496 | 524 | 552 | 581 |
| Supercritical Pulverized Coal-800 MW | 261 | 288 | 316 | 343 | 370 | 398 | 425 | 452 | 480 | 507 | 535 |
| Pressurized Fluidized Bed Combustion | 325 | 352 | 378 | 405 | 431 | 458 | 484 | 511 | 537 | --- | --- |
| 1x1 IGCC | 329 | 354 | 379 | 403 | 428 | 453 | 478 | 503 | 527 | --- | --- |
| 2x1 IGCC | 368 | 393 | 417 | 441 | 466 | 490 | 514 | 539 | 563 | --- | --- |
| Subcritical Pulverized Coal - 502 MW - CCS | 513 | 552 | 591 | 630 | 669 | 708 | 747 | 785 | 824 | 863 | 902 |
| Circulating Fluidized Bed - CC | 463 | 507 | 551 | 595 | 639 | 683 | 727 | 771 | 815 | 859 | 903 |
| Supercritical Pulverized Coal - 565 MW - CCS | 452 | 494 | 536 | 578 | 620 | 662 | 704 | 746 | 788 | 830 | 872 |
| Supercritical Pulverized Coal - 800 MW - CCS | 396 | 428 | 460 | 492 | 524 | 556 | 588 | 620 | 652 | 684 | 716 |
| 1x1 IGCC - CCS | 488 | 518 | 548 | 578 | 607 | 637 | 667 | 696 | 726 | --- | --- |
| 2x1 IGCC - CC | 441 | 469 | 498 | 526 | 555 | 583 | 611 | 640 | 668 | --- | --- |
| Wind Energy Conversion | 232 | 229 | 227 | 224 | --- | --- | --- | --- | --- | --- | --- |
| Solar Photovoltaic | 472 | 472 | --- | --- | --- | --- | --- | --- | --- | --- | --- |
| Solar Thermal, Parabolic Trough | 540 | 541 | --- | --- | --- | --- | --- | --- | --- | --- | --- |
| Solar Thermal, Power Tower w Storage | 679 | 679 | 680 | 681 | --- | --- | --- | --- | --- | --- | --- |
| Solar Thermal, Parabolic Dish | 627 | 627 | --- | --- | --- | --- | --- | --- | --- | --- | --- |
| Solar Thermal, Central Receiver | 678 | 679 | 680 | 680 | 681 | 682 | 683 | --- | --- | --- | --- |
| Solar Thermal, Solar Chimney | 557 | 557 | 557 | 557 | --- | --- | --- | --- | --- | --- | --- |
| MSW Mass Burn | 1701 | 1662 | 1623 | 1585 | 1546 | 1507 | 1468 | 1429 | --- | --- | --- |
| RDF Stoker-Fired | 1555 | 1644 | 1733 | 1821 | 1910 | 1999 | 2088 | 2176 | 2265 | --- | --- |
| Wood Fired Stoker Plant | 444 | 478 | 512 | 546 | 581 | 615 | 649 | 684 | 718 | --- | --- |
| Landfill Gas IC Engine | 245 | 320 | 394 | 469 | 543 | 618 | 692 | 767 | 841 | 916 | --- |
| TDF Multi-Fuel CFB (10% Co-fire) | 476 | 506 | 536 | 567 | 597 | 628 | 658 | 688 | 719 | 749 | 779 |
| Sewage Sludge & Anaerobic Digestion | 667 | 662 | 657 | 651 | 646 | 641 | 636 | 630 | 625 | 620 | --- |
| Bio Mass (Co-Fire) | 356 | 380 | 405 | 429 | 453 | 477 | 501 | 525 | 550 | 574 | 598 |
| Wood-Fired CFBC | 466 | 494 | 521 | 549 | 576 | 604 | 632 | 659 | 687 | 715 | 742 |
| Co-Fired CFBC | 569 | 617 | 665 | 713 | 762 | 810 | 858 | 906 | 954 | 1002 | 1050 |
| Molten Carbonate Fuel Cell | 219 | 271 | 324 | 377 | 429 | 482 | 535 | 587 | 640 | 693 | --- |
| Solid Oxide Fuel Cell | 198 | 250 | 301 | 353 | 404 | 456 | 507 | 559 | 610 | 662 | --- |
| Spark Ignition Engine | 406 | 483 | 560 | 636 | 713 | 790 | 867 | 943 | 1020 | 1097 | --- |
| Hydroelectric - New - 30 MW | 426 | 421 | 416 | 410 | 405 | --- | --- | --- | --- | --- | --- |
| Hydroelectric - 50 MW Bulb Unit | 371 | 366 | 361 | 355 | 350 | --- | --- | --- | --- | --- | --- |
| Hydroelectric - 25 MW Bulb Units | 483 | 478 | 472 | 467 | 462 | --- | --- | --- | --- | --- | --- |
| Hydroelectric - 50 MW Kaplan Unit | 454 | 449 | 443 | 438 | 433 | --- | --- | --- | --- | --- | --- |
| Hydroelectric - 50 MW Propeller Unit | 429 | 424 | 419 | 413 | 408 | --- | --- | --- | --- | --- | --- |
| Minimum Levelized \$/kW | 87 | 152 | 211 | 224 | 328 | 387 | 425 | 452 | 480 | 507 | 535 |

Levelized Dollars at Various Capacity Factors With SO2 Adders, without CO2 Adders, and with NOx Adders

Capital Cost-Low
Heat Rate - Base
Fuel Forecast-Low

2010 (\$/kW yr)

| Technology | Capacity Factors | | | | | | | | | | |
|--|------------------|------|------|------|------|------|------|------|------|------|------|
| | 0% | 10% | 20% | 30% | 40% | 50% | 60% | 70% | 80% | 90% | 100% |
| Pumped Hydro Energy Storage | 168 | 206 | 244 | --- | --- | --- | --- | --- | --- | --- | --- |
| Advanced Battery Energy Storage | 141 | 186 | 230 | --- | --- | --- | --- | --- | --- | --- | --- |
| Compressed Air Energy Storage | 135 | 191 | 248 | --- | --- | --- | --- | --- | --- | --- | --- |
| Simple Cycle GE LM6000 CT | 131 | 222 | 312 | 403 | 493 | 584 | 675 | 765 | 856 | 946 | 1037 |
| Simple Cycle GE 7EA CT | 107 | 216 | 326 | 435 | 544 | 653 | 762 | 871 | 980 | 1090 | 1199 |
| Simple Cycle GE 7FA CT | 88 | 173 | 257 | 342 | 427 | 512 | 597 | 682 | 767 | 852 | 936 |
| Combined Cycle GE 7EA CT | 194 | 257 | 320 | 383 | 446 | 508 | 571 | 634 | 697 | 760 | 823 |
| Combined Cycle 1x1 7F-Class | 137 | 189 | 241 | 293 | 345 | 398 | 450 | 502 | 554 | 606 | 658 |
| Combined Cycle 1x1 G-Class CT | 117 | 168 | 220 | 271 | 322 | 374 | 425 | 477 | 528 | 579 | 631 |
| Combined Cycle 2x1 7F-Class CT | 100 | 151 | 203 | 254 | 306 | 357 | 409 | 460 | 511 | 563 | 614 |
| Combined Cycle 3x1 7F-Class CT | 94 | 145 | 196 | 248 | 299 | 350 | 402 | 453 | 504 | 555 | 607 |
| Combined Cycle Siemens 5000F CT | 140 | 195 | 250 | 305 | 359 | 414 | 469 | 524 | 579 | 634 | 689 |
| Humid Air Turbine Cycle CT | 129 | 206 | 284 | 361 | 438 | 516 | 593 | 671 | 748 | 825 | 903 |
| Kalina Cycle CC CT | 137 | 183 | 230 | 277 | 324 | 370 | 417 | 464 | 510 | 557 | 604 |
| Cheng Cycle CT | 142 | 198 | 253 | 309 | 365 | 421 | 477 | 533 | 589 | 645 | 701 |
| Peaking Microturbine | 423 | 562 | 700 | 839 | 978 | 1117 | 1256 | 1394 | 1533 | 1672 | 1811 |
| Baseload Microturbine | 453 | 562 | 671 | 780 | 888 | 997 | 1106 | 1215 | 1324 | 1432 | 1541 |
| Subcritical Pulverized Coal - 256 MW | 331 | 355 | 379 | 403 | 426 | 450 | 474 | 498 | 521 | 545 | 569 |
| Subcritical Pulverized Coal - 512 MW | 295 | 318 | 342 | 365 | 389 | 412 | 435 | 459 | 482 | 506 | 529 |
| Circulating Fluidized Bed - 2x 250 MW | 271 | 301 | 330 | 360 | 389 | 418 | 448 | 477 | 507 | 536 | 566 |
| Supercritical Pulverized Coal - 565 MW | 299 | 323 | 348 | 373 | 398 | 423 | 448 | 473 | 498 | 523 | 548 |
| Supercritical Pulverized Coal-800 MW | 261 | 285 | 309 | 333 | 357 | 382 | 406 | 430 | 454 | 478 | 502 |
| Pressurized Fluidized Bed Combustion | 325 | 349 | 372 | 395 | 418 | 441 | 465 | 488 | 511 | --- | --- |
| 1x1 IGCC | 329 | 351 | 373 | 394 | 416 | 438 | 460 | 481 | 503 | --- | --- |
| 2x1 IGCC | 368 | 390 | 411 | 432 | 453 | 474 | 495 | 516 | 537 | --- | --- |
| Subcritical Pulverized Coal - 502 MW - CCS | 513 | 548 | 582 | 616 | 650 | 685 | 719 | 753 | 787 | 822 | 856 |
| Circulating Fluidized Bed - CC | 463 | 502 | 541 | 580 | 619 | 658 | 696 | 735 | 774 | 813 | 852 |
| Supercritical Pulverized Coal - 565 MW - CCS | 452 | 490 | 527 | 564 | 602 | 639 | 677 | 714 | 752 | 789 | 826 |
| Supercritical Pulverized Coal - 800 MW - CCS | 396 | 425 | 454 | 483 | 511 | 540 | 569 | 598 | 626 | 655 | 684 |
| 1x1 IGCC - CCS | 488 | 515 | 541 | 567 | 593 | 619 | 645 | 671 | 697 | --- | --- |
| 2x1 IGCC - CC | 441 | 466 | 490 | 515 | 540 | 564 | 589 | 614 | 638 | --- | --- |
| Wind Energy Conversion | 232 | 229 | 227 | 224 | --- | --- | --- | --- | --- | --- | --- |
| Solar Photovoltaic | 472 | 472 | --- | --- | --- | --- | --- | --- | --- | --- | --- |
| Solar Thermal, Parabolic Trough | 540 | 541 | --- | --- | --- | --- | --- | --- | --- | --- | --- |
| Solar Thermal, Power Tower w Storage | 679 | 679 | 680 | 681 | --- | --- | --- | --- | --- | --- | --- |
| Solar Thermal, Parabolic Dish | 627 | 627 | --- | --- | --- | --- | --- | --- | --- | --- | --- |
| Solar Thermal, Central Receiver | 678 | 679 | 680 | 680 | 681 | 682 | 683 | --- | --- | --- | --- |
| Solar Thermal, Solar Chimney | 557 | 557 | 557 | 557 | --- | --- | --- | --- | --- | --- | --- |
| MSW Mass Burn | 1701 | 1673 | 1644 | 1616 | 1588 | 1560 | 1532 | 1503 | --- | --- | --- |
| RDF Stoker-Fired | 1555 | 1633 | 1710 | 1788 | 1865 | 1943 | 2020 | 2098 | 2175 | --- | --- |
| Wood Fired Stoker Plant | 444 | 473 | 502 | 532 | 561 | 590 | 620 | 649 | 678 | --- | --- |
| Landfill Gas IC Engine | 245 | 268 | 291 | 313 | 336 | 359 | 381 | 404 | 427 | 449 | --- |
| TDF Multi-Fuel CFB (10% Co-fire) | 476 | 502 | 529 | 555 | 582 | 609 | 635 | 662 | 688 | 715 | 742 |
| Sewage Sludge & Anaerobic Digestion | 667 | 662 | 657 | 651 | 646 | 641 | 636 | 630 | 625 | 620 | --- |
| Bio Mass (Co-Fire) | 356 | 377 | 398 | 419 | 440 | 461 | 482 | 503 | 524 | 545 | 566 |
| Wood-Fired CFBC | 466 | 489 | 513 | 536 | 559 | 583 | 606 | 630 | 653 | 676 | 700 |
| Co-Fired CFBC | 569 | 612 | 656 | 699 | 742 | 785 | 829 | 872 | 915 | 959 | 1002 |
| Molten Carbonate Fuel Cell | 219 | 266 | 313 | 359 | 406 | 452 | 499 | 546 | 592 | 639 | --- |
| Solid Oxide Fuel Cell | 199 | 243 | 288 | 332 | 377 | 421 | 465 | 510 | 554 | 599 | --- |
| Spark Ignition Engine | 408 | 474 | 540 | 606 | 672 | 738 | 804 | 870 | 936 | 1002 | --- |
| Hydroelectric - New - 30 MW | 426 | 421 | 416 | 410 | 405 | --- | --- | --- | --- | --- | --- |
| Hydroelectric - 50 MW Bulb Unit | 371 | 366 | 361 | 355 | 350 | --- | --- | --- | --- | --- | --- |
| Hydroelectric - 25 MW Bulb Units | 483 | 478 | 472 | 467 | 462 | --- | --- | --- | --- | --- | --- |
| Hydroelectric - 50 MW Kaplan Unit | 454 | 449 | 443 | 438 | 433 | --- | --- | --- | --- | --- | --- |
| Hydroelectric - 50 MW Propeller Unit | 429 | 424 | 419 | 413 | 408 | --- | --- | --- | --- | --- | --- |
| Minimum Levelized \$/kW | 88 | 145 | 196 | 224 | 299 | 350 | 381 | 404 | 427 | 449 | 502 |

Levelized Dollars at Various Capacity Factors With SO2 Adders, without CO2 Adders, and with NOx Adders

| Technology | 2010 (\$/kW yr) | | | | | | | | | | |
|--|-----------------|------------|------------|------------|------------|------------|------------|------------|------------|------------|------------|
| | 0% | 10% | 20% | 30% | 40% | 50% | 60% | 70% | 80% | 90% | 100% |
| Pumped Hydro Energy Storage | 168 | 209 | 250 | --- | --- | --- | --- | --- | --- | --- | --- |
| Advanced Battery Energy Storage | 141 | 189 | 237 | --- | --- | --- | --- | --- | --- | --- | --- |
| Compressed Air Energy Storage | 135 | 197 | 260 | --- | --- | --- | --- | --- | --- | --- | --- |
| Simple Cycle GE LM6000 CT | 131 | 229 | 326 | 424 | 522 | 620 | 717 | 815 | 913 | 1010 | 1108 |
| Simple Cycle GE 7EA CT | 107 | 225 | 344 | 462 | 580 | 698 | 817 | 935 | 1053 | 1171 | 1290 |
| Simple Cycle GE 7FA CT | 88 | 180 | 273 | 365 | 458 | 550 | 643 | 735 | 828 | 920 | 1013 |
| Combined Cycle GE 7EA CT | 194 | 264 | 333 | 402 | 471 | 540 | 609 | 678 | 747 | 816 | 885 |
| Combined Cycle 1x1 7F-Class | 137 | 194 | 252 | 309 | 366 | 424 | 481 | 538 | 596 | 653 | 710 |
| Combined Cycle 1x1 G-Class CT | 117 | 174 | 230 | 287 | 343 | 400 | 456 | 513 | 570 | 626 | 683 |
| Combined Cycle 2x1 7F-Class CT | 100 | 157 | 213 | 270 | 327 | 383 | 440 | 497 | 553 | 610 | 666 |
| Combined Cycle 3x1 7F-Class CT | 94 | 150 | 207 | 263 | 320 | 376 | 433 | 489 | 546 | 602 | 659 |
| Combined Cycle Siemens 5000F CT | 140 | 200 | 261 | 321 | 381 | 442 | 502 | 563 | 623 | 683 | 744 |
| Humid Air Turbine Cycle CT | 129 | 214 | 300 | 385 | 470 | 556 | 641 | 727 | 812 | 898 | 983 |
| Kalina Cycle CC CT | 137 | 188 | 240 | 292 | 343 | 395 | 446 | 498 | 550 | 601 | 653 |
| Cheng Cycle CT | 142 | 203 | 265 | 326 | 388 | 449 | 511 | 573 | 634 | 696 | 757 |
| Peaking Microturbine | 423 | 573 | 723 | 873 | 1023 | 1173 | 1323 | 1473 | 1623 | 1773 | 1923 |
| Baseload Microturbine | 453 | 573 | 693 | 813 | 933 | 1053 | 1174 | 1294 | 1414 | 1534 | 1654 |
| Subcritical Pulverized Coal - 256 MW | 331 | 357 | 383 | 409 | 435 | 462 | 488 | 514 | 540 | 566 | 592 |
| Subcritical Pulverized Coal - 512 MW | 295 | 320 | 346 | 372 | 398 | 423 | 449 | 475 | 501 | 526 | 552 |
| Circulating Fluidized Bed - 2x 250 MW | 271 | 303 | 335 | 367 | 399 | 431 | 463 | 495 | 527 | 559 | 591 |
| Supercritical Pulverized Coal - 565 MW | 299 | 326 | 353 | 380 | 407 | 435 | 462 | 489 | 516 | 543 | 571 |
| Supercritical Pulverized Coal-800 MW | 261 | 287 | 314 | 340 | 366 | 393 | 419 | 445 | 472 | 498 | 525 |
| Pressurized Fluidized Bed Combustion | 325 | 351 | 376 | 402 | 427 | 453 | 478 | 503 | 529 | --- | --- |
| 1x1 IGCC | 329 | 353 | 377 | 401 | 424 | 448 | 472 | 496 | 520 | --- | --- |
| 2x1 IGCC | 368 | 392 | 415 | 438 | 462 | 485 | 508 | 532 | 555 | --- | --- |
| Subcritical Pulverized Coal - 502 MW - CCS | 513 | 551 | 588 | 626 | 663 | 700 | 738 | 775 | 813 | 850 | 888 |
| Circulating Fluidized Bed - CC | 463 | 505 | 548 | 590 | 632 | 675 | 717 | 760 | 802 | 845 | 887 |
| Supercritical Pulverized Coal - 565 MW - CCS | 452 | 493 | 533 | 574 | 615 | 655 | 696 | 736 | 777 | 817 | 858 |
| Supercritical Pulverized Coal - 800 MW - CCS | 396 | 427 | 458 | 489 | 520 | 551 | 582 | 613 | 644 | 675 | 706 |
| 1x1 IGCC - CCS | 488 | 517 | 546 | 574 | 603 | 631 | 660 | 688 | 717 | --- | --- |
| 2x1 IGCC - CC | 441 | 468 | 495 | 523 | 550 | 577 | 604 | 632 | 659 | --- | --- |
| Wind Energy Conversion | 232 | 229 | 227 | 224 | --- | --- | --- | --- | --- | --- | --- |
| Solar Photovoltaic | 472 | 472 | --- | --- | --- | --- | --- | --- | --- | --- | --- |
| Solar Thermal, Parabolic Trough | 540 | 541 | --- | --- | --- | --- | --- | --- | --- | --- | --- |
| Solar Thermal, Power Tower w Storage | 679 | 679 | 680 | 681 | --- | --- | --- | --- | --- | --- | --- |
| Solar Thermal, Parabolic Dish | 627 | 627 | --- | --- | --- | --- | --- | --- | --- | --- | --- |
| Solar Thermal, Central Receiver | 678 | 679 | 680 | 680 | 681 | 682 | 683 | --- | --- | --- | --- |
| Solar Thermal, Solar Chimney | 557 | 557 | 557 | 557 | --- | --- | --- | --- | --- | --- | --- |
| MSW Mass Burn | 1701 | 1665 | 1630 | 1594 | 1559 | 1523 | 1488 | 1452 | --- | --- | --- |
| RDF Stoker-Fired | 1555 | 1641 | 1726 | 1811 | 1896 | 1981 | 2067 | 2152 | 2237 | --- | --- |
| Wood Fired Stoker Plant | 444 | 476 | 509 | 542 | 575 | 607 | 640 | 673 | 706 | --- | --- |
| Landfill Gas IC Engine | 245 | 291 | 337 | 382 | 428 | 473 | 519 | 565 | 610 | 656 | --- |
| TDF Multi-Fuel CFB (10% Co-fire) | 476 | 505 | 534 | 563 | 592 | 622 | 651 | 680 | 709 | 738 | 768 |
| Sewage Sludge & Anaerobic Digestion | 667 | 662 | 657 | 651 | 646 | 641 | 636 | 630 | 625 | 620 | --- |
| Bio Mass (Co-Fire) | 356 | 379 | 403 | 426 | 449 | 472 | 495 | 519 | 542 | 565 | 588 |
| Wood-Fired CFBC | 466 | 492 | 519 | 545 | 571 | 598 | 624 | 650 | 677 | 703 | 729 |
| Co-Fired CFBC | 569 | 616 | 662 | 709 | 756 | 802 | 849 | 895 | 942 | 989 | 1035 |
| Molten Carbonate Fuel Cell | 219 | 270 | 321 | 372 | 423 | 473 | 524 | 575 | 626 | 677 | --- |
| Solid Oxide Fuel Cell | 199 | 248 | 298 | 347 | 396 | 446 | 495 | 544 | 594 | 643 | --- |
| Spark Ignition Engine | 408 | 481 | 555 | 628 | 702 | 775 | 848 | 922 | 995 | 1069 | --- |
| Hydroelectric - New - 30 MW | 426 | 421 | 416 | 410 | 405 | --- | --- | --- | --- | --- | --- |
| Hydroelectric - 50 MW Bulb Unit | 371 | 366 | 361 | 355 | 350 | --- | --- | --- | --- | --- | --- |
| Hydroelectric - 25 MW Bulb Units | 483 | 478 | 472 | 467 | 462 | --- | --- | --- | --- | --- | --- |
| Hydroelectric - 50 MW Kaplan Unit | 454 | 449 | 443 | 438 | 433 | --- | --- | --- | --- | --- | --- |
| Hydroelectric - 50 MW Propeller Unit | 429 | 424 | 419 | 413 | 408 | --- | --- | --- | --- | --- | --- |
| Minimum Levelized \$/kW | 88 | 150 | 207 | 224 | 320 | 376 | 419 | 445 | 472 | 498 | 525 |

Levelized Dollars at Various Capacity Factors With SO2 Adders, without CO2 Adders, and with NOx Adders

| Technology | Capacity Factors | | | | | | | | | | |
|--|------------------|------|------|------|------|------|------|------|------|------|------|
| | 0% | 10% | 20% | 30% | 40% | 50% | 60% | 70% | 80% | 90% | 100% |
| Pumped Hydro Energy Storage | 168 | 213 | 257 | — | — | — | — | — | — | — | — |
| Advanced Battery Energy Storage | 141 | 192 | 243 | — | — | — | — | — | — | — | — |
| Compressed Air Energy Storage | 135 | 203 | 272 | — | — | — | — | — | — | — | — |
| Simple Cycle GE LM6000 CT | 131 | 236 | 341 | 446 | 550 | 655 | 760 | 865 | 970 | 1074 | 1179 |
| Simple Cycle GE 7EA CT | 107 | 235 | 362 | 489 | 616 | 744 | 871 | 998 | 1126 | 1253 | 1380 |
| Simple Cycle GE 7FA CT | 88 | 188 | 288 | 388 | 488 | 588 | 688 | 788 | 889 | 989 | 1089 |
| Combined Cycle GE 7EA CT | 194 | 270 | 345 | 420 | 496 | 571 | 646 | 722 | 797 | 872 | 948 |
| Combined Cycle 1x1 7F-Class | 137 | 200 | 262 | 325 | 387 | 450 | 512 | 575 | 638 | 700 | 763 |
| Combined Cycle 1x1 G-Class CT | 117 | 179 | 240 | 302 | 364 | 426 | 488 | 549 | 611 | 673 | 735 |
| Combined Cycle 2x1 7F-Class CT | 100 | 162 | 224 | 286 | 348 | 409 | 471 | 533 | 595 | 657 | 719 |
| Combined Cycle 3x1 7F-Class CT | 94 | 156 | 217 | 279 | 341 | 403 | 464 | 526 | 588 | 649 | 711 |
| Combined Cycle Siemens 5000F CT | 140 | 206 | 272 | 337 | 403 | 469 | 535 | 601 | 667 | 733 | 799 |
| Humid Air Turbine Cycle CT | 129 | 222 | 316 | 409 | 502 | 596 | 689 | 783 | 876 | 970 | 1063 |
| Kalina Cycle CC CT | 137 | 193 | 250 | 306 | 363 | 419 | 476 | 532 | 589 | 646 | 702 |
| Cheng Cycle CT | 142 | 209 | 276 | 343 | 410 | 478 | 545 | 612 | 679 | 746 | 814 |
| Peaking Microturbine | 423 | 584 | 745 | 907 | 1068 | 1229 | 1391 | 1552 | 1713 | 1875 | 2036 |
| Baseload Microturbine | 453 | 585 | 716 | 847 | 978 | 1110 | 1241 | 1372 | 1504 | 1635 | 1766 |
| Subcritical Pulverized Coal - 256 MW | 331 | 360 | 388 | 416 | 445 | 473 | 501 | 530 | 558 | 586 | 615 |
| Subcritical Pulverized Coal - 512 MW | 295 | 323 | 351 | 379 | 407 | 435 | 463 | 491 | 519 | 547 | 575 |
| Circulating Fluidized Bed - 2x 250 MW | 271 | 306 | 340 | 375 | 409 | 444 | 478 | 513 | 547 | 582 | 616 |
| Supercritical Pulverized Coal - 565 MW | 299 | 328 | 357 | 387 | 416 | 446 | 475 | 505 | 534 | 564 | 593 |
| Supercritical Pulverized Coal-800 MW | 261 | 289 | 318 | 347 | 375 | 404 | 433 | 461 | 490 | 518 | 547 |
| Pressurized Fluidized Bed Combustion | 325 | 353 | 381 | 408 | 436 | 464 | 491 | 519 | 547 | — | — |
| 1x1 IGCC | 329 | 355 | 381 | 407 | 433 | 459 | 485 | 511 | 537 | — | — |
| 2x1 IGCC | 368 | 394 | 419 | 445 | 471 | 496 | 522 | 547 | 573 | — | — |
| Subcritical Pulverized Coal - 502 MW - CCS | 513 | 554 | 595 | 635 | 676 | 716 | 757 | 798 | 838 | 879 | 920 |
| Circulating Fluidized Bed - CC | 463 | 509 | 555 | 600 | 646 | 692 | 738 | 784 | 830 | 876 | 922 |
| Supercritical Pulverized Coal - 565 MW - CCS | 452 | 496 | 540 | 584 | 627 | 671 | 715 | 759 | 802 | 846 | 890 |
| Supercritical Pulverized Coal - 800 MW - CCS | 396 | 429 | 463 | 496 | 529 | 562 | 596 | 629 | 662 | 696 | 729 |
| 1x1 IGCC - CCS | 488 | 520 | 551 | 582 | 613 | 644 | 675 | 706 | 737 | — | — |
| 2x1 IGCC - CC | 441 | 471 | 501 | 530 | 560 | 590 | 620 | 650 | 680 | — | — |
| Wind Energy Conversion | 232 | 229 | 227 | 224 | — | — | — | — | — | — | — |
| Solar Photovoltaic | 472 | 472 | — | — | — | — | — | — | — | — | — |
| Solar Thermal, Parabolic Trough | 540 | 541 | — | — | — | — | — | — | — | — | — |
| Solar Thermal, Power Tower w Storage | 679 | 679 | 680 | 681 | — | — | — | — | — | — | — |
| Solar Thermal, Parabolic Dish | 627 | 627 | — | — | — | — | — | — | — | — | — |
| Solar Thermal, Central Receiver | 678 | 679 | 680 | 680 | 681 | 682 | 683 | — | — | — | — |
| Solar Thermal, Solar Chimney | 557 | 557 | 557 | 557 | — | — | — | — | — | — | — |
| MSW Mass Burn | 1701 | 1658 | 1615 | 1572 | 1530 | 1487 | 1444 | 1401 | — | — | — |
| RDF Stoker-Fired | 1555 | 1648 | 1741 | 1834 | 1927 | 2020 | 2113 | 2206 | 2299 | — | — |
| Wood Fired Stoker Plant | 444 | 480 | 516 | 552 | 588 | 624 | 660 | 697 | 733 | — | — |
| Landfill Gas IC Engine | 245 | 323 | 401 | 479 | 556 | 634 | 712 | 790 | 868 | 945 | — |
| TDF Multi-Fuel CFB (10% Co-fire) | 476 | 507 | 539 | 571 | 603 | 635 | 666 | 698 | 730 | 762 | 794 |
| Sewage Sludge & Anaerobic Digestion | 667 | 662 | 657 | 651 | 646 | 641 | 636 | 630 | 625 | 620 | — |
| Bio Mass (Co-Fire) | 356 | 382 | 407 | 432 | 458 | 483 | 509 | 534 | 559 | 585 | 610 |
| Wood-Fired CFBC | 466 | 495 | 524 | 554 | 583 | 612 | 642 | 671 | 700 | 729 | 759 |
| Co-Fired CFBC | 569 | 619 | 669 | 719 | 769 | 819 | 869 | 919 | 969 | 1019 | 1069 |
| Molten Carbonate Fuel Cell | 219 | 275 | 330 | 385 | 440 | 495 | 550 | 605 | 660 | 715 | — |
| Solid Oxide Fuel Cell | 199 | 253 | 308 | 362 | 416 | 470 | 525 | 579 | 633 | 687 | — |
| Spark Ignition Engine | 408 | 489 | 569 | 650 | 731 | 812 | 892 | 973 | 1054 | 1135 | — |
| Hydroelectric - New - 30 MW | 426 | 421 | 416 | 410 | 405 | — | — | — | — | — | — |
| Hydroelectric - 50 MW Bulb Unit | 371 | 366 | 361 | 355 | 350 | — | — | — | — | — | — |
| Hydroelectric - 25 MW Bulb Units | 483 | 478 | 472 | 467 | 462 | — | — | — | — | — | — |
| Hydroelectric - 50 MW Kaplan Unit | 454 | 449 | 443 | 438 | 433 | — | — | — | — | — | — |
| Hydroelectric - 50 MW Propeller Unit | 429 | 424 | 419 | 413 | 408 | — | — | — | — | — | — |
| Minimum Levelized \$/kW | 88 | 156 | 217 | 224 | 341 | 403 | 433 | 461 | 490 | 518 | 547 |

Levelized Dollars at Various Capacity Factors With SO2 Adders, without CO2 Adders, and with NOx Adders

| Technology | 2010 (\$/kW yr) | | | | | | | | | | |
|--|-----------------|------------|------------|------------|------------|------------|------------|------------|------------|------------|------------|
| | 0% | 10% | 20% | 30% | 40% | 50% | 60% | 70% | 80% | 90% | 100% |
| Pumped Hydro Energy Storage | 168 | 206 | 244 | — | — | — | — | — | — | — | — |
| Advanced Battery Energy Storage | 141 | 186 | 230 | — | — | — | — | — | — | — | — |
| Compressed Air Energy Storage | 135 | 193 | 250 | — | — | — | — | — | — | — | — |
| Simple Cycle GE LM6000 CT | 132 | 225 | 319 | 413 | 507 | 601 | 694 | 788 | 882 | 976 | 1069 |
| Simple Cycle GE 7EA CT | 108 | 221 | 334 | 448 | 561 | 674 | 787 | 901 | 1014 | 1127 | 1240 |
| Simple Cycle GE 7FA CT | 88 | 177 | 265 | 353 | 442 | 530 | 618 | 706 | 795 | 883 | 971 |
| Combined Cycle GE 7EA CT | 196 | 261 | 327 | 392 | 458 | 524 | 589 | 655 | 720 | 786 | 852 |
| Combined Cycle 1x1 7F-Class | 138 | 192 | 247 | 301 | 356 | 410 | 464 | 519 | 573 | 628 | 682 |
| Combined Cycle 1x1 G-Class CT | 118 | 171 | 225 | 279 | 333 | 386 | 440 | 494 | 547 | 601 | 655 |
| Combined Cycle 2x1 7F-Class CT | 101 | 155 | 208 | 262 | 316 | 370 | 423 | 477 | 531 | 585 | 638 |
| Combined Cycle 3x1 7F-Class CT | 95 | 148 | 202 | 256 | 309 | 363 | 417 | 470 | 524 | 577 | 631 |
| Combined Cycle Siemens 5000F CT | 141 | 198 | 256 | 313 | 371 | 428 | 485 | 543 | 600 | 657 | 715 |
| Humid Air Turbine Cycle CT | 130 | 211 | 292 | 374 | 455 | 536 | 617 | 698 | 779 | 860 | 941 |
| Kalina Cycle CC CT | 138 | 187 | 236 | 285 | 333 | 382 | 431 | 480 | 529 | 578 | 627 |
| Cheng Cycle CT | 143 | 201 | 260 | 318 | 377 | 435 | 494 | 552 | 611 | 669 | 728 |
| Peaking Microturbine | 424 | 568 | 711 | 855 | 999 | 1143 | 1287 | 1431 | 1575 | 1718 | 1862 |
| Baseload Microturbine | 456 | 570 | 683 | 797 | 911 | 1025 | 1139 | 1253 | 1367 | 1480 | 1594 |
| Subcritical Pulverized Coal - 256 MW | 331 | 356 | 381 | 406 | 430 | 455 | 480 | 505 | 530 | 554 | 579 |
| Subcritical Pulverized Coal - 512 MW | 295 | 319 | 344 | 368 | 393 | 417 | 442 | 466 | 491 | 515 | 540 |
| Circulating Fluidized Bed - 2x 250 MW | 271 | 302 | 332 | 363 | 394 | 424 | 455 | 485 | 516 | 547 | 577 |
| Supercritical Pulverized Coal - 565 MW | 299 | 324 | 350 | 376 | 402 | 428 | 454 | 480 | 506 | 532 | 558 |
| Supercritical Pulverized Coal-800 MW | 261 | 286 | 311 | 336 | 361 | 387 | 412 | 437 | 462 | 487 | 512 |
| Pressurized Fluidized Bed Combustion | 325 | 350 | 374 | 398 | 422 | 446 | 471 | 495 | 519 | — | — |
| 1x1 IGCC | 329 | 352 | 375 | 397 | 420 | 443 | 465 | 488 | 511 | — | — |
| 2x1 IGCC | 368 | 391 | 413 | 435 | 457 | 479 | 501 | 523 | 545 | — | — |
| Subcritical Pulverized Coal - 502 MW - CCS | 513 | 549 | 585 | 620 | 656 | 692 | 727 | 763 | 799 | 834 | 870 |
| Circulating Fluidized Bed - CC | 463 | 503 | 544 | 584 | 625 | 665 | 706 | 746 | 787 | 827 | 868 |
| Supercritical Pulverized Coal - 565 MW - CCS | 452 | 491 | 530 | 569 | 608 | 646 | 685 | 724 | 763 | 802 | 841 |
| Supercritical Pulverized Coal - 800 MW - CCS | 396 | 426 | 456 | 486 | 515 | 545 | 575 | 605 | 635 | 664 | 694 |
| 1x1 IGCC - CCS | 488 | 516 | 543 | 570 | 597 | 624 | 652 | 679 | 706 | — | — |
| 2x1 IGCC - CC | 441 | 467 | 493 | 518 | 544 | 570 | 596 | 622 | 648 | — | — |
| Wind Energy Conversion | 232 | 229 | 227 | 224 | — | — | — | — | — | — | — |
| Solar Photovoltaic | 472 | 472 | — | — | — | — | — | — | — | — | — |
| Solar Thermal, Parabolic Trough | 540 | 541 | — | — | — | — | — | — | — | — | — |
| Solar Thermal, Power Tower w Storage | 679 | 679 | 680 | 681 | — | — | — | — | — | — | — |
| Solar Thermal, Parabolic Dish | 627 | 627 | — | — | — | — | — | — | — | — | — |
| Solar Thermal, Central Receiver | 678 | 679 | 680 | 680 | 681 | 682 | 683 | — | — | — | — |
| Solar Thermal, Solar Chimney | 557 | 557 | 557 | 557 | — | — | — | — | — | — | — |
| MSW Mass Burn | 1701 | 1669 | 1638 | 1606 | 1575 | 1543 | 1512 | 1480 | — | — | — |
| RDF Stoker-Fired | 1555 | 1636 | 1717 | 1798 | 1879 | 1960 | 2041 | 2122 | 2203 | — | — |
| Wood Fired Stoker Plant | 444 | 474 | 505 | 536 | 567 | 598 | 629 | 660 | 691 | — | — |
| Landfill Gas IC Engine | 245 | 268 | 292 | 315 | 338 | 361 | 385 | 408 | 431 | 454 | — |
| TDF Multi-Fuel CFB (10% Co-fire) | 476 | 503 | 531 | 559 | 587 | 615 | 642 | 670 | 698 | 726 | 753 |
| Sewage Sludge & Anaerobic Digestion | 667 | 662 | 657 | 651 | 646 | 641 | 636 | 630 | 625 | 620 | — |
| Bio Mass (Co-Fire) | 356 | 378 | 400 | 422 | 444 | 466 | 488 | 510 | 532 | 554 | 576 |
| Wood-Fired CFBC | 466 | 491 | 515 | 540 | 565 | 589 | 614 | 639 | 664 | 688 | 713 |
| Co-Fired CFBC | 569 | 614 | 659 | 703 | 748 | 793 | 838 | 883 | 927 | 972 | 1017 |
| Molten Carbonate Fuel Cell | 220 | 269 | 317 | 366 | 414 | 463 | 511 | 560 | 608 | 657 | — |
| Solid Oxide Fuel Cell | 200 | 247 | 293 | 340 | 387 | 433 | 480 | 526 | 573 | 620 | — |
| Spark Ignition Engine | 409 | 479 | 548 | 618 | 687 | 756 | 826 | 895 | 964 | 1034 | — |
| Hydroelectric - New - 30 MW | 426 | 421 | 416 | 410 | 405 | — | — | — | — | — | — |
| Hydroelectric - 50 MW Bulb Unit | 371 | 366 | 361 | 355 | 350 | — | — | — | — | — | — |
| Hydroelectric - 25 MW Bulb Units | 483 | 478 | 472 | 467 | 462 | — | — | — | — | — | — |
| Hydroelectric - 50 MW Kaplan Unit | 454 | 449 | 443 | 438 | 433 | — | — | — | — | — | — |
| Hydroelectric - 50 MW Propeller Unit | 429 | 424 | 419 | 413 | 408 | — | — | — | — | — | — |
| Minimum Levelized \$/KW | 88 | 148 | 202 | 224 | 309 | 361 | 385 | 408 | 431 | 454 | 512 |

Levelized Dollars at Various Capacity Factors With SO2 Adders, without CO2 Adders, and with NOx Adders

| Technology | 2010 (\$/kW yr) | | | | | | | | | | |
|--|-----------------|------|------|------|------|------|------|------|------|------|------|
| | 0% | 10% | 20% | 30% | 40% | 50% | 60% | 70% | 80% | 90% | 100% |
| Pumped Hydro Energy Storage | 168 | 209 | 250 | --- | --- | --- | --- | --- | --- | --- | --- |
| Advanced Battery Energy Storage | 141 | 189 | 237 | --- | --- | --- | --- | --- | --- | --- | --- |
| Compressed Air Energy Storage | 135 | 199 | 263 | --- | --- | --- | --- | --- | --- | --- | --- |
| Simple Cycle GE LM6000 CT | 132 | 233 | 334 | 435 | 537 | 638 | 739 | 840 | 942 | 1043 | 1144 |
| Simple Cycle GE 7EA CT | 108 | 231 | 354 | 476 | 599 | 722 | 845 | 967 | 1090 | 1213 | 1336 |
| Simple Cycle GE 7FA CT | 88 | 185 | 281 | 377 | 474 | 570 | 666 | 762 | 859 | 955 | 1051 |
| Combined Cycle GE 7EA CT | 196 | 268 | 340 | 412 | 484 | 556 | 629 | 701 | 773 | 845 | 917 |
| Combined Cycle 1x1 7F-Class | 138 | 198 | 258 | 318 | 378 | 438 | 498 | 557 | 617 | 677 | 737 |
| Combined Cycle 1x1 G-Class CT | 118 | 177 | 236 | 295 | 354 | 414 | 473 | 532 | 591 | 650 | 709 |
| Combined Cycle 2x1 7F-Class CT | 101 | 160 | 219 | 279 | 338 | 397 | 456 | 516 | 575 | 634 | 693 |
| Combined Cycle 3x1 7F-Class CT | 95 | 154 | 213 | 272 | 331 | 390 | 449 | 509 | 568 | 627 | 686 |
| Combined Cycle Siemens 5000F CT | 141 | 204 | 267 | 330 | 394 | 457 | 520 | 583 | 646 | 709 | 772 |
| Humid Air Turbine Cycle CT | 130 | 220 | 309 | 399 | 488 | 578 | 667 | 756 | 846 | 935 | 1025 |
| Kalina Cycle CC CT | 138 | 192 | 246 | 300 | 354 | 408 | 462 | 516 | 570 | 625 | 679 |
| Cheng Cycle CT | 143 | 207 | 272 | 336 | 400 | 465 | 529 | 594 | 658 | 722 | 787 |
| Peaking Microturbine | 424 | 579 | 735 | 891 | 1046 | 1202 | 1358 | 1513 | 1669 | 1825 | 1980 |
| Baseload Microturbine | 456 | 581 | 707 | 833 | 958 | 1084 | 1210 | 1335 | 1461 | 1587 | 1712 |
| Subcritical Pulverized Coal - 256 MW | 331 | 359 | 386 | 413 | 440 | 467 | 494 | 522 | 549 | 576 | 603 |
| Subcritical Pulverized Coal - 512 MW | 295 | 322 | 348 | 375 | 402 | 429 | 456 | 483 | 510 | 537 | 563 |
| Circulating Fluidized Bed - 2x 250 MW | 271 | 304 | 338 | 371 | 404 | 437 | 471 | 504 | 537 | 570 | 604 |
| Supercritical Pulverized Coal - 565 MW | 299 | 327 | 355 | 383 | 412 | 440 | 468 | 497 | 525 | 553 | 582 |
| Supercritical Pulverized Coal-800 MW | 261 | 288 | 316 | 343 | 371 | 398 | 426 | 453 | 481 | 508 | 536 |
| Pressurized Fluidized Bed Combustion | 325 | 352 | 379 | 405 | 432 | 458 | 485 | 511 | 538 | --- | --- |
| 1x1 IGCC | 329 | 354 | 379 | 404 | 429 | 454 | 478 | 503 | 528 | --- | --- |
| 2x1 IGCC | 368 | 393 | 417 | 442 | 466 | 491 | 515 | 539 | 564 | --- | --- |
| Subcritical Pulverized Coal - 502 MW - CCS | 513 | 552 | 591 | 630 | 669 | 708 | 748 | 787 | 826 | 865 | 904 |
| Circulating Fluidized Bed - CC | 463 | 507 | 551 | 595 | 639 | 684 | 728 | 772 | 816 | 860 | 904 |
| Supercritical Pulverized Coal - 565 MW - CCS | 452 | 494 | 537 | 579 | 621 | 663 | 705 | 747 | 790 | 832 | 874 |
| Supercritical Pulverized Coal - 800 MW - CCS | 396 | 428 | 460 | 493 | 525 | 557 | 589 | 621 | 653 | 685 | 718 |
| 1x1 IGCC - CCS | 488 | 518 | 548 | 578 | 608 | 638 | 667 | 697 | 727 | --- | --- |
| 2x1 IGCC - CC | 441 | 470 | 498 | 527 | 555 | 584 | 612 | 641 | 669 | --- | --- |
| Wind Energy Conversion | 232 | 229 | 227 | 224 | --- | --- | --- | --- | --- | --- | --- |
| Solar Photovoltaic | 472 | 472 | --- | --- | --- | --- | --- | --- | --- | --- | --- |
| Solar Thermal, Parabolic Trough | 540 | 541 | --- | --- | --- | --- | --- | --- | --- | --- | --- |
| Solar Thermal, Power Tower w Storage | 679 | 679 | 680 | 681 | --- | --- | --- | --- | --- | --- | --- |
| Solar Thermal, Parabolic Dish | 627 | 627 | --- | --- | --- | --- | --- | --- | --- | --- | --- |
| Solar Thermal, Central Receiver | 678 | 679 | 680 | 680 | 681 | 682 | 683 | --- | --- | --- | --- |
| Solar Thermal, Solar Chimney | 557 | 557 | 557 | 557 | --- | --- | --- | --- | --- | --- | --- |
| MSW Mass Burn | 1701 | 1662 | 1623 | 1583 | 1544 | 1505 | 1466 | 1427 | --- | --- | --- |
| RDF Stoker-Fired | 1555 | 1644 | 1734 | 1823 | 1912 | 2001 | 2090 | 2179 | 2268 | --- | --- |
| Wood Fired Stoker Plant | 444 | 478 | 512 | 547 | 581 | 616 | 650 | 685 | 719 | --- | --- |
| Landfill Gas IC Engine | 245 | 293 | 340 | 387 | 435 | 482 | 529 | 577 | 624 | 671 | --- |
| TDF Multi-Fuel CFB (10% Co-fire) | 476 | 506 | 537 | 567 | 598 | 628 | 659 | 689 | 720 | 750 | 781 |
| Sewage Sludge & Anaerobic Digestion | 667 | 662 | 657 | 651 | 646 | 641 | 636 | 630 | 625 | 620 | --- |
| Bio Mass (Co-Fire) | 356 | 381 | 405 | 429 | 453 | 478 | 502 | 526 | 550 | 575 | 599 |
| Wood-Fired CFBC | 466 | 494 | 521 | 549 | 577 | 605 | 633 | 660 | 688 | 716 | 744 |
| Co-Fired CFBC | 569 | 617 | 666 | 714 | 762 | 811 | 859 | 907 | 955 | 1004 | 1052 |
| Molten Carbonate Fuel Cell | 220 | 273 | 326 | 379 | 432 | 485 | 538 | 591 | 644 | 697 | --- |
| Solid Oxide Fuel Cell | 200 | 252 | 304 | 355 | 407 | 459 | 511 | 563 | 614 | 666 | --- |
| Spark Ignition Engine | 409 | 487 | 564 | 641 | 718 | 795 | 872 | 949 | 1026 | 1103 | --- |
| Hydroelectric - New - 30 MW | 426 | 421 | 416 | 410 | 405 | --- | --- | --- | --- | --- | --- |
| Hydroelectric - 50 MW Bulb Unit | 371 | 366 | 361 | 355 | 350 | --- | --- | --- | --- | --- | --- |
| Hydroelectric - 25 MW Bulb Units | 483 | 478 | 472 | 467 | 462 | --- | --- | --- | --- | --- | --- |
| Hydroelectric - 50 MW Kaplan Unit | 454 | 449 | 443 | 438 | 433 | --- | --- | --- | --- | --- | --- |
| Hydroelectric - 50 MW Propeller Unit | 429 | 424 | 419 | 413 | 408 | --- | --- | --- | --- | --- | --- |
| Minimum Levelized \$/kW | 88 | 154 | 213 | 224 | 331 | 390 | 426 | 453 | 481 | 508 | 536 |

Levelized Dollars at Various Capacity Factors With SO2 Adders, without CO2 Adders, and with NOx Adders

| Technology | 2010 (\$/kW yr) | | | | | | | | | | |
|--|-----------------|------|------|------|------|------|------|------|------|------|------|
| | 0% | 10% | 20% | 30% | 40% | 50% | 60% | 70% | 80% | 90% | 100% |
| Pumped Hydro Energy Storage | 168 | 213 | 257 | --- | --- | --- | --- | --- | --- | --- | --- |
| Advanced Battery Energy Storage | 141 | 192 | 243 | --- | --- | --- | --- | --- | --- | --- | --- |
| Compressed Air Energy Storage | 135 | 205 | 275 | --- | --- | --- | --- | --- | --- | --- | --- |
| Simple Cycle GE LM6000 CT | 132 | 240 | 349 | 458 | 567 | 675 | 784 | 893 | 1002 | 1110 | 1219 |
| Simple Cycle GE 7EA CT | 108 | 240 | 373 | 505 | 637 | 770 | 902 | 1034 | 1166 | 1299 | 1431 |
| Simple Cycle GE 7FA CT | 88 | 193 | 297 | 401 | 506 | 610 | 714 | 818 | 923 | 1027 | 1131 |
| Combined Cycle GE 7EA CT | 196 | 274 | 353 | 432 | 511 | 589 | 668 | 747 | 826 | 904 | 983 |
| Combined Cycle 1x1 7F-Class | 138 | 203 | 269 | 334 | 400 | 465 | 531 | 596 | 661 | 727 | 792 |
| Combined Cycle 1x1 G-Class CT | 118 | 182 | 247 | 312 | 376 | 441 | 505 | 570 | 635 | 699 | 764 |
| Combined Cycle 2x1 7F-Class CT | 101 | 166 | 230 | 295 | 360 | 425 | 489 | 554 | 619 | 684 | 748 |
| Combined Cycle 3x1 7F-Class CT | 95 | 159 | 224 | 289 | 353 | 418 | 482 | 547 | 612 | 676 | 741 |
| Combined Cycle Siemens 5000F CT | 141 | 210 | 279 | 348 | 417 | 485 | 554 | 623 | 692 | 761 | 830 |
| Humid Air Turbine Cycle CT | 130 | 228 | 326 | 424 | 522 | 620 | 717 | 815 | 913 | 1011 | 1109 |
| Kalina Cycle CC CT | 138 | 197 | 256 | 315 | 375 | 434 | 493 | 552 | 612 | 671 | 730 |
| Cheng Cycle CT | 143 | 213 | 283 | 354 | 424 | 494 | 565 | 635 | 705 | 775 | 846 |
| Peaking Microturbine | 424 | 591 | 759 | 926 | 1094 | 1261 | 1429 | 1596 | 1764 | 1931 | 2099 |
| Baseload Microturbine | 456 | 593 | 731 | 868 | 1006 | 1143 | 1281 | 1418 | 1556 | 1693 | 1831 |
| Subcritical Pulverized Coal - 256 MW | 331 | 361 | 391 | 420 | 450 | 479 | 509 | 539 | 568 | 598 | 627 |
| Subcritical Pulverized Coal - 512 MW | 295 | 324 | 353 | 382 | 412 | 441 | 470 | 499 | 529 | 558 | 587 |
| Circulating Fluidized Bed - 2x 250 MW | 271 | 307 | 343 | 379 | 415 | 451 | 486 | 522 | 558 | 594 | 630 |
| Supercritical Pulverized Coal - 565 MW | 299 | 329 | 360 | 391 | 421 | 452 | 483 | 513 | 544 | 575 | 605 |
| Supercritical Pulverized Coal-800 MW | 261 | 291 | 321 | 350 | 380 | 410 | 440 | 470 | 500 | 529 | 559 |
| Pressurized Fluidized Bed Combustion | 325 | 354 | 383 | 412 | 441 | 470 | 499 | 528 | 557 | --- | --- |
| 1x1 IGCC | 329 | 356 | 383 | 410 | 437 | 465 | 492 | 519 | 546 | --- | --- |
| 2x1 IGCC | 368 | 395 | 422 | 449 | 475 | 502 | 529 | 556 | 582 | --- | --- |
| Subcritical Pulverized Coal - 502 MW - CCS | 513 | 556 | 598 | 640 | 683 | 725 | 768 | 810 | 852 | 895 | 937 |
| Circulating Fluidized Bed - CC | 463 | 511 | 558 | 606 | 654 | 702 | 750 | 797 | 845 | 893 | 941 |
| Supercritical Pulverized Coal - 565 MW - CCS | 452 | 498 | 543 | 589 | 634 | 680 | 725 | 771 | 816 | 862 | 907 |
| Supercritical Pulverized Coal - 800 MW - CCS | 396 | 431 | 465 | 500 | 534 | 569 | 603 | 638 | 672 | 707 | 741 |
| 1x1 IGCC - CCS | 488 | 521 | 553 | 586 | 618 | 651 | 683 | 716 | 748 | --- | --- |
| 2x1 IGCC - CC | 441 | 472 | 504 | 535 | 566 | 597 | 629 | 660 | 691 | --- | --- |
| Wind Energy Conversion | 232 | 229 | 227 | 224 | --- | --- | --- | --- | --- | --- | --- |
| Solar Photovoltaic | 472 | 472 | --- | --- | --- | --- | --- | --- | --- | --- | --- |
| Solar Thermal, Parabolic Trough | 540 | 541 | --- | --- | --- | --- | --- | --- | --- | --- | --- |
| Solar Thermal, Power Tower w Storage | 679 | 679 | 680 | 681 | --- | --- | --- | --- | --- | --- | --- |
| Solar Thermal, Parabolic Dish | 627 | 627 | --- | --- | --- | --- | --- | --- | --- | --- | --- |
| Solar Thermal, Central Receiver | 678 | 679 | 680 | 680 | 681 | 682 | 683 | --- | --- | --- | --- |
| Solar Thermal, Solar Chimney | 557 | 557 | 557 | 557 | --- | --- | --- | --- | --- | --- | --- |
| MSW Mass Burn | 1701 | 1654 | 1607 | 1560 | 1514 | 1467 | 1420 | 1373 | --- | --- | --- |
| RDF Stoker-Fired | 1555 | 1653 | 1750 | 1847 | 1944 | 2041 | 2139 | 2236 | 2333 | --- | --- |
| Wood Fired Stoker Plant | 444 | 482 | 520 | 558 | 596 | 634 | 672 | 710 | 748 | --- | --- |
| Landfill Gas IC Engine | 245 | 326 | 407 | 489 | 570 | 651 | 732 | 813 | 894 | 975 | --- |
| TDF Multi-Fuel CFB (10% Co-fire) | 476 | 509 | 542 | 575 | 609 | 642 | 675 | 708 | 742 | 775 | 808 |
| Sewage Sludge & Anaerobic Digestion | 667 | 662 | 657 | 651 | 646 | 641 | 636 | 630 | 625 | 620 | --- |
| Bio Mass (Co-Fire) | 356 | 383 | 409 | 436 | 463 | 489 | 516 | 542 | 569 | 595 | 622 |
| Wood-Fired CFBC | 466 | 497 | 528 | 559 | 589 | 620 | 651 | 682 | 713 | 744 | 775 |
| Co-Fired CFBC | 569 | 621 | 673 | 724 | 776 | 828 | 880 | 932 | 984 | 1035 | 1087 |
| Mollen Carbonate Fuel Cell | 220 | 278 | 335 | 392 | 450 | 507 | 564 | 622 | 679 | 737 | --- |
| Solid Oxide Fuel Cell | 200 | 257 | 314 | 371 | 428 | 485 | 542 | 599 | 656 | 713 | --- |
| Spark Ignition Engine | 409 | 494 | 579 | 664 | 749 | 833 | 918 | 1003 | 1088 | 1173 | --- |
| Hydroelectric - New - 30 MW | 426 | 421 | 416 | 410 | 405 | --- | --- | --- | --- | --- | --- |
| Hydroelectric - 50 MW Bulb Unit | 371 | 366 | 361 | 355 | 350 | --- | --- | --- | --- | --- | --- |
| Hydroelectric - 25 MW Bulb Units | 483 | 478 | 472 | 467 | 462 | --- | --- | --- | --- | --- | --- |
| Hydroelectric - 50 MW Kaplan Unit | 454 | 449 | 443 | 438 | 433 | --- | --- | --- | --- | --- | --- |
| Hydroelectric - 50 MW Propeller Unit | 429 | 424 | 419 | 413 | 408 | --- | --- | --- | --- | --- | --- |
| Minimum Levelized \$/kW | 88 | 159 | 224 | 224 | 350 | 410 | 440 | 470 | 500 | 529 | 559 |

Levelized Dollars at Various Capacity Factors With SO2 Adders, without CO2 Adders, and with NOx Adders

| Technology | 2010 (\$/kW yr) | | | | | | | | | | |
|--|------------------|------|------|------|------|------|------|------|------|------|------|
| | Capacity Factors | | | | | | | | | | |
| | 0% | 10% | 20% | 30% | 40% | 50% | 60% | 70% | 80% | 90% | 100% |
| Pumped Hydro Energy Storage | 186 | 224 | 261 | --- | --- | --- | --- | --- | --- | --- | --- |
| Advanced Battery Energy Storage | 156 | 201 | 246 | --- | --- | --- | --- | --- | --- | --- | --- |
| Compressed Air Energy Storage | 145 | 200 | 256 | --- | --- | --- | --- | --- | --- | --- | --- |
| Simple Cycle GE LM6000 CT | 141 | 228 | 316 | 403 | 490 | 578 | 665 | 753 | 840 | 927 | 1015 |
| Simple Cycle GE 7EA CT | 115 | 220 | 325 | 430 | 535 | 640 | 745 | 850 | 955 | 1060 | 1165 |
| Simple Cycle GE 7FA CT | 95 | 176 | 258 | 339 | 421 | 502 | 583 | 665 | 746 | 828 | 909 |
| Combined Cycle GE 7EA CT | 208 | 268 | 328 | 388 | 448 | 508 | 568 | 628 | 688 | 748 | 808 |
| Combined Cycle 1x1 7F-Class | 148 | 198 | 248 | 298 | 347 | 397 | 447 | 497 | 546 | 596 | 646 |
| Combined Cycle 1x1 G-Class CT | 127 | 176 | 225 | 274 | 323 | 372 | 421 | 470 | 519 | 568 | 617 |
| Combined Cycle 2x1 7F-Class CT | 108 | 157 | 206 | 255 | 304 | 353 | 402 | 451 | 500 | 549 | 598 |
| Combined Cycle 3x1 7F-Class CT | 101 | 150 | 199 | 248 | 297 | 345 | 394 | 443 | 492 | 541 | 590 |
| Combined Cycle Siemens 5000F CT | 149 | 202 | 254 | 307 | 359 | 411 | 464 | 516 | 569 | 621 | 674 |
| Humid Air Turbine Cycle CT | 136 | 210 | 284 | 358 | 431 | 505 | 579 | 653 | 727 | 801 | 874 |
| Kalina Cycle CC CT | 146 | 191 | 235 | 280 | 324 | 369 | 413 | 458 | 502 | 547 | 591 |
| Cheng Cycle CT | 151 | 205 | 258 | 312 | 365 | 419 | 472 | 525 | 579 | 632 | 686 |
| Peaking Microturbine | 445 | 579 | 713 | 846 | 980 | 1114 | 1247 | 1381 | 1515 | 1649 | 1782 |
| Baseload Microturbine | 474 | 578 | 682 | 785 | 889 | 993 | 1096 | 1200 | 1304 | 1408 | 1511 |
| Subcritical Pulverized Coal - 256 MW | 358 | 381 | 403 | 426 | 449 | 471 | 494 | 517 | 540 | 562 | 585 |
| Subcritical Pulverized Coal - 512 MW | 319 | 341 | 364 | 386 | 409 | 431 | 454 | 476 | 498 | 521 | 543 |
| Circulating Fluidized Bed - 2x 250 MW | 294 | 322 | 351 | 379 | 407 | 436 | 464 | 492 | 521 | 549 | 577 |
| Supercritical Pulverized Coal - 565 MW | 324 | 348 | 372 | 396 | 420 | 444 | 468 | 492 | 516 | 540 | 564 |
| Supercritical Pulverized Coal-800 MW | 284 | 307 | 330 | 353 | 376 | 399 | 422 | 445 | 469 | 492 | 515 |
| Pressurized Fluidized Bed Combustion | 367 | 389 | 411 | 434 | 456 | 478 | 500 | 522 | 544 | --- | --- |
| 1x1 IGCC | 358 | 379 | 400 | 421 | 441 | 462 | 483 | 504 | 525 | --- | --- |
| 2x1 IGCC | 399 | 419 | 439 | 459 | 479 | 499 | 519 | 540 | 560 | --- | --- |
| Subcritical Pulverized Coal - 502 MW - CCS | 561 | 593 | 626 | 659 | 692 | 725 | 758 | 790 | 823 | 856 | 889 |
| Circulating Fluidized Bed - CC | 502 | 539 | 576 | 614 | 651 | 689 | 726 | 763 | 801 | 838 | 876 |
| Supercritical Pulverized Coal - 565 MW - CCS | 471 | 507 | 543 | 579 | 615 | 651 | 687 | 723 | 759 | 795 | 831 |
| Supercritical Pulverized Coal - 800 MW - CCS | 413 | 441 | 469 | 496 | 524 | 552 | 580 | 607 | 635 | 663 | 691 |
| 1x1 IGCC - CCS | 510 | 535 | 560 | 585 | 610 | 634 | 659 | 684 | 709 | --- | --- |
| 2x1 IGCC - CC | 459 | 482 | 506 | 529 | 552 | 576 | 599 | 623 | 646 | --- | --- |
| Wind Energy Conversion | 257 | 254 | 251 | 248 | --- | --- | --- | --- | --- | --- | --- |
| Solar Photovoltaic | 580 | 580 | --- | --- | --- | --- | --- | --- | --- | --- | --- |
| Solar Thermal, Parabolic Trough | 655 | 656 | --- | --- | --- | --- | --- | --- | --- | --- | --- |
| Solar Thermal, Power Tower w Storage | 829 | 829 | 830 | 830 | --- | --- | --- | --- | --- | --- | --- |
| Solar Thermal, Parabolic Dish | 764 | 764 | --- | --- | --- | --- | --- | --- | --- | --- | --- |
| Solar Thermal, Central Receiver | 808 | 809 | 810 | 811 | 812 | 812 | 813 | --- | --- | --- | --- |
| Solar Thermal, Solar Chimney | 673 | 673 | 673 | 673 | --- | --- | --- | --- | --- | --- | --- |
| MSW Mass Burn | 1809 | 1784 | 1759 | 1734 | 1709 | 1684 | 1659 | 1634 | --- | --- | --- |
| RDF Stoker-Fired | 1723 | 1797 | 1871 | 1945 | 2019 | 2093 | 2167 | 2241 | 2316 | --- | --- |
| Wood Fired Stoker Plant | 493 | 521 | 549 | 577 | 605 | 633 | 660 | 688 | 716 | --- | --- |
| Landfill Gas IC Engine | 275 | 297 | 320 | 342 | 364 | 386 | 408 | 430 | 452 | 475 | --- |
| TDF Multi-Fuel CFB (10% Co-fire) | 514 | 540 | 565 | 591 | 616 | 641 | 667 | 692 | 718 | 743 | 769 |
| Sewage Sludge & Anaerobic Digestion | 735 | 730 | 725 | 719 | 714 | 709 | 704 | 698 | 693 | 688 | --- |
| Bio Mass (Co-Fire) | 387 | 407 | 427 | 447 | 467 | 487 | 507 | 527 | 547 | 567 | 587 |
| Wood-Fired CFBC | 506 | 528 | 550 | 572 | 594 | 616 | 638 | 660 | 682 | 704 | 726 |
| Co-Fired CFBC | 620 | 662 | 703 | 745 | 787 | 829 | 870 | 912 | 954 | 996 | 1037 |
| Molten Carbonate Fuel Cell | 266 | 311 | 356 | 400 | 445 | 490 | 534 | 579 | 624 | 668 | --- |
| Solid Oxide Fuel Cell | 171 | 213 | 256 | 298 | 340 | 382 | 424 | 466 | 509 | 551 | --- |
| Spark Ignition Engine | 423 | 486 | 549 | 612 | 674 | 737 | 800 | 863 | 925 | 988 | --- |
| Hydroelectric - New - 30 MW | 493 | 487 | 482 | 476 | 471 | --- | --- | --- | --- | --- | --- |
| Hydroelectric - 50 MW Bulb Unit | 434 | 428 | 423 | 418 | 412 | --- | --- | --- | --- | --- | --- |
| Hydroelectric - 25 MW Bulb Units | 566 | 560 | 555 | 550 | 544 | --- | --- | --- | --- | --- | --- |
| Hydroelectric - 50 MW Kaplan Unit | 532 | 526 | 521 | 516 | 510 | --- | --- | --- | --- | --- | --- |
| Hydroelectric - 50 MW Propeller Unit | 503 | 498 | 492 | 487 | 481 | --- | --- | --- | --- | --- | --- |
| Minimum Levelized \$/kW | 95 | 150 | 199 | 248 | 297 | 345 | 394 | 430 | 452 | 475 | 515 |

Levelized Dollars at Various Capacity Factors With SO2 Adders, without CO2 Adders, and with NOx Adders

Capital Cost- Base

2010 (\$/kW yr)

Heat Rate-Low

Fuel Forecast- Base

Capacity Factors

| Technology | 0% | 10% | 20% | 30% | 40% | 50% | 60% | 70% | 80% | 90% | 100% |
|--|-----------|------------|------------|------------|------------|------------|------------|------------|------------|------------|------------|
| Pumped Hydro Energy Storage | 186 | 227 | 268 | --- | --- | --- | --- | --- | --- | --- | --- |
| Advanced Battery Energy Storage | 156 | 204 | 252 | --- | --- | --- | --- | --- | --- | --- | --- |
| Compressed Air Energy Storage | 145 | 206 | 267 | --- | --- | --- | --- | --- | --- | --- | --- |
| Simple Cycle GE LM6000 CT | 141 | 235 | 329 | 423 | 518 | 612 | 706 | 800 | 894 | 988 | 1082 |
| Simple Cycle GE 7EA CT | 115 | 228 | 342 | 456 | 569 | 683 | 797 | 910 | 1024 | 1138 | 1252 |
| Simple Cycle GE 7FA CT | 95 | 183 | 272 | 361 | 449 | 538 | 627 | 715 | 804 | 893 | 982 |
| Combined Cycle GE 7EA CT | 208 | 274 | 340 | 406 | 471 | 537 | 603 | 669 | 735 | 801 | 867 |
| Combined Cycle 1x1 7F-Class | 148 | 203 | 258 | 313 | 367 | 422 | 477 | 531 | 586 | 641 | 696 |
| Combined Cycle 1x1 G-Class CT | 127 | 181 | 234 | 288 | 342 | 396 | 450 | 504 | 558 | 612 | 666 |
| Combined Cycle 2x1 7F-Class CT | 108 | 162 | 216 | 270 | 324 | 378 | 432 | 486 | 540 | 594 | 648 |
| Combined Cycle 3x1 7F-Class CT | 101 | 155 | 209 | 263 | 316 | 370 | 424 | 478 | 532 | 586 | 640 |
| Combined Cycle Siemens 5000F CT | 149 | 207 | 264 | 322 | 380 | 437 | 495 | 553 | 610 | 668 | 726 |
| Humid Air Turbine Cycle CT | 136 | 218 | 299 | 380 | 462 | 543 | 625 | 706 | 788 | 869 | 950 |
| Kalina Cycle CC CT | 146 | 195 | 245 | 294 | 343 | 392 | 441 | 490 | 540 | 589 | 638 |
| Cheng Cycle CT | 151 | 210 | 269 | 328 | 386 | 445 | 504 | 563 | 622 | 680 | 739 |
| Peaking Microturbine | 445 | 590 | 734 | 878 | 1023 | 1167 | 1312 | 1456 | 1600 | 1745 | 1889 |
| Baseload Microturbine | 474 | 589 | 703 | 817 | 932 | 1046 | 1161 | 1275 | 1389 | 1504 | 1618 |
| Subcritical Pulverized Coal - 256 MW | 358 | 383 | 408 | 433 | 458 | 482 | 507 | 532 | 557 | 582 | 607 |
| Subcritical Pulverized Coal - 512 MW | 319 | 343 | 368 | 393 | 417 | 442 | 467 | 491 | 516 | 540 | 565 |
| Circulating Fluidized Bed - 2x 250 MW | 294 | 325 | 355 | 386 | 417 | 448 | 478 | 509 | 540 | 571 | 601 |
| Supercritical Pulverized Coal - 565 MW | 324 | 350 | 376 | 403 | 429 | 455 | 481 | 507 | 533 | 559 | 585 |
| Supercritical Pulverized Coal-800 MW | 284 | 309 | 334 | 359 | 385 | 410 | 435 | 460 | 486 | 511 | 536 |
| Pressurized Fluidized Bed Combustion | 367 | 391 | 416 | 440 | 464 | 489 | 513 | 537 | 561 | --- | --- |
| 1x1 IGCC | 358 | 381 | 404 | 427 | 449 | 472 | 495 | 518 | 541 | --- | --- |
| 2x1 IGCC | 399 | 421 | 443 | 465 | 487 | 510 | 532 | 554 | 576 | --- | --- |
| Subcritical Pulverized Coal - 502 MW - CCS | 561 | 597 | 632 | 668 | 704 | 740 | 776 | 812 | 847 | 883 | 919 |
| Circulating Fluidized Bed - CC | 502 | 542 | 583 | 624 | 664 | 705 | 746 | 787 | 827 | 868 | 909 |
| Supercritical Pulverized Coal - 565 MW - CCS | 471 | 510 | 549 | 588 | 627 | 666 | 705 | 744 | 783 | 822 | 861 |
| Supercritical Pulverized Coal - 800 MW - CCS | 413 | 443 | 473 | 503 | 533 | 562 | 592 | 622 | 652 | 682 | 712 |
| 1x1 IGCC - CCS | 510 | 537 | 564 | 592 | 619 | 646 | 674 | 701 | 728 | --- | --- |
| 2x1 IGCC - CC | 459 | 484 | 510 | 536 | 562 | 588 | 614 | 640 | 666 | --- | --- |
| Wind Energy Conversion | 257 | 254 | 251 | 248 | --- | --- | --- | --- | --- | --- | --- |
| Solar Photovoltaic | 580 | 580 | --- | --- | --- | --- | --- | --- | --- | --- | --- |
| Solar Thermal, Parabolic Trough | 655 | 656 | --- | --- | --- | --- | --- | --- | --- | --- | --- |
| Solar Thermal, Power Tower w Storage | 829 | 829 | 830 | 830 | --- | --- | --- | --- | --- | --- | --- |
| Solar Thermal, Parabolic Dish | 764 | 764 | --- | --- | --- | --- | --- | --- | --- | --- | --- |
| Solar Thermal, Central Receiver | 808 | 809 | 810 | 811 | 812 | 812 | 813 | --- | --- | --- | --- |
| Solar Thermal, Solar Chimney | 673 | 673 | 673 | 673 | --- | --- | --- | --- | --- | --- | --- |
| MSW Mass Burn | 1809 | 1777 | 1745 | 1713 | 1682 | 1650 | 1618 | 1586 | --- | --- | --- |
| RDF Stoker-Fired | 1723 | 1805 | 1886 | 1967 | 2049 | 2130 | 2211 | 2293 | 2374 | --- | --- |
| Wood Fired Stoker Plant | 493 | 524 | 555 | 587 | 618 | 649 | 680 | 711 | 742 | --- | --- |
| Landfill Gas IC Engine | 275 | 319 | 363 | 407 | 451 | 495 | 539 | 583 | 627 | 671 | --- |
| TDF Multi-Fuel CFB (10% Co-fire) | 514 | 542 | 570 | 598 | 626 | 654 | 682 | 710 | 738 | 765 | 793 |
| Sewage Sludge & Anaerobic Digestion | 735 | 730 | 725 | 719 | 714 | 709 | 704 | 698 | 693 | 688 | --- |
| Bio Mass (Co-Fire) | 387 | 409 | 431 | 453 | 475 | 497 | 519 | 541 | 563 | 586 | 608 |
| Wood-Fired CFBC | 506 | 531 | 555 | 580 | 605 | 630 | 655 | 680 | 705 | 730 | 754 |
| Co-Fired CFBC | 620 | 665 | 710 | 755 | 800 | 845 | 889 | 934 | 979 | 1024 | 1069 |
| Molten Carbonate Fuel Cell | 266 | 315 | 364 | 412 | 461 | 510 | 558 | 607 | 656 | 704 | --- |
| Solid Oxide Fuel Cell | 171 | 218 | 265 | 312 | 359 | 406 | 452 | 499 | 546 | 593 | --- |
| Spark Ignition Engine | 423 | 493 | 563 | 633 | 702 | 772 | 842 | 911 | 981 | 1051 | --- |
| Hydroelectric - New - 30 MW | 493 | 487 | 482 | 476 | 471 | --- | --- | --- | --- | --- | --- |
| Hydroelectric - 50 MW Bulb Unit | 434 | 428 | 423 | 418 | 412 | --- | --- | --- | --- | --- | --- |
| Hydroelectric - 25 MW Bulb Units | 566 | 560 | 555 | 550 | 544 | --- | --- | --- | --- | --- | --- |
| Hydroelectric - 50 MW Kaplan Unit | 532 | 526 | 521 | 516 | 510 | --- | --- | --- | --- | --- | --- |
| Hydroelectric - 50 MW Propeller Unit | 503 | 498 | 492 | 487 | 481 | --- | --- | --- | --- | --- | --- |
| Minimum Levelized \$/kW | 95 | 155 | 209 | 248 | 316 | 370 | 424 | 460 | 486 | 511 | 536 |

Levelized Dollars at Various Capacity Factors With SO2 Adders, without CO2 Adders, and with NOx Adders

| Technology | 2010 (\$/kW yr) | | | | | | | | | | |
|--|-----------------|------------|------------|------------|------------|------------|------------|------------|------------|------------|------------|
| | 0% | 10% | 20% | 30% | 40% | 50% | 60% | 70% | 80% | 90% | 100% |
| Pumped Hydro Energy Storage | 186 | 231 | 275 | — | — | — | — | — | — | — | — |
| Advanced Battery Energy Storage | 156 | 207 | 259 | — | — | — | — | — | — | — | — |
| Compressed Air Energy Storage | 145 | 212 | 279 | — | — | — | — | — | — | — | — |
| Simple Cycle GE LM6000 CT | 141 | 242 | 343 | 444 | 545 | 646 | 746 | 847 | 948 | 1049 | 1150 |
| Simple Cycle GE 7EA CT | 115 | 237 | 359 | 482 | 604 | 726 | 848 | 971 | 1093 | 1215 | 1338 |
| Simple Cycle GE 7FA CT | 95 | 191 | 287 | 382 | 478 | 574 | 670 | 766 | 862 | 958 | 1054 |
| Combined Cycle GE 7EA CT | 208 | 280 | 352 | 423 | 495 | 567 | 639 | 711 | 783 | 855 | 927 |
| Combined Cycle 1x1 7F-Class | 148 | 208 | 268 | 327 | 387 | 447 | 507 | 566 | 626 | 686 | 745 |
| Combined Cycle 1x1 G-Class CT | 127 | 185 | 244 | 303 | 362 | 421 | 480 | 539 | 598 | 657 | 716 |
| Combined Cycle 2x1 7F-Class CT | 108 | 167 | 226 | 285 | 344 | 403 | 462 | 521 | 580 | 639 | 698 |
| Combined Cycle 3x1 7F-Class CT | 101 | 160 | 219 | 277 | 336 | 395 | 454 | 513 | 572 | 630 | 689 |
| Combined Cycle Siemens 5000F CT | 149 | 212 | 275 | 338 | 401 | 464 | 526 | 589 | 652 | 715 | 778 |
| Humid Air Turbine Cycle CT | 136 | 225 | 314 | 403 | 492 | 581 | 670 | 759 | 848 | 937 | 1026 |
| Kalina Cycle CC CT | 146 | 200 | 254 | 308 | 362 | 415 | 469 | 523 | 577 | 631 | 685 |
| Cheng Cycle CT | 151 | 215 | 280 | 344 | 408 | 472 | 536 | 600 | 664 | 728 | 793 |
| Peaking Microturbine | 445 | 600 | 755 | 911 | 1066 | 1221 | 1376 | 1531 | 1686 | 1841 | 1996 |
| Baseload Microturbine | 474 | 599 | 724 | 850 | 975 | 1100 | 1225 | 1350 | 1475 | 1600 | 1725 |
| Subcritical Pulverized Coal - 256 MW | 358 | 385 | 412 | 439 | 466 | 493 | 520 | 547 | 575 | 602 | 629 |
| Subcritical Pulverized Coal - 512 MW | 319 | 346 | 372 | 399 | 426 | 453 | 479 | 506 | 533 | 560 | 587 |
| Circulating Fluidized Bed - 2x 250 MW | 294 | 327 | 360 | 393 | 426 | 460 | 493 | 526 | 559 | 592 | 625 |
| Supercritical Pulverized Coal - 565 MW | 324 | 353 | 381 | 409 | 437 | 465 | 494 | 522 | 550 | 578 | 607 |
| Supercritical Pulverized Coal-800 MW | 284 | 311 | 338 | 366 | 393 | 420 | 448 | 475 | 503 | 530 | 557 |
| Pressurized Fluidized Bed Combustion | 367 | 393 | 420 | 446 | 473 | 499 | 526 | 552 | 578 | — | — |
| 1x1 IGCC | 358 | 383 | 408 | 433 | 457 | 482 | 507 | 532 | 556 | — | — |
| 2x1 IGCC | 399 | 423 | 447 | 472 | 496 | 520 | 544 | 569 | 593 | — | — |
| Subcritical Pulverized Coal - 502 MW - CCS | 561 | 600 | 638 | 677 | 716 | 755 | 794 | 833 | 872 | 911 | 950 |
| Circulating Fluidized Bed - CC | 502 | 546 | 590 | 634 | 678 | 722 | 766 | 810 | 854 | 898 | 942 |
| Supercritical Pulverized Coal - 565 MW - CCS | 471 | 513 | 555 | 597 | 639 | 681 | 723 | 765 | 807 | 849 | 891 |
| Supercritical Pulverized Coal - 800 MW - CCS | 413 | 445 | 477 | 509 | 541 | 573 | 605 | 637 | 669 | 701 | 733 |
| 1x1 IGCC - CCS | 510 | 539 | 569 | 599 | 628 | 658 | 688 | 718 | 747 | — | — |
| 2x1 IGCC - CC | 459 | 487 | 515 | 544 | 572 | 601 | 629 | 657 | 686 | — | — |
| Wind Energy Conversion | 257 | 254 | 251 | 248 | — | — | — | — | — | — | — |
| Solar Photovoltaic | 580 | 580 | — | — | — | — | — | — | — | — | — |
| Solar Thermal, Parabolic Trough | 655 | 656 | — | — | — | — | — | — | — | — | — |
| Solar Thermal, Power Tower w Storage | 829 | 829 | 830 | 830 | — | — | — | — | — | — | — |
| Solar Thermal, Parabolic Dish | 764 | 764 | — | — | — | — | — | — | — | — | — |
| Solar Thermal, Central Receiver | 808 | 809 | 810 | 811 | 812 | 812 | 813 | — | — | — | — |
| Solar Thermal, Solar Chimney | 673 | 673 | 673 | 673 | — | — | — | — | — | — | — |
| MSW Mass Burn | 1809 | 1770 | 1731 | 1693 | 1654 | 1615 | 1576 | 1538 | — | — | — |
| RDF Stoker-Fired | 1723 | 1812 | 1901 | 1989 | 2078 | 2167 | 2255 | 2344 | 2433 | — | — |
| Wood Fired Stoker Plant | 493 | 528 | 562 | 596 | 630 | 665 | 699 | 733 | 768 | — | — |
| Landfill Gas IC Engine | 275 | 350 | 424 | 499 | 573 | 648 | 722 | 797 | 871 | 946 | — |
| TDF Multi-Fuel CFB (10% Co-fire) | 514 | 545 | 575 | 605 | 636 | 666 | 697 | 727 | 757 | 788 | 818 |
| Sewage Sludge & Anaerobic Digestion | 735 | 730 | 725 | 720 | 714 | 709 | 704 | 698 | 693 | 688 | — |
| Bio Mass (Co-Fire) | 387 | 411 | 435 | 459 | 483 | 508 | 532 | 556 | 580 | 604 | 628 |
| Wood-Fired CFBC | 506 | 533 | 561 | 589 | 616 | 644 | 672 | 699 | 727 | 755 | 782 |
| Co-Fired CFBC | 620 | 668 | 716 | 764 | 812 | 860 | 909 | 957 | 1005 | 1053 | 1101 |
| Molten Carbonate Fuel Cell | 266 | 319 | 372 | 424 | 477 | 530 | 582 | 635 | 688 | 741 | — |
| Solid Oxide Fuel Cell | 171 | 223 | 274 | 326 | 377 | 429 | 480 | 532 | 584 | 635 | — |
| Spark Ignition Engine | 423 | 500 | 577 | 653 | 730 | 807 | 884 | 960 | 1037 | 1114 | — |
| Hydroelectric - New - 30 MW | 493 | 487 | 482 | 476 | 471 | — | — | — | — | — | — |
| Hydroelectric - 50 MW Bulb Unit | 434 | 428 | 423 | 418 | 412 | — | — | — | — | — | — |
| Hydroelectric - 25 MW Bulb Units | 566 | 560 | 555 | 550 | 544 | — | — | — | — | — | — |
| Hydroelectric - 50 MW Kaplan Unit | 532 | 526 | 521 | 516 | 510 | — | — | — | — | — | — |
| Hydroelectric - 50 MW Propeller Unit | 503 | 498 | 492 | 487 | 481 | — | — | — | — | — | — |
| Minimum Levelized \$/kW | 95 | 160 | 219 | 248 | 336 | 395 | 448 | 475 | 503 | 530 | 557 |

Levelized Dollars at Various Capacity Factors With SO2 Adders, without CO2 Adders, and with NOx Adders

Capital Cost- Base
Heat Rate- Base
Fuel Forecast-Low

2010 (\$/kW yr)

| Technology | Capacity Factors | | | | | | | | | | |
|--|------------------|------------|------------|------------|------------|------------|------------|------------|------------|------------|------------|
| | 0% | 10% | 20% | 30% | 40% | 50% | 60% | 70% | 80% | 90% | 100% |
| Pumped Hydro Energy Storage | 186 | 224 | 261 | --- | --- | --- | --- | --- | --- | --- | --- |
| Advanced Battery Energy Storage | 156 | 201 | 246 | --- | --- | --- | --- | --- | --- | --- | --- |
| Compressed Air Energy Storage | 145 | 202 | 258 | --- | --- | --- | --- | --- | --- | --- | --- |
| Simple Cycle GE LM6000 CT | 142 | 232 | 323 | 413 | 504 | 594 | 685 | 776 | 866 | 957 | 1047 |
| Simple Cycle GE 7EA CT | 115 | 224 | 334 | 443 | 552 | 661 | 770 | 879 | 989 | 1098 | 1207 |
| Simple Cycle GE 7FA CT | 95 | 180 | 265 | 350 | 435 | 520 | 605 | 689 | 774 | 859 | 944 |
| Combined Cycle GE 7EA CT | 209 | 272 | 334 | 397 | 460 | 523 | 586 | 648 | 711 | 774 | 837 |
| Combined Cycle 1x1 7F-Class | 149 | 201 | 253 | 305 | 358 | 410 | 462 | 514 | 566 | 618 | 670 |
| Combined Cycle 1x1 G-Class CT | 127 | 179 | 230 | 281 | 333 | 384 | 435 | 487 | 538 | 590 | 641 |
| Combined Cycle 2x1 7F-Class CT | 109 | 160 | 211 | 263 | 314 | 366 | 417 | 468 | 520 | 571 | 623 |
| Combined Cycle 3x1 7F-Class CT | 102 | 153 | 204 | 256 | 307 | 358 | 409 | 461 | 512 | 563 | 614 |
| Combined Cycle Siemens 5000F CT | 150 | 205 | 260 | 315 | 370 | 425 | 480 | 535 | 590 | 645 | 700 |
| Humid Air Turbine Cycle CT | 138 | 215 | 293 | 370 | 448 | 525 | 602 | 680 | 757 | 835 | 912 |
| Kalina Cycle CC CT | 147 | 194 | 241 | 287 | 334 | 381 | 428 | 474 | 521 | 568 | 615 |
| Cheng Cycle CT | 153 | 209 | 265 | 320 | 376 | 432 | 488 | 544 | 600 | 656 | 712 |
| Peaking Microturbine | 446 | 585 | 724 | 863 | 1001 | 1140 | 1279 | 1418 | 1556 | 1695 | 1834 |
| Baseload Microturbine | 477 | 585 | 694 | 803 | 912 | 1021 | 1129 | 1238 | 1347 | 1456 | 1564 |
| Subcritical Pulverized Coal - 256 MW | 358 | 382 | 405 | 429 | 453 | 477 | 500 | 524 | 548 | 572 | 595 |
| Subcritical Pulverized Coal - 512 MW | 319 | 342 | 366 | 389 | 413 | 436 | 460 | 483 | 507 | 530 | 554 |
| Circulating Fluidized Bed - 2x 250 MW | 294 | 323 | 353 | 382 | 412 | 441 | 471 | 500 | 530 | 559 | 589 |
| Supercritical Pulverized Coal - 565 MW | 324 | 349 | 374 | 399 | 424 | 449 | 474 | 499 | 524 | 549 | 574 |
| Supercritical Pulverized Coal-800 MW | 284 | 308 | 332 | 356 | 380 | 404 | 428 | 452 | 477 | 501 | 525 |
| Pressurized Fluidized Bed Combustion | 367 | 390 | 413 | 437 | 460 | 483 | 506 | 529 | 552 | --- | --- |
| 1x1 IGCC | 358 | 380 | 402 | 423 | 445 | 467 | 489 | 510 | 532 | --- | --- |
| 2x1 IGCC | 399 | 420 | 441 | 462 | 483 | 504 | 525 | 546 | 568 | --- | --- |
| Subcritical Pulverized Coal - 502 MW - CCS | 561 | 595 | 629 | 663 | 698 | 732 | 766 | 800 | 835 | 869 | 903 |
| Circulating Fluidized Bed - CC | 502 | 541 | 580 | 619 | 658 | 696 | 735 | 774 | 813 | 852 | 891 |
| Supercritical Pulverized Coal - 565 MW - CCS | 471 | 509 | 546 | 583 | 621 | 658 | 696 | 733 | 770 | 808 | 845 |
| Supercritical Pulverized Coal - 800 MW - CCS | 413 | 442 | 471 | 499 | 528 | 557 | 586 | 614 | 643 | 672 | 701 |
| 1x1 IGCC - CCS | 510 | 536 | 562 | 588 | 614 | 640 | 666 | 692 | 718 | --- | --- |
| 2x1 IGCC - CC | 459 | 483 | 508 | 532 | 557 | 582 | 606 | 631 | 656 | --- | --- |
| Wind Energy Conversion | 257 | 254 | 251 | 248 | --- | --- | --- | --- | --- | --- | --- |
| Solar Photovoltaic | 580 | 580 | --- | --- | --- | --- | --- | --- | --- | --- | --- |
| Solar Thermal, Parabolic Trough | 655 | 656 | --- | --- | --- | --- | --- | --- | --- | --- | --- |
| Solar Thermal, Power Tower w Storage | 829 | 829 | 830 | 830 | --- | --- | --- | --- | --- | --- | --- |
| Solar Thermal, Parabolic Dish | 764 | 764 | --- | --- | --- | --- | --- | --- | --- | --- | --- |
| Solar Thermal, Central Receiver | 808 | 809 | 810 | 811 | 812 | 812 | 813 | --- | --- | --- | --- |
| Solar Thermal, Solar Chimney | 673 | 673 | 673 | 673 | --- | --- | --- | --- | --- | --- | --- |
| MSW Mass Burn | 1809 | 1781 | 1753 | 1724 | 1696 | 1668 | 1640 | 1611 | --- | --- | --- |
| RDF Stoker-Fired | 1723 | 1801 | 1878 | 1956 | 2033 | 2111 | 2188 | 2266 | 2343 | --- | --- |
| Wood Fired Stoker Plant | 493 | 523 | 552 | 581 | 611 | 640 | 670 | 699 | 728 | --- | --- |
| Landfill Gas IC Engine | 275 | 298 | 321 | 343 | 366 | 389 | 411 | 434 | 457 | 480 | --- |
| TDF Multi-Fuel CFB (10% Co-fire) | 514 | 541 | 568 | 594 | 621 | 647 | 674 | 700 | 727 | 754 | 780 |
| Sewage Sludge & Anaerobic Digestion | 735 | 730 | 725 | 719 | 714 | 709 | 704 | 698 | 693 | 688 | --- |
| Bio Mass (Co-Fire) | 387 | 408 | 429 | 450 | 471 | 492 | 513 | 534 | 555 | 576 | 597 |
| Wood-Fired CFBC | 506 | 529 | 553 | 576 | 599 | 623 | 646 | 669 | 693 | 716 | 740 |
| Co-Fired CFBC | 620 | 663 | 706 | 750 | 793 | 836 | 879 | 923 | 966 | 1009 | 1053 |
| Molten Carbonate Fuel Cell | 267 | 314 | 360 | 407 | 454 | 500 | 547 | 593 | 640 | 686 | --- |
| Solid Oxide Fuel Cell | 172 | 217 | 261 | 306 | 350 | 394 | 439 | 483 | 527 | 572 | --- |
| Spark Ignition Engine | 425 | 491 | 557 | 623 | 689 | 755 | 821 | 887 | 953 | 1019 | --- |
| Hydroelectric - New - 30 MW | 493 | 487 | 482 | 476 | 471 | --- | --- | --- | --- | --- | --- |
| Hydroelectric - 50 MW Bulb Unit | 434 | 428 | 423 | 418 | 412 | --- | --- | --- | --- | --- | --- |
| Hydroelectric - 25 MW Bulb Units | 566 | 560 | 555 | 550 | 544 | --- | --- | --- | --- | --- | --- |
| Hydroelectric - 50 MW Kaplan Unit | 532 | 526 | 521 | 516 | 510 | --- | --- | --- | --- | --- | --- |
| Hydroelectric - 50 MW Propeller Unit | 503 | 498 | 492 | 487 | 481 | --- | --- | --- | --- | --- | --- |
| Minimum Levelized \$/kW | 95 | 153 | 204 | 248 | 307 | 358 | 409 | 434 | 457 | 480 | 525 |

Levelized Dollars at Various Capacity Factors With SO2 Adders, without CO2 Adders, and with NOx Adders

Capital Cost- Base
Heat Rate- Base
Fuel Forecast- High

2010 (\$/kW yr)

| Technology | Capacity Factors | | | | | | | | | | |
|--|------------------|------|------|------|------|------|------|------|------|------|------|
| | 0% | 10% | 20% | 30% | 40% | 50% | 60% | 70% | 80% | 90% | 100% |
| Pumped Hydro Energy Storage | 186 | 231 | 275 | --- | --- | --- | --- | --- | --- | --- | --- |
| Advanced Battery Energy Storage | 156 | 207 | 259 | --- | --- | --- | --- | --- | --- | --- | --- |
| Compressed Air Energy Storage | 145 | 214 | 283 | --- | --- | --- | --- | --- | --- | --- | --- |
| Simple Cycle GE LM6000 CT | 142 | 246 | 351 | 456 | 561 | 666 | 771 | 875 | 980 | 1085 | 1190 |
| Simple Cycle GE 7EA CT | 115 | 243 | 370 | 497 | 625 | 752 | 879 | 1007 | 1134 | 1261 | 1388 |
| Simple Cycle GE 7FA CT | 95 | 195 | 296 | 396 | 496 | 596 | 696 | 796 | 896 | 996 | 1096 |
| Combined Cycle GE 7EA CT | 209 | 284 | 359 | 435 | 510 | 585 | 661 | 736 | 811 | 887 | 962 |
| Combined Cycle 1x1 7F-Class | 149 | 212 | 274 | 337 | 399 | 462 | 525 | 587 | 650 | 712 | 775 |
| Combined Cycle 1x1 G-Class CT | 127 | 189 | 251 | 313 | 374 | 436 | 498 | 560 | 621 | 683 | 745 |
| Combined Cycle 2x1 7F-Class CT | 109 | 170 | 232 | 294 | 356 | 418 | 480 | 542 | 604 | 666 | 727 |
| Combined Cycle 3x1 7F-Class CT | 102 | 163 | 225 | 287 | 349 | 410 | 472 | 534 | 596 | 657 | 719 |
| Combined Cycle Siemens 5000F CT | 150 | 216 | 282 | 348 | 414 | 480 | 546 | 612 | 677 | 743 | 809 |
| Humid Air Turbine Cycle CT | 138 | 231 | 325 | 418 | 512 | 605 | 699 | 792 | 885 | 979 | 1072 |
| Kalina Cycle CC CT | 147 | 204 | 260 | 317 | 373 | 430 | 487 | 543 | 600 | 656 | 713 |
| Cheng Cycle CT | 153 | 220 | 287 | 354 | 421 | 489 | 556 | 623 | 690 | 757 | 825 |
| Peaking Microturbine | 446 | 608 | 769 | 930 | 1091 | 1253 | 1414 | 1575 | 1737 | 1898 | 2059 |
| Baseload Microturbine | 477 | 608 | 739 | 871 | 1002 | 1133 | 1264 | 1396 | 1527 | 1658 | 1790 |
| Subcritical Pulverized Coal - 256 MW | 358 | 386 | 415 | 443 | 471 | 500 | 528 | 556 | 585 | 613 | 641 |
| Subcritical Pulverized Coal - 512 MW | 319 | 347 | 375 | 403 | 431 | 459 | 487 | 515 | 543 | 571 | 599 |
| Circulating Fluidized Bed - 2x 250 MW | 294 | 328 | 363 | 397 | 432 | 466 | 501 | 535 | 570 | 604 | 639 |
| Supercritical Pulverized Coal - 565 MW | 324 | 354 | 383 | 413 | 442 | 472 | 501 | 530 | 560 | 589 | 619 |
| Supercritical Pulverized Coal-800 MW | 284 | 312 | 341 | 369 | 398 | 427 | 455 | 484 | 512 | 541 | 570 |
| Pressurized Fluidized Bed Combustion | 367 | 395 | 422 | 450 | 478 | 505 | 533 | 561 | 588 | --- | --- |
| 1x1 IGCC | 358 | 384 | 410 | 436 | 462 | 488 | 514 | 540 | 566 | --- | --- |
| 2x1 IGCC | 399 | 424 | 450 | 475 | 501 | 526 | 552 | 577 | 603 | --- | --- |
| Subcritical Pulverized Coal - 502 MW - CCS | 561 | 601 | 642 | 683 | 723 | 764 | 805 | 845 | 886 | 926 | 967 |
| Circulating Fluidized Bed - CC | 502 | 548 | 594 | 639 | 685 | 731 | 777 | 823 | 869 | 915 | 961 |
| Supercritical Pulverized Coal - 565 MW - CCS | 471 | 515 | 559 | 602 | 646 | 690 | 734 | 777 | 821 | 865 | 909 |
| Supercritical Pulverized Coal - 800 MW - CCS | 413 | 446 | 479 | 513 | 546 | 579 | 613 | 646 | 679 | 712 | 746 |
| 1x1 IGCC - CCS | 510 | 541 | 572 | 603 | 634 | 665 | 696 | 727 | 758 | --- | --- |
| 2x1 IGCC - CC | 459 | 488 | 518 | 548 | 578 | 608 | 638 | 667 | 697 | --- | --- |
| Wind Energy Conversion | 257 | 254 | 251 | 248 | --- | --- | --- | --- | --- | --- | --- |
| Solar Photovoltaic | 580 | 580 | --- | --- | --- | --- | --- | --- | --- | --- | --- |
| Solar Thermal, Parabolic Trough | 655 | 656 | --- | --- | --- | --- | --- | --- | --- | --- | --- |
| Solar Thermal, Power Tower w Storage | 829 | 829 | 830 | 830 | --- | --- | --- | --- | --- | --- | --- |
| Solar Thermal, Parabolic Dish | 764 | 764 | --- | --- | --- | --- | --- | --- | --- | --- | --- |
| Solar Thermal, Central Receiver | 808 | 809 | 810 | 811 | 812 | 812 | 813 | --- | --- | --- | --- |
| Solar Thermal, Solar Chimney | 673 | 673 | 673 | 673 | --- | --- | --- | --- | --- | --- | --- |
| MSW Mass Burn | 1809 | 1766 | 1723 | 1681 | 1638 | 1595 | 1552 | 1509 | --- | --- | --- |
| RDF Stoker-Fired | 1723 | 1816 | 1909 | 2002 | 2095 | 2188 | 2281 | 2374 | 2467 | --- | --- |
| Wood Fired Stoker Plant | 493 | 529 | 566 | 602 | 638 | 674 | 710 | 746 | 782 | --- | --- |
| Landfill Gas IC Engine | 275 | 353 | 431 | 509 | 586 | 664 | 742 | 820 | 898 | 975 | --- |
| TDF Multi-Fuel CFB (10% Co-fire) | 514 | 546 | 578 | 610 | 642 | 673 | 705 | 737 | 769 | 801 | 832 |
| Sewage Sludge & Anaerobic Digestion | 735 | 730 | 725 | 720 | 714 | 709 | 704 | 698 | 693 | 688 | --- |
| Bio Mass (Co-Fire) | 387 | 412 | 437 | 463 | 488 | 514 | 539 | 564 | 590 | 615 | 640 |
| Wood-Fired CFBC | 506 | 535 | 564 | 594 | 623 | 652 | 681 | 711 | 740 | 769 | 799 |
| Co-Fired CFBC | 620 | 670 | 720 | 770 | 820 | 870 | 920 | 970 | 1020 | 1069 | 1119 |
| Molten Carbonate Fuel Cell | 267 | 322 | 377 | 432 | 487 | 542 | 597 | 652 | 707 | 762 | --- |
| Solid Oxide Fuel Cell | 172 | 227 | 281 | 335 | 389 | 444 | 498 | 552 | 606 | 661 | --- |
| Spark Ignition Engine | 425 | 506 | 586 | 667 | 748 | 829 | 909 | 990 | 1071 | 1152 | --- |
| Hydroelectric - New - 30 MW | 493 | 487 | 482 | 476 | 471 | --- | --- | --- | --- | --- | --- |
| Hydroelectric - 50 MW Bulb Unit | 434 | 428 | 423 | 418 | 412 | --- | --- | --- | --- | --- | --- |
| Hydroelectric - 25 MW Bulb Units | 566 | 560 | 555 | 550 | 544 | --- | --- | --- | --- | --- | --- |
| Hydroelectric - 50 MW Kaplan Unit | 532 | 526 | 521 | 516 | 510 | --- | --- | --- | --- | --- | --- |
| Hydroelectric - 50 MW Propeller Unit | 503 | 498 | 492 | 487 | 481 | --- | --- | --- | --- | --- | --- |
| Minimum Levelized \$/kW | 95 | 163 | 225 | 248 | 349 | 410 | 455 | 484 | 512 | 541 | 570 |

Levelized Dollars at Various Capacity Factors With SO2 Adders, without CO2 Adders, and with NOx Adders

| Technology | 2010 (\$/kW yr) | | | | | | | | | | |
|--|-----------------|------|------|------|------|------|------|------|------|------|------|
| | 0% | 10% | 20% | 30% | 40% | 50% | 60% | 70% | 80% | 90% | 100% |
| Pumped Hydro Energy Storage | 186 | 224 | 261 | --- | --- | --- | --- | --- | --- | --- | --- |
| Advanced Battery Energy Storage | 156 | 201 | 246 | --- | --- | --- | --- | --- | --- | --- | --- |
| Compressed Air Energy Storage | 145 | 203 | 261 | --- | --- | --- | --- | --- | --- | --- | --- |
| Simple Cycle GE LM6000 CT | 142 | 236 | 330 | 424 | 517 | 611 | 705 | 799 | 892 | 986 | 1080 |
| Simple Cycle GE 7EA CT | 116 | 229 | 343 | 456 | 569 | 682 | 796 | 909 | 1022 | 1135 | 1249 |
| Simple Cycle GE 7FA CT | 96 | 184 | 273 | 361 | 449 | 538 | 626 | 714 | 802 | 891 | 979 |
| Combined Cycle GE 7EA CT | 210 | 275 | 341 | 407 | 472 | 538 | 604 | 669 | 735 | 800 | 866 |
| Combined Cycle 1x1 7F-Class | 150 | 204 | 259 | 313 | 368 | 422 | 477 | 531 | 585 | 640 | 694 |
| Combined Cycle 1x1 G-Class CT | 128 | 182 | 235 | 289 | 343 | 397 | 450 | 504 | 558 | 611 | 665 |
| Combined Cycle 2x1 7F-Class CT | 109 | 163 | 217 | 271 | 324 | 378 | 432 | 486 | 539 | 593 | 647 |
| Combined Cycle 3x1 7F-Class CT | 103 | 156 | 210 | 263 | 317 | 371 | 424 | 478 | 532 | 585 | 639 |
| Combined Cycle Siemens 5000F CT | 152 | 209 | 266 | 324 | 381 | 438 | 496 | 553 | 611 | 668 | 725 |
| Humid Air Turbine Cycle CT | 140 | 221 | 302 | 383 | 464 | 545 | 626 | 707 | 788 | 869 | 950 |
| Kalina Cycle CC CT | 148 | 197 | 246 | 295 | 344 | 393 | 442 | 491 | 540 | 589 | 638 |
| Cheng Cycle CT | 154 | 212 | 271 | 329 | 388 | 446 | 505 | 563 | 622 | 680 | 739 |
| Peaking Microturbine | 447 | 591 | 735 | 879 | 1023 | 1166 | 1310 | 1454 | 1598 | 1742 | 1886 |
| Baseload Microturbine | 479 | 593 | 707 | 821 | 934 | 1048 | 1162 | 1276 | 1390 | 1504 | 1618 |
| Subcritical Pulverized Coal - 256 MW | 358 | 383 | 407 | 432 | 457 | 482 | 507 | 531 | 556 | 581 | 606 |
| Subcritical Pulverized Coal - 512 MW | 319 | 343 | 368 | 392 | 417 | 441 | 466 | 490 | 515 | 539 | 564 |
| Circulating Fluidized Bed - 2x 250 MW | 294 | 325 | 355 | 386 | 416 | 447 | 478 | 508 | 539 | 569 | 600 |
| Supercritical Pulverized Coal - 565 MW | 324 | 350 | 376 | 402 | 428 | 454 | 480 | 506 | 532 | 558 | 584 |
| Supercritical Pulverized Coal-800 MW | 284 | 309 | 334 | 359 | 384 | 409 | 434 | 460 | 485 | 510 | 535 |
| Pressurized Fluidized Bed Combustion | 367 | 391 | 415 | 440 | 464 | 488 | 512 | 536 | 561 | --- | --- |
| 1x1 IGCC | 358 | 381 | 404 | 426 | 449 | 472 | 494 | 517 | 540 | --- | --- |
| 2x1 IGCC | 399 | 421 | 443 | 465 | 487 | 509 | 531 | 553 | 576 | --- | --- |
| Subcritical Pulverized Coal - 502 MW - CCS | 561 | 596 | 632 | 668 | 703 | 739 | 775 | 810 | 846 | 882 | 918 |
| Circulating Fluidized Bed - CC | 502 | 542 | 583 | 623 | 664 | 704 | 745 | 785 | 826 | 866 | 907 |
| Supercritical Pulverized Coal - 565 MW - CCS | 471 | 510 | 549 | 588 | 627 | 665 | 704 | 743 | 782 | 821 | 860 |
| Supercritical Pulverized Coal - 800 MW - CCS | 413 | 443 | 473 | 502 | 532 | 562 | 592 | 622 | 651 | 681 | 711 |
| 1x1 IGCC - CCS | 510 | 537 | 564 | 591 | 619 | 646 | 673 | 700 | 727 | --- | --- |
| 2x1 IGCC - CC | 459 | 484 | 510 | 536 | 562 | 588 | 613 | 639 | 665 | --- | --- |
| Wind Energy Conversion | 257 | 254 | 251 | 248 | --- | --- | --- | --- | --- | --- | --- |
| Solar Photovoltaic | 580 | 580 | --- | --- | --- | --- | --- | --- | --- | --- | --- |
| Solar Thermal, Parabolic Trough | 655 | 656 | --- | --- | --- | --- | --- | --- | --- | --- | --- |
| Solar Thermal, Power Tower w Storage | 829 | 829 | 830 | 830 | --- | --- | --- | --- | --- | --- | --- |
| Solar Thermal, Parabolic Dish | 764 | 764 | --- | --- | --- | --- | --- | --- | --- | --- | --- |
| Solar Thermal, Central Receiver | 808 | 809 | 810 | 811 | 812 | 812 | 813 | --- | --- | --- | --- |
| Solar Thermal, Solar Chimney | 673 | 673 | 673 | 673 | --- | --- | --- | --- | --- | --- | --- |
| MSW Mass Burn | 1809 | 1777 | 1746 | 1714 | 1683 | 1651 | 1620 | 1588 | --- | --- | --- |
| RDF Stoker-Fired | 1723 | 1804 | 1885 | 1966 | 2047 | 2128 | 2209 | 2290 | 2371 | --- | --- |
| Wood Fired Stoker Plant | 493 | 524 | 555 | 586 | 617 | 648 | 679 | 710 | 740 | --- | --- |
| Landfill Gas IC Engine | 275 | 299 | 322 | 345 | 368 | 391 | 415 | 438 | 461 | 484 | --- |
| TDF Multi-Fuel CFB (10% Co-fire) | 514 | 542 | 570 | 598 | 625 | 653 | 681 | 709 | 736 | 764 | 792 |
| Sewage Sludge & Anaerobic Digestion | 735 | 730 | 725 | 719 | 714 | 709 | 704 | 698 | 693 | 688 | --- |
| Bio Mass (Co-Fire) | 387 | 409 | 431 | 453 | 475 | 497 | 519 | 541 | 563 | 585 | 607 |
| Wood-Fired CFBC | 506 | 530 | 555 | 580 | 605 | 629 | 654 | 679 | 703 | 728 | 753 |
| Co-Fired CFBC | 620 | 665 | 709 | 754 | 799 | 844 | 888 | 933 | 978 | 1023 | 1068 |
| Molten Carbonate Fuel Cell | 268 | 317 | 365 | 414 | 462 | 511 | 559 | 607 | 656 | 704 | --- |
| Solid Oxide Fuel Cell | 173 | 220 | 267 | 313 | 360 | 406 | 453 | 500 | 546 | 593 | --- |
| Spark Ignition Engine | 427 | 496 | 565 | 635 | 704 | 773 | 843 | 912 | 981 | 1051 | --- |
| Hydroelectric - New - 30 MW | 493 | 487 | 482 | 476 | 471 | --- | --- | --- | --- | --- | --- |
| Hydroelectric - 50 MW Bulb Unit | 434 | 428 | 423 | 418 | 412 | --- | --- | --- | --- | --- | --- |
| Hydroelectric - 25 MW Bulb Units | 566 | 560 | 555 | 550 | 544 | --- | --- | --- | --- | --- | --- |
| Hydroelectric - 50 MW Kaplan Unit | 532 | 526 | 521 | 516 | 510 | --- | --- | --- | --- | --- | --- |
| Hydroelectric - 50 MW Propeller Unit | 503 | 498 | 492 | 487 | 481 | --- | --- | --- | --- | --- | --- |
| Minimum Levelized \$/kW | 96 | 156 | 210 | 248 | 317 | 371 | 415 | 438 | 461 | 484 | 535 |

Levelized Dollars at Various Capacity Factors With SO2 Adders, without CO2 Adders, and with NOx Adders

Capital Cost- Base

2010 (\$/kW yr)

Heat Rate- High

Fuel Forecast- Base

Capacity Factors

| Technology | 0% | 10% | 20% | 30% | 40% | 50% | 60% | 70% | 80% | 90% | 100% |
|--|------|------|------|------|------|------|------|------|------|------|------|
| Pumped Hydro Energy Storage | 186 | 227 | 268 | --- | --- | --- | --- | --- | --- | --- | --- |
| Advanced Battery Energy Storage | 156 | 204 | 252 | --- | --- | --- | --- | --- | --- | --- | --- |
| Compressed Air Energy Storage | 145 | 209 | 274 | --- | --- | --- | --- | --- | --- | --- | --- |
| Simple Cycle GE LM6000 CT | 142 | 243 | 345 | 446 | 547 | 648 | 750 | 851 | 952 | 1054 | 1155 |
| Simple Cycle GE 7EA CT | 116 | 239 | 362 | 484 | 607 | 730 | 853 | 976 | 1098 | 1221 | 1344 |
| Simple Cycle GE 7FA CT | 96 | 192 | 289 | 385 | 481 | 577 | 674 | 770 | 866 | 963 | 1059 |
| Combined Cycle GE 7EA CT | 210 | 282 | 354 | 426 | 499 | 571 | 643 | 715 | 787 | 860 | 932 |
| Combined Cycle 1x1 7F-Class | 150 | 210 | 270 | 330 | 390 | 450 | 510 | 570 | 630 | 689 | 749 |
| Combined Cycle 1x1 G-Class CT | 128 | 187 | 246 | 305 | 365 | 424 | 483 | 542 | 601 | 661 | 720 |
| Combined Cycle 2x1 7F-Class CT | 109 | 169 | 228 | 287 | 346 | 406 | 465 | 524 | 583 | 643 | 702 |
| Combined Cycle 3x1 7F-Class CT | 103 | 162 | 221 | 280 | 339 | 398 | 457 | 516 | 575 | 635 | 694 |
| Combined Cycle Siemens 5000F CT | 152 | 215 | 278 | 341 | 404 | 467 | 530 | 594 | 657 | 720 | 783 |
| Humid Air Turbine Cycle CT | 140 | 229 | 319 | 408 | 497 | 587 | 676 | 766 | 855 | 945 | 1034 |
| Kalina Cycle CC CT | 148 | 202 | 256 | 311 | 365 | 419 | 473 | 527 | 581 | 635 | 689 |
| Cheng Cycle CT | 154 | 218 | 283 | 347 | 411 | 476 | 540 | 605 | 669 | 733 | 798 |
| Peaking Microturbine | 447 | 603 | 758 | 914 | 1070 | 1225 | 1381 | 1537 | 1692 | 1848 | 2004 |
| Baseload Microturbine | 479 | 605 | 730 | 856 | 982 | 1107 | 1233 | 1359 | 1484 | 1610 | 1736 |
| Subcritical Pulverized Coal - 256 MW | 358 | 385 | 412 | 440 | 467 | 494 | 521 | 548 | 575 | 603 | 630 |
| Subcritical Pulverized Coal - 512 MW | 319 | 346 | 373 | 399 | 426 | 453 | 480 | 507 | 534 | 561 | 588 |
| Circulating Fluidized Bed - 2x 250 MW | 294 | 327 | 360 | 394 | 427 | 460 | 493 | 527 | 560 | 593 | 626 |
| Supercritical Pulverized Coal - 565 MW | 324 | 353 | 381 | 409 | 438 | 466 | 494 | 523 | 551 | 579 | 608 |
| Supercritical Pulverized Coal-800 MW | 284 | 311 | 339 | 366 | 393 | 421 | 448 | 476 | 503 | 531 | 558 |
| Pressurized Fluidized Bed Combustion | 367 | 394 | 420 | 447 | 473 | 500 | 526 | 553 | 579 | --- | --- |
| 1x1 IGCC | 358 | 383 | 408 | 433 | 458 | 483 | 508 | 532 | 557 | --- | --- |
| 2x1 IGCC | 399 | 423 | 447 | 472 | 496 | 521 | 545 | 570 | 594 | --- | --- |
| Subcritical Pulverized Coal - 502 MW - CCS | 561 | 600 | 639 | 678 | 717 | 756 | 795 | 834 | 873 | 912 | 951 |
| Circulating Fluidized Bed - CC | 502 | 546 | 590 | 634 | 678 | 722 | 767 | 811 | 855 | 899 | 943 |
| Supercritical Pulverized Coal - 565 MW - CCS | 471 | 513 | 555 | 598 | 640 | 682 | 724 | 766 | 808 | 851 | 893 |
| Supercritical Pulverized Coal - 800 MW - CCS | 413 | 445 | 477 | 509 | 542 | 574 | 606 | 638 | 670 | 702 | 734 |
| 1x1 IGCC - CCS | 510 | 540 | 569 | 599 | 629 | 659 | 689 | 718 | 748 | --- | --- |
| 2x1 IGCC - CC | 459 | 487 | 516 | 544 | 573 | 601 | 630 | 658 | 687 | --- | --- |
| Wind Energy Conversion | 257 | 254 | 251 | 248 | --- | --- | --- | --- | --- | --- | --- |
| Solar Photovoltaic | 580 | 580 | --- | --- | --- | --- | --- | --- | --- | --- | --- |
| Solar Thermal, Parabolic Trough | 655 | 656 | --- | --- | --- | --- | --- | --- | --- | --- | --- |
| Solar Thermal, Power Tower w Storage | 829 | 829 | 830 | 830 | --- | --- | --- | --- | --- | --- | --- |
| Solar Thermal, Parabolic Dish | 764 | 764 | --- | --- | --- | --- | --- | --- | --- | --- | --- |
| Solar Thermal, Central Receiver | 808 | 809 | 810 | 811 | 812 | 812 | 813 | --- | --- | --- | --- |
| Solar Thermal, Solar Chimney | 673 | 673 | 673 | 673 | --- | --- | --- | --- | --- | --- | --- |
| MSW Mass Burn | 1809 | 1770 | 1731 | 1692 | 1652 | 1613 | 1574 | 1535 | --- | --- | --- |
| RDF Stoker-Fired | 1723 | 1812 | 1901 | 1991 | 2080 | 2169 | 2258 | 2347 | 2436 | --- | --- |
| Wood Fired Stoker Plant | 493 | 528 | 562 | 597 | 631 | 666 | 700 | 734 | 769 | --- | --- |
| Landfill Gas IC Engine | 275 | 323 | 370 | 417 | 465 | 512 | 559 | 607 | 654 | 701 | --- |
| TDF Multi-Fuel CFB (10% Co-fire) | 514 | 545 | 575 | 606 | 636 | 667 | 697 | 728 | 758 | 789 | 819 |
| Sewage Sludge & Anaerobic Digestion | 735 | 730 | 725 | 720 | 714 | 709 | 704 | 698 | 693 | 688 | --- |
| Bio Mass (Co-Fire) | 387 | 411 | 435 | 460 | 484 | 508 | 532 | 557 | 581 | 605 | 630 |
| Wood-Fired CFBC | 506 | 534 | 561 | 589 | 617 | 645 | 673 | 700 | 728 | 756 | 784 |
| Co-Fired CFBC | 620 | 668 | 716 | 765 | 813 | 861 | 910 | 958 | 1006 | 1054 | 1103 |
| Molten Carbonate Fuel Cell | 268 | 321 | 374 | 427 | 480 | 533 | 586 | 639 | 691 | 744 | --- |
| Solid Oxide Fuel Cell | 173 | 225 | 277 | 329 | 381 | 432 | 484 | 536 | 588 | 639 | --- |
| Spark Ignition Engine | 427 | 504 | 581 | 658 | 735 | 812 | 889 | 966 | 1043 | 1120 | --- |
| Hydroelectric - New - 30 MW | 493 | 487 | 482 | 476 | 471 | --- | --- | --- | --- | --- | --- |
| Hydroelectric - 50 MW Bulb Unit | 434 | 428 | 423 | 418 | 412 | --- | --- | --- | --- | --- | --- |
| Hydroelectric - 25 MW Bulb Units | 566 | 560 | 555 | 550 | 544 | --- | --- | --- | --- | --- | --- |
| Hydroelectric - 50 MW Kaplan Unit | 532 | 526 | 521 | 516 | 510 | --- | --- | --- | --- | --- | --- |
| Hydroelectric - 50 MW Propeller Unit | 503 | 498 | 492 | 487 | 481 | --- | --- | --- | --- | --- | --- |
| Minimum Levelized \$/kW | 96 | 162 | 221 | 248 | 339 | 398 | 448 | 476 | 503 | 531 | 558 |

Levelized Dollars at Various Capacity Factors With SO2 Adders, without CO2 Adders, and with NOx Adders

Capital Cost- Base
Heat Rate- High
Fuel Forecast- High

2010 (\$/kW yr)

| Technology | Capacity Factors | | | | | | | | | | |
|--|------------------|------|------|------|------|------|------|------|------|------|------|
| | 0% | 10% | 20% | 30% | 40% | 50% | 60% | 70% | 80% | 90% | 100% |
| Pumped Hydro Energy Storage | 186 | 231 | 275 | — | — | — | — | — | — | — | — |
| Advanced Battery Energy Storage | 156 | 207 | 259 | — | — | — | — | — | — | — | — |
| Compressed Air Energy Storage | 145 | 216 | 286 | — | — | — | — | — | — | — | — |
| Simple Cycle GE LM6000 CT | 142 | 251 | 360 | 468 | 577 | 686 | 795 | 903 | 1012 | 1121 | 1230 |
| Simple Cycle GE 7EA CT | 116 | 248 | 381 | 513 | 645 | 778 | 910 | 1042 | 1175 | 1307 | 1439 |
| Simple Cycle GE 7FA CT | 96 | 200 | 305 | 409 | 513 | 617 | 722 | 826 | 930 | 1035 | 1139 |
| Combined Cycle GE 7EA CT | 210 | 289 | 367 | 446 | 525 | 604 | 682 | 761 | 840 | 919 | 998 |
| Combined Cycle 1x1 7F-Class | 150 | 215 | 281 | 346 | 412 | 477 | 543 | 608 | 674 | 739 | 804 |
| Combined Cycle 1x1 G-Class CT | 128 | 193 | 257 | 322 | 387 | 451 | 516 | 580 | 645 | 710 | 774 |
| Combined Cycle 2x1 7F-Class CT | 109 | 174 | 239 | 304 | 368 | 433 | 498 | 563 | 627 | 692 | 757 |
| Combined Cycle 3x1 7F-Class CT | 103 | 167 | 232 | 296 | 361 | 426 | 490 | 555 | 619 | 684 | 749 |
| Combined Cycle Siemens 5000F CT | 152 | 220 | 289 | 358 | 427 | 496 | 565 | 634 | 703 | 772 | 841 |
| Humid Air Turbine Cycle CT | 140 | 237 | 335 | 433 | 531 | 629 | 727 | 825 | 922 | 1020 | 1118 |
| Kalina Cycle CC CT | 148 | 208 | 267 | 326 | 385 | 445 | 504 | 563 | 622 | 682 | 741 |
| Cheng Cycle CT | 154 | 224 | 294 | 365 | 435 | 505 | 576 | 646 | 716 | 787 | 857 |
| Peaking Microturbine | 447 | 615 | 782 | 950 | 1117 | 1285 | 1452 | 1620 | 1787 | 1955 | 2122 |
| Baseload Microturbine | 479 | 617 | 754 | 892 | 1029 | 1167 | 1304 | 1442 | 1579 | 1717 | 1854 |
| Subcritical Pulverized Coal - 256 MW | 358 | 388 | 417 | 447 | 476 | 506 | 536 | 565 | 595 | 624 | 654 |
| Subcritical Pulverized Coal - 512 MW | 319 | 348 | 377 | 407 | 436 | 465 | 494 | 524 | 553 | 582 | 611 |
| Circulating Fluidized Bed - 2x 250 MW | 294 | 330 | 366 | 402 | 437 | 473 | 509 | 545 | 581 | 617 | 653 |
| Supercritical Pulverized Coal - 565 MW | 324 | 355 | 386 | 416 | 447 | 478 | 508 | 539 | 570 | 601 | 631 |
| Supercritical Pulverized Coal-800 MW | 284 | 313 | 343 | 373 | 403 | 433 | 463 | 492 | 522 | 552 | 582 |
| Pressurized Fluidized Bed Combustion | 367 | 396 | 425 | 454 | 483 | 511 | 540 | 569 | 598 | — | — |
| 1x1 IGCC | 358 | 385 | 412 | 439 | 467 | 494 | 521 | 548 | 575 | — | — |
| 2x1 IGCC | 399 | 425 | 452 | 479 | 506 | 532 | 559 | 586 | 613 | — | — |
| Subcritical Pulverized Coal - 502 MW - CCS | 561 | 603 | 645 | 688 | 730 | 773 | 815 | 857 | 900 | 942 | 985 |
| Circulating Fluidized Bed - CC | 502 | 550 | 597 | 645 | 693 | 741 | 789 | 836 | 884 | 932 | 980 |
| Supercritical Pulverized Coal - 565 MW - CCS | 471 | 517 | 562 | 608 | 653 | 699 | 744 | 790 | 835 | 881 | 926 |
| Supercritical Pulverized Coal - 800 MW - CCS | 413 | 447 | 482 | 516 | 551 | 585 | 620 | 654 | 689 | 723 | 758 |
| 1x1 IGCC - CCS | 510 | 542 | 575 | 607 | 639 | 672 | 704 | 737 | 769 | — | — |
| 2x1 IGCC - CC | 459 | 490 | 521 | 552 | 584 | 615 | 646 | 677 | 709 | — | — |
| Wind Energy Conversion | 257 | 254 | 251 | 248 | — | — | — | — | — | — | — |
| Solar Photovoltaic | 580 | 580 | — | — | — | — | — | — | — | — | — |
| Solar Thermal, Parabolic Trough | 655 | 656 | — | — | — | — | — | — | — | — | — |
| Solar Thermal, Power Tower w Storage | 829 | 829 | 830 | 830 | — | — | — | — | — | — | — |
| Solar Thermal, Parabolic Dish | 764 | 764 | — | — | — | — | — | — | — | — | — |
| Solar Thermal, Central Receiver | 808 | 809 | 810 | 811 | 812 | 812 | 813 | — | — | — | — |
| Solar Thermal, Solar Chimney | 673 | 673 | 673 | 673 | — | — | — | — | — | — | — |
| MSW Mass Burn | 1809 | 1762 | 1715 | 1669 | 1622 | 1575 | 1528 | 1481 | — | — | — |
| RDF Stoker-Fired | 1723 | 1820 | 1918 | 2015 | 2112 | 2209 | 2306 | 2404 | 2501 | — | — |
| Wood Fired Stoker Plant | 493 | 531 | 569 | 607 | 645 | 683 | 721 | 759 | 797 | — | — |
| Landfill Gas IC Engine | 275 | 356 | 437 | 519 | 600 | 681 | 762 | 843 | 924 | 1005 | — |
| TDF Multi-Fuel CFB (10% Co-fire) | 514 | 548 | 581 | 614 | 647 | 681 | 714 | 747 | 780 | 813 | 847 |
| Sewage Sludge & Anaerobic Digestion | 735 | 730 | 725 | 720 | 714 | 709 | 704 | 699 | 693 | 688 | — |
| Bio Mass (Co-Fire) | 387 | 413 | 440 | 466 | 493 | 520 | 546 | 573 | 599 | 626 | 653 |
| Wood-Fired CFBC | 506 | 537 | 568 | 598 | 629 | 660 | 691 | 722 | 753 | 784 | 815 |
| Co-Fired CFBC | 620 | 672 | 723 | 775 | 827 | 879 | 931 | 982 | 1034 | 1086 | 1138 |
| Molten Carbonate Fuel Cell | 268 | 325 | 383 | 440 | 497 | 555 | 612 | 670 | 727 | 784 | — |
| Solid Oxide Fuel Cell | 173 | 230 | 287 | 344 | 401 | 458 | 515 | 572 | 629 | 686 | — |
| Spark Ignition Engine | 427 | 511 | 596 | 681 | 766 | 850 | 935 | 1020 | 1105 | 1190 | — |
| Hydroelectric - New - 30 MW | 493 | 487 | 482 | 476 | 471 | — | — | — | — | — | — |
| Hydroelectric - 50 MW Bulb Unit | 434 | 428 | 423 | 418 | 412 | — | — | — | — | — | — |
| Hydroelectric - 25 MW Bulb Units | 566 | 560 | 555 | 550 | 544 | — | — | — | — | — | — |
| Hydroelectric - 50 MW Kaplan Unit | 532 | 526 | 521 | 516 | 510 | — | — | — | — | — | — |
| Hydroelectric - 50 MW Propeller Unit | 503 | 498 | 492 | 487 | 481 | — | — | — | — | — | — |
| Minimum Levelized \$/kW | 96 | 167 | 232 | 248 | 361 | 426 | 463 | 492 | 522 | 552 | 582 |

Levelized Dollars at Various Capacity Factors With SO2 Adders, without CO2 Adders, and with NOx Adders

| Technology | 2010 (\$/kW yr) | | | | | | | | | | |
|--|------------------|------------|------------|------------|------------|------------|------------|------------|------------|------------|------------|
| | Capacity Factors | | | | | | | | | | |
| | 0% | 10% | 20% | 30% | 40% | 50% | 60% | 70% | 80% | 90% | 100% |
| Pumped Hydro Energy Storage | 249 | 287 | 324 | --- | --- | --- | --- | --- | --- | --- | --- |
| Advanced Battery Energy Storage | 195 | 240 | 284 | --- | --- | --- | --- | --- | --- | --- | --- |
| Compressed Air Energy Storage | 183 | 238 | 293 | --- | --- | --- | --- | --- | --- | --- | --- |
| Simple Cycle GE LM6000 CT | 162 | 249 | 337 | 424 | 511 | 599 | 686 | 774 | 861 | 948 | 1036 |
| Simple Cycle GE 7EA CT | 131 | 236 | 341 | 446 | 551 | 656 | 761 | 866 | 971 | 1076 | 1182 |
| Simple Cycle GE 7FA CT | 110 | 192 | 273 | 354 | 436 | 517 | 599 | 680 | 762 | 843 | 925 |
| Combined Cycle GE 7EA CT | 236 | 296 | 356 | 416 | 476 | 536 | 596 | 656 | 716 | 776 | 836 |
| Combined Cycle 1x1 7F-Class | 173 | 222 | 272 | 322 | 371 | 421 | 471 | 521 | 570 | 620 | 670 |
| Combined Cycle 1x1 G-Class CT | 147 | 196 | 245 | 294 | 343 | 392 | 441 | 490 | 539 | 588 | 638 |
| Combined Cycle 2x1 7F-Class CT | 125 | 174 | 223 | 272 | 321 | 370 | 419 | 468 | 517 | 566 | 616 |
| Combined Cycle 3x1 7F-Class CT | 117 | 165 | 214 | 263 | 312 | 361 | 410 | 459 | 508 | 557 | 606 |
| Combined Cycle Siemens 5000F CT | 170 | 223 | 275 | 328 | 380 | 433 | 485 | 538 | 590 | 642 | 695 |
| Humid Air Turbine Cycle CT | 155 | 228 | 302 | 376 | 450 | 524 | 598 | 671 | 745 | 819 | 893 |
| Kalina Cycle CC CT | 167 | 212 | 256 | 301 | 345 | 390 | 435 | 479 | 524 | 568 | 613 |
| Cheng Cycle CT | 173 | 227 | 280 | 334 | 387 | 441 | 494 | 547 | 601 | 654 | 708 |
| Peaking Microturbine | 492 | 626 | 759 | 893 | 1027 | 1160 | 1294 | 1428 | 1562 | 1695 | 1829 |
| Baseload Microturbine | 521 | 625 | 728 | 832 | 936 | 1039 | 1143 | 1247 | 1351 | 1454 | 1558 |
| Subcritical Pulverized Coal - 256 MW | 424 | 447 | 470 | 493 | 515 | 538 | 561 | 583 | 606 | 629 | 652 |
| Subcritical Pulverized Coal - 512 MW | 379 | 402 | 424 | 447 | 469 | 492 | 514 | 537 | 559 | 582 | 604 |
| Circulating Fluidized Bed - 2x 250 MW | 351 | 379 | 408 | 436 | 464 | 493 | 521 | 549 | 578 | 606 | 634 |
| Supercritical Pulverized Coal - 565 MW | 389 | 413 | 437 | 461 | 485 | 509 | 533 | 557 | 580 | 604 | 628 |
| Supercritical Pulverized Coal-800 MW | 340 | 363 | 386 | 410 | 433 | 456 | 479 | 502 | 525 | 548 | 571 |
| Pressurized Fluidized Bed Combustion | 464 | 486 | 508 | 530 | 553 | 575 | 597 | 619 | 641 | --- | --- |
| 1x1 IGCC | 445 | 466 | 487 | 508 | 529 | 549 | 570 | 591 | 612 | --- | --- |
| 2x1 IGCC | 489 | 509 | 529 | 549 | 569 | 590 | 610 | 630 | 650 | --- | --- |
| Subcritical Pulverized Coal - 502 MW - CCS | 727 | 759 | 792 | 825 | 858 | 891 | 923 | 956 | 989 | 1022 | 1055 |
| Circulating Fluidized Bed - CC | 638 | 675 | 713 | 750 | 788 | 825 | 862 | 900 | 937 | 974 | 1012 |
| Supercritical Pulverized Coal - 565 MW - CCS | 604 | 640 | 675 | 711 | 747 | 783 | 819 | 855 | 891 | 927 | 963 |
| Supercritical Pulverized Coal - 800 MW - CCS | 530 | 558 | 586 | 614 | 642 | 669 | 697 | 725 | 753 | 780 | 808 |
| 1x1 IGCC - CCS | 658 | 683 | 708 | 733 | 758 | 783 | 808 | 833 | 858 | --- | --- |
| 2x1 IGCC - CC | 581 | 605 | 628 | 652 | 675 | 699 | 722 | 746 | 769 | --- | --- |
| Wind Energy Conversion | 305 | 302 | 299 | 297 | --- | --- | --- | --- | --- | --- | --- |
| Solar Photovoltaic | 689 | 689 | --- | --- | --- | --- | --- | --- | --- | --- | --- |
| Solar Thermal, Parabolic Trough | 770 | 771 | --- | --- | --- | --- | --- | --- | --- | --- | --- |
| Solar Thermal, Power Tower w Storage | 979 | 979 | 980 | 980 | --- | --- | --- | --- | --- | --- | --- |
| Solar Thermal, Parabolic Dish | 901 | 901 | --- | --- | --- | --- | --- | --- | --- | --- | --- |
| Solar Thermal, Central Receiver | 938 | 939 | 940 | 941 | 942 | 943 | 944 | --- | --- | --- | --- |
| Solar Thermal, Solar Chimney | 790 | 790 | 790 | 790 | --- | --- | --- | --- | --- | --- | --- |
| MSW Mass Burn | 1917 | 1892 | 1867 | 1842 | 1817 | 1792 | 1767 | 1742 | --- | --- | --- |
| RDF Stoker-Fired | 1891 | 1965 | 2039 | 2113 | 2187 | 2261 | 2335 | 2409 | 2483 | --- | --- |
| Wood Fired Stoker Plant | 543 | 571 | 599 | 627 | 654 | 682 | 710 | 738 | 766 | --- | --- |
| Landfill Gas IC Engine | 305 | 327 | 350 | 372 | 394 | 416 | 438 | 460 | 482 | 505 | --- |
| TDF Multi-Fuel CFB (10% Co-fire) | 611 | 636 | 662 | 687 | 713 | 738 | 764 | 789 | 814 | 840 | 865 |
| Sewage Sludge & Anaerobic Digestion | 803 | 798 | 793 | 788 | 782 | 777 | 772 | 766 | 761 | 756 | --- |
| Bio Mass (Co-Fire) | 463 | 483 | 503 | 523 | 543 | 563 | 583 | 603 | 623 | 643 | 663 |
| Wood-Fired CFBC | 606 | 628 | 650 | 672 | 694 | 716 | 738 | 760 | 782 | 804 | 826 |
| Co-Fired CFBC | 746 | 788 | 830 | 872 | 914 | 955 | 997 | 1039 | 1081 | 1122 | 1164 |
| Molten Carbonate Fuel Cell | 314 | 359 | 403 | 448 | 493 | 537 | 582 | 627 | 671 | 716 | --- |
| Solid Oxide Fuel Cell | 198 | 240 | 282 | 325 | 367 | 409 | 451 | 493 | 535 | 578 | --- |
| Spark Ignition Engine | 440 | 503 | 566 | 629 | 691 | 754 | 817 | 880 | 942 | 1005 | --- |
| Hydroelectric - New - 30 MW | 647 | 642 | 636 | 631 | 625 | --- | --- | --- | --- | --- | --- |
| Hydroelectric - 50 MW Bulb Unit | 579 | 574 | 568 | 563 | 558 | --- | --- | --- | --- | --- | --- |
| Hydroelectric - 25 MW Bulb Units | 758 | 753 | 748 | 742 | 737 | --- | --- | --- | --- | --- | --- |
| Hydroelectric - 50 MW Kaplan Unit | 712 | 707 | 702 | 696 | 691 | --- | --- | --- | --- | --- | --- |
| Hydroelectric - 50 MW Propeller Unit | 674 | 669 | 664 | 658 | 653 | --- | --- | --- | --- | --- | --- |
| Minimum Levelized \$/kW | 110 | 165 | 214 | 263 | 312 | 361 | 410 | 459 | 482 | 505 | 571 |

Levelized Dollars at Various Capacity Factors With SO2 Adders, without CO2 Adders, and with NOx Adders

| Technology | 2010 (\$/kW yr) | | | | | | | | | | |
|--|-----------------|------------|------------|------------|------------|------------|------------|------------|------------|------------|------------|
| | 0% | 10% | 20% | 30% | 40% | 50% | 60% | 70% | 80% | 90% | 100% |
| Pumped Hydro Energy Storage | 249 | 290 | 331 | --- | --- | --- | --- | --- | --- | --- | --- |
| Advanced Battery Energy Storage | 195 | 243 | 291 | --- | --- | --- | --- | --- | --- | --- | --- |
| Compressed Air Energy Storage | 183 | 244 | 305 | --- | --- | --- | --- | --- | --- | --- | --- |
| Simple Cycle GE LM6000 CT | 162 | 256 | 350 | 444 | 539 | 633 | 727 | 821 | 915 | 1009 | 1103 |
| Simple Cycle GE 7EA CT | 131 | 245 | 358 | 472 | 586 | 699 | 813 | 927 | 1040 | 1154 | 1268 |
| Simple Cycle GE 7FA CT | 110 | 199 | 287 | 376 | 465 | 553 | 642 | 731 | 819 | 908 | 997 |
| Combined Cycle GE 7EA CT | 236 | 302 | 368 | 434 | 500 | 566 | 632 | 698 | 764 | 830 | 896 |
| Combined Cycle 1x1 7F-Class | 173 | 227 | 282 | 337 | 391 | 446 | 501 | 556 | 610 | 665 | 720 |
| Combined Cycle 1x1 G-Class CT | 147 | 201 | 255 | 309 | 363 | 417 | 471 | 525 | 579 | 633 | 687 |
| Combined Cycle 2x1 7F-Class CT | 125 | 179 | 233 | 287 | 341 | 395 | 449 | 503 | 557 | 611 | 665 |
| Combined Cycle 3x1 7F-Class CT | 117 | 170 | 224 | 278 | 332 | 386 | 440 | 494 | 548 | 601 | 655 |
| Combined Cycle Siemens 5000F CT | 170 | 228 | 286 | 343 | 401 | 459 | 516 | 574 | 632 | 689 | 747 |
| Humid Air Turbine Cycle CT | 155 | 236 | 317 | 399 | 480 | 562 | 643 | 725 | 806 | 887 | 969 |
| Kalina Cycle CC CT | 167 | 217 | 266 | 315 | 364 | 413 | 463 | 512 | 561 | 610 | 659 |
| Cheng Cycle CT | 173 | 232 | 291 | 350 | 409 | 467 | 526 | 585 | 644 | 702 | 761 |
| Peaking Microturbine | 492 | 636 | 781 | 925 | 1070 | 1214 | 1358 | 1503 | 1647 | 1792 | 1936 |
| Baseload Microturbine | 521 | 635 | 750 | 864 | 979 | 1093 | 1207 | 1322 | 1436 | 1551 | 1665 |
| Subcritical Pulverized Coal - 256 MW | 424 | 449 | 474 | 499 | 524 | 549 | 574 | 599 | 624 | 649 | 673 |
| Subcritical Pulverized Coal - 512 MW | 379 | 404 | 429 | 453 | 478 | 502 | 527 | 552 | 576 | 601 | 626 |
| Circulating Fluidized Bed - 2x 250 MW | 351 | 382 | 412 | 443 | 474 | 505 | 535 | 566 | 597 | 628 | 658 |
| Supercritical Pulverized Coal - 565 MW | 389 | 415 | 441 | 467 | 493 | 519 | 545 | 571 | 598 | 624 | 650 |
| Supercritical Pulverized Coal-800 MW | 340 | 365 | 391 | 416 | 441 | 466 | 492 | 517 | 542 | 567 | 593 |
| Pressurized Fluidized Bed Combustion | 464 | 488 | 513 | 537 | 561 | 585 | 610 | 634 | 658 | --- | --- |
| 1x1 IGCC | 445 | 468 | 491 | 514 | 537 | 559 | 582 | 605 | 628 | --- | --- |
| 2x1 IGCC | 489 | 511 | 533 | 556 | 578 | 600 | 622 | 645 | 667 | --- | --- |
| Subcritical Pulverized Coal - 502 MW - CCS | 727 | 762 | 798 | 834 | 870 | 906 | 942 | 978 | 1013 | 1049 | 1085 |
| Circulating Fluidized Bed - CC | 638 | 679 | 719 | 760 | 801 | 841 | 882 | 923 | 963 | 1004 | 1045 |
| Supercritical Pulverized Coal - 565 MW - CCS | 604 | 643 | 682 | 721 | 760 | 799 | 838 | 877 | 916 | 954 | 993 |
| Supercritical Pulverized Coal - 800 MW - CCS | 530 | 560 | 590 | 620 | 650 | 680 | 710 | 740 | 770 | 800 | 829 |
| 1x1 IGCC - CCS | 658 | 686 | 713 | 740 | 768 | 795 | 822 | 850 | 877 | --- | --- |
| 2x1 IGCC - CC | 581 | 607 | 633 | 659 | 685 | 711 | 737 | 763 | 789 | --- | --- |
| Wind Energy Conversion | 305 | 302 | 299 | 297 | --- | --- | --- | --- | --- | --- | --- |
| Solar Photovoltaic | 689 | 689 | --- | --- | --- | --- | --- | --- | --- | --- | --- |
| Solar Thermal, Parabolic Trough | 770 | 771 | --- | --- | --- | --- | --- | --- | --- | --- | --- |
| Solar Thermal, Power Tower w Storage | 979 | 979 | 980 | 980 | --- | --- | --- | --- | --- | --- | --- |
| Solar Thermal, Parabolic Dish | 901 | 901 | --- | --- | --- | --- | --- | --- | --- | --- | --- |
| Solar Thermal, Central Receiver | 938 | 939 | 940 | 941 | 942 | 943 | 944 | --- | --- | --- | --- |
| Solar Thermal, Solar Chimney | 790 | 790 | 790 | 790 | --- | --- | --- | --- | --- | --- | --- |
| MSW Mass Burn | 1917 | 1885 | 1853 | 1821 | 1790 | 1758 | 1726 | 1694 | --- | --- | --- |
| RDF Stoker-Fired | 1891 | 1972 | 2054 | 2135 | 2217 | 2298 | 2379 | 2461 | 2542 | --- | --- |
| Wood Fired Stoker Plant | 543 | 574 | 605 | 636 | 667 | 698 | 729 | 761 | 792 | --- | --- |
| Landfill Gas IC Engine | 305 | 349 | 393 | 437 | 481 | 525 | 569 | 613 | 657 | 701 | --- |
| TDF Multi-Fuel CFB (10% Co-fire) | 611 | 639 | 667 | 695 | 723 | 750 | 778 | 806 | 834 | 862 | 890 |
| Sewage Sludge & Anaerobic Digestion | 803 | 798 | 793 | 788 | 782 | 777 | 772 | 766 | 761 | 756 | --- |
| Bio Mass (Co-Fire) | 463 | 485 | 507 | 529 | 551 | 573 | 595 | 617 | 640 | 662 | 684 |
| Wood-Fired CFBC | 606 | 630 | 655 | 680 | 705 | 730 | 755 | 780 | 804 | 829 | 854 |
| Co-Fired CFBC | 746 | 791 | 836 | 881 | 926 | 971 | 1016 | 1061 | 1106 | 1151 | 1196 |
| Molten Carbonate Fuel Cell | 314 | 363 | 411 | 460 | 509 | 557 | 606 | 655 | 704 | 752 | --- |
| Solid Oxide Fuel Cell | 198 | 245 | 292 | 339 | 385 | 432 | 479 | 526 | 573 | 620 | --- |
| Spark Ignition Engine | 440 | 510 | 580 | 650 | 719 | 789 | 859 | 928 | 998 | 1068 | --- |
| Hydroelectric - New - 30 MW | 647 | 642 | 636 | 631 | 625 | --- | --- | --- | --- | --- | --- |
| Hydroelectric - 50 MW Bulb Unit | 579 | 574 | 568 | 563 | 558 | --- | --- | --- | --- | --- | --- |
| Hydroelectric - 25 MW Bulb Units | 758 | 753 | 748 | 742 | 737 | --- | --- | --- | --- | --- | --- |
| Hydroelectric - 50 MW Kaplan Unit | 712 | 707 | 702 | 696 | 691 | --- | --- | --- | --- | --- | --- |
| Hydroelectric - 50 MW Propeller Unit | 674 | 669 | 664 | 658 | 653 | --- | --- | --- | --- | --- | --- |
| Minimum Levelized \$/kW | 110 | 170 | 224 | 278 | 332 | 386 | 440 | 494 | 542 | 567 | 593 |

Levelized Dollars at Various Capacity Factors With SO2 Adders, without CO2 Adders, and with NOx Adders

| Capital Cost- High Heat Rate-Low Fuel Forecast- High | 2010 (\$/kW yr) | | | | | | | | | | |
|--|------------------|------|------|------|------|------|------|------|------|------|------|
| | Capacity Factors | | | | | | | | | | |
| Technology | 0% | 10% | 20% | 30% | 40% | 50% | 60% | 70% | 80% | 90% | 100% |
| Pumped Hydro Energy Storage | 249 | 293 | 338 | — | — | — | — | — | — | — | — |
| Advanced Battery Energy Storage | 195 | 246 | 297 | — | — | — | — | — | — | — | — |
| Compressed Air Energy Storage | 183 | 250 | 317 | — | — | — | — | — | — | — | — |
| Simple Cycle GE LM6000 CT | 162 | 263 | 364 | 465 | 566 | 667 | 767 | 868 | 969 | 1070 | 1171 |
| Simple Cycle GE 7EA CT | 131 | 253 | 375 | 498 | 620 | 742 | 865 | 987 | 1109 | 1232 | 1354 |
| Simple Cycle GE 7FA CT | 110 | 206 | 302 | 398 | 494 | 590 | 686 | 781 | 877 | 973 | 1069 |
| Combined Cycle GE 7EA CT | 236 | 308 | 380 | 452 | 524 | 596 | 668 | 740 | 811 | 883 | 955 |
| Combined Cycle 1x1 7F-Class | 173 | 232 | 292 | 352 | 411 | 471 | 531 | 590 | 650 | 710 | 769 |
| Combined Cycle 1x1 G-Class CT | 147 | 206 | 265 | 324 | 383 | 442 | 501 | 560 | 619 | 677 | 736 |
| Combined Cycle 2x1 7F-Class CT | 125 | 184 | 243 | 302 | 361 | 420 | 479 | 538 | 597 | 656 | 715 |
| Combined Cycle 3x1 7F-Class CT | 117 | 176 | 234 | 293 | 352 | 411 | 470 | 528 | 587 | 646 | 705 |
| Combined Cycle Siemens 5000F CT | 170 | 233 | 296 | 359 | 422 | 485 | 548 | 610 | 673 | 736 | 799 |
| Humid Air Turbine Cycle CT | 155 | 244 | 333 | 422 | 511 | 600 | 689 | 778 | 867 | 956 | 1045 |
| Kalina Cycle CC CT | 167 | 221 | 275 | 329 | 383 | 437 | 490 | 544 | 598 | 652 | 706 |
| Cheng Cycle CT | 173 | 238 | 302 | 366 | 430 | 494 | 558 | 622 | 686 | 750 | 815 |
| Peaking Microturbine | 492 | 647 | 802 | 957 | 1112 | 1267 | 1423 | 1578 | 1733 | 1888 | 2043 |
| Baseload Microturbine | 521 | 646 | 771 | 896 | 1021 | 1146 | 1272 | 1397 | 1522 | 1647 | 1772 |
| Subcritical Pulverized Coal - 256 MW | 424 | 452 | 479 | 506 | 533 | 560 | 587 | 614 | 641 | 668 | 695 |
| Subcritical Pulverized Coal - 512 MW | 379 | 406 | 433 | 460 | 486 | 513 | 540 | 567 | 594 | 620 | 647 |
| Circulating Fluidized Bed - 2x 250 MW | 351 | 384 | 417 | 450 | 484 | 517 | 550 | 583 | 616 | 649 | 682 |
| Supercritical Pulverized Coal - 565 MW | 389 | 417 | 445 | 474 | 502 | 530 | 558 | 586 | 615 | 643 | 671 |
| Supercritical Pulverized Coal-800 MW | 340 | 368 | 395 | 422 | 450 | 477 | 504 | 532 | 559 | 587 | 614 |
| Pressurized Fluidized Bed Combustion | 464 | 490 | 517 | 543 | 570 | 596 | 623 | 649 | 675 | — | — |
| 1x1 IGCC | 445 | 470 | 495 | 520 | 545 | 569 | 594 | 619 | 644 | — | — |
| 2x1 IGCC | 489 | 513 | 538 | 562 | 586 | 611 | 635 | 659 | 684 | — | — |
| Subcritical Pulverized Coal - 502 MW - CCS | 727 | 765 | 804 | 843 | 882 | 921 | 960 | 999 | 1038 | 1077 | 1115 |
| Circulating Fluidized Bed - CC | 638 | 682 | 726 | 770 | 814 | 858 | 902 | 946 | 990 | 1034 | 1078 |
| Supercritical Pulverized Coal - 565 MW - CCS | 604 | 646 | 688 | 730 | 772 | 814 | 856 | 898 | 940 | 982 | 1024 |
| Supercritical Pulverized Coal - 800 MW - CCS | 530 | 562 | 594 | 627 | 659 | 691 | 723 | 755 | 787 | 819 | 851 |
| 1x1 IGCC - CCS | 658 | 688 | 718 | 747 | 777 | 807 | 837 | 866 | 896 | — | — |
| 2x1 IGCC - CC | 581 | 610 | 638 | 667 | 695 | 723 | 752 | 780 | 809 | — | — |
| Wind Energy Conversion | 305 | 302 | 299 | 297 | — | — | — | — | — | — | — |
| Solar Photovoltaic | 689 | 689 | — | — | — | — | — | — | — | — | — |
| Solar Thermal, Parabolic Trough | 770 | 771 | — | — | — | — | — | — | — | — | — |
| Solar Thermal, Power Tower w Storage | 979 | 979 | 980 | 980 | — | — | — | — | — | — | — |
| Solar Thermal, Parabolic Dish | 901 | 901 | — | — | — | — | — | — | — | — | — |
| Solar Thermal, Central Receiver | 938 | 939 | 940 | 941 | 942 | 943 | 944 | — | — | — | — |
| Solar Thermal, Solar Chimney | 790 | 790 | 790 | 790 | — | — | — | — | — | — | — |
| MSW Mass Burn | 1917 | 1878 | 1840 | 1801 | 1762 | 1723 | 1684 | 1646 | — | — | — |
| RDF Stoker-Fired | 1891 | 1980 | 2069 | 2157 | 2246 | 2335 | 2423 | 2512 | 2601 | — | — |
| Wood Fired Stoker Plant | 543 | 577 | 612 | 646 | 680 | 715 | 749 | 783 | 817 | — | — |
| Landfill Gas IC Engine | 305 | 380 | 454 | 529 | 603 | 678 | 752 | 827 | 901 | 976 | — |
| TDF Multi-Fuel CFB (10% Co-fire) | 611 | 641 | 672 | 702 | 732 | 763 | 793 | 824 | 854 | 884 | 915 |
| Sewage Sludge & Anaerobic Digestion | 803 | 798 | 793 | 788 | 782 | 777 | 772 | 767 | 761 | 756 | — |
| Bio Mass (Co-Fire) | 463 | 467 | 511 | 535 | 560 | 584 | 607 | 632 | 656 | 680 | 705 |
| Wood-Fired CFBC | 606 | 633 | 661 | 688 | 716 | 744 | 771 | 799 | 827 | 854 | 882 |
| Co-Fired CFBC | 746 | 795 | 843 | 891 | 939 | 987 | 1035 | 1083 | 1132 | 1180 | 1228 |
| Molten Carbonate Fuel Cell | 314 | 367 | 419 | 472 | 525 | 578 | 630 | 683 | 736 | 788 | — |
| Solid Oxide Fuel Cell | 198 | 250 | 301 | 353 | 404 | 456 | 507 | 559 | 610 | 662 | — |
| Spark Ignition Engine | 440 | 517 | 594 | 670 | 747 | 824 | 901 | 977 | 1054 | 1131 | — |
| Hydroelectric - New - 30 MW | 647 | 642 | 636 | 631 | 625 | — | — | — | — | — | — |
| Hydroelectric - 50 MW Bulb Unit | 579 | 574 | 568 | 563 | 558 | — | — | — | — | — | — |
| Hydroelectric - 25 MW Bulb Units | 758 | 753 | 748 | 742 | 737 | — | — | — | — | — | — |
| Hydroelectric - 50 MW Kaplan Unit | 712 | 707 | 702 | 696 | 691 | — | — | — | — | — | — |
| Hydroelectric - 50 MW Propeller Unit | 674 | 669 | 664 | 658 | 653 | — | — | — | — | — | — |
| Minimum Levelized \$/kW | 110 | 175 | 234 | 293 | 352 | 411 | 470 | 528 | 559 | 587 | 614 |

Levelized Dollars at Various Capacity Factors With SO2 Adders, without CO2 Adders, and with NOx Adders

| Technology | 2010 (\$/kW yr) | | | | | | | | | | |
|--|-----------------|------|------|------|------|------|------|------|------|------|------|
| | 0% | 10% | 20% | 30% | 40% | 50% | 60% | 70% | 80% | 90% | 100% |
| Pumped Hydro Energy Storage | 249 | 287 | 324 | — | — | — | — | — | — | — | — |
| Advanced Battery Energy Storage | 195 | 240 | 284 | — | — | — | — | — | — | — | — |
| Compressed Air Energy Storage | 183 | 239 | 296 | — | — | — | — | — | — | — | — |
| Simple Cycle GE LM6000 CT | 163 | 253 | 344 | 434 | 525 | 615 | 706 | 797 | 887 | 978 | 1068 |
| Simple Cycle GE 7EA CT | 132 | 241 | 350 | 459 | 568 | 677 | 787 | 896 | 1005 | 1114 | 1223 |
| Simple Cycle GE 7FA CT | 111 | 196 | 280 | 365 | 450 | 535 | 620 | 705 | 790 | 875 | 959 |
| Combined Cycle GE 7EA CT | 237 | 300 | 363 | 426 | 489 | 551 | 614 | 677 | 740 | 803 | 866 |
| Combined Cycle 1x1 7F-Class | 173 | 225 | 277 | 330 | 382 | 434 | 486 | 538 | 590 | 642 | 694 |
| Combined Cycle 1x1 G-Class CT | 148 | 199 | 251 | 302 | 353 | 405 | 456 | 508 | 559 | 610 | 662 |
| Combined Cycle 2x1 7F-Class CT | 126 | 177 | 229 | 280 | 331 | 383 | 434 | 486 | 537 | 588 | 640 |
| Combined Cycle 3x1 7F-Class CT | 117 | 169 | 220 | 271 | 322 | 374 | 425 | 476 | 528 | 579 | 630 |
| Combined Cycle Siemens 5000F CT | 172 | 226 | 281 | 336 | 391 | 446 | 501 | 556 | 611 | 666 | 721 |
| Humid Air Turbine Cycle CT | 156 | 234 | 311 | 389 | 466 | 543 | 621 | 698 | 776 | 853 | 931 |
| Kalina Cycle CC CT | 168 | 215 | 262 | 309 | 355 | 402 | 449 | 496 | 542 | 589 | 636 |
| Cheng Cycle CT | 175 | 231 | 287 | 343 | 398 | 454 | 510 | 566 | 622 | 678 | 734 |
| Peaking Microturbine | 493 | 632 | 770 | 909 | 1048 | 1187 | 1326 | 1464 | 1603 | 1742 | 1881 |
| Baseload Microturbine | 523 | 632 | 741 | 850 | 958 | 1067 | 1176 | 1285 | 1394 | 1502 | 1611 |
| Subcritical Pulverized Coal - 256 MW | 424 | 448 | 472 | 496 | 519 | 543 | 567 | 591 | 614 | 638 | 662 |
| Subcritical Pulverized Coal - 512 MW | 379 | 403 | 426 | 450 | 473 | 497 | 520 | 544 | 567 | 591 | 614 |
| Circulating Fluidized Bed - 2x 250 MW | 351 | 380 | 410 | 439 | 469 | 498 | 528 | 557 | 587 | 616 | 646 |
| Supercritical Pulverized Coal - 565 MW | 389 | 414 | 439 | 464 | 489 | 514 | 539 | 564 | 589 | 614 | 639 |
| Supercritical Pulverized Coal-800 MW | 340 | 364 | 388 | 413 | 437 | 461 | 485 | 509 | 533 | 557 | 582 |
| Pressurized Fluidized Bed Combustion | 464 | 487 | 510 | 533 | 557 | 580 | 603 | 626 | 649 | — | — |
| 1x1 IGCC | 445 | 467 | 489 | 511 | 532 | 554 | 576 | 598 | 619 | — | — |
| 2x1 IGCC | 489 | 510 | 531 | 552 | 573 | 595 | 616 | 637 | 658 | — | — |
| Subcritical Pulverized Coal - 502 MW - CCS | 727 | 761 | 795 | 829 | 864 | 898 | 932 | 966 | 1001 | 1035 | 1069 |
| Circulating Fluidized Bed - CC | 638 | 677 | 716 | 755 | 794 | 833 | 872 | 911 | 950 | 989 | 1027 |
| Supercritical Pulverized Coal - 565 MW - CCS | 604 | 641 | 678 | 716 | 753 | 791 | 828 | 865 | 903 | 940 | 978 |
| Supercritical Pulverized Coal - 800 MW - CCS | 530 | 559 | 588 | 617 | 646 | 674 | 703 | 732 | 761 | 789 | 818 |
| 1x1 IGCC - CCS | 658 | 684 | 711 | 737 | 763 | 789 | 815 | 841 | 867 | — | — |
| 2x1 IGCC - CC | 581 | 606 | 631 | 655 | 680 | 705 | 729 | 754 | 779 | — | — |
| Wind Energy Conversion | 305 | 302 | 299 | 297 | — | — | — | — | — | — | — |
| Solar Photovoltaic | 689 | 689 | — | — | — | — | — | — | — | — | — |
| Solar Thermal, Parabolic Trough | 770 | 771 | — | — | — | — | — | — | — | — | — |
| Solar Thermal, Power Tower w Storage | 979 | 979 | 980 | 980 | — | — | — | — | — | — | — |
| Solar Thermal, Parabolic Dish | 901 | 901 | — | — | — | — | — | — | — | — | — |
| Solar Thermal, Central Receiver | 938 | 939 | 940 | 941 | 942 | 943 | 944 | — | — | — | — |
| Solar Thermal, Solar Chimney | 790 | 790 | 790 | 790 | — | — | — | — | — | — | — |
| MSW Mass Burn | 1917 | 1889 | 1861 | 1832 | 1804 | 1776 | 1748 | 1720 | — | — | — |
| RDF Stoker-Fired | 1891 | 1969 | 2046 | 2124 | 2201 | 2279 | 2356 | 2434 | 2511 | — | — |
| Wood Fired Stoker Plant | 543 | 572 | 602 | 631 | 661 | 690 | 719 | 749 | 778 | — | — |
| Landfill Gas IC Engine | 305 | 328 | 351 | 373 | 396 | 419 | 441 | 464 | 487 | 510 | — |
| TDF Multi-Fuel CFB (10% Co-fire) | 611 | 638 | 664 | 691 | 717 | 744 | 771 | 797 | 824 | 850 | 877 |
| Sewage Sludge & Anaerobic Digestion | 803 | 798 | 793 | 788 | 782 | 777 | 772 | 766 | 761 | 756 | — |
| Bio Mass (Co-Fire) | 463 | 484 | 505 | 526 | 547 | 568 | 589 | 610 | 631 | 652 | 673 |
| Wood-Fired CFBC | 606 | 629 | 652 | 676 | 699 | 722 | 746 | 769 | 793 | 816 | 839 |
| Co-Fired CFBC | 746 | 790 | 833 | 876 | 920 | 963 | 1006 | 1049 | 1093 | 1136 | 1179 |
| Molten Carbonate Fuel Cell | 315 | 361 | 408 | 455 | 501 | 548 | 594 | 641 | 688 | 734 | — |
| Solid Oxide Fuel Cell | 199 | 243 | 288 | 332 | 377 | 421 | 465 | 510 | 554 | 599 | — |
| Spark Ignition Engine | 442 | 508 | 574 | 640 | 706 | 772 | 838 | 904 | 970 | 1037 | — |
| Hydroelectric - New - 30 MW | 647 | 642 | 636 | 631 | 625 | — | — | — | — | — | — |
| Hydroelectric - 50 MW Bulb Unit | 579 | 574 | 568 | 563 | 558 | — | — | — | — | — | — |
| Hydroelectric - 25 MW Bulb Units | 758 | 753 | 748 | 742 | 737 | — | — | — | — | — | — |
| Hydroelectric - 50 MW Kaplan Unit | 712 | 707 | 702 | 696 | 691 | — | — | — | — | — | — |
| Hydroelectric - 50 MW Propeller Unit | 674 | 669 | 664 | 658 | 653 | — | — | — | — | — | — |
| Minimum Levelized \$/kW | 111 | 169 | 220 | 271 | 322 | 374 | 425 | 464 | 487 | 510 | 582 |

Levelized Dollars at Various Capacity Factors With SO2 Adders, without CO2 Adders, and with NOx Adders

| Technology | 2010 (\$/kW yr) | | | | | | | | | | |
|--|-----------------|------|------|------|------|------|------|------|------|------|------|
| | 0% | 10% | 20% | 30% | 40% | 50% | 60% | 70% | 80% | 90% | 100% |
| Pumped Hydro Energy Storage | 249 | 290 | 331 | — | — | — | — | — | — | — | — |
| Advanced Battery Energy Storage | 195 | 243 | 291 | — | — | — | — | — | — | — | — |
| Compressed Air Energy Storage | 183 | 245 | 308 | — | — | — | — | — | — | — | — |
| Simple Cycle GE LM6000 CT | 163 | 260 | 358 | 456 | 553 | 651 | 749 | 847 | 944 | 1042 | 1140 |
| Simple Cycle GE 7EA CT | 132 | 250 | 368 | 486 | 605 | 723 | 841 | 959 | 1078 | 1196 | 1314 |
| Simple Cycle GE 7FA CT | 111 | 203 | 296 | 388 | 481 | 573 | 666 | 758 | 851 | 943 | 1036 |
| Combined Cycle GE 7EA CT | 237 | 306 | 376 | 445 | 514 | 583 | 652 | 721 | 790 | 859 | 928 |
| Combined Cycle 1x1 7F-Class | 173 | 231 | 288 | 345 | 403 | 460 | 517 | 575 | 632 | 689 | 747 |
| Combined Cycle 1x1 G-Class CT | 148 | 204 | 261 | 318 | 374 | 431 | 487 | 544 | 601 | 657 | 714 |
| Combined Cycle 2x1 7F-Class CT | 126 | 182 | 239 | 296 | 352 | 409 | 466 | 522 | 579 | 636 | 692 |
| Combined Cycle 3x1 7F-Class CT | 117 | 174 | 230 | 287 | 343 | 400 | 456 | 513 | 569 | 626 | 682 |
| Combined Cycle Siemens 5000F CT | 172 | 232 | 292 | 353 | 413 | 474 | 534 | 594 | 655 | 715 | 776 |
| Humid Air Turbine Cycle CT | 156 | 242 | 327 | 413 | 498 | 583 | 669 | 754 | 840 | 925 | 1011 |
| Kalina Cycle CC CT | 168 | 220 | 272 | 323 | 375 | 427 | 478 | 530 | 582 | 633 | 685 |
| Cheng Cycle CT | 175 | 236 | 298 | 359 | 421 | 483 | 544 | 606 | 667 | 729 | 791 |
| Peaking Microturbine | 493 | 643 | 793 | 943 | 1093 | 1243 | 1393 | 1543 | 1693 | 1843 | 1993 |
| Baseload Microturbine | 523 | 643 | 763 | 883 | 1003 | 1124 | 1244 | 1364 | 1484 | 1604 | 1724 |
| Subcritical Pulverized Coal - 256 MW | 424 | 451 | 477 | 503 | 529 | 555 | 581 | 607 | 633 | 659 | 685 |
| Subcritical Pulverized Coal - 512 MW | 379 | 405 | 431 | 457 | 482 | 508 | 534 | 560 | 585 | 611 | 637 |
| Circulating Fluidized Bed - 2x 250 MW | 351 | 383 | 415 | 447 | 479 | 511 | 543 | 575 | 607 | 639 | 671 |
| Supercritical Pulverized Coal - 565 MW | 389 | 416 | 443 | 471 | 498 | 525 | 552 | 579 | 607 | 634 | 661 |
| Supercritical Pulverized Coal-800 MW | 340 | 367 | 393 | 419 | 446 | 472 | 498 | 525 | 551 | 578 | 604 |
| Pressurized Fluidized Bed Combustion | 464 | 489 | 515 | 540 | 566 | 591 | 616 | 642 | 667 | — | — |
| 1x1 IGCC | 445 | 469 | 493 | 517 | 541 | 565 | 588 | 612 | 636 | — | — |
| 2x1 IGCC | 489 | 512 | 536 | 559 | 582 | 606 | 629 | 652 | 676 | — | — |
| Subcritical Pulverized Coal - 502 MW - CCS | 727 | 764 | 801 | 839 | 876 | 914 | 951 | 989 | 1026 | 1064 | 1101 |
| Circulating Fluidized Bed - CC | 638 | 680 | 723 | 765 | 808 | 850 | 892 | 935 | 977 | 1020 | 1062 |
| Supercritical Pulverized Coal - 565 MW - CCS | 604 | 644 | 685 | 725 | 766 | 806 | 847 | 888 | 928 | 969 | 1009 |
| Supercritical Pulverized Coal - 800 MW - CCS | 530 | 561 | 592 | 623 | 655 | 686 | 717 | 748 | 779 | 810 | 841 |
| 1x1 IGCC - CCS | 658 | 687 | 716 | 744 | 773 | 801 | 830 | 858 | 887 | — | — |
| 2x1 IGCC - CC | 581 | 609 | 636 | 663 | 690 | 718 | 745 | 772 | 799 | — | — |
| Wind Energy Conversion | 305 | 302 | 299 | 297 | — | — | — | — | — | — | — |
| Solar Photovoltaic | 689 | 689 | — | — | — | — | — | — | — | — | — |
| Solar Thermal, Parabolic Trough | 770 | 771 | — | — | — | — | — | — | — | — | — |
| Solar Thermal, Power Tower w Storage | 979 | 979 | 980 | 980 | — | — | — | — | — | — | — |
| Solar Thermal, Parabolic Dish | 901 | 901 | — | — | — | — | — | — | — | — | — |
| Solar Thermal, Central Receiver | 938 | 939 | 940 | 941 | 942 | 943 | 944 | — | — | — | — |
| Solar Thermal, Solar Chimney | 790 | 790 | 790 | 790 | — | — | — | — | — | — | — |
| MSW Mass Burn | 1917 | 1882 | 1846 | 1811 | 1775 | 1740 | 1704 | 1669 | — | — | — |
| RDF Stoker-Fired | 1891 | 1976 | 2062 | 2147 | 2232 | 2317 | 2403 | 2488 | 2573 | — | — |
| Wood Fired Stoker Plant | 543 | 576 | 609 | 641 | 674 | 707 | 740 | 772 | 805 | — | — |
| Landfill Gas IC Engine | 305 | 351 | 397 | 442 | 488 | 534 | 579 | 625 | 670 | 716 | — |
| TDF Multi-Fuel CFB (10% Co-fire) | 611 | 640 | 669 | 699 | 728 | 757 | 786 | 815 | 845 | 874 | 903 |
| Sewage Sludge & Anaerobic Digestion | 803 | 798 | 793 | 788 | 782 | 777 | 772 | 767 | 761 | 756 | — |
| Bio Mass (Co-Fire) | 463 | 486 | 509 | 532 | 556 | 579 | 602 | 625 | 648 | 672 | 695 |
| Wood-Fired CFBC | 606 | 632 | 658 | 685 | 711 | 737 | 764 | 790 | 816 | 843 | 869 |
| Co-Fired CFBC | 746 | 793 | 840 | 886 | 933 | 980 | 1026 | 1073 | 1119 | 1166 | 1213 |
| Molten Carbonate Fuel Cell | 315 | 366 | 417 | 467 | 518 | 569 | 620 | 671 | 721 | 772 | — |
| Solid Oxide Fuel Cell | 199 | 248 | 298 | 347 | 396 | 446 | 495 | 544 | 594 | 643 | — |
| Spark Ignition Engine | 442 | 515 | 589 | 662 | 736 | 809 | 882 | 956 | 1029 | 1103 | — |
| Hydroelectric - New - 30 MW | 647 | 642 | 636 | 631 | 625 | — | — | — | — | — | — |
| Hydroelectric - 50 MW Bulb Unit | 579 | 574 | 568 | 563 | 558 | — | — | — | — | — | — |
| Hydroelectric - 25 MW Bulb Units | 758 | 753 | 748 | 742 | 737 | — | — | — | — | — | — |
| Hydroelectric - 50 MW Kaplan Unit | 712 | 707 | 702 | 696 | 691 | — | — | — | — | — | — |
| Hydroelectric - 50 MW Propeller Unit | 674 | 669 | 664 | 658 | 653 | — | — | — | — | — | — |
| Minimum Levelized \$/kW | 111 | 174 | 230 | 287 | 343 | 400 | 456 | 513 | 551 | 578 | 604 |

Levelized Dollars at Various Capacity Factors With SO2 Adders, without CO2 Adders, and with NOx Adders

| Technology | 2010 (\$/kW yr) | | | | | | | | | | |
|--|-----------------|------------|------------|------------|------------|------------|------------|------------|------------|------------|------------|
| | 0% | 10% | 20% | 30% | 40% | 50% | 60% | 70% | 80% | 90% | 100% |
| Pumped Hydro Energy Storage | 249 | 293 | 338 | --- | --- | --- | --- | --- | --- | --- | --- |
| Advanced Battery Energy Storage | 195 | 246 | 297 | --- | --- | --- | --- | --- | --- | --- | --- |
| Compressed Air Energy Storage | 183 | 251 | 320 | --- | --- | --- | --- | --- | --- | --- | --- |
| Simple Cycle GE LM6000 CT | 163 | 267 | 372 | 477 | 582 | 687 | 792 | 896 | 1001 | 1106 | 1211 |
| Simple Cycle GE 7EA CT | 132 | 259 | 386 | 514 | 641 | 768 | 896 | 1023 | 1150 | 1277 | 1405 |
| Simple Cycle GE 7FA CT | 111 | 211 | 311 | 411 | 511 | 611 | 711 | 811 | 912 | 1012 | 1112 |
| Combined Cycle GE 7EA CT | 237 | 313 | 388 | 463 | 539 | 614 | 689 | 765 | 840 | 915 | 991 |
| Combined Cycle 1x1 7F-Class | 173 | 236 | 298 | 361 | 424 | 486 | 549 | 611 | 674 | 736 | 799 |
| Combined Cycle 1x1 G-Class CT | 148 | 210 | 271 | 333 | 395 | 457 | 519 | 580 | 642 | 704 | 766 |
| Combined Cycle 2x1 7F-Class CT | 126 | 188 | 249 | 311 | 373 | 435 | 497 | 559 | 621 | 683 | 745 |
| Combined Cycle 3x1 7F-Class CT | 117 | 179 | 241 | 303 | 364 | 426 | 488 | 549 | 611 | 673 | 735 |
| Combined Cycle Siemens 5000F CT | 172 | 237 | 303 | 369 | 435 | 501 | 567 | 633 | 699 | 764 | 830 |
| Humid Air Turbine Cycle CT | 156 | 250 | 343 | 437 | 530 | 624 | 717 | 810 | 904 | 997 | 1091 |
| Kalina Cycle CC CT | 168 | 225 | 282 | 338 | 395 | 451 | 508 | 564 | 621 | 677 | 734 |
| Cheng Cycle CT | 175 | 242 | 309 | 376 | 443 | 511 | 578 | 645 | 712 | 780 | 847 |
| Peaking Microturbine | 493 | 654 | 815 | 977 | 1138 | 1299 | 1461 | 1622 | 1783 | 1945 | 2106 |
| Baseload Microturbine | 523 | 655 | 786 | 917 | 1049 | 1180 | 1311 | 1442 | 1574 | 1705 | 1836 |
| Subcritical Pulverized Coal - 256 MW | 424 | 453 | 481 | 510 | 538 | 566 | 595 | 623 | 651 | 680 | 708 |
| Subcritical Pulverized Coal - 512 MW | 379 | 407 | 435 | 463 | 491 | 519 | 548 | 576 | 604 | 632 | 660 |
| Circulating Fluidized Bed - 2x 250 MW | 351 | 386 | 420 | 455 | 489 | 524 | 558 | 593 | 627 | 662 | 696 |
| Supercritical Pulverized Coal - 565 MW | 389 | 418 | 448 | 477 | 507 | 536 | 566 | 595 | 625 | 654 | 683 |
| Supercritical Pulverized Coal-800 MW | 340 | 369 | 397 | 426 | 455 | 483 | 512 | 540 | 569 | 598 | 626 |
| Pressurized Fluidized Bed Combustion | 464 | 492 | 519 | 547 | 575 | 602 | 630 | 658 | 685 | --- | --- |
| 1x1 IGCC | 445 | 471 | 497 | 523 | 549 | 575 | 601 | 627 | 653 | --- | --- |
| 2x1 IGCC | 489 | 514 | 540 | 566 | 591 | 617 | 642 | 668 | 693 | --- | --- |
| Subcritical Pulverized Coal - 502 MW - CCS | 727 | 767 | 808 | 849 | 889 | 930 | 970 | 1011 | 1052 | 1092 | 1133 |
| Circulating Fluidized Bed - CC | 638 | 684 | 730 | 776 | 822 | 867 | 913 | 959 | 1005 | 1051 | 1097 |
| Supercritical Pulverized Coal - 565 MW - CCS | 604 | 647 | 691 | 735 | 779 | 822 | 866 | 910 | 954 | 997 | 1041 |
| Supercritical Pulverized Coal - 800 MW - CCS | 530 | 564 | 597 | 630 | 663 | 697 | 730 | 763 | 796 | 830 | 863 |
| 1x1 IGCC - CCS | 658 | 689 | 721 | 752 | 783 | 814 | 845 | 876 | 907 | --- | --- |
| 2x1 IGCC - CC | 581 | 611 | 641 | 671 | 701 | 731 | 760 | 790 | 820 | --- | --- |
| Wind Energy Conversion | 305 | 302 | 299 | 297 | --- | --- | --- | --- | --- | --- | --- |
| Solar Photovoltaic | 689 | --- | --- | --- | --- | --- | --- | --- | --- | --- | --- |
| Solar Thermal, Parabolic Trough | 770 | 771 | --- | --- | --- | --- | --- | --- | --- | --- | --- |
| Solar Thermal, Power Tower w Storage | 979 | 979 | 980 | 980 | --- | --- | --- | --- | --- | --- | --- |
| Solar Thermal, Parabolic Dish | 901 | 901 | --- | --- | --- | --- | --- | --- | --- | --- | --- |
| Solar Thermal, Central Receiver | 938 | 939 | 940 | 941 | 942 | 943 | 944 | --- | --- | --- | --- |
| Solar Thermal, Solar Chimney | 790 | 790 | 790 | 790 | --- | --- | --- | --- | --- | --- | --- |
| MSW Mass Burn | 1917 | 1874 | 1832 | 1789 | 1746 | 1703 | 1660 | 1618 | --- | --- | --- |
| RDF Stoker-Fired | 1891 | 1984 | 2077 | 2170 | 2263 | 2356 | 2449 | 2542 | 2635 | --- | --- |
| Wood Fired Stoker Plant | 543 | 579 | 615 | 652 | 688 | 724 | 760 | 796 | 832 | --- | --- |
| Landfill Gas IC Engine | 305 | 383 | 461 | 539 | 616 | 694 | 772 | 850 | 928 | 1005 | --- |
| TDF Multi-Fuel CFB (10% Co-fire) | 611 | 643 | 675 | 706 | 738 | 770 | 802 | 834 | 865 | 897 | 929 |
| Sewage Sludge & Anaerobic Digestion | 803 | 798 | 793 | 788 | 782 | 777 | 772 | 767 | 761 | 756 | --- |
| Bio Mass (Co-Fire) | 463 | 488 | 514 | 539 | 564 | 590 | 615 | 640 | 666 | 691 | 717 |
| Wood-Fired CFBC | 606 | 635 | 664 | 693 | 723 | 752 | 781 | 810 | 840 | 869 | 898 |
| Co-Fired CFBC | 746 | 796 | 846 | 896 | 946 | 996 | 1046 | 1096 | 1146 | 1196 | 1246 |
| Molten Carbonate Fuel Cell | 315 | 370 | 425 | 480 | 535 | 590 | 645 | 700 | 755 | 810 | --- |
| Solid Oxide Fuel Cell | 199 | 253 | 308 | 362 | 416 | 470 | 525 | 579 | 633 | 687 | --- |
| Spark Ignition Engine | 442 | 523 | 603 | 684 | 765 | 846 | 926 | 1007 | 1088 | 1169 | --- |
| Hydroelectric - New - 30 MW | 647 | 642 | 636 | 631 | 625 | --- | --- | --- | --- | --- | --- |
| Hydroelectric - 50 MW Bulb Unit | 579 | 574 | 568 | 563 | 558 | --- | --- | --- | --- | --- | --- |
| Hydroelectric - 25 MW Bulb Units | 758 | 753 | 748 | 742 | 737 | --- | --- | --- | --- | --- | --- |
| Hydroelectric - 50 MW Kaplan Unit | 712 | 707 | 702 | 696 | 691 | --- | --- | --- | --- | --- | --- |
| Hydroelectric - 50 MW Propeller Unit | 674 | 669 | 664 | 658 | 653 | --- | --- | --- | --- | --- | --- |
| Minimum Levelized \$/kW | 111 | 179 | 241 | 297 | 364 | 426 | 488 | 540 | 569 | 598 | 626 |

Levelized Dollars at Various Capacity Factors With SO2 Adders, without CO2 Adders, and with NOx Adders

| Technology | 2010 (\$/kW yr) | | | | | | | | | | |
|--|-----------------|------|------|------|------|------|------|------|------|------|------|
| | 0% | 10% | 20% | 30% | 40% | 50% | 60% | 70% | 80% | 90% | 100% |
| Pumped Hydro Energy Storage | 249 | 287 | 324 | --- | --- | --- | --- | --- | --- | --- | --- |
| Advanced Battery Energy Storage | 195 | 240 | 284 | --- | --- | --- | --- | --- | --- | --- | --- |
| Compressed Air Energy Storage | 183 | 241 | 299 | --- | --- | --- | --- | --- | --- | --- | --- |
| Simple Cycle GE LM6000 CT | 163 | 257 | 351 | 445 | 538 | 632 | 726 | 820 | 913 | 1007 | 1101 |
| Simple Cycle GE 7EA CT | 132 | 246 | 359 | 472 | 585 | 699 | 812 | 925 | 1038 | 1152 | 1265 |
| Simple Cycle GE 7FA CT | 111 | 200 | 288 | 376 | 465 | 553 | 641 | 729 | 818 | 906 | 994 |
| Combined Cycle GE 7EA CT | 238 | 304 | 370 | 435 | 501 | 567 | 632 | 698 | 763 | 829 | 895 |
| Combined Cycle 1x1 7F-Class | 174 | 228 | 283 | 337 | 392 | 446 | 501 | 555 | 610 | 664 | 719 |
| Combined Cycle 1x1 G-Class CT | 149 | 202 | 256 | 310 | 363 | 417 | 471 | 525 | 578 | 632 | 686 |
| Combined Cycle 2x1 7F-Class CT | 126 | 180 | 234 | 288 | 342 | 395 | 449 | 503 | 557 | 610 | 664 |
| Combined Cycle 3x1 7F-Class CT | 118 | 172 | 226 | 279 | 333 | 386 | 440 | 494 | 547 | 601 | 655 |
| Combined Cycle Siemens 5000F CT | 173 | 230 | 287 | 345 | 402 | 460 | 517 | 574 | 632 | 689 | 747 |
| Humid Air Turbine Cycle CT | 158 | 239 | 320 | 401 | 482 | 563 | 644 | 725 | 806 | 887 | 968 |
| Kalina Cycle CC CT | 170 | 218 | 267 | 316 | 365 | 414 | 463 | 512 | 561 | 610 | 659 |
| Cheng Cycle CT | 176 | 234 | 293 | 351 | 410 | 468 | 527 | 585 | 644 | 702 | 761 |
| Peaking Microturbine | 494 | 638 | 782 | 925 | 1069 | 1213 | 1357 | 1501 | 1645 | 1788 | 1932 |
| Baseload Microturbine | 526 | 640 | 753 | 867 | 981 | 1095 | 1209 | 1323 | 1437 | 1550 | 1664 |
| Subcritical Pulverized Coal - 256 MW | 424 | 449 | 474 | 499 | 524 | 548 | 573 | 598 | 623 | 647 | 672 |
| Subcritical Pulverized Coal - 512 MW | 379 | 404 | 428 | 453 | 477 | 502 | 526 | 551 | 575 | 600 | 624 |
| Circulating Fluidized Bed - 2x 250 MW | 351 | 382 | 412 | 443 | 473 | 504 | 535 | 565 | 596 | 626 | 657 |
| Supercritical Pulverized Coal - 565 MW | 389 | 415 | 441 | 467 | 493 | 519 | 545 | 571 | 597 | 623 | 649 |
| Supercritical Pulverized Coal-800 MW | 340 | 365 | 390 | 416 | 441 | 466 | 491 | 516 | 541 | 566 | 592 |
| Pressurized Fluidized Bed Combustion | 464 | 488 | 512 | 537 | 561 | 585 | 609 | 633 | 657 | --- | --- |
| 1x1 IGCC | 445 | 468 | 491 | 513 | 536 | 559 | 582 | 604 | 627 | --- | --- |
| 2x1 IGCC | 489 | 511 | 533 | 555 | 577 | 600 | 622 | 644 | 666 | --- | --- |
| Subcritical Pulverized Coal - 502 MW - CCS | 727 | 762 | 798 | 834 | 869 | 905 | 941 | 976 | 1012 | 1048 | 1083 |
| Circulating Fluidized Bed - CC | 638 | 678 | 719 | 760 | 800 | 841 | 881 | 922 | 962 | 1003 | 1043 |
| Supercritical Pulverized Coal - 565 MW - CCS | 604 | 642 | 681 | 720 | 759 | 798 | 837 | 875 | 914 | 953 | 992 |
| Supercritical Pulverized Coal - 800 MW - CCS | 530 | 560 | 590 | 620 | 650 | 679 | 709 | 739 | 769 | 799 | 828 |
| 1x1 IGCC - CCS | 658 | 686 | 713 | 740 | 767 | 794 | 822 | 849 | 876 | --- | --- |
| 2x1 IGCC - CC | 581 | 607 | 633 | 659 | 685 | 710 | 736 | 762 | 788 | --- | --- |
| Wind Energy Conversion | 305 | 302 | 299 | 297 | --- | --- | --- | --- | --- | --- | --- |
| Solar Photovoltaic | 689 | 689 | --- | --- | --- | --- | --- | --- | --- | --- | --- |
| Solar Thermal, Parabolic Trough | 770 | 771 | --- | --- | --- | --- | --- | --- | --- | --- | --- |
| Solar Thermal, Power Tower w Storage | 979 | 979 | 980 | 980 | --- | --- | --- | --- | --- | --- | --- |
| Solar Thermal, Parabolic Dish | 901 | 901 | --- | --- | --- | --- | --- | --- | --- | --- | --- |
| Solar Thermal, Central Receiver | 938 | 939 | 940 | 941 | 942 | 943 | 944 | --- | --- | --- | --- |
| Solar Thermal, Solar Chimney | 790 | 790 | 790 | 790 | --- | --- | --- | --- | --- | --- | --- |
| MSW Mass Burn | 1917 | 1886 | 1854 | 1823 | 1791 | 1760 | 1728 | 1697 | --- | --- | --- |
| RDF Stoker-Fired | 1891 | 1972 | 2053 | 2134 | 2215 | 2296 | 2377 | 2458 | 2539 | --- | --- |
| Wood Fired Stoker Plant | 543 | 574 | 605 | 636 | 667 | 698 | 728 | 759 | 790 | --- | --- |
| Landfill Gas IC Engine | 305 | 329 | 352 | 375 | 398 | 421 | 445 | 468 | 491 | 514 | --- |
| TDF Multi-Fuel CFB (10% Co-fire) | 611 | 639 | 667 | 694 | 722 | 750 | 778 | 805 | 833 | 861 | 889 |
| Sewage Sludge & Anaerobic Digestion | 803 | 798 | 793 | 788 | 782 | 777 | 772 | 766 | 761 | 756 | --- |
| Bio Mass (Co-Fire) | 463 | 485 | 507 | 529 | 551 | 573 | 595 | 617 | 639 | 661 | 683 |
| Wood-Fired CFBC | 606 | 630 | 655 | 680 | 704 | 729 | 754 | 779 | 803 | 828 | 853 |
| Co-Fired CFBC | 746 | 791 | 836 | 881 | 926 | 970 | 1015 | 1060 | 1105 | 1150 | 1194 |
| Molten Carbonate Fuel Cell | 316 | 364 | 413 | 461 | 510 | 558 | 607 | 655 | 704 | 752 | --- |
| Solid Oxide Fuel Cell | 200 | 247 | 293 | 340 | 387 | 433 | 480 | 526 | 573 | 620 | --- |
| Spark Ignition Engine | 444 | 513 | 582 | 652 | 721 | 790 | 860 | 929 | 998 | 1068 | --- |
| Hydroelectric - New - 30 MW | 647 | 642 | 636 | 631 | 625 | --- | --- | --- | --- | --- | --- |
| Hydroelectric - 50 MW Bulb Unit | 579 | 574 | 568 | 563 | 558 | --- | --- | --- | --- | --- | --- |
| Hydroelectric - 25 MW Bulb Units | 758 | 753 | 748 | 742 | 737 | --- | --- | --- | --- | --- | --- |
| Hydroelectric - 50 MW Kaplan Unit | 712 | 707 | 702 | 696 | 691 | --- | --- | --- | --- | --- | --- |
| Hydroelectric - 50 MW Propeller Unit | 674 | 669 | 664 | 658 | 653 | --- | --- | --- | --- | --- | --- |
| Minimum Levelized \$/kW | 111 | 172 | 226 | 279 | 333 | 386 | 440 | 468 | 491 | 514 | 592 |

Levelized Dollars at Various Capacity Factors With SO2 Adders, without CO2 Adders, and with NOx Adders

| Technology | 2010 (\$/kW yr) | | | | | | | | | | |
|--|-----------------|------------|------------|------------|------------|------------|------------|------------|------------|------------|------------|
| | 0% | 10% | 20% | 30% | 40% | 50% | 60% | 70% | 80% | 90% | 100% |
| Pumped Hydro Energy Storage | 249 | 290 | 331 | --- | --- | --- | --- | --- | --- | --- | --- |
| Advanced Battery Energy Storage | 195 | 243 | 291 | --- | --- | --- | --- | --- | --- | --- | --- |
| Compressed Air Energy Storage | 183 | 247 | 311 | --- | --- | --- | --- | --- | --- | --- | --- |
| Simple Cycle GE LM6000 CT | 163 | 264 | 366 | 467 | 568 | 670 | 771 | 872 | 973 | 1075 | 1176 |
| Simple Cycle GE 7EA CT | 132 | 255 | 378 | 501 | 623 | 746 | 869 | 992 | 1115 | 1237 | 1360 |
| Simple Cycle GE 7FA CT | 111 | 208 | 304 | 400 | 497 | 593 | 689 | 785 | 882 | 978 | 1074 |
| Combined Cycle GE 7EA CT | 238 | 311 | 383 | 455 | 527 | 599 | 672 | 744 | 816 | 888 | 960 |
| Combined Cycle 1x1 7F-Class | 174 | 234 | 294 | 354 | 414 | 474 | 534 | 594 | 654 | 714 | 774 |
| Combined Cycle 1x1 G-Class CT | 149 | 208 | 267 | 326 | 385 | 444 | 504 | 563 | 622 | 681 | 740 |
| Combined Cycle 2x1 7F-Class CT | 126 | 186 | 245 | 304 | 364 | 423 | 482 | 541 | 601 | 660 | 719 |
| Combined Cycle 3x1 7F-Class CT | 118 | 177 | 236 | 296 | 355 | 414 | 473 | 532 | 591 | 650 | 709 |
| Combined Cycle Siemens 5000F CT | 173 | 236 | 299 | 362 | 425 | 488 | 552 | 615 | 678 | 741 | 804 |
| Humid Air Turbine Cycle CT | 158 | 248 | 337 | 426 | 516 | 605 | 695 | 784 | 874 | 963 | 1052 |
| Kalina Cycle CC CT | 170 | 224 | 278 | 332 | 386 | 440 | 494 | 548 | 602 | 656 | 710 |
| Cheng Cycle CT | 176 | 240 | 305 | 369 | 433 | 498 | 562 | 627 | 691 | 755 | 820 |
| Peaking Microturbine | 494 | 650 | 805 | 961 | 1117 | 1272 | 1428 | 1584 | 1739 | 1895 | 2051 |
| Baseload Microturbine | 526 | 651 | 777 | 903 | 1028 | 1154 | 1280 | 1405 | 1531 | 1657 | 1782 |
| Subcritical Pulverized Coal - 256 MW | 424 | 452 | 479 | 506 | 533 | 560 | 588 | 615 | 642 | 669 | 696 |
| Subcritical Pulverized Coal - 512 MW | 379 | 406 | 433 | 460 | 487 | 514 | 541 | 568 | 594 | 621 | 648 |
| Circulating Fluidized Bed - 2x 250 MW | 351 | 384 | 418 | 451 | 484 | 517 | 551 | 584 | 617 | 650 | 683 |
| Supercritical Pulverized Coal - 565 MW | 389 | 417 | 446 | 474 | 502 | 531 | 559 | 587 | 616 | 644 | 672 |
| Supercritical Pulverized Coal-800 MW | 340 | 368 | 395 | 423 | 450 | 478 | 505 | 533 | 560 | 588 | 615 |
| Pressurized Fluidized Bed Combustion | 464 | 490 | 517 | 544 | 570 | 597 | 623 | 650 | 676 | --- | --- |
| 1x1 IGCC | 445 | 470 | 495 | 520 | 545 | 570 | 595 | 620 | 644 | --- | --- |
| 2x1 IGCC | 489 | 513 | 538 | 562 | 587 | 611 | 636 | 660 | 684 | --- | --- |
| Subcritical Pulverized Coal - 502 MW - CCS | 727 | 766 | 805 | 844 | 883 | 922 | 961 | 1000 | 1039 | 1078 | 1117 |
| Circulating Fluidized Bed - CC | 638 | 682 | 726 | 770 | 815 | 859 | 903 | 947 | 991 | 1035 | 1080 |
| Supercritical Pulverized Coal - 565 MW - CCS | 604 | 646 | 688 | 730 | 772 | 814 | 857 | 899 | 941 | 983 | 1025 |
| Supercritical Pulverized Coal - 800 MW - CCS | 530 | 563 | 595 | 627 | 659 | 691 | 723 | 755 | 788 | 820 | 852 |
| 1x1 IGCC - CCS | 658 | 688 | 718 | 748 | 778 | 807 | 837 | 867 | 897 | --- | --- |
| 2x1 IGCC - CC | 581 | 610 | 638 | 667 | 696 | 724 | 753 | 781 | 810 | --- | --- |
| Wind Energy Conversion | 305 | 302 | 299 | 297 | --- | --- | --- | --- | --- | --- | --- |
| Solar Photovoltaic | 689 | 689 | --- | --- | --- | --- | --- | --- | --- | --- | --- |
| Solar Thermal, Parabolic Trough | 770 | 771 | --- | --- | --- | --- | --- | --- | --- | --- | --- |
| Solar Thermal, Power Tower w Storage | 979 | 979 | 980 | 980 | --- | --- | --- | --- | --- | --- | --- |
| Solar Thermal, Parabolic Dish | 901 | 901 | --- | --- | --- | --- | --- | --- | --- | --- | --- |
| Solar Thermal, Central Receiver | 938 | 939 | 940 | 941 | 942 | 943 | 944 | --- | --- | --- | --- |
| Solar Thermal, Solar Chimney | 790 | 790 | 790 | 790 | --- | --- | --- | --- | --- | --- | --- |
| MSW Mass Burn | 1917 | 1878 | 1839 | 1800 | 1761 | 1721 | 1682 | 1643 | --- | --- | --- |
| RDF Stoker-Fired | 1891 | 1980 | 2069 | 2158 | 2248 | 2337 | 2426 | 2515 | 2604 | --- | --- |
| Wood Fired Stoker Plant | 543 | 578 | 612 | 646 | 681 | 715 | 750 | 784 | 819 | --- | --- |
| Landfill Gas IC Engine | 305 | 353 | 400 | 447 | 495 | 542 | 589 | 637 | 684 | 731 | --- |
| TDF Multi-Fuel CFB (10% Co-fire) | 611 | 641 | 672 | 702 | 733 | 763 | 794 | 824 | 855 | 886 | 916 |
| Sewage Sludge & Anaerobic Digestion | 803 | 798 | 793 | 788 | 782 | 777 | 772 | 767 | 761 | 756 | --- |
| Bio Mass (Co-Fire) | 463 | 487 | 511 | 536 | 560 | 584 | 609 | 633 | 657 | 681 | 706 |
| Wood-Fired CFBC | 606 | 633 | 661 | 689 | 717 | 745 | 772 | 800 | 828 | 856 | 884 |
| Co-Fired CFBC | 746 | 795 | 843 | 891 | 940 | 988 | 1036 | 1085 | 1133 | 1181 | 1229 |
| Molten Carbonate Fuel Cell | 316 | 369 | 422 | 475 | 527 | 580 | 633 | 686 | 739 | 792 | --- |
| Solid Oxide Fuel Cell | 200 | 252 | 304 | 355 | 407 | 459 | 511 | 563 | 614 | 666 | --- |
| Spark Ignition Engine | 444 | 521 | 598 | 675 | 752 | 829 | 906 | 983 | 1060 | 1137 | --- |
| Hydroelectric - New - 30 MW | 647 | 642 | 636 | 631 | 625 | --- | --- | --- | --- | --- | --- |
| Hydroelectric - 50 MW Bulb Unit | 579 | 574 | 568 | 563 | 558 | --- | --- | --- | --- | --- | --- |
| Hydroelectric - 25 MW Bulb Units | 758 | 753 | 748 | 742 | 737 | --- | --- | --- | --- | --- | --- |
| Hydroelectric - 50 MW Kaplan Unit | 712 | 707 | 702 | 696 | 691 | --- | --- | --- | --- | --- | --- |
| Hydroelectric - 50 MW Propeller Unit | 674 | 669 | 664 | 658 | 653 | --- | --- | --- | --- | --- | --- |
| Minimum Levelized \$/kW | 111 | 177 | 236 | 296 | 355 | 414 | 473 | 532 | 560 | 588 | 615 |

Levelized Dollars at Various Capacity Factors With SO2 Adders, without CO2 Adders, and with NOx Adders


| Technology | 2010 (\$/kW yr) | | | | | | | | | | |
|--|-----------------|------------|------------|------------|------------|------------|------------|------------|------------|------------|------------|
| | 0% | 10% | 20% | 30% | 40% | 50% | 60% | 70% | 80% | 90% | 100% |
| Pumped Hydro Energy Storage | 249 | 293 | 338 | --- | --- | --- | --- | --- | --- | --- | --- |
| Advanced Battery Energy Storage | 195 | 246 | 297 | --- | --- | --- | --- | --- | --- | --- | --- |
| Compressed Air Energy Storage | 183 | 253 | 324 | --- | --- | --- | --- | --- | --- | --- | --- |
| Simple Cycle GE LM6000 CT | 163 | 272 | 381 | 489 | 598 | 707 | 816 | 924 | 1033 | 1142 | 1251 |
| Simple Cycle GE 7EA CT | 132 | 265 | 397 | 529 | 662 | 794 | 926 | 1059 | 1191 | 1323 | 1455 |
| Simple Cycle GE 7FA CT | 111 | 216 | 320 | 424 | 529 | 633 | 737 | 841 | 946 | 1050 | 1154 |
| Combined Cycle GE 7EA CT | 238 | 317 | 396 | 475 | 554 | 632 | 711 | 790 | 869 | 947 | 1026 |
| Combined Cycle 1x1 7F-Class | 174 | 239 | 305 | 370 | 436 | 501 | 567 | 632 | 698 | 763 | 829 |
| Combined Cycle 1x1 G-Class CT | 149 | 213 | 278 | 343 | 407 | 472 | 536 | 601 | 666 | 730 | 795 |
| Combined Cycle 2x1 7F-Class CT | 126 | 191 | 256 | 321 | 386 | 450 | 515 | 580 | 645 | 709 | 774 |
| Combined Cycle 3x1 7F-Class CT | 118 | 183 | 247 | 312 | 377 | 441 | 506 | 570 | 635 | 700 | 764 |
| Combined Cycle Siemens 5000F CT | 173 | 242 | 310 | 379 | 448 | 517 | 586 | 655 | 724 | 793 | 862 |
| Humid Air Turbine Cycle CT | 158 | 256 | 354 | 452 | 549 | 647 | 745 | 843 | 941 | 1039 | 1136 |
| Kalina Cycle CC CT | 170 | 229 | 288 | 347 | 407 | 466 | 525 | 584 | 644 | 703 | 762 |
| Cheng Cycle CT | 176 | 246 | 316 | 387 | 457 | 527 | 598 | 668 | 738 | 809 | 879 |
| Peaking Microturbine | 494 | 661 | 829 | 996 | 1164 | 1331 | 1499 | 1666 | 1834 | 2001 | 2169 |
| Baseload Microturbine | 526 | 663 | 801 | 938 | 1076 | 1213 | 1351 | 1488 | 1626 | 1763 | 1901 |
| Subcritical Pulverized Coal - 256 MW | 424 | 454 | 484 | 513 | 543 | 573 | 602 | 632 | 661 | 691 | 721 |
| Subcritical Pulverized Coal - 512 MW | 379 | 409 | 438 | 467 | 496 | 526 | 555 | 584 | 614 | 643 | 672 |
| Circulating Fluidized Bed - 2x 250 MW | 351 | 387 | 423 | 459 | 495 | 530 | 566 | 602 | 638 | 674 | 710 |
| Supercritical Pulverized Coal - 565 MW | 389 | 420 | 450 | 481 | 512 | 542 | 573 | 604 | 634 | 665 | 696 |
| Supercritical Pulverized Coal-800 MW | 340 | 370 | 400 | 430 | 460 | 489 | 519 | 549 | 579 | 609 | 639 |
| Pressurized Fluidized Bed Combustion | 464 | 493 | 522 | 551 | 580 | 608 | 637 | 666 | 695 | --- | --- |
| 1x1 IGCC | 445 | 473 | 500 | 527 | 554 | 581 | 608 | 635 | 662 | --- | --- |
| 2x1 IGCC | 489 | 516 | 542 | 569 | 596 | 623 | 649 | 676 | 703 | --- | --- |
| Subcritical Pulverized Coal - 502 MW - CCS | 727 | 769 | 811 | 854 | 896 | 939 | 981 | 1023 | 1066 | 1108 | 1151 |
| Circulating Fluidized Bed - CC | 638 | 686 | 734 | 781 | 829 | 877 | 925 | 973 | 1020 | 1068 | 1116 |
| Supercritical Pulverized Coal - 565 MW - CCS | 604 | 649 | 695 | 740 | 786 | 831 | 877 | 922 | 967 | 1013 | 1058 |
| Supercritical Pulverized Coal - 800 MW - CCS | 530 | 565 | 599 | 634 | 668 | 703 | 737 | 772 | 806 | 841 | 875 |
| 1x1 IGCC - CCS | 658 | 691 | 723 | 756 | 788 | 821 | 853 | 885 | 918 | --- | --- |
| 2x1 IGCC - CC | 581 | 613 | 644 | 675 | 706 | 738 | 769 | 800 | 831 | --- | --- |
| Wind Energy Conversion | 305 | 302 | 299 | 297 | --- | --- | --- | --- | --- | --- | --- |
| Solar Photovoltaic | 689 | 689 | --- | --- | --- | --- | --- | --- | --- | --- | --- |
| Solar Thermal, Parabolic Trough | 770 | 771 | --- | --- | --- | --- | --- | --- | --- | --- | --- |
| Solar Thermal, Power Tower w Storage | 979 | 979 | 980 | 980 | --- | --- | --- | --- | --- | --- | --- |
| Solar Thermal, Parabolic Dish | 901 | 901 | --- | --- | --- | --- | --- | --- | --- | --- | --- |
| Solar Thermal, Central Receiver | 938 | 939 | 940 | 941 | 942 | 943 | 944 | --- | --- | --- | --- |
| Solar Thermal, Solar Chimney | 790 | 790 | 790 | 790 | --- | --- | --- | --- | --- | --- | --- |
| MSW Mass Burn | 1917 | 1870 | 1824 | 1777 | 1730 | 1683 | 1636 | 1590 | --- | --- | --- |
| RDF Stoker-Fired | 1891 | 1988 | 2086 | 2183 | 2280 | 2377 | 2474 | 2572 | 2669 | --- | --- |
| Wood Fired Stoker Plant | 543 | 581 | 619 | 657 | 695 | 733 | 771 | 809 | 847 | --- | --- |
| Landfill Gas IC Engine | 305 | 386 | 467 | 549 | 630 | 711 | 792 | 873 | 954 | 1035 | --- |
| TDF Multi-Fuel CFB (10% Co-fire) | 611 | 644 | 677 | 711 | 744 | 777 | 810 | 844 | 877 | 910 | 943 |
| Sewage Sludge & Anaerobic Digestion | 803 | 798 | 793 | 788 | 782 | 777 | 772 | 767 | 761 | 756 | --- |
| Bio Mass (Co-Fire) | 463 | 489 | 516 | 543 | 569 | 596 | 622 | 649 | 676 | 702 | 729 |
| Wood-Fired CFBC | 606 | 636 | 667 | 698 | 729 | 760 | 791 | 822 | 853 | 884 | 914 |
| Co-Fired CFBC | 746 | 798 | 850 | 902 | 954 | 1006 | 1057 | 1109 | 1161 | 1213 | 1265 |
| Molten Carbonate Fuel Cell | 316 | 373 | 431 | 488 | 545 | 603 | 660 | 717 | 775 | 832 | --- |
| Solid Oxide Fuel Cell | 200 | 257 | 314 | 371 | 428 | 485 | 542 | 599 | 656 | 713 | --- |
| Spark Ignition Engine | 444 | 528 | 613 | 698 | 783 | 867 | 952 | 1037 | 1122 | 1207 | --- |
| Hydroelectric - New - 30 MW | 647 | 642 | 636 | 631 | 625 | --- | --- | --- | --- | --- | --- |
| Hydroelectric - 50 MW Bulb Unit | 579 | 574 | 568 | 563 | 558 | --- | --- | --- | --- | --- | --- |
| Hydroelectric - 25 MW Bulb Units | 758 | 753 | 748 | 742 | 737 | --- | --- | --- | --- | --- | --- |
| Hydroelectric - 50 MW Kaplan Unit | 712 | 707 | 702 | 696 | 691 | --- | --- | --- | --- | --- | --- |
| Hydroelectric - 50 MW Propeller Unit | 674 | 669 | 664 | 658 | 653 | --- | --- | --- | --- | --- | --- |
| Minimum Levelized \$/kW | 111 | 183 | 247 | 297 | 377 | 441 | 506 | 549 | 579 | 609 | 639 |

Exhibit 7

Exhibit 7
Graph - Least Costly
Technologies in All Cases

Least Costly Technologies In All Cases

Base Capital, Base Heatrate, Base Fuel




—◆— Combined Cycle 3x1 7F-Class CT —▲— Supercritical Pulverized Coal-800 MW —●— Simple Cycle GE 7FA CT —○— Wind Energy Conversion —■— Landfill Gas —◇— IC Engine

Exhibit 8

Graph - Technologies for Analysis within Strategist

Technologies Considered for Analysis Within Strategist


Base Capital, Base Heatrate, Base Fuel



2011

LG&E and KU 2011 Reserve Margin Study

Astrape Consulting
4/8/2011



Contents

| | |
|--|----|
| Executive Summary..... | 2 |
| I. List of figures | 10 |
| II. List of tables | 10 |
| III. Input Assumptions | 11 |
| A. Study Year | 11 |
| B. Load Modeling | 11 |
| C. Load Forecast Error Due to Economic Growth Uncertainty | 14 |
| D. Resources..... | 15 |
| E. Unit Outage Data..... | 16 |
| F. Planned Outage Data | 18 |
| G. Hydro Modeling..... | 19 |
| H. Load Management..... | 19 |
| I. Neighbor Representation and Reliability Purchase Modeling | 20 |
| J. Carrying Cost of Reserves | 23 |
| K. Operating Reserve Requirements | 24 |
| L. Cost of Unserved Energy | 24 |
| IV. Simulation Methodology | 25 |
| A. Case Probabilities..... | 26 |
| B. Reserve Margin Definition | 30 |
| V. Base Case Results and Risk Analysis | 30 |
| VI. Sensitivity Analysis..... | 36 |
| VII. Conclusions/Recommendations | 38 |

Executive Summary

The purpose of this study is to determine the optimum planning reserve margin for the Louisville Gas & Electric Company and Kentucky Utilities (the “Companies”) based on estimated total costs and risks to customers. Customers generally expect power to be available 24 hours a day, 365 days a year, but due to excessive costs it is imprudent for a load serving entity to hold enough reserves to always meet this expectation. Therefore, it is necessary for utilities to understand their risks relative to resource adequacy by determining the expected frequency and cost of reliability events. As a load serving entity increases its planning reserve margin, the total cost of carrying reserves rises while the costs related directly to reliability events decrease. The optimal planning reserve margin is the reserve margin where the cost of carrying reserves plus the cost of reliability events (or reliability energy) is minimized.

In determining the optimum reserve margin, SERVVM¹ (Strategic Energy and Risk Valuation Model) was used to model the uncertainty in weather, unit performance, load growth, and import capability from interconnected regions. Other key inputs include the value of unserved energy, the cost of expensive market purchases, and the cost of new peaking capacity². As additional peaking capacity is installed, the Companies can expect to reduce the following:

- Cost of Unserved Energy Events
- Cost of Expensive Purchased Power
- Cost of Dispatching Expensive Peaking Resources

¹ SERVVM has been used extensively by large utilities in the south-eastern U.S. for economic reserve margin studies, demand side resource evaluation, cost of intermittent or energy limited resources, and the economic and reliability value of tie line capacity to neighboring power systems.

² In this study, the cost of new peaking capacity is the cost of a new combustion turbine.

In this analysis, these costs are collectively referred to as “reliability energy costs”. When using SERVVM, reliability energy costs were computed over thousands of scenarios and various reserve margin levels (from 10 to 24 percent) to determine how these costs decrease as reserves increase. The reliability energy costs are then added to the cost of carrying reserves and the point at which these total reliability costs are minimized is the optimal reserve margin.

The resulting distributions of reliability energy costs and cost of carrying reserves were utilized to determine the optimal reserve margin level. Figure ES1 plots the distributions of reliability energy costs while Figure ES2 plots the cost for carrying reserves. Both are plotted at varying reserve margin levels. It is seen that reliability energy costs are extremely volatile across scenarios while the cost of carrying reserves is fixed. Reliability energy costs are relatively small in 50% of all scenarios. However, when combinations of extreme events such as generation outages, severe weather, load forecast error, and low import capability occur, these costs can be substantial. For a 12% reserve margin level, reliability energy costs can range from 200 thousand dollars to 900 million dollars for a single year. As illustrated in Figure ES2, the cost of carrying reserves increase as reserve margin increases. These costs are fixed across all scenarios because additional capacity can be constructed or purchased through a bilateral contract effectively locking in that cost for many years.

Figure ES1. Distribution of Reliability Energy Costs






Figure ES2. Fixed Cost of Carrying Reserves




The optimal reserve margin is where the sum of the cost of reliability energy costs (Distributions from ES1) and the cost of carrying reserves (Distributions from ES2) is minimized. However, since reliability costs are extraordinarily volatile but capacity costs are fixed, a conversion is necessary to put the two on the same basis. The casualty insurance industry faces a similar issue in computing a fixed premium for which it can viably accept the risk associated with potentially volatile casualty payouts. In this industry, the premium that best mitigates the company's exposure to the distribution of casualty payouts is typically computed as a value between the 85th and 95th percent confidence levels on this distribution. Therefore, in this example, if an insurance company were assuming the risks shown in Figure ES1, then an approximate premium would equal the 85th - 95th confidence level of the distribution. Astrape Consulting recommends a similar risk adjustment using reliability energy costs at the 85th to 90th confidence level range based on its experience in performing reserve margin studies for other jurisdictions within the southeast because these levels have resulted in the lowest cost resource plans that also avoid unreasonable risk for utilities, regulators, and customers. Figure ES3 summarizes total reliability costs assuming reliability energy costs at the 85th percentile. As reserve margin increases, reliability energy costs decrease and the cost of carrying reserves increase. With this assumption, total reliability costs are minimized at a reserve margin of 15.50%.

Figure ES3. Optimal Reserve Margin with Reliability Energy Costs at 85th Percentile Confidence Level



Next, total reliability costs were calculated assuming reliability energy costs at various confidence levels to understand how the least cost reserve margin is impacted by this assumption. Figure ES4 displays these results without the individual components being shown.

Figure ES4. Optimal Reserve Margin at Varying Confidence Intervals



| | Weighted Average (76th Percentile) | 85% Confidence Level | 90% Confidence Level | 95% Confidence Level | 99% Confidence Level |
|-------------------------------|------------------------------------|----------------------|----------------------|----------------------|----------------------|
| Optimal Reserve Margin | 14.00% | 15.50% | 17.25% | 18.25% | 22.25% |

The recommended range of reserve margin assuming the 85th and 90th confidence levels of reliability energy costs is between 15.50% and 17.25%. The weighted average case assumes the reliability energy costs are weighted based on the probability of each scenario which happens to fall out at the 76th percentile point on the distribution. However, it is Astrape Consulting’s experience that assuming this as a long term planning reserve margin provides more risk than utilities and regulators are willing to take in a given year even though it may minimize average costs in the long run. Based on Figure ES1, a 14.00% reserve margin results in a risk that in 5% of all scenarios reliability energy costs would exceed 90 million dollars and 1% of the time they

would exceed \$200 million dollars. A 15.50% reserve margin lowers this exposure to 60 million dollars and 140 million dollars respectively. In contrast, the 99 percentile confidence level reserve margin of 22.25% eliminates almost all risk but puts an unreasonable amount of cost on customers as shown in Figure ES4.

It is recognized that many inputs used to set the target reserve margin could vary more than expected introducing more reliability events. Several sensitivities were performed to understand how major assumptions impact the results. These sensitivities included varying the cost of carrying reserves, varying the cost of expected unserved energy, removing all tie assistance, increasing unit forced outage rates, decreasing neighbor reserve capacity, decreasing transmission limits, and increasing market prices during scarce conditions. Table ES5 shows the sensitivity of the minimum cost reserve margin to various input assumptions at several confidence levels of reliability energy costs. It is seen that the cost of EUE has little impact on the overall results. This is due to the fact that unserved energy events are short and infrequent events. The remaining sensitivities are discussed in greater detail in the full report.

Table ES5. Sensitivity Analysis

| | Weighted Average | 85% Confidence Level | 90% Confidence Level | 95% Confidence Level |
|--|------------------|----------------------|----------------------|----------------------|
| EUE = \$5,000/MWh | 13.75% | 15.50% | 17.00% | 18.00% |
| Base Case Optimal Reserve Margin (EUE = \$16,600/MWh) | 14.00% | 15.50% | 17.25% | 18.25% |
| EUE = \$30,000/MWh | 14.25% | 16.00% | 17.75% | 18.75% |
| Cost of Capacity - \$110/kW-yr | 13.25% | 15.25% | 16.50% | 18.00% |
| Base Case Optimal Reserve Margin (Cost of Capacity = \$88.42/kW-yr) | 14.00% | 15.50% | 17.25% | 18.25% |
| Cost of Capacity - \$70/kW-yr | 14.75% | 17.25% | 18.50% | 20.75% |

| | Weighted Average (76th Percentile) | 85% Confidence Level | 90% Confidence Level | 95% Confidence Level |
|---|------------------------------------|----------------------|----------------------|----------------------|
| Optimal Reserve Margin | 14.00% | 15.50% | 17.25% | 18.25% |
| Scarcity Pricing Sensitivity - Increase by 50% | 15.25% | 17.50% | 19.00% | 20.25% |
| EFOR Sensitivity - Increase by 50% | 17.00% | 19.00% | 21.25% | 22.75% |
| Neighbor Reserve Margin Sensitivity - 15% RM to 12% RM | 16.00% | 18.00% | 20.25% | 22.00% |
| Transmission Sensitivity - Decrease by 50% | 15.00% | 16.75% | 18.25% | 19.50% |
| Island Sensitivity - No Interconnection Ties | 21.75% | 23.75% | 24.75% | 26.00% |

In conclusion, the simulation results demonstrate the Companies’ potential risk due to lower planning reserve margins and show that low probability, high impact cost exposures exist at all reserve margin levels. No system is 100% reliable and this reliability assessment has quantified the frequency and duration of major events and their economic impact on customers under a full distribution of weather years, unit performance, and load forecast uncertainty. The study also demonstrates the value of capacity reserve margins to the extent they protect customers from extreme, high cost outcomes. Based on the simulations and sensitivities, the precedent set by other industries, and experience in other jurisdictions, Astrape Consulting recommends that the Companies set a long-term target reserve margin using the 85th to 90th percentile of reliability energy costs which results in reserve margins between 15% and 17%.

I. List of figures

- Figure 1. Load Forecast Error Due to Economic Growth Uncertainty
- Figure 2. Probability of Capacity Offline
- Figure 3. Planned Maintenance Outages
- Figure 4. Neighbor Summary
- Figure 5. Simulated Market Purchases by Load Level
- Figure 6. Reliability Purchase Price Model
- Figure 7. Distribution of Reliability Energy Costs
- Figure 8. Fixed Cost of Carrying Reserves
- Figure 9. Optimal Reserve Margin with Reliability Energy Costs at 85th Percentile Confidence Level
- Figure 10. Reserve Margin Components at 85th Percentile Confidence Level
- Figure 11. Optimal Resrve Margin at Varying Confidence Intervals

II. List of tables

- Table 1. 2016 Load Forecast
- Table 2. 2016 Peak Load Rankings for All Weather Years
- Table 3. Summary of Resources
- Table 4. Base Load and Intermediate Capacity
- Table 5. Peaking Capacity
- Table 6. Hydro Capacity
- Table 7. Full Outage Example
- Table 8. Partial Outage Example
- Table 9. Equivalent Forced Outage Rates
- Table 10. Load Management Representation
- Table 11. Generic Combustion Turbine Characteristics
- Table 12. Carrying Cost of Reserves
- Table 13. Costs of Unserved Energy
- Table 14. Case Probabilities
- Table 15. Sensitivities – Cost of EUE and Cost of Carrying Reserves
- Table 16. Other Sensitivities

III. Input Assumptions

A. Study Year

The selected study year is 2016. The year was chosen because it typically takes a utility 4 to 5 years to develop and install capacity once a decision to build new generation is confirmed. This process includes necessary regulatory approvals, air permits, engineering and design, construction, and startup and testing. Due to changing load forecasts, load shapes, outage data, resource mix, and other factors, the study results should be updated periodically.

B. Load Modeling

Table 1. 2016 Load Forecast

| <u>Month</u> | <u>Energy (MWh)</u> | <u>Peak Demand (MW)</u> | <u>Peak Demand (MW)*</u> |
|--------------|---------------------|-------------------------|--------------------------|
| 1 | 3,692,991 | 7269 | 7144 |
| 2 | 3,332,365 | 6962 | 6726 |
| 3 | 3,217,290 | 6205 | 6205 |
| 4 | 2,913,918 | 5297 | 5297 |
| 5 | 2,785,636 | 5611 | 5611 |
| 6 | 3,231,899 | 6592 | 6528 |
| 7 | 3,539,916 | 7011 | 6886 |
| 8 | 3,627,576 | 7196 | 7070 |
| 9 | 2,947,541 | 6536 | 6471 |
| 10 | 2,766,808 | 5103 | 5103 |
| 11 | 2,736,902 | 5186 | 5186 |
| 12 | 3,191,820 | 6061 | 6061 |

*Assumes Reduction For Interruptible Loads

Table 1 displays the monthly peak and energy forecast for 2016 under normal weather conditions. To model the effects of weather uncertainty, 35 synthetic load shapes based on 35 years of historical weather were created to reflect the impact of weather on load. The frequency and duration of severe weather has a significant impact on load shape and therefore reliability

simulations. Based on the last seven years of historical weather and load, a neural network program was used to develop relationships between weather observations, such as temperature, and load. This relationship was then used to develop 35 unique load shapes based on the last 35 years of weather. The synthetic load shapes were then scaled so that the average summer and winter peaks are equivalent to the 2016 forecasted summer and winter peaks. Equal probabilities were given to each of the 35 load shapes in the simulation. Table 2 summarizes the 35 synthetic weather year peaks (not reduced by interruptible load). It is seen that in the most severe weather conditions, the summer peak can be 7% higher than normal weather conditions whereas the most extreme winter peak is only 5% higher than normal weather conditions. The last section of the table represents the distribution of annual energy values seen over the last 35 years.

Table 2. 2016 Peak Load Rankings for All Weather Years

Summer Peaks (MW)

| | | |
|---------|-------|------|
| Max | 7,729 | 107% |
| Average | 7,196 | |
| Min | 6,699 | 93% |

Winter Peaks (MW)

| | | |
|---------|-------|------|
| Max | 7,621 | 105% |
| Average | 7,269 | |
| Min | 6,714 | 92% |

Annual Energy (GWh)

| | | |
|---------|--------|------|
| Max | 39,102 | 103% |
| Average | 37,925 | |
| Min | 36,822 | 97% |

| Rank | Year | Peak (MW) |
|------|------|-----------|
| 1 | 1983 | 7,729 |
| 2 | 1999 | 7,727 |
| 3 | 2007 | 7,648 |
| 4 | 1995 | 7,555 |
| 5 | 2005 | 7,503 |
| 6 | 1980 | 7,480 |
| 7 | 1990 | 7,474 |
| 8 | 1988 | 7,473 |
| 9 | 1978 | 7,401 |
| 10 | 1991 | 7,376 |
| 11 | 2002 | 7,374 |
| 12 | 2006 | 7,373 |
| 13 | 1993 | 7,323 |
| 14 | 1977 | 7,270 |
| 15 | 1987 | 7,232 |
| 16 | 1994 | 7,223 |
| 17 | 1979 | 7,154 |
| 18 | 1998 | 7,150 |
| 19 | 1997 | 7,134 |
| 20 | 2000 | 7,132 |
| 21 | 1981 | 7,109 |
| 22 | 1996 | 7,080 |
| 23 | 1986 | 7,061 |
| 24 | 2001 | 7,049 |
| 25 | 1989 | 7,044 |
| 26 | 2008 | 7,024 |
| 27 | 1976 | 7,004 |
| 28 | 1975 | 6,979 |
| 29 | 2003 | 6,934 |
| 30 | 2009 | 6,877 |
| 31 | 1992 | 6,849 |
| 32 | 1985 | 6,839 |
| 33 | 1984 | 6,806 |
| 34 | 2004 | 6,763 |
| 35 | 1982 | 6,699 |


| Rank | Year | Peak (MW) |
|------|------|-----------|
| 1 | 1977 | 7,621 |
| 2 | 2003 | 7,557 |
| 3 | 2009 | 7,556 |
| 4 | 1982 | 7,514 |
| 5 | 1978 | 7,489 |
| 6 | 1981 | 7,484 |
| 7 | 1992 | 7,469 |
| 8 | 2000 | 7,463 |
| 9 | 1984 | 7,460 |
| 10 | 2004 | 7,440 |
| 11 | 1994 | 7,436 |
| 12 | 1995 | 7,429 |
| 13 | 1979 | 7,416 |
| 14 | 1997 | 7,399 |
| 15 | 1987 | 7,393 |
| 16 | 1999 | 7,335 |
| 17 | 1976 | 7,323 |
| 18 | 2001 | 7,319 |
| 19 | 2005 | 7,299 |
| 20 | 2008 | 7,254 |
| 21 | 2007 | 7,220 |
| 22 | 1989 | 7,199 |
| 23 | 1983 | 7,190 |
| 24 | 1998 | 7,169 |
| 25 | 1991 | 7,144 |
| 26 | 1980 | 7,102 |
| 27 | 2006 | 7,098 |
| 28 | 1986 | 7,090 |
| 29 | 1985 | 7,081 |
| 30 | 1988 | 7,040 |
| 31 | 1993 | 6,980 |
| 32 | 2002 | 6,941 |
| 33 | 1996 | 6,911 |
| 34 | 1975 | 6,884 |
| 35 | 1990 | 6,714 |

| Rank | Year | Energy (GWh) |
|------|------|--------------|
| 1 | 1977 | 39,102 |
| 2 | 1978 | 38,814 |
| 3 | 1980 | 38,757 |
| 4 | 2007 | 38,693 |
| 5 | 2002 | 38,670 |
| 6 | 1983 | 38,597 |
| 7 | 1988 | 38,542 |
| 8 | 2008 | 38,457 |
| 9 | 1995 | 38,356 |
| 10 | 2005 | 38,205 |
| 11 | 1991 | 38,140 |
| 12 | 1993 | 38,041 |
| 13 | 1989 | 38,018 |
| 14 | 1987 | 38,004 |
| 15 | 1981 | 37,994 |
| 16 | 1986 | 37,994 |
| 17 | 1979 | 37,974 |
| 18 | 1999 | 37,963 |
| 19 | 1985 | 37,896 |
| 20 | 1996 | 37,844 |
| 21 | 2000 | 37,801 |
| 22 | 1975 | 37,753 |
| 23 | 1994 | 37,675 |
| 24 | 2003 | 37,663 |
| 25 | 1984 | 37,624 |
| 26 | 1982 | 37,615 |
| 27 | 2001 | 37,539 |
| 28 | 1998 | 37,496 |
| 29 | 1997 | 37,404 |
| 30 | 2009 | 37,305 |
| 31 | 2004 | 37,296 |
| 32 | 2006 | 37,276 |
| 33 | 1976 | 37,163 |
| 34 | 1990 | 36,868 |
| 35 | 1992 | 36,822 |

C. Load Forecast Error due to Economic Growth Uncertainty

Based on the observed load forecast error using 4 and 5 year load forecasts compared to normalized peak loads for the same periods, the following distribution was created to represent load forecast error relative to economic growth uncertainty. The continuous normal distribution was converted into a discrete distribution with the 7 points shown in the table below for use in determining discrete scenarios to be modeled. In the most extreme cases modeled, load can be as much at 4.76% higher than the 5 year forecast due to economic growth assumptions. This scenario has a 2.25% probability of occurring.

Figure 1. Load Forecast Error Due to Economic Growth Uncertainty



SERVM utilized each of the 35 weather years and applied each of these 7 load forecast error points to create 245 different load scenarios. Given that SERVM matches load and generation perfectly, every MW of load above the available capacity is calculated as EUE, but no adjustment is made for shedding more load than is required. In actual practice, load would be curtailed in large blocks and would be off longer than necessary. This limitation was offset by adding 50 MW of load to each hour in the study above the load forecast error assumption.

D. Resources

The resources and assumed monthly capacities for the 2016 study are shown in the following tables. For the simulation, the amounts of peaking units were varied to achieve different reserve margin levels. Once all existing peaking resources were utilized, a generic combustion turbine was used which is documented in Part J of the input section.

Table 3. Summary of Resources

| | Jan | Feb | Mar | Apr | May | Jun | Jul | Aug | Sep | Oct | Nov | Dec |
|--|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|
| Base Load and Intermediate Capacity | 5,688 | 5,688 | 5,658 | 5,599 | 5,599 | 5,568 | 5,568 | 5,568 | 5,599 | 5,658 | 5,656 | 5,686 |
| Peaking Capacity | 2,341 | 2,341 | 2,166 | 2,238 | 2,238 | 2,115 | 2,115 | 2,115 | 2,238 | 2,166 | 2,166 | 2,341 |
| Hydro Capacity | 130 | 130 | 130 | 130 | 130 | 130 | 130 | 130 | 130 | 130 | 130 | 130 |
| Total | 8,159 | 8,159 | 7,954 | 7,967 | 7,967 | 7,813 | 7,813 | 7,813 | 7,967 | 7,954 | 7,952 | 8,157 |

Table 4. Base load and Intermediate Capacity

| Base Load and Intermediate Capacity | Jan | Feb | Mar | Apr | May | Jun | Jul | Aug | Sep | Oct | Nov | Dec |
|--|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|
| Brown.1 | 107 | 107 | 107 | 105 | 105 | 105 | 105 | 105 | 105 | 107 | 107 | 107 |
| Brown.2 | 167 | 167 | 167 | 165 | 165 | 165 | 165 | 165 | 165 | 167 | 167 | 167 |
| Brown.3 | 407 | 407 | 407 | 403 | 403 | 403 | 403 | 403 | 403 | 407 | 407 | 407 |
| Ghent.1 | 481 | 481 | 481 | 488 | 488 | 488 | 488 | 488 | 488 | 481 | 481 | 481 |
| Ghent.2 | 476 | 476 | 476 | 486 | 486 | 486 | 486 | 486 | 486 | 476 | 476 | 476 |
| Ghent.3 | 480 | 480 | 465 | 465 | 465 | 449 | 449 | 449 | 465 | 465 | 465 | 480 |
| Ghent.4 | 491 | 491 | 487 | 487 | 487 | 483 | 483 | 483 | 487 | 487 | 487 | 491 |
| Mill.Creek.1 | 300 | 300 | 300 | 300 | 300 | 300 | 300 | 300 | 300 | 300 | 298 | 298 |
| Mill.Creek.2 | 296 | 296 | 296 | 298 | 298 | 298 | 298 | 298 | 298 | 296 | 296 | 296 |
| Mill.Creek.3 | 393 | 393 | 393 | 387 | 387 | 387 | 387 | 387 | 387 | 393 | 393 | 393 |
| Mill.Creek.4 | 487 | 487 | 487 | 472 | 472 | 472 | 472 | 472 | 472 | 487 | 487 | 487 |
| Trimble.County.1 | 381 | 381 | 381 | 378 | 378 | 378 | 378 | 378 | 378 | 381 | 381 | 381 |
| Trimble.County.2 | 571 | 571 | 560 | 560 | 560 | 549 | 549 | 549 | 560 | 560 | 560 | 571 |
| Tyrone.3 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| Combined.Cycle.2016 (2x1) | 651 | 651 | 651 | 605 | 605 | 605 | 605 | 605 | 605 | 651 | 651 | 651 |
| Total | 5,688 | 5,688 | 5,658 | 5,599 | 5,599 | 5,568 | 5,568 | 5,568 | 5,599 | 5,658 | 5,656 | 5,686 |

Table 5. Peaking Capacity

| Peaking Capacity | Jan | Feb | Mar | Apr | May | Jun | Jul | Aug | Sep | Oct | Nov | Dec |
|------------------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|
| Brown.10 | 129 | 129 | 116 | 116 | 116 | 102 | 102 | 102 | 116 | 116 | 116 | 129 |
| Brown.11 | 129 | 129 | 116 | 116 | 116 | 102 | 102 | 102 | 116 | 116 | 116 | 129 |
| Brown.5 | 131 | 131 | 122 | 122 | 122 | 112 | 112 | 112 | 122 | 122 | 122 | 131 |
| Brown.6 | 163 | 163 | 155 | 155 | 155 | 146 | 146 | 146 | 155 | 155 | 155 | 163 |
| Brown.7 | 163 | 163 | 155 | 155 | 155 | 146 | 146 | 146 | 155 | 155 | 155 | 163 |
| Brown.8 | 129 | 129 | 116 | 116 | 116 | 102 | 102 | 102 | 116 | 116 | 116 | 129 |
| Brown.9 | 129 | 129 | 116 | 116 | 116 | 102 | 102 | 102 | 116 | 116 | 116 | 129 |
| Cane.Run.11 | 14 | 14 | 14 | 14 | 14 | 14 | 14 | 14 | 14 | 14 | 14 | 14 |
| Haefling | 42 | 42 | 42 | 36 | 36 | 36 | 36 | 36 | 36 | 42 | 42 | 42 |
| Paddys.Run.11T | 13 | 13 | 13 | 12 | 12 | 12 | 12 | 12 | 12 | 13 | 13 | 13 |
| Paddys.Run.12T | 28 | 28 | 28 | 23 | 23 | 23 | 23 | 23 | 23 | 28 | 28 | 28 |
| Paddys.Run.13T | 175 | 175 | 167 | 167 | 167 | 158 | 158 | 158 | 167 | 167 | 167 | 175 |
| Trimble.Co.05T | 180 | 180 | 165 | 165 | 165 | 160 | 160 | 160 | 165 | 165 | 165 | 180 |
| Trimble.Co.06T | 180 | 180 | 165 | 165 | 165 | 160 | 160 | 160 | 165 | 165 | 165 | 180 |
| Trimble.Co.07T | 180 | 180 | 165 | 165 | 165 | 160 | 160 | 160 | 165 | 165 | 165 | 180 |
| Trimble.Co.08T | 180 | 180 | 165 | 165 | 165 | 160 | 160 | 160 | 165 | 165 | 165 | 180 |
| Trimble.Co.09T | 180 | 180 | 165 | 165 | 165 | 160 | 160 | 160 | 165 | 165 | 165 | 180 |
| Trimble.Co.10T | 180 | 180 | 165 | 165 | 165 | 160 | 160 | 160 | 165 | 165 | 165 | 180 |
| Zorn.1 | 16 | 16 | 16 | 14 | 14 | 14 | 14 | 14 | 14 | 16 | 16 | 16 |
| Brown.ICE.Units | 0 | 0 | 0 | 86 | 86 | 86 | 86 | 86 | 86 | 0 | 0 | 0 |
| Total | 2,341 | 2,341 | 2,166 | 2,238 | 2,238 | 2,115 | 2,115 | 2,115 | 2,238 | 2,166 | 2,166 | 2,341 |

Table 6. Hydro Capacity

| Hydro | Jan | Feb | Mar | Apr | May | Jun | Jul | Aug | Sep | Oct | Nov | Dec |
|------------|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|
| Ohio.Falls | 100 | 100 | 100 | 100 | 100 | 100 | 100 | 100 | 100 | 100 | 100 | 100 |
| Dix.Dam | 30 | 30 | 30 | 30 | 30 | 30 | 30 | 30 | 30 | 30 | 30 | 30 |
| Total* | 130 | 130 | 130 | 130 | 130 | 130 | 130 | 130 | 130 | 130 | 130 | 130 |

*Expected Capacity Available during Summer Peak hours is 94 MW

E. Unit Outage Data

Generating units typically operate for a period of time, fail and are repaired, and then operate again. SERVVM uses historical outage events for each unit representing both full outages and partial outages. SERVVM then randomly selects operating events from the historical events to determine generator availability. For every hour, each unit will be on reserve shutdown, operating, partially failed, completely failed, or on scheduled maintenance. GADS data was available for all units and data from 2007 – 2010 was used for this study to accurately represent the frequency and duration of full and partial outages. An example of the outage data input into SERVVM is below.

Table 7. Full Outage Example

| | | Summer Time to Fail Hours | Summer Time to Repair Hours | Winter Time to Fail Hours | Winter Time to Repair Hours | Off Peak Time to Fail Hours | Off Peak Time to Repair Hours |
|---------|--|------------------------------------|--------------------------------------|------------------------------------|--------------------------------------|--------------------------------------|--|
| Ghent 1 | | | | | | | |
| Ghent 1 | | | | | | | |
| Ghent 1 | | | | | | | |
| Ghent 1 | | | | | | | |

Table 8. Partial Outage Example

| | | Summer Time to Fail Hours | Summer Time to Repair Hours | Summer Derate % | Winter Time to Fail Hours | Winter Time to Repair Hours | Winter Derate % | Off Peak Time to Fail Hours | Off Peak Time to Repair Hours | Off Peak Derate % |
|---------|--|------------------------------------|--------------------------------------|--------------------|------------------------------------|--------------------------------------|--------------------|--------------------------------------|--|----------------------|
| Ghent 1 | | | | | | | | | | |
| Ghent 1 | | | | | | | | | | |
| Ghent 1 | | | | | | | | | | |
| Ghent 1 | | | | | | | | | | |


The following Equivalent Forced Outage Rates were targeted for each unit.

Table 9. Equivalent Forced Outage Rate

| Unit | EFOR | Unit | EFOR |
|----------------|------|------------------|------|
| Brown 5 | | Brown 1 | |
| Brown 6 | | | |
| Brown 7 | | | |
| Brown 8 | | | |
| Brown 9 | | | |
| Brown 10 | | | |
| Brown 11 | | | |
| Trimble Co 5 | | | |
| Trimble Co 6 | | | |
| Trimble Co 7 | | | |
| Trimble Co 8 | | | |
| Trimble Co 9 | | | |
| Trimble Co 10 | | | |
| Paddy's Run 13 | | | |
| Cane Run 11 | | | |
| Haefling 1 | | | |
| Haefling 2 | | | |
| Haefling 3 | | | |
| Paddy's Run 11 | | | |
| Paddy's Run 12 | | | |
| Zorn 1 | | | |
| | | Brown 2 | |
| | | Brown 3 | |
| | | Ghent 1 | |
| | | Ghent 2 | |
| | | Ghent 3 | |
| | | Ghent 4 | |
| | | Mill Creek 1 | |
| | | Mill Creek 2 | |
| | | Mill Creek 3 | |
| | | Mill Creek 4 | |
| | | Trimble County 1 | |
| | | Trimble County 2 | |
| | | Tyrone 3 | |

Figure 2 shows the total capacity offline as a percentage of total time. The chart compares the actual 2007 – 2010 data to the simulated distribution created within SERVVM. This comparison demonstrates the ability of the model to accurately predict the frequency and duration of generator outages based on history to ensure that the tails of the distribution are reasonable. It is seen that approximately 20% of the time, there are at least 1,000 MW offline due to generator outages or 80% of the time that there are less than 1,000 MW offline.


Figure 2. Probability of Capacity Offline



F. Planned Outage Data

The planned outage schedule for 2016 was incorporated into the analysis. Figure 3 shows the planned outages modeled in the simulation.

Figure 3. Planned Maintenance Outages



G. Hydro Modeling

Based on upgrades planned at Ohio Falls and Dix Dam, it is expected that 130 MW of hydro capacity will exist in 2016. However, it is not expected that all 130 MW of hydro capacity will be available on peak and based on operator input, the units were only dispatched up to 94 MW on peak. SERVVM has the ability to divide the hydro energy into run or river, scheduled energy with minimum flow requirements, and emergency energy. Ohio Falls and Dix Dam were modeled as scheduled energy and allowed to be optimally dispatched to peak load while only allowing 94 MW of capacity to be utilized across the peak. Given the small amount of hydro on the system, it unlikely the assumptions regarding hydro would be extremely material.

H. Load Management

A total of 126 MWs of load management were modeled in the simulation to be called upon given a reliability event similarly to a generating resource. These resources are called after all peaking resources are utilized. SERVVM takes into account the user input constraints on load

CONFIDENTIAL INFORMATION

management and dispatches accordingly. These constraints include a market price threshold before the interruptible contracts are called, a maximum number of hours per day, days per week, and hours per year. Because most of the company’s load management contracts force them to dispatch all existing resources first, the dispatch price was set at \$500/MWh. Table 10 summarizes the load management modeling.

Table 10. Load Management Representation


| Interruptible Contracts | Capacity MW | Hours Per Year | Dispatch Constraints | | |
|-------------------------|----------------|----------------|----------------------|---------------|------------------------|
| | | | Hours Per Day | Days Per Week | Dispatch Price \$/MWh* |
| | | 100 | 14 | 7 | 500 |
| | | 200 | 14 | 7 | 0 |
| | | 100 | 14 | 7 | 500 |
| | | 100 | 14 | 7 | 500 |
| | | 150 | 14 | 7 | 0 |
| | | 100 | 14 | 7 | 500 |
| Total | 125.6 | | | | |

*\$500/MWh was chosen to ensure that interruptibles were called after all resources and market purchases were dispatched. The contracts that have a \$0 dispatch price are called after the last CT is called.

I. Neighbor Representation and Reliability Purchase Modeling

The purpose of the market purchase modeling is to ensure that in a reliability event, SERVVM takes into account the ability of a utility to purchase capacity from its neighbors if capacity and transmission are available. It is expected that if a utility is in a reliability event due to high load conditions or extreme weather, then surrounding neighbors will likely be experiencing similar conditions causing capacity to be scarce. SERVVM calculates on an hourly basis, the expected capacity that is available in surrounding regions, the expected amount of import capability, and the scarcity premium that will be charged for the reliability purchase. Figure 4 displays the representation of interconnected neighbors.

Figure 4. Neighbor Summary




| Area | Reference for Capacity | Capacity | Peak Load | Reserve Margin |
|------|---------------------------------------|----------|-----------|----------------|
| PJM | PJM 2009 Reserve Margin Study | 184,000 | 160,000 | 15% |
| MISO | MISO LOLE Update for 2010, 2014, 2019 | 125,776 | 109,370 | 15% |
| EKPC | EIA 860 Forms | 3,592 | 3,123 | 15% |
| TVA | EIA 860 Forms | 40,226 | 34,979 | 15% |
| BREC | EIA 860 Forms | 1,971 | 1,714 | 15% |

The surrounding neighbor capacity information is based on publicly available information and engineering judgment. It was assumed that by 2016, surrounding areas will carry a 15% reserve margin level. Each neighbor’s capacity is dispatched to load to determine the hourly available generation at each interface. SERVUM is a transportation model in which transmission interface limits are input and varied hourly across each import interface. Historical hourly import capability was analyzed to establish a distribution that was representative of available transmission capacity. Astrape Consulting calibrated the amount of purchases predicted by the model based on historical purchases during high load periods. The amount of purchases that are occurring on average by load level in the simulations can be seen in Figure 5. As load


increases, reliability purchases increase but then decrease as the peak load is approached due to overall scarcity in the region.

Figure 5. Simulated Market Purchases by Load Level



The scarcity cost curves in Figure 6 represent the pricing that was assumed for purchases in the model. The prices represent the additional premium for energy above the cost of a CT. As reserve margins in the region for a given year are low and capacity shortages occur, the premium for energy in those hours is substantially higher than in conditions when reserves in the region are high. Reliability purchases are called upon after peaking resources have been dispatched in the system. It should be noted that these curves do not determine whether or not capacity is available, instead the curves are only used for the price if capacity and import capability from another region is available. These curves are based on actual company purchases over the last 6 years and extrapolated to tighter conditions and capped at the cost of unserved energy. As part of the modeling process, Astrape Consulting calibrated the model results to recent years to ensure that SERVIM is predicting reliability purchase costs reasonably.

Figure 6. Reliability Purchase Price Model



J. Carrying Cost of Reserves

The cost of carrying incremental reserves was based on the capital and fixed O&M of a new combustion turbine with the following characteristics.

Table 11. Generic Combustion Turbine Characteristics
Marginal Combustion Turbine

| | |
|------------------------------|------------|
| Fixed Charge Rate | 10.38% |
| Capital Cost - 2010 \$/kW-yr | ██████████ |
| Fixed O&M 2010\$ /kW-yr | 6.12 |
| Escalation Assumption | 2.50% |
| Discount Rate | 6.96% |
| Variable O&M 2010 \$/MWh | 25.38 |
| Heat Rate btu/kWh | 10,446 |

For this study additional reserves cost \$██████████/kW-yr as shown in Table 12.

Table 12. Carrying Cost of Reserves

| | Capital Cost | Fixed O&M | |
|------|--------------|-----------|----------|
| | \$/kW-yr | \$/kW-yr | \$/kW-yr |
| 2016 | | \$ 7.10 | |

K. Operating Reserve Requirements

The total operating reserve requirement assumed in the study is 287 MW. The spinning reserve requirement is 212 MW. Within the simulation, it is assumed that the company would shed firm load in order to maintain operating reserve requirements.

L. Cost of Unserved Energy (Value of Lost Load)

Some of the impacts of outages on business and residential customers include loss of productivity, interruption of a manufacturing process, lost product, potential damage to electrical services, and inconvenience or discomfort due to loss of cooling, heating, or lighting. While the value of lost load is important to understand, the risk of paying expensive market purchases in the market place impacts results more than the assumption for the value of lost load. For this study, unserved energy costs were derived based on information from four publicly available studies. Two of the studies were performed by the Berkeley National Laboratory for the Department of Energy in 2003 and 2009 respectively. All studies split customers into residential, commercial, and industrial classes which is a typical breakdown of customers in the electric industry. After escalating the costs from each study to 2010 dollars and weighting the cost based on LG&E and KU customer class weightings across all four studies, the cost of unserved energy costs was calculated to be \$14.97/kWh. Table 13 shows how the numbers were derived. The range for residential customers varied from \$1.1/kWh to \$2.82/kWh. The range

for commercial customers varied from \$20.22/kWh to \$29.94/kWh while industrial customers varied from \$10.48/kWh to \$24.31/kWh. It is expected that commercial and industrial customers would place a much higher value on reliability given the impact of lost production and/or product. The total system cost variance across the four studies was approximately \$6,000/MWh. As part of the reserve margin study, an additional sensitivity was performed to analyze how the cost of unserved energy assumption impacts the optimal planning reserve margin. Optimum reserve margins using a range of lost load value from \$5000 to \$30000/MWh only varied from 0.50% to 0.75% due to the rarity of outage events.

Table 13. Costs of Unserved Energy

| | | 2003 DOE Study | 2009 DOE Study | Christian Associates Study | Billinton and Wacker Study |
|--|--------------------|----------------|----------------|----------------------------|----------------------------|
| | Customer Class Mix | \$/kWh | \$/kWh | \$/kWh | \$/kWh |
| Residential | 34% | 1.32 | 1.12 | 2.82 | 2.47 |
| Commercial | 36% | 29.94 | 27.20 | 20.22 | 21.01 |
| Industrial | 30% | 17.27 | 24.31 | 10.48 | 21.01 |
| System Cost of Unserved Energy | | 16.37 | 17.46 | 11.35 | 14.71 |
| | | Min | Mean | Max | Variance |
| | Customer Class Mix | \$/kWh | \$/kWh | \$/kWh | \$/kWh |
| Residential | 34% | 1.12 | 1.93 | 2.82 | 1.69 |
| Commercial | 36% | 20.22 | 24.59 | 29.94 | 9.72 |
| Industrial | 30% | 10.48 | 18.27 | 24.31 | 13.83 |
| Average System Cost of Unserved Energy \$/kWh | | | 14.97 | | |
| All Values Scaled to 2010\$ | | | | | |

IV. Simulation Methodology

Since most reliability events are high impact, low probability events, a large number of scenarios must be considered in order to capture these events. Simply constructing worst case scenarios will not give an accurate representation of the operation of any system during such an event, nor would it provide the likelihood of such a scenario. By utilizing 35 years of historical weather, a robust distribution of load shapes will be considered. For each load shape, 7 load growth

multipliers are used to represent the uncertainty in the growth of the economy. For each of these 245 cases (35 load shapes * 7 economic forecast uncertainty points), 400 iterations of unit performance were simulated to allow for results to converge in each case resulting in 98,000 hourly simulations for each reserve margin level. From this analysis, an expected reliability energy costs can be calculated and compared to the cost of adding additional reserves which is equal to the carrying cost of a generic CT.

A. Case Probabilities

The probabilities given for each case are shown in Table 14. It is assumed that each weather year is given equal probability and each weather year is multiplied by the probability of each load forecast error point to calculate the overall case probability.

Table 14. Case Probabilities

| Weather Year | Weather Year Probability | LDF Errors | LDF Probability | Case Probability | Weather Year | Weather Year Probability | LDF Errors | LDF Probability | Case Probability |
|--------------|--------------------------|------------|-----------------|------------------|--------------|--------------------------|------------|-----------------|------------------|
| 1975 | 2.9% | -4.76% | 2.2% | 0.1% | 1983 | 2.9% | -4.8% | 2.2% | 0.1% |
| 1975 | 2.9% | -3.05% | 9.2% | 0.3% | 1983 | 2.9% | -3.0% | 9.2% | 0.3% |
| 1975 | 2.9% | -1.53% | 22.9% | 0.7% | 1983 | 2.9% | -1.5% | 22.9% | 0.7% |
| 1975 | 2.9% | 0.00% | 31.5% | 0.9% | 1983 | 2.9% | 0.0% | 31.5% | 0.9% |
| 1975 | 2.9% | 1.53% | 22.9% | 0.7% | 1983 | 2.9% | 1.5% | 22.9% | 0.7% |
| 1975 | 2.9% | 3.05% | 9.2% | 0.3% | 1983 | 2.9% | 3.0% | 9.2% | 0.3% |
| 1975 | 2.9% | 4.76% | 2.2% | 0.1% | 1983 | 2.9% | 4.8% | 2.2% | 0.1% |
| 1976 | 2.9% | -4.8% | 2.2% | 0.1% | 1984 | 2.9% | -4.8% | 2.2% | 0.1% |
| 1976 | 2.9% | -3.0% | 9.2% | 0.3% | 1984 | 2.9% | -3.0% | 9.2% | 0.3% |
| 1976 | 2.9% | -1.5% | 22.9% | 0.7% | 1984 | 2.9% | -1.5% | 22.9% | 0.7% |
| 1976 | 2.9% | 0.0% | 31.5% | 0.9% | 1984 | 2.9% | 0.0% | 31.5% | 0.9% |
| 1976 | 2.9% | 1.5% | 22.9% | 0.7% | 1984 | 2.9% | 1.5% | 22.9% | 0.7% |
| 1976 | 2.9% | 3.0% | 9.2% | 0.3% | 1984 | 2.9% | 3.0% | 9.2% | 0.3% |
| 1976 | 2.9% | 4.8% | 2.2% | 0.1% | 1984 | 2.9% | 4.8% | 2.2% | 0.1% |
| 1977 | 2.9% | -4.8% | 2.2% | 0.1% | 1985 | 2.9% | -4.8% | 2.2% | 0.1% |
| 1977 | 2.9% | -3.0% | 9.2% | 0.3% | 1985 | 2.9% | -3.0% | 9.2% | 0.3% |
| 1977 | 2.9% | -1.5% | 22.9% | 0.7% | 1985 | 2.9% | -1.5% | 22.9% | 0.7% |
| 1977 | 2.9% | 0.0% | 31.5% | 0.9% | 1985 | 2.9% | 0.0% | 31.5% | 0.9% |
| 1977 | 2.9% | 1.5% | 22.9% | 0.7% | 1985 | 2.9% | 1.5% | 22.9% | 0.7% |
| 1977 | 2.9% | 3.0% | 9.2% | 0.3% | 1985 | 2.9% | 3.0% | 9.2% | 0.3% |
| 1977 | 2.9% | 4.8% | 2.2% | 0.1% | 1985 | 2.9% | 4.8% | 2.2% | 0.1% |
| 1978 | 2.9% | -4.8% | 2.2% | 0.1% | 1986 | 2.9% | -4.8% | 2.2% | 0.1% |
| 1978 | 2.9% | -3.0% | 9.2% | 0.3% | 1986 | 2.9% | -3.0% | 9.2% | 0.3% |
| 1978 | 2.9% | -1.5% | 22.9% | 0.7% | 1986 | 2.9% | -1.5% | 22.9% | 0.7% |
| 1978 | 2.9% | 0.0% | 31.5% | 0.9% | 1986 | 2.9% | 0.0% | 31.5% | 0.9% |
| 1978 | 2.9% | 1.5% | 22.9% | 0.7% | 1986 | 2.9% | 1.5% | 22.9% | 0.7% |
| 1978 | 2.9% | 3.0% | 9.2% | 0.3% | 1986 | 2.9% | 3.0% | 9.2% | 0.3% |
| 1978 | 2.9% | 4.8% | 2.2% | 0.1% | 1986 | 2.9% | 4.8% | 2.2% | 0.1% |
| 1979 | 2.9% | -4.8% | 2.2% | 0.1% | 1987 | 2.9% | -4.8% | 2.2% | 0.1% |
| 1979 | 2.9% | -3.0% | 9.2% | 0.3% | 1987 | 2.9% | -3.0% | 9.2% | 0.3% |
| 1979 | 2.9% | -1.5% | 22.9% | 0.7% | 1987 | 2.9% | -1.5% | 22.9% | 0.7% |
| 1979 | 2.9% | 0.0% | 31.5% | 0.9% | 1987 | 2.9% | 0.0% | 31.5% | 0.9% |
| 1979 | 2.9% | 1.5% | 22.9% | 0.7% | 1987 | 2.9% | 1.5% | 22.9% | 0.7% |
| 1979 | 2.9% | 3.0% | 9.2% | 0.3% | 1987 | 2.9% | 3.0% | 9.2% | 0.3% |
| 1979 | 2.9% | 4.8% | 2.2% | 0.1% | 1987 | 2.9% | 4.8% | 2.2% | 0.1% |
| 1980 | 2.9% | -4.8% | 2.2% | 0.1% | 1988 | 2.9% | -4.8% | 2.2% | 0.1% |
| 1980 | 2.9% | -3.0% | 9.2% | 0.3% | 1988 | 2.9% | -3.0% | 9.2% | 0.3% |
| 1980 | 2.9% | -1.5% | 22.9% | 0.7% | 1988 | 2.9% | -1.5% | 22.9% | 0.7% |
| 1980 | 2.9% | 0.0% | 31.5% | 0.9% | 1988 | 2.9% | 0.0% | 31.5% | 0.9% |
| 1980 | 2.9% | 1.5% | 22.9% | 0.7% | 1988 | 2.9% | 1.5% | 22.9% | 0.7% |
| 1980 | 2.9% | 3.0% | 9.2% | 0.3% | 1988 | 2.9% | 3.0% | 9.2% | 0.3% |
| 1980 | 2.9% | 4.8% | 2.2% | 0.1% | 1988 | 2.9% | 4.8% | 2.2% | 0.1% |
| 1981 | 2.9% | -4.8% | 2.2% | 0.1% | 1989 | 2.9% | -4.8% | 2.2% | 0.1% |
| 1981 | 2.9% | -3.0% | 9.2% | 0.3% | 1989 | 2.9% | -3.0% | 9.2% | 0.3% |
| 1981 | 2.9% | -1.5% | 22.9% | 0.7% | 1989 | 2.9% | -1.5% | 22.9% | 0.7% |
| 1981 | 2.9% | 0.0% | 31.5% | 0.9% | 1989 | 2.9% | 0.0% | 31.5% | 0.9% |
| 1981 | 2.9% | 1.5% | 22.9% | 0.7% | 1989 | 2.9% | 1.5% | 22.9% | 0.7% |
| 1981 | 2.9% | 3.0% | 9.2% | 0.3% | 1989 | 2.9% | 3.0% | 9.2% | 0.3% |
| 1981 | 2.9% | 4.8% | 2.2% | 0.1% | 1989 | 2.9% | 4.8% | 2.2% | 0.1% |
| 1982 | 2.9% | -4.8% | 2.2% | 0.1% | 1990 | 2.9% | -4.8% | 2.2% | 0.1% |
| 1982 | 2.9% | -3.0% | 9.2% | 0.3% | 1990 | 2.9% | -3.0% | 9.2% | 0.3% |
| 1982 | 2.9% | -1.5% | 22.9% | 0.7% | 1990 | 2.9% | -1.5% | 22.9% | 0.7% |
| 1982 | 2.9% | 0.0% | 31.5% | 0.9% | 1990 | 2.9% | 0.0% | 31.5% | 0.9% |
| 1982 | 2.9% | 1.5% | 22.9% | 0.7% | 1990 | 2.9% | 1.5% | 22.9% | 0.7% |
| 1982 | 2.9% | 3.0% | 9.2% | 0.3% | 1990 | 2.9% | 3.0% | 9.2% | 0.3% |
| 1982 | 2.9% | 4.8% | 2.2% | 0.1% | 1990 | 2.9% | 4.8% | 2.2% | 0.1% |

LG&E and KU Reserve Margin Study

| Weather Year | Weather Year Probability | LDF Errors | LDF Probability | Case Probability | Weather Year | Weather Year Probability | LDF Errors | LDF Probability | Case Probability |
|--------------|--------------------------|------------|-----------------|------------------|--------------|--------------------------|------------|-----------------|------------------|
| 1991 | 2.9% | -4.8% | 2.2% | 0.1% | 1999 | 2.9% | -4.8% | 2.2% | 0.1% |
| 1991 | 2.9% | -3.0% | 9.2% | 0.3% | 1999 | 2.9% | -3.0% | 9.2% | 0.3% |
| 1991 | 2.9% | -1.5% | 22.9% | 0.7% | 1999 | 2.9% | -1.5% | 22.9% | 0.7% |
| 1991 | 2.9% | 0.0% | 31.5% | 0.9% | 1999 | 2.9% | 0.0% | 31.5% | 0.9% |
| 1991 | 2.9% | 1.5% | 22.9% | 0.7% | 1999 | 2.9% | 1.5% | 22.9% | 0.7% |
| 1991 | 2.9% | 3.0% | 9.2% | 0.3% | 1999 | 2.9% | 3.0% | 9.2% | 0.3% |
| 1991 | 2.9% | 4.8% | 2.2% | 0.1% | 1999 | 2.9% | 4.8% | 2.2% | 0.1% |
| 1992 | 2.9% | -4.8% | 2.2% | 0.1% | 2000 | 2.9% | -4.8% | 2.2% | 0.1% |
| 1992 | 2.9% | -3.0% | 9.2% | 0.3% | 2000 | 2.9% | -3.0% | 9.2% | 0.3% |
| 1992 | 2.9% | -1.5% | 22.9% | 0.7% | 2000 | 2.9% | -1.5% | 22.9% | 0.7% |
| 1992 | 2.9% | 0.0% | 31.5% | 0.9% | 2000 | 2.9% | 0.0% | 31.5% | 0.9% |
| 1992 | 2.9% | 1.5% | 22.9% | 0.7% | 2000 | 2.9% | 1.5% | 22.9% | 0.7% |
| 1992 | 2.9% | 3.0% | 9.2% | 0.3% | 2000 | 2.9% | 3.0% | 9.2% | 0.3% |
| 1992 | 2.9% | 4.8% | 2.2% | 0.1% | 2000 | 2.9% | 4.8% | 2.2% | 0.1% |
| 1993 | 2.9% | -4.8% | 2.2% | 0.1% | 2001 | 2.9% | -4.8% | 2.2% | 0.1% |
| 1993 | 2.9% | -3.0% | 9.2% | 0.3% | 2001 | 2.9% | -3.0% | 9.2% | 0.3% |
| 1993 | 2.9% | -1.5% | 22.9% | 0.7% | 2001 | 2.9% | -1.5% | 22.9% | 0.7% |
| 1993 | 2.9% | 0.0% | 31.5% | 0.9% | 2001 | 2.9% | 0.0% | 31.5% | 0.9% |
| 1993 | 2.9% | 1.5% | 22.9% | 0.7% | 2001 | 2.9% | 1.5% | 22.9% | 0.7% |
| 1993 | 2.9% | 3.0% | 9.2% | 0.3% | 2001 | 2.9% | 3.0% | 9.2% | 0.3% |
| 1993 | 2.9% | 4.8% | 2.2% | 0.1% | 2001 | 2.9% | 4.8% | 2.2% | 0.1% |
| 1994 | 2.9% | -4.8% | 2.2% | 0.1% | 2002 | 2.9% | -4.8% | 2.2% | 0.1% |
| 1994 | 2.9% | -3.0% | 9.2% | 0.3% | 2002 | 2.9% | -3.0% | 9.2% | 0.3% |
| 1994 | 2.9% | -1.5% | 22.9% | 0.7% | 2002 | 2.9% | -1.5% | 22.9% | 0.7% |
| 1994 | 2.9% | 0.0% | 31.5% | 0.9% | 2002 | 2.9% | 0.0% | 31.5% | 0.9% |
| 1994 | 2.9% | 1.5% | 22.9% | 0.7% | 2002 | 2.9% | 1.5% | 22.9% | 0.7% |
| 1994 | 2.9% | 3.0% | 9.2% | 0.3% | 2002 | 2.9% | 3.0% | 9.2% | 0.3% |
| 1994 | 2.9% | 4.8% | 2.2% | 0.1% | 2002 | 2.9% | 4.8% | 2.2% | 0.1% |
| 1995 | 2.9% | -4.8% | 2.2% | 0.1% | 2003 | 2.9% | -4.8% | 2.2% | 0.1% |
| 1995 | 2.9% | -3.0% | 9.2% | 0.3% | 2003 | 2.9% | -3.0% | 9.2% | 0.3% |
| 1995 | 2.9% | -1.5% | 22.9% | 0.7% | 2003 | 2.9% | -1.5% | 22.9% | 0.7% |
| 1995 | 2.9% | 0.0% | 31.5% | 0.9% | 2003 | 2.9% | 0.0% | 31.5% | 0.9% |
| 1995 | 2.9% | 1.5% | 22.9% | 0.7% | 2003 | 2.9% | 1.5% | 22.9% | 0.7% |
| 1995 | 2.9% | 3.0% | 9.2% | 0.3% | 2003 | 2.9% | 3.0% | 9.2% | 0.3% |
| 1995 | 2.9% | 4.8% | 2.2% | 0.1% | 2003 | 2.9% | 4.8% | 2.2% | 0.1% |
| 1996 | 2.9% | -4.8% | 2.2% | 0.1% | 2004 | 2.9% | -4.8% | 2.2% | 0.1% |
| 1996 | 2.9% | -3.0% | 9.2% | 0.3% | 2004 | 2.9% | -3.0% | 9.2% | 0.3% |
| 1996 | 2.9% | -1.5% | 22.9% | 0.7% | 2004 | 2.9% | -1.5% | 22.9% | 0.7% |
| 1996 | 2.9% | 0.0% | 31.5% | 0.9% | 2004 | 2.9% | 0.0% | 31.5% | 0.9% |
| 1996 | 2.9% | 1.5% | 22.9% | 0.7% | 2004 | 2.9% | 1.5% | 22.9% | 0.7% |
| 1996 | 2.9% | 3.0% | 9.2% | 0.3% | 2004 | 2.9% | 3.0% | 9.2% | 0.3% |
| 1996 | 2.9% | 4.8% | 2.2% | 0.1% | 2004 | 2.9% | 4.8% | 2.2% | 0.1% |
| 1997 | 2.9% | -4.8% | 2.2% | 0.1% | 2005 | 2.9% | -4.8% | 2.2% | 0.1% |
| 1997 | 2.9% | -3.0% | 9.2% | 0.3% | 2005 | 2.9% | -3.0% | 9.2% | 0.3% |
| 1997 | 2.9% | -1.5% | 22.9% | 0.7% | 2005 | 2.9% | -1.5% | 22.9% | 0.7% |
| 1997 | 2.9% | 0.0% | 31.5% | 0.9% | 2005 | 2.9% | 0.0% | 31.5% | 0.9% |
| 1997 | 2.9% | 1.5% | 22.9% | 0.7% | 2005 | 2.9% | 1.5% | 22.9% | 0.7% |
| 1997 | 2.9% | 3.0% | 9.2% | 0.3% | 2005 | 2.9% | 3.0% | 9.2% | 0.3% |
| 1997 | 2.9% | 4.8% | 2.2% | 0.1% | 2005 | 2.9% | 4.8% | 2.2% | 0.1% |
| 1998 | 2.9% | -4.8% | 2.2% | 0.1% | 2006 | 2.9% | -4.8% | 2.2% | 0.1% |
| 1998 | 2.9% | -3.0% | 9.2% | 0.3% | 2006 | 2.9% | -3.0% | 9.2% | 0.3% |
| 1998 | 2.9% | -1.5% | 22.9% | 0.7% | 2006 | 2.9% | -1.5% | 22.9% | 0.7% |
| 1998 | 2.9% | 0.0% | 31.5% | 0.9% | 2006 | 2.9% | 0.0% | 31.5% | 0.9% |
| 1998 | 2.9% | 1.5% | 22.9% | 0.7% | 2006 | 2.9% | 1.5% | 22.9% | 0.7% |
| 1998 | 2.9% | 3.0% | 9.2% | 0.3% | 2006 | 2.9% | 3.0% | 9.2% | 0.3% |
| 1998 | 2.9% | 4.8% | 2.2% | 0.1% | 2006 | 2.9% | 4.8% | 2.2% | 0.1% |

| Weather Year | Weather Year Probability | LDF Errors | LDF Probability | Case Probability |
|--------------|--------------------------|------------|-----------------|------------------|
| 2007 | 2.9% | -4.8% | 2.2% | 0.1% |
| 2007 | 2.9% | -3.0% | 9.2% | 0.3% |
| 2007 | 2.9% | -1.5% | 22.9% | 0.7% |
| 2007 | 2.9% | 0.0% | 31.5% | 0.9% |
| 2007 | 2.9% | 1.5% | 22.9% | 0.7% |
| 2007 | 2.9% | 3.0% | 9.2% | 0.3% |
| 2007 | 2.9% | 4.8% | 2.2% | 0.1% |
| 2008 | 2.9% | -4.8% | 2.2% | 0.1% |
| 2008 | 2.9% | -3.0% | 9.2% | 0.3% |
| 2008 | 2.9% | -1.5% | 22.9% | 0.7% |
| 2008 | 2.9% | 0.0% | 31.5% | 0.9% |
| 2008 | 2.9% | 1.5% | 22.9% | 0.7% |
| 2008 | 2.9% | 3.0% | 9.2% | 0.3% |
| 2008 | 2.9% | 4.8% | 2.2% | 0.1% |
| 2009 | 2.9% | -4.8% | 2.2% | 0.1% |
| 2009 | 2.9% | -3.0% | 9.2% | 0.3% |
| 2009 | 2.9% | -1.5% | 22.9% | 0.7% |
| 2009 | 2.9% | 0.0% | 31.5% | 0.9% |
| 2009 | 2.9% | 1.5% | 22.9% | 0.7% |
| 2009 | 2.9% | 3.0% | 9.2% | 0.3% |
| 2009 | 2.9% | 4.8% | 2.2% | 0.1% |

For this study, total reliability costs are defined as the following:

a. Reliability Energy Costs

- i. Cost Unserved Energy Events – The value of lost load to customers.
- ii. Cost of Expensive Purchased Power – defined as the costs of any purchases at prices higher than the generic CT costs
- iii. Cost of Dispatching Expensive Peaking Resources – defined as any costs of the system’s physical generation above the dispatch cost of the new capacity resource. This includes the dispatch of higher-cost generators such as oil-fired turbines and old natural gas turbine units.

b. Cost of Carrying Reserves – The carrying cost of adding additional capacity in \$/kW-yr.

These components are calculated for each of the above cases weighted based on probability.

B. Reserve Margin Definition

For this study, reserve margin is defined as the following:

- $(\text{Resources} - \text{Demand}) / \text{Demand} * 100\%$
 - Resources including Interruptible Capacity
 - Demand is the August Peak Load including Interruptible Load. August Peak Load was chosen because that is the month in which reserves are the lowest since capacity for most thermal resources is much higher in winter months compared to summer months.

V. Base Case Results and Risk Analysis

Figure 7 shows the resulting distribution of reliability energy costs across varying reserve margins. The components include the cost EUE, cost of reliability purchases, and production costs above a CT. As reserve capacity is added, these reliability energy costs are reduced. As seen, more than 70% of the time, the utility is going to pay more in capacity costs than for reliability energy because the reliability energy is concentrated in a few extreme cases when the combination of severe generator outages, weather, and load forecast error, and low import capability occur. It is the risk on the tail end of the distribution that forces a utility to carry reserves. Some years these costs may be close to zero while other years those costs may be orders of magnitude higher than the incremental cost of carrying additional reserves. Assuming a 12% reserve margin level, reliability energy costs can range from 200 thousand dollars to 900 million dollars for a single year.

Figure 7. Distribution of Reliability Energy Costs





Figure 8 shows the cost of carrying reserves at varying reserve margin levels. As reserve margin increases, the cost of carrying reserves increases. The cost of carrying reserves is fixed for all scenarios because capacity can be constructed or purchased through a bilateral contract which will effectively lock that cost for many years.

Figure 8. Fixed Cost of Carrying Reserves



The optimal reserve margin is where the sum of the cost of reliability energy costs (Distributions from Figure 7) and the cost of carrying reserves (Distributions from Figure 8) is minimized. However, since reliability costs are extraordinarily volatile but capacity costs are fixed, a conversion is necessary to put the two on the same basis. Otherwise, the comparison would inappropriately consider two very different cost structures. The casualty insurance industry faces a similar issue of how to compare fixed premiums with volatile casualty payouts. The typical solution is to remove the risk from the casualty distributions by selecting the 85th to 95th percent costly long-term scenario for comparing to fixed premiums. In other words, premiums are frequently set using anywhere between 85 to 95 percent confidence levels that the insurance company will be covered in the long-term. Therefore, in this example, if an insurance company were assuming the risks shown in Figure 7, then an approximate premium would equal the 85th -

95th confidence level of the distribution. Astrape Consulting recommends a similar risk adjustment using reliability energy costs at the 85th to 90th confidence level range based on its experience in performing reserve margin studies for other jurisdictions within the southeast because these levels have resulted in the lowest cost resource plans that also avoid unreasonable risk for utilities, regulators, and customers. Figure 9 summarizes total reliability costs assuming reliability energy costs at the 85th percentile. As reserve margin increases, reliability energy costs decrease and the cost of carrying reserves increase. With this assumption, total reliability costs are minimized at a reserve margin of 15.50%.

Figure 9. Optimal Reserve Margin with Reliability Energy Costs at 85th Percentile Confidence Level





Figure 10 supplies a breakdown of the optimal reserve margin into three components: Unit Performance, Weather Impact on Load, and Load Forecast Error Due to Economic Growth. The


largest component is unit performance which is not surprising given the fact that 1,000 MW of capacity are on outage 20% of the time as shown in Figure 2 of the Input Section.

Figure 10. Reserve Margin Components at 85th Percentile Confidence Interval



Next, total reliability costs were calculated assuming reliability energy costs at various confidence levels to understand how the least cost reserve margin is impacted by this assumption. Figure 11 displays these results. The study was performed at the weighted average (76th percentile), 80th, 85th, 90th, 95th, and 99th confidence levels.

Figure 10. Optimal Reserve Margin at Varying Confidence Intervals



| | Weighted Average (76th Percentile) | 85% Confidence Level | 90% Confidence Level | 95% Confidence Level | 99% Confidence Level |
|-------------------------------|------------------------------------|----------------------|----------------------|----------------------|----------------------|
| Optimal Reserve Margin | 14.00% | 15.50% | 17.25% | 18.25% | 22.25% |

The recommended range of reserve margin assuming the 85th and 90th confidence levels of reliability energy costs is between 15.50% and 17.25%. The weighted average case assumes the reliability energy costs are weighted based on the probability of each scenario which happens to fall out at the 76th percentile point on the distribution. However, it is Astrape Consulting’s experience that assuming this as a planning reserve margin provides more risk than utilities and regulators are willing to take in a given year even though it may minimize average costs in the long run. Based on Figure 7, a 14.00% reserve margin results in a risk that in 5% of all scenarios reliability energy costs would exceed 90 million dollars and 1% of the time they would exceed

\$200 million dollars. A 15.50% reserve margin lowers this exposure to 60 million dollars and 140 million dollars respectively. Also, even if the weighted average case is assumed, the increase in total reliability costs between the 14.00% reserve margin and the 15.50% reserve margin is only 1.2 million dollars. In contrast, the 99 percentile confidence level reserve margin of 22.25% eliminates almost all risk but puts an unreasonable amount of cost on customers as shown in Figure 10.

VI. Sensitivity Analysis

In addition to the base case analysis, several sensitivities were performed to test the major assumptions in the base case. These sensitivities included varying the cost of unserved energy, varying the cost of carrying additional capacity reserves, removing all tie assistance, increasing unit forced outage rates, decreasing neighbor capacity, decreasing transmission limits, and increasing market prices during scarce conditions.

Table 15. Sensitivities – Cost of EUE and Carrying Cost of Reserves

| | Weighted Average | 85% Confidence Level | 90% Confidence Level | 95% Confidence Level |
|--|------------------|----------------------|----------------------|----------------------|
| EUE = \$5,000/MWh | 13.75% | 15.50% | 17.00% | 18.00% |
| Base Case Optimal Reserve Margin (EUE = \$16,600/MWh) | 14.00% | 15.50% | 17.25% | 18.25% |
| EUE = \$30,000/MWh | 14.25% | 16.00% | 17.75% | 18.75% |
| Cost of Capacity - \$110/kW-yr | 13.25% | 15.25% | 16.50% | 18.00% |
| Base Case Optimal Reserve Margin (Cost of Capacity = \$88.42/kW-yr) | 14.00% | 15.50% | 17.25% | 18.25% |
| Cost of Capacity - \$70/kW-yr | 14.75% | 17.25% | 18.50% | 20.75% |

As the cost of reserves decreases, it is more economic for the system to carry additional capacity and vice versa if the cost of capacity increases. As shown in the results, the 85th percentile confidence level reserve margin ranges from 15.25% to 17.25% by varying the cost of capacity

from \$110/kW-yr to \$70/kW- yr. Because the risk exposure to reliability energy is exponential and not linear across reserve margins, there is a lesser effect of raising the cost of reserves than there is when lowering the cost of capacity as shown in the results.

As the cost of unserved energy decreases, it is more economic for the system to carry less capacity reserves. Due to the fact that the majority of reliability energy costs come from events in which reliability purchases occurred, the value for the cost of EUE is not a major driver in the analysis. For this sensitivity, the cost of EUE was varied from as much as \$5000/MWh to \$30,000/MWh and the 85th percentile confidence level reserve margin ranges from 15.50% to 16.00%.

Table 16 shows the results of the remaining sensitivities that were performed individually off of the Base Case.

Table 16. Other Sensitivities

| | Weighted Average (76th Percentile) | 85% Confidence Level | 90% Confidence Level | 95% Confidence Level |
|---|------------------------------------|----------------------|----------------------|----------------------|
| Optimal Reserve Margin | 14.00% | 15.50% | 17.25% | 18.25% |
| Scarcity Pricing Sensitivity - Increase by 50% | 15.25% | 17.50% | 19.00% | 20.25% |
| EFOR Sensitivity - Increase by 50% | 17.00% | 19.00% | 21.25% | 22.75% |
| Neighbor Reserve Margin Sensitivity - 15% RM to 12% RM | 16.00% | 18.00% | 20.25% | 22.00% |
| Transmission Sensitivity - Decrease by 50% | 15.00% | 16.75% | 18.25% | 19.50% |
| Island Sensitivity - No Interconnection Ties | 21.75% | 23.75% | 24.75% | 26.00% |

The effect of increasing the scarcity pricing by 50% increased the 85th percentile confidence level reserve margin by 2.00% to 17.50%. However, increasing the unit forced outage rates (FOR) by 50% had a much larger impact of 3.50% resulting in a 19.00% reserve margin. This is logical as increasing the FOR is effectively removing available capacity resulting in not only higher market prices but also more reliability energy. Increasing the scarcity pricing is only

increasing the cost of the reliability energy for a specific, but does not affect the energy available.

Market conditions were varied by assuming less reserve margins from existing neighbors (15% reserve margin to 12% reserve margin) and a 50% reduction in transmission import capability. The 85th percentile confidence level reserve margin shifts from 15.50 % to 18.00% for the reserve margin sensitivity and to 16.75% for the transmission reduction sensitivity.

Finally, the 85th percentile confidence level reserve margin point rises to 23.75% if the company is assumed to be an island without any emergency assistance from its neighbors. In this scenario, all reliability purchases are shifted to unserved energy which causes reliability costs to increase substantially. This sensitivity shows the importance that interconnected regions have on the Companies' reliability.

These sensitivities illustrate the potential change in reserve margin due to significant assumptions. Excluding the island sensitivity, the reserve margins only shift by a few percentage points even with significant changes in major inputs.

VII. Conclusions/Recommendations

In conclusion, the simulation results demonstrate the Companies' risk due to lower planning reserve margins and show that low probability, high impact cost exposures exist at all reserve margin levels. No system is 100% reliable and this reliability assessment has quantified the frequency and duration of major events and their economic impact on customers under a full distribution of weather years, unit performance, and load forecast uncertainty. The study also demonstrates the value of capacity reserve margins to the extent they protect customers from


extreme, high cost outcomes. Based on the simulations and sensitivities, the precedent set by other industries, and experience in other jurisdictions, Astrape Consulting recommends that the Companies set a long-term target reserve margin using the 85th to 90th percentile of reliability energy costs which results in reserve margins between 15% and 17%.

Appendix

Physical Reliability Metrics

Loss of Load Expectation (LOLE) is a common physical reliability metric used when looking at resource adequacy studies. An LOLE of 0.1 events per year or “1 day in 10 years” is a criterion that is used in many jurisdictions. Below is a figure showing the LOLE curve for the base case of this study. The 1 day in 10 year metric occurs at a 20% reserve margin level. For customers to achieve this level of reliability, costs would need to increase substantially which would lead to an inefficient level of reserves. LOLE metrics, especially for relatively smaller systems (less than 10,000 MW) do not always translate to the most economic reserve margin as shown below. Based on the recommended reserve margin of 15% - 17%, it is expected that there would be on average approximately 2 events every 10 years.

Figure A.1 Loss of Load Expectation as a Function of Reserve Margin



Kentucky Utilities Company

and

Louisville Gas and Electric Company

2011 Optimal Expansion Plan Analysis

Generation Planning and Analysis

April 2011

Table of Contents

| | |
|--|-----------|
| EXECUTIVE SUMMARY | 1 |
| Introduction..... | 2 |
| Overview of the Strategist® Computer Model..... | 2 |
| Supporting Studies..... | 4 |
| Minimum Reserve Margin Target Criterion..... | 4 |
| Supply-Side Technology Screening Analysis..... | 4 |
| Demand-Side Technologies | 6 |
| Base Case Development..... | 6 |
| Sensitivity Analyses..... | 11 |
| Sensitivity: Load | 11 |
| Sensitivity: Environmental Regulations | 13 |
| Break Even Analysis: Gas Prices | 14 |
| Break Even Analysis: Coal Unit Capital Cost..... | 15 |
| Summary and Recommendations..... | 15 |
| Appendix A System Data..... | 17 |

EXECUTIVE SUMMARY

Kentucky Utilities Company and Louisville Gas and Electric Company (collectively, “the Companies”) continually evaluate their resource needs. The purpose of this study is to update this ongoing analysis. The base case strategy is determined based on a minimum expected present value of revenue requirements criterion and subject to certain constraints, including unit operating characteristics and maintaining a target reserve margin of 16%.

As precursors to the optimization process, two independent analyses were conducted, one for screening supply-side alternatives and the other for selecting demand-side management programs. The purpose of the supply-side screening analysis was to evaluate, compare and suggest the least-cost supply-side options to use in Strategist® optimizations. An independent evaluation was conducted on numerous demand-side management options and ultimately recommended new DSM programs and enhancements to existing programs. This evaluation compared the merits and costs of each program to the avoided cost of building new generation units and resulted in the recommendation of the least-cost options. These programs have been included in the base load forecast that was then used in determining the technology choice and the construction timing of new generation units.

Base case results demonstrate that the plan to construct three 3x1 combined cycle combustion turbines beginning in 2016 provides lowest present value of revenue requirements. In order to consider uncertainty in the process, sensitivity cases were evaluated to demonstrate the effects on the optimal plan of variation in the load forecast and in environmental regulations, and the breakeven points for natural gas prices and coal unit capital costs.

Introduction

The purpose of this study is to produce a multiple year IRP for the companies. The IRP is determined based on a minimum expected PVRR criterion over a 30-year planning horizon and subject to certain constraints, including a target reserve margin of 16% and unit operating characteristics. This plan provides an indicative expansion plan, considering current business planning assumptions. Detailed construction plans would be submitted to the KPSC for approval with a Certificate of Public Convenience and Necessity (“CCN”) before the actual implementation of any part of this plan would begin.

This report provides an overview of the Strategist® computer model used in the analysis as well as discussions of the analyses regarding target reserve margin and supply-side screening. Based upon these supporting analyses, initial lists of technologies of various types and capacities were suggested for further analysis within the optimization module of Strategist®. Sensitivities regarding the load forecast and environmental regulations, along with break even analyses on natural gas prices and coal unit construction costs, were evaluated with computer optimizations and the least cost plan is presented for consideration.

Overview of the Strategist® Computer Model

The Load Forecast Adjustment (“LFA”), Generation and Fuel (“GAF”), Proview (“PRV”), and Capital Expenditure and Recovery (“CER”) modules of the Strategist® computer model were used in the study. The Strategist® computer software program can be used to either optimize a set of resource alternatives (determine a least-cost strategy under a prescribed set of constraints and

assumptions) or evaluate a single pre-specified plan. Input parameters to the Strategist® model are described in Appendix A of this document.

The LFA module allows the user to create typical monthly load shapes for each company modeled to be transferred to the GAF module for production costing purposes. Inputs to the LFA are the Companies' peak and energy load forecasts for multiple years and a load shape. The demand and energy forecasts are modeled to include the peak and energy reductions associated with interruptible or curtailable customers and DSM programs.

The GAF module is used to simulate power system dispatch and operation using a load duration curve production costing technique. Production costs including fuel, incremental operation and maintenance ("O&M"), purchase power and emission costs are calculated in this module. Inputs to the GAF include generating unit and purchase power characteristics, fuel costs and unit or fuel specific emissions information.

The PRV optimization module is used to evaluate all combinations of potential options to produce a list of resource plans, subject to user specified constraints, that satisfy the Companies' minimum target reserve margin criterion. PRV combines production cost analysis with an analysis of new construction expenditures to suggest an optimal resource plan and sub-optimal resource plans based on minimizing utility cost. PRV receives revenue requirements information associated with capital expenditures from the CER. Inputs to PRV include generic generating unit characteristics from the GAF, and construction/implementation parameters such as each option's first year available.

The CER module calculates revenue requirements associated with capital expenditures for both the construction and in-service periods. PRV receives project-specific revenue requirement

profiles for possible in-service dates from the CER for use in optimizations. The revenue requirement profiles are combined with the GAF production cost analysis to produce a total system revenue requirement for the study period. The CER contains capital information on resource projects associated with the optimal Integrated Resource Plan. Inputs to the CER include construction cost profiles, depreciation schedules and various economic assumptions.

Supporting Studies

Several supporting studies are utilized in this evaluation. These studies include the target minimum reserve margin, the supply-side technologies and the DSM programs used in this evaluation.

Minimum Reserve Margin Target Criterion

In April 2011, a study was completed to determine an optimal reserve margin criterion to be used by the Companies. This study recommended that a target reserve margin range of 15% to 17% be used in long range planning studies. Accordingly, in the evaluation and development of this optimal Integrated Resource Plan, the Companies have used a reserve margin target of 16%. The reserve margin study titled *LG&E and KU 2011 Reserve Margin Study* (April 2011) can be found in Volume III, Technical Appendix.

Supply-Side Technology Screening Analysis

As a precursor to the optimization process, a technology screening analysis was conducted. The purpose of the screening analysis was to evaluate, compare and suggest the least-cost supply-

side options to use in Strategist® optimizations. The number of supply-side options available necessitates that a screening analysis be conducted since modeling of all options in Strategist® is unfeasible. The supply-side screening report titled *Analysis of Supply-Side Technology Alternatives* (March 2011), can be found in Volume III, Technical Appendix. The supply-side technologies suggested by the screening evaluation for detailed analysis within the Strategist® model are shown in Table 1.

Table 1
Supply-Side Technologies Suggested for Analysis with Strategist®

Supercritical Pulverized Coal – Large
3x1 Combined Cycle Combustion Turbine
2x1 Combined Cycle Combustion Turbine
1x1 Combined Cycle Combustion Turbine
Wind Energy Conversion
Simple Cycle Combustion Turbine
Landfill Gas Internal Combustion Engine
Ohio Falls Hydro Expansion at Shippingport Island

The options listed in Table 1 include the options that passed the screening analysis and represent the complete list of supply-side alternatives available to Strategist®. A new run-of-river hydroelectric unit as an expansion of the existing Ohio Falls hydro facility to Shippingport Island was also included in Strategist® as a potential expansion option. Although it did not pass the supply-side screening analysis, it was included for further study as another alternative to fossil fuel based options. The Companies will continue to pursue possible opportunities through a request for proposals process and through participation in the wholesale marketplace on a real time basis when evaluating future resources. Purchase opportunities are compared to construction alternatives in the CCN process to arrive at an optimal strategy. Peaking type purchase power opportunities in optimizations would serve only to evaluate the delay of new capacity construction for short periods

of time, which is already under consideration by the Companies in greater detail in the CCN process.

Regardless of the method or the arena in which the evaluation is conducted, the Companies will continue to evaluate the benefits of purchase power, both short- and long-term, through participation in the wholesale marketplace on a real time basis as a method to delay generation construction.

Demand-Side Technologies

In addition to the supply-side screening analysis discussed above and as a precursor to developing the optimal supply-side expansion plan, a separate evaluation of demand-side options was performed, as discussed in detail in Sections 8.(3)(e) and 8.(5)(c) in Volume I. The relative costs and impacts of various demand-side options were compared to building new generation capacity. The DSM programs that were shown to be least cost have been included in the base load forecast and have therefore not been included explicitly in the supply-side optimization process. The existing DSM programs are assumed to continue into the future and the new DSM programs are collectively expected to reduce the Companies' coincident system peak by approximately 500 MW by the end of 2017. The uncertainty regarding the level of demand reduction achieved by the DSM programs is considered to be included within the range of uncertainty in load which is discussed in this report in the section titled *Sensitivity: Load*.

Base Case Development

Using the supply-side options identified in Table 1 along with the base assumptions for the fuel forecast, new unit capital costs, and demand and energy forecasts, an initial expansion plan was developed. Appendix A of this report details the existing units' operating characteristics as well as

documents the load forecasts (base, high and low) and fuel prices used in this evaluation. Table 2 below details relevant information pertaining to each of the supply-side options evaluated. The cost and performance data for all units except Ohio Falls Station are based on data from the EPRI TAG database, the Cummins and Barnard supply-side report (December 2007), or more project-specific data developed by the Companies' Project Engineering department in conjunction with engineering contractors. Cost and performance data for the Ohio Falls Station option are based on data from of a feasibility study supplied to the Companies in December 2008 by MWH Global, Inc. This study compared five alternatives and recommended a large unit on Shippingport Island that has been included in the expansion plan options. No purchase power alternatives are evaluated in this analysis but will be evaluated within the required CCN application process. For a more complete description of the origins of the data associated with each of the supply-side options see the *Analysis of Supply-Side Technology Alternatives* (March 2011) in Volume III, Technical Appendix.

Table 2
Supply-Side Alternatives Data
 All costs are in 2010 \$

| Unit Type | Reference Name ² | Net Capacity ³ | | Overnight Installed Cost ⁴ (\$/kW) | Total Non-Fuel Variable O&M Non-Ozone Season ⁵ (\$/MWh) | Total Fixed O&M ⁶ (\$M/yr) | Full Load HHV Heat Rate (MMBtu/MWh) | Unavailability ⁷ (%) |
|------------------------------|-----------------------------|---------------------------|-------------|---|--|---------------------------------------|-------------------------------------|---------------------------------|
| | | Summer (MW) | Winter (MW) | | | | | |
| Simple Cycle CT | SCCT | 194 | 228 | | 15.12 | 3.1 | 9.85 | 4.55% |
| 1x1 Combined Cycle CT | 1x1C | 388 | 435 | | 4.23 | 8.0 | 6.72 | 5.90% |
| 2x1 Combined Cycle CT | 2x1C | 605 | 673 | | 3.99 | 11.9 | 6.77 | 5.90% |
| 3x1 Combined Cycle CT | 3x1C | 907 | 1,009 | | 3.96 | 18.3 | 6.75 | 5.90% |
| Supercritical Coal - Large | LGSC | 789 | 811 | | 3.70 | 36.8 | 9.04 | 7.40% |
| Wind Turbine | Wind | 200 | 200 | | 7.37 | 2.2 | N/A | 69.0% ⁸ |
| Landfill Gas IC Engine | LFG | 5 | 5 | | 15.80 | 0.3 | 9.50 | 2.50% |
| Ohio Falls Unit ¹ | Falls | 50 | 50 | | 0.00 | 0.7 | N/A | 60.70% |

Notes to Table 2:

- ¹ Expansion of the Ohio Falls facility to Shippingport Island is a 50 MW run-of-river unit.
- Winter and summer capacities are expected to average 16 and 20 MW, respectively, with an annual average capacity factor of 39.3%.
- ² Reference names are used to more easily compare sensitivity plans.
- ³ For coal units and combustion turbines, summer ratings are used for June - August and winter ratings are used for December - February.
- ⁴ Installed cost is based on net summer capacity.
- ⁵ Variable O&M includes start fuel costs.
- ⁶ Fixed O&M for CTs and combined cycle options include costs associated with reserving firm gas-line capacity.
- ⁷ Unavailability is the long-term steady-state outage rate expected after initial operation for coal, combustion turbine, and landfill gas units. For wind and Ohio Falls units, unavailability reflects the expected capacity factor (unavailability = 1 - capacity factor).
- ⁸ Wind turbine capacity factor modeled at 31% with 15% of the capacity counting toward reserve margin.

As previously noted, the base assumptions for this IRP include the retirement of the six coal units at the Cane Run, Green River, and Tyrone Stations in 2016 due to the anticipated enactment of more stringent environmental regulations that are discussed in detail in Section 8.(5)(f) of Volume I. The retirement assumptions were based on an analysis that demonstrates that the PVRR of retiring these units and replacing the capacity is lower than the PVRR of keeping them in operation with the appropriate emissions controls. These PVRR calculations included revenue requirements for:

- the capital cost of constructing emissions control equipment to meet the proposed environmental regulations,
- the capital cost of constructing generation capacity to replace retired units to maintain the target reserve margin,
- and the operating costs of both existing and new generation units net of the savings from retired units.

This analysis was conducted by first comparing the PVRR of a plan that included no retirements and the required environmental controls to a plan that included only the retirement of the unit with the highest operating costs. Plans with the retirements of additional units were added incrementally in order of decreasing operating costs. Each incremental plan demonstrated whether the retirement of the specified units resulted in lower PVRR. The result of this analysis is that the least cost plan to maintain the target reserve margin as well as meet the proposed environmental regulations includes

- retiring the coal units at the Cane Run, Green River, and Tyrone Stations,
- replacing this retired capacity in 2016 and installing additional capacity in later years to maintain the target reserve margin,

- and installing the necessary emissions controls on existing units to meet the proposed environmental regulations.

For reference, this least cost base plan will be referred to as Plan “A” and it represents the 30-year expansion strategy that minimizes the present value of revenue requirements criterion under the base assumptions. As seen in Table 3, optimization results using the base assumptions indicate that the optimal plan is the installation of three 3x1 combined cycle units: one in 2016, one in 2018, and one in 2025.

Table 3
Base Expansion Plan

| Plan: | <u>"A"</u> |
|--------------|-------------------|
| 2011 | |
| 2012 | |
| 2013 | |
| 2014 | |
| 2015 | |
| 2016 | 3x1C |
| 2017 | |
| 2018 | 3x1C |
| 2019 | |
| 2020 | |
| 2021 | |
| 2022 | |
| 2023 | |
| 2024 | |
| 2025 | 3x1C |

With this plan, there is a 40 MW reserve margin shortfall in 2015 when the summer reserve margin was allowed to drop to approximately 15.4%, as shown in Table 8.(4)(a)-1 in Section 8 of Volume I. In 2015 and in other years with relatively small reserve margin deficits immediately

preceding the planned completion of a new generation unit, the possibility of meeting the projected deficit with a power purchase would be evaluated.

Sensitivity Analyses

The supply-side alternatives identified in Table 2 were also evaluated in several other sensitivity cases. Sensitivities were performed regarding uncertainty in the load forecast, coal unit retirements, and proposed environmental regulations. Additionally, break even analyses were performed on gas prices and coal unit capital cost to determine the points at which the PVRR would be similar to the base case for an expansion plan with a coal unit installed in 2018 instead of a gas-fired combined cycle unit.

Sensitivity: Load

The load forecast is a significant factor influencing the Companies' expansion plan. Each supply-side technology is designed for optimal unit performance at various levels of utilization. For example, simple cycle combustion turbines ("CT") are relatively inexpensive to construct; however, compared to coal-fired units, CTs are more costly to operate and maintain given the relative prices of gas and coal. Conversely, coal-fired units are expensive to construct but are relatively inexpensive to operate and maintain. The economics of adding a supply-side option to any generation system is based on the unit's expected fuel and O&M costs over the full range of loads it is expected to serve. Significant economic penalties may be incurred if the unit is operated above or below the level that it was planned to serve. For example, if a CT was added to a system in which load was greater than forecasted, the utilization of the CT may exceed the economical range for which it was planned. In

other words, it may have been more economical to install intermediate load serving capacity (such as combined cycle combustion turbines) or baseload capacity (coal or hydro) instead. Thus, load growth scenarios that are different from that which is currently forecasted may have a significant impact on the selection of an optimal technology type. Therefore, in order to evaluate the effect of various load forecasts, a load sensitivity analysis was incorporated into the process of determining an optimal resource plan.

In summary, the load sensitivity analysis consists of evaluating the effect of three load forecasts on the selection of resource alternatives. The three forecasts depict (1) the expected system load growth case, (2) a case where system load growth exceeds expected growth, and (3) a case in which system load growth is less than expected. For reference, the resulting forecasts are termed the base, high and low load forecasts. The details of and the basis for the various load forecasts are described in Volume II, Technical Appendices I-III. A tabulated summary of these respective forecasts can be found in Appendix A of this document.

Table 4 shows the optimal expansion plans when optimization runs are made on the low load (Plan "B") and high load (Plan "C") forecasts. For comparison, the optimization of the base load forecast (Plan "A") is also shown.

**Table 4
Load Sensitivity**

| Load Forecast: | Base | Low | High |
|----------------|------|------|-------------|
| Plan: | "A" | "B" | "C" |
| 2011 | | | |
| 2012 | | | |
| 2013 | | | |
| 2014 | | | |
| 2015 | | | |
| 2016 | 3x1C | 3x1C | 3x1C + 2x1C |
| 2017 | | | |
| 2018 | 3x1C | | |
| 2019 | | | |
| 2020 | | 2x1C | 3x1C |
| 2021 | | | |
| 2022 | | | |
| 2023 | | | |
| 2024 | | | |
| 2025 | 3x1C | 3x1C | |

As with the base optimization, sensitivity optimizations regarding the Companies' forecasted load continue to show that at least one combined cycle unit is installed in 2016. The first year available for all units is 2016. Allowing for an earlier install would result in the selection of units earlier than 2016 for the high load scenario.

Sensitivity: Environmental Regulations

Several of the environmental regulations discussed in Section 8.(5)(f) of Volume I are not final so there is a possibility that some regulations could change or be delayed. As a sensitivity to the base assumptions regarding proposed environmental regulations, it was assumed that no unit retirements would be required due to new regulations. Table 5 shows that without the unit

retirements associated with the proposed EPA regulations, the optimal expansion plan, Plan “D”, is to delay the next new unit to 2018 and to build only two 3x1 combined cycle units in the fifteen year planning period.

Table 5
Environmental Regulations Sensitivity

| Plan: | Base "A" | No Unit Retirements "D" |
|--------------|-------------|-------------------------------|
| 2011 | | |
| 2012 | | |
| 2013 | | |
| 2014 | | |
| 2015 | | |
| 2016 | 3x1C | |
| 2017 | | |
| 2018 | 3x1C | 3x1C |
| 2019 | | |
| 2020 | | |
| 2021 | | |
| 2022 | | |
| 2023 | | |
| 2024 | | 3x1C |
| 2025 | 3x1C | |

Break Even Analysis: Gas Prices

The relative prices of natural gas and coal may have a significant impact on the selection of an optimal technology type. Therefore, in order to evaluate the effect of natural gas and coal prices, a fuel sensitivity analysis was incorporated into the Companies’ process of determining an optimal Integrated Resource Plan. The natural gas prices were adjusted while holding the coal prices constant. This allows for a relatively simple method for evaluating the impact of the “gap,” or

difference in cost between that of coal and natural gas. All other inputs were held constant for this analysis including the assumption that the first unit to be built in 2016 is a gas-fired combined cycle unit since it is not feasible to construct a coal unit by then. Results indicate that natural gas prices would need to increase throughout the planning period by approximately 30% over those shown in Appendix A, Table 3 before a coal unit becomes economical over a natural gas unit in 2018 as the second unit to be built in the planning period.

Break Even Analysis: Coal Unit Capital Cost

Capital costs for generating units have increased dramatically in recent history. Baseload units generally have substantially higher \$/kW capital requirements than peaking, but benefit from lower fuel costs during its lifetime of operation. Capital intense generating units will be impacted more by the recent cost increases since there is more cost to make up via lower fuel costs. This analysis simply adjusts coal capital costs while holding all other inputs constant in order to determine the point at which a coal unit becomes preferred over gas as the second unit to be built in the planning period. Results indicate that coal capital costs would need to decrease by approximately 30% before being selected as the 2018 technology choice.

Summary and Recommendations

The results of the optimization performed with the base inputs identified Plan “A” as the least-cost expansion plan for meeting the Companies’ load requirements. The plan calls for 3x1 combined cycle units to be constructed in 2016 and 2018, and 2025. This plan is supported by sensitivities regarding assumptions related to the load forecast and environmental regulations and

breakeven analyses regarding natural gas prices and coal unit construction costs. In all of the sensitivities, the optimal expansion plan called for the construction of a 3x1 combined cycle unit in 2016 or 2017 plus at least one additional combined cycle unit before 2025.

Considering all options reviewed, this study recommends that the base generation expansion strategy of the Companies be that shown in Plan “A”. The Companies will continue to develop the least cost strategy to meet future load requirements by analyzing the economics of various configurations of combined cycle units, monitoring the development of environmental regulations, evaluating the potential for retiring existing units, and reviewing purchased power as an option to delay generation construction.

Appendix A

System Data

The Strategist[®] computer program is used to simulate the Companies' generating system. The model simulates the dispatch of the Companies' generating units and purchases to serve load while simultaneously maintaining reserve margin requirements. The following sections detail the information used to model Companies' generating systems.

General Data Items

- Base year: 2010
- Study period: 2011 to 2025
- The present value of revenue requirements is calculated by discounting nominal annual revenue requirements for 2011 through 2040 to the base year using a constant discount rate.
- Financial parameters:
 - Discount rate: 6.71%
 - Capital costs escalation rate: 2.5%
 - O&M costs escalation rate: 2%
 - Combined federal and state income tax rate: 38.9%
- Unserved energy cost is \$14,970 per MWh (2010 dollars) based on a study provided by Astrape as discussed in the reserve margin study titled *LG&E and KU 2011 Reserve Margin Study* (April 2011).

- Load Forecast: The base load forecast and the high and low sensitivities are based on the LG&E and KU Energy and Demand Forecast data for 2011-2040 contained in Section 7 of Volume I. The load forecasts include the effects of DSM programs. See Appendix A, Table 1.
- Unit Retirements: The base assumption reflects the retirements in 2016 of Cane Run 4, 5, and 6, Green River 3 and 4, and Tyrone 3 that are anticipated as a result of proposed environmental regulations. The operating life of all other existing units is assumed to be beyond the end of the study period.

KU/LG&E Unit Data:

- Capacity: See Appendix A, Table 2.
- Equivalent Forced Outage Rate (“EFOR”): See Appendix A, Table 2. The unit forced outage rates (“FORs”) were developed based on benchmark averages for the top quartile. FORs have been increased by inclusion of maintenance outage hours to better reflect actual unit availability. The modeled EFOR is the sum of FOR and the maintenance outage rate.
- Heat Rate: See Appendix A, Table 2.
- Fuel Costs: The fuel price forecast was developed in 2010 and is shown in Appendix A, Table 3.
- Maintenance inputs were determined by reviewing the Companies’ projected maintenance as of January 2011. Planned outages are scheduled to optimize reserves and reliability over all months of each year.

- Purchases: OVEC provided a projection of available capacity for 2010-2014 which incorporates seasonal ratings, capacity derates, planned maintenance, and forced outage rates. The monthly capacity levels for 2014 were assumed to continue indefinitely. In addition, OVEC provided a forecast of expected demand charges (including capital improvements, debt costs, operating, and administrative costs) and energy charges (including fuel, emissions allowances, emission control reagents, and coal handling). See Appendix A, Table 4 for annual details.

**Table 1 - 2011 Expansion Plan Appendix A
Combined Company Load Forecasts: Peak (MW) /Annual Energy (GWh)**

| Year | Base Forecast | | High Forecast | | Low Forecast | |
|------|---------------|--------------|---------------|--------------|--------------|--------------|
| | Peak (MW) | Energy (GWh) | Peak (MW) | Energy (GWh) | Peak (MW) | Energy (GWh) |
| 2011 | 6,757 | 35,782 | 7,011 | 37,092 | 6,503 | 34,471 |
| 2012 | 6,821 | 36,251 | 7,084 | 37,607 | 6,559 | 34,894 |
| 2013 | 6,915 | 36,720 | 7,180 | 38,101 | 6,650 | 35,339 |
| 2014 | 6,976 | 37,036 | 7,246 | 38,441 | 6,706 | 35,632 |
| 2015 | 7,059 | 37,515 | 7,333 | 38,940 | 6,785 | 36,091 |
| 2016 | 7,070 | 37,963 | 7,346 | 39,413 | 6,793 | 36,513 |
| 2017 | 7,135 | 38,340 | 7,416 | 39,813 | 6,854 | 36,867 |
| 2018 | 7,234 | 38,850 | 7,519 | 40,342 | 6,949 | 37,357 |
| 2019 | 7,393 | 39,488 | 7,684 | 41,001 | 7,103 | 37,974 |
| 2020 | 7,546 | 40,140 | 7,843 | 41,679 | 7,250 | 38,602 |
| 2021 | 7,616 | 40,685 | 7,916 | 42,248 | 7,316 | 39,121 |
| 2022 | 7,704 | 41,322 | 8,006 | 42,906 | 7,401 | 39,737 |
| 2023 | 7,819 | 41,896 | 8,126 | 43,505 | 7,512 | 40,287 |
| 2024 | 8,008 | 42,624 | 8,321 | 44,254 | 7,695 | 40,993 |
| 2025 | 8,156 | 43,268 | 8,476 | 44,927 | 7,837 | 41,610 |

Forecasts reflect effects of interruptible/CSR and DSM.
Peaks are combined company summer coincident peaks.

CONFIDENTIAL INFORMATION

**Table 2 - 2011 Expansion Plan Appendix A
Louisville Gas and Electric / Kentucky Utilities Generator Data (2011)**

| Unit | Installed Year | Summer Rating (MW) | EFOR % | Avg Heat Rate at Max Load (MMBtu/MWh) |
|-----------------|----------------|--------------------|--------|---------------------------------------|
| Brown 1 | 1957 | 106 | | |
| Brown 2 | 1963 | 166 | | |
| Brown 3 | 1971 | 411 | | |
| Brown 5 | 2001 | 122 | | |
| Brown 6 | 1999 | 146 | | |
| Brown 7 | 1999 | 146 | | |
| Brown 8 | 1995 | 121 | | |
| Brown 9 | 1994 | 121 | | |
| Brown 10 | 1995 | 121 | | |
| Brown 11 | 1996 | 121 | | |
| Ghent 1 | 1974 | 493 | | |
| Ghent 2 | 1977 | 490 | | |
| Ghent 3 | 1981 | 454 | | |
| Ghent 4 | 1984 | 487 | | |
| Green River 3 | 1954 | 68 | | |
| Green River 4 | 1959 | 95 | | |
| Tyrone 3 | 1953 | 71 | | |
| Dix 1-3 | 1925 | 26 | | |
| Haefling 1-3 | 1970 | 36 | | |
| Cane Run 4 | 1962 | 155 | | |
| Cane Run 5 | 1966 | 168 | | |
| Cane Run 6 | 1969 | 240 | | |
| Mill Creek 1 | 1972 | 303 | | |
| Mill Creek 2 | 1974 | 301 | | |
| Mill Creek 3 | 1978 | 391 | | |
| Mill Creek 4 | 1982 | 477 | | |
| Trimble 1 (75%) | 1990 | 383 | | |
| Trimble 2 (75%) | 2011 | 549 | | |
| Trimble 5 | 2002 | 160 | | |
| Trimble 6 | 2002 | 160 | | |
| Trimble 7 | 2004 | 160 | | |
| Trimble 8 | 2004 | 160 | | |
| Trimble 9 | 2004 | 160 | | |
| Trimble 10 | 2004 | 160 | | |
| Cane Run 11 | 1968 | 14 | | |
| Paddys Run 11 | 1968 | 12 | | |
| Paddys Run 12 | 1968 | 23 | | |
| Paddys Run 13 | 2001 | 158 | | |
| Zorn 1 | 1969 | 14 | | |
| Ohio Falls 1-8 | 1928 | 52 | | |

CONFIDENTIAL INFORMATION

Table 3 - 2011 Expansion Plan Appendix A
Louisville Gas and Electric/ Kentucky Utilities Fuel Costs (\$/MMBtu)

| Year | Brown Units 1-3 | Gr River Units 3-4 | Tyrone Unit 3 | Ghent Units 1-4 | Cane Run Units 4-6 | Mill Creek Units 1-4 | Trimble High SO2 | PRB | Oil | Gas * | Haeffling Units 1-3 Gas* |
|------|--------------------|-----------------------|------------------|--------------------|-----------------------|-------------------------|---------------------|-----|-----|-------|--------------------------------|
| 2011 | | | | | | | | | | | |
| 2012 | | | | | | | | | | | |
| 2013 | | | | | | | | | | | |
| 2014 | | | | | | | | | | | |
| 2015 | | | | | | | | | | | |
| 2016 | | | | | | | | | | | |
| 2017 | | | | | | | | | | | |
| 2018 | | | | | | | | | | | |
| 2019 | | | | | | | | | | | |
| 2020 | | | | | | | | | | | |
| 2021 | | | | | | | | | | | |
| 2022 | | | | | | | | | | | |
| 2023 | | | | | | | | | | | |
| 2024 | | | | | | | | | | | |
| 2025 | | | | | | | | | | | |

* Indicates a seasonal profile applies. Price shown is annual average.

CONFIDENTIAL INFORMATION

**Table 4 - 2011 Expansion Plan Appendix A
Kentucky Utilities/Louisville Gas and Electric
OVEC Purchase (2010 \$)**

| Year | Capacity During Peak Month (MW) | Demand Cost \$ million | Energy Cost \$/MWh |
|------|---------------------------------|------------------------|--------------------|
| 2011 | 155 | | |
| 2012 | 154 | | |
| 2013 | 152 | | |
| 2014 | 152 | | |
| 2015 | 152 | | |
| 2016 | 152 | | |
| 2017 | 152 | | |
| 2018 | 152 | | |
| 2019 | 152 | | |
| 2020 | 152 | | |
| 2021 | 152 | | |
| 2022 | 152 | | |
| 2023 | 152 | | |
| 2024 | 152 | | |
| 2025 | 152 | | |

**Kentucky Utilities Company/Louisville Gas and
Electric Company
Transmission Construction Projects**

| Project No. | Description | Expected Completion Date |
|------------------------|--------------------|---|
|------------------------|--------------------|---|

CONFIDENTIAL INFORMATION REDACTED

Transmission System Map

CONFIDENTIAL INFORMATION REDACTED