

# **LG&E/KU – Ghent Station**

## **Phase II Air Quality Control Study**

### **Sparing and Capacity**

**March 23, 2010  
Revision B – Issued For Client Review**

**B&V File Number 41.0814.2**



**BLACK & VEATCH**  
Building a **world** of difference.<sup>®</sup>

---

<b>Table of Contents</b>		
1.0	Introduction.....	1-1
2.0	Methodology .....	2-1
3.0	Results.....	3-1
	Appendix A Component Data.....	A-1
	Appendix B Logic Diagrams .....	B-1

DRAFT - CLIENT REVIEW

## **1.0 Introduction**

As part of the Phase II Air Quality Control Studies (AQCS) for LG&E/KU, Black & Veatch has completed a Reliability, Availability, and Maintainability (RAM) analysis on the components of Ghent Units 1-4 AQCS upgrades and modifications in order to evaluate system availability. The availability model will reflect the expected configuration and redundancy of major equipment critical to plant operation on a per unit basis. The model will use Monte Carlo simulation to provide the expected average availability.

DRAFT - CLIENT REVIEW

## 2.0 Methodology

In its simplest terms, generating unit availability is a function of mean time between failure (MTBF) and mean time to restore (MTTR) to service for the individual system components. It is a measure of the percent of time a unit is available to produce power while taking into account both planned and forced outages. The formula relating MTBF and MTTR to availability is Availability = MTBF / (MTBF + MTTR).

An assessment of Ghent's AQCS availability requires design and configuration information, with a list of critical components, and full information about the reliability of each item, the modes and frequencies of failure, time to repair for each failure mode, and unit impact (percent load loss) upon failure of each component or group of components.

Process flow diagrams along with associated equipment lists were developed by Black & Veatch as part of the conceptual design effort. These diagrams and lists were the basis for the development of critical component data sets to be used as model inputs to a Monte Carlo model (PowerRAM) developed by Black & Veatch. Logic diagrams were constructed as functional representations of the conceptual design modifications/upgrades for Ghent Units 1-4. A summary of component data for Units 1-4 is provided in Table 2-1. Both component data sets and logic diagrams can be found in Appendix A and B, respectively.

Data used in the analysis were based on data from North American Electric Reliability Corporation (NERC) Generating Availability Data System (GADS) for similar sized solid fueled plants and supplemented with in-house Black & Veatch data sources.

TABLE 2-1  
GHENT AQC System included in the LG&E/KU RAM Analysis

UNIT 1	UNIT 2	UNIT 3	UNIT 4
PJFF	2x50%	PJFF	2x50%
Booster Fans	2x50%	Booster Fans	2x50%
PAC Injection	3x50%	SCR	2x50%
		PAC Injection	3x50%
		Sorbent Injection	3x50%

Logic diagrams constructed for each subsystem describe the functional state of the subsystem based on the status of Ghent's AQC system components. Sequences of failure and repair events are generated by application of probability distributions to input specified mean values. The model determines the status (percent of maximum capability) for each subsystem as the outcome of the simulation events. The integrated effect of the events constitutes the reliability/availability projection of the AQC system.

Within the logic diagrams of the model seven different types of gates were used to trigger equipment components:

<b>COMPONENT</b>	Represents a single component or a series of components that can be functionally represented as one block and assigned a MTBF and a MTTR.
<b>OR gate</b>	Has two possible states – failed when one or more of its inputs are failed and not failed otherwise
<b>AND gate</b>	Has two possible states - failed when all of its inputs are failed and not failed otherwise
<b>ADDAND gate</b>	Assumes the value of the sum of its inputs
<b>ADDAND-1 gate</b>	Assumes a value based on the sum of its inputs. It requires an accompanying capacity table containing gate values for all possible values of the input sum. The table is one-dimensional in the sense that one value, the input sum, determines the gate value. The table may be defined as seasonal to have different capacity values for summer and non-summer.
<b>ADDAND-2 gate</b>	Similar to the ADDAND-1 except only two inputs are allowed and a two-dimensional table is required. The table must include gate values for all possible combinations of the two inputs. The table may be defined as seasonal to have different values for summer and non-summer.
<b>AUCLOW gate</b>	Assumes a value equal to the smallest capacity value among its inputs
<b>REMOTE gate</b>	References a gate that has been defined in another subsystem

The logic gates are distinguished by the number and type of inputs and the way the value of the gate is determined. In most cases gate values reflect fraction of maximum capacity. For numerical convenience these gate values are carried as 1 minus fraction of capacity. Thus, a failed gate has the value 1, a full capacity gate has the value 0, and a gate of 30 percent capacity, the value of 0.7.

Each “block” in the logic diagram represents a single component, or a series of components that can be functionally represented as one block. These “blocks” represent physical entities (pumps, fans, etc) or functional entities (scheduled maintenance, time delays, etc.) with binary status (failed or not failed, active or inactive). A component

referred to as a “pump” represents not only the pump itself but also the motor, bearings, couplings, impeller, and shaft. Failure of any of these subcomponents is assumed to effectively eliminate the use of all of them.

DRAFT - CLIENT REVIEW

### 3.0 Results

The model is an event-oriented simulation of the operation of a system. The majority of reliability / availability data (MTBF, MTTR) used in the Ghent RAM analysis were based on EPRI AP-2071 entitled “Component Failure and Repair Data for Coal-Fired Power Units” and the North American Electric Reliability Corporation (NERC) Generating Availability Data System (GADS).

Key modeling assumptions for the Ghent RAM analysis:

- Reliability data representing the AQCS were adjusted from the typical industry average contained in the above EPRI document. The adjustments were necessary since the EPRI data recorded in AP-2071 is more than 20 years old and does not accurately reflect the forced outage rates experienced while operating new SCR system on Unit 2. Current reliability data were compiled from NERC GADS for years 2000 – 2009 to better reflect current industry average.
- Similarly reliability data for Units 1-3 were compiled from NERC GADS for years 1990 – 2000 to better reflect refurbished units already in service.

The templates below characterize the RAM model system configurations for Ghent Units 1 through 4. Both component data sets and logic diagrams can be found in Appendix A and B, respectively.

UNIT 1: AQCS Included in the Ghent RAM Analysis	
Number	System
1	Particulate Control
2	Booster Fans
3	Powder Activated Carbon Injection
25	Total Availability

<b>UNIT 2: AQCS Included in the Ghent RAM Analysis</b>	
<b>Number</b>	<b>System</b>
1	Particulate Control
2	Booster Fans
3	Selective Catalytic Reduction
4	Powder Activated Carbon Injection
5	Sorbent Injection
25	Total Availability

<b>UNITS 3 &amp; 4: AQCS Included in the Ghent RAM Analysis</b>	
<b>Number</b>	<b>System</b>
1	Particulate Control
2	Induced Draft Fans
3	Powder Activated Carbon Injection
25	Total Availability

Only new equipment identified in the conceptual design for Units 1 - 4 were considered in the RAM analysis, thus the results show the differential impact of this new equipment. The total availability listed in Table 3.1 reflects the equivalent availability (EA) for the new equipment for each of the Ghent Units as a whole and by system.

**TABLE 3.1 - Equivalent Availability**

	<b>UNIT 1</b>	<b>UNIT 2</b>	<b>UNIT 3</b>	<b>UNIT 4</b>
PJFF	99.992%	99.992%	99.992%	99.992%
Booster/ID Fans	99.946%	99.946%	99.944%	99.944%
SCR	N/A	99.932%	N/A	N/A
PAC Injection	100.000%	100.000%	100.000%	100.000%
Sorbent Injection	N/A	100.000%	N/A	N/A
Total Availability	<b>99.896%</b>	<b>99.828%</b>	<b>99.895%</b>	<b>99.895%</b>

These results provide the expected duration of time per year that each system will be available for operation taking into account forced outages, deratings, partial capacity states excluding scheduled outages. The equivalent Outage Hours (EOH), the expected average hours per year of full outage that is equivalent to forced and partial outages, can be calculated by  $(1 - EA) * 8,760$ . For example, in Unit 2 SCR, the equivalent unavailability ( $1 - EA$ ) of 0.068% multiplied by 8,760 hours per year yields the

equivalent of 5.96 hours of outage. Multiplying this EOH by unit rating and capacity factor provides an estimate of the MWH per year of lost generation for the system.

The results in Table 3-1 demonstrate high availability for all the Ghent AQCS additions proposed. Typically, balance of plant systems should each have an EA in the 99.9% or better range to ensure that these systems do not appreciably impact unit equivalent availability. Optimizing the design for reliability is a matter of comparing the differential MWH saved for a higher EA to the capital costs for higher redundancy. These systems have high EA because of relatively reliable equipment and redundancy for lower cost or potentially less reliable equipment necessitating redundant pumps for the injection systems.

DRAFT - CLIENT REVIEW

**Appendix A  
Component Data**

DRAFT - CLIENT REVIEW

## **UNIT 1**

### **LG&E/KU - Unit 1 Component Data**

<b>SYSTEM 1 PARTICULATE CONTROL</b>				
<b>Component ID</b>	<b>Description</b>	<b>MTBF</b>	<b>MTTR</b>	<b>Source</b>
X01	Pulse Jet Fabric Filter	122,640	10.0	AP-2071
X02	Pulse Jet Fabric Filter	122,640	10.0	AP-2071

### **LG&E/KU - Unit 1 Component Data**

<b>SYSTEM 2 BOOSTER FANS</b>				
<b>Component ID</b>	<b>Description</b>	<b>MTBF</b>	<b>MTTR</b>	<b>Source</b>
X01	Couplings 1	769,000	33.0	AP-2071
X02	Bearings 1	769,000	37.0	AP-2071
X03	Miscellaneous 1	769,000	34.0	AP-2071
X04	Vibrations 1	512,000	53.0	AP-2071
X05	Inlet Vanes 1	179,000	30.0	AP-2071
X06	Seal Rubs 1	769,000	21.0	AP-2071
X07	Motor 1	3,850,000	360.0	AP-2071
X08	Outlet Damper 1	1,000,000	24.0	AP-2071
X09	Couplings 2	769,000	33.0	AP-2071
X10	Bearings 2	769,000	37.0	AP-2071
X11	Miscellaneous 2	769,000	34.0	AP-2071
X12	Vibrations 2	512,000	53.0	AP-2071
X13	Inlet Vanes 2	179,000	30.0	AP-2071
X14	Seal Rubs 2	769,000	21.0	AP-2071
X15	Motor 2	3,850,000	360.0	AP-2071
X16	Outlet Damper 2	1,000,000	24.0	AP-2071
X17	Couplings 1	769,000	33.0	AP-2071
X18	Bearings 1	769,000	37.0	AP-2071
X19	Miscellaneous 1	769,000	34.0	AP-2071
X20	Vibrations 1	512,000	53.0	AP-2071
X21	Inlet Vanes 1	179,000	30.0	AP-2071
X22	Seal Rubs 1	769,000	21.0	AP-2071
X23	Motor 1	3,850,000	360.0	AP-2071
X24	Outlet Damper 1	1,000,000	24.0	AP-2071
X25	Couplings 2	769,000	33.0	AP-2071
X26	Bearings 2	769,000	37.0	AP-2071
X27	Miscellaneous 2	769,000	34.0	AP-2071
X28	Vibrations 2	512,000	53.0	AP-2071
X29	Inlet Vanes 2	179,000	30.0	AP-2071
X30	Seal Rubs 2	769,000	21.0	AP-2071
X31	Motor 2	3,850,000	360.0	AP-2071
X32	Outlet Damper 2	1,000,000	24.0	AP-2071

**LG&E/KU - Unit 1 Component Data**

SYSTEM 3 POWDER ACTIVATED CARBON INJECTION				
Component ID	Description	MTBF	MTTR	Source
X01	Feeder Hopper 1	1,095,000	2,037	NERG GADS
X02	Eductor 1	46,105	11.0	NERG GADS
X03	Blowers 1	4,380,000	360.0	NERG GADS
X04	Feeder Hopper 2	1,095,000	2,037	NERG GADS
X05	Eductor 2	46,105	11.0	NERG GADS
X06	Blowers 2	4,380,000	360.0	NERG GADS
X07	Feeder Hopper 3	1,095,000	2,037	NERG GADS
X08	Eductor 3	46,105	11.0	NERG GADS
X09	Blowers 3	4,380,000	360.0	NERG GADS
X10	Silo 1	1,095,000	2037.0	NERG GADS
X11	Silo 2	1,095,000	2037.0	NERG GADS

**LG&E/KU - Unit 1 Component Data**

SYSTEM 25 AQCS				
Component ID	Description	MTBF	MTTR	Source
X01	Air Compressor 1	4,348	82.0	B&V Internal Database / Expert Opinion
X02	Air Compressor 2	4,348	82.0	B&V Internal Database / Expert Opinion

## **UNIT 2**

### **LG&E/KU - Unit 2 Component Data**

<b>SYSTEM 1 PARTICULATE CONTROL</b>				
<b>Component ID</b>	<b>Description</b>	<b>MTBF</b>	<b>MTTR</b>	<b>Source</b>
X01	Pulse Jet Fabric Filter	122,640	10.0	AP-2071
X02	Pulse Jet Fabric Filter	122,640	10.0	AP-2071

### **LG&E/KU - Unit 2 Component Data**

<b>SYSTEM 2 BOOSTER FANS</b>				
<b>Component ID</b>	<b>Description</b>	<b>MTBF</b>	<b>MTTR</b>	<b>Source</b>
X01	Couplings 1	769,000	33.0	AP-2071
X02	Bearings 1	769,000	37.0	AP-2071
X03	Miscellaneous 1	769,000	34.0	AP-2071
X04	Vibrations 1	512,000	53.0	AP-2071
X05	Inlet Vanes 1	179,000	30.0	AP-2071
X06	Seal Rubs 1	769,000	21.0	AP-2071
X07	Motor 1	3,850,000	360.0	AP-2071
X08	Outlet Damper 1	1,000,000	24.0	AP-2071
X09	Couplings 2	769,000	33.0	AP-2071
X10	Bearings 2	769,000	37.0	AP-2071
X11	Miscellaneous 2	769,000	34.0	AP-2071
X12	Vibrations 2	512,000	53.0	AP-2071
X13	Inlet Vanes 2	179,000	30.0	AP-2071
X14	Seal Rubs 2	769,000	21.0	AP-2071
X15	Motor 2	3,850,000	360.0	AP-2071
X16	Outlet Damper 2	1,000,000	24.0	AP-2071
X17	Couplings 1	769,000	33.0	AP-2071
X18	Bearings 1	769,000	37.0	AP-2071
X19	Miscellaneous 1	769,000	34.0	AP-2071
X20	Vibrations 1	512,000	53.0	AP-2071
X21	Inlet Vanes 1	179,000	30.0	AP-2071
X22	Seal Rubs 1	769,000	21.0	AP-2071
X23	Motor 1	3,850,000	360.0	AP-2071
X24	Outlet Damper 1	1,000,000	24.0	AP-2071
X25	Couplings 2	769,000	33.0	AP-2071
X26	Bearings 2	769,000	37.0	AP-2071
X27	Miscellaneous 2	769,000	34.0	AP-2071
X28	Vibrations 2	512,000	53.0	AP-2071
X29	Inlet Vanes 2	179,000	30.0	AP-2071
X30	Seal Rubs 2	769,000	21.0	AP-2071
X31	Motor 2	3,850,000	360.0	AP-2071
X32	Outlet Damper 2	1,000,000	24.0	AP-2071

**LG&E/KU - Unit 2 Component Data**

<b>SYSTEM 3 SELECTIVE CATALYTIC REDUCTION</b>				
<b>Component ID</b>	<b>Description</b>	<b>MTBF</b>	<b>MTTR</b>	<b>Source</b>
X01	SCR	182,492	118.7	NERG GADS
X02	SCR	182,492	118.7	NERG GADS

**LG&E/KU - Unit 2 Component Data**

<b>SYSTEM 4 POWDER ACTIVATED CARBON INJECTION</b>				
<b>Component ID</b>	<b>Description</b>	<b>MTBF</b>	<b>MTTR</b>	<b>Source</b>
X01	Feeder Hopper 1	1,095,000	2,037	NERG GADS
X02	Eductor 1	46,105	11.0	NERG GADS
X03	Blowers 1	4,380,000	360.0	NERG GADS
X04	Feeder Hopper 2	1,095,000	2,037	NERG GADS
X05	Eductor 2	46,105	11.0	NERG GADS
X06	Blowers 2	4,380,000	360.0	NERG GADS
X07	Feeder Hopper 3	1,095,000	2,037	NERG GADS
X08	Eductor 3	46,105	11.0	NERG GADS
X09	Blowers 3	4,380,000	360.0	NERG GADS
X10	Silo 1	1,095,000	2037.0	NERG GADS
X11	Silo 2	1,095,000	2037.0	NERG GADS

**LG&E/KU - Unit 2 Component Data**

<b>SYSTEM 5 SORBENT INJECTION</b>				
<b>Component ID</b>	<b>Description</b>	<b>MTBF</b>	<b>MTTR</b>	<b>Source</b>
X01	Feeder Hopper 1	1,095,000	2,037	NERG GADS
X02	Eductor 1	46,105	11.0	NERG GADS
X03	Blowers 1	4,380,000	360.0	NERG GADS
X04	Feeder Hopper 2	1,095,000	2,037	NERG GADS
X05	Eductor 2	46,105	11.0	NERG GADS
X06	Blowers 2	4,380,000	360.0	NERG GADS
X07	Feeder Hopper 3	1,095,000	2,037	NERG GADS
X08	Eductor 3	46,105	11.0	NERG GADS
X09	Blowers 3	4,380,000	360.0	NERG GADS
X10	Silo 1	1,095,000	2037.0	NERG GADS
X11	Silo 2	1,095,000	2037.0	NERG GADS

**LG&E/KU - Unit 2 Component Data**

<b>SYSTEM 25 AQCS</b>				
<b>Component ID</b>	<b>Description</b>	<b>MTBF</b>	<b>MTTR</b>	<b>Source</b>
X01	Air Compressor 1	4,348	82.0	B&V Internal Database / Expert Opinion
X02	Air Compressor 2	4,348	82.0	B&V Internal Database / Expert Opinion

## **UNITS 3, 4**

### **LG&E/KU - Units 3, 4 Component Data**

<b>SYSTEM 1 PARTICULATE CONTROL</b>				
<b>Component ID</b>	<b>Description</b>	<b>MTBF</b>	<b>MTTR</b>	<b>Source</b>
X01	Pulse Jet Fabric Filter	122,640	10.0	AP-2071
X02	Pulse Jet Fabric Filter	122,640	10.0	AP-2071

### **LG&E/KU - Units 3, 4 Component Data**

<b>SYSTEM 2 INDUCED DRAFT FANS</b>				
<b>Component ID</b>	<b>Description</b>	<b>MTBF</b>	<b>MTTR</b>	<b>Source</b>
X01	Couplings 1	769,000	33.0	AP-2071
X02	Bearings 1	769,000	37.0	AP-2071
X03	Miscellaneous 1	769,000	34.0	AP-2071
X04	Vibrations 1	512,000	53.0	AP-2071
X05	Inlet Vanes 1	179,000	30.0	AP-2071
X06	Seal Rubs 1	769,000	21.0	AP-2071
X07	Motor 1	3,850,000	360.0	AP-2071
X08	Outlet Damper 1	1,000,000	24.0	AP-2071
X09	Couplings 2	769,000	33.0	AP-2071
X10	Bearings 2	769,000	37.0	AP-2071
X11	Miscellaneous 2	769,000	34.0	AP-2071
X12	Vibrations 2	512,000	53.0	AP-2071
X13	Inlet Vanes 2	179,000	30.0	AP-2071
X14	Seal Rubs 2	769,000	21.0	AP-2071
X15	Motor 2	3,850,000	360.0	AP-2071
X16	Outlet Damper 2	1,000,000	24.0	AP-2071
X17	Couplings 1	769,000	33.0	AP-2071
X18	Bearings 1	769,000	37.0	AP-2071
X19	Miscellaneous 1	769,000	34.0	AP-2071
X20	Vibrations 1	512,000	53.0	AP-2071
X21	Inlet Vanes 1	179,000	30.0	AP-2071
X22	Seal Rubs 1	769,000	21.0	AP-2071
X23	Motor 1	3,850,000	360.0	AP-2071
X24	Outlet Damper 1	1,000,000	24.0	AP-2071
X25	Couplings 2	769,000	33.0	AP-2071
X26	Bearings 2	769,000	37.0	AP-2071
X27	Miscellaneous 2	769,000	34.0	AP-2071
X28	Vibrations 2	512,000	53.0	AP-2071
X29	Inlet Vanes 2	179,000	30.0	AP-2071
X30	Seal Rubs 2	769,000	21.0	AP-2071
X31	Motor 2	3,850,000	360.0	AP-2071
X32	Outlet Damper 2	1,000,000	24.0	AP-2071

**LG&E/KU - Units 3, 4 Component Data**

SYSTEM 3 POWDER ACTIVATED CARBON INJECTION				
Component ID	Description	MTBF	MTTR	Source
X01	Feeder Hopper 1	1,095,000	2,037	NERG GADS
X02	Eductor 1	46,105	11.0	NERG GADS
X03	Blowers 1	4,380,000	360.0	NERG GADS
X04	Feeder Hopper 2	1,095,000	2,037	NERG GADS
X05	Eductor 2	46,105	11.0	NERG GADS
X06	Blowers 2	4,380,000	360.0	NERG GADS
X07	Feeder Hopper 3	1,095,000	2,037	NERG GADS
X08	Eductor 3	46,105	11.0	NERG GADS
X09	Blowers 3	4,380,000	360.0	NERG GADS
X10	Silo 1	1,095,000	2037.0	NERG GADS
X11	Silo 2	1,095,000	2037.0	NERG GADS

**LG&E/KU - Units 3, 4 Component Data**


SYSTEM 25 AQCS				
Component ID	Description	MTBF	MTTR	Source
X01	Air Compressor 1	4,348	82.0	B&V Internal Database / Expert Opinion
X02	Air Compressor 2	4,348	82.0	B&V Internal Database / Expert Opinion

**Appendix B  
Logic Diagrams**

DRAFT - CLIENT REVIEW


GE: Ghent 1  
Particulate Control (System 1)  
Thu, Feb 17, 2011

Page 1 of 1




E: Ghent 1  
Booster Fans (System 2)  
Thu, Feb 17, 2011

Page 1 of 1




E: Ghent 1  
Powder Activated Carbon (System 3)  
Thu, Feb 17, 2011

Page 1 of 1




LG&E: Ghent 1  
Availability (System 25)  
Thu, Feb 17, 2011

Page 1 of 1




XE: Ghent 2  
Particulate Control (System 1)  
Thu, Feb 17, 2011

Page 1 of 1




E: Ghent 2  
Booster Fans (System 2)  
Thu, Feb 17, 2011

Page 1 of 1




E: Ghent 2  
Selective Catalytic Reduction (System 3)  
Thu, Feb 17, 2011

Page 1 of 1




E: Ghent 2  
Powder Activated Carbon (System 4)  
Thu, Feb 17, 2011

Page 1 of 1




E: Ghent 2  
Sorbent (System 5)  
Thu, Feb 17, 2011

Page 1 of 1




LG&E: Ghent 2  
Availability (System 25)  
Thu, Feb 17, 2011

Page 1 of 1



GE: Ghent 3  
Particulate Control (System 1)  
Thu, Feb 17, 2011


Page 1 of 1



E: Ghent 3  
Induced Draft Fans (System 2)  
Thu, Feb 17, 2011




Page 1 of 1




E: Ghent 3  
Powder Activated Carbon (System 3)  
Thu, Feb 17, 2011

Page 1 of 1




LG&E: Ghent 3  
Availability (System 25)  
Thu, Feb 17, 2011

Page 1 of 1



E: Ghent 4  
Particulate Control (System 1)  
Thu, Feb 17, 2011


Page 1 of 1



E: Ghent 4  
Induced Draft Fans (System 2)  
Thu, Feb 17, 2011




Page 1 of 1



E: Ghent 4  
Powder Activated Carbon (System 3)  
Thu, Feb 17, 2011

Page 1 of 1



LG&E: Ghent 4  
Availability (System 25)  
Thu, Feb 17, 2011

Page 1 of 1

