

BRITE & HOPKINS, PLLC
ATTORNEYS AT LAW
83 BALLPARK ROAD, P.O. BOX 309
HARDINSBURG, KENTUCKY 40143-0309
PHONE (270) 756-2184, FAX (270) 756-1214

THOMAS C. BRITE
e-mail: tbrite@bbtel.com

STEPHEN G. HOPKINS
e-mail: shopkins@bbtel.com

February 4, 2013

RECEIVED
FEB 7 2013
PUBLIC SERVICE
COMMISSION

Mr. Jeff Derouen
Commonwealth of Kentucky
Public Service Commission
211 Sower Blvd.
PO Box 615
Frankfort, KY 40602-0615

RE: Case No. 2012-00310
Case No. 2012-00311
Case No. 2012-00312

Dear Mr. Derouen:

Since Meade County RECC reported to you in a status report dated January 17, 2013, Meade has continued to monitor the voltage flickering on the electric line recently installed in the Big Bend area.

A recent week of monitoring yielded basically the same results as reported in the January 17th status report. There were four to six events measured with only one above the 1% flicker level. Meade has reinstalled the recorders and will continue to monitor this line.

Respectfully submitted,



Thomas C. Brite
Attorney for Meade County RECC

TCB: bep

cc: Monica Jarboe
7055 Big Bend Road
Battletown, KY 40104

cc: David Bell
5615 Big Bend Road
Battletown, KY 40104

cc: Steven Miles
6750 Big Bend Road
Battletown, KY 40104

cc: Burns E. Mercer, President/CEO
Meade County RECC
PO Box 489
Brandenburg, KY 40108